

Davis-BesseNPEm Resource

From: CuadradoDeJesus, Samuel
Sent: Friday, September 02, 2011 11:46 AM
To: custerc@firstenergycorp.com
Cc: Davis-BesseHearingFile Resource
Subject: RE: RAI responses
Attachments: image001.gif

Cliff:

Yes, I got your voicemail. Unfortunately I was on training the whole week and couldn't be as responsive as I like to be. We'll discuss the disposition of the remaining RAIs next week.

Thanks

From: custerc@firstenergycorp.com [<mailto:custerc@firstenergycorp.com>]
Sent: Thursday, September 01, 2011 4:39 PM
To: CuadradoDeJesus, Samuel
Cc: dorts@firstenergycorp.com; kmnesser@firstenergycorp.com
Subject: RAI responses

Sam,
I left you a voice mail yesterday. The RAI responses planned for this week have been delayed. The following responses will be provided on or before 9/09:

RAI	Source	FENOC Letter No.
B.2.32-1 PWR vessel internals AMP	R-11-190	L-11-252
B.2.32-2 AlloyX-750 heat treatment	R-11-190	L-11-252
B.2.32-3 Internals fracture toughness	R-11-190	L-11-252
3.1.2.2-3 RVI component management	R-11-190	L-11-252
B.2.22-5 Sand pocket mgmt	R-11-197	L-11-252
B.2.39-9 Refuel canal leakage mgmt	R-11-197	L-11-252
B.2.34-2 Head stud strength & cracking	R-11-224	L-11-252
3.1.2.2-3 RVI component management	R-11-224	L-11-252
Supp Resp - 3.2.2.2.3.6-2 Air-water interface	Telecon 8/22	L-11-252
Supp Resp - B.2.9 additional detail	Telecon 8/30	L-11-252

I am out of the office tomorrow, but will be back at the BVPS office on Tuesday (724) 682-7139. We need to discuss disposition of any remaining RAI's next week.

Cliff Custer
FENOC Project Manager
License Renewal
Work: (724) 682-7139

BPR: (412) 305-4981 ----- The information contained in this message is intended only for the personal and confidential use of the recipient(s) named above. If the reader of this message is not the intended recipient or an agent responsible for delivering it to the intended recipient, you are hereby notified that you have received this document in error and that any review, dissemination, distribution, or copying of this message is strictly prohibited. If you have received this communication in error, please notify us immediately, and delete the original message.

Hearing Identifier: Davis_BesseLicenseRenewal_Saf_NonPublic
Email Number: 1367

Mail Envelope Properties (377CB97DD54F0F4FAAC7E9FD88BCA6D0804F9AA1E0)

Subject: RE: RAI responses
Sent Date: 9/2/2011 11:45:58 AM
Received Date: 9/2/2011 11:45:59 AM
From: CuadradoDeJesus, Samuel

Created By: Samuel.CuadradoDeJesus@nrc.gov

Recipients:

"Davis-BesseHearingFile Resource" <Davis-BesseHearingFile.Resource@nrc.gov>
Tracking Status: None
"custer@firstenergycorp.com" <custer@firstenergycorp.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	1496	9/2/2011 11:45:59 AM
image001.gif	10731	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

RAI	Source	FENOC Letter No.
B.2.32-1 PWR vessel internals AMP	R-11-190	L-11-252
B.2.32-2 Alloy X-750 heat treatment	R-11-190	L-11-252
B.2.32-3 Internals fracture toughness	R-11-190	L-11-252
3.1.2.2-3 RVI component management	R-11-190	L-11-252
B.2.22-5 Sand pocket mgmt	R-11-197	L-11-252
B.2.39-9 Refuel canal leakage mgmt	R-11-197	L-11-252
B.2.34-2 Head stud strength & cracking	R-11-224	L-11-252
3.1.2.2-3 RVI component management	R-11-224	L-11-252
Supp Resp - 3.2.2.2.3.6-2 Air-water interface	Telecon 8/22	L-11-252
Supp Resp - B.2.9 additional detail	Telecon 8/30	L-11-252