

50-263

RESPONSE TO NRC BULLETIN 87-01

w/ltr 9-9-87 #8803160302

— NOTICE —

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE DIVISION OF DOCUMENT CONTROL. THEY HAVE BEEN CHARGED TO YOU FOR A LIMITED TIME PERIOD AND MUST BE RETURNED TO THE RECORDS FACILITY BRANCH 016. PLEASE DO NOT SEND DOCUMENTS CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST BE REFERRED TO FILE PERSONNEL.

DEADLINE RETURN DATE _____

RECORDS FACILITY BRANCH

UNITED STATES NUCLEAR REGULATORY COMMISSION

NORTHERN STATES POWER COMPANY

MONTICELLO NUCLEAR GENERATING PLANT

Docket No. 50-263

RESPONSE TO NRC BULLETIN 87-01

Northern States Power Company, a Minnesota corporation, by this letter dated September 9, 1987 hereby submits information required by NRC Bulletin 87-01 for the Monticello Nuclear Generating Plant.


This letter contains no restricted or other defense information.

NORTHERN STATES POWER COMPANY


By C E Larson
C E Larson
Vice President, Nuclear Generation

On this 9th day of September, 1987 before me a notary public in and for said County, personally appeared C E Larson, Vice President, Nuclear Generation, and being first duly sworn acknowledged that he is authorized to execute this document on behalf of Northern States Power Company, that he knows the contents thereof and that to the best of his knowledge, information and belief, the statements made in it are true and that it is not interposed for delay.


Judy L. Klapperick



MONTICELLO THICKNESS MEASUREMENTS AND
CHEC CALCULATIONS



● — MANWAY



H.P. TURBINE TO D' MOIST. SEP.
36" CROSSUNDER PIPING COPPER BEARING STEEL NOMINAL .500 MIN. .325

Crossover to MS-D

ES"

Area	Scaffold Reg'd.	Frequency	Line = (Ultra Image) file
1.0A	yes		61
1.1A	yes		60
1.2A	yes		59
1.3A (DS)	yes	"Downstream"	58
1.0A (DS)	yes		61
1.0A1/DS	yes		65
1.0A2/DS	Yes		65
1.0A3/DS	Yes		65
1.2B IPS	Yes		67
between 1.2B and 1.2C	Yes		Nortec
1.2C IS	Yes		68
1.2D (DS)	Yes	"Upstream"	69
1.3A S.S	Yes		Nortec

ISO-MTS-1

1924

Area 1.1A had UT Indications from 310° to 330°
Visual Inspection found no Erosion/Corrosion
damage.

Thickness Survey

Date 6-21-84
Disc 61

Plant Marticella

Iso # MTS-1

Area 1-0A/05/0-10

Grid Spacing 200

Examiner(s) ASW/OAH

Equipment Used UT III

Calibration Block: Type 3080-P3 Serial Number N/A

Transducer: Size 1/2" dia. Frequency 3.5 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.524	.504	.496	.500	.524	.563	.500	.545	.548	.504	.496	.496
2	.504	.512	.492	.499	.512	.573	.499	.550	.512	.500	.492	.492
3	.512	.508	.500	.496	.508	.560	.514	.547	.528	.528	.500	.504
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

THICKNESS SURVEY REPORT

DATE 5-9-86

DISC# 61

MT MONTICELLO

ISO# MTS-1

1.0 A

GRID SIZE 200

MINERS *Stan W. ...*

EQUIPMENT ULTRA IMAGE III

INDUCER (SIZE/FREQ.) .25" / 10 MHz.

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

MIN. WALL .500"

MIN. WALL .325"

POINTS REF. 0°-120° IS 1 1/2" CCW OF C OF L.S. REF 240°-0° IS 3 3/4" CCW OF C OF L.S.

0° C OF X-DIXER IS 17 1/4" FROM EDGE OF FLANGE. (REFERENCES REFER TO STARTING POINT OF GRID)

PLEASE INDICATE EDGE TO LIFT-OFF FROM L.S.

X degree	0	30	60	86	129	172	150	180	210	240	270	300	330	121
ridge	0	30	60	86	129	172	150	180	210	240	270	300	330	121
10	.540	.528	.520	.520	.528	.544	—	—	—	.544	.536	.524	.524	
110	.536	.528	.520	.520	.524	.544	—	—	—	.544	.536	.524	.524	
120	.540	.528	.520	.520	.528	.544	—	—	—	.624	.536	.520	.524	
130	.544	.528	.520	.520	.528	.540	—	—	—	—	.540	.536	.528	
140	.544	.536	.524	.524	.528	.528	—	—	—	.548	.532	.524	.528	
150	.540	.536	.524	.524	.524	.536	—	—	—	.540	.528	.520	.528	
7														
8														
9														
10														
11														
12														
13														
14														
15														
16														
17														
18														
19														
20														
21														

LOWEST AREA IS .516"
0°-120° X-77, Y-30

Thickness Survey

Date 7-6-84
Disc 65

Plant Monticello

Iso # MTS-1

Area LOA3 / DS 10-10"

Grid Spacing 180

Examiner(s) ASW/KLH/NAM

Equipment Used UI-III

Calibration Block: Type 3050-83 Serial Number N/A

Transducer: Size .5" Frequency 3.5 MHz PC

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.516	.500	.500	.576						.536	.500	.504
2	.516	.504	.516	.532						.528	.516	.504
3	.540	.496	.496	.512						.528	.504	.500
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Thickness Survey

Date 7-6-84
Disc 85

Plant MONTICELLO

Iso # MTS-1

Area 1.0A2 / DS 10-10"

Grid Spacing 190

Examiner(s) ASW / KKH / NAM

Equipment Used UI-III

Calibration Block: Type 7090-83 Serial Number N/A

Transducer: Size .5" Frequency 3.5 MHz P.C.

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.528	.504	.512	.592						.532	.516	.548
2	.524	.504	<u>.500</u>	.516						.556	.524	.516
3	.524	.516	.552	.532						.524	.508	.504
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Thickness Survey

Date: 7-6-84

Disc 65

Plant Monticello

Iso # MTS-1

Area LOA1/DS 10-10"

Grid Spacing 180

Examiner(s) ASW/KLH/INAM

Equipment Used UI-III

Calibration Block: Type 3080.82 Serial Number N/A

Transducer: Size .5" Frequency 3.5 mhz P.C

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.528	.516	.508	.558						.640	.528	.504
2	.528	.516	.516	.536	None					.536	.528	.512
3	.532	.508	.512	.532						.536	.518	.508
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Thickness Survey

Date 6-21-84
Disc 60

Plant Monticello

Iso # MTS-1

Area 11A/45/0-10"

Grid Spacing 200

Examiner(s) ASW/DAH/KLH/RL

Equipment Used UI-III

Calibration Block: Type 3090-83 Serial Number N/A

Transducer: Size 1/2" dia Frequency 7.5 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.500	.512	.504	.500	.496	.536	.532	(480) .492	.492	.500	.532	.504
2	.492	.492	.544	.552	.584	.492	.496	.508	.536	.504	.488	.512
3	.552	.500	.520	.552	.552	.532	.520	.524	.520	.504	.512	.508
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Min. reading
480

d.i.d


Comments:

1.1A 270° to 0° MTS.-1 ISO # 60

350°

330°

310°



THICKNESS SURVEY REPORT

DATE 5-8-86

DISC# 60

MONTICELLO

ISO# MTS-1

REA 1.1A US

GRID SIZE 200

XAMINERS A.S. WEALDON III / A.W. VOSS I / S.L. HALL I

EQUIPMENT ULTRA IMAGE III

TRANSDUCER (SIZE/FREQ.) .25" / 10 MHz

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

NOMINAL WALL .500"

MIN. WALL .325"

COMMENTS

X degree	0	30	60	90	120	150	180	210	240	270	300	330	108
10	.516	.516	.516	.516	.524	.516	.536	.516	.524	.516	.524	.516	.516
20	.520	.524	.528	.524	.528	.552	.524	.528	.524	.544	.524	.548	.548
30	.496	.544	.500	.568	.564	.540	.524	.528	.512	.508	.524	.516	.516
40	.532	.532	.544	.536	.576	.540	.552	.544	.552	.552	.560	.528	.528
50	.552	.524	.524	.536	.552	.544	.528	.540	.540	.552	.544	.536	.536
60	.556	.540	.524	.536	—	—	.536	.540	.508	.548	.544	.528	.528
7													
8													
9													
10													
11													
12													
13													
14													
15													
16													
17													
18													
19													
20													
21													

LOWEST AREA IS .484"

0°-90° X-17, Y-18

NOTE: (90°-180°) LAMINATION X-87 Y-3
GROOVE IN OD Y-15 & Y-22.

Thickness Survey

Date 6-20-84
Disc 59

Plant Monticello

Iso # MTS-1

Area 1.2A/05/0-10"

Grid Spacing 200

Examiner(s) ASW/DAH/QL/KLH

Equipment Used UI III

Calibration Block: Type 3080-83 Serial Number N/A

Transducer: Size 1/2" Frequency 5MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.476	.496	^{.492} .520	.520	.480	.504	.492	.476	.480	.476	.480	.476
2	.476	.488	.492	.500	.484	.484	.480	.492	.480	.492	.476	.484
3	.492	.504	.512	.508	.496	.504	.480	.480	.496	.476	<u>.472</u>	<u>.472</u>
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

d.d
M1-JKI

Comments:

THICKNESS SURVEY REPORT

DATE 5/9/86

DISC# 59

NT MONTICELLO

ISO# MTS-1

A 1.2A

GRID SIZE 200

MINERS DAN SELLS / STEVE ALGER / RAY WOLF

EQUIPMENT U I III

PRODUCER (SIZE/FREQ.) .25/16MHZ.

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 308089

MIN. WALL .5"

MIN. WALL N.Y. 288 MAX.

REMARKS DELAYS ARE OFF DUE TO 84% PRODUCER 86% PRODUCER

53x COUNTS = 30°

degree	grid	0	30	60	90	120	150	180	210	240	270	300	330
8	53	106	159	106	156	53	106	53	106	53	106	53	106
10	488	496	500	508	508	508	508	508	512	500	512	508	496
20	520	500	500	508	508	512	508	508	512	516	512	500	500
30	496	496	500	512	508	508	508	508	512	508	512	512	496
40	492	496	500	512	508	508	512	508	512	508	512	508	496
50	508	500	500	508	508	508	508	508	512	508	508	512	492
6													
7													
8													
9													
10													
11													
12													
13													
14													
15													
16													
17													
18													
19													
20													
21													

THINNEST SPOT .488"
(FILE 5)
X=8
Y=10
Z=14°

THINNEST AREA
FILE 5 0° - 22°

Thickness Survey

Date 6-25-84

Disc 58

Plant Monticello

Iso # MTS-1

Area 1.3A 10S 10-10" T.S.

Grid Spacing 200

Examiner(s) HSW/KCH/AL

Equipment Used UI-III

Calibration Block: Type 3080-83 Serial Number N/A

Transducer: Size 1/2" Frequency 3.5MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.492	.520	.536	.496	.508	.500	.500	.492				.500
2	.496	.504	.492	<u>.484</u>	.492	.504	.504	.492	MANWAY			.496
3	.492	.492	.496	<u>.484</u>	<u>.484</u>	.496	.500	.500				.492
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Thickness Survey

Date 06-26-84
Disc NA

Plant Monticello

Iso # MTS-1

Area 1.3 A S.S.

Grid Spacing 4"

Examiner(s) ASW/QL/KLH

Equipment Used Nortec 131-D

Calibration Block: Type 3080-83 Serial Number 269

Transducer: Size .25" Dia Frequency 5 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.519	.513	.517	.519	.547	.530	.527	.524	<div style="display: flex; align-items: center; justify-content: center;"> <div style="writing-mode: vertical-rl; transform: rotate(180deg); font-weight: bold; margin-right: 10px;">MAINWAY</div> </div>			
2	.522	.520	.520	.518	.517	.522	.523	.522				
3	.523	.519	.523	.516	.520	.529	.525	.526				
4	.523	.527	.526	.522	.520	.547	.525	.523				
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

THICKNESS SURVEY REPORT

DATE 5-17-86

DISC# 58

H. MONTICELLO

ISO# MTS-1

A. 1.3A

GRID SIZE 200

MINERS STEVENS FORD II / A.W. BOSS I / S.G. HALL I

EQUIPMENT ULTRA IMAGE III

TRANSDUCER (SIZE/FREQ.) .25" / 10 MHz.

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

MIN. WALL .500"

MIN. WALL .325"

REMARKS MAINWAY RESTRICTS SCAN. 240-330°

PULS LIKE SPATER LOW SEAMS.

X degree	54		30		168		50		100		150		51		102		13		O
	0	.528	.528	.524	.528	.524	.532	.528	.528	.524	.524	.532	.528	.528	.528	.528	.528	.528	
10	.528	.528	.524	.528	.528	.524	.532	.528	.528	.524	.524	.532	.528	.528	.528	.528	.528	.528	.536
20	.536	.528	.524	.528	.528	.524	.528	.528	.524	.524	.524	.532	.528	.528	.528	.528	.528	.528	.532
30	.528	.528	.524	.528	.528	.524	.528	.528	.528	.524	.532	.528	.528	.528	.528	.528	.528	.528	.528
40	.528	.528	.528	.528	.528	.524	.528	.528	.528	.524	.528	.528	.528	.528	.528	.528	.528	.528	.528
50	.528	.528	.524	.528	.528	.524	.528	.528	.524	.524	.528	.528	.528	.528	.528	.528	.528	.528	.528
7																			
8																			
9																			
10																			
11																			
12																			
13																			
14																			
15																			
16																			
17																			
18																			
19																			
20																			
21																			

LOWEST AREA .464

380°-60° 56X, 33Y

Thickness Survey

Date 7-30-84

Disc 67

Plant MONTICELLO

Iso # MTS-1

Area L2-B IPS 10-10

Grid Spacing 200

Examiner(s) ASW-KLH-JEB

Equipment Used UI III

Calibration Block: Type 3080-83

Serial Number N/A

Transducer: size 1/2" ϕ

Frequency 3.5 MHz P.C.

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.532	.528	.536	.532	.544	<u>.480</u>	.540	.536	.500	.508	.540	.540
2	.552	.532	.532	.532	.536	.532	.488	.524	.528	.536	.544	.504
3	.544	.532	.536	.544	.532	.544	.540	.532	.524	.536	.544	.552
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

P.P.

Comments:

THICKNESS SURVEY REPORT

DATE 5-21-86

DISC# 67

LOCATION MONTICELLO

ISO# MTS-1

EA 1.5A DS

GRID SIZE 200

MINERALS STEVE STANFORD II / A.W. VOSS / S.G. HALL

EQUIPMENT ULTRA IMAGE III

TRANSDUCER (SIZE/FREQ.) .25" / 10 MHz.

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

MIN. WALL .375"

MIN. WALL .325"

REMARKS _____

X Degree	Y Degree	Grid	0	30	60	90	120	150	180	210	240	270	300	330	1000
1	0		.524	.516	.528	.552	.528	.528	.528	.508	.528	.476	.536	.524	
2	10		.528	.524	.528	.528	.528	.508	.476	.500	.496	.532	.512	.532	
3	20		.532	.528	.528	.532	.528	.504	.464	.468	.492	.532	.516	.528	
4	30		.532	.524	.528	.528	.528	.496	.528	.524	.516	.480	.528	.528	
5	40		.532	.528	.528	.528	.528	.528	.524	.528	.520	.520	.544	.536	
6	50						.524	.536	.528	.528	.476	.476	.500	.520	
7															
8															
9															
10															
11															
12															
13															
14															
15															
16															
17															
18															
19															
20															
21															

LOWEST AREA IS .460" -
180° 270° X-B, Y-17

Thickness Survey

Date 07-30-84
Disc 68

Plant Monticello

Iso # MTS-1

Area 1.64 AC
7DS 10-10

Grid Spacing 200

Examiner(s) ASW/KLH/JEB

Equipment Used UI-III

Calibration Block: Type 3080-83

Serial Number NA

Transducer: Size 1/2" Dia.

Frequency 3.5 MHz P.C.

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.552	.532	.536	.540	.536	.536	.544	.536	.564	.544	.552	.564
2	<u>.516</u>	.556	.532	.584	.532	.532	.540	.540	.540	.564	.540	.552
3	.560	.540	.536	.556	.528	.532	.556	.556	.568	.564	.540	.544
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

THICKNESS SURVEY REPORT

DATE 5/16/86

DISC# 68

MONTICELLO

ISO# MTS-1

EA 1.6 A (1.2C) DOWNSTREAM

GRID SIZE 200

AMINERS Tom S. M. T. H. G. I

EQUIPMENT U I III

AMSDUCER (SIZE/FREQ.) .25 10 MHz

CAL. BLOCK (TYPE/SERIAL NO.) STEPWEDGE 3080-83

MIN. WALL .500

MIN. WALL MIN. 300 MAX. 824

MENTS

degree	0	30	60	90	120	150	180	240	270	300	330
1	476	512	508	508	504	504	524	528	528	540	564
2	488	508	508	508	512	528	544	524	536	536	536
3	488	508	508	504	500	504	516	520	544	528	532
4	488	508	504	512	516	552	528	520	536	532	532
5	356	380	528	528	504	504	528	524	—	524	524
6	558				536	528	400				
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											

THINNEST AREA 2-5

X 2
Y 1
D .468

Thickness Survey

Date 7-30-84
Disc 69

Plant Monticello
Area 1.7A-RIC
L20/US 10-10

Iso # MTS-1
Grid Spacing 200

Examiner(s) ASW/KLH/JEB

Equipment Used UT-III

Calibration Block: Type 3080-83 Serial Number N/A

Transducer: Size 1/2" dia Frequency 3.5MHz P-C

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.620	.528	.528	.628	.572	.556	.536	.532	.536	.544	.560	.576
2	.580	.536	.532	.532	.528	.596	.564	.568	.596	.536	.536	.540
3	.524	.592	.576	.584	.532	.556	.560	.566	.572	.532	.540	.536
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

THICKNESS SURVEY REPORT

DATE 5-17-86

DISC# 69

MONTICELLO

ISO# HTS-1

AREA 1.7 A US

GRID SIZE 200

EXAMINERS STEVE STANFORD II / A.W. VOSSI / SLOTT HALL

EQUIPMENT ULTRA IMAGE III

TRANSDUCER (SIZE/FREQ.) .25" / 10 MHz

CAL. BLOCK (TYPE/SERIAL NO.) STEPWEDGE 3080-83

NOMINAL WALL .500"

MIN. WALL .325"

COMMENTS LONG SEAMS & SPATTER

X Degree	C	0	30	60	90	120	150	180	210	240	270	300	330	108
10	.776	—	.524	.528	—	.532	.532	—	.536	.536	.528	.552	.516	
20	—	—	.528	.524	.536	.532	.536	.768	.548	.548	.532	.528	.536	
30	.772	—	.528	.528	.532	.532	.548	—	.536	.536	.532	.544	.552	
40	.832	—	.532	.528	.528	.532	.528	—	.544	.536	.532	.540	.548	
50	.804	—	.536	.532	.516	.528	.532	.756	.532	.528	.540	.552	.560	
60	—	—	.552	.544	.528	.524	.528	.756	—	.528	.536	.544	.552	
7														
8														
9														
10														
11														
12														
13														
14														
15														
16														
17														
18														
19														
20														
21														


LOWEST AREA .472"
270°-0° X-87 / Y-2

NOTES
ISO-MTS-2

Crossover to MSC

36"


Area	scaffold Req'd.	Frequency	Disc #
1.4A US	yes		64
T.5A	yes		45
T.6A	yes		46
1.4A DS,	yes		64



X — HANGER
● — MANWAY

DMONTS (NN)
For CHECK REF.

HIGH PRESS. TURBINE



C. MOISTURE SEP.

HP TO C MOISTURE SEP
36" CROSSUNDER PIPING
COPPER BEARING STEEL
NOMINAL .500
MIN. .325

ISO-MTS-2

Plant Monticello
Area 1.4A/45/0-10
Examiner(s) DAH/KLH/AL
Calibration Block: Type 3080-83
Transducer: Size 1/2"

Iso # MTS-2
Grid Spacing 180
Equipment Used UT III
Serial Number N/A
Frequency 5MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.652	.680	.672	.668	.668	.672	.688	.664	.668	.692	.668	.668
2	.660	.696	.672	.668	.668	.672	.688	.664	.672	.700	.688	.688
3	.656	.680	.676	.668	.680	.672	.692	.688	.696	.688	.680	.676
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

dd

Comments:

Date 6-28-84

Plant Monticello

Iso # MTS-2

Area 1.4A/D.S./0-10

Grid Spacing 180

Examiner(s) DAH/KLH/RL

Equipment Used UI III

Calibration Block: Type 3080-F3 Serial Number N/A

Transducer: Size 1/2" Frequency 5MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.660	.684	.696	.736	.672	.680	.672	.664	.668	.668	.668	.680
2	.656	.684	.688	.672	.676	.676	.680	.664	.664	.664	.668	.672
3	(.644)	.692	.680	.676	.664	.664	.672	.660	.660	.680	.672	.692
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

did

Plant Monticello

Iso # MYS-2

Date 11-27-67

Area T-6A/US/O-10

Grid Spacing 4"

Examiner(s) ASW-OAH-QL-KLH

Equipment Used 4I-III

Calibration Block: Type Step Block 3080P Serial Number N/A

Transducer: Size 1/2" dia PC Frequency 5MHZ

	0°	30°	60°	90°	120°	150°	210°	240°	270°	300°	330°
1	.472"	.484"	.480"	.468"	.476"	.472"	.476"	.468"	.476"	.472"	.472"
2	.468"	.484"	.480"	.460"	.476"	.476"	.468"	.472"	.472"	.464"	.456"
3	.472"	.500"	.484"	.440"	.484"	.468"	.468"	.468"	.480"	.472"	.476"
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											

did

THICKNESS SURVEY REPORT

DATE 5-16-86

DISC# 46

LOCATION MONTICELLO

ISO# MTS-2

AREA T.6A D.S.

GRID SIZE 180

EXAMINERS STEVE STANFORD II / BILL VOSSI / SCOTT WALLI

EQUIPMENT ULTRA IMAGE III

TRANSDUCER (SIZE/FREQ.) .25" / 10 MHz.

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

NOMINAL WALL .500"


MIN. WALL .325"

COMMENTS LONG SEAM

X Degree	0		30		60		90		120		150		180		210		240		270		300		330		360		
	0	30	0	30	0	30	0	30	0	30	0	30	0	30	0	30	0	30	0	30	0	30	0	30	0	30	
0	.520	.520	.524	.524	.524	.524	.524	.524	.520	.520	.524	.524	.524	.524	.536	.552	.532	.532	.524	.524	.524	.524	.524	.532	.532	.528	.528
10	.524	.516	.524	.524	.524	.524	.524	.524	.516	.516	.524	.524	.524	.544	.548	.548	.536	.536	.524	.524	.524	.524	.520	.520	.528	.528	.528
20	.524	.520	.524	.524	.524	.524	.524	.524	.524	.524	.524	.524	.524	.548	.548	.548	.536	.536	.524	.524	.524	.524	.520	.520	.528	.528	.528
30	.520	.516	.524	.524	.524	.524	.524	.524	.520	.520	.524	.524	.524	.548	.548	.548	.536	.536	.524	.524	.524	.524	.520	.520	.528	.528	.528
40	.516	.524	.524	.524	.524	.524	.524	.524	.528	.528	.524	.524	.524	.560	.560	.560	.560	.560	.524	.524	.524	.524	.524	.524	.528	.528	.528
50	.520	.524	.524	.524	.524	.524	.524	.524	.532	.532	.524	.524	.524	.568	.568	.568	.568	.568	.524	.524	.524	.524	.524	.524	.528	.528	.524
7																											
8																											
9																											
10																											
11																											
12																											
13																											
14																											
15																											
16																											
17																											
18																											
19																											
20																											
21																											


LOWEST AREAS 404"
90°-180° X-29, Y-53

SIF



MANWAY

HIGH PRESS.
TURBINE



1.3 'B' MOISTURE SEP

EL. 937'0"

6TH STG. STM TO HTR.
15B

H.P. TO 'B' MOIST
URE SEP
36" CROSSUNDER PIPING
COPPER BEARING STEEL
NOMINAL .500
MIN. .325

ISO-MTS-3

Crossover to MS-B

Area	scaffold Req'd.	Frequency	Disc #
1.0	yes		43
1.01	yes		42
1.02	yes		30
1.3 U.S.	yes		47
1.3 D.S.	yes		47

Plant Monticello

Iso # MTS-3

Area 11/US/W-10

Grid Spacing 180

Examiner(s) A.S.W./KLM/Q.L.

Equipment Used U.I. III

Calibration Block: Type 3080-83 Serial Number NA

Transducer: Size 1/2" dia. Frequency 5MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.520	.540	.532	.540	.500	.496	.500	.508	.504	.504	.520	.604
2	.524	.524	.536	.528	.580	.608	.608	.536	.536	.528	.532	.536
3	.580	.500	.508	.520	.524	.528	.520	.512	.528	.524	.508	.524
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

DATE 5-24-86

DISC# 47

MONTICELLO

ISO# MTS-3

1.3 DS

GRID SIZE 180

OWNERS STEVE STANFORD II / A.W. BOSSI / SCOTT HALL I

EQUIPMENT ULTRA IMAGE III

TRANSDUCER (SIZE/FREQ.) .25" / 10 MHz.

CAL. BLOCK (TYPE/SERIAL NO.) SERJENGE 3080-83

NOMINAL WALL .500"

MIN. WALL .325"

COMMENTS NO 240-330 SCAN DUE TO MAINWAY

SCAN 7" ϕ OF X-DIE TO ϕ OF VENT

X Degree	Y Grid	122	183	60	120	180	41	87	23	240	270	300	330	0
0	0	.512	.520	.516	.504	.520	.516	.516	.520	.524	—	—	.516	
	10	.504	.524	.516	.512	.516	.520	.524	.524	.524	—	—	.528	
	20	.524	.524	.516	.512	.520	.520	.520	.532	.532	—	—	.528	
	30	.528	.520	.524	.516	—	.516	.524	.528	.528	—	—	.540	
	40	.528	.520	.520	.540	.520	.528	.520	.516	.516	—	—	.524	
	50	.532	.520	.500	.512	.520	.520	.524	.544	.544	—	—	.528	
	7													
	8													
	9													
	10													
	11													
	12													
	13													
	14													
	15													
	16													
	17													
	18													
	19													
	20													
	21													

LOWEST AREA - .440"
@ 338-60° X-36, Y-3

THICKNESS SURVEY REPORT

DATE 5-24-86

DISC# 47

MONTICELLO

ISO# MTS-3

1.3 US

GRID SIZE 200

EXAMINERS STEVE STANFORD II / AW. VOSSI / S.G. HALL I

EQUIPMENT ULTRA IMAGE III

TRANSDUCER (SIZE/FREQ.) .25" / 10 MHz.

CAL. BLOCK (TYPE/SERIAL NO.) STEPWEDGE 3080-83

NOMINAL WALL .500"


MIN. WALL .325"

COMMENTS No 240-330° SAW DUE TO HANWAY

SCAN IS 39 1/2" FROM C OF X-DICER TO C OF JENT

X Degree Grid	12		68		126		189		45		210		240		330
	0	30	60	90	120	150	180	210	240	270	300	330			
1 0	.496	.516	.516	.512	.512	.520	.516	.528	.520	.520	.528	.520	.520	.516	
1 10	.520	.516	.516	.500	.520	.520	.524	.544	.524	.524	.544	.524	.524	.520	
1 20	.516	.520	.512	.516	.520	.520	.528	.528	.516	.528	.528	.516	.524	.524	
1 30	.512	.520	.520	.500	.512	.516	.532	.524	.532	.532	.524	.532	.524	.520	
1 40	.520	.520	.520	.520	.524	.524	.524	.524	.524	.524	.524	.524	.524	.528	
1 50	.516	.520	.524	.524	.516	.528	.520	.520	.520	.520	.520	.520	.520	.532	
7															
8															
9															
10															
11															
12															
13															
14															
15															
16															
17															
18															
19															
20															
21															

LOWEST AREA IS .496"
60-150° X-44, Y-20



Notes
ISO-MTS-4

Crossander to MS-A

36"

Area	scaffold Reg'd.	Frequency	Disc #
1.4DS	yes		52
T.5DS	yes		48
T.6	yes		49
T.7	yes		50
1.4US	yes		52
T.5US	yes		48

THICKNESS SURVEY REPORT

DATE 5-13-86

DISC# 48.B

MONTICELLO

ISO# MTS-4

AREA T.5 U.S.

GRID SIZE 180

EXAMINERS Stephen W. Starnes / A.W. Voss II / Scott Hall I

EQUIPMENT ULTRA IMAGE III

TRANSDUCER (SIZE/FREQ.) .25" / 10 MHz

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

NOMINAL WALL .500"

MIN. WALL .271"

COMMENTS

X Degree / Grid	0	30	60	90	120	180	516	112	168	EA 210	B 240	O 270	ES 300	110 330
10	.512	.512	.516	.520	.516	.524	.516	.524	.520	.516	.524	.524	.524	.520
110	.512	.516	.516	.512	.520	.544	.516	.544	.584	.516	.516	.524	.516	.520
120	.512	.516	.516	.504	.516	.504	.516	.520	.524	.512	.516	.520	.516	.520
130	.512	.516	.512	.504	.512	.504	.512	.516	.524	.512	.516	.520	.520	.516
140	.516	.516	.516	.504	.520	.504	.520	.516	.524	.512	.512	.520	.520	.516
150	.512	.512	.512	.512	.512	.512	.512	.524	—	.512	.512	.520	.516	.520
7														
8														
9														
10														
11														
12														
13														
14														
15														
16														
17														
18														
19														
20														
21														

LOWEST AREA - .500"
90°-180° - X-13, Y-13 AREA

THICKNESS SURVEY REPORT

DATE 5-13-86

DISC# 48.A

MONTICELLO

ISO# MTS-4

T.S. D.S.

GRID SIZE 180

EXAMINERS Spencer W. Stanger / Al. Jossz / Scott Hall

EQUIPMENT ULTRA IMAGE III

TRANSDUCER (SIZE/FREQ.) .25" / 10 MHz.

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

NOMINAL WALL .500"

MIN. WALL .271"

COMMENTS

X Degree	Grid	63 30	126 60	189 90	55 120	110 150	165 180	240 240	171 270	54 300	108 330
10	.512	—	—	.516	.516	.520	.524	.532	.540	.516	.516
110	.516	.516	.516	.528	.528	.524	.524	.528	.540	.524	.528
120	.516	.528	.528	.520	.524	.540	.532	.540	.532	.536	.528
130	.500	.528	.520	.552	.524	.556	.520	.528	.524	.528	.532
140	.500	.524	.516	.516	.520	.520	.528	.532	.516	.536	.524
150	.516	.524	.524	.512	.524	.524	.524	.524	.512	.528	.528
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											

LOWEST AREA .476"
270°-0° X-4, Y-57

THICKNESS SURVEY REPORT

DATE 5-13-86

DISC# 49

MONTICELLO

T.6

ISO# MTS-4

GRID SIZE 180

EXAMINERS DANSELL J. S. ALGER I R. WOLF I

EQUIPMENT O.I. III

TRANSDUCER (SIZE/FREQ.) .25/10 MHz.

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

NOMINAL WALL .500"


MIN. WALL .271"

COMMENTS _____

X Degree	64		128		192		63		124		189		28		192		64		126	
	Y 0	30	60	90	120	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570
0	.512	.508	.508	.508	.512	.516	.532	.532	.516	.524	.532	.532	.516	.524	.524	.524	.516	.516	.516	.516
10	.528	.524	.516	.512	.508	.524	.524	.524	.528	.524	.524	.524	.524	.528	.528	.528	.516	.516	.516	.516
20	.524	.524	.512	.516	.508	.524	.524	.524	.524	.524	.524	.524	.524	.524	.524	.524	.516	.516	.516	.516
30	.532	.512	.516	.516	.508	.516	.524	.524	.532	.524	.524	.524	.532	.524	.524	.524	.516	.516	.516	.512
40	.524	.516	.516	.516	.516	.524	.524	.516	.524	.524	.524	.524	.524	.524	.524	.524	.516	.516	.516	.516
50	.524	.528	.528	.524	.516	.524	.524	.516	.524	.524	.524	.524	—	.524	.524	.524	.516	.516	.516	.512
7																				
8																				
9																				
10																				
11																				
12																				
13																				
14																				
15																				
16																				
17																				
18																				
19																				
20																				
21																				

LOWEST AREA - .452"
90°-180° X-181 Y-36

David
A. Hall



ISO - MTS - 5

Crossunder for MS-A to FWH ISA

12"

Area	scaffold Reg'd.	Fragility	Disc #
3.0A	yes		Nortec
3.1A	yes		Nortec
3.2A	yes		Nortec
3.3A	yes		Nortec
3.4A	NO		56
3.5A	yes		Nortec
3.6A	yes		Nortec
3.7A	NO		
3.8A	Yes		

Areas 3.7A and 3.8A were added to the program in November 1984

ISO-MTS-5



Plant Monticello

Iso # MTS-5

Area 3.1A

Grid Spacing 2"

Examiner(s) ASW / QL / KLH

Equipment Used Nortec 131-D

Calibration Block: Type 3080-B3

Serial Number 269

Transducer: Size 25" Dia

Frequency 5 MHz

	0°	30°	60°	90°	120°	150°	160°	210°	240°	270°	300°	330°
1	.415	.423	.428	.426	.420	.402	.399	.405	.404	.407	.413	.418
2	.443	.438	.442	.431	.414	.392	.403	.399	.409	.425	.418	.429
3	.462	.450	.442	.428	.427	.412	.420	.414	.411	.422	.427	.436
4	.477	.463	.441	.423	.417	.415	.408	.407	.410	.458	.426	.446
5	.488	.461	.450	.422	.416	.410	.403	.399	.406	.418	.422	.456
6	.456	.442	.440	.424	.422	.388	.381	.381	.411	.419	.427	.457
7	.422	.466	.460	.435	.431	.399	.401	.408	.416	.433	.437	.447
8			.464	.458	.433	.418	.391	.400	.430	.442	.437	.444
9				.458	.447	.412	.409	.408	.431	.448	.434	
10				.499	.467	.420	.397	.420	.446	.454		
11					.487	.430	.406	.415	.464			
12						.445	.413	.435				
13						.455	.434	.448				
14												
15												
16												
17												
18												
19												

Comments:

Plant Monticello

Iso # MTS-5

Area 3.4A 10S 10-10"

Grid Spacing 100

Examiner(s) ASW/DAH/QL

Equipment Used UI-III

Calibration Block: Type 3090-83 Serial Number N/A

Transducer: Size 1/2" dia Frequency 3.5 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.584	.584	.584	.588	.600	.636	.632	.604	.604	.604	.588	.600
2	.644	.644	.636	.636	.628	.632	.644	.664	.660	.652	.660	.680
3	.660	.652	.652	.660	.636	.796	.692	.680	.680	.664	.676	.688
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Disc N/A

Plant Monticello

Iso # MTS-5

Area 3.6A on FWH vessel

Grid Spacing 4"


Examiner(s) ASW/QL/SRF

Equipment Used NoTeo 131 P

Calibration Block: Type 3080-83 Serial Number 322

Transducer: Size .25" Frequency 5 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.508					.507						
2	.513	.507	.520	.511	.508	.509						
3	.512	.516	.516	.517	.514	.509						
4	.522	.512	.515	.509	.510	.510						
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												



Comments:

THICKNESS SURVEY REPORT

DATE 5-19-86

DISC# 76

MT MONTICELLO

ISO# MTS-5

3.7A

GRID SIZE 180

EXAMINERS STEVE STANFORD II / BILL BISSI / SCOTT WALLT

EQUIPMENT ULTRA IMAGE III

TRANSDUCER (SIZE/FREQ.) .25/10MHz.

CAL. BLOCK (TYPE/SERIAL NO.) STEPWEXE 3080-83

NOMINAL WALL _____

MIN. WALL _____

COMMENTS _____

X Degree Y Grid	26		52		78		104		25		50		100		23		46		69	
	30	60	90	120	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600
0	.400	.432	.440	.420	.420	.420	.408	.396	.408	.420	.420	.408	.396	.408	.396	.408	.408	.392	.392	.408
10	.396	.416	.420	.420	.424	.416	.408	.392	.408	.420	.420	.408	.392	.408	.408	.408	.404	.404	.408	.408
20	.400	.400	.420	.420	.420	.420	.412	.408	.412	.420	.420	.412	.408	.408	.408	.408	.408	.408	.400	.400
30	.412	.420	.420	.412	.416	.416	.408	.408	.412	.420	.420	.412	.408	.408	.416	.416	.416	.416	.412	.412
40	.396	.400	.408	.420	.408	.420	.432	.408	.432	.420	.420	.432	.416	.416	.416	.416	.416	.416	.408	.408
50	.400	.392	.416	.424	.412	.424	.436	.408	.432	.424	.424	.440	.428	.428	.424	.424	.424	.424	.416	.416
60	.388	.388	.396	.436	.412	.436	.440	.432	.440	.436	.440	.444	.432	.432	.424	.424	.420	.420	.404	.404
70	.388	.384	.392	.400	.436	.440	.444	.408	.440	.436	.440	.444	.440	.440	.436	.436	.420	.420	.404	.404
80	.368	.380	.400	.412	.432	.452	.448	.412	.432	.432	.452	.448	.448	.448	.440	.440	.416	.416	.408	.408
90	.392	.384	.396	.400	.440	.448	.444	.416	.440	.440	.448	.448	.440	.440	.420	.420	.416	.416	.408	.408
11																				
12																				
13																				
14																				
15																				
16																				
17																				
18																				
19																				
20																				
21																				

LOWEST AREA .368"
0°-120° X-B, Y-38

THICKNESS SURVEY REPORT

DATE 5/22/86

DISC# N/A

MONTICELLO

ISOM MTS-5

P. MTS-3.7A

GRID SIZE SEE COMMENTS

EXAMINERS M.J. LONGSDORF / JT

EQUIPMENT NORTEC 131-D #371

TRANSDUCER (SIZE/FREQ.) 1/2" Ø 2.25 MHz A30160

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

NOMINAL WALL 1/4" CARBON STEEL

MIN. WALL N/A

COMMENTS 0° AT INNER RADII OF ELBOW; 0° AT DOWN STREAM CIRC. WELD.

SCAN STARTS AT 2° DUE TO INSULATION.

Degree Grid	30	60	90	120	150	180	240	270	300	330
2"	.530	.531	.536	.567	.575	.567	.568	.570	.546	.526
2 1/4"	.545	.550	.543	.569	.575	.558	.558	.570	.535	.532
3"	.563	.555	.545	.564	.570	.557	.548	.565	.545	.556
4"	.570	.555	.550	.559	.565	.569	.554	.564	.539	.554
5 1/10"	.573	.550	.548	.550	.569	.575	.555	.557	.538	.557
6 1/2"	.572	.558	.547	.555	.557	.560	.551	.564	.548	.564
7 1/4"	.577	.555	.536	.554	.554	.566	.555	.569	.564	.565
8 1/16"	.567	.554	.530	.545	.567	.563	.572	.580	.564	.555
9 1/8"	.565	.552	.530	.546	.555	.575	.575	.576	.555	.545
10 20"	.566	.556	.540	.545	.575	.580	.565	.570	.560	.544
11 22"	.563	.560	.544	.549	.570	.568	.557	.569	.555	.532
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										

MINIMUM WALL = .530

THICKNESS SURVEY REPORT

DATE 5/23/86

DISC# N/A

MONTICELLO

ISO# MTS-5

R. MTS-3.8A

GRID SIZE N/A

EXAMINERS M.J. Longdorf
M.J. LONGDORF/JT

EQUIPMENT NOPTEC 131-D # 371

TRANSDUCER (SIZE/FREQ.) 1/2" 2.25MHz, A 30160

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 7080-83

NOMINAL WALL 14" CARBON STEEL

MIN. WALL N/A

COMMENTS 0" AT INNER RADIUS OF ELBOW; 0" AT DOWNSTREAM CIRC. WELD

SCAN BEGINS AT 2" DUE TO INSULATION.

Degree Grid	30	60	90	120	150	180	240	270	300	330
2" X 2"	.565	.560	.568	.605	.582	.522	.568	.527	.540	.566
2" X 4"	.556	.552	.578	.575	.562	.585	.546	.536	.539	.562
2" X 6"	.582	.567	.587	.575	.560	.577	.555	.536	.539	.558
4" X 8"	.574	.555	.575	.574	.559	.590	.547	.539	.529	.548
6" X 10"	.567	.557	.559	.586	.584	.605	.565	.529	.545	.542
8" X 12"	.557	.553	.561	.599	.572	.610	.549	.522	.511	.522
7" X 14"	.554	.561	.575	.610	.599	.600	.564	.561	.520	.540
8" X 16"	.568	.560	.572	.603	.589	.594	.542	.533	.519	.542
9" X 18"	.550	.552	.565	.601	.584	.593	.550	.542	.524	.535
10" X 20"	.554	.552	.557	.605	.592	.584	.556	.545	.530	.525
11" X 22"	.540	.546	.585	.610	.598	.589	.557	.548	.528	.517
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										

MINIMUM WALL = .511"

THICKNESS SURVEY REPORT

DATE 5/23/86

DISC# N/A

MONTICELLO

ISO# MTS-5

MTS-3.8A

GRID SIZE N/A

EXAMINERS M.J. Longford
M.J. Longford/II

EQUIPMENT NORTEC 131-D # 371

TRANSDUCER (SIZE/FREQ.) 1/2" @ 2.25 MHz, A 30160

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 7080-83

NOMINAL WALL 14" CARBON STEEL

MIN. WALL N/A


COMMENTS 0" AT INNER RADIUS OF ELBOW; 0" AT DOWN STREAM CIRC. WELD

SCAN BEGINS AT 2" DUE TO INSULATION.

Degree	30	60	90	120	150	180	240	270	300	330
Grid										
2"	.565	.558	.560	.568	.605	.562	.582	.527	.540	.566
2 1/4"	.556	.552	.556	.578	.575	.585	.562	.536	.539	.562
2 1/2"	.582	.560	.561	.587	.575	.577	.560	.536	.539	.558
3"	.574	.555	.553	.575	.574	.590	.559	.539	.529	.548
3 1/2"	.567	.557	.559	.586	.587	.605	.584	.529	.545	.542
4"	.557	.553	.561	.599	.599	.610	.572	.522	.511	.522
4 1/4"	.554	.561	.575	.610	.599	.600	.564	.561	.520	.540
4 1/2"	.568	.560	.572	.603	.589	.594	.562	.533	.519	.542
5"	.550	.552	.565	.601	.584	.593	.568	.542	.524	.535
5 1/2"	.554	.552	.557	.605	.592	.584	.578	.545	.530	.525
6"	.540	.546	.585	.610	.598	.589	.575	.548	.528	.517
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										

MINIMUM WALL = .511"

By
A. Hall



ISO - MTS - 6

Crossover for MS-B to FW-15B

12"

Area	Scaffold Reg'd.	Frequency	Disc #
3.0	yes		Nortec
3.1	yes		Nortec
3.2	yes		Nortec
3.3	yes		Nortec
3.4	NO		57
3.5	yes		Nortec
3.6	yes		Nortec
3.7	No		
3.8	yes		

Areas 3.7 and 3.8 were added in November 1984

ISO-MTS-2

0



THICKNESS SURVEY REPORT

DATE 5/19/86

DISC# 73

MONTICELLO

ISO# MTS-6

3.3 DOWNSTREAM

GRID SIZE 100

EXAMINERS DAN SELLER & ALAN I

EQUIPMENT ULI III

TRANSDUCER (SIZE/FREQ.) .25 10MHz.

CAL. BLOCK (TYPE/SERIAL NO.) STEOWEDGE 3080-83

NOMINAL WALL .500

MIN. WALL MIN. 283 MAX. 599

COMMENTS NO EXAM 240°-270° DUE TO ADJACENT PIPE

Degree	30		60		90		120		150		180		240		270		300		330	
	45	90	90	45	135	180	180	135	90	45	60	60	120	120	45	45	90	90	120	120
1	.404	.408	.416	.424	.424	.424	.440	.420	.420	.416	.384	.396	.408	.396	.408	.408	.396	.408	.408	.408
2	.408	.396	.404	.412	.408	.420	.428	.408	.408	.416	.396	.408	.408	.396	.408	.408	.396	.408	.408	.392
3	.384	.392	.396	.404	.412	.408	.424	.408	.408	.416	.388	.396	.408	.388	.396	.404	.408	.396	.408	.392
4	.396	.396	.388	.388	.388	.396	.408	.408	.408	.408	.404	.408	.408	.404	.404	.408	.408	.408	.408	.404
5	.392	.384	.388	.388	.388	.388	.404	.396	.396	.396	.384	.384	.396	.412	.404	.408	.408	.408	.404	.404
6	.404	.392	.392	.392	.388	.388	.384	.384	.384	.396	.384	.384	.396	.412	.412	.412	.424	.416	.416	.416
7	.412	.396	.392	.388	.388	.388	.400	.392	.392	.388	.392	.388	.388	.392	.392	.412	.412	.412	.408	.408
8	.412	.412	.408	.396	.388	.388	.388	.396	.376	.384	.388	.388	.384	.392	.392	.416	.416	.416	.416	.416
9	.418	.412	.408	.404	.404	.404	.392	.404	.396	.396	.392	.392	.384	-	-	.408	.420	.420	.420	.420
10	.368	.428	.420	.416	.420	.420	-	.420	-	-	-	-	-	-	.392	.416	.416	.432	.432	.432
11																				
12																				
13																				
14																				
15																				
16																				
17																				
18																				
19																				
20																				
21																				

THINNESS FILE 3
 240°-270°
 X 28
 Y 99
 D 360

Plant Monticello

Iso # MTS-6

Area 3.410510-10"

Grid Spacing 100

Examiner(s) ASW/RL/DAH

Equipment Used UI-72

Calibration Block: Type 3090-83

Serial Number N/A

Transducer: Size 1/2" dia

Frequency 3.5 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.572	.560	.572	.584	.568	.560	.572	.560	.560	.580	.560	.580
2	.628	.640	.656	.650	.632	.640	.640	.640	.628	.608	.612	.604
3	.652	.660	.652	.656	.660	.652	.688	.648	.636	.640	.628	.628
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Date 6-14-84
Disc N/A

Plant Monticello

Iso # ANTS-6

Area 3.6 on FWH 15R on Vessel

Grid Spacing 4"

Examiner(s) ASW / QL / SRF

Equipment Used Mortec 131 D


Calibration Block: Type 3080-83

Serial Number 322

Transducer: Size 1.25" dia

Frequency 5 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.524						.530					
2	.508	.526	.505	.515	.525	.530	.512					
3	.503	.505	.525	.509	.506	.510	.519					
4	.503	.505	.526	.503	.529	.518	.530					
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												



Comments:

THICKNESS SURVEY REPORT

DATE 5/19/86

DISC# 74

IT MONITCELLO

ISO# MTS-6

3.7 UPSTREAM

GRID SIZE 100

OWNERS Tom Sells, John Albert

EQUIPMENT U I III

TRANSDUCER (SIZE/FREQ.) 25 10 MHz

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 30808

NOMINAL WALL .500

MIN. WALL Min. 283 MAX. 599

COMMENTS WELD SPLATTER 240°-360°

Degree Grid	30		60		90		120		150		180		210		240		270		300		330		
	45	90	45	90	45	90	45	90	45	90	45	90	45	90	45	90	45	90	45	90	45	90	
1	.396	.404	.412	.412	.408	.408	.396	.384	.388	.380	.376	.380	.376	.380	.380	.376	.380	.380	.380	.396	.380	.380	.380
2	.388	.396	.416	.412	.440	.408	.408	.404	.396	.392	.384	.392	.384	.384	.384	.384	.380	.380	.380	.376	.376	.376	.376
3	.392	.404	.412	.412	.416	.412	.412	.404	.392	.384	.384	.384	.372	.388	.388	.388	.388	.388	.388	.380	.380	.380	.380
4	.380	.380	.392	.412	.412	.412	.412	.408	.408	.408	.408	.408	.384	.384	.384	.384	.384	.384	.380	.380	.380	.360	.360
5	.376	.384	.392	.412	.412	.420	.420	.420	.416	.404	.404	.404	.384	.384	.384	.384	.380	.380	.368	.368	.368	.364	.364
6	.376	.368	.384	.396	.396	.396	.396	.396	.412	.408	.408	.412	.392	.380	.380	.384	.380	.380	.368	.368	.368	.364	.364
7	.364	.356	.372	.388	.388	.400	.400	.408	.416	.408	.416	.408	.392	.380	.380	.384	.380	.380	.368	.368	.368	.364	.364
8	.384	.384	.384	.400	.400	.404	.404	.396	.408	.408	.412	.404	.404	.396	.396	.404	.396	.404	.404	.416	.416	.404	.404
9	.384	.376	.368	.376	.376	.376	.376	.376	.408	.408	.416	.416	.416	.404	.404	.416	.404	.404	.416	.416	.416	.404	.404
10	.380	.360	.360	.360	.368	.368	.376	.376	.376	.376	.404	.432	.420	.432	.432	.432	.432	.432	.432	.432	.432	.404	.404
11																							
12																							
13																							
14																							
15																							
16																							
17																							
18																							
19																							
20																							
21																							

Thinest 30-120°
 X 100
 Y 91
 D .348

THICKNESS SURVEY REPORT

DATE 5/22/86

DISC# N/A

MONTICELLO

ISO# MTS-6

MTS-3.7

GRID SIZE SEE COMMENTS

EXAMINERS M. J. Longaker
M. B. LOWESTORF II

EQUIPMENT NORTEC 131-D # 371

TRANSDUCER (SIZE/FREQ.) 1/2", 2.25 MHz, A30160

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

NOMINAL WALL 14" CARBON STEEL

MIN. WALL N/A

COMMENTS 0° AT INNER RADIUS OF ELBO; D° AT DOWN STREAM CIRC. WELD.

SCAN STARTS AT 2" DUE TO INSULATION.

Degree	30	60	90	120	150	180	210	240	270	300	330
2"	.527	.495	.512	.531	.537	.556	.545	.563	.523	.584	.484
2 1/4"	.490	.497	.520	.532	.539	.562	.540	.565	.516	.499	.485
2 1/2"	.503	.501	.515	.537	.554	.575	.555	.554	.502	.487	.493
2 3/4"	.512	.515	.529	.540	.555	.580	.545	.540	.493	.485	.500
3"	.515	.527	.530	.538	.548	.567	.547	.535	.504	.495	.514
3 1/4"	.520	.520	.526	.538	.547	.563	.548	.537	.501	.496	.510
3 1/2"	.519	.520	.529	.544	.544	.555	.545	.545	.545	.485	.550
3 3/4"	.552	.529	.540	.546	.552	.530	.540	.542	.496	.483	.510
4"	.562	.530	.535	.537	.546	.532	.544	.550	.511	.498	.515
4 1/4"	.534	.528	.532	.540	.556	.547	.535	.552	.512	.500	.518
4 1/2"	.550	.553	.548	.540	.557	.553	.556	.554	.505	.498	.509
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											

MINIMUM WALL = .483"

THICKNESS SURVEY REPORT

DATE 5/19/86

DISC# 75

IT Monticello

ISO# MTS-6

3.7 Downstream

GRID SIZE 100

EXAMINERS VanSellen, F. M. Allen

EQUIPMENT UI III

TRANSDUCER (SIZE/FREQ.) .25 10mbz

CAL. BLOCK (TYPE/SERIAL NO.) STEPWEDGE. 3080-83

NOMINAL WALL .500

MIN. WALL Min. 271 Max. 587

COMMENTS 200° - 360° Rough Surface (chipped paint)
Threshold raised to 50% due to this condition

Degree	30		60		90		120		150		180		240		270		300		330	
	4	45	90	90	135	180	180	225	225	135	180	90	135	180	45	90	90	135	135	180
1	.412	.400	.392	.380	.388	.392	.388	.392	.380	.392	.392	.392	.388	.392	.416	.412	.412	.408	.408	.408
2	.408	.392	.384	.380	.388	.380	.380	.380	.380	.400	.400	.400	.408	.408	.412	.420	.420	.424	.424	.424
3	.412	.400	.380	.380	.388	.380	.380	.380	.392	.396	.396	.412	.412	.412	.424	.424	.424	.416	.416	.416
4	.392	.380	.380	.388	.384	.388	.388	.388	.392	.412	.412	.420	.420	.420	.416	.416	.416	.404	.404	.404
5	.404	.380	.372	.388	.384	.388	.388	.388	.392	.412	.412	.420	.420	.420	.416	.416	.416	.396	.396	.396
6	.388	.388	.326	.388	.388	.392	.392	.392	.408	.416	.416	.420	.420	.420	.408	.408	.376	.388	.388	.388
7	.368	.380	.376	.376	.376	.404	.404	.404	.420	.424	.424	.440	.416	.416	.396	.400	.400	.400	.400	.400
8	.388	.380	.380	.380	.396	.408	.408	.408	.416	.420	.420	.412	.400	.400	.404	.388	.388	.388	.388	.388
9	.396	.388	.396	.396	.412	.428	.428	.428	.420	.424	.424	.404	.396	.396	.384	.384	.384	.384	.384	.384
10	.392	.388	.396	.410	.410	.416	.416	.416	.436	.424	.424	.436	.400	.400	.388	.388	.388	.388	.388	.388
11																				
12																				
13																				
14																				
15																				
16																				
17																				
18																				
19																				
20																				
21																				

THINTEST FILE
 270-90°
 X 98
 Y 52
 Z 356

THICKNESS SURVEY REPORT

DATE 5-20-86

DISC# 77

IT MONTICELLO

ISO# MTS-6

3.8 (0-16")

GRID SIZE 190

MINERS STEVE STANFORD II / A.W. VOS / S.G. HALL

EQUIPMENT ULTRA IMAGE III

TRANSDUCER (SIZE/FREQ.) .25" / 10 MHz.

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

NOMINAL WALL .375"

MIN. WALL _____

COMMENTS 18" ARM

X Degree	Y Degree		22		44		66		88		24		48		72		0		23		46		69		
	0	30	60	90	120	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600	630	660	690	
1	0	.431	.392	.368	.356	.360	.352	.356	.414	.408	.414	.390	.414	.390	.414	.390	.414	.390	.414	.390	.414	.390	.414	.390	.414
1	10	.390	.374	.370	.362	.348	.336	.360	.384	.384	.348	.390	.384	.390	.384	.390	.384	.390	.384	.390	.384	.390	.384	.390	.384
1	20	.390	.388	.374	.354	.348	.352	.360	.388	.374	.348	.390	.388	.390	.388	.390	.388	.390	.388	.390	.388	.390	.388	.390	.388
1	30	.388	.390	.401	.374	.356	.352	.360	.424	.392	.388	.424	.392	.388	.424	.392	.388	.424	.392	.388	.424	.392	.388	.424	.392
1	40	.388	.386	.380	.368	.356	.340	.352	.392	.370	.352	.392	.370	.352	.392	.370	.352	.392	.370	.352	.392	.370	.352	.392	.370
1	50	.382	.394	.381	.366	.352	.348	.352	.386	.362	.348	.386	.362	.348	.386	.362	.348	.386	.362	.348	.386	.362	.348	.386	.362
1	60	.382	.388	.381	.380	.352	.356	.352	.404	.360	.356	.404	.360	.356	.404	.360	.356	.404	.360	.356	.404	.360	.356	.404	.360
1	70	.386	.396	.390	.396	.368	.348	.352	.390	.374	.348	.390	.374	.348	.390	.374	.348	.390	.374	.348	.390	.374	.348	.390	.374
1	80	.394	.394	.390	.384	.360	.356	.360	.410	.364	.356	.410	.364	.356	.410	.364	.356	.410	.364	.356	.410	.364	.356	.410	.364
1	90	.386	.392	.386	.380	.372	.372	.360	.374	.392	.372	.360	.374	.392	.372	.360	.374	.392	.372	.360	.374	.392	.372	.360	.374
11																									
12																									
13																									
14																									
15																									
16																									
17																									
18																									
19																									
20																									
21																									

LOWEST AREA IS .340"
120°-240° X 47, Y-54

THICKNESS SURVEY REPORT

DATE 5/22/86

DISC# N/A

MONTICELLO

ISO# MTS-6

MTS-3.B

GRID SIZE N/A

EXAMINERS M. J. Lonsdale
M. J. Lonsdale/TT

EQUIPMENT NORTEC 131-D # 371

TRANSDUCER (SIZE/FREQ.) 1/2" Ø 2.25 MHz, A30160

CAL. BLOCK (TYPE/SERIAL NO.) STEPWEDGE 3080-83

NOMINAL WALL 14" CARBON STEEL


MIN. WALL N/A

COMMENTS 0° AT INNER RADIUS OF ELBOW; 0° AT DOWNSTREAM CIRC. WELD.

SCAN BEGINS AT 2" DUE TO INSULATION

Degree Grid	30	60	90	120	150	180	210	240	270	300	330
Y 2'	.526	.550	.492	.535	.525	.542	.565	.540	.555	.495	.512
2 4'	.595	.505	.520	.545	.532	.555	.566	.536	.513	.492	.510
2 6'	.566	.560	.515	.538	.520	.555	.544	.529	.565	.496	.518
2 8"	.560	.515	.572	.535	.515	.535	.550	.530	.528	.508	.526
2 10"	.565	.585	.510	.534	.525	.525	.536	.554	.528	.517	.510
2 12"	.583	.590	.517	.530	.515	.533	.528	.538	.518	.508	.513
2 14"	.576	.535	.515	.522	.504	.525	.540	.518	.528	.519	.540
2 16"	.565	.525	.510	.520	.505	.514	.520	.522	.532	.522	.536
2 18"	.560	.540	.508	.525	.520	.503	.537	.523	.535	.522	.533
2 20"	.555	.555	.505	.510	.516	.525	.542	.527	.520	.528	.544
2 22"	.565	.545	.514	.517	.520	.520	.547	.527	.529	.533	.542
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											

MINIMUM WALL = .492"



ISO-MTS-7

Notes
ISO-MTS-7

MS-A To FWH 14A

6"

Area	Scaffold Reg'd.	Frequency	Disc #
9.0	yes		Nortec
9.1	yes		Nortec
9.2	No		Nortec
9.3	NO		Nortec
9.4	NO		

Area 9.4 was added in November 1984

Thickness Survey

Date 06-12-84
Disc N/A

Plant Monticello

Iso # MT 5-7

Area 9.0 Entire Elbow

Grid Spacing 2"

Examiner(s) ASW/KLH

Equipment Used Nortec 131-D

Calibration Block: Type 3080-83 Serial Number 322

Transducer: Size 25" Dia Frequency 5 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.318	.320	.325	.309	.315	.320	.326	.320	.320	.334	.352	.325
2	.309	.339	.317	.294	.304	.312	.312	.317	.330	.344	.369	.334
3	.309	.329	.314	.303	.316	.326	.306	.315	.327	.338	.337	.354
4	.332	.322	.299	.273	.308	.323	.301	.316	.327	.358	.361	.346
5	.329	.322	.278	.294	.302	.299	.305	.318	.319		.353	.354
6	.329	.300	.304	.299	.308	.296	.312	.315				.324
7	.309	.305	.319	.319	.318	.317	.316					
8	.312	.308	.326	.324	.309	.301	.339					
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Ave = .3192
 S.D. = .01764
 S.D.² = .01755
 Min = .278
 An engineering judgement of thickness ~ .350

Comments:

Thickness Survey

Date 06-12-84
Disc N/A

Plant Monticello

Iso # MTS-7

Area 9.1 Entire Elbow

Grid Spacing 2"

Examiner(s) ASW / KLH

Equipment Used Nortec 131-D

Calibration Block: Type 3080-83 Serial Number 322

Transducer: Size .25" Dia Frequency 5MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.295	.296	.316	.339	.353	.359	.359	.360	.336	.342	.326	.320
2	.289	.294	.316	.341	.353	.364	.366	.362	.335	.315	.304	.301
3	.315	.295	.344	.344	.350	.342	.365	.369	.330	.311	.302	.322
4	.294	.325	.341	.341	.351	.366	.362	.367	.326	.307	.321	.291
5	.294	.333	.314	.337	.350	.358	.354	.350	.322	.303	.317	.288
6	.323	.335	.313	.338	.352	.348	.364	.356	.321	.301	.316	.287
7	.323	.312	.337	.341	.345	.350	.356	.348	.320	.298	.291	.295
8	.325	.340	.316	.347	.344	.344	.349	.342	.324	.321	.299	.322
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

THICKNESS SURVEY REPORT

DATE 5/22/86

DISC# N/A

MONTICELLO

ISO# MTS-7

EA MTS-9.4

GRID SIZE N/A

TECHNICIANS M. J. Longshore / II

EQUIPMENT NOPTEC 131-D # 371

TRANSDUCER (SIZE/FREQ.) 1/2" 2.25MHz, A30160

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83


MIN. WALL 6" CARBON STEEL

MIN. WALL N/A

REMARKS 0° AT INNER RADIUS OF ELBOW; 0° AT DOWN STREAM CIRC. WELD

Degree Grid	30	60	90	120	150	180	240	270	300	330
0°	.38	.38	.38	.36	.36	.36	.36	.36	.38	.38
2°	.38	.38	.38	.36	.36	.34	.36	.36	.38	.38
4°	.38	.38	.36	.34	.34	.34	.34	.36	.36	.38
6°	.38	.38	.36	.35	.35	.35	.35	.36	.38	.38
8°	.38	.38	.36	.35	.35	.35	.35	.36	.38	.38
6										
7										
8										
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										

MINIMUM WALL = .34"



ISO-MTS 8

Notes
ISO-MTS-2

MS-B to FW4 14A

6"

Area scaffold Reg'd. | Frequency Disc #

10.0 yes Nortec

10.1 yes Nortec

10.3 NO Nortec

10.4 NO Nortec

10.2 NO

Area 10.2 was added in November 1984

Thickness Survey

Date 6-12-84
Disc N/A

Plant Mont. cell

Iso # MTS-8

Area 10.0 Entire Elbow

Grid Spacing 2"

Examiner(s) ASW / KKH

Equipment Used Nortec 131 D

Calibration Block: Type 3080-83

Serial Number 322

Transducer: Size .25" dia

Frequency 5 MHz

	0°	30°	60°	90°	120°	150	160	210°	240°	270°	300°	330°
1	.301	.296	.303	.313	.324	.310	.332	.317	.284	.307	.302	.299
2	.292	.306	.294	.303	.307	.336	.351	.335	.313	.303	.288	.294
3	.285	.281	.313	.300	.315	.334	.360	.338	.300	.302	.288	.288
4	.277	.295	.312	.304	.317	.340	.352	.345	.297	.300	.286	.273
5	.267	.292	.287	.297	.315	.341	.354	.345	.301	.287	.282	.264
6	.270	.271	.290	.297	.305	.331	.334	.333	.299	.294	.288	.274
7	.286	.282	.286	.303	.308	.324	.324	.319	.294	.299	.290	.284
8	.291	.287	.291	.301	.302				.291	.301	.292	.289
9	.298	.297	.300	.304						.307	.301	.300
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

"Reject" all > .325"

Avg = .304

S.D. = .0209

S.N. = .0206

Comments:

Thickness Survey

Date 6-12-84

Disc N/A

Plant MONTICELLO

Iso # MTS-8

Area 10.1 ENTIRE ELBOW

Grid Spacing 2"

Examiner(s) ASW IKLH

Equipment Used Nortec 1310

Calibration Block: Type 2080-83 Serial Number 322

Transducer: Size .25" Dia. Frequency 5MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.267	.309	.295	.298	.340	.338	.320	.314	.319	.294	.293	.301
2	.257	.276	.311	.296	.308	.335	.340	.327	.318	.303	.290	.308
3	.258	.270	.286	.289	.308	.348	.350	.341	.318	.301	.285	.302
4	.258	.282	.284	.284	.304	.339	.354	.344	.344	.296	.289	.304
5	.259	.272	.286	.284	.310	.327	.337	.334	.318	.303	.300	.303
6	.269	.273	.284	.293	.299	.322	.311	.313	.316	.312	.302	.290
7	.271	.281	.289	.316						.312	.313	.317
8	.284	.310	.334	.324						.315	.318	.246
9	.214	.303										.323
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

THICKNESS SURVEY REPORT

DATE 5/22/86

DISC# N/A

POINT MONTICELLO

ISO# MTS-8

AREA MTS-10.2

GRID SIZE N/A

EXAMINERS M.J. Fournier / M.J. LANSBURY/T

EQUIPMENT NORTEC 131-D #371

TRANSDUCER (SIZE/FREQ.) 1/2" 2.25 MHz, A30160

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

NOMINAL WALL 6" CARBON STEEL

MIN. WALL N/A

COMMENTS 0" AT INNER RADIUS OF ELBOW; 0" AT DOWN STREAM CIRC. WELD

Degree	0	30	60	90	120	150	180	210	240	270	300	330
Grid												
1" 0"	.38	.38	.38	.38	.38	.40	.42	.42	.42	.40	.38	.38
2" 2"	.38	.38	.38	.38	.37	.37	.38	.40	.40	.40	.40	.38
3" 4"	.40	.40	.38	.36	.38	.38	.38	.38	.40	.40	.40	.40
4" 6"	.40	.40	.36	.36	.38	.38	.38	.38	.38	.38	.40	.40
5" 8"	.40	.40	.38	.38	.38	.38	.38	.38	.38	.38	.40	.40
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												
21												

MINIMUM WALL = .36"

EPRI'S CHEC COMPUTER PROGRAM - VERSION 1 - 9/ 8/1987 18: 2:32
NORTHERN STATES POWER COMPANY

INPUT FILE NAME cmonts8

OUTPUT FILE NAME a:cmonts8.ou2

BOUNDING LEVEL = 90 %
NUMBER OF CASES = 1

EPRI'S CHEC COMPUTER PROGRAM - VERSION 1 - 9/ 8/1987 18: 2:32
NORTHERN STATES POWER COMPANY

MONTICELLO THICKNESS SUR.# 08

CASE = 1 NCHEM = 1 TOTAL TIME = 110000. NSEG = 1

ICHEM	FMULT	PH	OXY	HOURS
0	100.000	7.000	2000.0	110000.

NCOMP = 17 DESIGN PRESS.= 202. DESIGN TEMP.= 383.

MONTICELLO THICKNESS SUR.# 08

GEO (SECOND LINE)	MAT	COMP. NAME CR	DIA CU	THICK MO	TEMP SIGMA	FLOW
4	0	8.0E	6.	.280	383.	-4.500
	8.0000	.5000	1.0000	30000.		
8	5	8.0V1	6.	.280	383.	-4.500
9	5	8.0P1	6.	.280	383.	-4.500
1	5	8.1E2	6.	.280	383.	-4.500
9	5	8.1P2	6.	.280	383.	-4.500
2	5	8.1E3	6.	.280	383.	-4.500
9	5	8.1P3	6.	.280	383.	-4.500
2	5	8.1E4	6.	.280	383.	-4.500
9	5	8.1P4	6.	.280	383.	-4.500
2	5	8.3E1	6.	.280	383.	-4.500
9	5	8.3P1	6.	.280	383.	-4.500
2	5	8.3E2	6.	.280	383.	-4.500
9	5	8.3P2	6.	.280	383.	-4.500
2	5	8.2E1	6.	.280	383.	-4.500
9	5	8.2P1	6.	.280	383.	-4.500
2	5	8.4E1	6.	.280	383.	-4.500
2	5	8.1E1	6.	.280	383.	-4.500

MONTICELLO THICKNESS SUR.# 08

PASS 2 DATA
NUMBER OF INSPECTIONS = 17

NUMBER	COMP	MEASURED THICKNESS
1	8.0E	.280
2	8.0V1	.280
3	8.0P1	.280
4	8.1E2	.280
5	8.1P2	.280
6	8.1E3	.280
7	8.1P3	.280
8	8.1E4	.280
9	8.1P4	.280
10	8.3E1	.280
11	8.3P1	.280
12	8.3E2	.280
13	8.3P2	.280
14	8.2E1	.280
15	8.2P1	.280
16	8.4E1	.280
17	8.1E1	.280

MONTICELLO THICKNESS SUR.# 08

PASS 2 RESULTS AT 90% BOUNDING LEVEL
COMPONENT PREDICTED AVERAGE
EROSION RATE (MM/YR)

8.0V1	.00
8.1E3	.00
8.1E4	.00
8.3E1	.00
8.3E2	.00
8.2E1	.00
8.4E1	.00
8.1E1	.00
8.1E2	.00
8.0P1	.00
8.1P2	.00
8.1P3	.00
8.1P4	.00
8.3P1	.00
8.3P2	.00
8.2P1	.00
8.0E	.00

NOTE:
THE AVERAGE EROSION RATE FOR EACH COMPONENT IS CALCULATED
USING THE MAXIMUM TOTAL TIME FOR THE PROBLEM

MONTICELLO THICKNESS SUR.# 08

PASS 2 RESULTS AT 90% BOUNDING LEVEL
COMPONENT PREDICTED HOURS TO REACH
MINIMUM WALL THICKNESS

8.OV1	6586771.
8.1E3	11051290.
8.1E4	11051290.
8.3E1	11051290.
8.3E2	11051290.
8.2E1	11051290.
8.4E1	11051290.
8.1E1	11051290.
8.1E2	22212570.
8.OP1	33373850.
8.1P2	33373850.
8.1P3	33373850.
8.1P4	33373850.
8.3P1	33373850.
8.3P2	33373850.
8.2P1	33373850.
8.OE	1433682000.


WARNING:

THE DESIGN MINIMUM WALL THICKNESS USED IN PREDICTING TOTAL HOURS IS BASED ON DESIGN PRESSURE ONLY. UTILITIES MUST PERFORM PLANT SPECIFIC ENGINEERING EVALUATIONS THAT INCLUDE ALL LOADS TO PREDICT TOTAL HOURS BEFORE A FAILURE WOULD OCCUR.

MONTICELLO THICKNESS SUR.# 08

PASS 2 RESULTS AT 90% BOUNDING LEVEL

COMPONENT	PREDICTED THICKNESS (INCH)	PREDICTED WEAR (INCH)	LATEST EROSION RATE (MM/YEAR)	MINIMUM WALL THICKNESS (INCH)
8.0E	.280	.000	.00	.022
8.0V1	.276	.004	.00	.044
8.0P1	.279	.000	.00	.044
8.1E2	.279	.001	.00	.044
8.1P2	.279	.000	.00	.044
8.1E3	.278	.002	.00	.044
8.1P3	.279	.000	.00	.044
8.1E4	.278	.002	.00	.044
8.1P4	.279	.000	.00	.044
8.3E1	.278	.002	.00	.044
8.3P1	.279	.000	.00	.044
8.3E2	.278	.002	.00	.044
8.3P2	.279	.000	.00	.044
8.2E1	.278	.002	.00	.044
8.2P1	.279	.000	.00	.044
8.4E1	.278	.002	.00	.044
8.1E1	.278	.002	.00	.044



X - HANGER

CDG-6"
FRM. MOIST. SEP. D
HTR. 14B
9.1A
CDG-6"-GB

EL. 951'-0"
9.2A
9.5A
9.3A

EL. 612

DN
TO DRUTK
& DWP

9.4A

MOIST.
SEP. C'

C' MOISTURE SEP.
TO HTR. 14B
CDG-6" GB AND CDG-6" HK
CARBON STEEL

ISO-MTS-9

Notes
ISO-MTS-9

MS-C to FWH 143

6"

Area	Scaffold Reg'd.	Frequency	Disc #
------	-----------------	-----------	--------

9.1F	NO		Nortec
------	----	--	--------

9.3A	NO		Nortec
------	----	--	--------

9.4F	NO		Nortec
------	----	--	--------

9.2A	NO		
------	----	--	--

9.5A	NO		
------	----	--	--

Areas 9.2A and 9.5A were added in November 1984

Thickness Survey

Date 6-12-84
Disc N/A

Plant Monticello
Area 9.1A Entire Elbow
Examiner(s) ASW/KLH
Calibration Block: Type 3080-83
Transducer: Size .25" dia

Iso # MTS-8 9
Grid Spacing 2"
Equipment Used Nortec 131 D
Serial Number 322
Frequency 5 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.284	.277	.300	.315	.377	.355	.342	.327	.320	.307	.309	.276
2	.258	.283	.300	.318	.338	.353	.334	.324	.322	.314	.298	.300
3	.259	.297	.299	.324	.343	.367	.336	.322	.324	.314	.295	.272
4	.258	.271	.326	.316	.341	.345	.356	.338	.323	.335	.297	.267
5	.268	.278	.301	.320	.337				.320	.328	.294	.277
6	.274	.288	.310	.318						.311	.298	.288
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

THICKNESS SURVEY REPORT

DATE 5/16/86

DISC# N/A

PLANT MONTICELLO

ISO# MTS-9

AREA MTS-9-2A

GRID SIZE N/A

EXAMINERS M.A. Fitzgerald
M.J. Lowry

EQUIPMENT NORTEC 131-D # 409

TRANSDUCER (SIZE/FREQ.) 1/2" 2.25 MHz, A 30160

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 30RD-83

NOMINAL WALL 6" CARBON STEEL

MIN. WALL N/A

COMMENTS 0° AT INNER RADIUS OF LOWER ELBOW. 0" AT CIRC. WELD.

LIMITATION AT 270° DUE TO ADJACENT PIPE.

Degree	0	30	60	90	120	150	180	210	240	270	300	330
Grid												
1 0"	.32	.32	.32	.32	.32	.32	.32	.32	.32	/	.32	.32
2 "	.33	.33	.33	.34	.34	.34	.34	.33	.33	/	.33	.33
3 4"	.33	.33	.34	.34	.34	.34	.34	.33	.33	/	.33	.33
4 6"	.33	.32	.33	.34	.34	.34	.34	.33	.33	/	.32	.33
5 8"	.33	.33	.34	.34	.34	.34	.33	.33	.33	/	.33	.33
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												
21												

MINIMUM WALL = .32"

Thickness Survey

Date 6-26-84
Disc N/A

Plant Monticello

Iso # M.T.S. - 9

Area 9.3A

Grid Spacing 2"

Examiner(s) ASW/O.L./KLH

Equipment Used Nortec-131-D

Calibration Block: Type 3080-83 Serial Number 269

Transducer: Size .25" dia. Frequency 5 MHz.

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.299	.303	.317	.298	.306	.313	.311	.317	.316	.320	.310	.311
2	.265	.297	.333	.343	.334	.346	.316	.309	.303	.287	.315	.300
3	.283	.300	.346	.349	.347	.348	.312	.304	.299	.283	.290	.295
4	.276	.305	.329	.314	.326	.324	.308	.302	.288	.277	.283	.285
5	.281	.309	.322		.329	.318	.304	.301	.281	.266	.271	.281
6	.287	.314			.309	.303	.303	.291	.279	.258	.273	.279
7	.289					.302	.302	.290	.288	.264	.281	.287
8								.295	.285	.271	.315	.296
9										.278		
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

THICKNESS SURVEY REPORT

DATE 5/16/86

DISC# N/A

PLANT MONTICELLO

ISO# MTS-9

AREA MTS-9.4A

GRID SIZE N/A

EXAMINERS M. J. Langsdorf

EQUIPMENT NORTEC 131-D #409

TRANSDUCER (SIZE/FREQ.) 1/2" 2.25MHz A30160

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

NOMINAL WALL 6" CARBON STEEL

MIN. WALL N/A

COMMENTS 0" AT INNER RADIUS OF ELBOW; 0" AT DOWN STREAM CIRC. WELD

Degree	0	30	60	90	120	150	180	210	240	270	300	330
Grid												
1"	.37	.37	.37	.36	.34	.32	.32	.32	.34	.36	.37	.37
2"	.36	.37	.36	.36	.34	.32	.32	.32	.34	.36	.36	.36
3"	.36	.36	.36	.36	.36	.35	.34	.34	.34	.34	.35	.35
4"	.36	.36	.36	.38	.37	.35	.34	.32	.32	.32	.34	.34
5"	.38	.37	.37	.38	.36	.33	.32	.32	.31	.32	.34	.36
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												
21												

MINIMUM WALL = .31"

THICKNESS SURVEY REPORT

DATE 5/16/86

DISC# N/A

PLANT MONTICELLO

ISO# MTS-9

AREA MTS-9-5A

GRID SIZE N/A

EXAMINERS M. J. JONES
M. J. JONES

EQUIPMENT NORTEC 131-D # 409

TRANSDUCER (SIZE/FREQ.) 1/2" 2.25MHZ. A30160

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

NOMINAL WALL 6" CARBON STEEL


MIN. WALL N/A

COMMENTS 0° AT INNER RADII OF ELBOW; 0° AT DOWN STREAM CIRC. WELD.

LIMITATION AT 270°, 6"-8" DUE TO ADJACENT PIPES

Degree	0	30	60	90	120	150	180	210	240	270	300	330
Grid												
8"0"	.36	.36	.36	.36	.36	.34	.34	.34	.36	.36	.36	.36
2"	.36	.36	.36	.36	.36	.36	.36	.34	.32	.34	.34	.36
4"	.36	.36	.36	.36	.36	.36	.36	.34	.34		.32	.34
6"	.36	.36	.36	.36	.36	.36	.36	.36	.36		.34	.36
8"	.36	.36	.36	.36	.36	.36	.36	.36	.36			
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												
21												

MINIMUM WALL = .32"



D MOISTURE SEP.
TO HTR 14 B
6" CARBON STEEL
CD11-6"-GB TO CD6-6"-HK

THICKNESS SURVEY REF. DWNG.

Notes

ISO-MTS-10

MS-D to FWH 14B

6"

Area	Scaffold Reg'd.	Frequency	Disc #
------	-----------------	-----------	--------

10.0A	yes		Nortec
-------	-----	--	--------

10.1A	yes		Nortec
-------	-----	--	--------

10.3A	No		Nortec
-------	----	--	--------

10.4A	No		Nortec
-------	----	--	--------

10.2A	No		
-------	----	--	--

10.5A	No		
-------	----	--	--

Areas 10.2A and 10.5A were added in November 1974

Thickness Survey

Date 06-12-84

Disc NA

Plant Monticello

Iso # MTS-10

Area 10.0 A Entire Elbow

Grid Spacing 2"

Examiner(s) ASW / KLT

Equipment Used Montec 131-D

Calibration Block: Type 3080-83 Serial Number 322

Transducer: Size .25" Dia Frequency 5MHz

	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°	
1	.354	.328	.311	.335	.347	.324	.333	.359	.338	.345	.300	.334
2	.329	.320	.325	.304	.314	.317	.355	.341	.346	.337	.325	.342
3	.343	.336	.298	.294	.311	.336	.354	.340	.367	.355	.354	.340
4	.347	.310	.297	.288	.298	.316	.349	.340	.358	.363	.361	.339
5	.330	.313	.298	.313	.299	.320	.325	.338	.377	.361	.365	.332
6	.331	.341	.305	.298	.304	.325	.352	.334	.360	.348	.355	.352
7	.350	.326	.306	.305	.334	.334	.335	.330	.352	.335	.335	.350
8	.337	.324	.313	.320	.320	.350	.352					
9		.328	.332	.339								
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Thickness Survey

Date 06-12-84

Disc NIA

Plant Monticello

Iso # MTS-10

Area 10.1A Entire Elbow

Grid Spacing 2"

Examiner(s) ASW / KLH

Equipment Used Nortec 131-D

Calibration Block: Type 3080-83

Serial Number 322

Transducer: Size .25" Dia

Frequency 5 MHz

	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.330	.323	.324	.332	.337	.331	.321	.338	.328	.327	.320
2	.321	.314	.310	.326	.328	.328	.322	.338	.342	.350	.323
3	.321	.314	.300	.317	.323	.323	.329	.345	.352	.353	.332
4	.312	.309	.315	.312	.318	.320	.328	.339	.350	.345	.331
5	.312	.303	.296	.305	.320	.322	.330	.337	.338	.337	.333
6	.321	.305	.301	.304	.319	.328	.328	.330	.324	.329	.327
7	.345	.305	.307	.313	.321	.328	.327	.320	.312	.337	.318
8		.316	.312	.318	.328	.329					
9		.327	.326	.331							
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											

Comments:

THICKNESS SURVEY REPORT

DATE 5/16/86

DISC# N/A

PERMIT MONTICELLO

ISO# MTS-10

AREA MTS-10, 2A

GRID SIZE N/A

EXAMINERS M. J. L. LANSBARE

EQUIPMENT NOATEC 131-D #409

TRANSDUCER (SIZE/FREQ.) 1/2" 2.25 MHz A30160

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

NOMINAL WALL 6" CARBON STEEL

MIN. WALL N/A

COMMENTS 0° AT INNER RADII OF LOWER ELBOW; 0° AT CIRC. WELD.

LIMITATION AT 120° DUE TO ADJACENT PIPE.

Degree	0	30	60	90	120	150	180	210	240	270	300	330
Gr10	.31	.31	.31	.32	/	.32	.34	.34	.34	.34	.32	.32
X0"	.32	.32	.32	.33	/	.34	.34	.34	.34	.34	.32	.32
2"	.31	.31	.32	.33	/	.34	.34	.34	.34	.34	.32	.32
X4"	.32	.32	.32	.34	/	.34	.34	.34	.34	.34	.32	.32
X6"	.32	.32	.32	.34	/	.34	.34	.34	.34	.34	.32	.32
X8"	.32	.32	.32	.34	/	.34	.34	.34	.34	.34	.32	.32
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												
21												

MINIMUM WALL = .31"

Thickness Survey

Date 6-26-84

Disc N/A

Plant Monticello

Iso # MTS-10

Area 10.3A ENTIRE Elbow

Grid Spacing 2"

Examiner(s) ASW/KLH/QL

Equipment Used Nortec-131-D

Calibration Block: Type 3080-83 Serial Number 269

Transducer: Size .25" dia. Frequency 5 MHz.

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.315	.305	.305	.295	.314	.314	.325	.332	.296	.312	.315	.318
2	.310	.313	.327	.331	.323	.316	.313	.307	.287	.299	.301	.304
3	.304	.318	.339	.345	.325	.321	.309	.290	.282	.288	.287	.298
4	.304	.307	.331	.335	.320	.325	.308	.282	.273	.282	.286	.297
5	.308	.311	.319	.308	.313	.316	.301	.296	.266	.282	.295	.300
6	.306	.311				.312	.306	.301	.272	.283	.300	.300
7							.311	.304	.277	.290	.309	.309
8									.287	.303		
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

THICKNESS SURVEY REPORT

DATE 5/16/86

DISC# N/A

CONT MONTICELLO

ISO# MTS-10

AREA MTS-10.4A

GRID SIZE N/A

EXAMINERS M.J. LONGSDORF

EQUIPMENT NORTEC 131-D #409

TRANSDUCER (SIZE/FREQ.) 1/2" 2.25 MHz A30160

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

NOMINAL WALL 6" CARBON STEEL

MIN. WALL N/A

COMMENTS 0" AT INNER RADIUS OF ELBOW; 0" AT DOWN STREAM CIRC. WELD.

Degree Grid	0	30	60	90	120	150	180	210	240	270	300	330
X 0"	.36	.36	.36	.36	.36	.36	.34	.36	.36	.36	.36	.36
2"	.36	.36	.36	.36	.36	.34	.34	.36	.36	.36	.36	.36
X 4"	.36	.36	.36	.36	.34	.33	.32	.33	.35	.36	.36	.36
X 6"	.36	.36	.36	.36	.35	.34	.33	.34	.35	.36	.36	.36
X 8"	.36	.36	.36	.36	.36	.36	.36	.36	.36	.36	.36	.36
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												

MINIMUM WALL = .32"

THICKNESS SURVEY REPORT

DATE 5/16/86

DISC# N/A

PLANT MONTICELLO

ISO# MTS-10

AREA MTS-10.5A

GRID SIZE N/A

EXAMINERS M. J. Tomlinson
M. B. LANKESBORNE

EQUIPMENT NORTEC 131-D #409

TRANSDUCER (SIZE/FREQ.) 1/2" 2.25MHz A30160

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 308D-B3

NOMINAL WALL 6" CARBON STEEL

MIN. WALL N/A

COMMENTS 0° AT INNER RADIUS OF ELBOW; 0" AT DOWN STREAM CIRC. WELD
LIMITATION AT 8" AND 120° DUE TO ADJACENT PIPE.

Degree	0	30	60	90	120	150	180	210	240	270	300	330
Grid												
1"0"	.37	.36	.36	.36	.36	.34	.35	.36	.36	.36	.36	.36
2"	.36	.36	.36	.36	.35	.34	.32	.34	.35	.36	.36	.36
3"4"	.36	.36	.36	.34	.34	.33	.32	.33	.34	.34	.36	.36
4"6"	.36	.36	.36	.34	.34	.33	.32	.33	.34	.34	.36	.36
5"8"	.36	.36	.36	.36	—	.34	.34	.34	.34	.36	.36	.36
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												

MINIMUM WALL = .32"

EPRI'S CHEC COMPUTER PROGRAM - VERSION 1 -
NORTHERN STATES POWER COMPANY

9/ 8/1987

18: 3:19

INPUT FILE NAME cmonts10

OUTPUT FILE NAME a:cmonts10.ou2

BOUNDING LEVEL = 90 %

NUMBER OF CASES = 1

MONTICELLO THICKNESS SUR.#10

CASE = 1 NCHEM = 1 TOTAL TIME = 110000. NSEG = 2

ICHEM	FMULT	PH	OXY	HOURS
0	100.000	7.100	1000.0	110000.

NCOMP = 21 DESIGN PRESS.= 202. DESIGN TEMP.= 383.

MONTICELLO THICKNESS SUR.#10

PASS 2 RESULTS AT 90% BOUNDING LEVEL
COMPONENT PREDICTED AVERAGE
EROSION RATE (MM/YR)

10.1AE1	.00
10.0E1	.00
10.4AE1	.00
10.4AE2	.00
10.1AV1	.00
10.1AT1	.00
10.1AE2	.00
10.1AE3	.00
10.1AE4	.00
10.3AE1	.00
10.3AE2	.00
10.5AE1	.00
10.5AE2	.00
10.5AE3	.00
10.5AE4	.00
10.5AT1	.00
10.5AE1	.00
10.0AP1	.00
10.1AP1	.00
10.1AP1	.00
10.1AP2	.00
10.1AP3	.00
10.1AP4	.00
10.3AP1	.00
10.2AP1	.00
10.5AP1	.00
10.5AP2	.00
10.5AP3	.00
10.5AP4	.00
10.4AP0	.00
10.4AP1	.00

NOTE:

THE AVERAGE EROSION RATE FOR EACH COMPONENT IS CALCULATED
USING THE MAXIMUM TOTAL TIME FOR THE PROBLEM

MONTICELLO THICKNESS SUR.#10

PASS 2 RESULTS AT 90% BOUNDING LEVEL
COMPONENT PREDICTED HOURS TO REACH
MINIMUM WALL THICKNESS

10.1AE1	5470643.
10.0E1	5470643.
10.4AE1	5470643.
10.4AE2	5470643.
10.1AV1	6586771.
10.1AT1	6586771.
10.1AE2	11051290.
10.1AE3	11051290.
10.1AE4	11051290.
10.3AE1	11051290.
10.3AE2	11051290.
10.5AE1	11051290.
10.5AE2	11051290.
10.5AE3	11051290.
10.5AE4	11051290.
10.5AT1	16631930.
10.5AE1	22212570.
10.0AP1	33373850.
10.1AP1	33373850.
10.1AP1	33373850.
10.1AP2	33373850.
10.1AP3	33373850.
10.1AP4	33373850.
10.3AP1	33373850.
10.2AP1	33373850.
10.5AP1	33373850.
10.5AP2	33373850.
10.5AP3	33373850.
10.5AP4	33373850.
10.4AP0	33373850.
10.4AP1	33373850.


WARNING:

THE DESIGN MINIMUM WALL THICKNESS USED IN PREDICTING TOTAL HOURS IS BASED ON DESIGN PRESSURE ONLY. UTILITIES MUST PERFORM PLANT SPECIFIC ENGINEERING EVALUATIONS THAT INCLUDE ALL LOADS TO PREDICT TOTAL HOURS BEFORE A FAILURE WOULD OCCUR.

MONTICELLO THICKNESS SUR.#10

PASS 2 RESULTS AT 90% BOUNDING LEVEL

COMPONENT	PREDICTED THICKNESS (INCH)	PREDICTED WEAR (INCH)	LATEST EROSION RATE (MM/YEAR)	MINIMUM WALL THICKNESS (INCH)
10.1AE1	.275	.005	.00	.044
10.0AP1	.279	.000	.00	.044
10.0E1	.275	.005	.00	.044
10.1AP1	.279	.000	.00	.044
10.1AV1	.276	.004	.00	.044
10.1AP1	.279	.000	.00	.044
10.1AT1	.276	.004	.00	.044
10.1AE2	.278	.002	.00	.044
10.1AP2	.279	.000	.00	.044
10.1AE3	.278	.002	.00	.044
10.1AP3	.279	.000	.00	.044
10.1AE4	.278	.002	.00	.044
10.1AP4	.279	.000	.00	.044
10.3AE1	.278	.002	.00	.044
10.3AP1	.279	.000	.00	.044
10.3AE2	.278	.002	.00	.044
10.2AP1	.279	.000	.00	.044
10.5AE1	.278	.002	.00	.044
10.5AP1	.279	.000	.00	.044
10.5AE1	.279	.001	.00	.044
10.5AP2	.279	.000	.00	.044
10.5AT1	.278	.002	.00	.044
10.5AE2	.278	.002	.00	.044
10.5AE3	.278	.002	.00	.044
10.5AP3	.279	.000	.00	.044
10.5AP4	.279	.000	.00	.044
10.5AE4	.278	.002	.00	.044
10.4AP0	.279	.000	.00	.044
10.4AE1	.275	.005	.00	.044
10.4AP1	.279	.000	.00	.044
10.4AE2	.275	.005	.00	.044



ISO-MTS-11

Notes
ISO-MTS-11

MS-B to LPA

20'

Area	Scaffold Reg'd.	Frequency	Disc #
------	-----------------	-----------	--------

B	yes		32
---	-----	--	----

F	yes		34
---	-----	--	----

L	NO		28
---	----	--	----

B-2	yes		33
-----	-----	--	----

C	yes		35
---	-----	--	----

1984

Weld repair was done in several areas between B-2 and F. See plant report for details.

Plant Monticello

Iso # MT 5-11

Date 4-26-84

Area L

Grid Spacing 4"

Examiner(s) ASW/DAH/KLH

Equipment Used U.I. III

Calibration Block: Type 3080-83

Serial Number N/A

Transducer: Size 1/2" Dia

Frequency 5MHz

	0°	30°	60°	90°	120°	150°	210°	240°	270°	300°	330°
1	1.200	1.180	1.140	1.150	1.250	1.050	1.050	1.030	1.010	1.010	1.060
2	1.190	1.240	1.200	1.170	1.240	1.040	1.040	1.010	1.040	0.950	1.080
3	W	E	L	D							↑
4	.570	.570	.570	.590	.570	.580	.560	.550	.560	.570	.560
5	.550	.570	.540	.570	.590	.580	.570	.540	.560	.540	.570
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											

U.S.

D.S.

Thickness Survey

Date 7-17-84
Disc # 33

Plant MOYTCELLO
Area BZ/DS/PASTWELD
Examiner(s) ASW/KLH/NAM
Calibration Block: Type _____
Transducer: Size 1/2" Ø

Iso # MTS-11
Grid Spacing 200
Equipment Used UI II
Serial Number NA
Frequency 3.5 MHz pc

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.552	.536	.524	.524	.568	.528	.540	.520	←	←	←	←
2	.680	.644	.616	.588	.528	.528	.580	.532				
3	.576	.528	.532	.528	.520	.516	.544	.532				
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Thickness Survey

Date 7-18-84
Disc # 33

Plant MONTICELLO

Iso # MTS-11

Area B2/US/POSTWELD

Grid Spacing 200

Examiner(s) ASW/KLH/NAM

Equipment Used U I III

Calibration Block: Type 3090-83

Serial Number NA

Transducer: Size 1/2" Ø

Frequency 3.5 MHz PC

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	←	N/A	→	→	.508	.532	.488	.488	.540	←	←	←
2					.512	.508	.536	.504	.496			
3					.540	.516	.508	.512	.512			
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

THICKNESS SURVEY REPORT

DATE 5-10-86

DISC# 33.A&B

PLANT MONTICELLO

ISO# MTS-11

AREA B.2 U.S.

GRID SIZE 200

EXAMINERS [Signatures]

EQUIPMENT ULTRA IMAGE III

TRANSDUCER (SIZE/FREQ.) .25" / 10 MHz.

CAL. BLOCK (TYPE/SERIAL NO.) STEPWEDGE 3080-83

NOMINAL WALL .500"

MIN. WALL .271"

COMMENTS REF. POINT - TRANSDUCER @ 6 1/2" UPSTREAM OF BRACKET (HANGER).


UNSCANNED AREAS DUE TO BOLTS.

X Degree	Y Grid	10	30	60	90	120	150	180	210	240	270	300	330
0	0	.508	.504	.504	.504	.516	.524	.508	.508	.512	.516	.508	.508
10	10	—	.504	.504	—	.524	.520	.508	.508	.508	.520	.516	.516
20	20	.504	.504	.504	.504	.504	.516	.508	.512	.516	.520	.508	.508
30	30	.504	.512	.504	.504	.528	.528	.528	.520	.512	.512	.512	.508
40	40	.504	.504	.508	.504	.520	.536	.532	.508	.520	.516	.512	.508
50	50	.504	.504	.508	.504	.528	.536	.520	.536	.520	.516	.508	.508
7													
8													
9													
10													
11													
12													
13													
14													
15													
16													
17													
18													
19													
20													
21													

LOWEST AREA IS .428"
180°-270° X-11, Y-51

B-2 Disc# 33

Iso# MTS-11/05-9-84



THICKNESS SURVEY REPORT

DATE 5/10/86

DISC# 34

PLANT MONTICELLO

ISO# MTS-11

AREA "F"

GRID SIZE 200

EXAMINERS TAN SELLS / STEVE ALGER / RAY WOLF

EQUIPMENT UI III

TRANSDUCER (SIZE/FREQ.) .25" 10MHZ.

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

NOMINAL WALL .5"

MIN. WALL MIN=.360 MAX=.910

COMMENTS DELAYS ARE OFF DUE TO P/C IN 84, P/E 10MHZ. 86

Degree	Grid	File 0	File 9	File 10	File 12	File 13	File 14	File 15	File 16	File 17	File 18	File 19	File 20	File 21
	0	44	88	44	88	44	88	44	88	44	88	44	88	44
	10	.520	.512	.512	.512	.512	.512	.512	.512	.512	.512	.512	.512	.512
	20	.512	.520	.524	.524	.524	.524	.524	.524	.524	.524	.524	.524	.524
	30	.512	.520	.512	.508	.484	.496	.528	.524	.524	.524	.524	.524	.524
	40	.512	.520	.524	.524	.496	.528	.524	.524	.524	.524	.524	.524	.524
	50	.520	.524	.524	.556	.528	.524	.524	.524	.524	.524	.524	.524	.524
	6					← FILE 13								
	7					.512	.532	.520						
	8					.508	.520	.520						
	9					.512	.500	.516						
	10					.512	.520	.500						
	11					.512	.512	.432						
	12													
	13													
	14													
	15													
	16													
	17													
	18													
	19													
	20													
	21													


THINNEST AREA (FILE 13)

X = 38
Y = 28
D = .396


AREA (FILE 12)

202° - 256°
THIN WALL

Area F 180°-270°
Iso MTS-11 05-11-84



6" GEN. Area 730 BY VENT
Iso MTS-11 05-15-84



Iso MTS-11

Disc. # 34

AREA F 7:30 BY VENT

GENERAL AREA POST WELD

<u>.536</u>	<u>.512</u>	<u>.508</u>	<u>.508</u>	<u>.500</u>
<u>.508</u>	<u>.516</u>	<u>.496</u>	<u>.508</u>	<u>.496</u>
<u>.508</u>	<u>.504</u>	<u>.500</u>	<u>.496</u>	<u>.504</u>
<u>.496</u>	<u>.504</u>	<u>.512</u>	<u>.532</u>	<u>.504</u>
			<u>.428</u>	

Thickness Survey

Date 7-18-84
Disc # 32

Plant MONTICELLO

Iso # MTS-11

Area B- POSTWELD

Grid Spacing _____

Examiner(s) _____

Equipment Used UE III

Calibration Block: Type _____

Serial Number NA

Transducer: Size .5 DIA

Frequency 3.5 MHz PC

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	← NA →	→ NA →	.592	.508	.484	.512	.508	← NA →				
2			.488	.500	.508	.508	.536					
3			.484	.492	.508	.528	.572					
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

THICKNESS SURVEY REPORT

DATE 5-14-86

DISC# 32

PLANT MONTICELLO

ISO# MTS-11

AREA B

GRID SIZE 150

EXAMINERS STEVE STANFORD II / AW. VOSS / S.G. HALL

EQUIPMENT ULTRA IMAGE III

TRANSDUCER (SIZE/FREQ.) .25" / 10MHz.

CAL. BLOCK (TYPE/SERIAL NO.) PERWELDE 3080-83

NOMINAL WALL .500"

MIN. WALL .271"

COMMENTS LIMITATIONS DUE TO SPATTER, NUTS & L.S. ALSO ROUGH SURFACES CONTRIBUTE TO NOISE SIGNALS.

* REF. 10³/₄" FROM ϕ OF X-DUCT TO ϕ OF WELD D.S.

X Degree	Y Grid	10	110	120	130	140	150	160	8	9	10	11	12	13	14	15	16	17	18	19	20	21
0	0																					
1	30	.504	.508	.524	.528	.504	.504	.516														
67	60	.520	.508	.544	.528	.504	.508	.508														
0	90	.528	—	—	.524	.528	.524	.528														
174	180	.520	.508	—	.516	.508	.508	.512														
56	210	.516	.508	.508	.512	.500	.500	.516														
2	240	.512	.508	.508	.508	.504	.508	.508														
168	270	—	—	—	—	.516	.508	.508														
53	300	—	.520	.508	.516	.524	.524	—														
106	330	.516	.528	.516	.524	.520	.524	.520														

LOWEST AREA - .408"
210°-270° X-36, Y-61

THICKNESS SURVEY REPORT

DATE 5-9-86

DISC# 34

PLANT MONTICELLO

ISO# MTS-11

AREA 7:30 BY VENT

GRID SIZE 80

EXAMINERS Richard Stinson, I. Monticello

EQUIPMENT ULTRA IMAGE III

TRANSDUCER (SIZE/FREQ.) .25" / 10 MHz.

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

NOMINAL WALL .500"

MIN. WALL .271"


COMMENTS IMAGE GRID REF. 7 3/4" U.S. FROM NEAREST WELD & 3 1/4" CCW FROM 0°

SPATTER LIMITATION IN AREA OF X-85, Y-31

X Y Grid	Degree		0		20		40		60		80		90		180		210		240		270		300		330		
	φ	φ	φ	φ	φ	φ	φ	φ	φ	φ	φ	φ	φ	φ	φ	φ	φ	φ	φ	φ	φ	φ	φ	φ	φ	φ	
10	.520		.500	.504	.512	.512	.520	.520	.520	.520	.520	.520	.520	.520	.520	.520	.520	.520	.520	.520	.520	.520	.520	.520	.520	.520	.520
110	.528		.496	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504
120	.512		.492	.508	.512	.512	.512	.512	.512	.512	.512	.512	.512	.512	.512	.512	.512	.512	.512	.512	.512	.512	.512	.512	.512	.512	.512
130	.512		.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504
140	.520		.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504	.504
145	.520		.508	.500	.532	.532	.532	.532	.532	.532	.532	.532	.532	.532	.532	.532	.532	.532	.532	.532	.532	.532	.532	.532	.532	.532	.532
7																											
8																											
9																											
10																											
11																											
12																											
13																											
14																											
15																											
16																											
17																											
18																											
19																											
20																											
21																											

LOWEST AREA IS .472"
X-30, Y-21

8/28/87
MARK HUGO
SR. ENG. NSP-PPM/M&SP
MPLS, MN



A MOISTURE SEP. TO
C.I.V. NO. 4

30" CROSSOVER PIPING
COPPER BEARING STEEL.
NOMINAL .500
MIN. .271

THICKNESS SURVEY REF. DWNG.

MONTS12

Notes

ISO-MTS-12

MS-A to 2P-B

30'

Area	Scaffold Reg'd.	Frequency	Disc #
2.0	yes		54
2.1	yes		55
2.2	yes		53
2.3	yes		72
2.4	yes		70
2.5	No		27
2.6	yes		71

Thickness Survey

Date 0-2-87
Disc 54

Plant Monticello
Area 2.0 / US / 0-10"
Examiner(s) ASW / SRF / K LH
Calibration Block: Type 3080-83
Transducer: Size 1/2" P.C

Iso # MTS-12
Grid Spacing 180
Equipment Used UI-III
Serial Number N/A
Frequency 5 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.500	.524	.504	.516	*	.504	.504	.508	.488	.496	.508	.504
2	.500	.500	.446	.504	*	.508	.504	.504	.516	.484	.528	.504
3	.446	.460	.500	.504	*	*	.504	.508	.480	.476	.528	.504
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments: * Limited scan 90° to 180° due to 4" pipe
2 small welds at 90°

Thickness Survey

Date 6/11/01
Disc 55

Plant Monticello
Area 2.1/05/10"-0"
Examiner(s) ASW/KLH/SRF
Calibration Block: Type 3090-83
Transducer: Size 1/2" P-C

Iso # MTS-12
Grid Spacing 180
Equipment Used UT-III
Serial Number N/A
Frequency 5MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.524	.524	.496	.500	.504	.496	.516	.520	.516	.528	.544	.536
2	.520	.524	.512	.496	.504	.504	.524	.520	.508	.528	.520	.520
3	.532	.524	.500	.492	.516	.508	.504	.504	.524	.528	.504	.508
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Plant Monticello

Iso # MTS-12

Area 2.3 IDS 10-10

Grid Spacing 180

Examiner(s) ASW/RLH/JEB

Equipment Used UI-III

Calibration Block: Type 3080-83 Serial Number N/A

Transducer: Size 1/2" dia Frequency 3.5 MHz P-C

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.532	.524						.544	.540	.536	.528	.528
2	.524	.524		W	A	L		.528	.528	.524	.524	.528
3	.532	.524						.532	.528	.528	.528	.524
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Plant Marticello

Iso # MTS-12

Area 2.4 / DS / 10-10

Grid Spacing 190

Examiner(s) ASW / KLH / JEB

Equipment Used UI-III

Calibration Block: Type 3080-83 Serial Number N/A

Transducer: Size 1/2" dia Frequency 3.5 MHz P-C

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.520	.520	.572	.516	.520	.520	.520	.508	.524	.524	.520	.516
2	.520	.528	.520	.516	.520	.516	.520	.516	.516	.512	.520	.512
3	.500	.524	.524	.516	.524	.536	.520	.508	.520	.516	.520	.524
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Thickness Survey

Date 8-2-84
Disc 71

Plant Monticello

Iso # MTS-12

Area 2.6 / US / 0-10

Grid Spacing 180

Examiner(s) Asw / KGH / JEB


Equipment Used UI-III

Calibration Block: Type 3080-83 Serial Number N/A

Transducer: Size 1/2" dia Frequency 3.5 MHz P-C

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.492	.508	.508	.512	.492	.528	.528	.532	.532	.524	.544	.524
2	.496	.508	.516	.536	.508	.528	.528	.528	.528	.528	.524	.524
3	.488	.492	.508	.488	.488	.540	.528	.536	.528	.528	.524	.528
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:



ISO-MTS-13

NOTES
ISO-MTS-13

MS-C G LPB

20"

Area Scaffold Reg'd. | Frequency Disc #

2.0A yes 41

2.1A yes Nortec

2.2A yes Nortec

2.3A NO 39

2.4A yes 38

2.5A NO 29

2.6A yes 31

Plant MONTICELLO

Date 02/07/07
Disc 41

Area 2.0A 0° TO 180°

Iso # MTS-13

Grid Spacing 4"

Examiner(s) DHALL, KHAL, Q LOREDO

Equipment Used NORTEC 131D & U I III

Calibration Block: Type STEP Block

Serial Number 322

Transducer: Size 1/2" dia

Frequency 2.25 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.540	.548	.529	.513	.535	.538	.538	.528	.520	.468	.508	.504
2	.538	.545	.525	.514	.520	.542	.540	.508	.496	.508	.504	.500
3	.535	.542	.532	.528	.523	.537	.537	.508	.508	.572	.492	.516
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Plant MONTICELLO

DATE 2-1-81
Disc N/A

Area 2.1A 0° to 330°

Iso # MTS-13

Grid Spacing 4"

Examiner(s) D. HALL, Q LOREDO

Equipment Used NORTEC 131 D & UI III

Calibration Block: Type 3080-83

Serial Number 322 / NA

Transducer: Size .5" dia

Frequency 2.25 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.521	.534	.529	.535	.539	.529	.538	.533	.534	.532	.539	.534
2	.542	.529	.534	.541	.535	.528	.531	.526	.532	.528	.528	.535
3	.541	.524	.536	.545	.532	.531	.528	.526	.530	.524	.528	.535
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Date 5-21-84
Disc 44

Plant Monticello

Iso # MTS-13

Area 2.2A 90° to 270° Top of Elbow

Grid Spacing 4"

Examiner(s) DHALL, Q Loredo

Equipment Used Nortec 131-D, U.I III

Calibration Block: Type 3080-83

Serial Number 322, NA

Transducer: Size 5" dia.

Frequency 2.25 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.508	.520	.508	.540	.559	.551	.529	.556	.553	.549	.536	.532
2	.508	.524	.504	.545	.548	.548	.528	.554	.551	.543	.532	.512
3	.540	.508	.528	.542	.542	.541	.532	.552	.546	.542	.512	.536
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

THICKNESS SURVEY REPORT

DATE 5-14-86

DISC# 38

PLANT MONTICELLO

ISO# MTS-13

AREA 2.4 A U.S. 0"10"

GRID SIZE 180

EXAMINERS STEVE STANFORD / AW. VOSS / S.G. HALL

EQUIPMENT ULTRA IMAGE III

TRANSDUCER (SIZE/FREQ.) .25" / 10 MHz

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

NOMINAL WALL .500"

MIN. WALL .271"

COMMENTS _____

X Degree	Y Grid	10	110	165	49	98	0	50	150	240	300	330	94
0	0	.520	.520	.516	.516	.516	.520	.524	.516	.524	.520	.516	.516
	10	.520	.520	.516	.516	.516	.520	.524	.516	.524	.520	.516	.516
	110	.520	.520	.516	.532	.524	.524	.528	.516	.524	.532	.524	.516
	165	.520	.520	.516	.512	.516	.516	.528	.516	.524	.532	.488	.488
	49	.520	.520	.484	.512	.520	.520	.528	.516	.524	.520	.520	.520
	98	.512	.520	.516	.520	.524	.516	.524	.512	.520	.532	.552	.552
	0												
	50												
	150												
	240												
	300												
	330												
	94												

LOWEST AREA - .340" (0°-90°)
X-49, Y-7

GENERAL LOW AREA X-40 TO X-58
Y-0 TO Y-50

Plant Monticello

Date 4-26-84

Area 2.5-A

Iso # MTS #4-13

Examiner(s) ASW/DAH/KLH

Grid Spacing 4"

Calibration Block: Type 3080-83

Equipment Used U. I. III

Transducer: Size 1/2" Dia



Serial Number N/A
Frequency 5 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	1.160	1.070	1.040	1.030	1.040	1.040	1.040	1.090	1.170	1.140	1.150	1.170
2	1.170	1.060	1.020	1.030	1.040	1.050	1.030	1.070	1.190	1.180	1.150	1.150
3	W	E	L	D	W	E	L	D	W	E	L	D
4	.540	.540	.550	.600	.550	.560	.590	.570	.540	.550	.590	.570
5	.560	.540	.540	.590	.590	.590	.570	.600	.590	.600	.590	.560
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												


US

DS

C.I.V. NO. 2



- X — HANGER
- — MANWAY



D' MOIST. SEP

EL. 937'-0"

D' MOISTURE SEP
TO C.I.V. NO. 2
30" CROSSOVER PIPING
COPPER BEARING
NOMINAL ~~STEEL~~
MEN. 271

NOTES


ISO-MTC-14

MS-D to LPA

30'

Area	Scaffold Reg'd.	Frequency	Disc #
------	-----------------	-----------	--------

L-2	NO		40
-----	----	--	----



Notes

IED-MTS-15

7th stage LPA to FWH 14A

105

Area	scaffold Reg'd.	Frequency	Disc #
4.0	NO		Nortec
5.0	NO		Nortec
5.1	NO		Noun 100-D
5.2	yes		62
5.3	yes		Nortec
5.4	yes		Nortec
5.5	yes		Nortec

Plant Monticello Iso # M75-15
 Area 4.0 Entire Elbow Grid Spacing 2"
 Examiner(s) ASW/MLH Equipment Used Nortec 131D
 Calibration Block: Type 3080.83 Serial Number 287
 Transducer: Size .25" dia Frequency 5 mhz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	347	349	330	351	373	381	393	367	361	356	374	366
2	354	362	345	355	374	380	396	376	383	377	383	373
3	315	358	342	401	389	392	397	379	369	372	376	366
4	319	351	329	354	383	391	399	380	368	373	374	369
5	327	342	327	354	384	393	397	384	373	368	367	364
6		345	335	343	376	392	396	386	375	372	368	363
7			329	345	370	390	385	387	381	382	372	368
8				348	376	381	401	385	374	382	380	
9					377	374	388	381	380	370	372	
10					380	385	390	383	371	364	368	
11					381	395	400	390	366			
12								382	373			
13									377			
14												
15												
16												
17												
18												
19												

Comments:

Thickness Survey

Date 07-19-84
Disc N/A

Plant Monticello

Iso # MTS-15

Area 5.0 Entire Elbow

Grid Spacing 2"

Examiner(s) ASW KLT

Equipment Used Nortec 131-D

Calibration Block: Type 3080-83

Serial Number 287

Transducer: Size .25" Dia

Frequency 5MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.431	.440	.439	.429	.406	.404	.377	.358	.352	.376	.411	.420
2	.441	.437	.434	.420	.399	.400	.375	.361	.358	.381	.416	.423
3	.425	.432	.436	.422	.397	.394	.376	.355	.360	.385	.415	.417
4	.424	.430				.399	.366	.356	.361	.386	.404	.414
5								.352	.359	.384	.390	
6									.353	.368		
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Thickness Survey

Date 7-3-84
Disc N/A

Plant Monticello

Iso # MTS-15

Area S.1 Entire Elbow

Grid Spacing 2"

Examiner(s) ASW / DAH

Equipment Used Novu 100-D

Calibration Block: Type 3080-83 Serial Number 109

Transducer: Size .5" dia Frequency 5MHz PC

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.341	.366	.370	.363	.378	.377	.394	.373	.369	.336	.332	.346
2	.353	.362	.367	.361	.370	.378	.390	.377	.369	.342	.335	.356
3	.351	.368	.370	.358	.373	.373	.385	.373	.370	.341	.339	.353
4	.362	.371	.379	.369	.369	.365	.382	.374	.369	.340	.337	.352
5	.352	.378	.380	.371	.370	.368	.379	.368	.365	.338	.330	.349
6	.367	.372	.380	.373	.385	.366	.378	.371	.360	.336	.341	.349
7	.369	.371	.368	.363	.370	.368	.371	.369	.352	.338	.332	.365
8	.384	.381	.366	.354	.361	.370	.378	.366	.357	.342	.344	.388
9		.385	.372	.356	.348	.369	.384	.376	.366	.352	.352	.389
10			.399	.368	.351	.365	.382	.377	.370	.357	.355	
11				.366	.344	.352	.381	.378	.379	.362		
12					.348	.347	.371	.374	.380	.373		
13						.340	.367	.379	.377			
14						.341	.366	.368	.384			
15						.343	.357	.366	.369			
16												
17												
18												
19												

Comments:

Thickness Survey

Date 6-25-84
Disc 62

Plant Monticello

Iso # MTS-15

Area 5.2 / DS 10-10"

Grid Spacing 100

Examiner(s) ASW/KLH/QL

Equipment Used UI-III

Calibration Block: Type 3080-83 Serial Number N/A

Transducer: Size 1/2" Frequency 3.5 mhz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.380	.356	.368	.360	.356	.372	.408	.368	.364	.340	.344	.340
2	.360	.360	.344	.360	.368	.356	.372	.364	.368	.356	.344	.344
3	.356	.360	.360	.356	.372	.364	.392	.396	.368	.340	.356	.344
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Thickness Survey

Date 06/26/84
Disc NA

Plant Monticello

Iso # MTS-15

Area 5.3 Entire ELbow

Grid Spacing 2"

Examiner(s) ASW/OL/KLH

Equipment Used Nortec 131-D

Calibration Block: Type 3080-83

Serial Number 269

Transducer: Size .25" Dia

Frequency 5 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	430	427	436	440	431	421	415	406	421	444	435	434
2	443	422	426	434	421	426	420	412	426	441	437	433
3	436	427	415	431	419	428	423	424	433	448	442	435
4	432	425	408	433	426			433	431	447	444	433
5	434	423	417	447						441	444	436
6	449	431	433								444	441
7	442	437									433	440
8	453	434										437
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Thickness Survey

Date 06-26-84

Disc NA

Plant Monticello

Iso # MTS-15

Area 5.4 Entire Nozzle

Grid Spacing 2"

Examiner(s) ASW/OL/KLH

Equipment Used Nortec-131-D

Calibration Block: Type 3080-83

Serial Number 269

Transducer: Size .25" Dia

Frequency 5 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.318	.263	.421	.487	.486	.496	.493	.512	.527	.487	.492	.461
2	.306	.365	.453	.487	.490	.506	.508	.523	.541	.515	.545	.551
3	.504	.433	.428	.486	.485	.500	.521	.533	.535	.526	.544	.551
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

THICKNESS SURVEY REPORT

DATE 5/16/86

DISC# N/A

PLANT MONTICELLO

ISO# MTS-15

AREA MTS-5.4

GRID SIZE N/A

EXAMINERS M. J. Longsdorf

EQUIPMENT NORTEC 131-D = 409

TRANSDUCER (SIZE/FREQ.) 1/2", 2.25 MHz, A30160

CAL. BLOCK (TYPE/SERIAL NO.) ROMPAS # LMT052

NOMINAL WALL N/A

MIN. WALL N/A

COMMENTS 0° AT INSIDE RADIUS OF ELBOW; 0° AT DOWN STREAM CIRC. WELD.
RADIUS APPEARS THICKER DUE TO GAP UNDER TRANSDUCER.

Degree	Grid	0	30	60	90	120	150	180	210	240	270	300	330
X 0"		.34	.32	.30	.29	.29	.29	.28	.29	.29	.29	.30	.32
X 1"		.32	.30	.29	.29	.28	.26	.25	.26	.28	.29	.30	.30
X 2"		.34	.31	.30	.29	.28	.24	.23	.25	.28	.28	.29	.32
X 3"		.34	.32	.30	.28	.27	.26	.27	.28	.28	.29	.30	.32
X 4"		.34	.32	.29	.28	.28	.28	.27	.28	.29	.29	.30	.32
6													
7													
8													
9													
10													
11													
12													
13													
14													
15													
16													
17													
18													
19													
20													
21													


* MINIMUM WALL = .23"
 * CALIBRATION ON ROMPAS SIDE DRILLED HOLE @
 .3" AND .7" @
 3 DIV AND 7 DIV

Thickness Survey

Date 06-26-83
Disc NA


Plant Monticello Iso # MTS-15
 Area 5.5 on FWH-14A Grid Spacing 2"
 Examiner(s) ASW/QL/KLH Equipment Used Nortec 131-D
 Calibration Block: Type 3080-83 Serial Number 269
 Transducer: Size .25" Dia Frequency 5MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.471						.474					
2	.460	.463				.464	.464					
3	.461	.460	.464	.468	.468	.462	.460					
4	.457	.461	.461	.465	.461	.463	.404					
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												



Comments:

David A
Hall



8th Stage LPA to FWH 13A
Carbon Steel
LINE E8A-20"-HA
To Heater E-13A
Ref. Dwg. NX-13142-95
POINTS 6.4A, 6.5A, & 6.6A ARE
REPLACED PIPING ON 5-19-74

ISO-MTS-16

NOTES
IESD-MTS-16

2nd Stage LP-A to FW4 13A

20"

Area	Scaffold Reg'd.	Frequency	Disc #
6.0A	NO		Nortec
6.2A	yes		666
6.3A	yes		Nortec
6.4A	yes		Nortec
6.5A	yes		Nortec
6.6A	yes		Nortec

Plant MONTICELLO

Iso # MTS-16

Area 6.0A ENTIRE ELBOW

Grid Spacing 4"

Examiner(s) ASW / ALH

Equipment Used Nortec 1310

Calibration Block: Type 3080-83

Serial Number 287

Transducer: size 1/4" dia

Frequency 5 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.410	.411	.447	.434	.439	.413	.408	.440	.421	.439	.426	.392
2	.436	.439	.445	.437	.446	.408	.397	.424	.423	.422	.446	.423
3	.476	.454	.452	.448	.451	.396	.402	.429	.455	.439	.454	.455
4	.457	.458	.449	.449	.454	.443	.401	.444	.454	.442	.452	.433
5			.469	.451	.449	.449	.387	.410	.443	.434	.457	
6				.438	.441	.421	.391	.408	.446	.433		
7				.458	.433	.395	.393	.384	.437	.423		
8				.431	.426	.386	.374	.396	.430			
9					.412	.389	.396	.392	.421			
10					.412	.406						
11						.410						
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Thickness Survey

Date 7-18-84

Disc 66

Plant MouTicello

Iso # MTS-16

Area 6.2 A

Grid Spacing 200

Examiner(s) ASW/KLH/NAM

Equipment Used UI-TII

Calibration Block: Type 3080-83 Serial Number N/A

Transducer: Size 1/2" dia Frequency 3.5 mhz P-C

	0°	30°	60°	90°	120°	150°	160°	210°	240°	270°	300°	330°
1	.404	.388	.360	.340	.312	.384	.344	.380	.360	.388	.424	.396
2	.376	.400	.392	.364	.380	.352	.356	.312	.364	.404	.408	.388
3	.392	.388	.356	.320	.360	.332	.340	.368	.376	.392	.404	.392
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

THICKNESS SURVEY REPORT

DATE 5/23/86

DISC# N/A

PLANT MONTICELLO

ISO# MTS-16

AREA MTS-6.4A

GRID SIZE N/A

EXAMINERS M.J. Langford
M.J. Langford / JT

EQUIPMENT NORTEC 131-D # 371

TRANSDUCER (SIZE/FREQ.) 1/2" @ 2.25 MHz, A70160

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

NOMINAL WALL 20" CARBON STEEL

MIN. WALL N/A

COMMENTS 0" AT T.O.C. TO AGREE WITH FORMER INSPECTION.

0" AT DOWN STREAM CIRC. WELD AT INNER RADIUS OF ELBOW

Degree	0	30	60	90	120	150	180	210	240	270	300	330
6r1d												
X 3"	.566	.589	.584	.600	.594	.592	.579	.550	.490	.486	.505	.524
X 6"	.570	.592	.646	.615	.650	.626	.592	.556	.539	.484	.480	.526
X 9"	.575	.576	.638	.636	.632	.622	.590	.556	.536	.533	.467	.537
X 12"	.563	.610	.678	.661	.628	.633	.613	.564	.545	.522	.570	.522
X 15"	.546	.562	.656	.652	.640	.627	.605	.572	.556	.531	.573	.539
X 18"	.587	.547	.639	.691	.637	.610	.607	.584	.550	.552	.511	.522
X 21"	.543	.550	.637	.660	.613	.596	.593	.552	.571	.545	.574	.520
X 24"	.556	.555	.616	.618	.649	.622	.598	.588	.573	.581	.543	.532
X 27"	.554	.580	.596	.622	.603	.598	.574	.586	.573	.576	.542	.535
X 30"	.557	.560	.610	.600	.596	.577	.580	.592	.592	.580	.543	.532
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												
21												

Low spot

467

Thickness Survey

Plant Monticello

Iso # MTS-16

Date 6-18-84

Area 6.6A ON FWH 13A

Grid Spacing 4"

Examiner(s) ASW / QL

Equipment Used Nortec 131 D


Calibration Block: Type 3080-83

Serial Number 322


Transducer: Size .25"

Frequency 5 mhz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.545					.533						
2	.523	.520	.524	.530	.533	.538						
3	.530	.516	.523	.524	.529	.535						
4	.535	.510	.518	.524	.528	.526						
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												



Drawn by Kevin Hall



10th Stage

LPA to FWH 12A

Material - C.S.
REF DWG. NX-13142-94

ISO-MTS-17 + 18

Notes

ISD-MTC-17

10th Stage LPA to FWH12A - Inboard

20

Area

scaffold Reg'd.

Frequency

Disc #

T.O

NO

Novtec

Thickness Survey

Date 7-19-84
Disc N/A

Plant Mentivello

Iso # MTS-17

Area 7.0

Grid Spacing 4"

Examiner(s) ASW / KLH

Equipment Used Nortec 131D


Calibration Block: Type 3080-83 Serial Number 287

Transducer: Size 1/4" dia Frequency 5MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.382	.376	.377	.385	.390	.392	.394	.406	.414	.403	.399	.392
2	.377	.369	.372	.377	.385	.390	.394	.400	.407	.407	.392	.388
3	.380	.368	.370	.380	.385	.388	.391	.396	.407	.402	.392	.382
4	.389	.383	.382	.393	.403	.403	.402	.400	.411	.406	.387	.387
5	.378	.385	.382	.391	.405	.401	.398	.398	.400	.401	.385	.380
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Drawn by Kevin HALL



10th Stage

LPA to FWH 12A

Material - C.S.
REF DWG. NX-13142-94

ISO-MTS-17 + 18

NOTES

ISO-14-S-12

10th stage LPA to FWH 12A Outboard

Area

Scaffold Reg'd. | Frequency

Disc #

7.1

NO

Nortec

Plant MANTICELLO
Area 7.1
Examiner(s) ASW/KLH


Iso # MTS-18
Grid Spacing 4"
Equipment Used NonTec 131D

Calibration Block: Type 3080-83 Serial Number 287-
Transducer: Size 1/4" dia Frequency 5 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.388	.385	.379	.387	.374	.393	.360	.340	.348	.357	.360	.372
2	.385	.390	.381	.364	.375	.361	.355	.338	.347	.357	.366	.368
3	.382	.388	.379	.376	.370	.368	.349	.332	.344	.388	.361	.362
4	.375	.392	.381	.379	.374	.387	.351	.342	.343	.382	.375	.357
5	.371	.388	.390	.390	.382	.382	.385	.368	.356	.384	.355	.365
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Drawn by Kevin Hall



LPA to FWH 11A
MATERIAL - C.S.
REF. DWG. NX-13142-94

ISO-MTS-19+20

NOTES

IESO - MTS - 19



12th Stage LPA to FWH IIA Inboard - 1

Area

Scaffold Reg'd | Frequency

No spot Assigned

Drawn by Kevin Hall



LPA to FWH 11A
MATERIAL - C.S.
REF. DWG. NX-13142-94

ISO-MTS-19 +20


NOTES
IESD-147C-20

12th stage LPA to FWH IIA Outboard-1 26"

Area	Scaffold Reg'd.	Frequency
------	-----------------	-----------

No Area Assigned

Drawn by Kevin Hall



12th Stage

LPA to FWH 11A

Material - C.S.
REF. DWG. NX-13142-94



ISO-MTS-21

Notes
ISO-MTS-21

12th stage LPA to FWH 11A Inboard-2 26"

Area	Scaffold Req'd.	Frequency
------	-----------------	-----------

NO AREAS ASSIGNED



12" STG. LPA TO FWH11A
26" OUTBOARD
LINE E-12-26"-HB
REF. DWG. NK-13142-94

Notes
IED - MTS - 22

12th stage LPA to FWH 11A Outboard - 2 26"

Area	Scaffold Reg'd.	Frequency	Disc #
------	-----------------	-----------	--------

8.0	NO		Nortec
-----	----	--	--------

8.1	NO		Nortec
-----	----	--	--------

8.2	NO		Nortec
-----	----	--	--------

Thickness Survey

Date 07-20-87
Disc NA

Plant Monticello
Area 8.0 Entire Elbow
Examiner(s) ASW KLH
Calibration Block: Type 3080-83
Transducer: Size .25 mm

Iso # MTS-22
Grid Spacing 4"
Equipment Used Nortec 131-D
Serial Number 287
Frequency 5 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	408	432	415	420	423	412	411	421	428	421	424	420
2	412	422	422	397	423	399	420	422	420	428	423	424
3	395	424	420	417	404	421	407	427	419	421	424	423
4			423	416	396	395	417	404	422	420	426	
5					401	396	419	419	399			
6						402	418	408				
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Thickness Survey

Date 07-20-04
Disc N/A

Plant Monticello
Area 8.1 Entire Elbow
Examiner(s) ASW KLH
Calibration Block: Type 3080-B3
Transducer: Size .25" Dia

Iso # MTS-22
Grid Spacing 4"
Equipment Used Nortec - 131-D
Serial Number 287
Frequency 5kHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	421	390	381	429	420	414	312	394	407	389	379	380
2	421	418	423	418	423	385	383	388	417	409	413	398
3	396	402	402	426	425	406	414	397	419	389	381	383
4	377	372	401	417	422	416	336	402	411	385	371	367
5	375	418	395	415	423	413	415	418	406	401	384	368
6	382	380	394	417	423	415	401	421	409	378	381	385
7	380	403	402	404	408	421	404	417	397	399	387	392
8	401	378	370	423	372	372	349	400	418	416	392	379
9	387	374	418	370	414	381	422	419	411	392	351	391
10	391	380	375	392	421	403	420	395	419	421	370	384
11		388	385	398	419	370	420	393	403	422	402	425
12			416	391	422	454	412	404	422	399	423	413
13			377	396	381	423	414	418	421	401	417	
14				388	401	458	414	414	426	433	416	
15				373	407	421	420	417	401	427		
16				382	420	421	422	420	435	395		
17					419	422	421	420	418			
18					414		437					
19												

Comments:

Thickness Survey

 Date 7-20-84

 Disc N/A

 Plant Monticello

 Iso # MTS-22

 Area 8.2 ENT. RE Elbow

 Grid Spacing 4"

 Examiner(s) ASW / KLM

 Equipment Used Nortec 131 D


 Calibration Block: Type 3080-83 Serial Number 287

 Transducer: Size 1/4" Frequency 5MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.403	.397	.390	.389	.388	.388	.362	.413	.389	.389	.388	.394
2	.459	.394	.374	.387	.397	.391	.363	.393	.390	.392	.389	.400
3	.399	.396	.364	.419	.409	.384	.360	.392	.428	.391	.386	.385
4	.406	.400	.354	.396	.400	.386	.400	.393	.394	.404	.383	.400
5	.400	.420	.352	.396	.398	.379		.402	.416	.400	.386	.402
6	.401	.400	.384	.394	.398				.385	.380	.371	.404
7	.412	.361	.353	.412	.401					.392	.386	.429
8	.423	.387	.345								.366	.401
9	.402	.417	.340								.402	.432
10	.425	.388	.337									.397
11	.442											.398
12	.383											
13	.462											
14												
15												
16												
17												
18												
19												

Comments:

David A. Hall



7th Stage LPB to FWH 14B
Carbon Steel
Line E 7B-10" -HA
To Heater E-14B
Ref. Dwg. NX-13142-96

ISO-MTS-23

NOTES

IED-MTE-23

7th Stage LDB to 14B

10"

Area	Scaffold Req'd.	Frequency	Disc #
------	-----------------	-----------	--------

S.1B	NO		NOVA 100-3
------	----	--	------------

S.2B	YES		63
------	-----	--	----

S.3B	YES		Nortec
------	-----	--	--------

S.4B	YES		Nortec
------	-----	--	--------

S.5B	YES		Nortec
------	-----	--	--------

Thickness Survey

Date 2-3-84
Disc N/A

Plant Monticello

Iso # MTS-23

Area S.1 B Entire Elbow

Grid Spacing 2"

Examiner(s) ASW/DAH

Equipment Used Norm D

Calibration Block: Type 3080-83

Serial Number 109

Transducer: Size .5" dia

Frequency 5mhz PC

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.355	.335	.330	.353	.378	.396	.393	.368	.372	.371	.370	.348
2	.349	.339	.325	.348	.372	.394	.392	.371	.374	.381	.372	.351
3	.376	.343	.325	.343	.373	.398	.386	.373	.385	.387	.373	.370
4	.364	.341	.332	.363	.364	.397	.388	.373	.393	.389	.383	.363
5	.347	.335	.347	.347	.361	.392	.379	.376	.389	.390	.388	.353
6	.332	.336	.346	.359	.362	.389	.376	.372	.374	.391	.390	.346
7	.337	.308	.336	.363	.369	.385	.376	.370	.389	.385	.383	.343
8			.331	.373	.376	.391	.373	.370	.376	.388	.372	
9			.326	.372	.398	.395	.372	.378	.380	.378	.363	
10			.315	.360	.396	.403	.372	.391	.390	.380	.371	
11				.347	.400	.413	.381	.344	.385	.381		
12					.413	.420	.401	.383	.397	.393		
13					.403	.427	.405	.397	.400			
14						.416	.403	.401				
15							.412					
16												
17												
18												
19												

Comments:

Thickness Survey

 Date 6-25-84

 Disc 63

 Plant Monticello

 Iso # MTS-23

 Area 5.2B/D5/0-10"

 Grid Spacing 80

 Examiner(s) ASW/KLH/QL

 Equipment Used UI-III

 Calibration Block: Type 3090-83 Serial Number N/A

 Transducer: Size 1/2" dia. Frequency 3.5 mhz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.342	.372	.376	.360	.344	.344	.348	.360	.356	.360	.356	.364
2	.356	.356	.348	.332	.348	.368	.360	.356	.360	.360	.352	.344
3	.344	.356	.340	.356	.360	.364	.356	.356	.360	.340	.340	.340
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

THICKNESS SURVEY

Date 6-16-84
Disc N/A

Plant MONTICELLO

Iso # MTS-23

Area 5.3 B ENTIRE ELBOW

Grid Spacing 2"

Examiner(s) ASW/RL/KLH

Equipment Used NonTec 131D

Calibration Block: Type 3080-83 Serial Number 264

Transducer: Size .25" dia Frequency 5MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.393	.406	.403	.410	.385	.381	.395	.404	.402	.394	.388	.398
2	.399	.412	.437	.397	.385	.379	.385	.424	.422	.391	.390	.409
3	.409	.411	.398	.387	.370	.373	.389	.393	.439	.397	.392	.420
4	.398	.404	.408	.377					.392	.390	.386	.422
5	.387	.388	.391	.382								.395
6	.377	.385	.385									.395
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Plant Monticello

Iso # MTS-23

Area 5.4 B Entire Nozzle

Grid Spacing 2"

Examiner(s) ASW/QL/KLH

Equipment Used Nortec-131-D

Calibration Block: Type 3080-83

Serial Number 269

Transducer: Size 25" Dia


Frequency 5 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.377	.462	.444	.468	.482	.502	.502	.524	.500	.475	.504	.408
2	.375	.378	.425	.377	.409	.355	.460	.420	.446	.506	.573	.429
3	.429	.458	.464	.437	.414	.370	.374	.434	.466	.425	.505	.462
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:


Plant Monticello Iso # MTS-23
 Area 5.58 FWH-14B on base of Grid Spacing 2"
 Examiner(s) ASW / QL / KLH Equipment Used Nortec - 131-D
 Calibration Block: Type 3080-83 Serial Number 269
 Transducer: Size .25" Dia Frequency 5mhz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.497						.493					
2	.488	.490				.490	.481					
3	.484	.483	.487	.493	.492	.490	.483					
4	.481	.484	.488	.491	.491	.491	.484					
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												



Comments:

X - Denotes Hanger



8th Stage LPB to FWH-13B - (Carbon Steel)
Line E8B-20'-HA to Heater E-13B
Ref. Dwg. NX-13142-95

IED-ME-24

2nd stage LPZ to FWH 13B

Area	Scaffold Reg'd.	Frequency	Disc #
6.0	No		Nortec
6.1	NO		Nortec
6.2	yes		36
6.3	yes		Nortec
6.4	yes		37
6.5	yes		Nortec
6.6	yes		Nortec

DATE 1-27-84
 Disc NIA

Plant Monticello

Iso # MTS-24

Area 6.0 Entire Elbow

Grid Spacing 4"

Examiner(s) ASW/KLH/VJB

Equipment Used NOTEC 131D

Calibration Block: Type 3080-83

Serial Number 417

Transducer: Size 1/4" dia

Frequency 5MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.490	.495	.494	.459	.456	.462	.445	.422	.434	.423	.488	.514
2	.499	.440	.473	.441	.458	.463	.462	.412	.444	.463	.492	.505
3	.499	.476	.494	.467	.445	.443	.440	.426	.444	.499	.507	.477
4	.499	.464	.455	.468	.445	.442	.462	.441	.476	.495	.473	.437
5	.451	.461	.477	.474	.477	.446	.464	.436	.461	.442	.472	.468
6				.442	.471	.451	.461	.444	.403	.426	.488	
7				.443	.473	.460	.427	.425	.401	.450		
8					.466	.450	.428	.423	.385	.451		
9					.460	.463		.463	.400	.467		
10						.443		.429				
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Plant Monticello
Area 6.1

Iso # 24

Examiner(s) ASW JEB KLH

Grid Spacing 4"

Calibration Block: Type 3080-83

Equipment Used Nortec 131-D

Transducer: Size .25" Dia

Serial Number 417

Frequency 5 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.371	.402	.391	.385	.404	.416	.437	.427	.410	.385	.388	.371
2	.387	.398	.403	.386	.407	.413	.430	.439	.417	.374	.377	.367
3	.405	.402	.404	.412	.424	.429	.441	.436	.397	.376	.377	.384
4	.394	.403	.424	.404	.419	.424	.425	.423	.400	.368	.388	.380
5	.386	.408	.418	.416	.423	.419	.415	.420	.389	.383	.398	.393
6	.406	.399	.424	.413	.411	.414	.420	.410	.402	.382	.394	.389
7	.397	.441	.398	.397	.412	.395	.410	.412	.405	.376	.400	.391
8	.400	.430	.413	.400	.395	.411	.414	.418	.409	.385	.397	.389
9		.398	.395	.388	.410	.403	.417	.408	.412	.379	.400	.384
10			.397	.400	.401	.416	.404	.417	.404	.381		.395
11			.399	.422	.412	.420	.447	.418	.415	.385		
12					.405	.426	.415	.417	.405			
13					.423	.418	.432	.433	.402			
14						.414	.429	.425	.403			
15						.419	.427	.427	.398			
16						.431	.446	.430				
17						.457						
18												
19												

Comments:

Plant Monticello

Iso # MTS-24

Area 6.2 / US / 0-10

Grid Spacing 4"

Examiner(s) DAH / QL / KLH

Equipment Used UI III

Calibration Block: Type 3080-83

Serial Number NA

Transducer: Size .5" Dia

Frequency 5 MHz

	0°	30°	60°	90°	120°	150°	160°	210°	240°	270°	300°	330°
1	.360	.376	.384	.380	.388	.404	.388	.380	.380	.372	.384	.360
2	.368	.320	.384	.380	.312	.396	.288	.380	.372	.376	.380	.360
3	.372	.320	.400	.380	.376	.388	.388	.380	.368	.396	.360	.376
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Plant MonTiello

Iso # MTS-24

Area 6.3 Entire Elbow

Grid Spacing 4"

Examiner(s) D. Hall & Loreda

Equipment Used NonTec 1310

Calibration Block: Type 3080-53

Serial Number 322

Transducer: Size 5" dia

Frequency 2.25 mhz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.406	.416	.422	.410	.422	.426	.427	.431	.444	.432	.412	.403
2	.405	.424	.433	.427	.427	.433	.432	.430	.443	.419	.400	.405
3	.412	.415	.435	.438	.421	.428	.438	.440	.442	.428	.412	.412
4	.423	.424	.440	.431	.419	.432	.425	.432	.434	.418	.405	.413
5	.409	.430	.437	.427	.406	.429	.432	.428	.433	.426	.415	.407
6	.405	.420	.436	.426	.412	.417	.413	.438	.438	.423	.410	.413
7	.396	.414	.428	.415	.405	.415	.426	.434	.451	.432	.448	.405
8	.395	.407	.416	.416	.431	.417	.420	.442	.454	.428	.408	.407
9	.390	.408	.427	.422	.408	.418	.439	.453	.452	.427	.397	.388
10	.408	.423	.413	.419	.414	.424	.438	.451	.447	.424	.402	.411
11	.398	.420	.431	.414	.416	.405	.431	.453	.446	.424	.401	.400
12	.404	.428	.402	.393	.391	.403	.421	.438	.449	.434	.433	.424
13												
14												
15												
16												
17												
18												
19												

Comments:

Thickness Survey

Date 5-12-84
Disc 37

Plant Mantecello
Area 6.4 / US / 0-10"
Examiner(s) DAH / QL / KLT
Calibration Block: Type 3080.83
Transducer: Size .5" dia

Iso # MTS-24
Grid Spacing 200
Equipment Used US-377
Serial Number N/A
Frequency 5MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.628	.620	.612	.600	.600	.600	.604	.620	.644	.644	.652	.640
2	.628	.620	.612	.604	.600	.600	.600	.616	.632	.644	.644	.632
3	.632	.624	.620	.604	.620	.546	.604	.616	.628	.636	.648	.644
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:


Plant MONTICELLO
Area 6.5, 6.6 ENTIRE ELBOW
Examiner(s) D.HALL - Q. LOREDO
Calibration Block: Type S.W. 3080-83
Transducer: Size .5" Ø

Iso # MTS24
Grid Spacing 4"
Equipment Used NORTEC 131-D
Serial Number 322
Frequency 2.25 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.446	.426	.398	.391	.411	.436	.429	.422	.385	.424	.431	.437
2	.448	.428	.394	.386	.406	.442	.440	.409	.396	.415	.434	.439
3	.461	.448	.406	.382	.426	.455	.446	.420	.424	.410	.436	.454
4	.456	.450	.401	.401	.402	.456	.448	.427	.400	.405	.436	.454
5	.469	.442	.385	.404	.415	.449	.423	.435	.404	.404	.437	.465
6	.443	.436	.398	.422	.418	.443	.415	.416	.406	.386	.426	.460
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

by Kevin HALL



10 th Stage
LPB To FWH 12B
MATERIAL - C.S.
REF. DWG. NX-13142-94

ISO-MTS - 25 + 26

ISO-MTS-25

10th stage LP B to FWH 12 B Inboard 20'

Area	Scaffold Req'd.	Frequency	Disc #
------	-----------------	-----------	--------

7.0R	NO		Nortec
------	----	--	--------

7.1A	NO		Nortec
------	----	--	--------

Date 7-24-84
Disc N/A

Plant Monticello
Area 7.0A

Survey
Iso # MTS-25
Grid Spacing 4"

Examiner(s) ASW/KLH/JEP
Equipment Used NonTec 131D
Calibration Block: Type 3080-83 Serial Number 417
Transducer: Size 4" dia Frequency 5mhz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.389	.393	.408	.405	.374	.375	.344	.354	.344	.371	.364	.370
2	.384	.393	.398	.411	.385	.368	.344	.345	.344	.351	.361	.371
3	.378	.398	.400	.395	.371	.375	.398	.345	.354	.350	.360	.372
4	.376	.390	.407	.394	.403	.369	.362	.353	.351	.348	.361	.386
5	.374	.386	.395	.391	.387	.362	.364	.347	.342	.344	.355	.377
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Date 7-24-84
Disc N/A



Plant MONTICELLO
Area 7.1 A
Examiner(s) ASW/KLH/JEB
Calibration Block: Type 3080-83
Transducer: Size .25" dia

Iso # MTS-25
Grid Spacing 3"
Equipment Used MoTea 131D
Serial Number 417
Frequency 5 mhz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.512	.524	.542	.475	.527	.452	.480	.548	.518	.536	.512	.518
2	.558	.559	.567	.546	.562	.544	.562	.537	.548	.550	.526	.556
3	.606	.562	.562	.542	.471	.468	.519	.442	.571	.562	.539	.550
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

by Kevin HALL



LPB To FWH 12B
MATERIAL - C.S. REF. DWG. NX-13142-94

ISO-MTS - 25 + 26


NOTES
IESD - MTS - 26

10th Stage LP-B to FWH 12B Outboard 20'

Area Scaffold Reg'd. | Frequency

No Area Assigned

Drawn by Kevin Hall



ISO - MTS - 27, 28, + 29

NOTES


ISO-MTS-27

12th stage LP-3 5 FW4 11B Inboard 1 26"

Area

Scaffold Reg'd. | Frequency

No. Assigned



ISO - MTS - 27, 28, + 29

NOTES


IED-MTB-27

12th Stage LPB to FWHIB Outboard 1

Area	Scaffold Reg'd.	Frequency
------	-----------------	-----------

No Area Assigned

Drawn by Kevin Hall



ISO - MTS - 27, 28, + 29

Notes
I 20-MTS-29

12th Stage LPB to FWH 11B Inboard 2 26"


Area

Scaffold Reg'd. | Frequency

No. Assigned

Assigned

Drawn by Kevin Hall



12th stage

LPB to FWH 11B OUTBOARD

MATERIAL - C.S.
REF. DWG. NY-13142-94

ISO-MTS-30

NOTES

IESD-MTE-3D

12th stage LDB to FW4 11B Outboard-2

26"

Area	Scaffold Reg'd.	Frequency	Disc #
------	-----------------	-----------	--------

2.0A	NO		Nortec
------	----	--	--------

8.1A	NO		Nortec
------	----	--	--------

8.2A	NO		Nortec
------	----	--	--------

Date 07-25-84
Disc. NA

Plant Monticello

Iso # 30

Area B.O.A Entire Elbow

Grid Spacing 4"

Examiner(s) ASW, JEB, KLT

Equipment Used Nortec 131-D

Calibration Block: Type 3080-83

Serial Number 417

Transducer: Size 25" Dia

Frequency 5 MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	.412	.422	.415	.432	.428	.422	.436	.414	.434	.396	.434	.438
2	.354	.397	.382	.434	.438	.419	.433	.402	.404	.397	.401	.418
3	.363	.403	.434	.432	.437	.436	.437	.407	.395	.380	.436	.404
4			.440	.438	.427	.419	.438	.419	.380	.422	.434	.410
5					.422	.431	.434	.436	.377	.416	.412	
6						.428	.409	.361				
7							.435					
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

Date 07-25-84
Disc NA

Plant Monticello
Area 8.1 A Entire Elbow

Iso # 30
Grid Spacing 4"

Examiner(s) ASW, JEB, KLT Equipment Used Nortec 131-D

Calibration Block: Type 3080-83 Serial Number 417

Transducer: Size 25" Dia Frequency 5MHz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	398	430	440	415	434	423	442	456	438	448	443	457
2	415	432	433	451	430	444	467	432	440	480	443	448
3	416	446	440	448	428	424	463	466	442	447	440	450
4	398	435	448	427	459	421	458	438	454	445	448	478
5	395	427	451	432	430	458	460	468	430	457	479	446
6	403	441	445	432	443	455	461	440	436	443	447	444
7	400	437	444	426	445	429	483	439	453	455	449	443
8	425	447	436	429	441	448	460	442	426	449	441	450
9	419	438	459	428	427	431	442	430	451	447	445	444
10	422	440	473	428	430	438	463	438	436	448	447	451
11			437	428	428	445	445	444	458	446	435	
12				428	425	453	472	449	439	435	433	
13				429	447	456	463	445	424	442		
14				442	433	460	442	445	428	464		
15				446		464	439	444	441			
16				446		447	448	440	437			
17							460	447	422			
18							441					
19							448					

Comments:

Plant Monticello

Iso # MTS-30

Area 8.2A ENTIRE ELBOW

Grid Spacing 4"

Examiner(s) ASW/ALH/JEB

Equipment Used NoTEC 131D

Calibration Block: Type 3080-83

Serial Number 417


Transducer: Size 1/4" dia

Frequency 5 mhz

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
1	406	400	392	415	404	411	373	422	405	402	408	427
2	432	406	397	394	402	426	355	439	421	403	401	386
3	379	393	419	381	400	404	374	423	416	404	354	398
4	413	400	371	391	418	398	402	410	419	413	410	400
5	437	400	434	422	399	414	401	435	377	390	399	413
6	378	424	372	424	405					400	399	398
7	395	417	351	396	415					337	395	363
8	426	393	338	372						347	400	344
9	407	409	387	400								
10	377											
11												
12												
13												
14												
15												
16												
17												
18												
19												

Comments:

N
X - HANGER



HTR. 12A & EL. 935'-5"

C.I.V. 1015

13 HTR. STA. SIDE
DMP TO COND.

HTR. 13A

LINE HD5-10" HB

FWH 13A TO FWH
12 A DRAIN LINE
10" CARBON STEEL
REF. DWG. NX-12142-119

ISO-MTS-31

Notes

IED-MTS-31

FWH 13A to FWH 12R Drain

10"

Area

Scaffold Reg'd. | Frequency

No. assigned

assigned

EPRI'S CHEC COMPUTER PROGRAM - VERSION 1 - 9/ 8/1987
NORTHERN STATES POWER COMPANY

18: 4: 7

INPUT FILE NAME cmonts31

OUTPUT FILE NAME a:cmonts31.ou2

BOUNDING LEVEL = 90 %

NUMBER OF CASES = 1

MONTICELLO THICKNESS SUR. #31

CASE = 1 NCHEM = 1 TOTAL TIME = 110000. NSEG = 1

ICHEM	FMULT	PH	OXY	HOURS
0	100.000	7.100	1000.0	110000.

NCOMP = 16 DESIGN PRESS.= 23. DESIGN TEMP.= 241.

MONTICELLO THICKNESS SUR. #31

GEO (SECOND LINE)	MAT	COMP. NAME CR	DIA CU	THICK MO	TEMP SIGMA	FLOW
9	5	31 P1	10.	.365	241.	-8.000
4	5	31 E1	10.	.365	241.	-8.000
9	5	31 P2	10.	.365	241.	-8.000
4	5	31 E2	10.	.365	241.	-8.000
14	5	31 T1	10.	.365	241.	-8.000
9	5	31 P3	10.	.365	241.	-8.000
2	5	31 E3	10.	.365	241.	-8.000
9	5	31 P4	10.	.365	241.	-8.000
2	5	31 E4	10.	.365	241.	-8.000
9	5	31 P5	10.	.365	241.	-8.000
4	5	31 E5	10.	.365	241.	-8.000
9	5	31 P6	10.	.365	241.	-8.000
9	5	16.0A	10.	.365	241.	-8.000
4	5	31 E6	10.	.365	241.	-8.000
9	5	31 P8	10.	.365	241.	-8.000
8	5	31 V1	10.	.365	241.	-8.000

MONTICELLO THICKNESS SUR. #31

PASS 2 DATA
NUMBER OF INSPECTIONS = 16

NUMBER	COMP	MEASURED THICKNESS
1	31 P1	.365
2	31 E1	.365
3	31 P2	.365
4	31 E2	.365
5	31 T1	.365
6	31 P3	.365
7	31 E3	.365
8	31 P4	.365
9	31 E4	.365
10	31 P5	.365
11	31 E5	.365
12	31 P6	.365
13	16.0A	.365
14	31 E6	.365
15	31 P8	.365
16	31 V1	.365

MONTICELLO THICKNESS SUR. #31

PASS 2 RESULTS AT 90% BOUNDING LEVEL
COMPONENT PREDICTED AVERAGE
EROSION RATE (MM/YR)

31 E1	.01
31 E2	.01
31 E5	.01
31 E6	.01
31 T1	.01
31 V1	.01
31 E3	.00
31 E4	.00
31 P1	.00
31 P2	.00
31 P3	.00
31 P4	.00
31 P5	.00
31 P6	.00
16.0A	.00
31 P8	.00

NOTE:
THE AVERAGE EROSION RATE FOR EACH COMPONENT IS CALCULATED
USING THE MAXIMUM TOTAL TIME FOR THE PROBLEM

MONTICELLO THICKNESS SUR. #31

PASS 2 RESULTS AT 90% BOUNDING LEVEL
COMPONENT PREDICTED HOURS TO REACH
MINIMUM WALL THICKNESS


31 E1	5629689.
31 E2	5629689.
31 E5	5629689.
31 E6	5629689.
31 T1	6777627.
31 V1	6777627.
31 E3	11369380.
31 E4	11369380.
31 P1	34328140.
31 P2	34328140.
31 P3	34328140.
31 P4	34328140.
31 P5	34328140.
31 P6	34328140.
16.OA	34328140.
31 P8	34328140.

WARNING:
THE DESIGN MINIMUM WALL THICKNESS USED IN PREDICTING TOTAL HOURS IS BASED ON
DESIGN PRESSURE ONLY. UTILITIES MUST PERFORM PLANT SPECIFIC ENGINEERING
EVALUATIONS THAT INCLUDE ALL LOADS TO PREDICT TOTAL HOURS BEFORE A FAILURE
WOULD OCCUR.

MONTICELLO THICKNESS SUR. #31

PASS 2 RESULTS AT 90% BOUNDING LEVEL

COMPONENT	PREDICTED THICKNESS (INCH)	PREDICTED WEAR (INCH)	LATEST EROSION RATE (MM/YEAR)	MINIMUM WALL THICKNESS (INCH)
31 P1	.364	.001	.00	.008
31 E1	.358	.007	.01	.008
31 P2	.364	.001	.00	.008
31 E2	.358	.007	.01	.008
31 T1	.359	.006	.01	.008
31 P3	.364	.001	.00	.008
31 E3	.362	.003	.00	.008
31 P4	.364	.001	.00	.008
31 E4	.362	.003	.00	.008
31 P5	.364	.001	.00	.008
31 E5	.358	.007	.01	.008
31 P6	.364	.001	.00	.008
16.0A	.364	.001	.00	.008
31 E6	.358	.007	.01	.008
31 P8	.364	.001	.00	.008
31 V1	.359	.006	.01	.008



THICKNESS SURVEY REF. DWNG.

MONTS32

NOTES

IESD-MTS-32

FWH 11A 5 Center between FWH 11A + 12A

12"

Area

Scaffold Reg'd. | Frequency

No. Assigned

INPUT FILE NAME cmonts32

OUTPUT FILE NAME a:cmonts32.ou2

BOUNDING LEVEL = 90 %
NUMBER OF CASES = 1

MONTICELLO THICKNESS SUR.# 32

CASE = 1 NCHEM = 1 TOTAL TIME = 110000. NSEG = 1

ICHEM	FMULT	PH	OXY	HOURS
0	100.000	7.100	1000.0	110000.

NCOMP = 16 DESIGN PRESS.= 8. DESIGN TEMP.= 178.

MONTICELLO THICKNESS SUR.# 32

GEO (SECOND LINE)	MAT	COMP. NAME CR	DIA CU	THICK MO	TEMP SIGMA	FLOW
9	5	32 P1	12.	.375	178.	-6.000
4	5	32 E1	12.	.375	178.	-6.000
8	5	32 V1	12.	.375	178.	-6.000
9	5	32 P3	12.	.375	178.	-6.000
4	5	32 E2	12.	.375	178.	-6.000
9	5	32 P4	12.	.375	178.	-6.000
2	5	32 E3	12.	.375	178.	-6.000
4	5	32 E4	12.	.375	178.	-6.000
9	5	32 P6	12.	.375	178.	-6.000
13	5	32 T1	12.	.375	178.	-6.000
1	5	32 E5	12.	.375	178.	-6.000
9	5	32 P8	12.	.375	178.	-6.000
1	5	32 E6	12.	.375	178.	-6.000
9	5	32 P9	12.	.375	178.	-6.000
9	5	15.0A	12.	.375	178.	-6.000
9	5	32 P7	12.	.375	178.	-6.000

MONTICELLO THICKNESS SUR.# 32

PASS 2 DATA
NUMBER OF INSPECTIONS = 16

NUMBER	COMP	MEASURED THICKNESS
1	32 P1	.375
2	32 E1	.375
3	32 V1	.375
4	32 P3	.375
5	32 E2	.375
6	32 P4	.375
7	32 E3	.375
8	32 E4	.375
9	32 P6	.375
10	32 T1	.375
11	32 E5	.375
12	32 P8	.375
13	32 E6	.375
14	32 P9	.375
15	15.0A	.375
16	32 P7	.375

MONTICELLO THICKNESS SUR.# 32

PASS 2 RESULTS AT 90% BOUNDING LEVEL
COMPONENT PREDICTED AVERAGE
EROSION RATE (MM/YR)

32 E1	.00
32 E2	.00
32 E4	.00
32 V1	.00
32 T1	.00
32 E3	.00
32 E5	.00
32 E6	.00
32 P1	.00
32 P3	.00
32 P4	.00
32 P6	.00
32 P8	.00
32 P9	.00
15.0A	.00
32 P7	.00

NOTE:
THE AVERAGE EROSION RATE FOR EACH COMPONENT IS CALCULATED
USING THE MAXIMUM TOTAL TIME FOR THE PROBLEM

MONTICELLO THICKNESS SUR.# 32

PASS 2 RESULTS AT 90% BOUNDING LEVEL
COMPONENT PREDICTED HOURS TO REACH
MINIMUM WALL THICKNESS

32 E1	11687080.
32 E2	11687080.
32 E4	11687080.
32 V1	14046500.
32 T1	14046500.
32 E3	23484160.
32 E5	47078320.
32 E6	47078320.
32 P1	70672490.
32 P3	70672490.
32 P4	70672490.
32 P6	70672490.
32 P8	70672490.
32 P9	70672490.
15.0A	70672490.
32 P7	70672490.


WARNING:

THE DESIGN MINIMUM WALL THICKNESS USED IN PREDICTING TOTAL HOURS IS BASED ON DESIGN PRESSURE ONLY. UTILITIES MUST PERFORM PLANT SPECIFIC ENGINEERING EVALUATIONS THAT INCLUDE ALL LOADS TO PREDICT TOTAL HOURS BEFORE A FAILURE WOULD OCCUR.

MONTICELLO THICKNESS SUR.# 32

PASS 2 RESULTS AT 90% BOUNDING LEVEL

COMPONENT	PREDICTED THICKNESS (INCH)	PREDICTED WEAR (INCH)	LATEST EROSION RATE (MM/YEAR)	MINIMUM WALL THICKNESS (INCH)
32 P1	.374	.000	.00	.003
32 E1	.372	.003	.00	.003
32 V1	.372	.003	.00	.003
32 P3	.374	.000	.00	.003
32 E2	.372	.003	.00	.003
32 P4	.374	.000	.00	.003
32 E3	.373	.002	.00	.003
32 E4	.372	.003	.00	.003
32 P6	.374	.000	.00	.003
32 T1	.372	.003	.00	.003
32 E5	.374	.000	.00	.003
32 P8	.374	.000	.00	.003
32 E6	.374	.000	.00	.003
32 P9	.374	.000	.00	.003
15.0A	.374	.000	.00	.003
32 P7	.374	.000	.00	.003



HTR 12B @ EL. 935'-5"

9-15B

LINE HD-13-10-HB1

EL. 931'-13/16"

COND. E 1B

HEATER
13B
@ EL. 934'-0"

HTR 13B TO HTR
12B DRAIN
CARBON STEEL
REF. DWG. NX 1242-10

ISO-MTS-33

NOTES
IED-MTS-33

FWH 12B to FWH 12B Drain

10"

Area

Scaffold Reg'd. | Frequency

No #

Assigned

INPUT FILE NAME cmonts33

OUTPUT FILE NAME a:cmonts33.ou2

BOUNDING LEVEL = 90 %
NUMBER OF CASES = 1

MONTICELLO THICKNESS SUR. #33

CASE = 1 NCHEM = 1 TOTAL TIME = 110000. NSEG = 1

ICHEM	FMULT	PH	OXY	HOURS
0	100.000	7.100	1000.0	110000.

NCOMP = 19 DESIGN PRESS.= 8. DESIGN TEMP.= 241.

MONTICELLO THICKNESS SUR. #33

GEO (SECOND LINE)	MAT	COMP. NAME CR	DIA CU	THICK MO	TEMP SIGMA	FLOW
9	5	33 P1	10.	.365	241.	-8.000
4	5	33 E1	10.	.365	241.	-8.000
9	5	33 P2	10.	.365	241.	-8.000
4	5	33 E2	10.	.365	241.	-8.000
9	5	33 P3	10.	.365	241.	-8.000
2	5	33 E3	10.	.365	241.	-8.000
9	5	33 P4	10.	.365	241.	-8.000
2	5	33 E4	10.	.365	241.	-8.000
9	5	33 P5	10.	.365	241.	-8.000
14	5	33 T1	10.	.365	241.	-8.000
9	5	33 P6	10.	.365	241.	-8.000
4	5	16B	10.	.365	241.	-8.000
14	5	33 T2	10.	.365	241.	-8.000
8	5	33 V1	10.	.365	241.	-8.000
9	5	33 P7	10.	.365	241.	-8.000
1	5	33 E5	10.	.365	241.	-8.000
9	5	33 P8	10.	.365	241.	-8.000
2	5	33 E6	10.	.365	241.	-8.000
9	5	33 P9	10.	.365	241.	-8.000

MONTICELLO THICKNESS SUR. #33

PASS 2 DATA
NUMBER OF INSPECTIONS = 19

NUMBER	COMP	MEASURED THICKNESS
1	33 P1	.365
2	33 E1	.365
3	33 P2	.365
4	33 E2	.365
5	33 P3	.365
6	33 E3	.365
7	33 P4	.365
8	33 E4	.365
9	33 P5	.365
10	33 T1	.365
11	33 P6	.365
12	16B	.365
13	33 T2	.365
14	33 V1	.365
15	33 P7	.365
16	33 E5	.365
17	33 P8	.365
18	33 E6	.365
19	33 P9	.365

MONTICELLO THICKNESS SUR. #33

PASS 2 RESULTS AT 90% BOUNDING LEVEL
COMPONENT PREDICTED AVERAGE
EROSION RATE (MM/YR)

33 E1	.01
33 E2	.01
16B	.01
33 T1	.01
33 T2	.01
33 V1	.01
33 E3	.00
33 E4	.00
33 E6	.00
33 E5	.00
33 P1	.00
33 P2	.00
33 P3	.00
33 P4	.00
33 P5	.00
33 P6	.00
33 P7	.00
33 P8	.00
33 P9	.00

NOTE:
THE AVERAGE EROSION RATE FOR EACH COMPONENT IS CALCULATED
USING THE MAXIMUM TOTAL TIME FOR THE PROBLEM

MONTICELLO THICKNESS SUR. #33

PASS 2 RESULTS AT 90% BOUNDING LEVEL
COMPONENT PREDICTED HOURS TO REACH
MINIMUM WALL THICKNESS

33 E1	5716092.
33 E2	5716092.
16B	5716092.
33 T1	6881310.
33 T2	6881310.
33 V1	6881310.
33 E3	11542180.
33 E4	11542180.
33 E6	11542180.
33 E5	23194370.
33 P1	34846550.
33 P2	34846550.
33 P3	34846550.
33 P4	34846550.
33 P5	34846550.
33 P6	34846550.
33 P7	34846550.
33 P8	34846550.
33 P9	34846550.

WARNING:


THE DESIGN MINIMUM WALL THICKNESS USED IN PREDICTING TOTAL HOURS IS BASED ON DESIGN PRESSURE ONLY. UTILITIES MUST PERFORM PLANT SPECIFIC ENGINEERING EVALUATIONS THAT INCLUDE ALL LOADS TO PREDICT TOTAL HOURS BEFORE A FAILURE WOULD OCCUR.

MONTICELLO THICKNESS SUR. #33

PASS 2 RESULTS AT 90% BOUNDING LEVEL

COMPONENT	PREDICTED THICKNESS (INCH)	PREDICTED WEAR (INCH)	LATEST EROSION RATE (MM/YEAR)	MINIMUM WALL THICKNESS (INCH)
33 P1	.364	.001	.00	.003
33 E1	.358	.007	.01	.003
33 P2	.364	.001	.00	.003
33 E2	.358	.007	.01	.003
33 P3	.364	.001	.00	.003
33 E3	.362	.003	.00	.003
33 P4	.364	.001	.00	.003
33 E4	.362	.003	.00	.003
33 P5	.364	.001	.00	.003
33 T1	.359	.006	.01	.003
33 P6	.364	.001	.00	.003
16B	.358	.007	.01	.003
33 T2	.359	.006	.01	.003
33 V1	.359	.006	.01	.003
33 P7	.364	.001	.00	.003
33 E5	.363	.002	.00	.003
33 P8	.364	.001	.00	.003
33 E6	.362	.003	.00	.003
33 P9	.364	.001	.00	.003

FWH 11 B TO COOLER
FWH 11B & FWH 12B
MATERIAL C.S.
REF. DWG:
NX-13142-117



THICKNESS SURVEY REF. DWNG.

MONTS34

Notes

IED-MTS-34

FWH 11B to Cooler between FWH 11B to FWH 12B

12"

Area

Scaffold Reg'd. | Frequency

ISO

Assigned

INPUT FILE NAME cmonts34

OUTPUT FILE NAME a:cmonts34.ou2

BOUNDING LEVEL = 90 %

NUMBER OF CASES = 1

MONTICELLO THICKNESS SUR. #34

CASE = 1 NCHEM = 1 TOTAL TIME = 110000. NSEG = 1

ICHEM	FMULT	PH	OXY	HOURS
0	100.000	7.000	1000.0	110000.

NCOMP = 10 DESIGN PRESS.= 8. DESIGN TEMP.= 178.

MONTICELLO THICKNESS SUR. #34

GEO (SECOND LINE)	MAT	COMP. NAME CR	DIA CU	THICK MO	TEMP SIGMA	FLOW
9	5	15.0B	12.	.375	178.	-6.000
8	5	34 V1	12.	.375	178.	-6.000
9	5	34 P3	12.	.375	178.	-6.000
2	5	34 E3	12.	.375	178.	-6.000
9	5	34 P2	12.	.375	178.	-6.000
4	5	34 E1	12.	.375	178.	-6.000
4	5	34 E2	12.	.375	178.	-6.000
9	5	34 P1	12.	.375	178.	-6.000
9	5	34FILL	12.	.375	178.	-6.000
9	5	34FILL2	12.	.375	178.	-6.000

MONTICELLO THICKNESS SUR. #34

PASS 2 DATA
NUMBER OF INSPECTIONS = 10

NUMBER	COMP	MEASURED THICKNESS
1	15.0B	.375
2	34 V1	.375
3	34 P3	.375
4	34 E3	.375
5	34 P2	.375
6	34 E1	.375
7	34 E2	.375
8	34 P1	.375
9	34FILL	.375
10	34FILL2	.375

MONTICELLO THICKNESS SUR. #34

PASS 2 RESULTS AT 90% BOUNDING LEVEL
COMPONENT PREDICTED AVERAGE
EROSION RATE (MM/YR)

34 E1	.00
34 E2	.00
34 V1	.00
34 E3	.00
15.0B	.00
34 P3	.00
34 P2	.00
34 P1	.00
34FILL	.00
34FILL2	.00

NOTE:

THE AVERAGE EROSION RATE FOR EACH COMPONENT IS CALCULATED
USING THE MAXIMUM TOTAL TIME FOR THE PROBLEM

MONTICELLO THICKNESS SUR. #34

PASS 2 RESULTS AT 90% BOUNDING LEVEL
COMPONENT PREDICTED HOURS TO REACH
MINIMUM WALL THICKNESS

34 E1	11687080.
34 E2	11687080.
34 V1	14046500.
34 E3	23484160.
15.0B	70672490.
34 P3	70672490.
34 P2	70672490.
34 P1	70672490.
34FILL	70672490.
34FILL2	70672490.

WARNING:

THE DESIGN MINIMUM WALL THICKNESS USED IN PREDICTING TOTAL HOURS IS BASED ON DESIGN PRESSURE ONLY. UTILITIES MUST PERFORM PLANT SPECIFIC ENGINEERING EVALUATIONS THAT INCLUDE ALL LOADS TO PREDICT TOTAL HOURS BEFORE A FAILURE WOULD OCCUR.

MONTICELLO THICKNESS SUR. #34

PASS 2 RESULTS AT 90% BOUNDING LEVEL

COMPONENT	PREDICTED THICKNESS (INCH)	PREDICTED WEAR (INCH)	LATEST EROSION RATE (MM/YEAR)	MINIMUM WALL THICKNESS (INCH)
15.0B	.374	.000	.00	.003
34 V1	.372	.003	.00	.003
34 P3	.374	.000	.00	.003
34 E3	.373	.002	.00	.003
34 P2	.374	.000	.00	.003
34 E1	.372	.003	.00	.003
34 E2	.372	.003	.00	.003
34 P1	.374	.000	.00	.003
34FILL	.374	.000	.00	.003
34FILL2	.374	.000	.00	.003

THICKNESS SURVEY REPORT

DATE 5-22-86

DISC# 78

PLANT MONTICELLO

ISO# MTS-35

AREA 11.A1

GRID SIZE 200

EXAMINERS STEVE STANFORD II / BILL BASS I / SCOTT WALL I

EQUIPMENT ULTRA IMAGE III

TRANSDUCER (SIZE/FREQ.) .25" / 10 MHz.

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

NOMINAL WALL .937"

MIN. WALL _____

COMMENTS _____

X Degree	Grid		0		30		60		90		120		150		180		210		240		270		300		330		360	
	Y	Grid	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	
0	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
10	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
20	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
30	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
40	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
50	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
60	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
70	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
80	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
90	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
100	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
110	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
120	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
130	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
140	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
150	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
160	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
170	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
180	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
190	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
200	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890
210	0	162	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890	.890

LOWEST AREA - .840
0°-180° - X-166, Y-8

THICKNESS SURVEY REPORT

DATE 5-27-86

DISC# 81

CLIENT MONTICELLO

ISO# MTS-35

AREA 11. A2

GRID SIZE 200

EXAMINERS STEVE STANFORD II / AW BOSSI / S.G. HALL I

EQUIPMENT ULTRA IMAGE III

TRANSDUCER (SIZE/FREQ.) .25" / 10 MHz.

CAL. BLOCK (TYPE/SERIAL NO.) STEPWEDGE 3080-03

NOMINAL WALL 1.037"

MIN. WALL _____

COMMENTS _____

X Degree	Y Grid	0	30	60	90	120	150	180	210	240	270	300	330	150
10	10	1.040	1.040	1.020	1.000	1.000	1.010	1.020	1.040	1.040	1.070	1.060	1.060	1.060
10	20	1.060	1.040	1.030	1.020	1.010	1.010	1.020	1.040	1.080	1.070	1.070	1.060	1.070
10	30	1.080	1.060	1.020	1.020	1.010	1.010	1.030	1.030	1.060	1.070	1.070	1.070	1.070
10	40	1.070	1.020	1.030	1.000	1.000	1.010	1.030	1.030	1.060	1.070	1.080	1.070	1.070
10	50	1.070	1.030	1.010	1.030	1.000	1.000	1.030	1.020	1.070	1.080	1.080	1.080	1.080
10	60	1.070	1.030	1.010	1.030	1.000	1.000	1.030	1.030	1.060	1.080	1.080	1.080	1.070
10	70	1.060	1.030	1.020	1.020	1.000	1.010	1.030	1.030	1.060	1.080	1.080	1.080	1.080
10	80	1.080	1.040	1.020	1.010	1.000	1.000	1.030	1.040	1.060	1.070	1.090	1.070	1.070
10	90	1.070	1.040	1.020	1.010	1.000	1.020	1.020	1.030	1.040	1.060	1.060	1.070	1.070
11														
12														
13														
14														
15														
16														
17														
18														
19														
20														
21														

LOWEST AREA .970"
0-180° X-125, Y-46

THICKNESS SURVEY REPORT

DATE 5-22-86

DISC# 78

SNT MONTICELLO

ISO# MTS-35

AREA 11. D1 0.18"

GRID SIZE 200

EXAMINERS STEVE STANFORD II / ANDY BOSS / S.G. HALL

EQUIPMENT ULTRA IMAGE III

TRANSDUCER (SIZE/FREQ.) .25"/10 MHz.

CAL. BLOCK (TYPE/SERIAL NO.) STEP WEDGE 3080-83

NOMINAL WALL 1.037

MIN. WALL _____

COMMENTS _____

X Degree	Y Grid	0	30	60	90	120	150	180	210	240	270	300	330	145
10	10	1.040	1.020	1.040	1.040	1.040	1.040	1.010	1.050	1.060	1.010	1.050	1.040	1.040
20	10	1.020	1.040	1.040	1.050	1.050	1.040	1.050	1.010	1.060	1.060	1.060	1.040	1.040
30	10	1.050	1.040	1.030	1.040	1.020	1.040	1.060	1.060	1.010	1.060	1.080	1.050	1.050
40	10	1.050	1.040	1.030	1.020	1.050	1.060	1.080	1.060	1.060	1.060	1.040	1.040	1.040
50	10	—	1.010	—	—	—	—	.930	1.070	1.040	1.040	1.010	1.080	1.080
60	10	.960	.960	.960	.980	1.000	1.010	1.020	—	—	—	.850	—	—
70	10	.960	.960	.980	1.000	.930	1.010	1.020	1.040	1.020	1.050	.990	.990	.990
80	10	.980	.960	.980	1.000	1.010	1.020	1.050	1.040	1.020	.900	1.000	.980	.980
90	10	.980	.990	.990	1.000	1.010	1.020	1.020	1.060	1.010	1.000	.980	.950	.950
100	10	.980	.990	.990	1.000	1.010	1.020	1.020	1.060	1.010	1.000	.980	.950	.950
11	10													
12	10													
13	10													
14	10													
15	10													
16	10													
17	10													
18	10													
19	10													
20	10													
21	10													

LOWEST AREA - .950"
180°-0° X-160, Y-76

Date January 10, 1985

From Randy Coleman

Location Midland Square -3

To Dan Couch


Location Monticello

Subject: TURBINE PIPING THICKNESS SURVEY

Dear Dan,

I have enclosed a copy of the Monticello Turbine Piping Thickness Survey Report and a Thickness Survey Log Book. If you have any questions, please let me know.

Sincerely,



Randy J Coleman
Material & Special Process Engineer

wmh

GENERAL

This report covers the turbine piping wall thickness survey done on Monticello Nuclear Generating Plant Unit I from April 25 through August 2, 1984. The inspection was done by personnel from Lambert, McGill, and Thomas Inc (LMT) of Santa Clara, California under the supervision of Randy Coleman from Production Plant Maintenance Department. The site coordinator was Dan Couch from the Monticello Plant.

The inspection was conducted as a baseline for an ongoing turbine piping wall thickness study at the Monticello plant. The data points were chosen by plant personnel. Isometric diagrams showing the pipe layout and location of data acquisition areas were sketched by personnel from LMT.

Data was gathered using a Nortec 131-D Digital Ultrascope or the General Dynamics Ultra Image III. The Nortec 131-D is a conventional manually operated ultrascope with a digital readout. The next two paragraphs describe the Ultra Image III and some of its capabilities.

The Ultra Image III is an ultrasonic imaging inspection system whose functions are monitored and controlled by a microprocessor. Information on administrative records, scanner set-up, calibration parameters, and ultrasonic instrument control settings is stored in the microprocessor header memory in preparation for taking data. The thickness data is gathered over a pre-determined area in accordance with information in the header and is stored in a data memory. The header and data memory may then be analyzed and stored on magnetic floppy disks as permanent records.

The Ultra Image III is capable of presenting data in various forms. Analysis may be performed on general areas or on given points because the thickness and signal amplitude data stored in the memory are arranged in grid form with X and Y coordinates. The coordinates correspond to specific points of the area examined. Multiple presentation format permits the analyst to display a plan view with an infinite number of thickness ranges given in percent of nominal wall thickness. In addition to the plan view, cross sections of the inspection area may be viewed.

Data taken while using the Nortec instrument was put directly on report forms. Data taken using the Ultra Image system was stored on floppy disks and later transcribed to report forms. The completed report forms are in the Monticello Thickness Survey log book. Information stored on floppy disks will be retained by Production Plant Maintenance Department.

The results of this baseline inspection have been organized and put into a Monticello Thickness Survey Log Book. The book is divided into sections based on thickness survey isometric diagrams. Sections are labeled with the appropriate isometric diagram number. They contain a copy of the isometric, copies of the thickness survey reports and a note page for comments. The reasons for organizing the log book in this fashion is that as reports are received from subsequent inspections the log book may be conveniently updated by dividing it into subsections containing reports on specific areas.

RESULTS

The results of the inspection can be summarized by stating that the crossunder piping shows signs of tiger stripping and areas of severe erosion/corrosion. The extraction and drain piping areas tested show no sign of severe localized erosion/corrosion.

The worst areas of erosion/corrosion were discovered when a maintenance worker crawled through the crossunder line between B moisture separator and #3 CIV to retrieve a part that had been accidentally dropped into the line. He noticed that the horizontal run between B2 and F on ISO-MTS-11 had numerous spots that appeared to have one fourth inch wall loss. In addition to this the pipe to elbow weld at area B had wall loss upstream of the weld and the general area around C had tiger stripping.

The suspect areas were scanned with the Ultra Image III. The results were that some areas were at or below the 0.271" minimum wall thickness. The areas that required weld repair and reinspection are at B2, F and B. Area C was not repaired because the tiger striped areas had minimum thickness readings greater than 0.450 inches. Repair work was handled by the plant.

One additional noteworthy area on crossunder piping was area 1.1A on ISO-MTS-1. Scan data on the Ultra Image III shows thin areas between 310° and 330°. The thin spots could not be found when a visual examination inside the pipe was performed. The spots are apparently laminations in the pipe.

Visual examination of the remainder of the crossunder piping that was accessible revealed areas of tiger stripping but no severely eroded areas.

Selected areas of the extraction and drain piping as stated earlier in this report, were examined and the results were favorable. None of the areas tested showed severe erosion/corrosion damage like that in the crossunder piping. However, the areas in Table 1 show major thickness variations over the data acquisition areas. These suspect areas should be examined during the next refueling outage.

TABLE 1

ISO	AREA
MTS-4	T.5
MTS-4	T.6
MTS-9	9.4A
MTS-10	10.4A
MTS-15	5.4
MTS-16	6.4A
MTS-24	6.2

On September 5, 1984 a seminar entitled Erosion/Corrosion of Turbine Piping Systems was given by Electric Power Research Institute at the J.A. Jones Applied Research Center in Charlotte, North Carolina. Don Pedersen from the Monticello plant and Randy Coleman from Production Plant Maintenance Department attended the seminar. The material presented in the seminar was focused on current research of the erosion/corrosion problem and how to develop a plant specific program to monitor it. Table 2 contains a list of data acquisition areas that should be added to the current Monticello Thickness Survey Program if the monitoring program EPRI suggested is to be followed.

TABLE 2

ISO#	AREA#
MTS-5	3.7A
MTS-5	3.8A
MTS-6	3.7
MTS-6	3.8
MTS-7	9.4
MTS-8	10.2
MTS-9	9.2A
MTS-9	9.5A
MTS-10	10.2A
MTS-10	10.5A

Recommendations

1. The weld repaired areas of the crossunder piping should be reinspected during the next refueling outage.
2. The areas listed in Table 1 should be reinspected during the next refueling outage.
3. The interior surface of the crossunder piping should be given a visual examination during the next refueling outage.
4. The data acquisition areas listed in Table 2 should be added to the thickness survey program and baseline inspection should be done on them during the next refueling outage.

Document Name:
RJC112884WMH01

Requestor's ID:
OPR4

Author's Name:
RANDY COLEMAN

Document Comments:
MONTICELLO THICKNESS SURVEY REPORT

1 - 9 - 74

GENERAL

This report covers the turbine piping wall thickness survey done on Monticello Nuclear Generating Plant Unit I from April 25 through August 2, 1984. The inspection was done by personnel from Lambert, McGill, and Thomas Inc (LMT) of Santa Clara, California under the supervision of Randy Coleman from Production Plant Maintenance Department. The site coordinator was Dan Couch from the Monticello Plant.

The inspection was conducted as a baseline for an ongoing turbine piping wall thickness study at the Monticello plant. The data points were chosen by plant personnel. Isometric diagrams showing the pipe layout and location of data acquisition areas were sketched by personnel from LMT.

Data was gathered using a Nortec 131-D Digital Ultrascope or the General Dynamics Ultra Image III. The Nortec 131-D is a conventional manually operated ultrascope with a digital readout. The next two paragraphs describe the Ultra Image III and some of its capabilities.

The Ultra Image III is an ultrasonic imaging inspection system whose functions are monitored and controlled by a microprocessor. Information on administrative records, scanner set-up, calibration parameters, and ultrasonic instrument control settings is stored in the microprocessor header memory in preparation for taking data. The thickness data is gathered over a pre-determined area in accordance with information in the header and is stored in a data memory. The header and data memory may then be analyzed and stored on magnetic floppy disks as permanent records.

The Ultra Image III is capable of presenting data in various forms. Analysis may be performed on general areas or on given points because the thickness and signal amplitude data stored in the memory are arranged in grid form with X and Y coordinates. The coordinates correspond to specific points of the area examined. Multiple presentation format permits the analyst to display a plan view with an infinite number of thickness ranges given in percent of nominal wall thickness. In addition to the plan view, cross sections of the inspection area may be viewed.

Data taken while using the Nortec instrument was put directly on report forms. Data taken using the Ultra Image system was stored on floppy disks and later transcribed to report forms. The completed report forms are in the Monticello Thickness Survey log book. Information stored on floppy disks will be retained by Production Plant Maintenance Department.

The results of this baseline inspection have been organized and put into a Monticello Thickness Survey Log Book. The book is divided into sections based on thickness survey isometric diagrams. Sections are labeled with the appropriate isometric diagram number. They contain a copy of the isometric, copies of the thickness survey reports and a note page for comments. The reasons for organizing the log book in this fashion is that as reports are received from subsequent inspections the log book may be conveniently updated by dividing it into subsections containing reports on specific areas.

RESULTS

The results of the inspection can be summarized by stating that the crossunder piping shows signs of tiger stripping and areas of severe erosion/corrosion. The extraction and drain piping areas tested show no sign of severe localized erosion/corrosion.

The worst areas of erosion/corrosion were discovered when a maintenance worker crawled through the crossunder line between B moisture separator and #3 CIV to retrieve a part that had been accidentally dropped into the line. He noticed that the horizontal run between B2 and F on ISO-MTS-11 had numerous spots that appeared to have one fourth inch wall loss. In addition to this the pipe to elbow weld at area B had wall loss upstream of the weld and the general area around C had tiger stripping.

The suspect areas were scanned with the Ultra Image III. The results were that some areas were at or below the 0.271" minimum wall thickness. The areas that required weld repair and reinspection are at B2, F and B. Area C was not repaired because the tiger striped areas had minimum thickness readings greater than 0.450 inches. Repair work was handled by the plant.

One additional noteworthy area on crossunder piping was area 1.1A on ISO-MTS-1. Scan data on the Ultra Image III shows thin areas between 310° and 330°. The thin spots could not be found when a visual examination inside the pipe was performed. The spots are apparently laminations in the pipe.

Visual examination of the remainder of the crossunder piping that was accessible revealed areas of tiger stripping but no severely eroded areas.

Selected areas of the extraction and drain piping as stated earlier in this report, were examined and the results were favorable. None of the areas tested showed severe erosion/corrosion damage like that in the crossunder piping. However, the areas in Table 1 show major thickness variations over the data acquisition areas. These suspect areas should be examined during the next refueling outage.

TABLE 1

ISO	AREA
MTS-4	T.5
MTS-4	T.6
MTS-9	9.4A
MTS-10	10.4A
MTS-15	5.4
MTS-16	6.4A
MTS-24	6.2

On September 5, 1984 a seminar entitled Erosion/Corrosion of Turbine Piping Systems was given by Electric Power Research Institute at the J.A. Jones Applied Research Center in Charlotte, North Carolina. Don Pedersen from the Monticello plant and Randy Coleman from Production Plant Maintenance Department attended the seminar. The material presented in the seminar was focused on current research of the erosion/corrosion problem and how to develop a plant specific program to monitor it. Table 2 contains a list of data acquisition areas that should be added to the current Monticello Thickness Survey Program if the monitoring program EPRI suggested is to be followed.

TABLE 2

ISO#	AREA#
MTS-5	3.7A
MTS-5	3.8A
MTS-6	3.7
MTS-6	3.8
MTS-7	9.4
MTS-8	10.2
MTS-9	9.2A
MTS-9	9.5A
MTS-10	10.2A
MTS-10	10.5A

Recommendations

1. The weld repaired areas of the crossunder piping should be reinspected during the next refueling outage.
2. The areas listed in Table 1 should be reinspected during the next refueling outage.
3. The interior surface of the crossunder piping should be given a visual examination during the next refueling outage.
4. The data acquisition areas listed in Table 2 should be added to the thickness survey program and baseline inspection should be done on them during the next refueling outage.

1-10-87

Monticello Feedwater Piping Wall Thickness Survey Summary

<u>Inspection Point No.</u>	<u>Description and Line No.</u>	<u>Nominal Wall Thickness in.</u>	<u>Max Wall Loss in.</u>
A1	#11 RFP Recirc branch flow tee, FW3-8-DE	0.594	.014
A2	Elbow downstream of CV 6-12A, FW2B-14-DE	0.938	.078 (in the counterbore area)
A3	Elbow after branch tee A FW line to CV 6-13 FW2-6-DE	0.562	.005
A4	Branch Tee downstream of CV 6-13, FW2-6-DE	0.562	.044
A5	Elbow downstream of A4 FW2-6-DE	0.562	.040
A6	Elbow on #12 RFP Suction C4B-16-GB	0.375	.025
B1	Elbow Upstream of SPE C2-24-GB	0.500	.005
B2	Mixing tee where A & B condensate loops mix downstream of SJAEs, C2-24-GB	0.500	.020
B3	Mixing tee of B loop inner and after SJAE condensers, C2B-16-GB	0.375	-.007
C1	B loop FW cleanup line branch flow tee, FW10-8-DE	0.594	.024
D1	Elbow downstream of CV 1095A, C5-10-GB	0.365	.024
D2	Branch tee upstream of CV 1095A, C5-6-GB	0.280	.007
D3	Branch flow tee to 11B drain cooler, C4B-16-GB	0.375	-.021


Negative wall loss indicates that the thinnest area measured is that much greater than the nominal wall thickness.

All wall loss is less than manufacturers tolerance (12.5%)

Future Plans


1. During 1987 outage inspect one RFP recirc line downstream of the recirculation valve.
2. During 1987 outage inspect the branch flow tee on the B feedwater riser inside the drywell.

With the above results evaluate if future inspections are warranted.



1" BYPASS (TYP)
 1" DRAIN (TYP) REACTOR FEED PUMP
 P-2A

RELATION A-1



C EL. 922'-6"
 FW2B-14'-DE
 SA4-4'-JB

C EL. 921'-11"

F-2

MIST. ELIM. (6"-255)

4"-54

6" X 4" RED.

S-28

MCC

10" X 6" RED.

SA3-3'-JB

C EL. 919'-2 3/4"

ESW8-3'-HBD

SA3-JB

SA2-8'-JB

8"-255

CV 6-12A

A2

C EL. 913'-9"

MCC

SA1-8'-JB


C EL. 913'-8"

DRAIN (TYP)


C BLOWER K-2
 C SEPARATOR T-54

3"-DRAIN PIPING
 BY FIELD.

LOCATION A2




LOCATIONS
A3, A4, A5



REACTOR FEED PUMP
 P-2B

LOCATION A6


TURBINE LUBE OIL RE




5612
 TURB. BLDG. COND.
 DRAIN PUMP
 P. 000A

T.B. COND.
 DR. PUMP
 P. 000B

LOCATIONS
 B1, B2, B3



LOCATION C1



LOCATIONS
 D1, D2

B.O.L. EL. 927'-8"

AO-3"-463

HDI9-14-HB

AO
2562A

AO
2562B

MO-16"-26

6 1/16"

DRA
E
(RW)

CH5-4-HC

MO
1089

HDIG-12-HB

AO-3"-463

C4B-16"-GB

D3

CEL 914-6 1/16"

DRA
E

WELDOLET

DRAIN

LOCATION D3

INPUT FILE NAME cmonts2p

OUTPUT FILE NAME a:cmonts2p.ou2

BOUNDING LEVEL = 90 %
NUMBER OF CASES = 1

A Comparison of Observed Results in 2 Phase Flow Systems
versus CHEC predictions:

AREA:	OBSERVED RATE: (mils/year)	PREDICTED RATE: (mils/year)
1.0A	16	98
1.0A Inner Radius	21	98
5.4 (ISO 15)	95	17
6.4 (ISO 16)	0	0
6.2 (ISO 24)	0	0
B.2 (ISO 11)	14	24
B (ISO 11)	24	24
* 10.0A	4.7	2

* Note: 10.0A is water solid, and is the only water solid area repeated to date in the 84' and '86 exams.

MONTICELLO TWO PHASE WORK

CASE = 1 NCHEM = 1 TOTAL TIME = 17520. NSEG = 5

ICHEM	FMULT	PH	OXY	HOURS
0	100.000	7.000	8.0	17520.

NCOMP = 2 DESIGN PRESS.= 197. DESIGN TEMP.= 380.

MONTICELLO TWO PHASE WORK

GEO (SECOND LINE)	MAT	COMP. NAME CR	DIA CU	THICK MO	TEMP SIGMA	FLOW
4	7	1.0A	-36.	.549	380.	.168
4	7	1.0A IR	-36.	.535	380.	.168

NCOMP = 1

DESIGN PRESS.= 111.

DESIGN TEMP.= 341.

MONTICELLO TWO PHASE WORK

GEO (SECOND LINE)	MAT	COMP. NAME CR	DIA CU	THICK MO	TEMP SIGMA	FLOW
8	25	5.4	10.	.480	341.	.070

NCOMP = 2 DESIGN PRESS.= 66. DESIGN TEMP.= 313.

MONTICELLO TWO PHASE WORK

GEO (SECOND LINE)	MAT	COMP. NAME CR	DIA CU	THICK MO	TEMP SIGMA	FLOW
9	25	6.2	20.	.372	313.	.004
2	25	6.2	20.	.372	313.	.004

NCOMP = 3

DESIGN PRESS.= 191.

DESIGN TEMP.= 378.

MONTICELLO TWO PHASE WORK

GEO (SECOND LINE)	MAT	COMP. NAME CR	DIA CU	THICK MO	TEMP SIGMA	FLOW
9	7	B.2	-30.	.553	378.	.168
9	7	F	-30.	.501	378.	.168
9	7	B	-30.	.538	378.	.168

NCOMP = 2 DESIGN PRESS.= 100. DESIGN TEMP.= 383.

MONTICELLO TWO PHASE WORK

GEO (SECOND LINE)	MAT	COMP. NAME CR	DIA CU	THICK MO	TEMP SIGMA	FLOW
9	0	10.0A	6.	.333	383.	-4.500
	12.0000	.5000	1.0000	36000.		
2	0	10.0A	6.	.333	383.	-4.500
	12.0000	.5000	1.0000	36000.		

MONTICELLO TWO PHASE WORK

PASS 2 DATA
NUMBER OF INSPECTIONS = 10

NUMBER	COMP	MEASURED THICKNESS
1	1.0A	.533
2	1.0A IR	.515
3	5.4	.291
4	6.2	.372
5	6.2	.372
6	B.2	.538
7	F	.501
8	B	.513
9	10.0A	.329
10	10.0A	.329

MONTICELLO TWO PHASE WORK

PASS 2 RESULTS AT 90% BOUNDING LEVEL
COMPONENT PREDICTED AVERAGE
EROSION RATE (MM/YR)

1.0A	1.25
1.0A IR	1.25
B.2	.31
B	.31
F	.31
5.4	.22
10.0A	.02
10.0A	.00
6.2	.00
6.2	.00

NOTE:

THE AVERAGE EROSION RATE FOR EACH COMPONENT IS CALCULATED
USING THE MAXIMUM TOTAL TIME FOR THE PROBLEM

MONTICELLO TWO PHASE WORK

PASS 2 RESULTS AT 90% BOUNDING LEVEL
COMPONENT PREDICTED HOURS TO REACH
MINIMUM WALL THICKNESS

1.0A IR	25469.
1.0A	27980.
F	173546.
B	198969.
B.2	209691.
5.4	433883.
10.0A	2957942.
10.0A	8908866.
6.2	29843160.
6.2	89564540.

WARNING:

THE DESIGN MINIMUM WALL THICKNESS USED IN PREDICTING TOTAL HOURS IS BASED ON DESIGN PRESSURE ONLY. UTILITIES MUST PERFORM PLANT SPECIFIC ENGINEERING EVALUATIONS THAT INCLUDE ALL LOADS TO PREDICT TOTAL HOURS BEFORE A FAILURE WOULD OCCUR.

MONTICELLO TWO PHASE WORK

PASS 2 RESULTS AT 90% BOUNDING LEVEL

COMPONENT	PREDICTED THICKNESS (INCH)	PREDICTED WEAR (INCH)	LATEST EROSION RATE (MM/YEAR)	MINIMUM WALL THICKNESS (INCH)
1.0A	.451	.099	1.25	.294
1.0A IR	.437	.098	1.25	.294
5.4	.463	.017	.22	.040
6.2	.372	.000	.00	.044
6.2	.371	.000	.00	.044
B.2	.529	.024	.31	.237
F	.477	.024	.31	.237
B	.513	.024	.31	.237
10.0A	.333	.000	.00	.009
10.0A	.331	.002	.02	.009

From Randy Coleman

To Dan Couch

Date January 10, 1985

Location Midland Square -3


Location Monticello

Subject: TURBINE PIPING THICKNESS SURVEY

Dear Dan,

I have enclosed a copy of the Monticello Turbine Piping Thickness Survey Report and a Thickness Survey Log Book. If you have any questions, please let me know.

Sincerely,



Randy J Coleman
Material & Special Process Engineer

wmh

GENERAL

This report covers the turbine piping wall thickness survey done on Monticello Nuclear Generating Plant Unit I from April 25 through August 2, 1984. The inspection was done by personnel from Lambert, McGill, and Thomas Inc (LMT) of Santa Clara, California under the supervision of Randy Coleman from Production Plant Maintenance Department. The site coordinator was Dan Couch from the Monticello Plant.

The inspection was conducted as a baseline for an ongoing turbine piping wall thickness study at the Monticello plant. The data points were chosen by plant personnel. Isometric diagrams showing the pipe layout and location of data acquisition areas were sketched by personnel from LMT.

Data was gathered using a Nortec 131-D Digital Ultrascope or the General Dynamics Ultra Image III. The Nortec 131-D is a conventional manually operated ultrascope with a digital readout. The next two paragraphs describe the Ultra Image III and some of its capabilities.

The Ultra Image III is an ultrasonic imaging inspection system whose functions are monitored and controlled by a microprocessor. Information on administrative records, scanner set-up, calibration parameters, and ultrasonic instrument control settings is stored in the microprocessor header memory in preparation for taking data. The thickness data is gathered over a pre-determined area in accordance with information in the header and is stored in a data memory. The header and data memory may then be analyzed and stored on magnetic floppy disks as permanent records.

The Ultra Image III is capable of presenting data in various forms. Analysis may be performed on general areas or on given points because the thickness and signal amplitude data stored in the memory are arranged in grid form with X and Y coordinates. The coordinates correspond to specific points of the area examined. Multiple presentation format permits the analyst to display a plan view with an infinite number of thickness ranges given in percent of nominal wall thickness. In addition to the plan view, cross sections of the inspection area may be viewed.

Data taken while using the Nortec instrument was put directly on report forms. Data taken using the Ultra Image system was stored on floppy disks and later transcribed to report forms. The completed report forms are in the Monticello Thickness Survey log book. Information stored on floppy disks will be retained by Production Plant Maintenance Department.

The results of this baseline inspection have been organized and put into a Monticello Thickness Survey Log Book. The book is divided into sections based on thickness survey isometric diagrams. Sections are labeled with the appropriate isometric diagram number. They contain a copy of the isometric, copies of the thickness survey reports and a note page for comments. The reasons for organizing the log book in this fashion is that as reports are received from subsequent inspections the log book may be conveniently updated by dividing it into subsections containing reports on specific areas.

RESULTS

The results of the inspection can be summarized by stating that the crossunder piping shows signs of tiger stripping and areas of severe erosion/corrosion. The extraction and drain piping areas tested show no sign of severe localized erosion/corrosion.

The worst areas of erosion/corrosion were discovered when a maintenance worker crawled through the crossunder line between B moisture separator and #3 CIV to retrieve a part that had been accidentally dropped into the line. He noticed that the horizontal run between B2 and F on ISO-MTS-11 had numerous spots that appeared to have one fourth inch wall loss. In addition to this the pipe to elbow weld at area B had wall loss upstream of the weld and the general area around C had tiger stripping.

The suspect areas were scanned with the Ultra Image III. The results were that some areas were at or below the 0.271" minimum wall thickness. The areas that required weld repair and reinspection are at B2, F and B. Area C was not repaired because the tiger striped areas had minimum thickness readings greater than 0.450 inches. Repair work was handled by the plant.

One additional noteworthy area on crossunder piping was area 1.1A on ISO-MTS-1. Scan data on the Ultra Image III shows thin areas between 310° and 330°. The thin spots could not be found when a visual examination inside the pipe was performed. The spots are apparently laminations in the pipe.

Visual examination of the remainder of the crossunder piping that was accessible revealed areas of tiger stripping but no severely eroded areas.

Selected areas of the extraction and drain piping as stated earlier in this report, were examined and the results were favorable. None of the areas tested showed severe erosion/corrosion damage like that in the crossunder piping. However, the areas in Table 1 show major thickness variations over the data acquisition areas. These suspect areas should be examined during the next refueling outage.

TABLE 1

ISO	AREA
MTS-4	T.5
MTS-4	T.6
MTS-9	9.4A
MTS-10	10.4A
MTS-15	5.4
MTS-16	6.4A
MTS-24	6.2

MONTICELLO THICKNESS SURVEY REPORT

On September 5, 1984 a seminar entitled Erosion/Corrosion of Turbine Piping Systems was given by Electric Power Research Institute at the J.A. Jones Applied Research Center in Charlotte, North Carolina. Don Pedersen from the Monticello plant and Randy Coleman from Production Plant Maintenance Department attended the seminar. The material presented in the seminar was focused on current research of the erosion/corrosion problem and how to develop a plant specific program to monitor it. Table 2 contains a list of data acquisition areas that should be added to the current Monticello Thickness Survey Program if the monitoring program EPRI suggested is to be followed.

TABLE 2

ISO#	AREA#
MTS-5	3.7A
MTS-5	3.8A
MTS-6	3.7
MTS-6	3.8
MTS-7	9.4
MTS-8	10.2
MTS-9	9.2A
MTS-9	9.5A
MTS-10	10.2A
MTS-10	10.5A

Recommendations

1. The weld repaired areas of the crossunder piping should be reinspected during the next refueling outage.
2. The areas listed in Table 1 should be reinspected during the next refueling outage.
3. The interior surface of the crossunder piping should be given a visual examination during the next refueling outage.
4. The data acquisition areas listed in Table 2 should be added to the thickness survey program and baseline inspection should be done on them during the next refueling outage.

Document Name:
RJC112884WMH01

Requestor's ID:
OPR4

Author's Name:
RANDY COLEMAN

Document Comments:
MONTICELLO THICKNESS SURVEY REPORT

1-9-24

Mark Hugo

Date 9-9-87
Int'l Ctr 3

From Dan Couch

Location Monticello

To

Location


TURBINE PIPING THICKNESS SURVEY

Subject

Dear Dan,

I have enclosed a copy of the Monticello Thickness Survey Report covering the work done in May of 1986. If you have any questions, please let me know.

Sincerely,



Mark Hugo
Interim PPM/M&SP Engineer assigned
to the Thickness Survey

Authored by:



Zane Johnson
Engineering Intern

I. General Information

The thickness survey is organized into sections based on isometric diagrams and further subdivided into areas where actual thickness measurements are made.

The inspection was carried out by personnel from Lambert, MacGill and Thomas, Inc. of Santa Clara, California, under the supervision of Randy Coleman of Production Plant Maintenance.

The thickness measurements were made using either of two instruments; the Nortec 131-D unit or the Ultra Image III system. In the case of the Nortec Unit, the area of interest was laid out in a grid pattern and thickness readings were recorded at the intersection points. The Ultra Image system, however, records and stores on diskettes a "contour map" of the area, not just discrete points. The system divides the scan area into a 100x200 point map which may, at a later time, be reviewed and thickness values transcribed to paper for various coordinate positions. More information on these units may be found in the Appendix.

II. RESULTS

From the results of the 1984 inspection it was recommended that the following areas, shown in Table 1, be rechecked in the 1986 inspection. The values shown for "5/86 min." and "6/84 min." are taken directly from the field data sheets and represent the single thinnest reading taken in that area at that time. All measurements are in inches.

It would appear from the 1986 results that the only area of concern is Area 5.4 of MTS-15. This area has been found to have an overall thickness change (i.e. the average of all data points taken) of .189". While the remaining average thickness of .291" is well above the required minimum wall calculated on a hoop-stress basis, the measured existing wall thickness is well below the nominal wall minus 12.6% manufacturing tolerance. Production Plant Maintenance, Materials and Special Processes Engineers will resurvey this area in 1987.

On September 5, 1984 a seminar entitled Erosion/Corrosion of Turbine Piping Systems was given by EPRI. Don Pedersen of the Monticello plant and Randy Coleman of Production Plant Maintenance attended. Table

2 contains a list of areas that were added as a result of the EPRI recommendations.

Table 1

<u>Iso #</u>	<u>Area</u>	<u>5/86 min.</u>	<u>6/84 min.</u>	<u>Nom./Min. wall</u>
MTS-4	T.5,us	.500	.456	.500/.325
	T.5,ds	.476	.468	.500/.325
	T.6	.452	.412	.500/.325
MTS-9	9.4A	.310	.234	.280/ ?
MTS-10	10.4A	.320	.241	.280/ ?
MTS-15	5.4	.230	.263	.365/ ?
MTS-16	6.4A	.467	.470	.375/ ?
MTS-24	6.2	.352	.288	.375/ ?

Table 2

<u>Iso #</u>	<u>Area</u>	<u>5/86 min.</u>	<u>Nom./Min. wall</u>
MTS-5	3.7A,UI	.368	.375/ ?
	3.7A,N	.530	.375/ ?
	3.8A	.511	.375/ ?
MTS-6	3.7	.483	.375/ ?
	3.7,us	.348	.500/.283
	3.7,ds	.356	.500/.271
	3.8,UI	.340	.375/ ?
	3.8,N	.492	.375/ ?
MTS-7	9.4	.340	.280/.045
MTS-8	10.2	.360	.280/ ?
MTS-9	9.2A	.320	.280/ ?
	9.5A	.320	.280/ ?
MTS-10	10.2A	.310	.280/ ?
	10.5A	.320	.280/ ?

III. CONCLUSION

Aside from Area 5.4 of MTS-15, there were no areas found to be below the manufacturing tolerance of 12.6%.

IV. Appendix

A) Nortec 131-D:

This instrument is a portable ultrasonic inspection unit fitted with a standard CRT display and a digital display for thickness measurements. Information on accuracy and repeatability of these units in general may be found in the EPRI report entitled Nondestructive Examination of Ferritic Piping for Erosion/Corrosion, April 1987.

B) Ultra Image III:

The Ultra Image III is an ultrasonic inspection system whose functions are monitored and controlled by a microprocessor. Information on administrative records, scanner setup, calibration parameters and ultrasonic control settings is stored in the microprocessor header memory in preparation for taking data. The thickness data is gathered over a predetermined area in accordance with information in the header and is stored in memory. The header and data memory may then be stored on magnetic floppy disks as permanent records.

The UI-III is capable of presenting data in various forms. Analysis may be performed on general areas or on given points because the thickness and signal amplitude data stored in memory are arranged in grid form with X and Y coordinates corresponding to specific points on the examination area. The multiple presentation format permits the analyst to display a plan view with an infinite number of thickness ranges in percent of nominal wall thickness using colors on the screen. Four and eight color displays are available. In addition to the plan view, cross-sections of the inspection area may be viewed.

One major advantage of the UI-III is that it may be used to collect data on a given area and store that data on a floppy disc. The data may then be compared to data collected during previous inspections of that area. However, there are limitations in the data comparison techniques available. The one that has the most effect on the Prairie Island and Monticello Thickness Surveys is the apparent increase of pipe wall thickness that may occur when the data is transcribed directly to data sheets. The situation occurs when two sets of data are gathered on a specific area but the inspection starting points are different. In other words, the data collected for coordinates X=1, Y=1 on the current inspection will not represent the same position on the pipe as the coordinates X=1, Y=1 for a previous inspection unless the transducer starting and scanning positions are identical for both inspections. Position variations as small as 0.020 inches can be the cause of such discrepancies. The technicians that gather the data try to inspect the exact areas covered

in the previous inspection but placement of the transducer and the scanner belt are best effort jobs.

The actual data analysis is more complicated than comparing readings from the X and Y positions of a grid of data to that of the previous inspection. When the data is presented on the UI-III, large areas of erosion may be evaluated by using the erosion pattern edges and center to estimate the amount that one set of data must be offset to match the other set of data. Comparison of the data may then be completed. For small areas of localized thinning, the thin areas may be picked out and analyzed separately. In areas where gross erosion has occurred between inspections, determining the amount of offset may be a best effort job.