

AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: 4701

FROM: Northern States Power Co. Minneapolis, Minn. 55401 L.O. Mayer		DATE OF DOC: 8-25-72	DATE REC'D 8-28-72	LTR X	MEMO	RPT	OTHER
TO: Peter A. Morris		ORIG 1 signed	CC 39	OTHER	SENT AEC PDR ✓ SENT LOCAL PDR ✓		
CLASS: U/PROP INFO		INPUT	NO CYS REC'D 40	DOCKET NO: 50-263			
DESCRIPTION: Ltr furnishing info on HPCI System for the period 5-3-71 to 8-15-72 for Monticello Plant.....			ENCLOSURES:				
* PLEASE CIRCULATE-INSUFFICIENT CYS REC'D FOR FULL DISTRIBUTION			DO NOT REMOVE ACKNOWLEDGED				
PLANT NAMES: Monticello Plant							

FOR ACTION/INFORMATION

8-28-72

Appl

BUTLER(L) W/ Copies	KNIEL(L) W/ Copies	VASSALLO(L) W/ Copies	ZIEMANN(L) W/ 6 Copies	KNIGHTON(ENVIRO) W/ Copies
CLARK(L) W/ Copies	SCHWENCER(L) W/ Copies	H. DENTON W/ Copies	CHITWOOD(FM) W/ Copies	YOUNGBLOOD(ENVIRO) W/ Copies
GOLLER(L) W/ Copies	STOLZ(L) W/ Copies	SCHEMEL(L) W/ Copies	DICKER(ENVIRO) W/ Copies	

INTERNAL DISTRIBUTION

<u>REG FILE</u>	TECH REVIEW	VOLLMER	HARLESS	WADE (E)
✓ AEC PDR	✓ HENDRIE / <i>Schroeder</i>	DENTON		SHAFFER (F&M)
✓ OGC, ROOM P-506A	SCHROEDER	GRIMES	F & M	BROWN (E)
✓ MUNTZING/STAFF	✓ MAQCARY (LTR)	GAMMILL	SMILEY	G. WILLIAMS (E)
✓ CASE	* ✓ VLANGE	KASTNER	NUSSBAUMER	A/T IND
GIAMBUSSO	PAWLICKI	BALLARD		BRAITMAN
✓ BOYD-L (BWR)	SHAO	FINE	LIC ASST.	SALTZMAN
DEYOUNG-L (PWR)	* ✓ KNUTH	ENVIRO	SERVICE (L)	
✓ SKOVHOLT-L	STELLO	MULLER	MASON (L)	PLANS
P. COLLINS	MOORE	DICKER	WILSON (L)	MCDONALD
REG OPR	THOMPSON	KNIGHTON	KARI (L)	DUBE
✓ FILE & REGION (2)	✓ TEDESCO (LTR)	YOUNGBLOOD	SMITH (L)	INFO
✓ MORRIS	* ✓ LONG	PROJECT LEADER	GEARIN (L)	C. MILES
✓ STEELE	LAINAS		DIGGS (L)	
	BENAROYA		TEETS (L)	

EXTERNAL DISTRIBUTION

✓ 1-LOCAL PDR Minneapolis, Minn.	(1)(5)(9)-NATIONAL LAB'S	1-PDR-SAN/LA/NY
✓ 1-DTIE (LAUGHLIN)	ANL/ORNL/PNL	1-GERALD LELLUCHE
✓ 1-NSIC (BUCHANAN)	1-R. CARROLL-OC, GT-B227	BROOKHAVEN NAT. LAB
1-ASLB-YORE/SAYRE	1-R. CATLIN, A-170-GT	1-BOLAND, IDAHO FALLS,
WOODWARD/H. ST.	1-CONSULANT'S	IDAHO (50-331 Only)
✓ 16-CYS ACRS HOLDING	NEWMARK/BLUME/AGABIAN	1-RD..MULLER.. F-309GT
	✓ H. MULLER - F-309 G.T.	

NSP

Regulatory



File Cy

NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

August 25, 1972

Peter A Morris, Director
Office of Operations Evaluation
Directorate of Regulatory Operations
United States Atomic Energy Commission
Washington, D C 20545



Dear Dr. Morris:

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

HPCI Operating Experience Information

The following information is submitted in response to your request for operating experience information regarding the High Pressure Coolant Injection (HPCI) System. The data present covers the period from completion of system startup testing, May 3, 1971 to August 15, 1972.

1. The HPCI system has been "removed from service" and "declared inoperable" eighteen (18) times for the purpose of routine instrument surveillance tests in accordance with prescribed procedures.

The HPCI system was "declared inoperable" an additional four (4) times and "removed from service" on only one (1) of these occasions.

(The system is considered "removed from service" when administrative instructions are implemented to isolate or otherwise physically prevent the system from performing its function. The system is considered "inoperable" when it is removed-from-service or fails to function in accordance with Technical Specifications.)

2. The cumulative removed-from-service time for instrument surveillance testing was approximately 36 hours.

Additionally, the HPCI system was declared "inoperable" for a cumulative total of 29 days. Of this total "inoperable" time, the system was "removed-from-service" for only 16 days. The plant remained in a condition of Power Operation only 4 days during the period when the HPCI was removed from service and was placed in a condition of cold shutdown the remainder of the 16 day period.

4701

RW

3. The following routine tests were conducted on the HPCI system:

	<u>Total No</u>	<u>(a)*</u>	<u>(b)*</u>
(i). HPCI Pump Operability Test	19	13	6
(ii). HPCI Flow Rate Test	11	11	-
(iii). HPCI High Steam Flow Isolation Test	18	18	-
(iv). HPCI High Temperature Isolation Test	14	14	-
*(a). Functioned in accordance with design			
*(b). Failed to function in accordance with design			

The six instances of "failure to function in accordance with design" as shown above for (i) HPCI Pump Operability Test are reported as logged at the time these tests were performed. Subsequent evaluation indicated that five of these instances were not accountable as failures-to-function but rather were attributable to surveillance test conditions of main steam line flow effects on the HPCI flow metering that would not be present for the design conditions under which the HPCI system must operate. In the initial instances, the system was declared inoperable while resolution was sought. This is discussed in Ref. (1), (2), and (3). During this time, however, the HPCI system was able to function in accordance with design, as evidenced in Ref. (4).

Recent HPCI problems are discussed in Ref. (5) and (6).

4. During reactor operation, the HPCI has received a signal to operate one (1) time when the system was in service (Ref. 4) and one (1) time when the HPCI was out of service (Ref. 7).
5. There have been no instances during reactor operation when the HPCI received a signal to start and failed to function in accordance with design.

We hope that this information is suitable for your needs.

Yours very truly,



L O Mayer, P.E.
Director of Nuclear Support Services

LOM/DWJ/br

Attachment: List of references

cc: B H Grier

References:

Received w/ File 8-25-72

- (1). NSP letter to AEC, "Inoperability of the High Pressure Coolant Injection System," Monticello Nuclear Generating Plant, Docket No. 50-263, License No. DPR-22, R O Duncanson to P A Morris, dated September 15, 1971
- (2). NSP letter to AEC, "Inoperability of the High Pressure Coolant Injection System," Monticello Nuclear Generating Plant, Docket No. 50-263, License No. DPR-22, R O Duncanson to P A Morris, dated September 28, 1971
- (3). NSP letter to AEC, "Planned Modifications to High Pressure Coolant Injection System Steam Line Flow Sensing Device," Monticello Nuclear Generating Plant, Docket No. 50-263, License No. DPR-22, L O Mayer to P A Morris, dated March 2, 1972
- (4). NSP letter to AEC, "Reporting of Unusual Occurrences," Monticello Nuclear Generating Plant, Docket No. 50-263, License No. DPR-22, R O Duncanson to P A Morris, dated October 5, 1971
- (5). NSP letter to AEC, "Reporting of High Pressure Coolant Injection System Failure," Monticello Nuclear Generating Plant, Docket No. 50-263, License No. DPR-22, L O Mayer to A Giambusso, dated July 27, 1972
- (6). NSP letter to AEC, "Fast Start Failure of the High Pressure Coolant Injection System," Monticello Nuclear Generating Plant, Docket No. 50-263, License No. DPR-22, L O Mayer to A Giambusso, dated August 3, 1972
- (7). NSP letter to AEC, "Turbine Trip at 100% Power and Subsequent Events," Monticello Nuclear Generating Plant, Docket No. 50-263, License No. DPR-22, L O Mayer to A Giambusso, dated July 20, 1972

... ..

... ..

... ..

... ..

... ..

... ..

... ..

... ..