

FRDM: Northern States Power Company Minneapolis, Minnesota K. H. Clarity		DATE OF DOCUMENT: 4-28-71	DATE RECEIVED: 4-28-71	NO.: 25
TO: Dr. Peter A. Morris		LTR.	MEMO:	REPORT:
CLASSIF: U		OTHER: TWX		
POST OFFICE		ORIG.:	CC:	OTHER:
REG. NO:		1		
DESCRIPTION: (Must Be Unclassified) TWX advising plant will be shut down longer than 7 days....System expected to be returned to operable condition by Wednesday 5-5-71.....		ACTION NECESSARY <input type="checkbox"/>	CONCURRENCE <input type="checkbox"/>	DATE ANSWERED:
ENCLOSURES:		NO ACTION NECESSARY <input type="checkbox"/>	COMMENT <input type="checkbox"/>	BY:
REMARKS:		FILE CODE: 50-263		
		REFERRED TO	DATE	RECEIVED BY
		Knuth W/9 cys for ACTION	4-29-71	
		DISTRIBUTION:		
		Reg Files ARC PDR		
		Compliance (2) OGC, Rm P 506A		
		H. Price & Staff D. Thompson		
		Morris/Schroeder Skovholt		
		Boyd E.G. Case	DO NOT REMOVE	
		DTIE (Laughlin) NSIC (Buchanan)		
				fod

RECEIVED

1971 APR 28 PM 3 55

U.S. ATOMIC ENERGY COMM.
BETHESDA GEN. SERV. BR.
MAIL ROOM

66

XXXX

AT APPROXIMATELY ONE O,CLOCK PM ON THURSDAY,
APRIL 22, 1971 THE NPCL SYSTEM WAS DECLARED INOPERABLE
AND TAKEN OUT OF SERVICE FOR REPAIR OF MINOR STEAM LEAKS.
DURING THE MAINTENANCE OUTAGE THE LUBRICATION AND CONTROL
SYSTEM OIL WAS TESTED AND FOUND TO BE UNACCEPTABLY DIRTY.
NEW OIL HAS BEEN ORDERED AND AN OIL SYSTEM CLEANING AND
FLUSHING PROGRAM WILL BE CONDUCTED. THE FLUSH IS EXPECTED
TO BE COMPLETED AND THE SYSTEM RETURNED TO AN OPERABLE
CONDITION BY WEDNESDAY, MAY 5, 1971.

DURING THE NPCL OUTAGE, THE AVAILABILITY OF THE REMAINING
EMERGENCY CORE COOLING SYSTEMS WILL BE MAINTAINED IN
ACCORDANCE WITH TECHNICAL SPECIFICATION 3.5.D.2. THE
SURVEILLANCE REQUIREMENTS OF TECHNICAL SPECIFICATION
4.5.D.2 WILL BE REPEATED IF REACTOR OPERATION AT PRESSURES
ABOVE 150 PSIG IS CONDUCTED BEYOND THE SEVEN DAY OUT OF
SERVICE PERIOD.

M H CLARITY
ASSISTANT PLANT SUPERINTENDENT
MONTICELLO NUCLEAR GENERATING PLANT
END OR GA PLS

END

LOOKS OK HERE W R BOW

