

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8307010104 DOC. DATE: 83/06/24 NOTARIZED: YES DOCKET #  
 FACIL: 50-263 Monticello Nuclear Generating Plant, Northern States 05000263  
 AUTH. NAME AUTHOR AFFILIATION  
 MUSOLF, D. Northern States Power Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 Office of Nuclear Reactor Regulation, Director

SUBJECT: Application to amend License DPR-22, changing Tech Specs to comply w/NUREG-0737, Items II.F.1.1 - II.F.1.6 re accident monitoring instrumentation, per Generic Ltr 83-02.

DISTRIBUTION CODE: A046S COPIES RECEIVED: LTR 1 ENCL 40 SIZE: 3+44  
 TITLE: OR Submittal: TMI Action Plan Rgmt NUREG-0737 & NUREG-0660

NOTES: *Rec'd w/ check \$1,200*

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	NRR ORB2 BC 01	7 7		
INTERNAL:	ELD/HDS1	1 0	IE/DEPER DIR 33	1 1
	IE/DEPER/EPB	3 3	IE/DEPER/IRB	1 1
	NRR PAWLSON, W.	1 1	NRR/DHFS/DEPY29	1 1
	NRR/DL DIR 14	1 1	NRR/DL/ADL 16	1 1
	NRR/DL/ORAB 18	3 3	NRR/DSI/ADRS 27	1 1
	NRR/DSI/AEB	1 1	NRR/DSI/ASB	1 1
	NRR/DSI/RAB	1 1	NRR/DST DIR 30	1 1
	<u>REG FILE</u> 04	1 1	RGN3	1 1
EXTERNAL:	ACRS 34	10 10	INPO, J. STARNES	1 1
	LPDR 03	1 1	NRC PDR 02	1 1
	NSIC 05	1 1	NTIS	1 1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 42 ENCL 41



Northern States Power Company

414 Nicollet Mall  
Minneapolis, Minnesota 55401  
Telephone (612) 330-5500

June 24, 1983

Director  
Office of Nuclear Reactor Regulation  
US Nuclear Regulatory Commission  
Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT  
Docket No. 50-263 License No. DPR-22

License Amendment Request dated June 22, 1983

NUREG-0737 Technical Specifications - Response to  
NRC Generic Letter 83-02 dated January 10, 1983

Attached are three originals and 37 conformed copies of a request for a change in the Technical Specifications, Appendix A, of Operating License DPR-22. Also attached is one copy of the license amendment class determination and a check in the amount of \$1,200.00 for the amendment fee.

The proposed changes are being submitted as requested in a letter dated January 10, 1983 from Mr Darrel G Eisenhut, Director, Division of Licensing, USNRC (Generic Letter 83-02). In addition to the NUREG-0737 items covered by this letter, we have included proposed Technical Specification changes for accident monitoring instrumentation required by NUREG-0737, Items II.F.1.1 through II.F.1.6 following guidance provided in a letter dated December 7, 1981 from Mr Thomas A Ippolito, Chief, Operating Reactors Branch #2, Division of Licensing, USNRC.

All of the items required by Generic Letter 83-02 have been included in our proposed Technical Specification changes with the following exceptions:


- a. Item I.A.1.1.3, STA Training - Further guidance will be provided by the Commission. No action required at this time.
- b. Item II.E.4.1, Dedicated Hydrogen Penetrations - Fully redundant external hydrogen recombiners are currently being installed. Following installation, proposed Technical Specification changes will be submitted. These changes will include testing requirements for the dedicated containment penetrations being installed.
- c. Item II.E.4.2.5, Containment Pressure Setpoint - No change was necessary in the containment pressure setpoint. NRC Staff review of this item was documented in a letter dated August 31, 1981 from Mr Thomas A Ippolito, Chief, Operating Reactors Branch #2, Division of Licensing, USNRC.

8307010104 830624  
PDR ADOCK 05000263  
PDR

A046  
1/40  
Rec'd w/check \$1,200

- d. Item II.E.4.2.6, Containment Purge Valves - Proposed Technical Specification Changes were submitted as Exhibit A, Item 9, of our License Amendment Request dated September 24, 1982.
- e. Item II.E.4.2.7, Radiation Signal on Purge Valves - Further guidance will be provided by the Commission.
- f. Item II.K.3.19, Interlocks on Recirculation Pump Loops - This item is not applicable to the Monticello Nuclear Generating Plant.
- g. Item II.K.3.27, Common Reference Level - No Technical Specification changes are required to implement this item at the Monticello Nuclear Generating Plant. All reactor vessel water levels contained in the Technical Specifications refer to a common reference level. NRC acceptance of our implementation of this item is documented in a letter dated October 27, 1981 from Mr Thomas A Ippolito, Chief, Operating Reactors Branch #2, Division of Licensing, USNRC.
- h. Item II.K.3.45, Manual Depressurization - No Technical Specification changes or other action will be required by the NRC Staff. Documentation of this position is contained in a letter dated May 18, 1983 from Mr Domenic B Vassallo, Chief, Operating Reactors Branch #2, Division of Licensing, USNRC.

Exhibit A contains the proposed changes, reasons for change, and significant hazards evaluations. Exhibit B contains revised Technical Specification pages showing the proposed changes.

  
David Musolf  
Manager - Nuclear Support Services

cc: Regional Administrator - III, NRC  
NRR Project Manager, NRC  
Resident Inspector, NRC  
G Charnoff  
MPCA (State Contact)  
Attn: J W Ferman

Attachments

UNITED STATES NUCLEAR REGULATORY COMMISSION

NORTHERN STATES POWER COMPANY  
MONTICELLO NUCLEAR GENERATING PLANT

Docket No. 50-263

REQUEST FOR AMENDMENT TO  
OPERATING LICENSE NO. DPR-22

License Amendment Request Dated June 24, 1983

Northern States Power Company, a Minnesota corporation, request authorization for changes to the Technical Specifications as shown on the attachments labeled Exhibit A and Exhibit B. Exhibit A describes the proposed changes along with reasons for the change. Exhibit B is a set of Technical Specification pages incorporating the proposed changes.

This letter contains no restricted or other defense information.

NORTHERN STATES POWER COMPANY

By David Musolf  
David Musolf  
Manager - Nuclear Support Services

On this 24th day of June, 1983 before me a notary public in and for said County, personally appeared David Musolf, Manager - Nuclear Support Services, and being first duly sworn acknowledged that he is authorized to execute this document on behalf of Northern States Power Company, that he knows the contents thereof and that to the best of his knowledge, information and belief, the statements made in it are true and that it is not interposed for delay.

Dody A Brose

