

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8411160306 DOC.DATE: 84/11/08 NOTARIZED: YES DOCKET #
 FACIL:50-263 Monticello Nuclear Generating Plant, Northern States 05000263
 AUTH.NAME AUTHOR AFFILIATION
 MUSOLF,D. Northern States Power Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Office of Nuclear Reactor Regulation, Director

SUBJECT: Forwards Rev 1 to 840830 application for amend to License
 DPR-22, revising Tech Specs to allow reactor water level or
 drywell pressure instruments to be removed from svc during
 outage for maint & testing.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 1+2
 TITLE: OR Submittal: General Distribution

NOTES: OL:09/08/70 05000263

	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT ID CODE/NAME		COPIES	
			LTR	ENCL			LTR	ENCL
	NRR ORB2 BC	01	7	7				
INTERNAL:	ACRS	09	6	6	ADM/LFMB		1	0
	ELD/HDS1		1	0	NRR/DE/MTEB		1	1
	NRR/DL DIR		1	1	NRR/DL/ORAB		1	0
	NRR/DSI/METB		1	1	NRR/DSI/RAB		1	1
	<u>REG FILE</u>	04	1	1	RGN3		1	1
EXTERNAL:	LPDR	03	1	1	NRC PDR	02	1	1
	NSIC	05	1	1	NTIS		1	1



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401
Telephone (612) 330-5500

November 8, 1984

Director
Office of Nuclear Reactor Regulation
U S Nuclear Regulatory Commission
Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

Revision No. 1 to License Amendment Request Dated August 30, 1984
Clarification of Radiation Monitor Requirements

Enclosed are three originals and 37 conformed copies of a revision to our License Amendment Request dated August 30, 1984. No additional licensing review application fee is necessary since a fee accompanied the August 30, 1983 submittal.

The revision consists of a correction to page 59 included in Exhibit B of the August 30, 1984 submittal. This page has been corrected to clarify the notes to Table 3.2.4. The page included in the August 30, 1984 application would not allow reactor water level or drywell pressure instruments to be removed from service during outages for maintenance and testing.

A revised page 59 is attached. All other portions of our August 30, 1984 submittal are unaffected by this correction.


David Musolf
Manager - Nuclear Support Services

DMM/dab

c: Regional Administrator - III, NRC
Resident Inspector, NRC
NRR Project Manager, NRC
G Charnoff
MPCA (State Contact)
Attn: J W Ferman

Attachments

*Flow
11*

8411160306 841108
PDR ADOCK 05000263
P PDR