

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8411160312 DOC. DATE: 84/11/09 NOTARIZED: YES DOCKET #
 FACIL: 50-263 Monticello Nuclear Generating Plant, Northern States 05000263
 AUTH. NAME AUTHOR AFFILIATION
 MUSOLF, D. Northern States Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Office of Nuclear Reactor Regulation, Director

SUBJECT: Forwards rev 1 to application for amend to License DPR-22,
 changing Tech Specs re degraded voltage protection logic.
 Table 3.2.6 revised to include allowable setting band.

DISTRIBUTION CODE: A015D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+3
 TITLE: OR Submittal: Onsite Emergency Power System

NOTES: 05000263
 OL: 09/08/70

	RECIPIENT			COPIES		RECIPIENT			COPIES	
	ID	CODE/NAME		LTR	ENCL	ID	CODE/NAME		LTR	ENCL
	NRR	ORB2 BC	01	7	7					
INTERNAL:	ACRS		16	6	6	ADM/LFMB			1	0
	NRR/DL/ORAB		12	1	1	NRR/DSI/ICSB	09		1	1
	NRR/DSI/PSB		14	1	1	<u>REG FILE</u>	04		1	1
	RGN3			1	1	RM/DDAMI/MIB	18		1	1
EXTERNAL:	LPDR		03	1	1	NRC PDR	02		1	1
	NSIC		05	1	1	NTIS			1	1



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401
Telephone (612) 330-5500

November 9, 1984

Director
Office of Nuclear Reactor Regulation
U S Nuclear Regulatory Commission
Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

Revision No. 1 to License Amendment Request Dated July 27, 1984
Degraded Voltage Protection Logic

Enclosed are three originals and 37 conformed copies of a revision to our License Amendment Request dated July 27, 1984. No additional licensing review fee is necessary since an application fee accompanied the July 27, 1984 submittal.

A revision to two pages in the July 27, 1984 License Amendment Request is proposed. Table 3.2.6 on page 60a is revised to explicitly include an allowable relay setting band. This is consistent with the format of the other tables in Section 3.2 of the Technical Specifications. The table of allowable deviations on page 71 is revised to take into account the changes to Table 3.2.6 and also to provide more realistic deviations for the loss of voltage relays.

Revised pages 60a and 71 are attached. All other portions of our July 27, 1984 submittal are unaffected by these corrections.


David Musolf
Manager - Nuclear Support Services

DMM/dab

c: Regional Administrator - III, NRC
NRR Project Manager, NRC
Resident Inspector, NRC
G Charnoff
MPCA (State Contact)
Attn: J W Ferman

Attachments

*AOIS
1/1*

8411160312 844109
PDR ADOCK 05000263
P PDR