

Bases Continued:

- 3.2 The RBM bypass time delay is set low enough to assure minimum rod movement while upscale trips are bypassed.

The IRM rod block function provides local as well as gross core protection. The scaling arrangement is such that trip setting is less than a factor of 10 above the indicated level. Analysis of the worst case accident results in rod block action before MCPR approaches the Safety Limit (T.S.2.1.A).

A downscale indication of an APRM or IRM is an indication the instrument has failed or the instrument is not sensitive enough. In either case the instrument will not respond to changes in control rod motion and thus control rod motion is prevented. The downscale trips are set at 3/125 of full scale.

For effective emergency core cooling for the small pipe break the HPCI or Automatic Pressure Relief system must function since for these breaks, reactor pressure does not decrease rapidly enough to allow either core spray or LPCI to operate in time. The arrangement of the tripping contacts is such as to provide this function when necessary and minimize spurious operation. The trip settings given in the specification are adequate to assure the above criteria is met. Reference Section 6.2.4 and 6.2.6 FSAR. The specification preserves the effectiveness of the system during periods of maintenance, testing, or calibration, and also minimizes the risk of inadvertent operation; i.e., only one instrument channel out of service.

Six radiation monitors (two reactor building vent plenum, two reactor building vent wide range gas and two refueling floor) are provided which initiate isolation of the reactor building and operation of the standby gas treatment system following a refueling accident. The monitors measure radioactivity in the reactor building ventilation exhaust and on the refueling floor. One upscale trip signal or two downscale/inoperable trip signals, from a pair of monitors performing the same function, will cause the desired action. Trip settings of 100 mR/hr for the reactor building vent plenum monitors and the refueling floor monitors are based upon initiating normal ventilation isolation and standby gas treatment system operation so that none of the activity released during the refueling accident leaves the reactor building via the normal ventilation stack but that all the activity is processed by the standby gas treatment system. The reactor building vent wide range gas monitors trip settings will be calculated in accordance with NRC approved methods in the ODCM to ensure that the alarm/trip will occur prior to exceeding the limits of 10CFR Part 20.

The recirculation pump trip description and performance analysis is discussed in Topical Report NEDO-25016, September 1976, "Evaluation of Anticipated Transients Without Scram for the Monticello Nuclear Generating Plant". (See September 15, 1976 letter from Mr L O Mayer, NSP, to Mr D L Ziemann, USNRC.) The pump trip is provided to minimize reactor pressure in the highly unlikely event of a plant transient coincident with the failure of all control rods to scram. The rapid flow reduction

	Trip Function	Deviation
Reactor Building Ventilation Isolation and Standby Gas Treatment System Initiation Specification 3.2.E.3 and Table 3.2.4	Reactor Building Vent Plenum Monitors	+5 mR/hr
	Refueling Floor Radiation Monitors	+5 mR/hr
	Low Reactor Water Level High Drywell Pressure	-6 inches +1 psi
Primary Containment Isolation Functions Table 3.2.1	Low Low Water Level	-3 inches
	High Flow in Main Steam Line	+2%
	High Temp. in Main Steam Line Tunnel	+10°F
	Low Pressure in Main Steam Line	-10 psi
	High Drywell Pressure	+1 psi
	Low Reactor Water Level	-6 inches
	HPCI High Steam Flow	+7,500 lb/hr
	HPCI Steam Line Area High Temp.	+2°F
	RCIC High Steam Flow	+2250 lb/hr
	RCIC Steam Line Area High Temp	+2°F
Shutdown Cooling Supply ISO	+7 psi	

3.2 BASES

70
REV

TABLE 4.8.1 - RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION
SURVEILLANCE REQUIREMENTS

Instrument	Sensor Check Frequency	Source Check Frequency	Functional Test Frequency	Calibration Frequency
Liquid Radwaste Effluent Line Gross Radioactivity Monitor	Daily during release	Immediately Prior to Each Release	Within 3 months prior to making a release	Within 12 months prior to making a release.*
Liquid Radwaste Effluent Line Flow Instrument	Daily during release	-	Within 3 months prior to making a release	Within 12 months prior to making a release.
Instruments used in Determination of Discharge Canal Flow	Daily during release	-	Within 3 months prior to making a release	Within 18 months prior to making a release.
Service Water Discharge Pipe Gross Radioactivity Monitor	Daily	Monthly	Quarterly	Each Operating Cycle*
Discharge Canal Gross Radioactivity Monitor	Daily	Monthly	Quarterly	Each Operating Cycle**
Turbine Building Normal Drain Sump Monitor	Daily	Monthly	Quarterly	Each Operating Cycle
Level Monitors for Temporary Outdoor Tanks Holding Radioactive Liquid	Daily when in use	-	Quarterly when in use	Each Operating Cycle when in use

* - The initial Instrument Calibration shall be performed using one or more of the reference standards certified by the National Bureau of Standards (NBS) or using sources traceable to NBS standards. These standards shall permit calibrating the system over its intended range of energy and measurement range. For subsequent calibration sources that have been related to the initial calibration shall be used.

** - An initial Instrument Calibration was performed using a liquid reference standard over the systems intended range of energy and measurement range. Solid calibration sources traceable to NBS Standards currently being applied for instrument calibrations were related to the initial calibration. If, in the future, the canal radioactivity monitor is replaced, the following conditions shall apply:

- a. Detector response and system efficiency shall be equal to or better than the present system.
- b. Footnote (*) shall apply.