

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8608010153 DDC. DATE: 86/07/22 NOTARIZED: YES DOCKET #
 FACIL: 50-263 Monticello Nuclear Generating Plant, Northern States 05000263
 AUTH. NAME AUTHOR AFFILIATION
 MUSOLF, D. Northern States Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Office of Nuclear Reactor Regulation, Director (post 851125)

SUBJECT: Forwards Rev 1 to 860324 application for amend to License
 DPR-22, revising Tech Specs re allowed time limits for
 adjusting setpoints & safety sys settings. Fee paid.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+2
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTTR	ENCL		LTTR	ENCL
	BWR EB	1	1	BWR EICSB	2	2
	BWR FOB	1	1	BWR PD1 LA	1	0
	BWR PD1 PD 01	5	5	AULUCK, R	1	1
	BWR PSB	1	1	BWR RSB	1	1
INTERNAL:	ADM/LFMB	1	0	ELD/HDS1	1	0
	NRR/ORAS	1	0	<u>REG FILE</u> 04	1	1
	RCN3	1	1			
EXTERNAL:	EG&G BRUSKE, S	1	1	LPDR 03	1	1
	NRC PDR 02	1	1	NSIC 05	1	1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 22 ENCL 18



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401
Telephone (612) 330-5500

July 22, 1986

Director
Office of Nuclear Reactor Regulation
U S Nuclear Regulatory Commission
Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22


Revision No. 1 to
License Amendment Request Dated March 24, 1986
Single Recirculation Loop Operation

Attached are three originals and 37 conformed copies of a revision to our License Amendment Request dated March 24, 1986. A license amendment fee for this revision was determined to be unnecessary because a fee was included with the original submittal.

This submittal proposes changes to the allowed time limits for adjusting setpoints and safety system settings and a clarification of the LPRM detectors to be used for baseline data and monitoring purposes during operation with only one recirculation loop in operation. These changes are the result of NRC Staff review of our March 24, 1986 submittal. These changes have been discussed with the Monticello Project Manager in the Division of Licensing.

This submittal consists of revised page 114 of Exhibit B.

Please contact us if you have any question related to this revised License Amendment Request.


David Musolf
Manager - Nuclear Support Services

DMM/RJM/rjm

c: Regional Administrator-III, NRC
NRR Project Manager, NRC
Resident Inspector, NRC
MPCA
Attn: F W Ferman
G Charnoff

Attachments

8608010153 860722
PDR ADOCK 05000263
P PDR

A001
11