

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8610210476 DOC. DATE: 86/10/10 NOTARIZED: NO DOCKET #
 FACIL: 50-263 Monticello Nuclear Generating Plant, Northern States 05000263
 AUTH. NAME AUTHOR AFFILIATION
 MUSOLF, D. Northern States Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Office of Nuclear Reactor Regulation, Director (post 851125)

SUBJECT: Supplemental application to amend License DPR-22, revising
 Tech Specs to incorporate time limits on allowed sys control
 inoperability for alternate shutdown sys. Revises 860331
 amend request.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+1
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	BWR EB		1	1		BWR EICSB		2	2
	BWR FOB		1	1		BWR PD1 LA		1	0
	BWR PD1 PD	01	5	5		LYNCH, D		1	1
	BWR PSB		1	1		BWR RSB		1	1
INTERNAL:	ADM/LFMB		1	0		ELD/HDS1		1	0
	NRR/DHET/TSCB		1	1		NRR/ORAS		1	0
	<u>REG FILE</u>	04	1	1		RGN3		1	1
EXTERNAL:	EG&G BRUSKE, S		1	1		LPDR	03	1	1
	NRC PDR	02	1	1		NSIC	05	1	1



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401
Telephone (612) 330-5500

October 10, 1986

Director
Office of Nuclear Reactor Regulation
U S Nuclear Regulatory Commission
Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT

DOCKET NO. 50-263 LICENSE NO. DPR-22

Revision No. 1 to License Amendment
Request dated March 31, 1986


Attached is a revised Exhibit B page for our License Amendment Request dated March 31, 1986. The attached Exhibit B page 227c should be substituted for page 227c of the original submittal.

This revised page incorporates time limits on the allowed system control inoperability for the Alternate Shutdown System and for the compensatory measures taken in lieu of returning the system controls to operable status. This is being done at the request of the Monticello NRR Project Manager and NRC technical lead reviewer assigned to this license amendment.

The evaluations, contained in Exhibit A, of our original submittal are not effected by these revisions.

In response to a related NRC staff question, the hourly fire watch patrol required by this specification will be an individual trained in the use of fire extinguishers.

A license amendment fee for this submittal was determined to be unnecessary because it is a revision to a License Amendment Request for which a fee has already been paid.


David Musolf
Manager - Nuclear Support Services

c: Regional Administrator-III, NRC
Resident Inspector, NRC
NRR Project Manager, NRC
G Charnoff

Attachment

8610210476 861010
PDR ADOCK 05000263
P PDR

A001
11