

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: B611140130 DDC. DATE: 86/11/03 NOTARIZED: YES DOCKET #
 FACIL: 50-263 Monticello Nuclear Generating Plant, Northern States 05000263
 AUTH. NAME AUTHOR AFFILIATION
 MUSOLF, D. Northern States Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director (post 851125)

SUBJECT: Forwards Rev 4 to B20924 application for amend to License
 DPR-22, incorporating NRC requirement for vent & purge valve
 operating time.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2 + 10
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL		RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	
	BWR EB	1	1	BWR EICSB	2	2
	BWR FOB	1	1	BWR PD1 LA	1	0
	BWR PD1 PD 01	5	5	LYNCH, D	1	1
	BWR PSB	1	1	BWR RSB	1	1
INTERNAL:	ADM/LFMB	1	0	ELD/HDS1	1	0
	NRR/DHET/TSCB	1	1	NRR/ORAS	1	0
	<u>REG FILE</u> 04	1	1	RGN3	1	1
EXTERNAL:	EG&G BRUSKE, S	1	1	LPDR 03	1	1
	NRC PDR 02	1	1	NSIC 05	1	1



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401
Telephone (612) 330-5500

November 3, 1986

Harold R Denton, Director
Office of Nuclear Reactor Regulation
U S Nuclear Regulatory Commission
Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

Revision No. 4 to License Amendment
Request Dated September 24, 1982

The purpose of this letter is to transmit a revision to our License Amendment dated September 24, 1986.

Following NRC Staff review of Exhibit A, Item 9, "Specification 3.7.A.5, Containment Purge and Vent Operation," it was determined that a faster operating time must be specified for the containment purge and vent valves to meet current NRC Staff requirements. Additional information related to this issue was contained in our letter dated November 22, 1985.

Attached is new Exhibit B page 172 which incorporates the NRC Staff requirement for vent and purge valve operating time. This page has also been revised to clarify one entry and correct the normal position of several purge and vent valves. Page 165 of our original submittal has been revised to reflect a recent Technical Specification change related to another system on this page. Pages 166 and 171 of our original submittal have been slightly revised to correct a typographical error and clarify wording.

NRC review and approval of this request will complete action on the generic concern related to demonstration of containment purge and vent valve operability (B-24) for the Monticello Nuclear Generating Plant. It will also complete all required action related to our License Amendment Request dated September 24, 1982. The attachment is a complete replacement of Exhibit A, Item (9), and related Exhibit B pages of our original September 24, 1982 submittal.

8611140130 861103
PDR ADOCK 05000263
P PDR


A001
1/1

Director of NRR
November 3, 1986
Page 2

Northern States Power Company

A license amendment fee for this revision was determined to be unnecessary because it is a correction to a License Amendment Request for which a fee has already been paid.

Please contact us if you require additional information to complete your action related to this item.


David Musolf
Manager - Nuclear Support Services

DMM/TMP/tp

c: Regional Administrator-III, NRC
NRR Project Manager, NRC
Resident Inspector, NRC
G Charnoff
MPCA Attn: Dr J W Ferman (State Contact)

Attachments