

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8706260384 DOC. DATE: 87/06/22 NOTARIZED: YES DOCKET #
 FACIL: 50-263 Monticello Nuclear Generating Plant, Northern States 05000263
 AUTH. NAME AUTHOR AFFILIATION
 MUSOLF, D. Northern States Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Office of Nuclear Reactor Regulation, Director (Post 870411)

SUBJECT: Forwards application for amend to License DPR-22, revising
 Tech Spec Sections 3.4 & 4.4 to implement ATWS rule
 requirements.

DISTRIBUTION CODE: A055D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2 + 21
 TITLE: OR/Licensing Submittal: Salem ATWS Events GL-83-28

NOTES:

| | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|-----------|---------------------------|---------------------|---------------------------|---------------------|
| | PD3-3 LA | 1 0 | PD3-3 PD | 3 3 |
| | SCALETTI, D | 1 1 | | |
| INTERNAL: | ARM/DAF/LFMB | 1 0 | NRR LASHER, D | 1 1 |
| | NRR/DEST/ICSB | 1 1 | NRR/DEST/PSB | 1 0 |
| | NRR/DEST/RSB | 1 1 | NRR/DLPQ/QAB | 1 0 |
| | NRR/DOEA/GCB | 1 0 | NRR/PMAS/ILRB | 1 0 |
| | NRR/PMAS/PMSB | 1 0 | OGC/HDS1 | 1 0 |
| | REG FILE 01 | 1 1 | | |
| EXTERNAL: | LPDR | 1 1 | NRC PDR | 1 1 |
| | NSIC | 1 1 | | |

w/cheap \$150
 #476449



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401
Telephone (612) 330-5500

June 22, 1987

10 CFR Part 50
Section 50.90

Director
Office of Nuclear Reactor Regulation
U S Nuclear Regulatory Commission
Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

License Amendment Request Dated June 22, 1987
ATWS Rule Requirements

- Reference: (a) Letter from T A Ippolito (NRC) to L O Mayer (NSP) dated September 15, 1978 entitled, "Amendment No. 35 to DPR-22 dated September 15, 1978, Recirculation Pump Trip System".
- (b) Letter from R Auluck (NRC) to D M Musolf (NSP) dated July 1, 1986 entitled, "Miscellaneous Technical Specifications (TAC 49101 and 61425)".
- (c) Letter from D M Musolf (NSP) to the Director of NRR dated October 11, 1985 entitled, "Schedule for Compliance with 10 CFR Part 50, Section 50.62, "Requirements for Reduction of Risk from Anticipated Transients Without Scram (ATWS) Events for Light-Water-Cooled Nuclear Power Plants.".

Attached is a request for a change of Technical Specifications, Appendix A, of Operating License DPR-22. Also enclosed is a check in the amount of \$150.00 in accordance with 10 CFR Part 170 as the required application fee.

This submittal proposes changes to Section 3.4 and 4.4 of the Monticello Technical Specifications. The requested changes address the implementation of the requirements of 10 CFR Part 50, Section 50.62, "Requirements for reduction of risk from anticipated transients without scram (ATWS) events for light-water-cooled nuclear power plants," as applicable to Boiling Water Reactors. Specifically, Paragraph 50.62(c)(4), which addresses the Standby Liquid Control System (SLCS), is addressed. Paragraphs 50.62(c)(3) and 50.62(c)(5) which address the alternate rod injection (ARI) and Recirculation Pump Trip (RPT) requirements, have already been incorporated into the Monticello Technical

8706260384 870622
PDR ADOCK 05000263
P PDR

Aoss
11

w/ check
\$150
*A76249

Dir of NRR
June 22, 1987
Page 2


Northern States Power Company

Specifications as approved by References (a) and (b). This submittal is intended to fulfill the documentation requirements of Paragraph 50.62(c)(6) for the Standby Liquid Control System. The only remaining documentation which needs to be submitted to fulfill the requirements of Paragraph 50.62(c)(6) is information on the configuration and type of the redundant scram air header exhaust valves and the design and performance of the system. As noted in Reference (c) this information will be submitted later this year.

Exhibit A contains a description of the proposed changes, the reason for these changes, and a significant hazards evaluation. Exhibit B contains marked up Technical Specification pages showing the proposed changes.

It is requested that these changes be reviewed and approved by the NRC Staff prior to October 1, 1987 to permit modifications to the SLCS to be made during the 1987 refueling outage. These changes should be issued with an implementation date of, "Prior to startup for Cycle 13."

Please contact us if you have any questions related to our request.


David Musolf
Manager - Nuclear Support Services

DMM/TAP

c: Regional Administrator-III, NRC
NRR Project Manager, NRC
Resident Inspector, NRC
MPCA
Attn: J W Ferman
G Charnoff

Attachments