

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9008060310 DOC. DATE: 90/07/31 NOTARIZED: YES DOCKET #
 FACIL: 50-263 Monticello Nuclear Generating Plant, Northern States 05000263
 AUTH. NAME AUTHOR AFFILIATION
 PARKER, T.M. Northern States Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Office of Nuclear Reactor Regulation, Director (Post 870411) R

SUBJECT: Forwards application for amend to License DPR-22, updating I
 min oil storage tank level from 26,250 to 32,500 gallons. I

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+10 D
 TITLE: OR Submittal: General Distribution S

NOTES: NRR/LONG, W. 05000263 /

	RECIPIENT ID CODE/NAME	COPIES	LTTR	ENCL	RECIPIENT ID CODE/NAME	COPIES	LTTR	ENCL	
	PD3-1 LA	1		1	PD3-1 PD	1		1	D
	LONG, B.	5		5					D
INTERNAL:	NRR/DET/ECMB 9H	1		1	NRR/DOEA/OTSB11	1		1	S
	NRR/DST 8E2	1		1	NRR/DST/SELB 8D	1		1	
	NRR/DST/SICB 7E	1		1	NRR/DST/SRXB 8E	1		1	
	NUDOCS-ABSTRACT	1		1	OC/LEMB	1		0	
	OGC/HDS1	1		0	<u>REG FILE</u> 01	1		1	
	RES/DSIR/EIB	1		1					
EXTERNAL:	LPDR	1		1	NRC PDR	1		1	
	NSIC	1		1					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 21 ENCL 19

AAA/2
cut



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401-1927
Telephone (612) 330-5500

July 31, 1990

Director
Office of Nuclear Reactor Regulation
U S Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

10 CFR Part 50
Section 50.90

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

License Amendment Request Dated July 31, 1990
Diesel Fuel Oil Storage Tank Level

Attached is a request for a change in the Technical Specifications, Appendix A of the Operating License for the Monticello Nuclear Generating Plant. This request is submitted in accordance with the provisions of 10 CFR Part 50, Section 50.90.

This amendment updates the minimum oil storage tank level from 26,250 gallons to 32,500 gallons, and clarifies that a diesel generator full load is 2500 KW.

Exhibit A contains a description of the proposed changes, the reasons for requesting the changes, and a Safety Evaluation/Determination of Significant Hazards Consideration. Exhibit B contains the Technical Specification pages marked up with the proposed wording changes. Exhibit C contains revised Monticello Technical Specification pages.

Please contact us if you require further information related to this request.

Thomas M Parker
Manager
Nuclear Support Services

c: Regional Administrator-III, NRC
NRR Project Manager, NRC
Resident Inspector, NRC
MPCA
Attn: J W Ferman
G Charnoff

Attachments: Affidavit to the US Nuclear Regulatory Commission
Exhibit A - Evaluation of Proposed Changes
Exhibit B - Technical Specification Pages marked up with
proposed wording changes
Exhibit C - Revised Monticello Technical Specification Pages

9008060310 900731
PDR ADOCK 05000263
P PDC

A001
1/1