

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9106190191 DOC.DATE: 91/06/13 NOTARIZED: NO DOCKET #  
FACIL:50-263 Monticello Nuclear Generating Plant, Northern States 05000263  
AUTH.NAME AUTHORITY AFFILIATION  
PARKER,T.M. Northern States Power Co.  
RECIP.NAME RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

SUBJECT: Forwards application for amend to License DPR-22, changing description of remote test panel for drywell-suppression chamber vacuum breakers to reflect new test switches installed as part of control room human factors upgrade.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+20  
TITLE: OR Submittal: General Distribution

NOTES: NRR/LONG, W.

05000263

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD3-1 LA	1 1	PD3-1 PD	1 1
LONG, B.	2 2		
INTERNAL: NRR/DET/ECMB 7D	1 1	NRR/DET/ESGB	1 1
NRR/DOEA/OTSB11	1 1	NRR/DST 8E2	1 1
NRR/DST/SELB 7E	1 1	NRR/DST/SICB8H7	1 1
NRR/DST/SRXB 8E	1 1	NUDOCS-ABSTRACT	1 1
OC/LEMB	1 0	OGC/HDS1	1 0
<u>REG FILE</u> 01	1 1	RES/DSIR/EIB	1 1
EXTERNAL: NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 16

AA.2



Northern States Power Company

414 Nicollet Mall  
Minneapolis, Minnesota 55401-1927  
Telephone (612) 330-5500

June 13, 1991

U S Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

10 CFR Part 50  
Section 50.90

MONTICELLO NUCLEAR GENERATING PLANT  
Docket No. 50-263 License No. DPR-22

License Amendment Request Dated June 13, 1991  
Drywell - Suppression Chamber Vacuum Breaker Test Switch  
Description and Diesel Fuel Oil Storage Tank Minimum Level

Attached is a request for a change in the Technical Specifications, Appendix A of the Operating License for the Monticello Nuclear Generating Plant. This request is submitted in accordance with the provisions of 10 CFR Part 50, Section 50.90.

The first portion of this amendment involves changing the description of the remote test panel for the drywell - suppression chamber vacuum breakers to reflect new test switches installed as part of the control room human factors upgrade.

The second portion of this amendment involves increasing the minimum level to be maintained in the Diesel Fuel Oil Storage Tanks in order to account for permissible variations in the specific gravity of the diesel fuel.

Exhibit A contains a description of the proposed changes, the reasons for requesting the changes, and a Safety Evaluation/Determination of Significant Hazards Consideration. Exhibit B contains the current Technical Specification pages marked up with the proposed changes. Exhibit C contains revised Monticello Technical Specification pages.


9106190191 910613  
PDR ADDCK 05000263  
P PDR

ADD 1/1

USNRC  
June 13, 1991  
Page 2

Northern States Power Company

Please contact us if you require further information related to this request.



Thomas M Parker  
Manager  
Nuclear Support Services

c: Regional Administrator-III, NRC  
NRR Project Manager, NRC  
Resident Inspector, NRC  
MPCA, Attn: J W Ferman  
J Silberg

Attachments: Affidavit to the US Nuclear Regulatory Commission  
Exhibit A - Evaluation of Proposed Changes  
Exhibit B - Technical Specification pages marked up with  
proposed wording changes  
Exhibit C - Revised Monticello Technical Specification Pages