

October 21, 1992

Docket No. 50-263

Mr. Thomas M. Parker, Manager  
Nuclear Support Services  
Northern States Power Company  
414 Nicollet Mall  
Minneapolis, Minnesota 55401

Dear Mr. Parker:

DISTRIBUTION

~~Docket File~~  
NRC & LPDRs  
PD31 Rdg File  
JRoe  
JZwolinski  
LMarsh  
WLong  
OGC  
DHagen MNBB-3206  
ACRS(10)  
OPA  
OC/LFMB

Monticello P/F  
WShafer  
RDefayette  
SNewberry 8/H/7

SUBJECT: MONTICELLO - WITHDRAWAL OF AN AMENDMENT REQUEST (TAC NO. M74965)

By letter dated October 21, 1991, you applied for an amendment to the Facility Operating License No. DPR-22. The proposed change would have added new limiting conditions for operation (LCO) and surveillance requirements for reactor vessel overfill protection instrumentation. Subsequently, by letter dated September 21, 1992, you withdrew the amendment request based on the staff's position that a license amendment is no longer considered necessary for certain facilities, including Monticello, provided the reactor feedwater pump trip instrumentation is periodically tested under the control of plant procedures.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication. If you have any questions concerning this action, please contact me at (301) 504-3026.

Sincerely,

Original signed by

William O. Long, Project Manager  
Project Directorate III-1  
Division of Reactor Projects - III/IV/V  
Office of Nuclear Reactor Regulation

Enclosure:  
Notice

cc w/enclosure:

See next page

\*SEE PREVIOUS CONCURRENCE

OFFICE	LA:PD31*	PM:PD31	BC:SCIB*	D:PD31 <i>W</i>
NAME	MShuttleworth	WLong:jkd	SNewberry	LMarsh
DATE	10/21/92	/ /92	10/1/92	10/21/92

OFFICIAL RECORD COPY

FILENAME: B:\M74965.LTR

9210270319 921021  
PDR ADOCK 05000263  
P PDR

NRC FILE CENTER COPY

*CP*  
*DF01*