REGULATERY INFORMATION DISTRIBUTION YSTEM (RIDS)

DOC.DATE: 80/10/15 NOTARIZED: NO DOCKET # ACCESSION NBR:8010220495 FACIL:50-263 Monticello Nuclear Generating Plant, Northern States

05000263

AUTH.NAME MAYER, L.O.

RECIP.NAME

AUTHOR AFFILIATION Northern States Power Co.

RECIPIENT AFFILIATION

Office of Nuclear Reactor Regulation, Director

SUBJECT: Advises that evaluation of Task A-31, "RHR Shutdown Requirements" will be completed by 810415. Facility has been reviewed for safe shutdown capability as part of fire protection review program.

DISTRIBUTION CODE: A001S COPIES RECEIVED:LTR ___ENCL ___ TITLE: General Distribution for after Issuance of Operating License

NOTES:

ACTION:	RECIPIENT ID CODE/NAME IPPOLITO, T. 0		ES ENCL 1	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL	
INTERNAL:	D/DIR, HUM FACO NRC PDR 0 OR ASSESS BR 1	2 1	Ď	I&E OFLO REG FILE	06 11 01	2 1 1	e e
EXTERNAL:	ACRS 0 NSIC 0		16	LPDR	03	1	

OCT 23 1980





NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

October 15, 1980

Director
Office of Nuclear Reactor Regulation
U S Nuclear Regulatory Commission
Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License DPR-22

Resolution of Task A-31 "RHR Shutdown Requirements"

One of the "Unresolved Safety Issues Relating to Nuclear Power Plants" indentified by the NRC Staff in their Annual Reports to Congress relates to the safe cold shutdown of a plant following an incident not related to a loss of coolant accident. Regulatory Guide 1.139 has been issued for comment by the Staff in response to this concern. This Regulatory Guide requires plants applying for construction permits after January 1, 1978 to have the capability to proceed from full power operation to cold shutdown in less than 36 hours using only safety-grade systems, either on or off-site power, and with the assumption of a single failure.

Guidance on resolution of this issue for plants whose construction permit application was made prior to January 1, 1978 has not yet been issued by the Staff and therefore a detailed comparison of the Monticello facility to the requirements of Regulatory Guide 1.139 has not been completed. In an effort to resolve this issue for the Monticello Full Term Operating License proceedings, however, we will undertake this evaluation and provide the results to the NRC Staff for their review. A preliminary estimate of the effort required to perform this evaluation indicates that a completion date of April 15, 1981 can be met.

It should be noted that the Monticello facility has been reviewed for safe shutdown capability as part of the current fire protection review program. This evaluation assumed the use of non-safeguards grade equipment in some instances. Following the completion of a small number of plant modifications required by the Fire Protection Safety Evaluation Report, issued by the NRC Staff on August 29, 1979, the plant will have the capability to go to cold shutdown in less than 72 hours using on or off-site power. The maximum credible fire in any area of the plant was assumed in this evaluation. This assumption is equivalent to multiple single failures in many cases.

Director NRR ·

- 2 -

October 15, 1980

Please contact us if you have any questions related to our proposed plans for resolving this issue.

L O Mayer, PE

Manager of Nuclear Support Services

LOM/DMM/bd

cc: J G Keppler

G Charnoff

NRC Resident Inspector