

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8110080361 DOC. DATE: 81/10/01 NOTARIZED: NO DOCKET #
 FACIL: 50-263 Monticello Nuclear Generating Plant, Northern States 05000263
 AUTH: NAME: AUTHOR AFFILIATION
 MAYER, L. O. Northern States Power Co.
 RECIP. NAME: RECIPIENT AFFILIATION
 Office of Nuclear Reactor Regulation, Director

SUBJECT: Provides final test results demonstrating operational adequacy of safety/relief valves, discharge piping & supports, per NUREG-0737 Item II.D.1. Final test results contained in NEDE-24988-P.

DISTRIBUTION CODE: A046S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Response to NUREG-0737/NUREG-0660 TMI Action Plan Rgnts (OL's)

NOTES:

ACTION:	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL		RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	ORB #2 BC 05	7			
INTERNAL:	A/D C&S SYS 27	1		A/D C&S ENG 22	1
	A/D FOR TECH 32	1		A/D GEN PROJ 31	1
	A/D LICENS 16	1		A/D M&Q ENG 23	1
	A/D OP REACT 15	1		A/D PLANT SYS 25	1
	A/D RAD PROT 26	1		A/D SAFETY AS 17	1
	DEP. DIR, DHFS 29	1		DIR, EM PREP 33	1
	DIRECTOR, DE 21	1		DIRECTOR, DHFS 28	1
	DIRECTOR, DL 14	1		DIRECTOR, DSI 24	1
	DIRECTOR, DST 30	1		ELD	1
	I&E 12	2		IE/EPDB	1
	IE/EPLB	1		OR ASSESS BR 18	3
	PDR 02	1		RAD ASMT BR	1
	<u>REG. FILE</u> 01	1			
EXTERNAL:	ACRS 34	16	1	FEMA-REP DIV	1
	INPO, J. STARNES	1		LPDR 03	1
	NSIC 04	1		NTIS	1

OCT 09 1981

TOTAL NUMBER OF COPIES REQUIRED: LTR 56 ENCL 0

42



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401
Telephone (612) 330-5500

October 1, 1981

Director of Nuclear Reactor Regulation
U S Nuclear Regulatory Commission
Washington DC 20555

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

Safety/Relief Valve Operability Test Report

- References:
- 1) Letter from T Dente (BWR Owner's Group) to D G Eisenhut (NRC), "Transmittal of Valve Operability Test Report from Generic BWR Safety/Relief Valve (S/RV) Test Program" dated September 25, 1981.
 - 2) Letter from L O Mayer to Director of Nuclear Reactor Regulation, "Information Submitted in Response to TMI Action Plan Items II.B.1, II.D.1, and II.K.3.25" dated July 6, 1981.

In response to NUREG 0737 Item II.D.1, this letter provides the final test results which demonstrate the operational adequacy of the S/RV's for the Monticello Plant. In addition, the adequacy of the S/RV discharge piping and supports has also been demonstrated. These final test results are contained in NEDE-24988-P, "Analysis of Generic BWR Safety/Relief Valve Operability Test Results" which was submitted to the NRC via Reference 1. Northern States Power Company is a participant in the BWR Owners Group generic S/RV operability test program.

The Monticello Plant employs the Target Rock three-stage S/RV. The applicability of the generic test results to this plant's S/RV's has been demonstrated in Reference 2.

A review of the test report shows that the operational adequacy of the S/RV's and the piping and supports for the Monticello Plant has been demonstrated for the conditions defined in Item II.D.1. The submittal of NEDE-24988-P and this letter satisfies the October 1, 1981 and January 1, 1982 submittal requirements of Item II.D.1 and completes Northern States Power Company's efforts on this item.

L O Mayer, PE
Manager of Nuclear Support Services

LOM/TWO/bp

cc: J G Keppler
G Charnoff
NRC Resident Inspector

A046
s
1/0