



U.S. NUCLEAR REGULATORY COMMISSION
STANDARD REVIEW PLAN

**19.1 DETERMINING THE TECHNICAL ADEQUACY OF
 PROBABILISTIC RISK ASSESSMENT RESULTS FOR RISK-INFORMED
 ACTIVITIES LICENSE AMENDMENT REQUESTS AFTER INITIAL FUEL
 LOAD**

REVIEW RESPONSIBILITIES

Primary - Organization responsible for the review of probabilistic risk assessment.

Secondary -- None

I. AREAS OF REVIEW

Introduction

~~While this~~ This Standard Review Plan (SRP) section ~~was primarily developed to address~~ addresses the technical adequacy of a baseline ~~PRA~~ probabilistic risk assessment (PRA) used by a licensee to support license amendments for an operating reactor, ~~it is also applicable to assessing the technical~~ as well as license amendment requests submitted after initial fuel load for new reactors. Technical adequacy, scope, and level of ~~a detail~~ are components of overall PRA quality. Regulatory Guide (RG) 1.174 provides guidance regarding all three attributes of PRA quality. Note that the technical adequacy of the PRA used by an

Revision 3 – May 2012

USNRC STANDARD REVIEW PLAN

This Standard Review Plan (SRP), NUREG-0800, has been prepared to establish criteria that the U.S. Nuclear Regulatory Commission (NRC) staff responsible for the review of applications to construct and operate nuclear power plants intends to use in evaluating whether an applicant/licensee meets the NRC's regulations. The SRP is not a substitute for the NRC's regulations, and compliance with it is not required. However, an applicant is required to identify differences between the design features, analytical techniques, and procedural measures proposed for its facility and the SRP acceptance criteria and evaluate how the proposed alternatives to the SRP acceptance criteria provide an acceptable method of complying with the NRC regulations.

The SRP sections are numbered in accordance with corresponding sections in Regulatory Guide (RG) 1.70, "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants (LWR Edition)." Not all sections of RG 1.70 have a corresponding review plan section. The SRP sections applicable to a combined license application for a new light-water reactor (LWR) are based on RG 1.206, "Combined License Applications for Nuclear Power Plants (LWR Edition)."

These documents are made available to the public as part of the NRC's policy to inform the nuclear industry and the general public of regulatory procedures and policies. Individual sections of NUREG-0800 will be revised periodically, as appropriate, to accommodate comments and to reflect new information and experience. Comments may be submitted electronically by e-mail to NRR_SRP@nrc.gov

Requests for single copies of SRP sections (which may be reproduced) should be made to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Reproduction and Distribution Services Section, or by fax to (301) 415-2289; or by email to DISTRIBUTION@nrc.gov. Electronic copies of this section are available through the NRC's public Web site at <http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr0800/>, or in the NRC's Agencywide Documents Access and Management System (ADAMS) at <http://www.nrc.gov/reading-rm/adams.html>, under Accession # ML112990771.

Formatted: Font: (Default) Arial

Formatted: Centered

Style Definition: Normal: Font: Widow/Orphan control, Adjust space between Latin and Asian text, Adjust space between Asian text and numbers

Style Definition: Level 1: Font: Indent: Left: 0", First line: 0", Adjust space between Latin and Asian text, Adjust space between Asian text and numbers

Formatted: Font: Bold

Formatted: Indent: Left: 0", Hanging: 1"

applicant to support a design certification (DC) or combined license (COL) application. However, it needs to be recognized that in these cases there will be aspects of the plant design or operating features, e.g., emergency operating procedures, site specific external factors, that will not be fully developed. Therefore, the PRA used, and by a licensee to support such applications will of necessity be incomplete. license amendments submitted prior to the initial fuel load is addressed in SRP Section 19.0. In using this SRP section, the reviewer should focus on the determination that determining if the baseline PRA reflects the status of the design and the appropriate operational features appropriate to the application.

~~This SRP section relies on and defines what constitutes a technically acceptable baseline PRA, which is addressed by RG 1.200. RG 1.200 describes the existence of NRC endorsed necessary scope, the technical elements of a PRA, and the technical attributes and characteristics for a full-scope PRA. RG 1.200 allows the use of PRA standards. The following paragraphs describe the historical development and current status of these standards, and their relevance to this SRP section.~~

~~In their March 1999 report, "Nuclear Regulation: Strategy Needed To Regulate Safety Using Information on Risk," GAO/RCED-99-95, the General Accounting Office (GAO) identified a number of issues that it believed required resolution for the NRC to successfully implement a risk informed regulatory approach. Among these, GAO indicated that more was- and peer reviews to demonstrate conformance. As such, RG 1.200 also provides the needed to "develop standards on the scope attributes and detail characteristics of risk assessments needed for utilities to determine that changes to their plants' designs will not negatively affect safety."~~

~~Probabilistic risk assessment (PRA) standards have been developed by the a peer review and endorses both American Society of Mechanical Engineers (ASME) and American Nuclear Society (ANS). On April 5, 2002, ASME issued a standard (ASME RA-S-2002) for a full-power, internal events (excluding fire) Level 1 and a limited Level 2 PRA. Addenda A and B to the Standard were issued in December, 2003 and December, 2005 respectively. In December 2003, ANS issued a standard for external events (ANSI/ANS-58.21-2003). ANS is developing Level 1 and limited Level 2 PRA standards for internal fire, the low power and shutdown modes of operation, and Level 2 and Level 3 PRAs. In parallel, reactor owners' groups developed a PRA peer review program documented in NEI 00-02, "Probabilistic Risk Assessment Peer Review Process Guidance," Revision A3. Over the course of several years, this peer review program was applied at all the U.S. nuclear power plants. For all but one of the plants, the criteria used to assess the technical adequacy of the PRAs had been developed to some extent independently of the development of the ASME PRA standard. Therefore, the results of the standards, as well as industry peer review could not be used directly to assess whether the PRA was in conformance with the ASME PRA standard.~~

~~On August 16, 2002, NEI submitted draft industry guidance for self assessments (Letter A. Pietrangelo to S. Newberry) to address the use of industry peer review results in demonstrating conformance with the ASME PRA standard. This additional guidance contains:~~

- ~~1. Self-assessment guidance document~~
- ~~2. Appendix 1, actions for industry self assessment~~

Revision 2 - June 2007

USNRC STANDARD REVIEW PLAN

This Standard Review Plan, NUREG-0800, has been prepared to establish criteria that the U.S. Nuclear Regulatory Commission staff responsible for the review of applications to construct and operate nuclear power plants intends to use in evaluating whether an applicant/licensee meets the NRC's regulations. The Standard Review Plan is not a substitute for the NRC's regulations, and compliance with it is not required. However, an applicant is required to identify differences between the design features, analytical techniques, and procedural measures proposed for its facility and the SRP acceptance criteria and evaluate how the proposed alternatives to the SRP acceptance criteria provide an acceptable method of complying with the NRC regulations.

The standard review plan sections are numbered in accordance with corresponding sections in Regulatory Guide 1.70, "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants (LWR Edition)." Not all sections of Regulatory Guide 1.70 have a corresponding review plan section. The SRP sections applicable to a combined license application for a new light-water reactor (LWR) are based on Regulatory Guide 1.206, "Combined License Applications for Nuclear Power Plants (LWR Edition)."

These documents are made available to the public as part of the NRC's policy to inform the nuclear industry and the general public of regulatory procedures and policies. Individual sections of NUREG-0800 will be revised periodically, as appropriate, to accommodate comments and to reflect new information and experience. Comments may be submitted electronically by email to NRR_SRP@nrc.gov.

Requests for single copies of SRP sections (which may be reproduced) should be made to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Reproduction and Distribution Services Section, or by fax to (301) 415-2289; or by email to DISTRIBUTION@nrc.gov. Electronic copies of this section are available through the NRC's public Web site at <http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr0800/>, or in the NRC's Agencywide Documents Access and Management System (ADAMS), at <http://www.nrc.gov/reading-rm/adams.html>, under Accession # ML071700657.

3. ~~Appendix 2, industry peer review subtier criteria.~~

~~Concerns regarding PRA quality and the standards development effort were discussed during the March 31, 2000, Commission briefing on the Risk Informed Regulation Implementation Plan. The Commission, in their April 18, 2000, Staff Requirements Memorandum (SRM) on that briefing, indicated that the staff "should provide its recommendations to the Commission for addressing the issue of PRA quality until the ASME and ANS standards have been completed, including the potential role of an industry PRA certification process." In response to the Commission's SRM dated April 18, 2000, the staff issued SECY-00-162, "Addressing PRA Quality in Risk Informed Activities," which described an approach for addressing PRA quality, including identification of the scope and minimal functional attributes necessary to ensure that the PRA information is adequate for its intended application in decision making. The Commission, in their October 27, 2000, SRM, indicated that the "... the timely resolution of PRA quality requirements is necessary to support existing and developing risk informed regulation" In response to that SRM, Regulatory Guide 1.200 was issued for trial use in February 2004. This provided the staff's position on Addendum A of the ASME Standard, and on the NEI peer review process, including the self-assessment guidance. On May 19, 2006, NEI issued a revision to the self-assessment guidance and incorporated it in NEI-00-02, to satisfy the peer review requirement(s) of the ASME PRA Standard (ASME RA-Sa-2003) as endorsed/modified by the NRC and updated by Addendum B of the ASME PRA Standard (ASME RA-Sb-2005). Regulatory Guide 1.200 and this Standard Review Plan (SRP) Section 19.1 have been revised to address Addendum B of the ASME standard and the revised NEI peer review process.~~

~~In developing this SRP section, the staff considered the NRC's guidance on the use of PRA in risk informed regulatory applications, as documented in Regulatory Guide 1.174 and the associated SRP Section 19.2. These documents make it clear that PRA information is one input into making a decision. Specifically, the decision-making process will use the results of the risk analyses in a manner that complements traditional engineering approaches, supports the defense in depth philosophy, and preserves safety margins. Thus, risk analysis will inform, but it will not determine regulatory decisions.~~

Applicability

~~This SRP section is applicable to any licensee **amendment** request submitted for U.S. Nuclear Regulatory Commission (NRC) review and approval for which information from a PRA **plays an effective role in** is used to support the **decision-making process**. ~~It requested action.~~ This SRP section will be used to support application-specific SRP sections that provide guidance for **several** activities, including the following examples:~~

- ~~• **applications to support a design certification or combined operating license (SRP Section 19.0)**~~
 - ~~• **changes**Changes to a plant's licensing basis (SRP Section 19.2)).~~
 - ~~• **changes**Changes to allowed outage times and surveillance test intervals in plant-specific technical specifications (SRP Section 16.1)).~~
 - ~~• **changes**Changes in the scope and frequency of tests on pumps and valves in a licensee's **inservice**in-service test program (SRP Section 3.9.7)).~~

Formatted: Don't keep lines together

Formatted: Bulleted + Level: 1 + Aligned at: 0.25" + Tab after: 0.5" + Indent at: 0.5"

Formatted: Bulleted + Level: 1 + Aligned at: 0.25" + Tab after: 0.5" + Indent at: 0.5"

Formatted: Bulleted + Level: 1 + Aligned at: 0.25" + Tab after: 0.5" + Indent at: 0.5"

- ~~changes~~ Changes in the scope and frequency of inspections in a licensee's ~~inservice~~ in-service inspection program (SRP Section 3.9.8).
- Implementation of National Fire Protection Association (NFPA) 805 in accordance with Title 10 of the *Code of Federal Regulations* (10 CFR), Paragraph 50.48(c) (SRP Section 9.5.1.2).

Formatted: Bulleted + Level: 1 + Aligned at: 0.25" + Tab after: 0.5" + Indent at: 0.5"

The above ~~documents~~ SRP sections address reviewing the application in terms of some or all of the following:

- ~~the structures~~ Structures, systems, and components (SSCs); operator actions; and plant operational characteristics affected by the application.
- ~~the description of the cause~~ Cause-effect relationships between the change and the above SSCs, operator actions, and plant operational characteristics.
- ~~mapping~~ Mapping of the cause-effect relationships onto PRA model elements.
- ~~identification~~ Identification of the PRA results that will be used in the decision making.
- ~~Scope of the scope of risk contributors~~ PRA needed to support the decision.

Formatted: Bulleted + Level: 1 + Aligned at: 0.25" + Tab after: 0.5" + Indent at: 0.5"

Formatted: Bulleted + Level: 1 + Aligned at: 0.25" + Tab after: 0.5" + Indent at: 0.5"

Formatted: Bulleted + Level: 1 + Aligned at: 0.25" + Tab after: 0.5" + Indent at: 0.5"

Formatted: Bulleted + Level: 1 + Aligned at: 0.25" + Tab after: 0.5" + Indent at: 0.5"

Formatted: Bulleted + Level: 1 + Aligned at: 0.25" + Tab after: 0.5" + Indent at: 0.5"

The ~~documents~~ also address issues related to limitations in scope of the PRA.

~~However the PRA results are used, and whatever role they play in the decision making, the PRA analysis must~~ should be of sufficient ~~quality~~ technical adequacy to support ~~that its~~ role in the decision making process. The existing SRP sections ~~only~~ give guidance on assessing the use ~~of the~~ of the PRA results, ~~but do not~~. RG 1.200 and this SRP Section 19.1 give specific guidance on assessing the adequacy of the ~~base PRA~~. ~~Regulatory Guide 1.200 and this SRP section are intended to fill that gap.~~ baseline PRA.

This SRP section ~~provides guidance to the NRC staff on determining the scope of review of the elements of a PRA analysis used to support a specific regulatory application, based on information provided by the licensee on the results of a comparison with an industry PRA standard or the results of a peer review performed in accordance with an industry approved peer review process. This SRP section is intended to~~ may be used in conjunction with an application-specific SRP section such as SRP Section 19.0, Section 19.2, Section 16.1, Section 3.9.7, ~~or~~ Section 3.9.8, ~~or~~ Section 9.5.1.2, which focus on the appropriate use of the PRA results in an integrated decision-making process. This SRP section may also be used to support novel applications in which the licensee is expected to identify how the PRA results are used to provide information to the decision makers.

~~This SRP section does not focus on the decision-making process itself, which is addressed in the application-specific SRP sections.~~

General

This SRP is intended to support the staff in its assessment of the technical adequacy of the PRA model used to generate results to support a risk-informed submittal. As such, it applies to all the parts¹ of a PRA that support the results that inform the regulatory decision being made.

Review Interfaces

Other SRP sections interface with this section as follows:

See described in the applicability section.

~~The specific acceptance criteria and review procedures are contained in the referenced SRP sections.~~

II. ACCEPTANCE CRITERIA

Requirements

Acceptance criteria are based on the Commission's policy statements (Reference 11) and, for reactors licensed under Part 52, on meeting the relevant requirements of the following Commission's regulations:

~~The underlying regulations are.~~ If the applicant shows that its PRA model meets the regulatory positions set forth in RG 1.200, the technical reviewer should be able to conclude that the PRA is technically adequate. If exceptions to RG 1.200 have been identified in the SRP sections which invoke this SRP section and the staff has determined that the exceptions would not affect the risk results sufficiently to affect the regulatory decision, the staff should also be able to conclude that the PRA is technically adequate.

Formatted: Keep with next, Keep lines together

Requirements

The following regulatory requirements pertain to new reactors:

10 CFR 50.71(h)(1) requires that no later than the scheduled date for initial loading of fuel, each holder of a COL shall develop a Level 1 and a Level 2 PRA. The PRA must cover those initiating events and modes for which NRC-endorsed consensus standards on PRA exist 1 year prior to the scheduled date for initial loading of fuel.

10 CFR 50.71(h)(2) requires that each COL holder shall maintain and upgrade the PRA required by 10 CFR 50.71(h)(1). The upgraded PRA must cover initiating events and modes of operation contained in NRC-endorsed consensus standards on PRA in effect 1 year prior to each required upgrade. The PRA must be upgraded every 4 years until the permanent cessation of operations under 10 CFR 52.110(a).

10 CFR 50.71(h)(3) requires that each COL holder shall, no later than the date on which the licensee submits an application for a renewed license, upgrade the PRA required by 10 CFR 50.71(h)(1) to cover all modes and all initiating events.

¹ In this SRP, a part of a PRA can be understood as being equivalent to that piece of the analysis for which an applicable PRA standard (i.e., ASME/ANS RA-Sa-2009) identifies a supporting level requirement.

Formatted: Font: 10 pt

Formatted: Font: 10 pt

SRP Acceptance Criteria

Formatted: Underline

~~Specific SRP acceptance criteria acceptable to meet the relevant requirements of the NRC's regulations identified above are as follows for the review described in this SRP section. The SRP is not a substitute for the NRC's regulations, and compliance with it is not required. However, an applicant is required to identify differences between the design features, analytical techniques, and procedural measures proposed for its facility and the SRP acceptance criteria and evaluate how the proposed alternatives to the SRP acceptance criteria provide acceptable methods of compliance with the NRC regulations.~~

In order for the NRC staff to conclude that a PRA is of sufficient technical adequacy to support an application, the staff needs to be assured that (1) the parts of the PRA needed to support the application have been appropriately identified and (2) those parts ~~have been performed in a manner consistent with current good PRA practice~~ are technically defensible. The former needs to be addressed as part of the assessment of the application. The latter can be met by determining that the necessary parts of the PRA have been performed in accordance with the staff position on consensus PRA standards ~~and~~ industry programs as documented in the appendices to ~~Regulatory Guide~~RG 1.200. Where there are differences in approach to performing a specific part, the staff ~~must~~can determine that the approach used by the applicant is either equivalent to, or better than, that supported by the staff position.

III. REVIEW PROCEDURES

~~The reviewer should select material from the procedures described below, as may be appropriate for a particular case.~~

These review procedures are based on the identified SRP acceptance criteria. For deviations from these acceptance criteria, the staff should review the ~~applicant's~~applicant's evaluation of how the proposed ~~alternatives~~alternative would provide an acceptable method of complying with the relevant NRC requirements ~~identified in Subsection II~~.

~~The objective of this SRP is to provide guidance to the NRC staff on how to determine that the PRA results being used in a decision are supported by the underlying analysis. It must~~should be clear that the elements of the model used to generate those results are of sufficient technical ~~quality~~adequacy and that the assumptions and uncertainties that have the potential to affect the results have been ~~properly~~evaluated ~~as being~~and ~~determined to be~~ appropriate.

III.1 Scope of Review

In order to perform the review for ~~quality~~PRA technical adequacy, the reviewer should first understand the context in which the PRA is being used.

III.1.1 Use of the PRA in the Application

The reviewer should become familiar with the way the PRA is used in the application. This includes ~~understanding~~:

- ~~identification of~~ the SSCs, operator actions, and plant operational characteristics ~~that are~~ affected by or important to the application.

Formatted: Line spacing: single, Tab stops:
Not at 0" + 0.5" + 1" + 1.5" + 2" + 2.5" +
3" + 3.5" + 4" + 4.5" + 5" + 5.5"

- ~~a description of~~ the cause-effect relationships between the change and the above SSCs, operator actions, and plant operational characteristics ~~(when, where applicable, e.g., for licence amendment applications).~~
- the mapping of the cause-effect relationships onto PRA model elements ~~(when, where applicable).~~
- ~~definition of~~ the acceptance criteria or guidelines, including identification of the PRA results that will be used to compare against the acceptance criteria or guidelines and how the comparison is to be made.

Formatted: Font: Bold

III.1.2 Scope of ~~Risk Contributors Addressed in~~ the PRA Model

~~Based on the definition of the application, The reviewer should identify the scope of the PRA (i.e., risk contributors (internal measures, hazard groups, and external initiating events, modes of plant operation) of based on the PRA can be identified application. For example, if the application is designed around using applies the acceptance guidelines of Regulatory Guide RG 1.174, the evaluations of core damage frequency (CDF), the change in CDF (Δ CDF), large early release frequency (LERF), and the change in LERF (Δ LERF) should be performed with a full-scope PRA, including external initiating events and that includes all hazard groups and all modes of operation. However, since most PRAs do not address this full scope,~~

In accordance with the Commission direction on PRA technical adequacy, when the risk associated with a particular hazard group or operating mode is significant to the decision being made, and a staff-endorsed PRA standard exists for that hazard group or operating mode, then the risk should be assessed using a PRA that meets that standard.

For reactors, licensed under 10 CFR 52 the reviewer should become familiar with 10 CFR 50.71(h). As required by 10 CFR 50.71(h)(1), each COL holder shall develop a Level 1 and a Level 2 PRA no later than the scheduled date for initial loading of fuel. The PRA must cover those initiating events and modes for which NRC-endorsed consensus standards on PRA exist 1 year prior to the scheduled date for initial loading of fuel. In addition, 10 CFR 50.71(h)(3) requires that each COL holder shall upgrade the PRA required by 10 CFR 50.71(h)(1) to cover all modes and all initiating events no later than the date on which the licensee submits an application for a renewed license. With respect to this regulation, the reviewer should be aware that an all-mode, all-initiator PRA must be developed by the time a license renewal application is submitted, even if standards for such a PRA do not yet exist. It should be noted that the above regulations may have a significant impact to the decision being made for a risk-informed license amendment request.

Screening and conservative analyses may be used to demonstrate that the risk contributions not addressed by a PRA model are not significant to the decision. This is discussed more fully in NUREG-1855, "Guidance on the Treatment of Uncertainties Associated with PRAs in Risk-Informed Decision Making." Decision makers ~~must make allowances for~~ may address these omissions in other ways. Examples of allowances include the introduction of compensatory measures, and restriction of the implementation of the proposed change to the aspects of the plant covered by the risk model, ~~and use of bounding arguments to cover the risk contributions not addressed by the model.~~ This SRP section does not address this aspect of decision making but ~~is focused~~ focuses on what PRA information should be provided. The ~~reviewer's~~ reviewer's responsibility is to understand the scope of the PRA used in the decision making so that the appropriate appendices to ~~Regulatory Guide~~ RG 1.200 are identified as references for the review.

III.1.3 Parts of the PRA Model Used in Application

To assess the ~~quality~~ technical adequacy of the PRA input for a decision, the licensee ~~identifies~~ should identify which parts of the PRA are used to provide the PRA results ~~called for by the~~ that will be compared to acceptance criteria or guidelines that apply to the application. For example, for license amendments, these parts of the PRA include not only the logic model events onto which the cause-effect relationships are mapped, but also all the events that appear together with those events in the affected accident sequences, and the parts of the analysis

Formatted: Don't keep with next

Formatted: Font: Arial

Formatted: Font: Arial

Formatted: Don't keep lines together

~~required~~needed to evaluate the necessary results. For some applications, this may be a limited set, but for others, (e.g., risk-informing the scope of special treatment requirements,) all parts of the PRA model are relevant. In addition, when the assessed impact of a proposed change, is measured in terms of Δ CDF or Δ LERF, ~~is greater than 1E-06/yr or 1E-07/yr respectively as described in RG 1.174,~~ the total CDF and LERF ~~are required to~~should also be ~~estimated~~considered, broadening the scope of review for technical adequacy.

Formatted: Font: Arial

Formatted: Font: Arial

~~In~~The reviewer, in applying this SRP section, ~~the reviewer need only address~~should become familiar with those parts of the PRA identified as ~~being required to support~~supporting the PRA results ~~used~~.

Formatted: Font: Bold

III.2 Assessment of the PRA

The ~~part~~reviewer should ensure that the parts of the PRA used for the application ~~is assessed to determine whether it is~~are of sufficient technical quality. ~~There are two aspects to assessing the acceptability and adequacy of the.~~ The PRA results. First, the underlying PRA must ~~should~~ be technically sound. This ~~implies~~means that (1) the PRA model, or the parts of the model ~~required~~relied upon to support the application, represent the as-built and as-operated² plant, which in turn ~~implies~~means that the PRA is up-to-date and reflects the current design and operating practices, (2) the PRA logic model ~~has been~~is developed in a manner consistent with ~~current good practice and it correctly reflects the dependencies of systems based on one another acceptable methods and on operator actions data,~~ and (3) the probabilities and frequencies are estimated ~~consistently~~consistent with the definitions of the corresponding events of the logic model.

Formatted: Indent: Left: 0", First line: 0", Line spacing: single, Tab stops: Not at 0" + 0.5" + 1" + 1.5" + 2" + 2.5" + 3" + 3.5" + 4" + 4.5" + 5" + 5.5"

² For new reactors, since plant-specific operational data (i.e., initiating event frequencies, failure rates, etc.) and test and maintenance data may not yet be available in sufficient quantity, the staff should ensure that the impact caused by the use of generic experience or data is insignificant or otherwise acceptable. The staff should assess relevant assumptions and data to ensure that the PRA is statistically and feasibly developed.

~~Second, the~~The engineering analyses, assumptions, and approximations used in developing the PRA model ~~must~~should be appropriate and ~~must~~demonstrate the robustness of the conclusions with respect to the uncertainties in the ~~analysis~~assessment. There are issues for which there is no consensus on analytical models or methods of analysis. Furthermore, PRAs are models, and in that sense the developers of those models rely on certain approximations to make the models manageable and on certain assumptions to address the uncertainties concerning the modeling of certain issues. This is recognized in ~~regulatory guides~~RGs such as ~~Regulatory Guide~~RG 1.174, which ~~give~~gives guidance on how to address the uncertainties by, for instance, performing appropriate sensitivity analyses. This aspect is expected to be addressed in the ~~application-specific regulatory guides~~RGs and associated SRP sections— that are applicable to a particular application.

Formatted: Don't keep with next

III.2.1 Determination ~~That~~that the PRA Model ~~Is~~ Current

When using risk insights based on a PRA model, the PRA model ~~must be up to date and represent the current plant configuration and operating practices.~~The reviewer should confirm that the licensee has a process for updating and maintaining the PRA model that is consistent with the staff position on the process in the ASME PRA standard. ~~—~~should reasonably represent the as-built and as-operated plant. "Reasonableness" is judged relative to the application being considered. For NFPA 805 applications, 10 CFR 50.48(c), which incorporates NFPA 805 by reference, requires that the PRA approach, methods, and data be appropriate for the nature and scope of the change being evaluated, be based on the as-built and as-operated and maintained plant, and reflect the operating experience at the plant. For new reactors, the licensee shall maintain and upgrade the PRA in accordance with the requirements of 10 CFR 50.71(h).

Formatted: Don't keep lines together

The reviewer should confirm that the PRA has been revised to reflect any significant changes in design or operational practices (including operating procedures), and that the data used to estimate the parameters are current. This may be achieved by reviewing the licensee's description of ~~their~~its updating process and ascertaining that the licensee has adequately addressed recent plant modifications and operational changes that could have a significant impact -on the results of the specific application that are not reflected in the current PRA model.

III.2.2 Assessment of the Technical Adequacy of the PRA Required by the Application

The parts of the PRA ~~required~~relied upon by the application ~~are to~~should be assessed for technical adequacy. – The reviewer should determine that the peer review and self-assessment have been performed in conformance with the relevant documents and with the exceptions and clarifications found in the appendices to RG 1.200.

The reviewer should understand that the PRA standard allows each technical requirement provided in the standard to be assessed at various capability categories based on the risk-informed application. As stated in Section 1-1.3.3 of the ASME/ANS PRA Standard (Reference 4):

The intent of the delineation of the Capability Categories within the SRs is generally that the degree of scope and level of detail, the degree of plant-specificity, and the degree of realism increases from Capability Category I to Capability Category III. However, the Capability Categories are not based on the level of conservatism (i.e., tendency to overestimate risk due to simplifications in the PRA) in a particular aspect of the analysis. The level of conservatism may decrease as the Capability Category increases and more detail and more realism are introduced into the analysis. However, this is not true for all requirements and should not be assumed....

When a specific application is undertaken, judgment is needed to determine which Capability Category is needed for each portion of the PRA, and hence which SRs apply to the applications.

For further information, the reviewer is referred to Table 1-1.3-3 of the ASME/ANS PRA Standard.

Implementation of ~~Regulatory Guide~~RG 1.200 should obviate the need for a detailed staff review of the ~~base~~baseline PRA for a risk contributor (e.g., internal events, internal floods, internal fires, external ~~events~~hazards) for which a standard and a corresponding appendix to ~~Regulatory Guide~~RG 1.200 exist. A staff review of those PRAs for the risk contributors significant to the decision and for which no standard has been endorsed in ~~Regulatory Guide~~RG 1.200 will be necessary to the extent needed to support the decision. However, even for the risk contributors addressed by standards, the staff may, under certain circumstances, decide to perform an audit to verify the technical adequacy of the PRA. An audit may be initiated for a number of reasons, some of which are identified below:

- Lack of evidence that the self-assessment actions³ that are most relevant to the application have been adequately performed.

³³ Self assessment actions are relevant for current operating reactor applications when the original or current peer review was performed using criteria (e.g., peer reviews using early Boiling Water Reactor Owners Group (BWROG) guidance and peer reviews using the NEI 00-02 subtier criteria-) that are different from the provisions of ASME/ANS RA-Sa-2009 as endorsed by RG 1.200.

Formatted: Indent: Left: 0", First line: 0", Line spacing: single, Tab stops: Not at 0" + 0.5" + 1" + 1.5" + 2" + 2.5" + 3" + 3.5" + 4" + 4.5" + 5" + 5.5"

Formatted: Level 1, Outline numbered + Level: 1 + Numbering Style: Bullet + Aligned at: 0.25" + Tab after: 0.5" + Indent at: 0.5"

Formatted: Font: 10 pt

Formatted: Font: 10 pt

Formatted: Font: 10 pt

- Concerns about ~~the resolution of peer review findings associated with the PRA technical requirements that~~ **are most relevant apply** to the application.
- Contributors (e.g., accident sequences, cutsets, operator actions), **etc.**) to the results that differ from those seen at other, similar plants, and for which no plant-specific design features can be identified that would explain the differences.
- Results that seem to be counterintuitive, e.g., a decrease in CDF when equipment is taken out of service.
- Estimates of CDF or LERF that differ significantly from those in prior submittals from the same licensee, without a sufficient explanation.

Formatted: Level 1, Outline numbered + Level: 1 + Numbering Style: Bullet + Aligned at: 0.25" + Tab after: 0.5" + Indent at: 0.5"

Formatted: List Paragraph, Line spacing: single, Tab stops: Not at 0" + 0.5" + 1" + 1.5" + 2" + 2.5" + 3" + 3.5" + 4" + 4.5" + 5" + 5.5"

Formatted: Level 1, Outline numbered + Level: 1 + Numbering Style: Bullet + Aligned at: 0.25" + Tab after: 0.5" + Indent at: 0.5"

Formatted: Level 1, Outline numbered + Level: 1 + Numbering Style: Bullet + Aligned at: 0.25" + Tab after: 0.5" + Indent at: 0.5"

Formatted: Outline numbered + Level: 1 + Numbering Style: Bullet + Aligned at: 0.25" + Tab after: 0.5" + Indent at: 0.5"

It is expected that a licensee using a PRA standard or standards, ~~and/or~~ the industry peer-review process has taken account of the exceptions and clarifications found in the appendices of **Regulatory Guide RG 1.200** and has documented the **comparison assessment of these matters** with the relevant documents as endorsed.

Formatted: List Paragraph

The **capability category** needed for each PRA supporting requirement of the applicable PRA standard technical element is dependent on the application. In general, the staff anticipates that current good practice, i.e., **Capability Category II** of the ASME/ANS Standard, is the level of detail that is adequate for the majority of applications. However, for some applications, **Capability Category I** may be sufficient for some PRA supporting requirements, whereas for other applications it may be necessary to achieve **Capability Category III** for specific PRA supporting requirements.

The reviewer should ~~determine that the peer review and self-assessment have been performed in conformance with the relevant documents with the exceptions and clarifications found in the Appendices to Regulatory Guide 1.200.~~

The reviewer ~~is to~~ focus on the elements that have deviations from, or **have** discrepancies with, the PRA technical requirements of the endorsed documents. The reviewer ~~may make a judgment should ensure~~ that the deviation or discrepancy ~~leads to an~~ acceptable **equivalent** as compared to the ~~requirements of the~~ endorsed documents. ~~Alternatively, the~~ The reviewer ~~may should~~ also determine that the ~~issue has~~ **issues have** been addressed adequately ~~if~~ when the licensee ~~has given~~ **provides** reasons as to why the discrepancies are not important, or ~~provided a demonstration demonstrated~~ that the discrepancy has no significant impact on the results used in the decision.

Formatted: Font: Arial

Formatted: Line spacing: single, Don't adjust space between Latin and Asian text, Don't adjust space between Asian text and numbers, Tab stops: Not at 0" + 0.5" + 1" + 1.5" + 2" + 2.5" + 3" + 3.5" + 4" + 4.5" + 5" + 5.5"

III.2.3 Assessment of Engineering Analyses, Assumptions, and Approximations

Since the standards and industry PRA programs are not (or are not expected to be) prescriptive, there is some freedom on how to model certain issues in the PRA, ~~so that~~. **In dealing with this model uncertainty**, different analysts may make different assumptions regarding these issues, yet the issues still meet the ~~requirements of the~~ PRA standard or have been accepted by the peer review. The choice of a specific assumption or a particular approximation may, however, influence the results of the PRA. The ~~NRC staff needs to be confident~~ **should ensure** that the conclusions drawn from the PRA are not invalidated by the use of specific assumptions. This is addressed primarily in the application-specific assessment through the use of sensitivity analyses. ~~However, the~~ **The** staff should review the ~~licensee's~~ **licensee's** basis for those

Formatted: Font: Arial

assumptions and their justification, taking into account the peer reviewers' assessment. The staff should determine ~~that whether~~ the assumptions have been characterized appropriately ~~so that, and whether~~ there is sufficient information to conclude that the sensitivity studies performed to test the robustness of the conclusions are reasonable with respect to what is seen in current PRA practice. ~~The staff's~~ focus should be on assessing the licensee's approach to the identification of the key assumptions, which are those made in response to key sources of uncertainty ~~(see Regulatory Guide 1.200, Footnote 7 and Table A-1)~~; and on assessing the appropriateness of the key assumptions.⁴

Formatted: Font: Arial

Formatted: Indent: Left: 0", First line: 0", Line spacing: single, Tab stops: Not at 0" + 0.5" + 1" + 1.5" + 2" + 2.5" + 3" + 3.5" + 4" + 4.5" + 5" + 5.5"

IV. EVALUATION FINDINGS

~~If~~ acceptable, the reviewer should provide documentation to conclude that the elements of the PRA ~~required~~ relied upon to produce the results have been performed in such a way that the PRA results are fully supportable.

IV.1 Assessment of PRA ~~Against Current Good PRA Practice~~ against the Endorsed Standards

The PRA elements are assessed to determine ~~that whether~~ they have been performed in a technically correct manner that conforms ~~with current good~~ to the NRC endorsed PRA ~~practices~~ standards. This can be determined by an assessment ~~that of whether~~ the PRA elements are performed ~~consistently~~ consistent with the standard ~~or~~ and peer review process as endorsed in the appendices to ~~Regulatory Guide~~ RG 1.200, or ~~that, where, if~~ a discrepancy exists, ~~whether~~ the approach used is equivalent to, or ~~is superior to~~ better than that referenced in the standard or peer review process document. Alternatively, the reviewer may rely on a demonstration that the impact on the results used in the application is not significant.

Formatted: Font: Arial

⁴ In the ASME/ANS PRA Standard (Reference 4) a source of model uncertainty is labeled "key" when it could impact the PRA results that are being used in a decision, and consequently, may influence the decision being made.

IV.2 Key Assumptions and ~~Approximations Assessed~~Key Sources of Uncertainty

The reviewer should ~~benot~~ approve this portion of the analysis in the application unless the reviewer is satisfied that the key assumptions and ~~approximations made to address the key~~ sources of uncertainty identified as having the potential to significantly impact the particular PRA results have been characterized in an acceptable manner given the current state of knowledge, and that the characterization has taken into account the results of the peer review.

- Formatted: Font: Arial
- Formatted: Font: Arial
- Formatted: Font: Arial
- Formatted: Font: Arial

V. IMPLEMENTATION

This SRP is intended to be used in conjunction with, and in support of, an application-specific SRP such as SRP Section 19.0, Section 19.2, Section 16.1, Section ~~3.9.5.1.2~~, Section 3.9.7, Section 3.9.8, or Section ~~3.9.85.1.2~~.

VI. REFERENCES

1. ~~4.~~ 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities."
2. ~~2.~~ 10 CFR Part 52, "Early Site Permits; Standard Design Certifications; and Combined Licenses for Nuclear Power Plants."
3. ~~American Nuclear Society. "External Events PRA Methodology." ANS/ANS 58-21 2003. ANS: La Grange Park, IL. December 2003.~~
3. ~~4.~~ American Society of Mechanical Engineers. ~~"/American Nuclear Society. "Standard for Probabilistic Risk Assessment for Nuclear Power Plant Applications."~~ Revision 1, ASME RA-S-2002. ASME/ANS RA-S-2008. ASME: New York, NY. ANS: La Grange Park, IL. April ~~5, 2002~~2008.
5. American Society of Mechanical Engineers. ~~"Standard for Probabilistic Risk Assessment for Nuclear Power Plant Applications." ASME RA-Sa-2003 (Addendum A to RA-S-2002). ASME: New York, NY. December 5, 2003.~~
4. ~~6.~~ /American Nuclear Society of Mechanical Engineers. ~~"Standard for Level 1/Large Early Release Frequency Probabilistic Risk Assessment for Nuclear Power Plant Applications."~~ Addendum A to ASME ~~RA-Sb-2005 (addendum B to/ANS RA-S-2002). ASME: New York, NY. December 30, 2005.~~2008.
7. ASME/ANS RA-Sa-2009, ASME: New York, NY. ANS: La Grange Park, IL. February 2009.
5. Nuclear Energy Institute. ~~"Probabilistic Risk Assessment (PRA) Peer Review Process Guidance." NEI 00-02."~~ Revision A3, NEI 00-02. NEI: Washington, DC. March 20, 2000.
8. ~~Piترangelo, A. (NEI) Director of Risk and Performance Based Regulation Nuclear Generation, to S. Newberry (NRC) Director of Energy Institute. "Process for Performing Follow-On PRA Peer Reviews Using the Division of Risk Analysis and Applications. Letter dated August 16, 2002.~~

- Formatted: List Paragraph, Indent: Hanging: 0.5", Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5"
- Formatted: List Paragraph, Indent: Hanging: 0.5", Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5"
- Formatted: Indent: Left: 0", Hanging: 0.5"
- Formatted: List Paragraph, Indent: Hanging: 0.5", Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5"
- Formatted: French (France)
- Formatted: French (France)
- Formatted: Indent: Left: 0", Hanging: 0.5"
- Formatted: List Paragraph, Indent: Hanging: 0.5", Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5"
- Formatted: Indent: Left: 0", Hanging: 0.5"

- 9. ~~Pietrangelo, A. (NEI) Senior Director, Risk Regulation, to Mary Drouin (NRC). Letter dated May 19, 2006.~~
- 6. ~~40. Regulatory Guide 1.70, ASME PRA Standard." Revision 3. "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants (LWR Edition)." 2, NEI 05-04. NEI: Washington, DC. November 1978 2008.~~
- 7. ~~41. Nuclear Energy Institute. "Fire Probabilistic Risk Assessment (FPRA) Peer Review Process Guidelines," Draft Version H, Revision 0, NEI 07-12. NEI: Washington, DC. November 2008.~~
- 8. ~~U.S. Nuclear Regulatory Guide 1.174, Revision 1, "Commission. "An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis." Revision 1, Regulatory Guide 1.174. NRC: Washington, DC. July 2002.~~
- 9. ~~42. U.S. Nuclear Regulatory Guide 1.200 For Trial Use, "Commission. "An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-informed Activities." February 2004." Revision 2, Regulatory Guide 1.200. NRC: Washington, DC. March 2009.~~
- 13. ~~Regulatory Guide 1.200, "An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-informed Activities." Revision 1. January 2007.~~
- 10. ~~44. Regulatory Guide 1.206, "U.S. Nuclear Regulatory Commission. "Combined License Applications for Nuclear Power Plants (LWR Edition)." June." Regulatory Guide 1.206. NRC: Washington, DC. June 2007.~~
- 15. ~~U.S. General Accounting Office. "Nuclear Regulation: Strategy Needed To Regulate Safety Using Information on Risk." GAO/RCED-99-95. GAO: Washington, DC. March 19, 1999.~~
- 11. ~~46. U.S. Nuclear Regulatory Commission. ~~SECY-00-0162.~~ "Addressing PRA Quality in Risk-Informed Activities." SECY-00-0162. NRC: Washington, DC. July- 28, 2000.~~
- 12. ~~47. U.S. Nuclear Regulatory Commission. "Regulatory Guide 1.200 Implementation." Regulatory Issue Summary 2007-06. NRC: Washington, DC. March 22, 2007.~~
- 13. ~~U.S. Nuclear Regulatory Commission. "Guidance on the Treatment of Uncertainties Associated with PRAs in Risk-Informed Decision Making." NUREG-1855. NRC: Washington, DC. March, 2009.~~
- 14. ~~Vietti-Cook, A. (NRC) to W.D. Travers (NRC). Staff Requirements Memorandum. "Staff Requirements - Briefing on Risk-Informed Regulation Implementation Plan (SECY-00-0062), March 31, 2000." NRC: Washington, DC. April- 18, 2000.~~

Formatted: List Paragraph, Indent: Hanging: 0.5", Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5"

Formatted: Indent: Left: 0", Hanging: 0.5"

Formatted: List Paragraph, Indent: Hanging: 0.5", Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5"

Formatted: Indent: Left: 0", Hanging: 0.5"

Formatted: List Paragraph, Indent: Hanging: 0.5", Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5"

Formatted: Indent: Left: 0", Hanging: 0.5"

Formatted: List Paragraph, Indent: Hanging: 0.5", Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5"

Formatted: List Paragraph, Indent: Hanging: 0.5", Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5"

Formatted: Indent: Left: 0", Hanging: 0.5"

Formatted: List Paragraph, Indent: Hanging: 0.5", Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5"

Formatted: Indent: Left: 0", Hanging: 0.5"

15. ~~48.~~ Vietti-Cook, A. (NRC) to W.D. Travers (NRC). *Staff Requirements Memorandum*. "Staff Requirements - Addressing PRA Quality In Risk-Informed Activities." NRC: Washington, DC. October 27, 2000.

Formatted: List Paragraph, Indent: Hanging: 0.5", Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5"

Formatted: Indent: Left: 0", Hanging: 0.5"

16. Vietti-Cook, A. (NRC) to W.D. Travers (NRC). *Staff Requirements Memorandum*. "Staff Requirements - COMNJD-03-0002 - Stabilizing the PRA Quality Expectations and Requirements." NRC: Washington, DC. December 18, 2003.

PAPERWORK REDUCTION ACT STATEMENT

The information collections contained in the Standard Review Plan are covered by the requirements of 10 CFR Part 50 and 10 CFR Part 52, and were approved by the Office of Management and Budget, approval number 3150-0011 and 3150-0151.

Formatted: Font: Arial, 9 pt

Formatted: Centered, Tab stops: Not at 3.5" + 4" + 4.5" + 5" + 5.5"



Formatted: Font: Arial, 9 pt

Formatted: Tab stops: Not at 3.5" + 4" + 4.5" + 5" + 5.5"

Formatted: Border: Bottom: (Single solid line, Auto, 1.5 pt Line width)

PUBLIC PROTECTION NOTIFICATION

The NRC may not conduct or sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid OMB control number.



SRP Section 19.1

“Determining the technical adequacy of probabilistic risk assessment for risk-informed license amendment requests after initial fuel load”

Description of Changes

This SRP section affirms the technical accuracy and adequacy of the guidance previously provided in Revision 42, dated ~~September 2006~~ June 2007 of this SRP. See ADAMS ~~accession number ML062540220~~ Accession No. ML07170057.

~~In addition, this SRP section was administratively updated in accordance with NRR Office Instruction, LIC-200, Revision 1, “Standard Review Plan (SRP) Process.” The revision also adds standard paragraphs to extend application of the updated SRP section to prospective submittals by applicants pursuant to 10 CFR Part 52.~~

The technical changes ~~are~~ incorporated in Revision 23, dated ~~Month, 2007~~XXXX 2012:

~~Review Responsibilities – Reflects changes in review branches resulting from reorganization and branch consolidation. Changes is reflected throughout the SRP.~~

The title of this section is modified from the earlier Revision 2 as shown above.

I. AREAS OF REVIEW

- 1. Updated the introduction to indicate that SRP 19.1 applies to PRAs that support design certifications and combined operating licenses, in addition to PRAs used to support license amendment requests.
- ~~2. Revised references to SRP Chapter 19.0 to SRP Section 19.2 to reflect change in SRP numbering.~~
- ~~3. Updated text to indicate that SRP 19.1 relies on the existence of NRC endorsed PRA standards.~~
- ~~4. UpdatedDeleted the development history of the ASME and ANS standardsStandards.~~
- 52. Updated text to include regulatory requirements in 10 CFR 50.71(h)(1), (h)(2), and (h)(3).
- 3. Updated text to indicate the development and issuance of ~~Regulatory Guide~~Revision 2 to RG 1.200.
- 64. Updated text to indicate the ~~revision~~issuance of RIS 2007-06.
- 5. Updated text to indicate the issuance of NEI-00-02 to incorporate self assessment guidance 07-12.
- ~~7-6. Added the Applicability subheading~~transition to NFPA 805 to applicability.
- ~~8-7. Added the General subheading and moved the text under former Section I beneath it.~~

Formatted: Font: Bold

Formatted: Tab stops: Not at 3.5" + 4" + 4.5" + 5" + 5.5"

Formatted: Tab stops: 3.25", Centered + Not at 0" + 0.5" + 1" + 1.5" + 2" + 2.5" + 3" + 3.5" + 4" + 4.5" + 5" + 5.5"

Formatted: Font: Arial

Formatted: Font: Arial

Formatted: Indent: Left: 0", Hanging: 0.5"

Formatted: Font: Arial

Formatted: Font: Arial

Formatted: Font: Arial

Formatted: Font: Arial

~~9. Added the Review Interfaces subheading.~~

~~II. ACCEPTANCE CRITERIA~~

~~1. Added the Requirements subheading and standardized SRP footnote to explain changes to text.~~

~~2. Added the SRP Acceptance Criteria subheading and standardized SRP text (as the first paragraph).~~

~~III. REVIEW PROCEDURES~~

~~1. Review Procedures, added first two paragraphs of standardized SRP text.~~

~~2. Added text to indicate when review of the total CDF and LERF is required.~~

~~3. Added guidance to determine when an audit is needed to verify the technical adequacy of the PRA.~~

~~4. Added guidance for reviewers to determine that PRA peer reviews and self-assessments have been performed in conformance with the relevant documents, and have considered the exceptions and clarifications in Regulatory Guide 1.200.~~

~~5. Clarified guidance about the review of key assumptions.~~

~~IV. EVALUATION FINDINGS~~

~~1. Revised the heading of Section IV.2 (changed "significant" to "key").~~

~~V. IMPLEMENTATION~~

~~None~~

VI. REFERENCES

1. Updated references to reflect the issuance of ~~addenda to the combined ASME standard/ANS Standard and Addendum A~~.

2. ~~Added the ANS standard on external events to references NEI 05-04.~~

3. Added ~~letter from NEI dated May 19, 2006 to references NEI 07-12.~~

4. Added ~~Regulatory Guide Revision 2 to RG 1.200 to references.~~

5. ~~Deleted SECY 99-256 from the references.~~

6. ~~Deleted NEI letter dated December 18, 2001 from the references.~~

7. ~~Deleted SRP Chapter 19 from the references.~~

8. ~~Deleted SRP Section 16.1 from the references.~~

Formatted: Bottom: 1.33", Do not suppress endnotes

Formatted: Font: Arial

9. Deleted SRP Section 3.9.7 from the references.

10. Deleted SRP Section 3.9.8 from the references.

Formatted: Indent: Left: 0", First line: 0"

Formatted: Font: Not Bold

Formatted: Indent: Left: 0", Hanging: 0.5"

Formatted: Font: 12 pt

Formatted: Indent: Left: 2.94", Tab stops: 4.5", Left

Formatted: Font: Arial, 10 pt