

DOD-016

DISTRIBUTION:  
Docket File  
NRC PDR  
L PDR

Docket No. 50-263

ORB#2 Rdg  
OELD  
AEOD  
IE  
ACRS-10  
Gray File  
DEisenhut


SNorris  
HNicolaras  
BDudley

MAY 28 1982

Mr. L. O. Mayer, Manager  
Nuclear Support Services  
Northern States Power Company  
414 Nicollet Mall - 8th Floor  
Minneapolis, Minnesota 55401

Dear Mr. Mayer:

Re: Monticello Nuclear Generating Plant



By letters dated January 30, June 25 and November 2, 1981, you provided information related to the Monticello Nuclear Generating Plant electrical distribution system voltages in response to the NRC generic letter of August 8, 1979, "Adequacy of Station Electric Distribution Systems Voltages".

On the basis of our review, (copy enclosed), we have concluded that the Monticello Nuclear Generating Plant design is acceptable with respect to the adequacy of station electric distribution system voltages.

Sincerely,

ORIGINAL SIGNED BY

Domenic B. Vassallo, Chief  
Operating Reactors Branch #2  
Division of Licensing

Enclosure:  
Safety Evaluation

cc w/enclosure:  
See next page

8206220006 820528  
PDR ADOCK 05000263  
PDR

OFFICE	ORB#2:DL	ORB#2:DL	ORB#2:DL	ORB#2:DL	C-ORB#2:DL		
SURNAME	SNorris	HNicolaras	BDudley	VRoonney	DVassallo		
DATE	5/20/82	5/20/82	5/20/82	5/16/82	5/28/82		

Mr. L. O. Mayer  
Northern States Power Company

cc:

Gerald Charnoff, Esquire  
Sahw, Pittman, Potts and  
Trowbridge  
1800 M Street, N. W.  
Washington, D. C. 20036

Mr. Steve Gadler  
2120 Carter Avenue  
St. Paul, Minnesota 55108

Plant Manager  
Monticello Nuclear Generating Plant  
Northern States Power Company  
Monticello, Minnesota 55362

Russell J. Hatling, Chairman  
Minnesota Environmental Control  
Citizens Association (MECCA)  
Energy Task Force  
144 Melbourne Avenue, S. E.  
Minneapolis, Minnesota 55414

Ms. Terry Hoffman  
Executive Director  
Minnesota Pollution Control Agency  
1935 W. County Road B2  
Roseville, Minnesota 55113

The Environmental Conservation Library  
Minneapolis Public Library  
300 Nicollet Mall  
Minneapolis, Minnesota 55401

U. S. Nuclear Regulatory Commission  
Resident Inspectors Office  
Box 1200  
Monticello, Minnesota 55362

James G. Keppler  
Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
CONCERNING

ADEQUACY OF STATION ELECTRIC DISTRIBUTION SYSTEM VOLTAGES

FOR

NORTHERN STATES POWER COMPANY

MONTICELLO NUCLEAR GENERATING PLANT

DOCKET NO. 50-263

Principal Contributor: R. Prevatte

INTRODUCTION

Northern States Power Company (NSP, licensee) was requested by NRC letter dated August 8, 1979 to review the electric power system at Monticello Nuclear Generating Plant. The review was to consist of:

- a) Determining analytically the capacity and capability of the offsite power system and onsite distribution system to start automatically as well as operate all required loads within their required voltage ratings in the event of: 1) an anticipated transient, or 2) an accident (such as a LOCA) without manual shedding of any electric loads.
- b) Determining if there are any events or conditions which could result in the simultaneous or consequential loss of both required circuits from the offsite network to the onsite electric distribution system and thus violating the requirements of General Design Criteria (GDC) 17, "Electric Power Systems" of Appendix A to 10 CFR 50.

The August 8, 1979, letter included staff guidelines for performing the required voltage analysis and the licensee was further required to perform a test to verify the validity of the analytical results. NSP responded by letters dated January 30, June 25, and November 2, 1981.

DISCUSSION

NSP analyzed each offsite power source to the onsite distribution system under maximum and minimum load conditions with the offsite power sources at maximum and minimum voltages. NSP then verified the voltage analysis by taking voltage and load measurements on the grid and that string of Class 1E buses which showed the lowest voltages during the analysis. Additionally, included in the tests were the transient voltage effects created by starting a large non-Class 1E and Class 1E load. NSP compared the experimental to the analytical results and found that the voltages measured approximately 2% higher than the calculated voltages. Therefore, the analysis was confirmed as accurate and conservative.

As a result of the voltage analysis, NSP had to perform the following modifications:

1. The emergency core cooling system loads had to be sequenced on both off-site power source transformers; and

2. The transformer taps on the reserve auxiliary transformer had to be changed from 13.3/4.33 to 14.0/4.33. In a phone conversation on April 20, 1982, the licensee stated that the modifications were completed during the October 1981 maintenance outage and during the April 1981 refueling outage, respectively.

### EVALUATION

Under a technical assistance contract to the NRC, EG&G performed a detailed review and technical evaluation of the submittals. EG&G reported this work in the Technical Evaluation Report (TER), "Adequacy of Station Electric Distribution System Voltages, Monticello Nuclear Generating Plant, Unit 1," dated February, 1982 (copy attached). We have reviewed the report and concur in the conclusions drawn by EG&G that the Monticello offsite power system and the onsite distribution system (as modified) are capable of providing acceptable voltages for worst-case station electric load and grid voltages.

### CONCLUSION

After reviewing the licensee's submittals and completed modifications, we conclude that NSP has reaffirmed compliance with General Design Criterion 17 of Appendix A to 10 CFR Part 50. Therefore, we find the Monticello Nuclear Generating Plant design to be acceptable with respect to the adequacy of station electric distribution system voltages.

Attachment:

EGG-EA-5783, February 1982

Dated: