REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8410300275 DUC.DATE: 84/10/25 NOTARIZED: NO DOCKET # FACIL:50=263 Monticello Nuclear Generating Plant, Northern States 05000263 AUTH.NAME AUTHOR AFFILIATION MUSOLF.D. Northern States Power Co. RECIP.NAME RECIPIENT AFFILIATION Office of Nuclear Reactor Regulation, Director

SUBJECT: Forwards addl info re mods to degraded voltage protection logic & diesel generator start logic.Info intended to suppl 831230 analysis,840727 license amend request & Attachment I of 840925 ltr.

DISTRIBUTION CODE: A015D COPIES RECEIVED:LTR / ENCL / SIZE:______ TITLE: OR Submittal: Onsite Emergency Power System

05000263

NOTES:

01:09/08/70

RECIPIENT RECIPIENT COPIES COPIES LTTR ENCL ID CODE/NAME LTTR ENCL ID CODE/NAME NRR ORB2 BC 01 7 7 INTERNAL: ADM/LFMB 0 NRR/DL/ORAB 12 1 1 1 NRBADST7TCGB 09 1 NRR/DSI/PSB 14 1 1 1 REG 11 04 RGN3 1 1 1 1 RM/DDAMI/MIB 18 1 1 EXTERNAL: ACRS 6 LPDR 03 1 1 16 6 NRC PDR NSIC 05 1 1 02 1 1 NTIS 1 1



Northern States Power Company

Ø

414 Nicollet Mall Minneapolis. Minnesota 55401 Telephone (612) 330-5500



October 25, 2984

Director Office of Nuclear Reactor Regulation U S Nuclear Regulatory Commission Washington, DC 20555

> MONTICELLO NUCLEAR GENERATING PLANT Docket No. 50-263 License No. DPR-22

Additional Information Related to Modifications to Degraded Voltage Protection Locic and Diesel Generator Start Logic

On December 30, 1983 Northern States Power Company submitted a re-analysis of the adequacy of station distribution system voltages. On September 25, 1984 we submitted additional information requested by the NRC Staff related to this analysis and certain modifications we committed to make to the degraded voltage protection logic and the diesel generator start logic. A License Amendment Request imposing a more conservative degraded voltage logic setpoint was submitted on July 27, 1984. The purpose of this letter is to document additional information which was provided by telephone to Mr John Emani of the Power Systems Branch during review of these items earlier this month.

The attached information is intended to supplement our earlier correspondence:

- Page 4 of our December 30, 1983 analysis has been corrected to reflect the comments of Mr Emani with respect to diesel generator operations.
- b. The Tables presented on page 3 of the attachment to our License Amendment dated July 27, 1984 have been corrected. The deviations expressed in these tables are stated in terms of per unit percentage.
- c. Two errors on page 3 of Attachment I of our September 25, 1984 submittal have been corrected.

8410300275 841025 PDR ADOCK 05000263

Director of NRR October 25, 1984 Page 2

> d. Two pages of our July 27, 1984 License Amendment Request will be amended. Table 3.2.6 will be revised to explicitly include an allowable relay setting band. This is done with the other setpoints in the Section 3.2 tables. The table of allowable deviations will be revised to be consistent with these changes and provide more realistic deviations for the loss of voltage relays. The affected pages are attached for preliminary NRC Staff review.

Northern States Power Company

Please contact us if you have any questions related to the attached information.

 $\cdot O$ David Musolf

Manager - Nuclear Support Services

DMM/dab

c: Regional Administrator-III, NRC NRR Project Manager, NRC Resident Inspector, NRC G Charnoff

Attachments

- 4 -

The diesel engine-generator units are a standard design with engine, generator, electrical controls and auxiliaries all mounted on a common base. Output is rated at 2500 kW (3125 KVA @ .8PF), 4160V, three phase, 60 Hz ac. Protective relays are provided to prevent loading the generator until the diesel engine has accelerated to operating speed. Voltage and speed regulators are provided as well as overload alarms. Overloads or ground faults do not cause automatic trip out of the generator circuit breakers. Operators will adjust loads if the overload alarm indicates a need. The diesel generators are rated for 10% overload for 2000 hours or 22% overload for 30 minutes out of each 24 hours. Protective relays initiate tripping of the generator circuit breakers and the engine for differential overcurrent, phase fault or reverse power. An automatic overspeed trip device is the only mechanical device which will trip the diesel engine.

The generators are Y connected with the neutral of each grounded through special transformers with ground current monitors provided. Voltmeters, ammeters, and wattmeters are provided to permit monitoring the loading of each unit. Equipment is provided for manually synchronizing the generators with the incoming a-c power lines for test purposes. Automatic synchronization capability is not provided. Each diesel generator unit is so loaded and of such capacity that, even if only one unit operates, safe shutdown of the reactor is assured, even under design basis accident conditions.

Each diesel generator is designed to start automatically, and within 10 seconds begin to accept sequenced load (see 2.4.4). As shown in this section, pump motors are started at five second intervals. The diesel generator and its control system are designed to maintain output voltage above 70% of rated voltage upon the application of any of these pump motor loads including the running load at the instant of connecting each successive load. Voltage will be restored to within 87% in 1 second and 98% within 1.7 seconds.

The diesel generators are each capable of starting and carrying the largest vital loads required under postulated accident conditions. After the automatic start sequence is complete, the generator may be manually loaded to its rated capacity at the discretion of the operator. Alarms are provided which will annunciate an overloaded condition; however, the generator load will not trip when the generator becomes overloaded. Operator action will correct the overload condition.

Although an automatic start of the diesel generator has been initiated, there may have been no loss of voltage on the essential buses, or an automatic transfer to another source may have been effected, in which case the running generators are held in reserve during the emergency period.

If the essential buses are still de-energized when the diesels have accelerated, automatic relaying will remove unnecessary loads and disconnect the essential buses from the normal auxiliary system. If

> Reanalysis of Adequacy of Station Electric Distribution System Voltages December 30, 1983

TABLE 1

	Comparison	TO HOUGE T	or THICKNE				
	Init	Lial Condit:	ions	Fin	al Condition	ls	
Bus #	Test	Model	% dv	Test	Model	% dv	
115 KV	119.7 KV	119.7 KV	0	119.3 KV	119.3 KV	0	
1 11	4080	4068	0.28	4050	4049	0.02	
1 12	4070	4069	0.02	4040	4049	0.22	
1 13	4200	4230	0.72	4190	4180	0.24	
1 14	4190	4231	0.99	4180	4180	0.0	
1 15	4220	4230	0.24	4210	4179	0.75	
1 16	4220	1 4230	0.24	4210	4180	0.72	
	485	488	0.63	484	482	0.42	
	484	482	0.42	481	477	0.83	
1 102	476	1 471	1.04	470	465	1.04	
1 106	1 484	482	0 42	482	476	1.25	
1 104	1 404	1 466	0 42	463	460	i 0.63	
1 #V10	1 112 5	1 113 5	0.83	111.0	112.0	0.83	
<u> "110</u>	1 116.3		0.00				

Comparison To Model For Initial and Final Conditions

TABLE 2

Comparison To Model For Specific 1E Buses						
Cases Modeled		Bus 15	LC 103	MCC 133A	Y10 Instr.	
	1	Volts	Volts	Volts	AC Volts*	
Initial Conditions	Test	4220	476	468	112.5	
119.7 KV Source	Model	4230	471	466	113.5	
Steady State	% dv	0.24	1.04	0.42	0.83	
#12 Cooling Tower	Test	3898	435.3	428.6	102.7	
Pump-Start	Model	3951	438	432	105	
	% d⊽	1.27	0.56	0.71	1.92	
1 #12 Cooling Tower	Test	4252.5	475.1	467.0	112.1	
Pump Running	Model	4201	468	463	112.7	
	% dv	1.24	1.48	0.83	0.50	
#12 Cooling Tower	Test	4239.4	472.3	↑ 464.1	111.4	
Pump Running.	Model	4189	466	461	112.2	
1 119.3 KV Source	% dv	1.21	1.31	0.65	0.67	
1 #11 Core Spray Pump	Test	4095.0	455.5	1 449.0	107.6	
Start	Model	4092	455	449	109.2	
1	% dv	0.07	0.1	0.0	1.33	
#11 Core Spray Pump	Test	4226.2	470.4	462.9	111.0	
Running	Model	4179	465	460	112.0	
	1 % dv	1.13	1.13	0.60	0.83	

*Instru AC volts are not an output of the model; however they are calculated based on known transformer losses and tap settings.

> Attachment to License Amendment Request dated July 27, 1984

HHH145

settings for the 1AR transformer. Tap "B", 14,000/4,330, is the correct tap position. It was also noted that figures 15, 16 and 17 are incorrect; the wrong tap position is shown on these plots. Corrected plots are provided in attachment 2.

We also changed our assumption on minimum voltage for the LAR transformer. The original minimum voltage was based on a minimum load, minimum source condition. However, since this transformer is normally in standby, it should be maintained in a condition to accept the LOCA load if called upon. Using this assumption, the lower limit on the 345 KV grid changes from 340 KV to 342 KV.

QUESTION

 Provide details of the design changes described in your report for staff review. Also provide a copy of the revised Technical Specifications for staff review.

RESPONSE

The design changes committed to in our re-analysis of the station auxiliary electrical distribution report are described below. Revised Technical Specifications were submitted on July 27, 1984.

I. Instrument Transformer Tap Change:

The instrument transformers identified in Table 5 of the above mentioned report will have the high side tap moved from the 480V to the 456:120 position.

II. Replacement of the Degraded Voltage Relays:

The original ITE-270 undervoltage relays were replaced with the tighter tolerance higher precision ITE-27N undervoltage relay.

III. Degraded Voltage Transfer Scheme:

The degraded voltage transfer scheme was modified to transfer essential safeguard buses No. 15 & No. 16 on a degraded voltage condition to the preferred off-site standby reserve transformer if it has acceptable no load voltage. The absence of acceptable voltage would result in completion of the transfer to the emergency diesel generator. Also, a degraded condition on the preferred off-site standby reserve transformer after transfer to it would result in a degraded voltage transfer to the emergency diesel generators. In addition, this sampling of the no load voltage of the preferred off-site standby reserve transformer has no effect on the existing time sequence for transfer to the emergency diesel generators.

IV. Emergency Diesel Generator Start Logic:

The existing fast start logic of the emergency diesel generators wiFl be modified to reduce the number of initiation signals, see figures 2 & 3. The modified logic will automatically fast start the diesels for only:

0001068

September 25, 1984 Submittal

Та	рŤ	е	3	•	2	•	6	

Instrumentation for Safeguards Bus Degraded Voltage and Loss of Voltage Protection

Fur	nction	Trip Setting	Minimum No. of Operable or Operating Trip Systems (1)	Total No. of Instrument Channels Per Trip System	Minimum No. of Oper- able or Operating Channels Per Trip System (1)	Required Conditions
1.	Degraded Voltage Protection (3)	3915 <u>+</u> 18 volts 9 <u>+</u> 1 sec	l/bus	3	3	A
2.	Loss of Voltage Protection (2)	2625 <u>+</u> 175 volts No intentional dela	2/bus _ ay	2	2	A

NOTE:

1. Upon discovery that minimum requirements for the number of operable or operating trip systems or instrument channels are not satisfied, action shall be initiated to:

a. Satisfy the requirements by placing the appropriate channels or systems in the tripped condition, or

b. Place the plant under the specified required conditions using normal operating procedures.

2. One out of two twice logic.

3. Two out of three logic.

* Required conditions when minimum conditions for operation are not satisfied:

A. Cold shutdown within 24 hours.

	Trip Function	Deviation	
Instrumentation That Initiates Emergency Core Cooling Systems	Low-Low Reactor Water Level	-3 Inches	
Table 3.2.2	Reactor Low Pressure (Pump Start) Permissive	-10 psi	
	lligh Drywell Pressure	+l psi	
	Low Reactor Pressure (Valve Permissive)	-10 psi	
Instrumentation That Initiates	IRM Downscale	-2/125 of Scale	
Rod Block	IRM Upscale	+2/125 of Scale	
Table 3.2.3		-,	
	APRM Downscale	-2/125 of Scale	
	APRM Upscale	See Basis 2.3	
	RBM Downscale	-2/125 of Scale	
· ·	RBM Upscale	Same as APRM Upscale	
	Scram Discharge Volume-High Level	+ 1 gallon	
Instrumentation That Initlates	lligh Reactor Pressure	+ 12 ps1	
Recirculation Pump Trip	Low Reactor Water Level	-3 Inches	
Instrumentation for Safeguards	Degraded Voltage	≥3897 volts (trip)	
Bus Protection		≤3975 volts (reset)	
		\geq 5 sec \leq 10 sec (delay)	
	Loss of Voltage	< 3000 volts >2000 volts	
		:	

A violation of this specification is assumed to occur only when a device is knowingly set outside of the limiting trip settings, or, when a sufficient number of devices have been affected by any means such that the automatic function is incapable of operating within the allowable deviation while in a reactor mode in which the specified function must be operable or when actions specified are not initiated as specified.

Exhibit B License Amendment	71
Request dated July 27, 1984	REV

3.2 BASES