REGULATO INFORMATION DISTRIBUTION YSTEM (RIDS)

er 1	KEAAF		VIUM-LI DIN		TEP (KIDD)
FACIL: 50 AUTH. NA)-263 Montice ME AU). Nor AME RE	110 Nuclear THOR AFFIL thern State CIPIENT AF	r Genera IATION es Power FILIATIC	Co. IN	ED: NO DOCKET # hern States 05000263 Director (post 851125
SUBJECT: Provides addl info re mod of vacuum breakers on Mark I containment,per 860116 request.Chugging source rate used in CDI Rept 84-3 identical to methodology used in evaluation & detailed in response to NRC Question 5.					
DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR \perp ENCL \swarrow SIZE: \checkmark TITLE: OR Submittal: General Distribution					
NOTES:					. 8in.
	RECIPIENT ID CODE/NA BWR ADTS BWR EB BWR FOB BWR FOB BWR PSB			RECIPIENT ID CODE/NAME BWR PD1 PD 01 BWR EICSB AULUCK,R BWR RSB	1993 - Sec Se
	ADM/LFMB NRR/DHET/TSC REG FILE	1 B 1 04 1	ф 1 1	ELD/HDS1 NRR/ORAS RGN3	1 1 1
	24X LPDR NSIC	1 03 1 05 1		EG&G BRUSKE,S NRC PDR 02	

NRR BUR ADTS add: NRR DSRO PIR NRR Long. W NRR/TAMB

• • • • • •

Sand Still and and a sugar state of the second state of the s

Ø

28 ENCL

5.44

ž





Northern States Power Company

414 Nicollet Mall Minneapolis, Minnesota 55401 Telephone (612) 330-5500

February 28, 1986

Director Office of Nuclear Reactor Regulation US Nuclear Regulatory Commission Washington, DC 20555

> MONTICELLO NUCLEAR GENERATING PLANT DOCKET NO. 50-263 LICENSE NO. DPR-22

Additional Information Related to the Modification of Vacuum Breakers on Mark I Containment

The purpose of this letter is to respond to a request for additional information contained in a letter dated January 16, 1986 from Mr John A Zwolinski, Director, BWR Project Directorate #1, Division of BWR Licensing, USNRC.

The following information is provided as requested:

1. Is the chugging source rate used in the Monticello evaluation the same as the one developed in CDI Report #84-3? If not the same, provide the chugging source rate with the supporting justification.

Response

Yes. The methodology followed in CDI Report No. 84-3 is identical to the methodology used in the Monticello evaluation (Reference 1) and detailed in response to question 5 from the NRC (Reference 2).

2. Did the Monticello calculation apply the 1.07 load factor to account for the uncertainty in calculating the underpressure (Section IV of the staff's generic evaluation)?

Response

A load factor used to assure conservative prediction of the underpressure and detailed in response to question 2 from the NRC (Reference 2), was applied to the Monticello evaluation (Reference 1). The load factor used in the plant unique evaluation was 1.06 and yields a conservative prediction of the underpressure.

8603100101 860228 PDR ADOCK 05000263 P PDR

Holl Add: NRR BWR ADTS NRR DSRO DIR NRR Long. W NRR Long. W NRR ITAMA

Director of NRR February 28, 1986 Page 2

3. Have the Monticello calculations used the drywell model which results in the most conservative prediction (Section V of the generic evaluation)?

Response

Yes. Drywell modeling was examined in response to question 6 from the NRC (reference 2). For the Monticello evaluation (Reference 1), the capacitance model results in a more conservative forcing function, and was therefore used.

References:

1. "Mark I Wetwell to Drywell Differential Pressure Load and Vacuum Breaker Response for the Monticello Nuclear Generating Plant," Revision 0, Continuum Dynamics, Inc., Technical Note No. 84-21, January, 1985.

2. "Response to NRC Request for Additional Information on Mark I Containment Program Wetwell to Drywell Vacuum Breaker Load Methodology," Revision 0, Continuum Dynamics, Inc., Technical Note No. 84-11, October, 1984.

Please contact us if you have any questions related to the information we have provided.

Dign

David Musolf Manager Nuclear Support Services

c: NRR Project Manager, NRC Resident Inspector, NRC Regional Administrator, Region III, NRC G Charnoff