

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: B6052B0190 DDC. DATE: 86/05/21 NOTARIZED: NO DOCKET #
 FACIL: 50-263 Monticello Nuclear Generating Plant, Northern States 05000263
 AUTH. NAME AUTHOR AFFILIATION
 MUSOLF, D. Northern States Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Office of Nuclear Reactor Regulation, Director (post 851125)

SUBJECT: Provides addl commitment in Generic Ltr 83-28 re post-trip review requirements. Scram followup repts will be retained for life of plant, instead of 6 yrs.

DISTRIBUTION CODE: A055D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: OR/Licensing Submittal: Salem ATWS Events QL-83-28

NOTES:

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
	BWR ADTS	1	1	BWR EB	1	1
	BWR EICSB	2	2	BWR FOB	1	1
	BWR PDI PD 01	3	3	AULUCK, R	1	1
	BWR PSB	1	1	BWR RSB	1	1
INTERNAL:	ADM/LFMB	1	1	ELD/HDS1	1	1
	IE/DI	1	1	IE/DGAVT	1	1
	NRR BWR ADTS	1	1	NRR LASHER, D	1	1
	NRR PWR-A ADTS	1	1	NRR PWR-B ADTS	1	1
	NRR/DSRB/RSIB	1	1	NRR/TAMB	1	1
	<u>REG FILE</u> 04	1	1	RGN3	1	1
EXTERNAL:	24X	1	1	LPDR 03	1	1
	NRC PDR 02	1	1	NSIC 05	1	1



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401
Telephone (612) 330-5500

May 21, 1986

Director
Office of Nuclear Reactor Regulation
US Nuclear Regulatory Commission
Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT
DOCKET NO. 50-263 LICENSE NO. DPR-22

Additional Information Related to
Generic Letter 83-28, Item 1.2

The purpose of this letter is to provide an additional commitment to satisfy NRC requirements related to post-trip review requirements contained in Generic Letter 83-28.

Existing plant procedures require that scram followup reports be stored for a minimum of six years. The NRC Staff has recommended that these records be retained for the life of the plant. We will revise existing Administrative Control Directives to require that scram followup reports be retained for the live of the plant.

Please contact us if you have any questions related to our resolution of this matter.

David Musolf
Manager Nuclear Support Services

c: NRR Project Manager, NRC
Resident Inspector, NRC
Regional Administrator, Region III, NRC
G Charnoff

8605280190 860521
PDR ADOCK 05000263
P PDR

A055
40