

NRC FORM 699 (9-2003)		U.S. NUCLEAR REGULATORY COMMISSION		DATE
CONVERSATION RECORD				10/25/2011
				TIME
				1:00pm
NAME OF PERSON(S) CONTACTED OR IN CONTACT WITH YOU		TELEPHONE NO.		TYPE OF CONVERSATION <input type="checkbox"/> VISIT <input type="checkbox"/> CONFERENCE <input checked="" type="checkbox"/> TELEPHONE <input checked="" type="checkbox"/> INCOMING <input type="checkbox"/> OUTGOING
Tom Szymanski		804-273-3065		
ORGANIZATION Virginia Electric and Power Company				
SUBJECT				
Clarification on the submitted ANSYS files to support the thermal analysis relating to the exemption request at the Surry and North Anna Power Station ISFSIs (Docket Nos. 72-55, 72 -56)				
<p>████████████████████</p> <p>Virginia Electric and Power Company (Dominion): Tom Szymanski, Brian Wakeman Transnuclear, Inc. (TN): Ken Boone, Kamran Tavassoli, Venata Venigalla Nuclear Regulatory Commission (NRC): Jennie Rankin, Joe Borowsky</p> <p>The NRC staff is currently reviewing the exemption requests concerning NUHOMS HD-Dry Shielded Canisters being loaded to the incorrect heat load limits at the Surry and North Anna Power Station ISFSIs. The NRC staff has issued a request for supplemental information and Dominion, with the assistance of TN, has provided the ANSYS files used in the thermal analysis of the exemption request.</p> <p>The NRC staff requested this telephone conference to clarify the contents of the provided ANSYS files. Upon initial review of the ANSYS files, the NRC staff could not locate the input files to verify the boundary conditions. TN provided details on where the decay heat inputs were located in the submittal and explanation on how the ambient temperature input was derived. The NRC staff understood TN's response and no additional information was needed at this time.</p>				
<p>████████████████████</p>				
ACTION REQUIRED				
NAME OF PERSON DOCUMENTING CONVERSATION		SIGNATURE		DATE
Jennie Rankin		<i>Jennie Rankin</i>		10/25/11
ACTION TAKEN				
TITLE OF PERSON TAKING ACTION		SIGNATURE OF PERSON TAKING ACTION		DATE