

444 South 16th Street Mall
Omaha, NE 68102-2247

October 26, 2011
LIC-11-0107

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555-0001


- References:
1. Docket No. 50-285
 2. Letter from OPPD (T. C. Matthews) to NRC (Document Control Desk), "Closure of NRC TAC Issues for Fort Calhoun Station Unit No. 1," dated October 6, 2010 (LIC-10-0081)

SUBJECT: Closure of NRC TAC Issues for Fort Calhoun Station, Unit No. 1

The Omaha Public Power District (OPPD) has completed the necessary actions associated with the open TAC issues listed in the Attachment. Subject to agreement by the NRC/NRR Project Manager, these issues are ready to close. The attached list of TAC issues are subsequent to those of the previous TAC Closure letter (Reference 2).

No commitments to the NRC are made in this letter. If you have any questions or require additional information, please contact Mr. Bill Hansher at (402) 533-6894.

Sincerely,


S. E. Baughn
Manager-Nuclear Licensing

SEB/mle

Attachment

- c: E. E. Collins, Jr., NRC Regional Administrator, Region IV
L. E. Wilkins, NRC Project Manager
J. C. Kirkland, NRC Senior Resident Inspector

**Table of Implemented TAC Issues
 Fort Calhoun Station**

Amendment No.	Description	TAC No.	FCS Implementation Date
N/A	<p>OPPD requested relief from certain requirements of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code (Code), Section XI, because ASME Code depth sizing was impractical. Therefore, OPPD proposed an alternative to the depth sizing error requirements in ASME Code Case N-695, "Qualification Requirements for Dissimilar Metal Piping Welds," for the fourth 10-year inservice inspection (ISI) interval for Fort Calhoun Station (FCS) Unit No. 1. The fourth 10-year ISI interval began on October 3, 2003, and ends on September 25, 2013.</p>	ME2512	October 18, 2010
N/A	<p>Omaha Public Power District (OPPD) requested an extension of the deadline from March 31, 2010, until October 5, 2011, for the implementation of three specified requirements in 10 CFR Part 73 (New Security Rule).</p>	ME3027	<p>October 5, 2011 for two of the three requirements for which an extension was originally sought.</p> <p>A separate exemption (i.e., to November 5, 2013) was approved for the third requirement (TAC No. ME7065).</p>

**Table of Implemented TAC Issues
 Fort Calhoun Station**

Amendment No.	Description	TAC No.	FCS Implementation Date
N/A	Generic Letter (GL) 2008-01, "Managing Gas Accumulation in Emergency Core Cooling, Decay Heat Removal, and Containment Spray Systems," requested addressees to submit information to demonstrate that the subject systems are in compliance with the current licensing and design bases and applicable regulatory requirements, and that suitable design, operational, and testing control measures are in place for maintaining this compliance.	MD7829	May 23, 2011
N/A	OPPD requested NRC approval of an alternative to the visual examination requirements of American Society of Mechanical Engineers (ASME) Code, Section XI, Code Case N-722, "Additional Examinations for PWR Pressure Retaining Welds in Class 1 Components Fabricated With Alloy 600/82/182 Materials, Section XI, Division 1."	ME4541	July 8, 2011
266	The amendment approved the cyber security plan and associated implementation schedule, and revised Paragraph 3.C of Renewed Facility Operating License No. DPR-40 to provide a license condition to require OPPD to fully implement and maintain in effect all provisions of the NRC-approved Cyber Security Plan. The proposed change was consistent with Nuclear Energy Institute (NEI) 08-09, Revision 6, "Cyber Security Plan for Nuclear Power Reactors."	ME4380	August 25, 2011