



Entergy Operations, Inc.
P. O. Box 756
Port Gibson, MS 39150

Mike Perito
Vice President, Operations
Grand Gulf Nuclear Station
Tel. (601) 437-6409

GNRO-2011/00093

October 28, 2011

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

SUBJECT: License Renewal Application
Grand Gulf Nuclear Station, Unit 1
Docket No. 50-416
License No. NPF-29

Dear Sir or Madam:

Pursuant to 10 CFR 51 and 10 CFR 54, Entergy Operations, Inc. (EOI) hereby applies for renewal of the operating license for the Grand Gulf Nuclear Station (GGNS) to extend the license for an additional 20 years beyond the current expiration date. With renewal, the GGNS operating license would be extended from midnight on November 1, 2024 to midnight on November 1, 2044.

The enclosed License Renewal Application and related Appendices contain the information required by 10 CFR 54 for the contents of an application.

As required by 10 CFR 54.21(b), current licensing basis changes which have a material effect on the content of this application, including the Final Safety Analysis Report (FSAR) Supplement (Appendix A), will be identified at least annually while the application is under NRC review and at least three months prior to the scheduled completion of the NRC review.

This application is submitted in accordance with 10 CFR 2 Subpart A, 10 CFR 50.4, and 10 CFR 50.30. EOI hereby submits the original of the application pursuant to 10 CFR 50.4(b), 10 CFR 51.55(a), and 10 CFR 54.17(a).


Commitments contained in this application are summarized in the attachment.

A035
NRC

If you have any questions or require additional information, please contact Christina L. Perino at 601-437-6299.

I declare under penalty of perjury that the foregoing is true and correct. Executed on the 28th day of October, 2011.

Sincerely,



Jeremy Browning GMPD/GGAS Acting VP for Mike Perito
MP/JAS

Attachment:

1. List of Regulatory Commitments

Enclosure:

1. License Renewal Application
2. Appendix A Updated Final Safety Analysis Report Supplement
3. Appendix B Aging Management Programs and Activities
4. Appendix C Response to BWRVIP Applicant Action Items
5. Appendix D Technical Specifications Changes
6. Appendix E Environmental Report
7. CD of LRA Suitable for ADAMS

cc: (see next page)

cc: with Attachment and Enclosures

Mr. John P. Boska, Project Manager
Plant Licensing Branch I-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Mail Stop O-8-C2
Washington, DC 20555

cc: without Attachment and Enclosures

Mr. Elmo E. Collins, Jr.
Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
612 East Lamar Blvd., Suite 400
Arlington, TX 76011-4125

U. S. Nuclear Regulatory Commission
ATTN: Mr. A. Wang, NRR/DORL
Mail Stop OWFN/8 G14
11555 Rockville Pike
Rockville, MD 20852-2378

U. S. Nuclear Regulatory Commission
ATTN: Mr. Nathaniel Ferrer NRR/DLR
Mail Stop OWFN/ 11 F1
11555 Rockville Pike
Rockville, MD 20852-2378

NRC Senior Resident Inspector
Grand Gulf Nuclear Station
Port Gibson, MS 39150

State Health Officer
Mississippi Department of Health
P. O. Box 1700
Jackson, MS 39215-1700

**Attachment 1 to
GNRO-2011/00093
List of Regulatory Commitments**

List of Regulatory Commitments

The following table identifies those actions committed to by Entergy in this document. Any other statements in this submittal are provided for information purposes and are not considered to be regulatory commitments.

#	COMMITMENT	IMPLEMENTATION SCHEDULE	SOURCE	RELATED LRA SECTION / AUDIT ITEM
1	Implement the 115 kilovolt (KV) Inaccessible Transmission Cable Program for Grand Gulf Nuclear Station (GGNS) as described in License Renewal Application (LRA) Section B.1.1	Prior to November 1, 2024	GNRO-2011/00093	B.1.1
2	Implement the Aboveground Metallic Tanks Program for GGNS as described in LRA Section B.1.2	Prior to November 1, 2024	GNRO-2011/00093	B.1.2
3	<p>Enhance the Bolting Integrity Program for GGNS to clarify the prohibition on use of lubricants containing MoS₂ for bolting, and to specify that proper gasket compression will be visually verified following assembly.</p> <p>Enhance the Bolting Integrity Program to include consideration of the guidance applicable for pressure boundary bolting in Regulatory Guide (NUREG) 1339, Electric Power Research Institute (EPRI) NP-5769, and EPRI TR-104213.</p> <p>Enhance the Bolting Integrity Program to include volumetric examination per American Society of Mechanical Engineers (ASME) Code Section IX, Table IWB-2500-1, Examination Category B-G-1, for high-strength closure bolting regardless of code classification.</p>	Prior to November 1, 2024	GNRO-2011/00093	B.1.3

#	COMMITMENT	IMPLEMENTATION SCHEDULE	SOURCE	RELATED LRA SECTION / AUDIT ITEM
4	<p>Enhance the Boraflex Monitoring Program for GGNS to perform periodic surveillances of the boraflex neutron absorbing material on at least a five year frequency using Boron-10 Areal Density Gage for Evaluating Racks (BADGER) testing.</p> <p>RACKLIFE analysis will continue to be performed each cycle. This analysis will include a comparison of the RACKLIFE predicted silica to the plant measured silica. This comparison will determine if adjustments to the RACKLIFE loss coefficient are merited. The analysis will include projections to the next planned RACKLIFE analysis date to ensure current Region I storage locations will not need to be reclassified as Region II storage locations in the analysis interval.</p>	Prior to November 1, 2024	GNRO-2011/00093	B.1.4
5	Implement the Buried Piping and Tanks Inspection Program for GGNS as described in LRA Section B.1.5.	Prior to November 1, 2024	GNRO-2011/00093	B.1.5

#	COMMITMENT	IMPLEMENTATION SCHEDULE	SOURCE	RELATED LRA SECTION / AUDIT ITEM
6	<p>Enhance the Boiling Water Reactor (BWR) Vessel Internals Program for GGNS as follows.</p> <p>(a) Evaluate the susceptibility to neutron or thermal embrittlement for reactor vessel internal components composed of CASS, X-750 alloy, precipitation-hardened (PH) martensitic stainless steel(e.g., 15-5 and 17-4 PH steel), and martensitic stainless steel (e.g., 403, 410 and 431 steel).</p> <p>(b) Inspect portions of the susceptible components determined to be limiting from the standpoint of thermal aging susceptibility, neutron fluence, and cracking susceptibility (i.e., applied stress, operating temperature, and environmental conditions). The inspections will use an inspection technique capable of detecting the critical flaw size with adequate margin. The critical flaw size will be determined based on the service loading condition and service-degraded material properties. The initial inspection will be performed either prior to or within 5 years after entering the period of extended operation. If cracking is detected after the initial inspection, the frequency of re-inspection will be justified based on fracture toughness properties appropriate for the condition of the component. The sample size will be 100% of the accessible component population, excluding components that may be in compression during normal operations.</p>	Prior to November 1, 2024	GNRO-2011/00093	B.1.11

#	COMMITMENT	IMPLEMENTATION SCHEDULE	SOURCE	RELATED LRA SECTION / AUDIT ITEM
7	<p>Enhance the Compressed Air Monitoring Program for GGNS to apply a consideration of the guidance of ASME OM-S/G-1998, Part 17; ANSI/ISA-S7.0.01-1996; EPRI NP-7079; and EPRI TR-108147.</p> <p>Enhance the Compressed Air Monitoring Program to include periodic and opportunistic inspections of accessible internal surfaces of the following compressed air systems.</p> <ul style="list-style-type: none"> • Automatic Depressurization System (ADS) air • Division 1 Diesel Generator Starting Air (D1DGSA) • Division 2 Diesel Generator Starting Air (D2DGSA) • Division 3 Diesel Generator Starting Air (D3DGSA), also known as the HPCS Diesel Generator • Instrument Air (IA) 	Prior to November 1, 2024	GNRO-2011/00093	B.1.12

#	COMMITMENT	IMPLEMENTATION SCHEDULE	SOURCE	RELATED LRA SECTION / AUDIT ITEM
8	<p>Enhance the Diesel Fuel Monitoring Program to include a ten-year periodic cleaning and internal inspection of the fire water pump diesel fuel oil tanks, the diesel fuel oil day tanks for Divisions I, II, III, and the diesel fuel oil drip tanks for Divisions I, II. These cleanings and internal inspections will be performed at least once during the 10-year period prior to the period of extended operation and at succeeding 10-year intervals. If visual inspection is not possible, a volumetric inspection will be performed.</p> <p>Enhance the Diesel Fuel Monitoring Program to include a volumetric examination of affected areas of the diesel fuel tanks if evidence of degradation is observed during visual inspection. The scope of this enhancement includes the diesel fuel oil day tanks (Divisions I, II, III), the diesel fuel oil storage tanks (Divisions I, II, III), the diesel fuel oil drip tanks (Divisions I, II), and the diesel fire pump fuel oil storage tanks, and is applicable to the inspections performed during the 10-year period prior to the period of extended operation and at succeeding 10-year intervals.</p>	Prior to November 1, 2024	GNRO-2011/00093	B.1.16
9	<p>Enhance the External Surfaces Monitoring Program to include instructions for monitoring of the aging effects for flexible polymeric components through manual or physical manipulation of the material, including a sample size for manipulation of at least 10 percent of available surface area.</p> <p>Enhance the External Surfaces Monitoring Program as follows.</p> <ol style="list-style-type: none"> 1. Underground components within the scope of this program will be clearly identified in program documents. 2. Instructions will be provided for inspecting all underground components within the scope of this program during each 10-year period, beginning 10 years prior to entering the period of extended operation. 	Prior to November 1, 2024	GNRO-2011/00093	B.1.18

#	COMMITMENT	IMPLEMENTATION SCHEDULE	SOURCE	RELATED LRA SECTION / AUDIT ITEM
10	<p>Enhance the Fatigue Monitoring Program to monitor and track all critical thermal and pressure transients for all components that have been identified to have a fatigue Time-Limited Aging Analyses (TLAA).</p> <p>Enhance the Fatigue Monitoring Program to perform a review of the GGNS high energy line break analyses and the corresponding tracking of associated cumulative usage factors to ensure the GGNS program adequately manages fatigue usage for these locations.</p> <p>Fatigue usage calculations that consider the effects of the reactor water environment will be developed for a set of sample reactor coolant system components. This sample set will include the locations identified in NUREG/CR-6260 and additional plant-specific component locations in the reactor coolant pressure boundary if they are found to be more limiting than those considered in NUREG/CR-6260.</p> <p>Enhance the Fatigue Monitoring Program to provide updates of the fatigue usage calculations on an as-needed basis if an allowable cycle limit is approached, or in a case where a transient definition has been changed, unanticipated new thermal events are discovered, or the geometry of components have been modified.</p>	Two years prior to November 1, 2024	GNRO-2011/00093	B.1.19
11	<p>Enhance the Fire Protection Program to require visual inspections of the Halon/CO2 fire suppression system at least once every fuel cycle to examine for signs of corrosion.</p> <p>Enhance the Fire Protection Program to require visual inspections of fire damper framing at least once every fuel cycle to check for signs of degradation.</p> <p>Enhance the Fire Protection Program to require visual inspection of concrete curbs, manways, hatches, manhole covers, hatch covers, and roof slabs at least once every fuel cycle to confirm that aging effects are not occurring.</p>	Prior to November 1, 2024	GNRO-2011/00093	B.1.20

#	COMMITMENT	IMPLEMENTATION SCHEDULE	SOURCE	RELATED LRA SECTION / AUDIT ITEM
12	<p>Enhance the Fire Water Program to include inspection of hose reels for degradation. Acceptance criteria will be enhanced to verify no unacceptable degradation.</p> <p>Enhance the Fire Water Program to include one of the following options.</p> <p>(1) Wall thickness evaluations of fire protection piping using non-intrusive techniques (e.g., volumetric testing) to identify evidence of loss of material will be performed prior to the period of extended operation and at periodic intervals thereafter. Results of the initial evaluations will be used to determine the appropriate inspection interval to ensure aging effects are identified prior to loss of intended function.</p> <p><u>OR</u></p> <p>(2) A visual inspection of the internal surface of fire protection piping will be performed upon each entry to the system for routine or corrective maintenance. These inspections will be capable of evaluating (a) wall thickness to ensure against catastrophic failure and (b) the inner diameter of the piping as it applies to the design flow of the fire protection system. Maintenance history shall be used to demonstrate that such inspections have been performed on a representative number of locations prior to the period of extended operation. A representative number is 20% of the population (defined as locations having the same material, environment, and aging effect combination) with a maximum of 25 locations. Additional inspections will be performed as needed to obtain this representative sample prior to the period of extended operation.</p>	Prior to November 1, 2024	GNRO-2011/00093	B.1.21

#	COMMITMENT	IMPLEMENTATION SCHEDULE	SOURCE	RELATED LRA SECTION / AUDIT ITEM
12 (cont.)	<p>Enhance the Fire Water Program to include a visual inspection of a representative number of locations on the interior surface of below grade fire protection piping in at least one location at a frequency of at least once every 10 years during the period of extended operation. A representative number is 20% of the population (defined as locations having the same material, environment, and aging effect combination) with a maximum of 25 locations. Acceptance criteria will be revised to verify no unacceptable degradation.</p> <p>Enhance the Fire Water Program to test or replace a representative sample of sprinkler heads before the end of the 50-year sprinkler head service life and at 10-year intervals thereafter during the period of extended operation. Acceptance criteria will be no unacceptable degradation. NFPA-25 defines a representative sample of sprinklers to consist of a minimum of not less than 4 sprinklers or 1 percent of the number of sprinklers per individual sprinkler sample, whichever is greater.</p> <p>Enhance the Fire Water Program to include visual inspection of spray and sprinkler system internals for evidence of degradation. Acceptance criteria will be enhanced to verify no unacceptable degradation.</p>		GNRO-2011/00093	
13	Enhance the Flow-Accelerated Corrosion Program to revise program documentation to specify that downstream components are monitored closely to mitigate any increased wear when susceptible upstream components are replaced with resistant materials, such as high Cr material.	Prior to November 1, 2024	GNRO-2011/00093	B.1.22
14	Enhance the Inservice Inspection - IWF Program to address inspections of accessible sliding surfaces.	Prior to November 1, 2024	GNRO-2011/00093	B.1.24

#	COMMITMENT	IMPLEMENTATION SCHEDULE	SOURCE	RELATED LRA SECTION / AUDIT ITEM
14 (cont.)	<p>Enhance the Inservice Inspection - IWF Program to; clarify that parameters monitored or inspected will include corrosion; deformation; misalignment of supports; missing, detached, or loosened support items; improper clearances of guides and stops; and improper hot or cold settings of spring supports and constant load supports. Accessible areas of sliding surfaces will be monitored for debris, dirt, or indications of excessive loss of material due to wear that could prevent or restrict sliding as intended in the design basis of the support. Elastomeric vibration isolation elements will be monitored for cracking, loss of material, and hardening. Structural bolts will be monitored for corrosion and loss of integrity of bolted connections due to self-loosening and material conditions that can affect structural integrity. High-strength structural bolting (actual measured yield strength greater than or equal to 150 ksi or 1,034 MPa in sizes greater than 1 inch nominal diameter) susceptible to stress corrosion cracking (SCC) will be monitored for SCC.</p> <p>Enhance the Inservice Inspection - IWF Program to clarify that detection of aging will include:</p> <ul style="list-style-type: none"> a) Monitoring structural bolting (American Society for Testing and Materials (ASTM) A-325, ASTM F1852, and ASTM A490 bolts) and anchor bolts will be monitored for loss of material, loose or missing nuts, loss of pre-load and cracking of concrete around the anchor bolts. b) Volumetric examination comparable to that of ASME Code Section XI, Table IWB-2500-1, Examination Category B-G-1 should be performed for high strength structural bolting to detect cracking in addition to the VT-3 examination. This volumetric examination may be waived with adequate plant-specific justification. 		GNRO-2011/00093	

#	COMMITMENT	IMPLEMENTATION SCHEDULE	SOURCE	RELATED LRA SECTION / AUDIT ITEM
14 (cont.)	<p>Enhance the Inservice Inspection - IWF Program acceptance criteria to include the following as unacceptable conditions.</p> <ul style="list-style-type: none"> a) Loss of material due to corrosion or wear, which reduces the load bearing capacity of the component support; b) Debris, dirt, or excessive wear that could prevent or restrict sliding of the sliding surfaces as intended in the design basis of the support; and c) Cracked or sheared bolts, including high strength bolts, and anchors. 			
15	<p>Enhance the Inspection of Overhead Heavy Load and Light Load Handling Systems Program to include monitoring of rails in the rail system for the aging effect "wear", and structural connections/bolting for loose or missing bolts, nuts, pins or rivets. Additionally, the program will be clarified to include visual inspection of structural components and structural bolts for loss of material due to various mechanisms and structural bolting for loss of preload due to self-loosening.</p> <p>Enhance the Inspection of Overhead Heavy Load and Light Load Handling Systems Program acceptance criteria to state that any significant loss of material for structural components and structural bolts, and significant wear of rails in the rail system, is evaluated according to ASME B30.2 or other applicable industry standard in the ASME B30 series.</p>	Prior to November 1, 2024	GNRO-2011/00093	B.1.25
16	Implement the Internal Surfaces in Miscellaneous Piping and Ducting Components Program as described in LRA Section B.1.26.	Prior to November 1, 2024	GNRO-2011/00093	B.1.26

#	COMMITMENT	IMPLEMENTATION SCHEDULE	SOURCE	RELATED LRA SECTION / AUDIT ITEM
17	<p>Enhance the Masonry Wall Program to clarify that parameters monitored or inspected will include monitoring gaps between the supports and masonry walls that could potentially affect wall qualification.</p> <p>Enhance the Masonry Wall Program to clarify that detection of aging effects require masonry walls to be inspected every 5 years unless technical justification is provided to extend the inspection to a period not to exceed 10 years.</p>	Prior to November 1, 2024	GNRO-2011/00093	B.1.27
18	Implement the Non-EQ Cable Connections Program as described in LRA Section B.1.28	Prior to November 1, 2024	GNRO-2011/00093	B.1.28
19	<p>Enhance the Non environmentally Qualified (Non-EQ) Inaccessible Power Cables (400V to 35kV) Program to include low-voltage (400V to 2kV) power cables.</p> <p>Enhance the Non-EQ Inaccessible Power Cables (400V to 35kV) Program to include condition-based inspections of manholes not automatically dewatered by a sump pump being performed following periods of heavy rain or potentially high water table conditions, as indicated by river level.</p> <p>Enhance the Non-EQ Inaccessible Power Cables (400V to 35kV) Program to clarify that the inspections will include direct observation that cables are not wetted or submerged, that cables/splices and cable support structures are intact, and that dewatering/drainage systems (i.e., sump pumps) and associated alarms if applicable operate properly.</p>	Prior to November 1, 2024	GNRO-2011/00093	B.1.29
20	Implement the Non-EQ Instrumentation Circuits Test Review Program as described in LRA Section B.1.30.	Prior to November 1, 2024	GNRO-2011/00093	B.1.30
21	Implement the Non-EQ Insulated Cables and Connections Program as described in LRA Section B.1.31.	Prior to November 1, 2024	GNRO-2011/00093	B.1.31

#	COMMITMENT	IMPLEMENTATION SCHEDULE	SOURCE	RELATED LRA SECTION / AUDIT ITEM
22	<p>Enhance the Oil Analysis Program to provide a formalized analysis technique for particulate counting.</p> <p>Enhance the Oil Analysis Program to include piping and components within the main generator system (N41) with an internal environment of lube oil.</p>	Prior to November 1, 2024	GNRO-2011/00093	B.1.32
23	Implement the One-Time Inspection Program as described in LRA Section B.1.33.	Within the 10 years prior to November 1, 2024	GNRO-2011/00093	B.1.33
24	Implement the One-Time Inspection – Small Bore Piping Program as described in LRA Section B.1.34.	Within the 6 years prior to November 1, 2024	GNRO-2011/00093	B.1.34
25	Enhance the Periodic Surveillance and Preventive Maintenance Program to include all activities described in the table provided in LRA Section B.1.35 program description.	Prior to November 1, 2024	GNRO-2011/00093	B.1.35
26	<p>Enhance the Protective Coating Program to include parameters monitored or inspected by the program per the guidance provided in ASTM D5163-08.</p> <p>Enhance the Protective Coating Monitoring and Maintenance Program to provide for inspection of coatings near sumps or screens associated with the Emergency Core Cooling System.</p> <p>Enhance the Protective Coating Program to include acceptance criteria per ASTM D 5163-08.</p>	Prior to November 1, 2024	GNRO-2011/00093	B.1.36
27	Enhance the Reactor Vessel Surveillance Program to ensure that the additional requirements specified in the final NRC safety evaluation for BWRVIP-86 Revision 1 are addressed before the period of extended operation.	Prior to November 1, 2024	GNRO-2011/00093	B.1.38

#	COMMITMENT	IMPLEMENTATION SCHEDULE	SOURCE	RELATED LRA SECTION / AUDIT ITEM
28	<p>Enhance the Regulatory Guide (RG) 1.127, Inspection of Water-Control Structures Associated With Nuclear Power Plant Program to clarify that detection of aging effects will monitor accessible structures on a frequency not to exceed 5 years consistent with the frequency for implementing the requirements of RG 1.127.</p> <p>Enhance the RG 1.127, Inspection of Water-Control Structures Associated With Nuclear Power Plant Program to perform periodic sampling, testing, and analysis of ground water chemistry for pH, chlorides, and sulfates on a frequency of at least every 5 years.</p> <p>Enhance the RG 1.127, Inspection of Water-Control Structures Associated With Nuclear Power Plant Program acceptance criteria to include quantitative acceptance criteria for evaluation and acceptance based on the guidance provided in ACI 349.3R.</p>	Prior to November 1, 2024	GNRO-2011/00093	B.1.39
29	Implement the Selective Leaching Program as described in LRA Section B.1.40.	Prior to November 1, 2024	GNRO-2011/00093	B.1.40
30	<p>Enhance the Structures Monitoring Program to clarify that the scope includes the following:</p> <p>a) In-scope structures and structural components.</p> <ul style="list-style-type: none"> • Containment Building (GGN 2) • Control House – Switchyard • Culvert No. 1 and drainage channel • Manholes and Ductbanks • Radioactive Waste Building Pipe Tunnel <p>b) In-scope structural components</p> <ul style="list-style-type: none"> • Anchor bolts • Anchorage / embedments • Base plates • Basin debris screen and grating • Battery racks • Beams, columns, floor slabs and interior walls • Cable tray and cable tray supports • Component and piping supports • Conduit and conduit supports • Containment sump liner and penetrations • Containment sump structures • Control room ceiling support system 	Prior to November 1, 2024	GNRO-2011/00093	B.1.42

#	COMMITMENT	IMPLEMENTATION SCHEDULE	SOURCE	RELATED LRA SECTION / AUDIT ITEM
30 (cont.)	<ul style="list-style-type: none"> • Cooling tower drift eliminators • Cooling tower fill • CST/RWST retaining basin (wall) • Diesel fuel tank access tunnel slab • Drainage channel • Drywell floor slab (concrete) • Drywell wall (concrete) • Ductbanks • Electrical and instrument panels and enclosures • Equipment pads/foundations • Exterior walls • Fan stack grating • Fire proofing • Flood curbs • Flood retention materials (spare parts) • Flood, pressure and specialty doors • Floor slab • Foundations • HVAC duct supports • Instrument line supports • Instrument racks, frames and tubing trays • Interior walls • Main steam pipe tunnel • Manholes • Manways, hatches, manhole covers, and hatch covers • Metal siding • Missile shields • Monorails • Penetration sealant (flood, radiation) • Penetration sleeves (mechanical/ electrical not penetrating primary containment boundary) • Pipe whip restraints • Pressure relief panels • Reactor pedestal • Reactor shield wall (steel portion) • Roof decking • Roof hatches • Roof membrane • Roof slabs • RPV pedestal sump liner and penetrations • Seals and gaskets (doors, manways and hatches) • Seismic isolation joint • Stairway, handrail, platform, grating, decking, 			

#	COMMITMENT	IMPLEMENTATION SCHEDULE	SOURCE	RELATED LRA SECTION / AUDIT ITEM
30 (cont)	<p>and ladders</p> <ul style="list-style-type: none"> • Structural bolting • Structural steel, beams columns, and plates • Sumps and Sump liners • Support members: welds; bolted connections; support anchorages to building structure • Support pedestals • Transmission towers (see Note 1) • Upper containment pool floor and walls • Vents and louvers <p>Note 1: The inspections of these structures may be performed by the transmission personnel. However, the results of the inspections will be provided to the GGNS Structures Monitoring Program owner for review.</p> <p>c) Clarify the term “significant degradation” to include “that could lead to loss of structural integrity”.</p> <p>d) Include guidance to perform periodic sampling, testing, and analysis of ground water chemistry for pH, chlorides, and sulfates on a frequency of at least every 5 years.</p> <p>Enhance the Structures Monitoring Program to clarify that parameters monitored or inspected include:</p> <p>a) inspection for missing nuts for structural connections.</p> <p>b) monitoring sliding/bearing surfaces such as Lubrite plates for loss of material due to wear or corrosion, debris, or dirt. The program will be enhanced to include monitoring elastomeric vibration isolators and structural sealants for cracking, loss of material, and hardening.</p> <p>Enhance the Structures Monitoring Program to clarify that detection of aging effects will:</p> <p>a) include augmented inspections of vibration isolators by feel or touch to detect hardening if the vibration isolation function is suspect.</p> <p>b) Require inspections every 5 years for structures and structural components within the scope of license renewal unless technical justification is provided to extend the inspection to a period not</p>			

#	COMMITMENT	IMPLEMENTATION SCHEDULE	SOURCE	RELATED LRA SECTION / AUDIT ITEM
30 (cont)	<p>to exceed 10 years.</p> <p>Enhance the Structures Monitoring Program acceptance criteria by prescribing acceptance criteria based on information provided in industry codes, standards, and guidelines including NEI 96-03, ACI 201.1R-92, ANSI/ASCE 11-99 and ACI 349.3R-96. Industry and plant-specific operating experience will also be considered in the development of the acceptance criteria.</p>			
31	<p>Enhance the Water Chemistry Control – Closed Treated Water Program to provide a corrosion inhibitor for the engine jacket water on the engine-driven fire water pump diesel in accordance with industry guidelines and vendor recommendations.</p> <p>Enhance the Water Chemistry Control – Closed Treated Water Program to provide periodic flushing of the engine jacket water and cleaning of heat exchanger tubes for the engine-driven fire water pump diesel in accordance with industry guidelines and vendor recommendations.</p> <p>Enhance the Water Chemistry Control – Closed Treated Water Program to provide testing of the engine jacket water for the engine-driven fire water pump diesels at least once per refueling cycle.</p>	Prior to November 1, 2024	GNRO-2011/00093	B.1.44

#	COMMITMENT	IMPLEMENTATION SCHEDULE	SOURCE	RELATED LRA SECTION / AUDIT ITEM
31 (cont.)	<p>Enhance the Water Chemistry Control – Closed Treated Water Program to conduct inspections whenever a boundary is opened for the following systems.</p> <ul style="list-style-type: none"> • Drywell chilled water (DCW – system P72) • Plant chilled water (PCW – system P71) • Diesel generator cooling water subsystem for Division I and II standby diesel generators • Diesel engine jacket water for engine-driven fire water pump • Diesel generator cooling water subsystem for Division III (HPCS) diesel generator • Turbine building cooling water (TBCW–system P43) • Component cooling water (CCW – system P42) <p>These inspections will be conducted in accordance with applicable ASME Code requirements, industry standards, and other plant-specific inspection and personnel qualification procedures that are capable of detecting corrosion or cracking.</p>			

#	COMMITMENT	IMPLEMENTATION SCHEDULE	SOURCE	RELATED LRA SECTION / AUDIT ITEM
31 (cont.)	<p>Enhance the Water Chemistry Control – Closed Treated Water Program to conduct inspections whenever a boundary is opened for the following systems.</p> <ul style="list-style-type: none"> • Drywell chilled water (DCW – system P72) • Plant chilled water (PCW – system P71) • Diesel generator cooling water subsystem for Division I and II standby diesel generators • Diesel engine jacket water for engine-driven fire water pump • Diesel generator cooling water subsystem for Division III (HPCS) diesel generator • Turbine building cooling water (TBCW– system P43) • Component cooling water (CCW – system P42) <p>These inspections will be conducted in accordance with applicable ASME Code requirements, industry standards, and other plant-specific inspection and personnel qualification procedures that are capable of detecting corrosion or cracking.</p>			

Enclosure 1 to
GNRO-2011/00093
License Renewal Application

Enclosure 2 to

GNRO-2011/00093

Appendix A Updated Final Safety Analysis Report Supplement

Enclosure 3 to

GNRO-2011/00093

Appendix B Aging Management Programs and Activities

Enclosure 4 to

GNRO-2011/00093

Appendix C Response to BWRVIP Applicant Action Items

Enclosure 5 to

GNRO-2011/00093

Appendix D Technical Specifications Changes

Enclosure 6 to
GNRO-2011/00093
Appendix E Environmental Report

Enclosure 7 to
GNRO-2011/00093
CD of LRA Suitable for ADAMS