

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
AP 1000 Subcommittee: Open Session

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Wednesday, October 19, 2011

Work Order No.: NRC-1215

Pages 1-139

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

AP1000 SUBCOMMITTEE

+ + + + +

WEDNESDAY

OCTOBER 19, 2011

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B1, 11545 Rockville Pike, at 8:30 a.m., Harold B.
Ray, Chairman, presiding.

SUBCOMMITTEE MEMBERS:

HAROLD B. RAY, Chairman

DENNIS C. BLEY, Member

CHARLES H. BROWN, JR. Member

JOY REMPE, Member

MICHAEL T. RYAN, Member

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ACRS CONSULTANT:

WILLIAM HINZE

DESIGNATED FEDERAL OFFICIAL:

WEIDONG WANG

1	I-N-D-E-X	3
2	Opening remarks by Chairman Ray	4
3	Open Action Items from Day 1	4
4	Applicant Presentation	
5	Sections 2.0, 2.1 and 2.2	10
6	Staff Presentation Section 2.0, 2.1 and 2.2	14
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		
25		

P-R-O-C-E-E-D-I-N-G-S

8:27 a.m.

CHAIRMAN RAY: The meeting will now come to order. This is the second day of the meeting of the AP1000 Reactor Subcommittee, a standing subcommittee of the Advisory Committee on Reactor Safeguards. I'm Harold Ray, chairman of the subcommittee. ACRS members in attendance are Dennis Bley, Mike Ryan, Joy Rempe and Charles Brown.

ACRS consultant Dr. Bill Hinze is present and Weidong Wong is designated federal official for this meeting. I recited the purpose and scope of our discussion at the beginning of the meeting yesterday, I won't do it again now. We will have a closed portion of the meeting later this morning.

And we're going to begin today with an opportunity, not on the agenda, for the staff to respond to some action items from yesterday. So with that, Brian, go ahead.

MR. ANDERSON: Thank you, Mr. Chairman. Just for the record I'll say again. I'm Brian Anderson, I'm the lead project manager for the Levy County COLA review. With me at the front table are Mark McBride and Michelle Hart. Mark is a member of the NRC's Hydrology Branch. Michelle works in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Siting and Accident Consequences Branch, both in the
2 Office of New Reactors.

3 From yesterday's session the staff
4 actually had three action items. One was related to
5 a topic that's on the agenda for today. The other two
6 items are listed on the screen. We had a follow-up
7 related to chi/Q values and the associated margins to
8 the DCV values.

9 And there was also a bullet on one of the
10 groundwater slides in the staff's presentation, we'd
11 like to clarify that bullet related to radionuclide
12 activity at receptor sites. So with that I'll turn it
13 over to Mark McBride to address the groundwater
14 clarification.

15 MR. MCBRIDE: Thank you. The question
16 came up at the very end of yesterday's session. And
17 normally I would have referred it to our consultants
18 at PNNL but because of telephone difficulties they
19 were not able to respond to us. However, they were
20 online and were able to listen to the entire session.

21 So by the time I called Paul Thorne as a
22 follow-up he was already well on his way toward
23 preparing a response. And the question was that there
24 was a statement that was in my presentation yesterday.
25 The alternate analysis resulted in a dose of 54

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 percent of the 10 CFR Appendix B limit that produces
2 50 millirems per year compared to the FSAR analysis
3 that resulted in 0.7 percent.

4 And the question was was the comparison
5 really made in terms of concentration or in terms of
6 dose? And the answer is that it was made in terms of
7 concentration. You have to keep in mind that the
8 groundwater modeling program that was used to
9 calculate concentrations at the receptor point deals
10 entirely in concentration units.

11 And converting this to a dose would
12 require additional analysis which was not carried out.
13 So that's the basic answer, it's a concentration.

14 MEMBER RYAN: So it's a percent of the
15 allowable concentration?

16 MR. MCBRIDE: Pardon?

17 MEMBER RYAN: It was the percent of
18 allowable concentration?

19 MR. MCBRIDE: That's right.

20 MEMBER RYAN: And what was that citation
21 again?

22 MR. MCBRIDE: 10 CFR 20, Appendix B. It's
23 Table 2 specifically.

24 MEMBER RYAN: Right, that's correct.

25 Thanks.

1 CHAIRMAN RAY: All right. That completes
2 that item then I believe. Unless there's some
3 question.

4 MEMBER RYAN: Yes. No.

5 CHAIRMAN RAY: All right. Michelle.

6 MS. HART: I understood that there were
7 some questions on the chi/Q values yesterday. The
8 first question what is short-term for the purposes of
9 that analysis. And Don had answered that it is two
10 hours, and that is true for the exclusionary boundary
11 dose. However, for the low population zone dose it
12 can go up as long as 30 days. And so that's the
13 answer for that one.

14 MEMBER REMPE: But did he check all of
15 them? The short-term and the long-term? Because
16 that's what the slide had said, that he just checked
17 the short-term ones.

18 MS. HART: For the purposes of Chapter 15,
19 those short-term ones are the only ones that matter.
20 The long-term ones are used for the effluence doses
21 and those are also checked as well.

22 MEMBER REMPE: Okay.

23 MS. HART: And so you'll hear from the
24 meteorologist later today about that.

25 MEMBER REMPE: Okay.

1 MS. HART: The other question was about
2 the margin to the DCD chi/Qs, the site characteristic
3 one's to the site parameter ones. And Don gave you an
4 answer based on the current revision that was in-
5 house, that it was approximately, off-site it was
6 approximately a factor of two.

7 And that is true. There isn't a request
8 for additional information that they responded to
9 which did change those values for the off-site doses,
10 I mean for the off-site chi/Qs. And those will be
11 changing in the next revision so that there is not,
12 basically, any margin for the EAB chi/Q in the next
13 revision. It is less than the DCD value, but it is
14 not much less.

15 MEMBER RYAN: Is it within the uncertainty
16 of the calculation? Or does it overlap the
17 uncertainty of the calculation? I guess if you're
18 waiting for something to come in that's an unfair
19 question at this point. Maybe we can address that
20 when it --

21 MS. HART: Well the RAI response is in and
22 the meteorologist is in the building. I mean he's in
23 the room and I guess there's a presentation later
24 today. But if you have any specific questions about
25 that you can ask it then, or if you would like to hear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it now.

2 MEMBER RYAN: Yes, that's fine. Either
3 way. But, I mean, that's fine.

4 MS. HART: Yes, but they are all less.
5 Even in the RAI response they're all less.

6 MEMBER RYAN: If essentially equal that's
7 fine, but that means one could be higher than the
8 other or not. Could be the other way around. So I'm
9 curious about the uncertainty of the calculated value.

10 MS. HART: Right.

11 MEMBER RYAN: Guessing they overlap.

12 MS. HART: He will be able to answer that
13 question for you.

14 MEMBER RYAN: Okay. Great, thanks.

15 CHAIRMAN RAY: All right. So there's this
16 little piece then that we'll get to later on today.
17 Thank you.

18 MS. HART: Thank you.

19 MEMBER RYAN: Very much.

20 CHAIRMAN RAY: All right. With that,
21 Brian, I think we're ready for the applicant. Looks
22 like it. We don't have to wait long for the
23 meteorology to be subject again. Bob, you can begin.

24 MR. KITCHEN: Good morning.

25 CHAIRMAN RAY: Good morning.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. KITCHEN: We're going to talk about
2 Sections 2.0 through 2.3, which will address site
3 characteristics, demography of nearby facilities and
4 meteorology.

5 So as indicated we'll be talking a bit
6 about this right now. Paul Snead, who we introduced
7 yesterday is the Environmental Services supervisor
8 that's going to present for us. So, Paul.

9 MR. SNEAD: Good morning. Go to the next
10 slide. We can go through some of these briefly. FSAR
11 2.0 Site Characteristics. For this Section of course
12 the DCD was incorporated by reference.

13 Table 2.0-201 compares the site specific
14 characteristics to the AP1000 required site parameters
15 found in DCD Table 2-1. All site specific
16 characteristics are bounded by the AP1000 site
17 parameters for Levy.

18 Next slide. In Section 2.1, Geography and
19 Demography. Again DCD was incorporated by reference.
20 There was a COL information item addressed as noted.
21 The population density in 2000 for 20 miles
22 surrounding the Levy site was 97 people per square
23 mile.

24 The population density projected for 2020,
25 within 20 miles, is 146 people per square mile, which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is well below the Reg Guide 4.7 criteria 500 people
2 per square mile.

3 FSAR 2.2, Nearby Industrial Hazards.
4 Again, DCD was incorporated by reference and ICOL
5 information item was addressed. We evaluated nearby
6 industrial hazards in accordance with the standard
7 review plan. Sources of potential hazards within the
8 five miles were road transportation of explosive
9 material.

10 Failure of a nearby natural gas pipeline
11 and toxic material release from a nearby water
12 treatment plant. No design basis events were
13 identified that required any mitigating actions.

14 And then Section 2.3, Meteorology. The
15 DCD was incorporated by reference and these five
16 information items that you see on the slide were
17 addressed. All of the AP1000 DCD site parameters are
18 met.

19 We thought we would discuss with you three
20 major items of interest, or we thought might be items
21 of interest. One, is a discussion of onsite calm wind
22 observations. Another is the operating basis wind
23 speed site parameter. And a third is the maximum site
24 characteristic temperatures for the Levy site. So
25 we're going to talk about each of these in turn.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The site is located about eight miles
2 inland and there is a diurnal sea breeze wind effect
3 that is consistently observed at the site using onsite
4 meteorological tower, evaluating the two years of data
5 that we collected there. The onsite meteorological
6 tower meets all of the NRC Guidance in Reg Guide 1.23.

7 And there were calm winds that were
8 observed in our data that required further evaluation.
9 Most of the observed calm winds were actually light
10 winds. True calm winds exhibit erratic and meandering
11 wind direction. The observed winds had measurable
12 direction. So our actual observations of true calm
13 winds, that are actually near zero wind speed and
14 variable wind direction, were rare and infrequent.

15 So in terms of resolution of the light
16 wind speeds in our chi/Q modeling analysis the
17 standard PAVAN dispersion modeling approach was not
18 designed for treatment of very light winds. Basically
19 the way PAVAN is modeled, chi/Q is inversely
20 proportional to wind speed such that as wind speeds
21 such that as wind speeds go to zero concentration goes
22 to infinity.

23 So basically Progress Energy performed a
24 detailed sector-by-sector assessment of the data using
25 an analysis that was consistent with NRC Guidance in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Reg Guide 1.145. And the maximum possible sector
2 dependent two-hour chi/Qs were substituted for PAVAN
3 extrapolations in light wind cases. So the conclusion
4 of the light wind discussion was that the projected
5 worst case impacts of routine and accidental releases
6 do not exceed the AP1000 DCD criteria at or beyond the
7 exclusionary boundary. Any questions?

8 CHAIRMAN RAY: All set, thanks.

9 MR. SNEAD: All right. Next we'll talk
10 about the operating basis wind speeds for the site.
11 The DCD operating basis wind speed for the site
12 parameter is 145 miles per hour based on a three-
13 second gust. The DCD procedures were followed to
14 determine the 50 and 100-year recurrent Levy
15 characteristic wind speeds, which includes hurricanes.

16 The 50-year recurrent wind speeds were 120
17 miles per hour. The 100-year recurrent wind speeds
18 were 128 miles per hour. So the conclusion here was
19 that maximum wind speeds at the Levy site region will
20 not exceed the DCD wind speed criteria as defined by
21 the procedure. Any question there?

22 And then with regard to site
23 characteristic temperatures for the Levy site. The
24 maximum safety temperature criteria is 115 degrees dry
25 bulb, 86.1 degrees Fahrenheit coincident wet bulb.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And then the 86.1 degrees Fahrenheit non-coincident
2 wet bulb.

3 Analysis was based on long-term historical
4 records from the region surrounding the Levy site. We
5 used National Weather Service data that had the
6 longest available data to us from Tampa, Jacksonville
7 and Tallahassee. And the statistical regression
8 analysis procedure was used to estimate the 100-year
9 recurrent temperatures for the site based on
10 historical temperature records.

11 MEMBER BROWN: How far back did the
12 historical go?

13 MR. SNEAD: I have that. It's, I believe
14 it was on the order of 50 to 60 years. For all those
15 sites. Next slide. So no projected maximum site
16 temperatures exceeded the criteria, concluding that
17 the maximum ambient temperature at the Levy site
18 region are below the DCD ambient temperature criteria.

19 DR. HINZE: Did you do any comparison with
20 your Crystal River statistics?

21 MR. SNEAD: We did look at Crystal River
22 data, that being a little closer to the coast from a
23 wind speed standpoint. It wasn't really
24 representative temperature wise, it was consistent
25 with the same type of information we were getting from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Tampa and Tallahassee.

2 DR. HINZE: Very good.

3 MEMBER BROWN: How close did you get to
4 the 115?

5 MR. SNEAD: The highest that we saw to the
6 115 was a Tallahassee reading of 105.1 degrees dry
7 bulb. The highest coincident wet bulb temperature was
8 82.3 degrees, coincident wet bulb temperature of 82.3
9 degrees in Jacksonville. For the non-coincident wet
10 bulb temperature we did have a reading in Tampa of
11 85.5 degrees, wet bulb, non-coincident. Any further
12 questions?

13 CHAIRMAN RAY: All right. Thank you, Bob.

14 MR. SNEAD: Thank you.

15 CHAIRMAN RAY: All right. I guess we'll
16 engage in some shuttle back and forth here and hear
17 from the staff on these subjects before moving on.
18 So, Brian, are you ready?

19 MR. ANDERSON: Good morning. This is the
20 NRC's staff's presentation for Sections 2.0, 2.1, 2.2
21 and 2.3 of the Levy County COLA. I'm Brian Anderson,
22 I was the project manager for this portion of the
23 staff safety review. With me at the front table are
24 Rao Tamara and Kevin Quinlan. Rao and Kevin are both
25 members of the Citing and Accident Consequences

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Branch.

2 Kevin performed the meteorology portions
3 of the review. Rao is involved with the demography
4 and nearby facilities portion of this review. I'll
5 start by providing a similar overview to what you just
6 heard from Progress Energy.

7 Section 2.0 of the FSAR is a description
8 of the characteristics of the Levy County proposed
9 site. That provides a table which compares Levy
10 County site parameters to DCD specified parameters.
11 So it's a little bit of nuance in the way that 2.0 is
12 structured.

13 But the staff's review in 2.0 and the
14 conclusion that they make in their safety evaluation
15 is to determine that all of the site characteristics
16 are acceptable and that they are bounded by the
17 parameters of the AP1000 DCD.

18 So similar to what you heard yesterday
19 during the seismic and geology portions of the review,
20 the hydrology portions of the review and what you'll
21 hear from Rou and Kevin, the staff found that all of
22 the site parameters that are discussed in Chapter 2 of
23 the FSAR are acceptable.

24 Those are the acceptable values that we
25 then compare to the AP1000 DCD values. And just to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reiterate Progress Energy's conclusion that all of the
2 values are bounded by the AP1000 DCD. And with that
3 I will turn the presentation over to Rao Tamara.

4 MR. TAMARA: My name is Seshagiri Rao
5 Tamara. I'm a technical reviewer in Siting and
6 Accident Branch in the Office of New Reactors. My
7 branch chief is Robert Schaaf and Levy Safety Manager
8 is Brian Anderson.

9 Section 2.1 of FSAR addresses the
10 geography and demography. Section 2.2 addresses the
11 location and description of nearby facilities and
12 evaluation of potential accidents due to these
13 facilities.

14 In Section 2.1 the applicant addressed the
15 site location, excluding the area boundary and
16 population distribution. This has been individually
17 verified from the publicly available information at
18 the site location by determining the UTM coordinates
19 with the new proposed units from latitude and
20 longitude.

21 The staff reviewed the applicant addressed
22 information pertaining to EAB, ownership of the land,
23 control over the EAB and population distribution. The
24 staff independently verified the published data and
25 projections based on the data from Census Bureau

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 county projections.

2 Also verified the nearest population
3 center, Ocala, which is about 30 miles to the east,
4 northeast of the site. The population density within
5 20 miles from the center of the proposed units in
6 2020, five years after the approval, is independently
7 determined by the staff and found to be comparable to
8 that of the applicant reported value of 146 persons
9 per square mile, which is less than acceptable value
10 of 1,200.

11 Based on this independent review of the
12 data from different available sources and the
13 confirmation of the information the staff considers
14 that the required information is addressed by the
15 applicant in Section 2.1 pertaining to above areas is
16 adequate and acceptable. Next slide please.

17 The applicant identified and provided
18 descriptions of the nearby facilities, transportation
19 routes, military facilities and pipelines within the
20 five miles of the site. The staff independently
21 verified the information from the publicly available
22 data and also from the information obtained from the
23 Levy County Planning Department.

24 And also other sources. And therefore
25 considers the applicant has identified all activities

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that have the potential for hazards on the site and in
2 the site vicinity. The evaluation of these potential
3 accidents from the activities are addressed Section
4 2.2.3. Next slide, please.

5 The applicant addressed the potential
6 accidents from the identified facilities and
7 activities within five miles of the site performing
8 site-specific hazard evaluations for potential
9 explosions, vapor cloud explosions from natural gas
10 release from pipelines. Aircraft crashes and fires.

11 Staff also performed independent analysis
12 and verified that there are no adverse effects due to
13 road transport of chemicals or explosives. Transport
14 of natural gas via pipelines and fires. The aircraft
15 properly determined by the applicant exceeded the
16 acceptance criteria of 10^4 minus 6 per year.

17 However, based on the applicant's
18 application of conditional core damage probability of
19 $5.85 \cdot 10^4$ -8 for the AP1000 design, the core damage
20 frequency, CDF, is determined smaller than the current
21 planned CDF acceptance criteria, 10^4 -8 per year.
22 Therefore, this has also been reviewed by and
23 addressed in the 19.2 PRA specs.

24 Based on the delivery of the applicant's
25 analysis, of course the staff also has performed an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 independent analysis, getting data from FAA for the
2 total flights. And it also meets the acceptance
3 criteria.

4 MEMBER RYAN: I'm just curious, does the
5 FAA database include military flights or is that
6 separate?

7 MR. TAMARA: Yes, what we requested is, it
8 is very difficult to get day-by-day, so we have asked
9 them to give five years of data. All the flights
10 flying within five miles of the site.

11 So they gave every flight, which has a
12 designation of five types of aircrafts. Air carrier,
13 commercial airline, military and so every flight
14 which is going within the ten miles, per day.

15 It has a flight number, origination,
16 destination and what is the type of the flight. Like
17 that they give for five years. So we analyze it for
18 five years and we took the maximum and saw what is
19 the, you know, what would be the probability.

20 And we applied what would be if there is
21 a one percent increase, or whatever it is, what it
22 would be in the future.

23 Just see the projection and see whether
24 that also will apply. So based upon that confirmed
25 analysis, still probably it is acceptable. So that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 what we did. But since the applicant didn't have that
2 kind of data they made a conservative calibration
3 therefore. They addressed it from the consequence
4 point of view.

5 MEMBER RYAN: All right. Thanks very
6 much.

7 MR. TAMARA: Based on the review of the
8 applicant analyses and results and also on the staff's
9 independent confirmatory calculations, the staff
10 concludes that the applicant provided sufficient
11 information and evaluations to meet the requirements
12 of 10 CFR 52 and 10 CFR 100.

13 And it has been demonstrated with a
14 reasonable assurance that the plant is adequately
15 protected and can be operated safely. Any questions?

16 CHAIRMAN RAY: Okay. No questions. Thank
17 you very much.

18 MR. TAMARA: Thank you.

19 MR. QUINLAN: Good morning. My name is
20 Kevin Quinlan and I'm a meteorologist in the Siting
21 and Accident Consequences Branch within the Division
22 of Site and Environmental reviews. I'll be discussing
23 Section 2.3 of the Levy County SER COL for
24 meteorology. My branch chief is Robert Schaaf and the
25 project manager for Chapter 2, the SER, is Brian

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Anderson.

2 Section 2.3 of the Levy FSAR incorporates
3 by reference Section 2.3 of the AP1000 DCD. Please
4 note that Section 2.3 of the AP1000 DCD standard
5 content SER, with open items, was issued with no open
6 items.

7 There are five subsections in SER Section
8 2.3 related to regional climatology, local
9 meteorology, an onsite meteorological measurements
10 program, short-term atmospheric dispersion estimates
11 for accidental releases and long-term atmospheric
12 dispersed estimates for routine releases.

13 LNP supplemental Item 2.0-1 includes Table
14 2.0-201, which is a comparison table of AP1000 DCD
15 site parameters and the LNP site characteristics.
16 Next slide, please.

17 SER Section 2.3.1 describes the review of
18 regional climatological information and addresses one
19 AP1000 COL information items. AP1000 COL information
20 item 2.3-1 states that the applicant should provide
21 site specific information related to regional
22 climatology.

23 This section of the SER addresses the 50
24 and 100 year return period to three second gust wind
25 speeds. The wind speeds were confirmed by the staff

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 through the use of Figure 6-1B of the ASCE 705
2 document. And by examination of the NOAA Coastal
3 Services Center Hurricane Database.

4 The maximum tornado wind speed of 300
5 miles an hour was determined through the use of
6 Regulatory Guide 1.76 Revision 1. Because the
7 applicant identified the most conservative tornado
8 site characteristic by following the NRC guidance and
9 the site characteristic is bounded by the DCD site
10 parameter, the staff found it acceptable.

11 To determine the maximum precipitation
12 winter roof load, the applicant followed the guidance
13 provided in Interim Staff Guidance 7. Interim Staff
14 Guidance on assessment of normal and extreme winter
15 precipitation loads on the roofs of seismic category
16 1 structures.

17 Because the applicant followed the Staff
18 Guidance and the site characteristic is bounded by the
19 DCD site parameter the staff found the analysis to be
20 correct and acceptable.

21 Ambient temperature and humidity site
22 characteristics were confirmed through the use of
23 National Climatic Center data records from the Tampa,
24 Florida and Tallahassee, Florida National Weather
25 Service Reporting stations. The calculation of 100-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 year return period temperatures uses a method endorsed
2 by the ASHRAE Fundamentals Handbook.

3 Because the applicant followed the
4 appropriate NRC guidance, a conservative method and
5 the site characteristics are bounded by the DCD site
6 parameters, the staff found the analysis to be
7 acceptable.

8 The applicant presented all of this
9 information in FSAR Section 2.3.1. The staff found
10 that all LNP site characteristics were bounded by the
11 AP1000 DCD site parameters and are therefore
12 acceptable to the staff.

13 AP1000 COL information Item 2.3-2 states
14 that the applicant should provide site specific
15 information related to local meteorology. This
16 section of the FSAR addresses the potential cooling
17 tower induced affects on ambient temperature, moisture
18 and salt deposition.

19 This section of the FSAR also provided
20 detailed information showing that the LNP
21 meteorological data are representative of the site
22 area. The applicant presented this information in the
23 FSAR Section 2.3.2, and the staff has accepted it as
24 correct and adequate. Next slide please.

25 MEMBER REMPE: Could you go back for a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 second? It has there that the effects of salt
2 deposition on the ambient, or the cooling tower
3 effects on ambient temperature, moisture and salt
4 deposition?

5 MR. QUINLAN: Yes.

6 MEMBER REMPE: What did you do for salt
7 deposition?

8 MR. QUINLAN: We looked at SACTI the
9 program that analyses cooling tower plumes. And our
10 main concern was the effect of corrosion in the switch
11 yard. So the long-term effects of salt building up
12 and the potential effects on the equipment used in the
13 switch yard.

14 And essentially the conclusions were that
15 it would take two months of salt deposition in the
16 switch yard to create any type of, really even to hit
17 the lower limits of the contamination that you'd be
18 concerned of.

19 And in that time you have all kinds of
20 local precipitation, being Florida the constant rain
21 at the site, it would wash away the salt. So it
22 really was of little concern.

23 MEMBER REMPE: Okay. Thanks.

24 MR. QUINLAN: You're welcome.

25 CHAIRMAN RAY: Well, wait a minute. That

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 seems, forgive me for saying so, sir, but glib in the
2 sense that there are dry periods, they may be
3 exceptional but --

4 MR. QUINLAN: Yes.

5 CHAIRMAN RAY: The question is is there
6 some way of assuring that under unusual conditions
7 there wouldn't be a -- I mean the threat in the switch
8 yard is a loss of offsite power. This is a very
9 robust plant design so perhaps we're not too worried
10 about that.

11 But, nevertheless, is there something
12 other than just relying on a rainstorms to remove the
13 salt build-up that you considered? Insulator is
14 typically done on a seaside plant pretty frequently.
15 Is that part of the assessment also?

16 MR. QUINLAN: It was not part of the
17 assessment in Chapter 2 and I wouldn't want to speak
18 as far as inspection procedures or plant procedures,
19 but I would imagine that that would be --

20 CHAIRMAN RAY: Okay. Well I certainly
21 understand that it's not within the scope of Chapter
22 2. I guess I would just say if the judgement was
23 reached that salt deposition, or accumulation,
24 wouldn't be a problem because it rains often it seems
25 like that needs a little more assessment. Brian, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 tell me who can respond to that.

2 I mean you could respond by saying, well
3 there's nothing safety related in the switchyard
4 anyway so we don't care. I don't think you'll say
5 that but that's one answer you could give.

6 MR. ANDERSON: I won't say that now, but
7 I will take this a follow-up and give you an answer
8 sometime today.

9 CHAIRMAN RAY: Yes. Because, like I say,
10 if we're relying on the frequency of rain to keep the
11 switchyard in service, why I think we need to talk
12 about it a little bit more.

13 MR. ANDERSON: Okay.

14 CHAIRMAN RAY: Okay. We'll direct a
15 question to the applicant at some point as well. But
16 go ahead.

17 MR. QUINLAN: SER Section 2.3.3 describes
18 a review of the onsite meteorological measurements
19 program and addresses AP1000 COL Information Item.
20 AP1000 COL Information Item 2.3-3 states that the
21 applicant should describe site specific onsite
22 meteorological measurements program.

23 A new meteorological tower was built for
24 Units 1 and 2 and began recording in February of 2007.
25 The staff has verified the location of the new tower

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is representative of the site area and meets the
2 guidance provided in Regulatory Guide 1.2.3 Revision
3 1.

4 The staff has determined that the
5 applicant has adequately provided all relevant
6 information in FSAR Section 2.3.3. Next slide,
7 please.

8 SER Section 2.3.4 describes a review of
9 the short-term atmospheric dispersion estimates, or
10 chi/Q values, that are used to evaluate design basis
11 accidental releases to the exclusion area boundary,
12 the outer boundary of the low population zone and the
13 control room.

14 AP1000 COL Information Item 2.3-4 states
15 that the applicant should provide site specific short-
16 term atmospheric dispersion estimates. Using NRC
17 approved computer models, the applicant has provided
18 this information and the staff has accepted it as
19 correct and adequate.

20 FSAR Section 2.3.5 describes the review of
21 long-term atmospheric dispersed estimates that are
22 used to evaluate releases of meteorological affluence
23 to the atmosphere during normal plant operation.

24 AP1000 COL Information Item 2.3-5 states
25 that the applicant should provide site specific long-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 term atmospheric disperse estimates. Using NRC
2 approved computer models the applicant has provided
3 this information and staff has accepted it as correct
4 and adequate. Slide please.

5 In conclusion, all LNP site
6 characteristics presented in FSAR Section 2.3 have
7 been found to be acceptable and bounded by the
8 corresponding AP1000 site parameters.

9 Section 2.3 of the LNP, COL, FSAR has been
10 reviewed by the staff and has been found to adhere to
11 all regulatory requirements. SER Section 2.3 has been
12 submitted with no open items, exemptions or
13 departures.

14 There are currently seven confirmatory
15 items that the applicant has committed to through the
16 RAI process. The staff will be looking to ensure that
17 the information presented in the RAI responses are
18 included in the next provision of the FSAR. And once
19 these commitments are confirmed the staff will close
20 the confirmatory items. Thank you.

21 CHAIRMAN RAY: Now, if the RAI answers, I
22 think you had a question about it, didn't you or are
23 you satisfied?

24 MEMBER RYAN: It'll be all right.

25 CHAIRMAN RAY: All right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DR. HINZE: Let me just slip in with a
2 question. How did you show that the meteorological
3 measurements program was located in a representative
4 area? What's representative area?

5 MR. QUINLAN: Well, to make sure that it
6 conformed to Regulatory Guide 1.23 guidance, we
7 actually did a site inspection in 2008. We went out
8 there and surveyed the area to make sure that there
9 were not obstructions. But one of the other
10 comparisons that we did was we looked at the
11 meteorological data from the surrounding National
12 Weather Service stations, be it Tampa, Tallahassee,
13 Orlando.

14 And then we compared wind directions, wind
15 speeds to make sure that they are close. We also
16 looked at temperature and humidity data to make sure
17 that they were reasonably close to each other too. So
18 we really compared it against the whole region to make
19 sure that the site was representative.

20 DR. HINZE: Crystal River as well?

21 MR. QUINLAN: We did not use Crystal River
22 data, no.

23 DR. HINZE: Thank you.

24 CHAIRMAN RAY: All right. Nothing else,
25 we'll -- Thank you very much.

1 MR. QUINLAN: Thank you.

2 CHAIRMAN RAY: Okay. Now, we're doing
3 well, which I'm interested in maintaining that
4 performance. So we will move on without taking a
5 break at this time and take up Chapter 8 and 9 on the
6 part of the applicant's. And since this does involve
7 Chapter 8 and offsite power why don't you talk to us
8 about the switchyard and salt buildup and what you're
9 going to do about it. If it shouldn't rain.

10 MR. KITCHEN: Okay. Bob Kitchen. We have
11 Jeremy Baksh, who's a senior engineer, actually our
12 transition planning group. And Mike Franklin who's
13 our supervisor of site engineering. Jeremy is going
14 to discuss Chapter 8, Electrical Power and then Mike
15 will discuss Chapter 7 and 10.

16 CHAIRMAN RAY: Okay. And Jeremy, so I
17 don't look for it you make sure you talk about keeping
18 salt off the insulators in the switchyard so that we
19 still have offsite power.

20 MR. BAKSH: Would you like me to address
21 that question prior to my presentation?

22 CHAIRMAN RAY: No, no, no. Whenever it
23 comes up. I'll keep quiet on that point and expect
24 you'll take it up.

25 MR. BAKSH: Yes, sir, I will. So again,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 good morning. My name is Jeremy Baksh. I'm an
2 Electrical Engineer with Progress Energy's New
3 Generation Department. Next slide, please, Bob. So
4 as has been mentioned previously, we got our standard
5 plan so the DCD is incorporated by reference. And we
6 can discuss those site specific portions of our
7 application, Chapter 8, which include the switchyard
8 and connected transmission.

9 So integration of the Levy units into the
10 Progress Energy transmission system will require the
11 construction of 91 circuit miles of 500 kV
12 transmission and 88 circuit miles of 230 kV
13 transmission.

14 Progress Energy will also construct four
15 new substation facilities in addition to the
16 switchyard at Levy. And perform upgrades to various
17 substations and transmission lines within our service
18 territory.

19 We have completed our failure modes and
20 effects analysis. And we've also performed a grid
21 stability study and meet the Westinghouse requirements
22 for the AP1000. Next slide please, Bob.

23 Here we show a simple sketch --

24 MEMBER BROWN: How close did you come to
25 the three second limit? You didn't state, I didn't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 find it in the FSAR. So that's I asked the question.

2 MR. BAKSH: I'm going to actually have to
3 defer that question to Mr. Pigg from our group.

4 MR. KITCHEN: We'll have to, think we need
5 to -- Ken, do you have an answer for that?

6 KEN: No I don't have an answer for that.

7 MR. KITCHEN: We'll have to check that out
8 and get back to you.

9 MR. BAKSH: Let's go to the next one.

10 Here we show a simple sketch of the Levy switchyard in
11 relation to the Units LNP1 and LNP2. The switchyard
12 is shown on the right of the drawing. The
13 transmission corridor that contains the four
14 transmission lines that leave the Levy property are
15 shown to the right of that switchyard. Those lines
16 turn and head south and exit the property. Next slide
17 please, Bob.

18 Now we show a simple single line diagram
19 of the Levy switchyard. The output of the step-up
20 transformers, or the GSUs for the units, is connected
21 to a unique double-breaker position within the 500 kV
22 portion of the switchyard shown on the top of the
23 drawing.

24 The 500 and 230 kV BUSES are connected
25 through two 500 to 230 kV autotransformers shown in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the center of the drawing. And they are connected to
2 unique break and a half positions on both the 500 and
3 230 kV BUSES. The 230 kV BUS at the Levy site is a
4 normal source for all reserve Aux transformers for
5 Unit 1 and 2 shown to the bottom of the drawing. And
6 we've highlighted a breaker and a half configuration
7 and the double breaker schemes.

8 The Levy switchyard is a new addition to
9 the Progress Energy's transmission system and will be
10 constructed to meet all current and applicable
11 industry standards, as well as our own internal
12 standards for design and construction. For example,
13 all 500 kV lines constructed will have three
14 equivalent protection schemes, while all BUSES and
15 transformers will have two.

16 All breakers will have separate trip coils
17 sourced from separate DC supplies. The layout and
18 design features employed on the Levy switchyard offer
19 high reliability and support maintenance activities
20 going forward.

21 CHAIRMAN RAY: When it says future line,
22 how is that future scheduled relative to plant
23 operation? Before? After?

24 MR. BAKSH: It would be based on
25 transmission needs.

1 CHAIRMAN RAY: Okay. So it's not related
2 to --

3 MR. BAKSH: It is not related to the
4 issue.

5 CHAIRMAN RAY: We should ignore it for the
6 purposes of this?

7 MR. BAKSH: That's correct.

8 CHAIRMAN RAY: Okay.

9 MR. BAKSH: Next slide, please, Bob.

10 CHAIRMAN RAY: Before you --

11 MR. BAKSH: I'm sorry.

12 CHAIRMAN RAY: Okay. Go ahead and finish
13 the next slide. I'm sorry. Go ahead and do that and
14 I'll ask my question.

15 MR. BAKSH: The next slide is very simple.
16 So as I mentioned earlier we performed an FMEA and
17 confirmed for the Levy switchyard that no single
18 initiating event results in one or more off site
19 transmission lines or a loss of offsite power at the
20 LNP 1 or LNP 2.

21 MEMBER BROWN: The figure you had in the
22 FSAR conflicts like all the lines come in along the
23 same path. The figure I'm referring to is 8.2-202.
24 And it just shows all the lines coming parallel to
25 each other and then going up into the, seaward's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 north. The east side of the switchyard.

2 MR. BAKSH: That's correct, sir.

3 MEMBER BROWN: There's no other, when you
4 say you did the analysis, how far apart are all those.
5 I mean there was no definition that I could see that
6 specified how far they were apart other than the
7 statement in the FSAR that you did the FMEA.

8 MR. BAKSH: Right, you are correct that
9 the structures are located within a common corridor.
10 Currently the structures are spaced 105 feet apart,
11 center to center. And they are designed such that no
12 one structure has the ability to impact an adjacent
13 structure if an accident were to occur.

14 MEMBER BROWN: So I take it they're not
15 150 feet tall?

16 MR. BAKSH: The structure heights will
17 vary. They're averaging between 110 to 190 feet tall.
18 But the structures would be designed, we have two
19 different designs right now. We have a single mono-
20 pole design and what we describe as the battered a-
21 frame design. So it's a typical a-frame structure but
22 the legs are built inward so a collapse of that
23 structure would collapse upon itself and not lean to
24 one side.

25 MEMBER BROWN: I guess I don't picture it,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 since I'm not familiar with that type of construction
2 I --

3 MR. BAKSH: That's all right --

4 MEMBER BROWN: You mean to say it goes
5 like this?

6 MR. BAKSH: It's a battered A-frame so the
7 legs are bent inwards and there's a crossmember that
8 runs across. But there is no vertical -

9 MEMBER BROWN: So there's no way for it to
10 fall over?

11 MR. BAKSH: Well it's designed to collapse
12 in on itself. We can show a picture.

13 MEMBER BROWN: Put little nicks on the
14 inside, so if it's like when you're doing a lumberjack
15 thing you're putting nicks on the inside so it only
16 goes one direction. I'm just --

17 (Simultaneous speaking)

18 MEMBER BROWN: I have no familiarity with
19 this at all.

20 CHAIRMAN RAY: And we don't need to. Like
21 I say loss of offsite power is a design, it's a plant
22 design basis.

23 MEMBER BROWN: So 150 feet center to
24 center and the tallest towers are about 190 feet?

25 MR. BAKSH: Yes, sir. And those towers

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are in relation to the barge canal so the crossing in
2 the barge canal area would have the tallest towers.

3 MEMBER BROWN: Okay.

4 MR. BAKSH: Okay. The question was asked
5 about salt spray on the switchyard. Our typical
6 practice is to coat our insulators within our
7 substation switchyard. So we'll employ a silicon
8 based coating prior to energization of the switchyard.
9 We do have standard maintenance practices for a
10 hotwash of insulators, which can be done after a major
11 storm event as we have experience with our Crystal
12 River site, which is on the coast as well.

13 Recently Progress Energy has employed the
14 use of polymer bushing for insulators and for large
15 transmission equipment. So with the polymer
16 insulators and the coating we will employ our
17 maintenance practices to ensure that we minimize salt
18 build-up on transmission equipment within the
19 switchyard.

20 CHAIRMAN RAY: Do you guys have any
21 experience with evaporative salt cooling towers?

22 MR. BAKSH: Not within the coastal area to
23 my knowledge.

24 CHAIRMAN RAY: Well you'll get some
25 experience then. And you may find you'll have to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 change your maintenance practices but that's, there'll
2 be adequate warning that you have flash-overs.

3 MR. THOMAS: There was a question. Chase
4 Thomas, with Progress Energy. There was a question
5 about our experience. We do have Units 4 and 5,
6 natural draft cooling towers that are salt water.

7 MR. BAKSH: Across the river.

8 MR. THOMAS: And they're right adjacent to
9 the switchyard if I'm not mistaken.

10 MR. BAKSH: Yes. And the insulators at
11 the Crystal River switch are coated.

12 CHAIRMAN RAY: Okay. So you do have that
13 much experience at least?

14 MR. THOMAS: Yes.

15 CHAIRMAN RAY: Okay. All right.

16 MR. BAKSH: That's all I intended to
17 present. Unless there were other questions.

18 CHAIRMAN RAY: Okay. I mean in a coastal
19 environment where you have foggy days you can build up
20 salt on the insulators very fast.

21 MEMBER BROWN: I did have one other
22 questions.

23 CHAIRMAN RAY: Gratuitous advice.

24 MEMBER BROWN: If I can find it again.

25 Yes. In your assessment of plant interface

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 requirements, it was on page, grid availability you
2 talked about being 99.9 percent. And you said leading
3 causes of forced outage were recorded, or public
4 interference. What's public interference?

5 MR. BAKSH: That's an information --

6 MEMBER BROWN: Just an information item.

7 MR. BAKSH: Yes, if I can get back to you
8 on that. I'm not clear, I'd had to read that section
9 and get the context of it.

10 MEMBER BROWN: So there's nothing else in
11 there?

12 CHAIRMAN RAY: Would it be like car
13 accidents, that sort of thing?

14 MR. BAKSH: It could potentially be, you
15 know.

16 MEMBER BROWN: I was just trying to get a
17 feel for what you mean. You went through a list of
18 other items, such as lightning strikes, animals
19 running into, I guess, the posts or doing something.
20 I have no idea how a wolf or fox would impact the
21 towers. But the public interference seemed like an
22 interesting one. With trucks going down the road,
23 what's the adjacency. Can you have semis run into
24 them or something.

25 MR. BAKSH: We do have transmission

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 circuits that are located close to road right of way
2 and that impacted by public traffic, so vehicles.
3 These circuits would not be. They would be in our
4 common corridor that we would own and purchase the
5 land right to.

6 CHAIRMAN RAY: Well, Palo Verde lost all
7 offsite power due to a squirrel, for example.

8 MEMBER BROWN: Is that right? Ran up a
9 post huh?

10 CHAIRMAN RAY: No, in the switch gear.

11 MEMBER BROWN: Well that's not good.

12 CHAIRMAN RAY: So anyway it can happen.

13 MEMBER BROWN: Well I'd be interested in
14 what you considered in terms of public interference,
15 just a question that's all.

16 MR. BAKSH: I can follow-up with you.

17 CHAIRMAN RAY: Okay. Anything else?

18 MEMBER BROWN: That's it.

19 MR. KITCHEN: Okay we'll go ahead and move
20 to Chapter 9 and 10. Mike.

21 MR. FRANKLIN: Good morning. My name is
22 Mike Franklin, I'm the supervisor of site engineering
23 for the Levy Project. Today I'll be covering Chapter
24 9, which is Auxiliary Systems. And Chapter 10, which
25 is Steam and Power Conversion. As you've seen before

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the DCD is incorporated by reference and standard
2 material has also been incorporated. What I plan to
3 cover this morning is our site-specific raw water
4 system.

5 For Levy the raw water system's comprised
6 of two separate subsystems. A saltwater subsystem,
7 which takes its source from the cross floor at a barge
8 canal. It provides make-up to the surf water system
9 mechanical draft cooling towers.

10 And then we have the freshwater subsystem
11 that takes its source from the underground aquifer and
12 it provides makeup to the service water system cooling
13 tower, the fire protection system water storage tanks
14 and the potable water storage tank and the demand
15 water treatment system.

16 Next slide, Bob. Neither raw water
17 subsystem serves a safety related function. The raw
18 water system does not have interconnections with any
19 system that contains radioactive fluids. It is a
20 robust design. Failure of the system or its
21 components does not affect the ability of the safety
22 related system to perform its intended function.

23 The freshwater subsystem of raw water can
24 maintain water supply to the service water system
25 after sustaining a single active component failure.

1 This includes a loss of normal AC power, since the
2 freshwater, raw water well pumps and the booster pumps
3 can be manually loaded on the stand-by diesel
4 generator.

5 Flooding from the raw water system is
6 bounded by the surf water system. Failure analysis
7 for both the yard area and the turbine building.
8 That's all I have on Chapter 9. Are there any
9 questions?

10 CHAIRMAN RAY: No.

11 MR. FRANKLIN: Okay. The next is Chapter
12 10, which is Steam and Power Conversion. As similar
13 to Chapter 9, the DCD is incorporated by reference and
14 the standard material has also been incorporated.
15 What I plan to cover this morning are the site
16 specific cooling towers and the circ water system
17 blowdown system.

18 Levy's a little different. Instead of
19 natural draft cooling towers we'll be using mechanical
20 draft cooling towers. The towers are less than 70
21 feet tall. The closest seismic Category 1 structure
22 is approximately 700 feet away. So a tower collapse
23 does not affect safety related structure systems or
24 components.

25 A tower failure could potentially rupture

1 raw water system, circ water system and blowdown
2 piping. However, that rupture does not result in
3 flooding of any safety related SSEs and that's due to
4 the grading differences between the cooling towers and
5 the safety related structures. Next slide, Bob.

6 This is a schematic of our blowdown, circ
7 water blowdown system. And I just wanted to cover
8 some of the design features of that system. The
9 blowdown is on the high pressure side of the circ
10 water system pumps. There are two vacuum breakers
11 installed in series. And they are located near the
12 pumps and before the tie ins to the waste water
13 system, the sanitary drain system and the liquid
14 radwaste system.

15 The blowdown piping is made of 54 inch
16 high-density polyethylene piping. There is a cross-
17 connect located between the units. The blowdown
18 system has a very high flow rate, while the plants are
19 operating, of approximately 28,000 gallons per minute,
20 that's per unit. Just to give you a perspective, the
21 maximum liquid radwaste flow rate is 75 gallons per
22 minute per unit.

23 CHAIRMAN RAY: Is this like a semi once
24 through cooling system almost. The blowdown, I'm just
25 referring to the blowdown being the size that it is.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. FRANKLIN: Right. And it's about
2 three times what you would see for a solely fresh
3 water plant. The liquid radwaste piping is double
4 walled until it reaches the point of the blowdown line
5 and it's also part of our groundwater monitoring
6 program, which will be performed in accordance with
7 NEI 0808.

8 And the blowdown piping from that
9 interconnection point to where it discharges to the
10 Crystal River Energy Complex discharge canal is also
11 included in the scope of the groundwater monitoring
12 program.

13 CHAIRMAN RAY: Maybe keep it in
14 perspective it's about an eight mile run, right?

15 MR. FRANKLIN: It's a total of about 13
16 miles.

17 CHAIRMAN RAY: Thirteen miles.

18 MR. FRANKLIN: Yes. There is one vent
19 valve that's located prior to its crossing the cross
20 floor at the barge canal. That valve is a manual
21 valve that is locked closed. And it's only operated
22 when needed, primarily during system startup. So
23 that's all I have on Chapter 10. Open to any
24 questions you may have.

25 CHAIRMAN RAY: No, we've got a pretty good

1 overview starting out as to how that thing is laid
2 out.

3 MR. FRANKLIN: Okay. Thank you very much.

4 CHAIRMAN RAY: One question. When are
5 they going to rename the cross floor to barge canal to
6 something else?

7 MR. FRANKLIN: The Progress Energy --

8 (Off the record comments)

9 CHAIRMAN RAY: All right. Now let's see.
10 It's 9:25 we're doing well. We won't go to the closed
11 session. I think we should still hold that so we can
12 terminate it at the lunch break. Do you agree, Brian?

13 MR. ANDERSON: Yes, sir, I do agree.

14 CHAIRMAN RAY: Okay. So you guys are up.
15 So just looking ahead for those who are bringing folks
16 from next door or whatever, we will take a break after
17 this presentation. And then we'll look to try and do
18 some of the afternoon stuff and then have the closed
19 session, as I said, so that we can end it at the lunch
20 break and wrap up perhaps shortly after we return from
21 lunch. Okay.

22 MR. ANDERSON: This is the NRC Staff's
23 presentation of Chapters 8, 9 and 10. I'm Brian
24 Anderson, I was the project manager for these portions
25 of NRC's review. With me are Om Chopra and Larry

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Wheeler. Om is a lead electrical reviewer in the
2 electrical engineering branch. And Larry is a lead
3 reviewed in the Balance of Plant Branch. Both within
4 the Office of New Reactors.

5 This slide highlights the site specific
6 evaluations that were performed in Chapter 8. As you
7 can see the majority of these items are highlighted
8 here and will be touched on in some way as part of
9 Om's presentation. Om's presentation will be an
10 overview of these items. But as you can see the
11 majority of the site specific material in Chapter 8 is
12 part of the staff's presentation today. And with that
13 I will turn it over to Om.

14 MR. CHOPRA: Good morning. My name is Om
15 Chopra and I'm from Electrical Engineering of Nuclear
16 Reactors. This morning I'll be presenting the staff
17 review of Levy County COL FSAR Chapter 8. We just saw
18 the overview and the same COL action items and the
19 supplement items are identical to what we presented to
20 the Committee for summer as well as water.

21 The applicant has adequately addressed LNP
22 Supplement 8.1-1 regarding Levy County Unit 1 and 2
23 connection to the Progress Energy Florida Transmission
24 System. They have adequately described the connection
25 of the auxiliary, main and the startup transfer going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to the switchyard. And the applicant has adequately
2 addressed supplement regarding additional information
3 on regulatory guidelines and standards. Next slide,
4 please.

5 The applicant has adequately addressed the
6 details of the plans to chart connection to the grid.
7 You saw the presentation from the applicant. Unit 1
8 and 2 are connected to a new common switchyard having
9 two voltages, 500 kV and 230 kV and there are four
10 transmission line that connect the switchyard to the
11 Progress Energy Florida grid, as you heard from the
12 applicant.

13 The applicant has provided the site
14 specific voltage and frequency variations expected at
15 the LNP Units 1 and 2 switchyard during transient and
16 steady state operating conditions. And site specific
17 frequency decay rate.

18 The applicant incorporated a cable
19 condition monitoring program for underground, or
20 inaccessible cables, into the maintenance crew
21 program. The cable condition monitoring program
22 incorporates the guidelines of GL 2007-01 and NUREG CR
23 7000. Next slide please.

24 The applicant has adequately addressed all
25 site power systems adequacy, reliability, testing and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 inspection of switchyard components and effects
2 analysis of the switchyard. And they have also
3 addressed the interfaces. It is also the applicant's
4 stability analysis indicates that the designs satisfy
5 Westinghouse interface requirement.

6 The reactor coolant pump BUS holders will
7 remain above roof as necessary to maintain the flow
8 assumed in the Chapter 8 analysis for three seconds
9 following a turbine trip.

10 CHAIRMAN RAY: But do you know the answer
11 to the question that was asked? How much margin there
12 is in the three seconds?

13 MR. CHOPRA: Well, the AP1000 design is
14 that on a turbine trip the generator stays online for
15 additional 15 seconds. After 15 seconds they open the
16 breaker. So that 15 seconds connection still to the
17 grid provides, it stores the voltage for the
18 electrical and pump BUSES.

19 CHAIRMAN RAY: so it's not a grid related
20 answer, it's plant related.

21 MR. CHOPRA: Yes it is grid related. Sir,
22 it is grid related because they still have to
23 demonstrate that the grid is stable. So what we ask
24 them to do is provide a grid stability analysis. So
25 what they do is they look at various transmission

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 lines and the generation to the grid.

2 And they will take the worst case and see
3 if those lines or those generators are not there if
4 the grid was still stable. So that analysis indicates
5 the grid is stable. But what we want to know here is
6 if you keep the generator online for under 15 seconds
7 they would satisfy that three second criteria.

8 CHAIRMAN RAY: Okay. Charlie, does that
9 answer your question?

10 MEMBER BROWN: Well, the point being is
11 that when you have a turbine trip and the generator
12 stays online the grid is picking up load because it's
13 slowing down. So you have to worry about, number one,
14 the grid stability, that's the one issue.

15 The second issue is that you were running
16 within 15 percent of the rated voltage so that you
17 don't have adverse reactor cooling pump effects. And
18 therefore you've got to keep yourself within that band
19 for three seconds. Didn't really answer the question.

20 They say they did the analysis, I just
21 wondered how --

22 CHAIRMAN RAY: Okay. But I'm trying to
23 get you to ask the question of him.

24 MEMBER BROWN: You beat me to it. So my
25 point being is when they did the analysis how close

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 did they come to the three seconds, or there is no
2 analysis that applies to that. I'm just responding to
3 what I saw in here and regulated in the DCD, that's
4 all.

5 MR. CHOPRA: Let me put it in a different
6 way. They did the analysis, they said with the worst
7 case the voltage drops to 15 percent. But
8 Westinghouse criteria is you must maintain at least 80
9 percent voltage at the RCP pump BUSES. So that is a
10 transient for 15 percent, for worst case.

11 So obviously they meet the criteria of 30
12 percent voltage. This is the worst case they have
13 calculated. And no cases in will go below 15 percent.
14 And Westinghouse criteria you must have 80 percent.
15 So they allowed 20 percent transient voltage.

16 MEMBER BROWN: Okay. That wasn't stated
17 in the FSAR. It just said that the limit was 15
18 percent. They didn't say that they have five percent
19 margin in it. So you're telling me that they got five
20 percent margin relative to the DCD?

21 MR. CHOPRA: Well, they said the worst
22 case is 15 percent, so we asked the question 15
23 percent is acceptable. And they said yes, because
24 Westinghouse allows you to go up to 20 percent.

25 MEMBER BROWN: Okay. Let me go back. If

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you read the words, their words say, "The grid voltage
2 at the high side of the main step up and reserve
3 auxiliary transformers cannot drop from the pre-trip
4 steady state value by more than 15 percent." It
5 didn't say that's the worst case. Just says it cannot
6 drop below that.

7 MR. CHOPRA: But, yes --

8 MEMBER BROWN: In order to meet the three
9 second requirement.

10 MR. CHOPRA: Right.

11 MEMBER BROWN: So the 20 percent didn't
12 come in. And what that means I have no idea. I just,
13 but they're right up against the edge or do they have
14 some margin to it. That's all.

15 MR. CHOPRA: Well --

16 MEMBER BROWN: So if it was 2.9999 seconds
17 then that's not within the margin of uncertainty of
18 your analysis techniques.

19 MR. CHOPRA: But if it indeed for their
20 FSAR they are indicating that in normal conditions the
21 voltage variation is only five percent, plus/minus
22 five percent, it's just --

23 MEMBER BROWN: That's when operating.

24 MR. CHOPRA: When they're operating.

25 MEMBER BROWN: You haven't subtracted

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 load, it doesn't get past that. But that's not when
2 you've lost steam.

3 MR. CHOPRA: Right but this --

4 MEMBER BROWN: In this case you're
5 coasting down.

6 MR. CHOPRA: Okay. I evaluated there, I
7 know they had done worst cases and if the applicant
8 tells me it doesn't go below 15 percent, I --

9 MEMBER BROWN: He didn't say it doesn't.
10 He says it cannot drop. In order to meet the 20
11 percent. So there's a difference that's all.

12 CHAIRMAN RAY: You had an RAI and a
13 response on this one, right?

14 MR. CHOPRA: Yes, I do.

15 CHAIRMAN RAY: Maybe if we could see the
16 RAI it would take care of this.

17 (Simultaneous speaking)

18 MEMBER BROWN: It'd be nice to see it,
19 that's all.

20 MR. CHOPRA: Yes, okay. We can do that.

21 CHAIRMAN RAY: All right, can you get that
22 for us this morning still? It should be easy to
23 retrieve, the RAI and the response?

24 MR. CHOPRA: Well, I have to think.

25 CHAIRMAN RAY: It's a big job? Okay,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 typically we have access. Brian, could you?

2 MR. ANDERSON: We can find that RAI
3 response this morning once the presentation's done,
4 not -

5 CHAIRMAN RAY: Yes, obviously not now.

6 MR. CHOPRA: I guess the point I'm trying
7 to make is, you're right, the grid has to be stable.
8 But on a turbine trip or a generator trip, generator
9 stays on line for 15 seconds.

10 What it does is immediately when the
11 turbine trips it motors and becomes a synchronous
12 motor. And it provides that additional water support
13 to the --

14 MEMBER BROWN: I understand that.

15 MR. CHOPRA: Okay. All right, I'll dig
16 that up. Is it 7?

17 PARTICIPANT: You're on Slide 7.

18 MR. CHOPRA: Yes, applicant has adequately
19 addressed the grounding grid system design and the
20 lightning protection using acceptable matter
21 consistent with IEEE 80 and IEEE 665. Next slide,
22 please.

23 The applicant has adequately addressed the
24 standard departure related to periodic testing of
25 voltage regulating transformer. This is one of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 conformity item we have.

2 That concludes my presentation.

3 MEMBER BROWN: I did have one other
4 question that I didn't ask the applicant and I don't,
5 because I forgot. It's in a table. There's a table
6 that's provided in the FSAR relative to grid stability
7 and interface evaluation, goes to all like steady
8 state load in rush, nominal voltage, et cetera down
9 the table.

10 And there's one DC, the table item where
11 the limiting under-frequency value for the reactor
12 cooling pumps, the Westinghouse acceptance criteria is
13 57.7 hertz.

14 And they have a similar, the rest of the
15 table is the same. It's got an AC, you know,
16 Westinghouse requirement and a leading nuclear plant
17 value assumed.

18 And in all the other circumstances the
19 value assumed equals the Westinghouse requirement for
20 whatever reason, for whatever application. In this
21 particular one, instead of assuming a criteria of 57.7
22 hertz as being the bounding, the value, they used 59.5
23 hertz. I didn't understand how that was applied.

24 Is there an analysis they used that they
25 don't use the bounding value, and they assume based

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 another analysis that the pump never goes below 59-1/2
2 in some other accident analysis in terms of flow
3 criteria?

4 MR. CHOPRA: I think if it doesn't go
5 below 59.5 that's more conservative.

6 MEMBER BROWN: I couldn't find what they
7 meant by, you know, everything else they assumed the
8 Westinghouse values for whatever purpose analyses they
9 were doing. This one they didn't.

10 I didn't understand it, so that's why I
11 asked the question. And I meant to ask the question
12 of the applicant and didn't.

13 (Simultaneous speaking)

14 MR. CHOPRA: I think it's conservative so
15 I didn't question it.

16 MEMBER BROWN: Okay. All right, well,
17 I'll think about that one since I don't know what it's
18 used for.

19 MR. PIGG: I might be able to help with
20 that. My name is Ken Pigg. I'm an electrical
21 engineer on the Levy Project Development Team. And I
22 think the intent was as Om said, it's 59.5.

23 Basically, our design criteria for the
24 plant for that generator is around at plus or minus a
25 half hertz all the time. So we viewed that as a more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 stringent requirement which would bound the
2 requirement of, I think it was 57.7 that Westinghouse
3 required.

4 MEMBER BROWN: Well, you've got that
5 listed up in the other part of the table. It says
6 allowable frequency fluctuation for normal plant
7 operation.

8 MR. PIGG: Yes.

9 MEMBER BROWN: But then for this limiting
10 value, I guess the only way I could assume this was
11 that you all were assuming that you never go below 59-
12 1/2 based on that particular plus or minus half a
13 hertz.

14 But I didn't know what application you
15 were using it for that's why. But that's for normal
16 operation when you're fully powered and everything
17 else.

18 MR. PIGG: Right.

19 MEMBER BROWN: And the 57-1/2, I don't
20 remember what the DCD value is based on, whether
21 that's a normal operation value or whether that was
22 some other transient value based on some other, you
23 know, condition that occurs in the plant.

24 MR. PIGG: Off the top of my head I don't
25 remember what that's based on either.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Well, I didn't ask it and
2 still don't know what it is.

3 CHAIRMAN RAY: Yes, let's move on.

4 MR. ANDERSON: That's the end of the
5 Chapter 8 presentation. Before I let Om get up and
6 walk away, I want to try to address the earlier
7 question related to salt deposition in the switchyard.

8 In the staff's meteorology review there
9 was a statement made that modeling that was run from
10 a meteorological perspective determined that salt
11 deposition in the switchyard would be minimized or
12 neutralized through natural washing of rain.

13 And that I believe that the time period
14 was two months of salt deposition, two months of
15 continuous salt deposition was what was required in
16 order to impact the switchyard operability.

17 Om, correct me if I'm wrong. In the
18 Chapter 8 review, the staff's electric power review,
19 we do not specifically review the loss of offsite
20 power event that's caused by salt deposition, and we
21 do not specifically review and evaluate the
22 applicant's proposed maintenance and operations
23 practices that they discussed during their part of the
24 presentation.

25 Chapter 8 obviously considers a failure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 modes effects analysis that the applicant provides,
2 the staff evaluates that. And the loss of offsite
3 power is obviously considered as part of the PRA
4 analysis that occurs in Chapter 19.

5 But I think the short answer to the
6 question is there's not a specific staff evaluation to
7 the consideration of switchyard failure due to salt
8 deposition specifically.

9 CHAIRMAN RAY: That's fine. You know, by
10 experience, they'll figure out what needs to be done.
11 And I was just reacting to the proposition that it
12 something that you could rely on the rainfall to deal
13 with, and I'm not sure that's always going to be the
14 case.

15 But whatever it is, it's not something I
16 think we need to be worried about.

17 MR. ANDERSON: Understood.

18 CHAIRMAN RAY: Okay, anything --

19 MR. ANDERSON: That concludes the staff's
20 Chapter 8 presentation. We'll move on to
21 presentations of Chapters 9 and 10. In fact, the
22 next, I think, five slides just provide an overview of
23 the site-specific evaluations that the staff performed
24 in Chapters 9 and 10.

25 The focus of our presentation and what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Larry Wheeler is going to speak to you about is the
2 raw water system. So the next few slides simply show
3 tables of site-specific evaluations in Chapters 9 and
4 10.

5 These are all items that the staff
6 performed in evaluation and documented in its safety
7 evaluation. You'll also note that a variety of the
8 items are standard content or incorporated by
9 reference from the DCD.

10 But I'll just slowly scroll through these
11 next slides, and if there are any questions related to
12 topics other than raw water, offer the committee the
13 opportunity to ask.

14 And with that I will turn things over to
15 Larry Wheeler.

16 MR. WHEELER: Good morning.

17 CHAIRMAN RAY: Good morning.

18 MR. WHEELER: Parts of this slide were
19 previously described by the applicant, but the
20 emphasized raw water system is non-safety related and
21 non-seismic.

22 The raw water or fresh water subsystem
23 provides makeup to the service water cooling towers,
24 water treatment, potable water and fire protection.
25 Raw water supports the service water system which has

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 availability controls in the AP1000 DCD, it's in
2 Section 2.4. For the service water system that's for
3 modes 5 and 6.

4 The other subsystem salt water supplies
5 raw water to the circ water system and provides
6 alternate water for the liquid radwaste discharge in
7 the event that the circ water normal blowdown is not
8 available for the discharge path. Next slide, please.

9 Focusing on the details of the fresh water
10 subsystem includes two 100 percent capacity well
11 pumps, four 50 percent capacity booster pumps,
12 automatic strainers, media filters, 150,000-gallon
13 storage tank.

14 We have a diesel, standby diesel generator
15 supports for the raw water well pumps, the booster
16 pumps, discharge valves, and this design also includes
17 the HDPE materials for the underground piping system
18 for raw water. Next slide.

19 Being passed around is a sample of the
20 HDPE. This happens to have a wall thickness of about
21 an inch, inch and a quarter.

22 CHAIRMAN RAY: Larry, I think your papers
23 may be impacting on the microphone there. If you can
24 just pull them back.

25 MR. WHEELER: Thank you.

1 CHAIRMAN RAY: Thank you.

2 MR. WHEELER: So I would like to pass this
3 around just in case some of the members have not seen
4 what HDPE looks like. Next slide, please.

5 MEMBER RYAN: Is there any plan to, maybe
6 you're going to cover it in a minutes, on monitoring
7 the pipe, outside the pipe as life goes on? I
8 understand this is a fairly robust welded pipe, but I
9 always think the, your monitoring wells along the
10 length of the pipe --

11 (Simultaneous speaking)

12 MR. WHEELER: My understanding, the
13 groundwater monitoring program would be the, what is
14 utilized at the site to measure leakage. If the
15 applicant could clarify that?

16 MEMBER RYAN: Yes, I would like to hear a
17 little more detail. Maybe we can get that from them
18 later. Thank you.

19 MR. WHEELER: Next slide, please.
20 Focusing on the details of the salt water subsystem,
21 this includes three 50 percent capacity makeup pumps,
22 trapping screens, three screen wash pumps and
23 automatic strainers. The salt water subsystem has a
24 cross connection between units. Next slide, please.

25 The staff's review summary, the raw water

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 system is non-safety related, non-seismic, fresh water
2 system supports the RTNSS functions for both 5 and 6.
3 Fresh water subsystem has redundancy, 150,000-gallon
4 storage tanks, pumps and discharge valves are diesel
5 backed.

6 Fresh water subsystem pumps, wells, well
7 exceeds the service water base and makeup
8 requirements. Fresh water well pumps are two at 1,040
9 gpm each, and the fresh water booster pumps are at
10 four at 500 gpm each.

11 Reliable materials are being utilized
12 consistent with industry good practices applicable
13 codes and standards. Raw water system is non-
14 radioactive, contamination is not feasible due to its
15 configuration relative to potential sources of
16 contamination. Next slide, please.

17 GDC 2 and 4 have been satisfied. Pipe
18 breaks associated with the raw water system are
19 bounded by the circ water line break analysis.

20 Postulated breaks in the raw water piping
21 will not impact safety related components, because the
22 raw water system is not located in the vicinity of
23 safety related equipment and the water from the
24 postulated break will not reach any safety related
25 equipment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 RTNNS systems that are located in the
2 turbine building are not expected to be affected by
3 the flood. The staff concludes the raw water system
4 meets all applicable regulations. It's considered
5 highly reliable to support cold shutdown functions.

6 That is my presentation.

7 CHAIRMAN RAY: All right, any questions?
8 Okay, Brian, that finishes this segment of your
9 presentations, does it?

10 MR. ANDERSON: It does, yes.

11 CHAIRMAN RAY: All right, we'll take a
12 break now until 10 o'clock, and then we'll resume.
13 The basic game plan will be to take a look at anything
14 we should bring forward from this afternoon prior to
15 taking, going into closed session for the discussion
16 that's planned for the agenda.

17 That discussion was scheduled here for 15
18 minutes. Is that what we think it's going to take?

19 MR. ANDERSON: The closed session should
20 take no longer than 15 minutes.

21 CHAIRMAN RAY: All right, then if we get
22 back at 10:00, or let me go ahead and say five minutes
23 after 10:00 given that we should allow people 15
24 minutes here.

25 At five minutes after 10:00, then it looks

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to me like we can bring forward anything that's
2 available from this afternoon and thereby, and that
3 includes applicant's, I don't know if you've got your
4 resources for the response that you wanted to make to
5 us today or not.

6 MR. KITCHEN: We'll check during the break
7 to see if we can move that up.

8 CHAIRMAN RAY: Okay.

9 MR. KITCHEN: If not, we can certainly
10 move some presentations.

11 CHAIRMAN RAY: All right, in any event my
12 expectation is that we will as I say come back briefly
13 after lunch. I don't want to try and jam everything
14 into before lunch, but then we should be able to
15 finish up earlier this afternoon it looks to me like.

16 Okay, five minutes after 10:00.

17 (Whereupon, the foregoing matter went off
18 the record at 9:46 a.m. and went back on the record at
19 10:03 a.m.)

20 CHAIRMAN RAY: On the record. Brian, what
21 do you want to do?

22 MR. ANDERSON: My suggestion would be that
23 we move the presentations on Chapters 6, 11 and 12
24 forward. We think that's a relatively short
25 discussion, but we also think that might help address

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 some of the groundwater monitoring questions that were
2 asked before the break.

3 CHAIRMAN RAY: Yes.

4 MR. ANDERSON: And if we progress smoothly
5 through that I would suggest that following that
6 discussion we move into the emergency planning,
7 Section 13.3 discussion.

8 CHAIRMAN RAY: Yes, that's all fine. If
9 you guys are ready for that we are too.

10 MEMBER BROWN: Don't we need Mike for the
11 groundwater?

12 CHAIRMAN RAY: Got Mike right now as we
13 speak.

14 MEMBER BROWN: Oh, okay.

15 CHAIRMAN RAY: It takes awhile to get
16 people up there and actually moving, so I had every
17 confidence. Let's then proceed as you suggest, Brian,
18 and we begin as usual with the applicant if he's
19 ready.

20 But it doesn't look like -- well, maybe I
21 shouldn't speak so soon. You guys ready?

22 MR. KITCHEN: I guess we will go ahead.

23 CHAIRMAN RAY: Okay.

24 MR. KITCHEN: Okay, we'll go ahead and get
25 started. I'm Bob Kitchen. I'm Manager of Licensing,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and I'm going to discuss 6, 11 and 12. Paul Snead
2 will address questions that come up on groundwater
3 monitoring.

4 It might be best, we'll just go ahead and
5 do that first to go ahead and try to hopefully address
6 questions that the committee has.

7 CHAIRMAN RAY: Sure.

8 MR. KITCHEN: Paul?

9 MR. SNEAD: Yes. Is this thing on? Paul
10 Snead. Can you hear me?

11 CHAIRMAN RAY: Yes.

12 MR. SNEAD: Basically in FSAR Section
13 12AA, 5.4.14, the groundwater monitoring program. Per
14 standard for new licensees, that section adopts NEI
15 08-08A with regard to the groundwater monitoring
16 program description.

17 In general, we would be doing groundwater
18 monitoring like we do at our existing plants with
19 regard to groundwater protection initiatives, where we
20 would have shallow wells in close proximity to the
21 pipeline.

22 And then occasionally we would have, you
23 know, more emphasis say at a valve or somewhere where
24 there might be more likelihood of an event as opposed
25 to that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But the purpose of those wells would be to
2 confirm that there's no pipeline leakage or to, you
3 know, provide early detection if any such leakage were
4 to occur.

5 CHAIRMAN RAY: Okay, so you're meeting the
6 standard, and in this case it would involve the use of
7 monitoring wells near the discharge pump?

8 MR. SNEAD: Correct.

9 CHAIRMAN RAY: Okay, well, I think that
10 satisfies the question then.

11 MR. KITCHEN: Okay, we'll go ahead and
12 discuss Chapter 6. And Chapter 6 says, if you've seen
13 much of the presentation, it's very standard. We've
14 incorporated the DCD.

15 We've also, this Chapter includes the
16 hazardous chemicals table for the plant. FSAR Section
17 2.2.3, which we presented, discussed the offsite
18 hazards analysis which we discussed earlier this
19 morning.

20 Onsite chemical use would be maintained
21 for pH adjustment, corrosion inhibitors, scale
22 inhibitors, biocide algaecides, chemicals that we
23 would plan to use for Levy for these applications are
24 all standard chemicals and have been evaluated for the
25 AP1000. Yes, sir?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER RYAN: Chairman Ray just suggested
2 the answer to my question. I'm sorry I had to jump
3 out for a minute. They'll be monitoring along the
4 discharge fault line or at the --

5 (Simultaneous speaking)

6 CHAIRMAN RAY: Can we ask you to come up
7 to the microphone again, Paul?

8 MEMBER RYAN: I'm sorry, I apologize.

9 MR. SNEAD: No, that's quite all right.
10 No, they won't be monitoring along the pipeline to
11 confirm.

12 MEMBER RYAN: So you're confirming the
13 leakage.

14 MR. SNEAD: Confirming the leakage, or if
15 leakage were to occur it would be an early detection.

16 MEMBER RYAN: Perfect, just the answer I
17 was looking for, thank you.

18 MR. KITCHEN: That's really the extent of
19 Chapter 6 that's outside of -- Chapter 11.

20 CHAIRMAN RAY: These SCOLAs are nice,
21 aren't they?

22 MR. KITCHEN: They are, yes, sir. The
23 pattern seems to be helpful. Chapter 11, radioactive
24 waste management, again, standard material and DCD
25 incorporated.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 There are some site-specific items of
2 interest here, first is liquid radwaste and the waste
3 water system we'll talk about just a little bit. And
4 also gaseous waste management.

5 Also discuss briefly effluent monitoring
6 and long term onsite storage, really is, we thought it
7 might be a matter of interest because we have a
8 contention in that area.

9 Section 11.2 and 11.3 is, addresses liquid
10 and gaseous waste management. We, like I believe most
11 if not all others, use the LADTAP code for the
12 analysis for liquid waste.

13 This is based on Reg Guide 1.109, which is
14 calculation of annual doses demand. We use that to
15 calculate the estimated dose and dose rates. The
16 GASPAR computer code was used for gaseous waste
17 calculations. It is also per Reg Guide 1.109, and
18 both of those were determined acceptable limits.

19 Doses to individuals due to liquid and
20 gaseous waste discharges were determined to be within
21 10 CFR Part 50 Appendix I. We also did cost benefit
22 analyses for liquid system augments or gaseous waste
23 system augments.

24 Basically determined that were no augments
25 that were beneficial in terms of the cost of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 augment compared to the man rem savings that we could
2 achieve both in the gaseous and liquid waste. And
3 that was evaluated for whole body and thyroid.

4 Looking at 11.4, solid waste management.
5 Of course we do have long term onsite storage plans.
6 We have a contingent plan which is very similar to the
7 Vogtle plan that was developed, a little more detail
8 than you might see in a standard COLA.

9 This really stems from, the question we
10 had was with regard to contention is the challenge
11 that we wouldn't have adequate storage facility beyond
12 two years due to the restriction on shipment of
13 radwaste or long term storage I should say.

14 Our plans would be to develop an outside
15 storage pad which would be located onsite outside the
16 protected area within the owner controlled area. Of
17 course it would be located in high integrity
18 containers that would not degrade and those would be
19 stored within shielded containers.

20 We also looked at operational
21 considerations. Of course the primary concern here is
22 Class B and C waste, not Class A. Concern with Class
23 B and C, or the reality is that most of that waste
24 discharge is very predictable in terms with alignment
25 with outages because it's primarily resin discharge.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So in terms of planning, preparation,
2 understanding of what to expect, we have a good handle
3 on that during operational periods, and we would of
4 course implement actions to minimize waste generation.

5 So if you look at that we have actually
6 considerable storage that we could take advantage of
7 onsite. For example, the auxiliary building provides
8 more than a year of storage if needed for spent resin.

9 We actually do have vendor services
10 available. Currently right now, there's even for
11 Class B and C there's a vendor in Texas, for example,
12 that we could use to ship Class B and C waste for
13 storage.

14 They don't have the ability to dispose of
15 it but they do have long term storage. So we believe
16 just in terms of dealing with the waste situation we
17 have a very good ability to handle that.

18 And also the belief that certainly as we
19 proceed through time there will be even better
20 solutions. So we believe that the solid waste
21 management is well under control.

22 MEMBER RYAN: On the resin, you said
23 you're going to have those in probably, I guess high
24 integrity containers and then overpacks which would be
25 concrete overpacks for outdoor storage, is that right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. KITCHEN: Let me let Tony Pilo address
2 that, Tony? Tony Pilo is actually is an Emergency
3 Planning Supervisor at Robinson plant, but in his
4 previous life he worked with us.

5 MR. PILO: Tony Pilo, Progress Energy.
6 And that's correct, we would use concrete overpacks
7 for the --

8 MEMBER RYAN: Okay. I'm guessing you'd
9 have some sort of a pad, you know, concrete pad and
10 that kind of thing to --

11 MR. PILO: Yes, concrete pad, a fence for
12 security and personnel restrictions, operations
13 control.

14 MEMBER RYAN: Okay. Have you evaluated
15 any kind of a weather impact or a hurricane event or
16 is that factored into your safety analysis in any way?

17 MR. KITCHEN: We haven't actually done a
18 detailed analysis in terms of design.

19 MEMBER RYAN: Yes.

20 MR. KITCHEN: So we haven't done a
21 hurricane analysis, but if we needed, and this is
22 contingency so that's why we haven't done a full
23 analysis on it. It's really, in a sense, very
24 standard for storage.

25 MEMBER RYAN: Oh, sure I know that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. KITCHEN: So if we needed to do this,
2 this is the approach that we would take. We also
3 looked at, one of the questions I think where you're
4 going is, would you have enough time to plan, design,
5 construct a facility if you determined you needed
6 longer term storage than we had.

7 And our answer is, yes. Because it's very
8 predictable, it's tied to an operational discharge,
9 the manner that we would locate and store the waste is
10 very common. And at that point we would do those
11 analysis.

12 Tony, in fact, did a review to look at the
13 time required to plan, design, and construct, to
14 confirm that we could meet that within an operating
15 cycle, which is the most that we think would be
16 needed.

17 MEMBER RYAN: Yes, that sounds pretty
18 reasonable. I guess at this point you're not really
19 worried about irradiated hardware or anything like
20 that, really at plant life.

21 MR. KITCHEN: No, sir, not for --

22 MEMBER RYAN: Yes.

23 MR. KITCHEN: -- many years I would hope.
24 You talking about like a steam generator or something?

25 MEMBER RYAN: Or any other kind of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 irradiated hardware.

2 MR. KITCHEN: No, --

3 MEMBER RYAN: I can't imagine that would
4 be on the near term horizon.

5 MR. KITCHEN: Right, and that's the
6 reality even of this, is years away to have to deal
7 with. Thank you.

8 DR. HINZE: Tentatively, is there a site
9 selected?

10 MR. KITCHEN: There is a waste control
11 specialist, Tony, for shipment of waste. We're
12 talking primarily, I guess in Class B and C waste?

13 MR. PILO: Correct. Tony Pilo again,
14 Progress Energy. Currently our Progress Energy is a
15 fleet. The contracts, we actually do use the vendor
16 in Texas to send our Class B NC waste to, for long-
17 term storage.

18 So they have licensed a long-term storage
19 just not to bury it at this point. That's being
20 pursued, so contracts are set up that Levy, the
21 chemical site would fall right into that contract.

22 So reality, our first option would be to
23 send our Class B and C waste offsite for long-term
24 storage versus the pad. But if that contract or
25 vendor is no longer available, we would have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 contingencies to pursue our own type of --

2 MEMBER RYAN: Just so the other members
3 got a feel for it. What's long-term storage?

4 MR. KITCHEN: We can provide onsite
5 storage for the full operating life.

6 MEMBER RYAN: No, at your contractor, what
7 would it need to be long-term?

8 MR. PILO: Currently for the contract, the
9 long-term storage is indefinite. There's no
10 definitive time period so it's basically forever,
11 current contract.

12 MEMBER RYAN: That's interesting.

13 (Off microphone discussion)

14 MEMBER RYAN: I guess I'm just curious, is
15 that something spelled out in your arrangement, that
16 they're going to take it and you don't have to worry
17 about taking it back?

18 MR. PILO: That's correct. It's in the
19 contract and part of their license for long-term
20 storage itself.

21 MEMBER RYAN: Okay. Thank you.

22 MR. KITCHEN: Thanks, Tony. We'll move on
23 to Chapter 12 unless there, Chapter 12 is largely
24 standard. One area that we did do a site specific
25 evaluation was dose to construction workers.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Of course, Levy being a greenfield site,
2 first unit there's no dose to consider, no near onsite
3 operating plant. With Unit 2, of course, we'd have to
4 do an analysis which we did.

5 The direct radiation from both liquid and
6 gases, influenced from Unit 1 during the construction
7 period, I think remained well below the 10 CFR 20.1301
8 limits for public dose.

9 Excuse me, construction workers would be
10 classified as members of the public. In fact, when we
11 looked at both the total effective dose for the RAD,
12 for the construction workers during that period, it's
13 about less than one and a half percent of the dose
14 that occurs from background, just due to the dose.

15 We also factored into that considerations,
16 the Crystal River 3 releases and how that might affect
17 construction workers. And it's really not
18 significant.

19 I might also mention that analysis
20 included the worst case, chi/Q sector, even though the
21 workers, for example, are constructing Unit 2 North as
22 we showed in the location earlier, north of Unit 1.

23 We used the worst case sector which was
24 the west/southwest sector, and that alone adds a
25 margin of factor of six in terms of dose calculations.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But they were very small. So we don't see that as
2 significant. And that's all I have on Chapter 12.
3 Thank you.

4 CHAIRMAN RAY: Thank you. So you'll tee
5 up the staff presentation. We'll move to that.

6 (Off microphone discussion)

7 MR. HABIB: Okay. My name's Don Habib and
8 I'll be presenting Chapter 6, 11, and 12 for the staff
9 review. And for these three chapters, there were no
10 site specific areas we wanted to give a presentation
11 on.

12 What I'm going to do is just give an
13 overview, what was standard, what was site specific in
14 the review. And then if you all have questions, we do
15 have staff here who can address them.

16 For Chapter 6, the only site specific
17 items appeared in the control room habitability
18 review. And the applicant used the, accepted the
19 standard chemicals and did not have any site specific
20 chemicals.

21 And there were two items. One is the site
22 specific chemical list, which there was none. And
23 then also a statement about the usage of gas
24 dispersants. And that's all for Chapter 6.

25 For Chapter 11, RAD Waste Management,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 source term is an IBR section. The other sections,
2 the solid, liquid, and gas all have considerable site
3 specific information, cost benefit analysis, the
4 compliance with the part 50 limits, accidental release
5 for the liquid tank failure, and then a liquid
6 discharge pipe. But we didn't have any specific items
7 for that.

8 CHAIRMAN RAY: Any questions on that,
9 discharge line? Okay, no.

10 MR. HABIB: Okay. And then in Chapter 12,
11 two site specific items. The discharge pipe from
12 Chapter 11 is actually reviewed in Chapter 12. And
13 then there's the construction worker dose, which the
14 applicant just talked about. And that's the review.
15 If there's any questions.

16 CHAIRMAN RAY: All right.

17 MEMBER RYAN: Sounds good.

18 CHAIRMAN RAY: Hearing none, we'll thank
19 you again. And it looks like then we'll be easily
20 able to accommodate emergency planning before we
21 close, take a break for lunch, and then wrap up after
22 lunch with whatever additional information is
23 remaining at that point in time.

24 MR. KITCHEN: Larry Taylor is going to
25 present our emergency planning. Larry is a licensed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 senior reactor operator, actually worked at Harris, he
2 now works with us in Operational Readiness in New
3 Generation programs and projects. Larry?

4 MR. TAYLOR: Thank you. For Levy
5 emergency planning, I chose majority of my
6 presentation to point out some things that are unique
7 or unique to Levy or potentially different from global
8 and standard that you heard about previously.

9 You can go to the first slide, it looks
10 like. The Levy nuclear site, you've already been
11 presented as essentially separate from the Crystal
12 River site, so the emergency plan addresses the two
13 units at Levy.

14 We will point out to you that there is
15 some overlap on Emergency Planning Zones. And I'll
16 cover that a little bit later. The emergency plan for
17 Levy nuclear plant was developed in accordance with
18 NUREG-0654 10 CFR 50.47 and 10 CFR 50 Appendix Echo.
19 Next slide.

20 One thing that is standard, but a little
21 bit different than some of the other AP 1000s are
22 onsite emergency facilities. The Levy site will have
23 the technical support center and operation support
24 center in the AP 1000 DCD designated location. Okay,
25 next.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 For offsite emergency facilities, the
2 Emergency Operations Facility, EOF for Levy, we plan
3 to consolidate facilities with Crystal River and have
4 a common EOF in the location of the current Crystal
5 River nuclear plant EOF. That EOF will be established
6 consistent with NUREG-0696 guidelines.

7 MEMBER RYAN: How far away is that from
8 the site?

9 MR. TAYLOR: It's around 14 miles from
10 Levy and just outside the ten mile Emergency Planning
11 Zone for Crystal River.

12 CHAIRMAN RAY: And does it exist now and
13 is --

14 MR. TAYLOR: It currently exists.

15 MEMBER RYAN: Do you have to make any
16 changes if there's, god forbid, an emergency at both
17 facilities?

18 MR. TAYLOR: I'm going to talk a little
19 bit about the ability to handle simultaneous
20 emergencies in the next slide. But it will be able to
21 accommodate that.

22 MEMBER RYAN: Okay.

23 MR. TAYLOR: All right, yes. For a case
24 where there is a simultaneous emergency, both Crystal
25 River and Levy have emergency classifications at the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 same time, the EOF will be able to accommodate that,
2 and basically emergency response personnel from both
3 sites will report to the EOF.

4 There will be two separate staffs. The
5 facility lead for the EOF which is termed the EOF
6 Director, there will be an EOF Director for each site.

7 One of those individuals, during facility
8 activation, will be designated to be the single point
9 of contact to interface with state, counties, and
10 federal agents.

11 MEMBER RYAN: For both emergencies?

12 MR. TAYLOR: For, right. So if you think
13 about it, rather than there's some efficiency to be
14 gained and less confusion if you have both facilities'
15 EOF trying to make communications to the state and
16 county when there may be common things, such as PAR
17 communications, that would be consolidated from the
18 emergency.

19 So you would have one point of contact,
20 less confusion on things coming from two different
21 sites.

22 CHAIRMAN RAY: Yes, and the EOF, that
23 doesn't seem problematic to me. It's when you have a
24 single TSC supporting multiple units.

25 MR. TAYLOR: Right.

1 CHAIRMAN RAY: Or different, diverse
2 units, there's more question that I have.

3 MEMBER RYAN: It's just interesting to
4 think about and I'm not challenging a decision, but it
5 puts a burden on that one point of communication to
6 keep it all straight, I guess.

7 MR. TAYLOR: Right.

8 MEMBER RYAN: So really it sort of raises
9 the bar for the level of support from each, and I can
10 see it to support that communicator.

11 MR. TAYLOR: Okay. I think Tony, you
12 wanted to elaborate?

13 MR. PILO: Tony Pilo, Progress Energy.
14 The one thing I would like to add is in the state of
15 Florida, in Crystal River specifically, the state and
16 county individuals who are associated with all site
17 communications are actually in the Emergency
18 Operations Facility with the utility.

19 And so that carries over with the Levy.
20 So it'll help reduce the communications because there
21 are decision makers for the local counties and state
22 are actually in the facility together. And so they'll
23 all hear everything together. And they meet and
24 decide what the appropriate actions are to take.

25 MEMBER BLEY: Three counties, right, that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are --

2 MR. PILO: Yes, that's correct.

3 MEMBER BLEY: And that was the same,
4 you've always had three counties involved with Crystal
5 River as one?

6 MR. PILO: Marion County is a new county
7 for Levy that's not currently in with Crystal River,
8 so there will be one additional county for the Levy
9 plant that's not for Crystal River.

10 MEMBER BLEY: Thanks.

11 MR. TAYLOR: Okay, next slide. And you
12 guys are moving me right in, leading me into the next
13 portion of the slide. Next I want to talk about the
14 overlapping Emergency Planning Zones associated with
15 Crystal River and Levy.

16 As previously stated, Levy is
17 approximately nine miles, I think closer to nine and
18 a half from Crystal River, the existing site.

19 Because of that proximity and you have a
20 ten mile Emergency Planning Zone, they overlap. As
21 part of our evacuation time estimate, we did take into
22 account potential simultaneous emergencies at both
23 sites. And that was addressed.

24 And next slide is the best thing I can use
25 to explain the overlap. As Tony just mentioned,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Marion County is new. It is not in the Crystal River
2 Emergency Planning Zone.

3 But if you'll look at the, for the Levy
4 Emergency Planning Zone, the red and blue encompass
5 Levy. Your red and green encompass Crystal River. So
6 Citrus 2, the green is the only thing that's not in
7 Levy that currently exists with Crystal River.

8 The other thing to point out here is, you
9 can see these are labeled identical. So if you look
10 at the Crystal River Emergency Planning Zone and
11 there's a member of the public that's in Citrus 1 for
12 Crystal River, that individual is also in Citrus 1
13 Protective Action Zone for Levy. So those are aligned
14 to be the same.

15 MEMBER BLEY: I guess a dual event might
16 limit some of your evacuation routes but probably not
17 very much, it looks like.

18 MR. TAYLOR: Yes, from what I've read
19 there were some slightly different routes potentially
20 and more congestion, but there weren't routes
21 mentioned that were eliminated. But maybe that's what
22 they meant by different routes.

23 CHAIRMAN RAY: But you have done time
24 study that involves emergencies, evacuation from both
25 units?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. TAYLOR: Yes.

2 CHAIRMAN RAY: Okay.

3 MR. PILO: Tony Pilo, Progress Energy.

4 Yes, the time studies include evacuation, full
5 evacuation of Levy, strictly Levy, strictly Crystal
6 River, and then a combined full evacuation of Levy and
7 Crystal River simultaneously, and that's correct.

8 MEMBER BLEY: Much difference in the
9 estimates?

10 MR. TAYLOR: They like to talk in
11 percentile.

12 MEMBER BLEY: Yes.

13 MR. TAYLOR: So at 95 percent, there's a
14 five minute difference between individual or
15 simultaneous. At the 100 percentile, it's about a ten
16 minute difference.

17 MEMBER BLEY: Not bad.

18 MR. TAYLOR: Barely insignificant.

19 CHAIRMAN RAY: Okay.

20 MR. TAYLOR: That's everything I had
21 planned to present. Any other questions?

22 CHAIRMAN RAY: No. It's looking pretty
23 good place to site a plant from that standpoint. Seen
24 another, have seen worse. A lot worse.

25 MR. MISENHIMER: Okay, this is the staff's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 presentation for the Levy, Section 13.3 on Emergency
2 Planning. My name is Dave Misenhimer. I'm an NRO and
3 a project manager. And to my right is Tony Bowers,
4 the person who prepared Section 13.3 and he's going to
5 present today. Tony?

6 MR. BOWERS: Good morning.

7 CHAIRMAN RAY: Morning.

8 MR. BOWERS: My name is Tony Bowers. I'm
9 the Emergency Preparedness Specialist with the Office
10 of Nuclear Security and Incident Response, Division of
11 Preparedness and Response. I'm a Levy P reviewer for
12 the Levy COLA Section 13.3 on Emergency Planning.

13 I'd like to share some information with
14 you regarding the staff's evaluation of the emergency
15 plan and supporting information provided in the
16 application.

17 My presentation is going to include a
18 brief overview of some of the key regulations and
19 guidance important to the staff's findings regarding
20 emergency planning.

21 I intend to highlight a number of
22 outstanding confirmatory action items and briefly
23 describe the Applicant's proposed post-COL activities.

24 I'll also provide an overview of the Levy
25 Emergency Planning Zone, emergency response

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 facilities, and discuss the staff's overall
2 conclusions regarding evaluation of this information.
3 Next slide.

4 Our current regulations under Part 52
5 require that an applicant for a combined license
6 include information on emergency planning in its
7 application that complies with the requirements of 10
8 CFR Part 50.

9 Applicant Progress Energy Florida provided
10 its emergency plan for Levy nuclear Units 1 and 2 in
11 Part 5 of the COL application, which also included
12 supplemental information such as the evacuation time
13 estimate analysis for Levy County, and emergency plans
14 for the state of Florida and local Governments of
15 Levy, Citrus, and Marion Counties.

16 It's also important to note that Part 50
17 regulations require that no initial combined license
18 be issued unless a finding is made by the NRC, and
19 there is reasonable assurance that adequate protective
20 measures for the public can and will be taken in the
21 event of a radiological emergency.

22 Part 50.47(a)(2) requires that the NRC
23 base its findings in part on the review of Federal
24 Emergency Management Agency findings, and
25 determinations as to whether state and local emergency

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plans are adequate and whether there is reasonable
2 assurance that they can be implemented.

3 A FEMA finding will be based primarily on
4 its review of plans, but will also require a
5 demonstration of state and local emergency response
6 capabilities during a full participation exercise with
7 the licensee.

8 The NRC will also base its findings on NRC
9 staff's assessment as to whether the applicant's
10 onsite emergency plans are adequate, and whether there
11 is reasonable assurance that these plans can be
12 implemented.

13 The NRC will make an overall determination
14 of reasonable assurance of the emergency plans, taking
15 into account both the onsite and offsite reviews.

16 In addition to the existing regulations,
17 the staff used endorsed guidance to complete its
18 review of the emergency planning information provided
19 by the Applicant.

20 Regulatory Guide 1.101 states that
21 criteria on recommendations and NUREG-0654, FEMA-REP-1
22 Revision 1 are considered by the NRC staff to be
23 acceptable methods for complying with the 16 planning
24 standards in 10 CFR 50.47(b), and will be used for the
25 basis for evaluating the adequacy of emergency plans.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Next slide.

2 The staff conducted its review of the
3 emergency plan in accordance with NUREG-0800 Section
4 13.3 Emergency Planning, which is the standard review
5 plan.

6 Staff's review of the emergency plan
7 focused on whether the plan represented an overall
8 concept of operations for how the Levy emergency
9 organization would respond to a radiological emergency
10 at the LNP site, including provisions to protect the
11 public health and safety.

12 Specifically the staff reviewed and
13 evaluated the evacuation time estimate analysis
14 provided by the Applicant, dose assessment
15 capabilities, adequacy of the emergency response
16 facilities, ability to communicate with staff among
17 its facilities and federal, state, and local
18 Governments.

19 In addition, the staff reviewed the
20 Applicant's proposed emergency classification and
21 action level scheme, siren system, and response to
22 hostile action-type events.

23 Currently there are no open items with
24 regards to the staff's review of the emergency plan.
25 There are approximately 30 confirmatory action items

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 which will require NRC staff to validate various
2 revisions being made by the Applicant to the emergency
3 plan and EP ITAAC.

4 And I'd also like to note on that point,
5 that we have actually received Revision 3 to Part 5 of
6 the COL application for which the staff has not
7 reviewed, but should resolve these confirmatory
8 actions.

9 CHAIRMAN RAY: Well, it seems like a large
10 number, I don't know whether it is or not in this
11 category, but is it because of the only existing plan
12 for Crystal River that requires modification, what's
13 --

14 MR. BOWERS: The answer is no. Crystal
15 River was not necessarily factored into the staff's
16 review of the Levy emergency plan. It really just had
17 to do with the information presented by the Applicant
18 and my review of the regulations and guidance.

19 So there was information that I felt was
20 important, should've been considered and represented
21 in the emergency plan, and I requested the Applicant
22 provide justification for why that information either
23 wasn't in the plan or make the appropriate revisions.

24 CHAIRMAN RAY: Okay, but no open items is
25 the main --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BOWERS: No open items.

2 CHAIRMAN RAY: -- status point here?

3 MR. BOWERS: Correct. The staff has
4 reviewed the information provided by the Applicant and
5 its responses to requests for additional information.
6 And found that information to be acceptable. The
7 staff will confirm that that information is, in fact,
8 incorporated into Rev 3 of the COL application at a
9 later time.

10 CHAIRMAN RAY: Okay.

11 MR. BOWERS: The Applicant has proposed
12 several license conditions including EP ITAAC to
13 address items that can not fully be addressed at this
14 time, such as emergency planning implementation
15 milestones, to include submittal of emergency plan
16 implementing procedures, emergency action levels,
17 finalized --

18 PARTICIPANT: I think it was a static or
19 something on the phone line.

20 MR. BOWERS: Okay. Finalized letters of
21 agreement by state and local Governments, an exercise
22 to demonstrate response capabilities in the event of
23 a simultaneous emergency at Levy and Crystal River 3,
24 and the initial distribution of emergency information
25 to the public. Next slide.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Current regulations require the Applicant
2 to define Emergency Planning Zones for which advanced
3 planning shall be performed to adequately respond to
4 an emergency.

5 This figure is a simple illustration which
6 shows that the Levy ten mile plume exposure pathway
7 EPZ overlaps the Crystal River 3 EPZ, encompassing the
8 Crystal River 3 plant within its boundaries. Levy
9 nuclear plant is conversely included within the
10 Crystal River 3 EPZ.

11 Levy nuclear plant's plume exposure
12 pathway includes portions of Citrus, Levy, and Marion
13 Counties.

14 The Applicant states in its emergency plan
15 that the state in Florida, and the respective counties
16 within the ten mile EPZ have prepared plans for
17 responding to an emergency at the Levy site,
18 describing their respective responsibilities,
19 authorities, capabilities, and emergency functions.

20 The emergency plan further states in part,
21 the demographical data, topographical information,
22 land characteristics, access routes, and
23 jurisdictional boundaries. We're taking into
24 consideration in the Applicant's determination of the
25 ten mile and 50 mile Emergency Planning Zones.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The Applicant provided supplemental
2 information in response to our request for additional
3 information by the staff.

4 Confirming that the exact sizes and
5 configurations of the Emergency Planning Zone
6 surrounding the Levy site were discussed and
7 coordinated with representatives from the State of
8 Florida Division of Emergency Management, and Citrus,
9 Levy, and Marion County emergency management directors
10 for the ten mile EPZ counties. Staff found the size
11 of the Levy EPZ to be acceptable. Next slide.

12 Emergency response facilities, I'd like to
13 provide a general overview of the site emergency
14 response facilities, TSCs, OSCs, and the EOF.

15 The proposed locations of the TSCs and
16 OSCs at the Levy nuclear plant are consistent with the
17 TSC and OSC locations identified in the AP1000 DCD.

18 Staff's evaluation of the TSC location
19 size, habitability, and ventilation is contained in
20 the staff's evaluation of the DCD NUREG-1793 and its
21 supplements.

22 I'd like to highlight the proposed EOF.
23 The proposed EOF is to be located at Crystal River
24 Training Center on West Venable Street in Crystal
25 River, Florida.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The facility is a shared facility with
2 Crystal River 3. It's an existing facility approved
3 for use by the NRC for Crystal River 3. The EOF is
4 outside the ten mile emergency planning zone, but
5 within 20 miles of the Levy control rooms and TSCs.

6 EOF provides approximately 21,000 square
7 feet of working space, will serve as an assembly point
8 for EOF staff and representatives of federal, state,
9 county, and industry emergency response agencies.

10 The Levy emergency plan states that the
11 EOF is capable of supporting an extended emergency
12 operations including simultaneous activation with
13 Crystal River 3.

14 The emergency plan states in part, that
15 the EOF will have sufficient space and equipment to
16 accommodate response to a simultaneous emergency at
17 both sites.

18 And stated the equipment will be available
19 and adequate in number with connection capability to
20 facilitate unimpeded communication with offsite
21 agencies, onsite emergency response facilities, and
22 the emergency news center.

23 The Applicant stated the EOF will have the
24 capability to acquire, display, and evaluate
25 radiological, meteorological, and plant system data

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 essential for recommending offsite protective measures
2 for both Levy and Crystal River 3 sites without any
3 decrease in effectiveness.

4 The staff's evaluation of the existing EOF
5 as a shared facility included the consideration of
6 past implementation practices for shared facilities
7 pertaining to operating reactors and associated
8 commission requirements for operation.

9 In addition, the staff's evaluation
10 focused on the potential impact of functionality and
11 capability of the existing facility with the addition
12 of the two new units.

13 The Applicant proposed EP ITAAC to verify
14 that the EOF equipment and data displays will identify
15 and reflect the various effected units during an
16 emergency.

17 In addition, as briefly described prior,
18 the Applicant provided a license condition to
19 demonstrate its integrated capability and
20 functionality of the EOF for simultaneous activation
21 by the Levy and Crystal River emergency response
22 organizations for a simulated emergency condition.

23 This will include the demonstration of
24 voice and data communications with site emergency
25 response facilities, the NRC, and other federal,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 state, and local coordination centers. Next slide.

2 The results of the staff's technical
3 evaluation of the information incorporated by
4 reference in the Levy COL application are documented
5 in NUREG-1793 and its supplements.

6 Staff's conclusions for Section 13.3
7 Emergency Planning, are subject to the successful
8 closure of confirmatory action items identified in the
9 SER.

10 FEMA has reviewed the emergency plans for
11 the state of Florida, Levy, and Citrus, Marion
12 Counties, and provided its interim finding report for
13 reasonable assurance dated February 17th, 2010.

14 FEMA has concluded that based on its
15 review of the offsite plans and procedures, the
16 offsite plans are adequate, and there is reasonable
17 assurance that the plans can be implemented with no
18 corrections needed.

19 NRC staff has reviewed the FEMA report and
20 based its overall reasonable assurance finding on the
21 FEMA findings and determinations regarding offsite
22 emergency planning.

23 The LNP COL application includes post-
24 licensing commitments including EP ITAAC that are
25 necessary and sufficient to provide reasonable

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 assurance for onsite plans.

2 Based on the staff's evaluation of the
3 Applicant's emergency plan for proposed Units 1 and 2,
4 the staff finds the additional information and
5 proposed textual revisions provided in response to the
6 staff's requests for additional information.

7 The onsite emergency plans meet the
8 planning standards in 50.47(b) and Appendix E to Part
9 50. And that concludes my presentation.

10 CHAIRMAN RAY: Okay, that sounds like a
11 complete and comprehensive review. Any questions
12 anyone had? Thank you very much.

13 MR. BOWERS: Thank you.

14 CHAIRMAN RAY: Now I turn to the Applicant
15 and ask, do you want at this time to talk about things
16 that we had open at the end of the day yesterday, Bob?

17 MR. KITCHEN: Chairman, we've got that
18 planned at 1 o'clock.

19 CHAIRMAN RAY: All right.

20 MR. KITCHEN: And I think somebody is out
21 trying to contact them. But right now, I'd have to
22 say we're not ready until after lunch.

23 CHAIRMAN RAY: That's fine. No problems
24 at all in that regard. Then that leaves 14, 16, and
25 18, doesn't it?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. ANDERSON: That's right. The
2 remainder of Chapter 13 is also part of that because
3 that would be the last remaining item before our
4 closed session.

5 CHAIRMAN RAY: All right. Well, let's do
6 that then. And that way then after lunch we'll just
7 have the completion items, plans for the full
8 committee meeting, and any discussion that remains to
9 be had. Yes, Charlie?

10 MEMBER BROWN: I spoke with, where is he,
11 what's his name?

12 MR. ANDERSON: Om.

13 MEMBER BROWN: Om, thank you. And he gave
14 me some information out of the SC. I was able to find
15 that. I went back to the volt for the DCD, and it's
16 a voltage issue not a frequency issue and they've got
17 plenty of margin on that, so I'm satisfied.

18 CHAIRMAN RAY: Thank you, Charlie.

19 MEMBER BROWN: Thank you. If the
20 Applicant didn't hear that, they should take note.

21 PARTICIPANT: They don't need to do
22 anything to the targets.

23 MEMBER BROWN: Okay, thank you.

24 CHAIRMAN RAY: I'm sure they're paying
25 close attention.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: They don't miss that much.

2 MR. KITCHEN: I'm Bob Kitchen, Licensing
3 Manager. We're going to discuss Chapters 13, 14, 16,
4 and 18 which as you've seen, much are largely
5 standard.

6 Chapter 13, of course, as everyone's aware
7 does not include 13.3 which we just discussed, the
8 emergency plan. So it is a standard chapter and the
9 standard material is incorporated, but you'll see a
10 lot of text in Chapter 13 with regard to
11 organizational structure.

12 There's really nothing unusual here.
13 Typically this is titles. There are also some
14 differences in alignment as you might expect, for
15 example how our construction organization is aligned
16 within our corporate structure, as opposed to maybe
17 another utility.

18 So there's really nothing in terms of how
19 the organization structure that's really out of line,
20 let's say. That is really the only difference in
21 Chapter 13, other than the emergency plan.

22 Looking at 14, Chapter 14 is Initial Test
23 Program. Site specific material really related to
24 looking to see what ITAAC, for example, might need to
25 be incorporated because of site specific systems

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 unique to the Levy plant.

2 Also things such as emergency plan and
3 security plan. The emergency plan was looked at in
4 terms of ITAAC based on Reg Guide 1.206, generic ITAAC
5 recommendations, and then modified to reflect anything
6 that would be Levy specific. Similar for security
7 ITAAC, is based on NRC and NEI generic ITAAC.

8 Systems, structures, and components. We
9 looked at in terms of classification of the system,
10 the importance of classification A, B, C, et cetera,
11 whether the system was related, required for defense
12 in depth.

13 For non-safety systems, were there any
14 features or functions that were credited for
15 mitigation of the design basis events.

16 And anything which was identified in the
17 Chapter 16.3 is for additional regulatory oversights.
18 We did a screen on systems to see if any of the items
19 fell out requiring that.

20 The only system that was identified for
21 unique, shouldn't say unique, for ITAAC were
22 transmission switch yard and offsite power, and the
23 words from ITAAC, developed for that system.

24 More significant for Levy in terms of this
25 would be the roller compacted concrete, waterproof

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 membrane which is standard, but the drill shafts for
2 the turbine building, RAD waste, and annex building,
3 which we discussed at length yesterday.

4 Those systems being unique or should it
5 say non-systems, being unique for Levy required ITAAC.
6 And we did help ITAAC for each of these areas. That's
7 all I have for 14.

8 CHAIRMAN RAY: Bob, since we talked about
9 it before, what's the deal on the waterproof membrane,
10 ITAAC, anything out there?

11 MR. KITCHEN: The waterproof membrane has
12 an ITAAC for sliding coefficient.

13 CHAIRMAN RAY: Yes.

14 MR. KITCHEN: And specifically that we
15 demonstrate that the waterproof membrane would meet a
16 coefficient friction of .55.

17 CHAIRMAN RAY: Okay.

18 MR. KITCHEN: Which is the standard DCD.

19 CHAIRMAN RAY: Right. Seen that before.
20 Okay.

21 MR. KITCHEN: Okay. Chapter 16, there are
22 a lot of words up here, it's really not different. We
23 incorporated the tech specs without exception as the
24 standard tech specs. We did replace bracketed
25 information. It was the generic with the site

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 information, of course.

2 Part of that involves a set point control
3 program or, for example, for set point development as
4 systems are designed.

5 The Section 2 and 3, which are the design
6 and reliability assurance program and investment
7 protection, it was nothing different at Levy. Then
8 the tech specs that would be issued for the plant are
9 actually contained in Part 4 of the application.

10 Chapter 18 is standard. Nothing Levy
11 unique there. It just reflects the activities that
12 would be done to insure that human factors are
13 incorporated appropriately in design change or a new
14 design in terms of lessons learned, in terms of
15 operating experiences, et cetera, so those are related
16 back to Chapter 18. That's all I have on those
17 things.

18 CHAIRMAN RAY: It's hard to find something
19 to talk about on a unique basis, isn't it? Okay, any
20 questions? If not, we'll now hear corresponding
21 sections from the staff perspective and then we'll
22 take another break to close the meeting. We'll
23 conduct the closed portion of the meeting and then
24 we'll recess for lunch.

25 (Off microphone discussion)

1 MR. MISENHIMER: Okay, we are here to
2 present Chapters 13, 14, 16, and 18 for Levy COL
3 application. It will be presented by both me, David
4 Misenhimer, I'm an NRO and a project manager and Tom
5 Galletta. It's a very abbreviated presentation.

6 For Chapter 13, we highlighted here are
7 site specific evaluations that had to be done,
8 otherwise everything was incorporated by reference or
9 was standard content. Are there any questions on any
10 of these? Same thing for Chapter 16, there was just
11 one site specific item highlighted on this slide. Any
12 questions?

13 CHAIRMAN RAY: No.

14 MR. MISENHIMER: Okay, I'd like to turn it
15 over to Tom for Chapter 14.

16 MR. GALLETTA: Okay. Well, I'm Tom
17 Galletta with again, with Division of New Reactor
18 Licensing AP 1000 Branch. The staff doesn't have a
19 prepared presentation on Chapter 14.

20 Sections 14.1 and 14.2 are IBR or IBR
21 standard. And 14.3 contains certain site design
22 material that's evaluated in other chapters. The
23 Applicant mentioned some of the things in Chapter 3,
24 Chapter 13. Does this committee have any questions?

25 Okay, turning to Chapter 18, just one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 clarification on that opening slide, it says and I
2 don't know if you caught that, it said, steam
3 powering, steam and power conversion system, it's
4 actually human factors. It should say human factors.

5 CHAIRMAN RAY: I did catch that. But I
6 hadn't figured out yet what the problem was. But you
7 explained it now.

8 MR. GALLETTA: Confusing Chapter 10 with
9 Chapter 18.

10 CHAIRMAN RAY: Yes, okay.

11 MR. GALLETTA: Okay. Oh, we don't have a
12 prepared presentation for Chapter 18. The slide
13 indicates that Section 18.2 has the only site specific
14 evaluation regarding the location of the EOF.

15 The remaining sections are IBR or IBR
16 standard and the Applicant did speak extensively about
17 the location of the EOF. Are there any other
18 questions?

19 CHAIRMAN RAY: No.

20 MR. GALLETTA: That's the end of our
21 presentation.

22 CHAIRMAN RAY: Yes, that's actually why I
23 was talking to Weidong, I was trying to figure out,
24 did he talk about steam and power conversion systems
25 because he it went past me, without realizing it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Okay, thank you.

2 All right, we'll take a ten minute break
3 and come back in closed session, conduct the closed
4 session portion of the meeting. And we may have some
5 further stuff just for this afternoon to make sure
6 we're all on the same page. And then we'll take a
7 break and return.

8 Let me advise for any who leave now, the
9 schedule shows returning from lunch at 1 o'clock. I'm
10 not sure we want to wait until 1 o'clock, I'll consult
11 with the Applicant to see if he'd be ready any earlier
12 than that. So we may come back from lunch a little
13 earlier than 1 o'clock. And I just want to make note
14 of that.

15 MR. KITCHEN: Mr. Chairman?

16 CHAIRMAN RAY: Yes.

17 MR. KITCHEN: Just so you can maybe set a
18 time. We can be available for the follow-up from
19 yesterday from 11:30 on, so whatever time you want to
20 set for it would work for us.

21 CHAIRMAN RAY: I see, all right. Well,
22 then let's, I don't want to cause too much confusion
23 among people that might not be part of the closed
24 session, so let's say that right now we plan to come
25 back from lunch at 12:30?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So that anybody who's interested in
2 hearing the wrap-up, because I think that will give us
3 an hour lunch easily after we're done with the closed
4 session from what I understand any way, or it may turn
5 out I'm mistaken about that.

6 We'll take a ten minute break now. Come
7 back at 11:10. We'll go then until probably 11:30,
8 take our lunch break. Yes, Joy?

9 MEMBER REMPE: Okay, just out of
10 curiosity, is it possible to do the closed session and
11 then come back at 11:30 and hear your response and be
12 done before noon?

13 CHAIRMAN RAY: Well, it's certainly
14 conceivable we can do that. I was just concerned
15 about folks who might leave and then not know when
16 we're going to resume the open session. Is there
17 anybody who objects to doing what she's recommended we
18 consider? What's your feeling about that, Bob?

19 MR. ANDERSON: I don't have any objection.
20 Staff can support closing the session and then
21 returning for follow-up before lunch.

22 CHAIRMAN RAY: All right. You guys have
23 any, anybody have any objection? Hearing none then,
24 what we'll do is we'll close the session. Resume at
25 11:10. We will then do the material that's called for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 then.

2 We'll reopen the session and see if we can
3 finish before lunch so that those of you who, this is
4 not a particularly great travel day and anybody that
5 has to worry about that, I'm sure would be glad to get
6 an earlier start rather than a later one. I know
7 that's not why you asked --

8 MEMBER REMPE: I have a meeting with
9 another staff member from 12:00 to 1:00 that's why --

10 CHAIRMAN RAY: Oh, I see.

11 MEMBER REMPE: -- I'm suggesting it.

12 CHAIRMAN RAY: Well, in any event, that's
13 the general outline. We'll close, we'll then reopen,
14 see if we can finish before lunch.

15 (Whereupon, the meeting in the foregoing
16 matter went off the record at 11:00 a.m. and went back
17 on the record at 11:10 a.m.)

18 CHAIRMAN RAY: Okay, we've got our phone
19 line open it sounds like. We're back in open session.

20 PARTICIPANT: Can I take these back? You
21 offered to --

22 CHAIRMAN RAY: Yes, yes you may. And
23 we're prepared to address or receive applicant's
24 response with regard to items that we discussed at the
25 end of the day yesterday, and then we'll see where we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 stand.

2 Now, basically, it's no surprise, I don't
3 believe, to anyone, that in the entire agenda for this
4 two-day meeting that where we began is where we
5 return to now, and that is things that are really
6 unique about this site and which can be more
7 challenging sometimes, than most other things are.

8 And that has to do with the seismology and
9 geology type issues that are site-specific. And this
10 being a greenfield site, then there's, perhaps, even
11 though it's nearby to an existing operating plant, the
12 plant was licensed quite some time ago, and therefore
13 we have to look at this entire area with fresh eyes,
14 which is what we're doing.

15 With that having been said, are you ready
16 now, Bob, to begin?

17 MR. KITCHEN: I hope so. I need some
18 people on the phone. Keep feeling lonely up here.

19 PARTICIPANT: Go ahead.

20 MR. KITCHEN: Bob Youngs, are you on?

21 MR. YOUNGS: Yes, I am.

22 MR. KITCHEN: Okay. Kathryn Hanson?

23 MS. HANSON: Yes, I am.

24 MR. KITCHEN: Okay, we have two
25 presentations, basically, to try to address the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 questions that the committee left with us yesterday.

2 Specifically, on the 2008 Charleston
3 update with the USGS, I should say, and also on the
4 question regarding the fault types with regard to
5 furthering documentation.

6 I'd like to start with Bob Young's. Bob,
7 we have your slides up.

8 MR. YOUNGS: Okay.

9 MR. KITCHEN: So as you step through,
10 we'll just page through the slides.

11 MR. YOUNGS: All right. Can everyone hear
12 me all right?

13 CHAIRMAN RAY: Yes, we can.

14 MR. YOUNGS: Okay. I have a brief
15 presentation on the comparison of the USGS 2002 --
16 Sorry I can't, there's some, I can't quite hear. Is
17 there something by the phone?

18 CHAIRMAN RAY: Well, I don't know. We're
19 trying hard to listen to you. This is a third world
20 country, after all, and communications are
21 intermittent, accordingly.

22 (Off the record comments)

23 MR. KITCHEN: Kathryn, are you on a land
24 line?

25 MS. HANSON: Yes, I am. Can you hear me

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 okay?

2 CHAIRMAN RAY: Yes.

3 MR. KITCHEN: We can. I think maybe we'll
4 just move to you first.

5 MS. HANSON: Okay.

6 (Off the record comments)

7 MR. KITCHEN: We have your first slide up,
8 Kathryn. Go ahead and start.

9 MS. HANSON: Okay. In response to some
10 questions that were raised yesterday about the faults
11 that had been populated by Vernon, 1951, I put
12 together a series of slides to go over some of the
13 basic populations that Vernon used to hypothesize the
14 fault, and then our assessment of those faults.

15 We described the information on the Vernon
16 fault in FSAR Section 25114-34, and then some
17 additional detail in Section 25124.

18 Basically, Vernon inferred a number of
19 faults as steeply dipping, normal dip slip sheer
20 faults that sounded graben depressions and horst
21 ridges associated with a, what he inferred to be a
22 tectonic uplift, referred to as the Ocala uplift.

23 He acknowledged that was no direct
24 observations regarding the dip or down-dip extent of
25 these faults. He did assume a very steep dip for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 these features, based on the fact that they had very
2 linear traits.

3 They were expressed as topographic
4 features, and vegetation lineaments that cut across
5 the relief, suggesting a steep dip. The question was
6 raised yesterday about what the vertical displacement
7 is on the individual faults.

8 For the faults that they did provide, or
9 he did provide some information, which was not all of
10 the faults, including several of the small faults that
11 projected into the study area, the site area, but the
12 vertical displacements range from 20 feet, six meters,
13 to 160 feet. The field evidence he sited for the
14 apparent displacements on these faults were based on
15 very widely spaced outcrops and limited subsurface
16 information from Wells, one of the faults that
17 projects into the site area.

18 The control points on the displacement are
19 over three kilometers apart, so these were not well-
20 constrained vertical displacements. Next slide,
21 please.

22 PARTICIPANT: We're there, Kathryn.

23 MS. HANSON: All right. So we evaluated
24 these faults. One of the issues that came up, that
25 the Florida Geological Survey provided was the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 assessment of what the Ocala Uplift really represents,
2 and, in fact, the general consensus is that this is
3 not a true uplift. That, in fact, the Florida
4 Geological Survey refers to it as the Ocala platform.

5 It's relatively stable feature, the deposit, the
6 depth, the pre-Middle Eocene units are not warped or
7 deformed, and the apparent deformation or folding of
8 some of the younger units is attributed to
9 differential compaction or possibly some
10 sedimentological processes in the Middle Eocene.

11 So the, kind of, tectonic association of
12 these features, these proposed faults with a tectonic
13 structure is not valid.

14 The Vernon Fault parallel, and they're not
15 particularly distinct from other regional lineaments
16 that have been interpreted be joint sets of curves
17 throughout the site region and, in fact, throughout
18 most of the state of Florida.

19 And we looked at these features in a
20 little more detail in the site vicinity, and we
21 compared them to regional scale Landsat and digital
22 elevation model data that we had for this site, and
23 the lineaments are not particularly apparent in the
24 data sets. Next slide.

25 PARTICIPANT: We're there.

1 MS. HANSON: Also, we talked at length
2 with the Florida Geological Survey. The survey does
3 not show these faults on any geologic map.

4 There are recent structure, contour maps
5 on Tertiary subsurface units that were presented by
6 Arthur et al. 2008 in a regional hydro-stratigraphic
7 volume, and these also do not show evidence for these
8 faults.

9 The Florida Geological Survey also has looked at
10 these features in several of the quarries that Vernon
11 cited as evidence for surface displacement and infers
12 these to be the deformation features in those quarries
13 could be attributed to localized karst-related
14 deformation features.

15 They also noted that many of the offsets
16 in the top of the Ocala that were postulated to be
17 faults, may also be related to the fact that the Ocala
18 surface we talked about over the past day or so, is a
19 karstified, unconformable material and there can be
20 significant relief on the surface on tectonic. Next
21 slide.

22 So, in conclusion, as we outlined in
23 Section 2.5.3, the postulated faults that Vernon
24 hypothesized, likely, do not exist.

25 There's no evidence to suggest that they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 exist or propagate into the site area, or that they've
2 been active in the Quaternary, and, therefore, we
3 concluded that they were not capable tectonic sources,
4 as defined by Red Guide 1208.

5 Therefore, we did not feel there were any
6 specific features or targets in the site area that
7 would warrant additional investigations, you know,
8 more detailed subsurface studies, geophysical surveys
9 growing.

10 And that was, basically, what we concluded
11 and summarized in the FSAR.

12 CHAIRMAN RAY: All right. Thank you. Dr.
13 Hinze will have questions.

14 DR. HINZE: Kathryn, your usual very
15 comprehensive job and I want to congratulate you on
16 putting this together.

17 I just, really, have one question, and
18 that is, in the pre-Tertiary rocks, or in the Tertiary
19 rocks, looking at the drilling logs that are
20 available, is there any chance that there is vertical
21 displacement. Can it accommodate vertical
22 displacements as suggested by Vernon?

23 MS. HANSON: I think that there's some
24 potential evidence for possibly karst-related features
25 along some of these features, that may, in some of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 cross sections that he presented.

2 Based on our discussions with the Florida
3 Geological Survey and their assessment of the
4 subsurface stratigraphy, there has been no suggestion
5 or evidence for displacement or the existence of these
6 faults.

7 We -- at the site, there was no
8 indications in any of the site-specific borings or any
9 deformation features that would suggest that there had
10 been faulting in the vicinity, or near the borings.

11 We also don't see between the deeper
12 borings, between the LNP 1 and 2 units seem to show
13 consistent dip to the deepest units, the peak beds
14 that were observed at the bottoms of the deeper
15 borings under the nuclear islands in both sites. The
16 dip on that seems to be consistent with the regional
17 dip.

18 So, to my knowledge, we don't see any
19 evidence from either our studies or from more recent
20 studies by researchers in Florida.

21 DR. HINZE: You focused, in your last
22 comments, on the more local geology associated with
23 the two LNP units. What, on a more regional basis,
24 did you look at some of these deep drilled, I mean,
25 logs on a more regional basis outside of the LNP site?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. HANSON: Yes. We did go and collect
2 all of the logs for the deeper oil and gas exploration
3 wells that were available in the site vicinity.

4 Three of those deeper wells borings that
5 had velocity profiles were used to assess the velocity
6 profile at depths between the 500 feet to basement.

7 The question was raised yesterday about
8 the location and the information from those wells.
9 Those three wells are shown on the site vicinity map.

10 The general stratigraphy that you saw in
11 all of those wells suggested a fairly uniform or a
12 uniform slight southward dip to the bedding, which is
13 consistent with the regional hydro geologic cross-
14 sections by Miller and others. So we did look at that
15 well data, as well.

16 DR. HINZE: Well, it would be difficult,
17 if I understand correctly, to get 150 feet of relief
18 on a fault, vertical relief on a fault to be
19 accommodated by this drilling result, so, if I
20 understand you correctly.

21 I have no further questions, Mr. Chairman. In
22 fact, I want to go on record as congratulating Kathryn
23 for putting this together, and I agree with her.

24 CHAIRMAN RAY: All right. Well, this will
25 become part our record. Before we go to Dr. Youngs,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 let me ask about one of my colleagues, here. Joy, do
2 you anticipate you'll be wanting to put anything on
3 the table when we have our final go-around?

4 MEMBER REMPE: I think I'm good. I'm
5 fine.

6 CHAIRMAN RAY: What?

7 MEMBER REMPE: No.

8 CHAIRMAN RAY: No.

9 MEMBER REMPE: Yes.

10 CHAIRMAN RAY: Okay. Well, we'll continue
11 on then. My expectation now is, because I don't want
12 to rush our conclusion because the next thing we do is
13 we go to a full committee meeting, is that we will
14 take a lunch break and resume at 1 o'clock to do that,
15 but now that we're set up the way we are, we'll go
16 ahead with Dr. Youngs' presentation, make sure that
17 that's satisfied, then we'll have a chance to make
18 sure we're all organized.

19 We'll come back at 1 o'clock, we'll decide
20 exactly what we want to ask for at the full committee
21 meeting. I just don't want to do that in a rush and
22 then wind up being incomplete in what we plan to do,
23 then.

24 So we will meet again at 1 o'clock, and
25 you can come back and join us and we'll decide. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 let's go ahead with Dr. Youngs, and we'll get his
2 presentation and then we'll recess for lunch and come
3 back at 1 o'clock. Go ahead.

4 MR. KITCHEN: Bob, are you on the line?

5 MR. YOUNGS: Yes, I am.

6 MR. KITCHEN: Bob, we have your
7 introductory slide up, so we'll go ahead and start.

8 MR. YOUNGS: Okay. So, again, this is Bob
9 Youngs. If we go to Slide 2, I have summarized here
10 that there is only one difference between the 2002 and
11 2008 USGS models for Charleston, and on the slide in
12 the two columns, I've summarized the characteristics
13 of the USGS models for the Charleston earthquake
14 source, and at the bottom, in red, is the only
15 difference, which is description of the seismic source
16 zones they used for modeling the location of future
17 Charleston-like earthquakes.

18 In 2002, they used two alternative
19 geometries, a narrow zone along the Woodstock
20 lineaments and a broad areal zone which has limited
21 off-shore extent.

22 And in 2008, they again used the same two
23 weighted alternatives. A narrow zone along the
24 Woodstock, and then the off-shore broad zone with
25 extended off-shore to the Helena Banks.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And if you go to Slide 3, those two source zones
2 are shown side by side. On the left is 2002, on the
3 right is the 2008 model. And you can see on the right
4 model, where they've widened out the source zone to
5 encompass the Helena Banks.

6 But in terms of the extent of the source
7 zones to the southwest, towards the Levy site, they
8 both extend to the exact same place, which is the
9 northern edge of the St. Helena Sound.

10 So if we go to Slide 4, the conclusion is
11 that the only difference between the 2002 and 2008
12 USGS models is that the shape of the large zone, and
13 the difference of the shape does not affect the
14 distance to the Levy site from the USGS source zone.

15 There's a couple other points. The 2002
16 USGS model was reviewed as part of the development of
17 the, what is called the UCSS, or Updated Charleston
18 Seismic Source model, that was developed for the
19 Vogtle DFP, and that was used in the Levy PSHA
20 calculations to the FSAR.

21 The Vogtle UCSS, or Updated Charleston
22 Seismic Source model, allows for the potential for the
23 Charleston source to be closer to the Levy site than
24 the USGS model, and the next two slides illustrate
25 that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Slide 5, again, shows USGS 2002 source
2 zone, which is the black small rectangle is their
3 narrow zone, and then the blue larger shape is their
4 large source zone, and you can see off-shore to the
5 southeast, those red lines, which are the area of the
6 Helena Banks.

7 If we go to Slide 6, what you see are the
8 source geometries used in the Vogtle Updated
9 Charleston Seismic Source zone, and there, they have
10 four options.

11 And you can see that the two options, one
12 option that goes off-shore, which is shown by the
13 black rectangle, and then another option which is
14 along the shore, but it's the black hatched area,
15 those both extend further to the southwest towards the
16 Levy site.

17 And then the red rectangle encompasses the
18 peak to the southwest, the same as the USGS model.

19 So, again, in conclusion, the difference
20 between the 2002 and 2008 USGS models has no impact on
21 the hazard at the Levy site.

22 DR. HINZE: Bob, thanks very much. This
23 is Bill Hinze. Thanks very much for your review here,
24 and I think it's appropriate and important that you
25 point out that, even with including the Helena Banks

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in 2008 model, that the distribution of magnitudes did
2 not change, nor did the weighting of the two seismic
3 source zones in the Charleston area change.

4 So those are the critical items, and as
5 you point out, this does not change the hazard
6 evaluation at the Levy site. I agree.

7 CHAIRMAN RAY: All right, well, again,
8 that'll be part of the record of this sub-committee
9 meeting. While we have this gathering here, did you
10 want to talk further about bedrock topography?

11 DR. HINZE: Well, I would still like to
12 see bedrock topography, not -- but I think it would be
13 helpful to understand the basic underpinnings of the
14 site, and it may provide some insight into solutioning
15 zones, and I'd like to know where those paleochannels
16 are that are referred to as a cause of some of the
17 changes in the bedrock topography.

18 I realize that the coverage of the depth
19 of bedrock is not uniform, and therefore that
20 certainly complicates contouring, and may even suggest
21 that some areas can't be contoured.

22 But, there are areas where one should be
23 able to contour that data, in my view. And I think it
24 should be available.

25 CHAIRMAN RAY: Okay, now, everybody

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 understands, Dr. Hinze is a consultant to the ACRS.
2 This is just a sub-committee meeting so this is just
3 an issue that has been raised.

4 You can respond to it as you wish, but I
5 want you to be aware that it's something that, you
6 know, without some more input, we'll probably talk
7 about, and if there's something that you want to
8 offer, describe in response, why, this is a good time
9 to do it.

10 MR. KITCHEN: All right, thank you,
11 Chairman.

12 We had four items from yesterday. We just
13 talked about two. The bedrock topography was the
14 third.

15 CHAIRMAN RAY: I'm sorry. I thought --

16 MR. KITCHEN: And the fourth was the
17 uncertainty regarding the dissolution rate.

18 CHAIRMAN RAY: Right.

19 MR. KITCHEN: And we talked this over last
20 night, and we've presented what we feel, we hope
21 closes two of the items. The other two, we really
22 just need a little more time to put together something
23 that we would want to present to the committee.

24 CHAIRMAN RAY: All right.

25 MR. KITCHEN: And so, I guess, our option

1 there is a full committee, or possibly there's
2 something else. But we probably, they could prepare
3 it and go through the reviews that we would want to
4 do. We're looking at, at least, a couple weeks before
5 we'd be ready.

6 CHAIRMAN RAY: All right, well that's
7 understandable, and that's fine. And right now the
8 full committee meeting on December 15th is the thing
9 that we would --

10 MR. WANG: December 1st.

11 CHAIRMAN RAY: What?

12 MR. WANG: December 1st, the full
13 committee meeting.

14 CHAIRMAN RAY: December 1st. Why did I
15 say December 15th? December 15th doesn't make any
16 sense, obviously. Thank you, thank you Weidong.
17 December 1st, yes. I have another meeting on the
18 15th. It's Watts Bar 2 again. That's the problem.
19 Okay, anyway, December 1st.

20 So let's go ahead and have lunch and
21 that'll be, at least, one topic that we'll plan to
22 talk about. Now you said there was a fourth. Did you
23 want to touch on it now, or --

24 MR. KITCHEN: No sir. Both of those, the
25 uncertainty in the dissolution rate was the fourth --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RAY: Okay.

2 MR. KITCHEN: -- item, and we would --

3 CHAIRMAN RAY: All right.

4 MR. KITCHEN: -- need a little more time
5 on that, as well.

6 CHAIRMAN RAY: Okay, so both of those,
7 then, will be ones that we'll revisit. We'll do that
8 at 1 o'clock. We'll decide, try to lock down what
9 we're going to do at the full committee meeting, and
10 that'll be all, I think, that we'll need to talk
11 about.

12 Go around and find out what the members
13 want to add to the list, but for now, we'll recess to
14 1 o'clock.

15 MR. KITCHEN: Bob and Kathryn, thanks.

16 (Whereupon, the meeting in the foregoing
17 matter went off the record at 12:02 p.m.
18 and went back on the record at 12:59
19 p.m.)
20

A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N

12:59 p.m.

1
2
3 CHAIRMAN RAY: Okay, we're back to wrap up
4 here, now. The only chore I think we have now, is to
5 make sure we're aligned for what comes next. Brian,
6 did you want to say anything before I make a few
7 comments here.

8 MR. ANDERSON: I believe that we've
9 completed everything on the agenda, and just want to
10 make sure that the staff and applicant can support the
11 full committee meeting in December.

12 CHAIRMAN RAY: All right. It's very rare,
13 and undesirable from everybody's standpoint, for us to
14 see new information at a full committee meeting, as
15 I'm sure you're aware.

16 Therefore, the material that you, although
17 we also do this rarely, but I think it's the only
18 choice, under the circumstances, the material that you
19 would present to us that's outstanding, you mentioned
20 the two items earlier, and anything else.

21 But anything that we haven't seen, we
22 really should get in our hands and look at before the
23 full committee meeting, so we don't come in the full
24 committee meeting seeing this information for the
25 first time, and we can also give you any feedback that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 will help that meeting.

2 Now that won't put it on the record.
3 We'll still have to present it at the full committee
4 meeting, but if we've seen it, we can be more
5 confident that we'll be able to receive whatever
6 information it is you provide to us, without it
7 resulting in any unintended or unexpected
8 consequences. Is that okay with the applicant?

9 MR. KITCHEN: Yes, we'll send it to you
10 prior to the ACRS meeting for sure.

11 CHAIRMAN RAY: Yes. So that's what we'll
12 look for. Now, would you, I'll ask the applicant
13 again, to identify what, we will certainly do this in
14 response as well, but tell us what it is, then, that
15 you would expect to, want to be sure, from your
16 standpoint, is covered in the full committee meeting.

17 MR. KITCHEN: Well, we would think,
18 certainly, a brief overview of the sites, that there's
19 an understanding of the layout and site. Certainly,
20 geotech and foundation design.

21 The only other area that I wondered about,
22 just in light of Fukushima, and other concerns with
23 the emergency plan, if there's anything to present for
24 that.

25 CHAIRMAN RAY: Well, that's a fair

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 question. We're trying not to get ahead of the
2 commission as it wrestles with lessons learned from
3 Fukushima, insofar as it involves applicants such as
4 yourself.

5 Anybody on the sub-committee here have any
6 comment as to whether this application should address
7 any of the things that we currently recognize as what
8 -- we got, for example, the discussion of the spent
9 fuel pool cooling changes that the referenced COL is
10 making. That, probably, is something that's quite of
11 interest and pertinent and responsive and helpful.
12 Anything else?

13 MR. BROWN: I'm probably going to get a
14 question on extended SBO. I may or may not, I don't
15 know.

16 CHAIRMAN RAY: Well, but that's just a
17 sales pitch, when it comes to AP1000, isn't it?

18 MR. BROWN: I was just, all I'm saying is
19 it, we'll have the full meeting there, and liable to
20 hear that question, because it's been on the table.

21 CHAIRMAN RAY: Yes.

22 MR. BROWN: So the Fukushima issues,
23 that's all.

24 CHAIRMAN RAY: I forget, this is the COL
25 meeting, not a DCD meeting, so --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: That's why I think it
2 there's not much to talk about on those areas.

3 CHAIRMAN RAY: Yes, I think we ought to
4 stick with site-related items.

5 MEMBER BROWN: So I'm not going to bring
6 in --

7 MEMBER RYAN: I think we had a pretty
8 thorough discussion of seismic, you know, issues that
9 would relate to flooding or any kind of --

10 CHAIRMAN RAY: Well --

11 MEMBER RYAN: -- related events, so I think
12 we're caught up on that.

13 CHAIRMAN RAY: I do too, Mike. The
14 information that was presented this time, and from my
15 standpoint, particularly the 2008 USGS discussion --

16 MEMBER RYAN: Yes.

17 CHAIRMAN RAY: I don't think discounting
18 this 50-year-old hypothesis about faulting is
19 something you need to be concerned about.

20 It was something that we needed to do, but
21 we don't need to do it at the full committee. But on
22 the other hand, the full committee is somewhat aware,
23 because of Vogtle and Summer, of the USGS thing, and
24 the fact that you have gone ahead and presented to us
25 this information we received today is probably worth

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mentioning, that, even though the application was
2 submitted prior to the 2008 USGS, we've looked at it,
3 presented it to sub-committee, and demonstrated that
4 it didn't have any affect on discipline requirements.

5 As far as emergency planning is concerned,
6 I guess I would suggest that the fact that Crystal
7 River is located in proximity, is something that
8 someone might be interested in.

9 And it's not Fukushima, necessarily, but
10 certainly the relationship of the plant to Crystal
11 River and the fact that you've fully considered, in a
12 conservative manner, emergencies that could occur at
13 both sites, and looked at evacuation times with that
14 in mind.

15 Things like that, I think are worth
16 noting. Again, that's a site-related matter. Yes.

17 MEMBER BLEY: I think that the issue you
18 brought up somebody else will bring up, and that's the
19 use of salt water in your cooling towers, and that
20 your company has had experience with that, I think,
21 will surely come up.

22 CHAIRMAN RAY: Okay.

23 MEMBER BLEY: So it's probably worth, just

24 --

25 CHAIRMAN RAY: Yes. I mean, just, make it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 clear that you're confident that you -- Now, I think
2 it was mentioned, this is an environmental contention,
3 is it, that we don't get into, of course, but it is --

4 MR. KITCHEN: It is --

5 CHAIRMAN RAY: All right, so you need to
6 be cognizant of that, in terms of what you say to us.
7 Anything else from applicant? Any trial balloons you
8 want to float here?

9 MR. KITCHEN: Well, I don't know if
10 there's anything particularly, for the full committee.
11 I believe the hydrology that I feel is pretty solid.
12 I'm not sure there was anything, really, of interest,
13 there for the full committee. I --

14 CHAIRMAN RAY: Well, I think the unique
15 foundation design and the fact that you're located in
16 a place that calls for something like that, and it, at
17 least, seems to me as if you've addressed it in a very
18 robust way.

19 Those are things that are responsive to
20 the natural concerns that people would have. This
21 thing is almost a floating vessel in this environment
22 that it's in, and I'd like to say it seems to be very
23 robust with regard to the foundation design.

24 MR. ANDERSON: I'd feel, at least from my
25 perspective, that, you know, most of the rest of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 FSAR is pretty much standard, or reference to the DCD,
2 and --

3 CHAIRMAN RAY: Yes, and I would urge, that
4 is almost as simple as you put it, is that because
5 we've done Vogtle and Summer, the only thing that we
6 should be talking about, I think, are differences or
7 uniquenesses.

8 But taking time with recitals one by one
9 by one, that don't really add anything to the
10 information is not something, we have to do it here,
11 but we shouldn't do it in the full committee. Okay,
12 same questions of staff.

13 MR. ANDERSON: I don't think the staff
14 would have any new or different topics from what's
15 been previously discussed. Our focus would be on the
16 site characteristics, seismic and geotechnical
17 engineering aspects, the unique foundation design.

18 And we think that the greenfield nature of
19 the site makes emergency planning an appropriate
20 topic, as well. So seismic, geotech and emergency
21 planning topics would be the focus of the staff's
22 presentation.

23 CHAIRMAN RAY: Okay, I think overall --

24 MEMBER RYAN: -- water source, hydrology.

25 CHAIRMAN RAY: What?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER RYAN: Because water source,
2 hydrology, that kind of stuff, is unique to a site.

3 CHAIRMAN RAY: Okay.

4 MEMBER REMPE: Would the stuff --
5 emergency planning, I didn't hear you explicitly say
6 the location of the technical support center, and
7 should that be mentioned?

8 MEMBER RYAN: Sure.

9 CHAIRMAN RAY: Well, I, yes, sure, we can
10 mention it. The fact that it is consistent with the
11 DCD, in other words, it's not like Vogtle or Summer in
12 which they're consolidating the tech support center
13 outside the power block, makes it almost an
14 informational item, because it's part of the design
15 certification that way.

16 MEMBER REMPE: Also, just as a counter
17 opinion, since the Commission hasn't decided what
18 they're going to do about the action items for
19 Fukushima, I'm not sure it's worth bringing it up.

20 CHAIRMAN RAY: Well, I wouldn't have --

21 MEMBER REMPE: It's up to people that are
22 wiser than me to make recommendations that --

23 CHAIRMAN RAY: Yes. I agree with you,
24 Joy. That's why I said we're still, we're trying not
25 to plow new ground in a --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER REMPE: Right. And I think all you
2 do is opening up, well I only reviewed some of the
3 things, and that's great, but someone's going to start
4 asking about the other things.

5 CHAIRMAN RAY: The only thing I suggested
6 was this increased spent fuel pool cooling capability
7 that the staff talked about today, or --

8 MEMBER REMPE: Yes.

9 MEMBER BLEY: And that's site specific.

10 CHAIRMAN RAY: What?

11 MEMBER BLEY: That is site specific, so
12 that's --

13 CHAIRMAN RAY: Well, no, but he was
14 talking about reference COLA, Vogtle, and of course,
15 these guys will follow that.

16 MEMBER BLEY: Okay.

17 CHAIRMAN RAY: We didn't focus too much on
18 status of staff's review completion, outstanding items
19 or anything. I'm not talking about confirmatory
20 action. I'm talking about open items.

21 We didn't focus on that during these two
22 days here. It was just part of the mix, but,
23 probably, we should have something that boils that
24 down into something more visible by that point in
25 time. Where do we stand, in terms of completing the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 review?

2 MR. ANDERSON: Okay, we can certainly
3 provide remarks to that effect. I can confirm for
4 you, right now, that there is no additional technical
5 review that the staff intends to perform for the Levy
6 County application.

7 CHAIRMAN RAY: All right.

8 MR. ANDERSON: All that remains is the
9 closure of confirmatory items, which, I think, as you
10 know, is administrative tracking to ensure that
11 information the staff has already reviewed does
12 actually appear in the final revision of the FSAR.

13 CHAIRMAN RAY: All right. So basically,
14 there are no --

15 MR. ANDERSON: That's correct.

16 CHAIRMAN RAY: -- open technical issues.

17 MR. ANDERSON: There are no open items.

18 CHAIRMAN RAY: Okay. Well, that's worth
19 saying.

20 MR. ANDERSON: Okay.

21 CHAIRMAN RAY: Okay, and the confirmatory
22 items are administrative and not anything we need to
23 take up the full committee's time on.

24 Well, you know, I'm going to make the point at
25 the full committee that this is the first chance we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have, really, to see the standardization applied at a
2 greenfield site, and it seems to have the effect that
3 was advertised for it, in terms of the review process.
4 I assume the staff would concur on that, and say
5 something similar. Correct?

6 MR. ANDERSON: The staff would say
7 something similar, yes.

8 CHAIRMAN RAY: Correct.

9 MR. ANDERSON: : We agree. The staff --

10 CHAIRMAN RAY: You agree. All right.

11 Well, that's the only thing I would say is, you know,
12 noteworthy, sort of, is this is their first
13 SCOLA/greenfield site, and no ESP, so it's different
14 in that sense than anything we've seen before.

15 But, anyway, it seems to have gone well,
16 and I'm sure that reflects the applicant's effort, as
17 well as a good site they appear to have selected, and
18 so on.

19 Okay, is there anything else that we need
20 to discuss in connection with this sub-committee
21 meeting, because this will be the only one held, as
22 far as we know, before the full committee meeting, and
23 we will look forward to getting a couple of items from
24 the applicant, so that when we go into the full
25 committee meeting, those of us on the sub-committee

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 will not have to say I've never seen this before.

2 MEMBER REMPE: It seems a couple of those
3 items are primarily things that Dr. Hinze should
4 review and, perhaps, give us comments on --

5 CHAIRMAN RAY: He will --

6 MEMBER REMPE: -- if possible.

7 CHAIRMAN RAY: And I should mention it, it
8 should come to us through the staff. The items that
9 the applicant are going to provide should be provided
10 to you as well as to us.

11 MS. MCGOVERN: If you provide them to us,
12 we will make sure that they get into the hearing file
13 appropriately --

14 CHAIRMAN RAY: Okay.

15 MS. MCGOVERN: -- and we will share them
16 with ACRS.

17 CHAIRMAN RAY: That's right. So, we're
18 not having any side dialog with the applicant here.
19 It's just a matter we need to get them and look at
20 them before the full committee meeting, so that we --
21 like you say, we're not saying, I don't know what that
22 is.

23 All right. Well, with that, I'm about
24 ready to adjourn this meeting. If anybody has
25 anything else they'd like to say, speak now.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. ANDERSON: Mr. Chairman, I have one
2 question, just in terms of the time on the agenda for
3 the full committee, do you have any insight as to, for
4 our planning purposes for presentations, how much time
5 would we spend in front of the full committee? What
6 should we plan and prepare for?

7 CHAIRMAN RAY: Shorter rather than longer
8 is my opinion, but that should be something to discuss
9 with the staff that does the full scheduling. I don't
10 know what else is on the full committee agenda.

11 MEMBER REMPE: The agenda has been issued.

12 CHAIRMAN RAY: But I don't feel like we
13 need a lot of time. Yes? What did you say Joy?

14 MEMBER REMPE: They sent a draft agenda to
15 us.

16 CHAIRMAN RAY: Oh, it's probably two
17 hours.

18 PARTICIPANT: Well, is it for December?

19 MEMBER REMPE: Yes. No, you're right, I'm
20 sorry. Yes, you're right.

21 CHAIRMAN RAY: December 1st, yes, I was
22 going to say, that's a long way away.

23 MEMBER REMPE: You're right.

24 CHAIRMAN RAY: In any event, no, I don't
25 feel compelled to say we need sufficient time. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 don't, assuming that there isn't a concern that arises
2 from either of these things that we haven't yet seen,
3 and if there is, we'll do what we can to make sure
4 it's given adequate attention at the full committee
5 meeting, because I certainly don't want to go over,
6 beyond that. I don't see any reason for that to
7 occur.

8 MEMBER BROWN: Wouldn't you expect this to
9 be a bit, no more than about a half of the middle,
10 first part of a day, something like one-and-a-half
11 hours or so? I mean that --

12 CHAIRMAN RAY: Well, that's why I said,
13 Charlie, that I think that --

14 MEMBER BROWN: I'm just saying, that's
15 roughly what we've seen on some --

16 CHAIRMAN RAY: Yes, that ought to be, yes.
17 As a -- no, I -- whether it's an hour-and-a-half, two
18 hours, one hour, it should be worked out with the guys
19 who schedule the full committee meeting.

20 MR. ANDERSON: Understand.

21 CHAIRMAN RAY: All right. Going, going --

22 (Whereupon, the meeting in the foregoing
23 matter was concluded at 1:15 p.m.)

24

25



United States Nuclear Regulatory Commission

Protecting People and the Environment

Presentation to the ACRS Subcommittee

Levy County Units 1 and 2 COL Application Review

NRC Action Items from October 18, 2011

- χ/Q values – margins to DCD values
- Groundwater – clarification of radionuclide activity at receptors

Levy Nuclear Plant

FSAR 2.0 – 2.3

Site Characteristics, Demography Nearby Facilities and Meteorology

Paul Snead
Supervisor – Environmental Services



FSAR 2.0 Site Characteristics

- DCD incorporated by reference
- Table 2.0-201 compares site-specific characteristics to the AP1000 required site parameters found in DCD Table 2-1
- All site-specific characteristics are bounded by AP1000 site parameters for LNP

FSAR 2.1 Geography and Demography

- DCD incorporated by reference
- COL information items addressed
 - ◆ COL 2.1-1 Geography and Demography
- Population Density in 2000 within 20 miles of LNP was 97 ppsm
- Population Density projected in 2020 within 20 miles of LNP is 146 ppsm

FSAR 2.2 Nearby Industrial Hazards

- DCD incorporated by reference
- COL information items addressed
 - ◆ COL 2.2-1 Identification of Site-Specific Potential Hazards
- Evaluated nearby industrial hazards in accordance with Standard Review Plan
- Sources of potential hazards within 5 miles:
 - ◆ Road transportation of explosive material
 - ◆ Failure of nearby natural gas pipeline
 - ◆ Toxic material release from water treatment plant
- No design basis events identified requiring mitigating actions

FSAR 2.3 Meteorology

- DCD incorporated by reference
- COL information items addressed
 - ◆ COL 2.3-1 Regional Climatology
 - ◆ COL 2.3-2 Local Meteorology
 - ◆ COL 2.3-3 Onsite Meteorological Measurement Program
 - ◆ COL 2.3-4 Short-Term Diffusion Estimates
 - ◆ COL 2.3-5 Long-Term Diffusion Estimates
- All AP1000 DCD site parameters are met

Major Items of Interest

- Onsite “calm wind” Observations
- Operating Basis Wind Speed Site Parameter
- Maximum LNP Site Characteristic Temperatures

Onsite “calm wind” Observations

- Site located ~8 miles inland
- Diurnal “sea-breeze” wind effects are consistently observed at the site using an onsite meteorological tower (2 years of data)
- Onsite meteorological tower meets all NRC guidance in RG 1.23 *Meteorological Monitoring Programs for Nuclear Power Plants*
- Calm winds were observed in our data that required further evaluation

Analysis of Two Years of Onsite Meteorological Data

- Most of the observed “calm” winds were actually light winds
- True calm winds exhibit erratic and meandering wind directions
- Observed winds had measurable directions
- Actual observations of true calm winds (i.e., near zero wind speed and variable wind direction) were rare and infrequent

Resolution of Light Wind Speeds in X/Q Modeling Analysis

- Standard PAVAN dispersion modeling approach is not designed for treatment of light winds
- PEF performed a detailed sector-by-sector assessment
 - ◆ Analysis was consistent with NRC guidance in RG 1.145 *Atmospheric Dispersion Models for Potential Accident Consequence Assessments at Nuclear Power Plants*
 - ◆ *Maximum possible* sector-dependent 2-hour X/Q's were substituted for PAVAN extrapolations in light wind cases

Resolution of Light Wind Speeds in X/Q Modeling Analysis (cont'd)

- Conclusion: Projected worst-case impacts of routine and accidental releases do not exceed AP1000 DCD criteria at or beyond the Exclusion Area Boundary (EAB)

Operating Basis Wind Speed Site Parameter

- DCD Operating Basis Wind Speed Site Parameter is 145 mph (3-sec gust)
- DCD procedures were followed to determine the 50- and 100-year recurrent LNP site characteristic wind speeds (including hurricanes).
 - ◆ 50-year: 120 mph
 - ◆ 100-year: 128 mph
- Conclusion: Maximum winds speeds in the LNP site region will not exceed the DCD Wind Speed Criteria

Maximum LNP Site Characteristic Temperatures

- Maximum Safety Temperature Criteria
 - ◆ 115⁰F dry bulb/86.1⁰F coincident wet-bulb
 - ◆ 86.1⁰F non-coincident wet-bulb
- Analysis based on long-term historical records from the region surrounding the LNP site
- Statistical regression analysis procedure was used to estimate 100-year recurrence temperatures for the site, based on historical temperature records

Maximum LNP Site Characteristic Temperatures (cont'd)

- No projected maximum site temperatures exceeded criteria
- Conclusion: Maximum ambient temperatures in the LNP site region are below the DCD Ambient Temperature Criteria



United States Nuclear Regulatory Commission

Protecting People and the Environment

Presentation to the ACRS Subcommittee

Levy County Units 1 and 2 COL Application

Section 2.0 – Site Characteristics

Sections 2.1/2.2 – Geography, Demography, & Nearby Facilities

Section 2.3 – Meteorology

October 18-19, 2011

Staff Review Team

- Technical Staff
 - Rao Tammara (Siting & Accident Consequences Branch)
 - Kevin Quinlan (Siting & Accident Consequences Branch)
- Project Manager
 - Brian Anderson

Site Characteristics

- **2.0 – Site Characteristics**
- FSAR Section 2.0 describes the characteristics and site-related design parameters of Levy County (LNP) Units 1 and 2.
- FSAR Table 2.0-201 provides a comparison of the LNP site characteristics and the AP1000 DCD site parameters.
- All LNP site characteristics have been found to be acceptable.
- The LNP site characteristics are bounded by the site parameters specified in the AP1000 DCD.

Geography and Demography

- **2.1 – Geography and Demography**
- DCD Incorporated By Reference
- Site specific information
 - Site Location
 - Exclusion Area Boundary (EAB)
 - Population Distribution, Projections
 - Population Center and Population Density
- Conclusions

Nearby Facilities

- **2.2.1 - 2.2.2 – Location and Description**
- DCD Incorporated By Reference
- Site specific information
 - Nearby Industrial, Transportation, and Military Facilities
 - Pipelines
- Conclusions

Nearby Facilities

- **2.2.3 – Evaluation of Potential Accidents**
 - The evaluation of potential hazards to new units 1 and 2 due to potential accidents from nearby facilities, pipelines, and transportation routes.
 - The evaluation of potential toxic chemical releases from nearby facilities, transportation routes and onsite storage for the control room habitability of new units 1 and 2.
- **DCD Incorporated By Reference**
 - Onsite storage of AP1000 DC chemicals
- **Site Specific Evaluations**
 - Explosions
 - Gas pipelines
 - Aircraft hazards
 - Toxic chemicals (MCR habitability)
 - Fires
 - Collision with intake structures
 - Liquid spills
- **Conclusions**

Meteorology

- **2.3 – Meteorology**
- DCD Incorporated By Reference
- COL items and Supplemental Information
 - LNP COL 2.3-1 – Regional Climatology
 - LNP COL 2.3-2 – Local Meteorology
 - LNP COL 2.3-3 – Onsite Meteorological Measurements Program
 - LNP COL 2.3-4 – Short-Term Diffusion Estimates
 - LNP COL 2.3-5 – Long-Term Diffusion Estimates
 - LNP SUP 2.0-1 – Comparison of Site Parameters Versus Site Characteristics

Meteorology

- **Technical Topics of Interest**
 - **2.3.1 Regional Climatology**
 - All LNP site characteristic values presented in FSAR Section 2.3.1 have been found to be acceptable
 - 50-year/100-year Wind Speed (3-second gust)
 - Maximum Tornado Wind Speed
 - Maximum Roof Load (Winter Precipitation)
 - Air Temperature and Humidity
 - **2.3.2 Local Meteorology**
 - Addressed cooling tower-induced effects on ambient temperature, moisture, and salt deposition
 - Provided detailed information showing that the LNP meteorological data are representative of the site area

Meteorology

- **Technical Topics of Interest**
 - **2.3.3 Onsite Meteorological Measurements Program**
 - COL applicant described the onsite meteorological measurements program and provided a copy of the resulting meteorological data
 - Applicant met RG 1.23, Revision 1 criteria for siting of the tower in relation to Units 1 & 2

Meteorology

- **Technical Topics of Interest**
 - **2.3.4 Short-Term (Accident) Diffusion Estimates**
 - All LNP site characteristic values presented in FSAR Section 2.3.4 have been found to be acceptable
 - EAB & LPZ χ/Q values
 - Control Room χ/Q values
 - **2.3.5 Long-Term (Routine) Diffusion Estimates**
 - All LNP site characteristic values presented in FSAR Section 2.3.5 have been found to be acceptable
 - COL FSAR 2.3-5 verified release points and receptor locations

Meteorology

- **Conclusion**

- All LNP site characteristics presented in FSAR Section 2.3 have been found to be acceptable and bounded by the corresponding AP1000 site parameters
- All regulatory requirements for Section 2.3 have been satisfied
- No open items
- No exemptions or departures
- Seven confirmatory items

Levy Nuclear Plant Units 1 and 2

FSAR Chapter 8, 9 and 10

Electrical Power, Auxiliary Systems and Power Conversion

Jeremy Baksh – Senior Engineer

Mike Franklin – Supervisor Site Engineering




Chapter 8 – Electrical Power

- DCD incorporated by reference
- Standard material incorporated (including standard departure)
- Site specific off-site power description


Section 8.2 – Offsite Power

- Four planned 500kV transmission lines will connect the Levy switchyard to the Progress Energy Florida (PEF) transmission system. (COL 8.2-1)
- Upgrades to existing PEF facilities (COL 8.2-1)
- Failure Modes and Effects Analysis performed (SUP 8.2-1)
- Grid stability study performed (SUP 8.2-3)
 - ◆ Includes Westinghouse interface requirement for maintaining Reactor Coolant Pump voltage for three seconds after a turbine trip

Levy Switchyard



Switchyard Single-Line Diagram



Levy Switchyard FMEA

- Failure Modes and Effects Analysis (FMEA) for the switchyard confirms that no single initiating event results in the failure of more than one off-site transmission line or a loss of off-site power to either LNP 1 or LNP 2

Chapter 9 – Auxiliary Systems

- DCD incorporated by reference
- Standard material incorporated (including standard departure)
- Site-specific Raw Water System

Chapter 9 – Auxiliary Systems

Raw Water System (RWS)

- Site Specific – Saltwater and Freshwater Separate Subsystems
- Saltwater Subsystem provides makeup to:
 - Circulating Water System Mechanical Draft Cooling Tower Basins
- Freshwater Subsystem provides makeup to:
 - Service Water System Cooling Tower Basins
 - Fire Protection System Fire Water Storage Tanks
 - Potable Water Storage Tank
 - Demineralized Water Treatment System

Chapter 9 – Auxiliary Systems

Raw Water System (RWS) - Continued

- Neither Raw Water Subsystem serves a safety related function
- The RWS does not have an interconnection with any system that contains radioactive fluids
- Flooding from RWS is bounded by Circulating Water System failure analysis (DCD 3.4.1.2.2.3)

Chapter 10 – Steam and Power Conversion

- DCD incorporated by reference
- Standard material incorporated (including standard departure)
- Site-specific Cooling Towers and Circulating Water System blowdown


Chapter 10 – Steam and Power Conversion

CWS Cooling Tower:

- Mechanical Draft Linear Towers
- Tower collapse does not affect safety related SSC's
- Failure of tower could rupture RWS, CWS, CWS-Blowdown
 - A rupture of any system does not result in flooding of safety related SSC's.

Chapter 10 – Steam and Power Conversion

Levy CWS Blowdown



**Levy Nuclear Plant
FSAR 6, 11 & 12
Engineered Safety Systems
Radioactive Waste
Radiation Protection**

**Bob Kitchen - Manager
NGPP Licensing**



FSAR CHAPTER 6

Engineered Safety Systems

- DCD Incorporated by reference
- Standard Material Incorporated
- FSAR 2.2.3 discusses offsite hazardous materials
- Onsite - DCD standard chemicals

Chapter 11

Radioactive Waste Management

- DCD Incorporated by Reference
- Standard material incorporated
- Site-specific information of interest
 - ◆ Liquid Radwaste System (WLS) and Waste Water System (WWS)
 - ◆ Gaseous Waste Management
 - ◆ Effluent Monitoring
 - ◆ Long-term Onsite Storage

Section 11.2 and 11.3

Liquid & Gaseous Waste Management

- LADTAP code utilized for liquid waste to determine estimated dose and dose rates
- GASPAR computer code used for gaseous waste to calculate dose and dose rates
- Doses to individuals due to liquid & gaseous waste discharges are within the limits of 10 CFR Part 50 Appendix I
- Based on estimated population doses cost benefit analyses were performed and no augments were determined to be cost beneficial

Section 11.4 - Solid Waste Management

11.4.6.3 Long Term On-Site Storage Facility

- Contingent storage plan - Identical to Vogtle
- An outside storage pad will be located on-site
- Storage would be in high integrity containers (HICs) or other suitable containers.
 - ◆ Will not degrade over time
 - ◆ Stored within shielded containers
- Operational considerations also addressed
 - ◆ Discharge during outages
 - ◆ Actions to minimize

Chapter 12

Radiation Protection

- DCD Incorporated by Reference
- Standard material incorporated
- Site –specific evaluations of dose to construction workers
 - ◆ Significantly below the 10CFR20.1301 public dose limit



United States Nuclear Regulatory Commission

Protecting People and the Environment

Presentation to the ACRS Subcommittee

**Levy Nuclear Plant Units 1 and 2
COL Application Review**

ASE Chapter 8 – Electric Power

ASE Chapter 9 – Auxiliary Systems

ASE Chapter 10 – Steam and Power Conversion Systems

October 18 - 19, 2011

Staff Review Team

- Technical Staff
 - Om Chopra (Electrical Engineering Branch)
 - Larry Wheeler (Balance of Plant Branch)
- Project Management
 - Brian Anderson, Lead PM

Levy County FSAR Chapter 8

Electric Power

FSAR Section	Site-Specific Evaluations
8.1 Introduction	<ul style="list-style-type: none"> • LNP SUP 8.1-1 Description of the Utility Grid • LNP SUP 8.1.2 Levy Units 1 and 2 connection to the utility grid • LNP SUP 8.1-3 Additional information on regulatory guidelines and standards
8.2 Offsite Power System	<ul style="list-style-type: none"> • LNP COL 8.2-1 Transmission system description, and its testing and inspection plan • LNP COL 8.2-2 Transmission system requirements and studies • LNP SUP 8.2-1 FMEA of the switchyard • LNP SUP 8.2-2 Transmission system Protective relaying • LNP SUP 8.2-4 Transmission system planning • LNP SUP 8.2-3 Stability and reliability of the offsite transmission power system • Interface Requirements
8.3.1 AC Power Systems (Onsite)	<ul style="list-style-type: none"> • LNP COL 8.3-1 Grounding system and lightning protection • LNP SUP 8.3-1 Site-specific switchyard and power transformer voltage • LNP SUP 8.3-2 EDG rating based on site conditions
8.3.2 DC Power Systems (Onsite)	<ul style="list-style-type: none"> • STD DEP 8.3-1* Class 1E voltage regulating transformer periodic testing

* This section is entirely IBR or IBR/Standard

Staff Review Summary

- **Section 8.1 – Introduction**

- Applicant has adequately addressed LNP SUP 8.1-1 regarding Levy County Units 1 and 2 connection to the Progress Energy Florida Transmission system
- The applicant has adequately described the connection of auxiliary and startup transformers to the switchyards
- The applicant has adequately addressed LNP SUP 8.1-3 regarding additional information for regulatory guidelines and standards

Staff Review Summary

- **Section 8.2 – Offsite Power System**
 - The staff finds COL information items LNP COL 8.2-1 involving the design details of the plant site switchyard and its interface with the local transmission grid adequately addressed
 - The staff concludes that the applicant's condition monitoring program for underground or inaccessible cables satisfies the recommendations of GL 2007-01, and the guidance in NUREG/CR-7000 and NUREG-0800

Staff Review Summary

- **Section 8.2 – Offsite Power System**

- The applicant has adequately addressed LNP SUP 8.2-1 thru 8.2-4 involving the offsite power system adequacy and availability, testing and inspection of switchyard components and failure modes and effects analysis
- The applicant provided sufficient information regarding the interfaces for standard design from the generic AP1000 DCD, Table 1.8-1, Items 8.1, 8.2, and 8.3

Staff Review Summary

- **Section 8.3.1 – AC Power System (Onsite)**
 - The applicant has adequately addressed LNP SUP 8.3-1 involving the site-specific switchyard and transformer voltage
 - The applicant has adequately addressed LNP COL 8.3-1 related to the grounding grid system design and lightning protection

Staff Review Summary

- **Section 8.3.2 – DC System (Onsite)**
 - The applicant has adequately addressed STD DEP 8.3-1 related to periodic testing of voltage regulating transformers pending closure of Confirmatory Item 8.3.2-1.

Levy County FSAR Chapter 9

Auxiliary Systems

FSAR Section	Site-Specific Evaluations
9.1.1 New Fuel Storage	<ul style="list-style-type: none"> • None*
9.1.2 Spent Fuel Storage	<ul style="list-style-type: none"> • None*
9.1.3 Spent Fuel Pool Cooling System	<ul style="list-style-type: none"> • None*
9.1.4 Light Load Handling System	<ul style="list-style-type: none"> • None*
9.1.5 Overhead Heavy Load Handling Systems	<ul style="list-style-type: none"> • None*
9.2.1 Service Water System	<ul style="list-style-type: none"> • LNP COL 9.2-2 provides additional information regarding the service water system cooling tower potential interactions
9.2.2 Component Cooling Water System	<ul style="list-style-type: none"> • None*
9.2.3 Demineralized Water Treatment System	<ul style="list-style-type: none"> • None*
9.2.4 Demineralized Water Transfer and Storage System	<ul style="list-style-type: none"> • None*

* This section is entirely IBR or IBR/Standard

Levy County FSAR Chapter 9

Auxiliary Systems

FSAR Section	Site-Specific Evaluations
9.2.5 Potable Water System	<ul style="list-style-type: none"> • LNP COL 9.2-1, Potable water system description outside the power block
9.2.6 Sanitary Drains	<ul style="list-style-type: none"> • LNP SUP 9.2-1, Sanitary waste system discharge description
9.2.7 Central Chilled Water System	<ul style="list-style-type: none"> • None*
9.2.8 Turbine Building Closed Cooling Water System (TCS)	<ul style="list-style-type: none"> • LNP CDI provides the source of cooling water for the TCS heat exchangers
9.2.9 Waste Water System	<ul style="list-style-type: none"> • LNP COL 9.2-2 provides information on the waste water settling basin and associated discharge flowpath
9.2.10 Hot Water Heating System	<ul style="list-style-type: none"> • None*
9.2.11 Raw Water System	<ul style="list-style-type: none"> • LNP SUP 9.2-2 provides site-specific information related to the raw water system

* This section is entirely IBR or IBR/Standard

Levy County FSAR Chapter 9

Auxiliary Systems

FSAR Section	Site-Specific Evaluations
9.3.1 Compressed and Instrument Air System	• None*
9.3.2 Plant Gas System	• None*
9.3.3 Primary Sampling System	• None*
9.3.4 Secondary Sampling System	• None*
9.3.5 Equipment and Floor Drainage Systems	• None*
9.3.6 Chemical and Volume Control System	• None*
9.4.1 Nuclear Island Nonradioactive Ventilation System	• LNP COL 9.4-1b provides local toxic gas evaluations
9.4.2 Annex/Auxiliary Buildings Nonradioactive HVAC System	• None*
9.4.6 Containment Recirculation Cooling System	• None*
9.4.7 Containment Air Filtration System	• None*

* This section is entirely IBR or IBR/Standard

Levy County FSAR Chapter 9

Auxiliary Systems

FSAR Section	Site-Specific Evaluations
9.4.8 Radwaste Building HVAC System	<ul style="list-style-type: none"> • None*
9.4.9 Turbine Building Ventilation System	<ul style="list-style-type: none"> • None*
9.4.10 Diesel Generator Building Heating and Ventilation System	<ul style="list-style-type: none"> • None*
9.4.11 Health Physics and Hot Machine Shop HVAC System	<ul style="list-style-type: none"> • None*
9.5.1 Fire Protection System	<ul style="list-style-type: none"> • LNP COL 9.5-1, qualification requirements for the fire protection program • LNP COL 9.5-2, site-specific hazards analysis of the yard areas and outlying buildings
9.5.2 Communication System	<ul style="list-style-type: none"> • LNP COL 9.5-9, offsite interfaces • LNP COL 9.5-10, emergency offsite communications • LNP COL 9.5-11, security communications
9.5.3 – 9.5.8	<ul style="list-style-type: none"> • None*

* This section is entirely IBR or IBR/Standard

Levy County FSAR Chapter 10

Steam and Power Conversion

FSAR Section	Site-Specific Evaluations
10.1 Summary Description	<ul style="list-style-type: none"> • None*
10.2 Turbine Generator	<ul style="list-style-type: none"> • None*
10.3 Main Steam Supply System	<ul style="list-style-type: none"> • None*
10.4 Other Features of Steam and Power Conversion System	<ul style="list-style-type: none"> • LNP CDI, relating to COL Section 10.4.2 for the site specific cooling water source for the vacuum pump seal water heat exchangers. • LNP CDI, relating COL Section 10.4.5 for the site specific Circulating Water System design information. • LNP COL 10.4-1, relating to the Circulating Water System design parameters. • LNP COL 10.4-2 and 10.4-3, relating to Condensate, Feedwater and Auxiliary Steam System Chemistry Control

* This section is entirely IBR or IBR/Standard

RWS Description

- **RWS is non-safety and non-RTNSS**
- **RWS consists of two subsystems:**
 - Freshwater subsystem pumps from ground wells
 - Makeup to SWS cooling towers
 - Demineralizer water treatment system
 - Potable Water System
 - Fire protection
 - Saltwater subsystem supplies from the Cross Florida Barge Canal
 - Makeup to CWS mechanical draft cooling tower basins

RWS Description

- **Freshwater subsystem (each unit)**
 - 2 – 100% capacity well pumps
 - 4 – 50% capacity booster pumps
 - Automatic strainer and media filters
 - ~150,000 gal storage tank (~30' diameter x 30' tall)
 - Standby diesel generator supports (manually loaded)
 - Raw water well pumps
 - Raw water booster pumps
 - Discharge valves
 - HDPE underground piping materials

RWS Description

- **HDPE underground piping material**



RWS Description

- **Saltwater subsystem (each unit)**
 - 3 – 50% capacity makeup pumps
 - Traveling screens
 - 3 screen wash pumps
 - Automatic strainers

Staff Review Summary

- RWS is nonsafety-related, non seismic, freshwater subsystem supports RTNSS function for Modes 5 and 6
- Freshwater subsystem has redundancy, a ~150,000 gallon storage tank, pumps and discharge valves are diesel backed
- Freshwater subsystem pumps well exceed the SWS basin makeup requirements
 - Freshwater well pumps ~ (2) at 1,040 gpm
 - Freshwater boosters pumps ~ (4) at 500 gpm
- Reliable materials are being utilized consistent with industry good practices and applicable codes and standards
- RWS is non radioactive and contamination is not feasible due to its configuration relative to potential sources of contamination

Staff Review Summary

- **GDC 2 and GDC 4 have been satisfied**
 - Failure of the RWS/components will not affect the ability of any risk-significant systems to perform their intended safety functions
 - Failure of the RWS/components will not affect any RTNSS considerations
- **Staff concludes that RWS:**
 - Meets all applicable regulations
 - Considered highly reliable to support CSD



United States Nuclear Regulatory Commission

Protecting People and the Environment

Presentation to the ACRS Subcommittee

Levy Nuclear Plant Units 1 and 2

COL Application Review

ASE Chapter 6 – Engineered Safety Features

ASE Chapter 11 – Radioactive Waste Management

ASE Chapter 12 – Radioactive Protection

October 18 - 19, 2011

Levy County FSAR Chapter 6

Engineered Safety Features

FSAR Section	Site-Specific Evaluations
6.1.1 Engineered Safety Materials Features, Metallic Materials	<ul style="list-style-type: none"> • None *
6.1.2 Engineered Safety Materials Features, Organic Materials	<ul style="list-style-type: none"> • None *
6.2 Containment Systems	<ul style="list-style-type: none"> • None *
6.3 Passive Core Cooling System	<ul style="list-style-type: none"> • None *
6.4 Habitability Systems	<ul style="list-style-type: none"> • LNP SUP 6.4-1, states that the site does not plan to use any gas dispersants • LNP COL 6.4-1, related to toxic chemical habitability
6.5 Fission Product Removal and Control Systems	<ul style="list-style-type: none"> • None *
6.6 Inservice Inspection of Class 2, 3, and MC Components	<ul style="list-style-type: none"> • None *

* This section is entirely IBR or IBR/Standard

Levy County FSAR Chapter 11

Radioactive Waste Management

FSAR Section	Site-Specific Evaluations
11.1 Source Term	<ul style="list-style-type: none"> • None*
11.2 Liquid Radioactive Waste Management	<ul style="list-style-type: none"> • LNP COL 11.2-2, Liquid waste discharge cost-benefit analysis • LNP COL 2.4-5 and LNP 15.7-1, Doses from accidental release from liquid waste tank failure • LNP COL 11.5-3, Compliance with 10 CFR Part 50, Appendix I, Sections II.A for liquid waste discharges • LNP SUP 11.2-1, Liquid waste discharge pipe
11.3 Gaseous Radioactive Waste Management	<ul style="list-style-type: none"> • LNP COL 11.3-1, Gaseous waste discharge cost-benefit analysis • LNP COL 11.5-3, Compliance with 10 CFR Part 50, Appendix I, Section II.B and II.C for gaseous waste discharges
11.4 Solid Radioactive Waste Management	<ul style="list-style-type: none"> • LN P COL 11.4-1 and Proposed LNP COL 11.4-2, Alternatives for B and C waste • LNP SUP 11.4-1, Long term onsite storage facilities for low-level waste
11.5 Radiation Monitoring	<ul style="list-style-type: none"> • LNP COL 11.5-2, QA for effluent and environmental monitoring program

* This section is entirely IBR or IBR/Standard

Levy County FSAR Chapter 12

Radiation Protection

FSAR Section	Site-Specific Evaluations
12.1 Assuring ALARA	<ul style="list-style-type: none">• None*
12.2 Radiation Sources	<ul style="list-style-type: none">• None*
12.3 Radiation Protection Design Features	<ul style="list-style-type: none">• LNP SUP 11.2-1, Liquid waste discharge pipe
12.4 Dose Assessment	<ul style="list-style-type: none">• LNP SUP 12.4-1, Construction worker dose
12.5 Health Physics Facility Design	<ul style="list-style-type: none">• None*

* This section is entirely IBR or IBR/Standard

Levy Units 1 and 2

FSAR Section 13.3

Emergency Planning

Larry Taylor

Progress Energy – Emergency Preparedness



Levy Nuclear Plant

Emergency Plan Design

- Single Emergency Plan for two Levy Nuclear Plant units on a green field site.
- Developed in accordance with:
 - NUREG-0654/FEMA-REP-1 Rev 1
 - 10 CFR 50.47
 - 10 CFR 50 Appendix E

Levy Nuclear Plant

On-site Emergency Facilities

- Technical Support Center (TSC)
 - The Levy Unit 1 and Unit 2 TSCs will be in the control support area (CSA) in the Annex Building, which is adjacent to the main control room area.
- Operations Support Center (OSC)
 - The Levy Nuclear Plant OSC is located inside the Protected Area on the second floor of the Annex Building of each unit, adjacent to the control room.
- These are AP1000 Design Control Document (DCD) designated locations.

Levy Nuclear Plant

Emergency Operations Facility (EOF)

- A single EOF location is intended to be used for both the Levy Nuclear Plant (LNP) and Crystal River Nuclear Plant (CRNP).
- The Emergency Operations Facility will be established consistent with NUREG-0696 guidelines.

Levy Nuclear Plant

Off-site Utility Emergency Response


- In the event of a simultaneous emergency at both LNP and CRNP, personnel assigned to each site's EOF Emergency Response Organization (ERO) will respond to the EOF.
- One of the site's EOF Facility leads (EOF Director) will be assigned to be a single point of contact to interface with State, County, and Federal agencies.

Levy Nuclear Plant

Overlapping EPZs with CRNP

- LNP is located approximately 9 miles northeast of the existing CRNP.
- Simultaneous evacuation of the EPZs for both LNP and CRNP are addressed in the LNP Evacuation Time Estimate (ETE).
- Emergency Planning Zones (EPZs) for CRNP and LNP overlap.

Levy and Crystal River EPZs





**Levy County COL
ACRS Subcommittee Meeting
Staff Presentation**

Section 13.3 - Emergency Planning

October 19, 2011

- Technical Staff (New Reactor Licensing Branch, NSIR)
 - Tony Bowers, Emergency Preparedness Specialist

- Project Manager
 - David Misenhimer

Emergency Planning

- Regulations and Guidance
- Open Items/Confirmatory Items/Post COL Activities
- Emergency Planning Zones
- Emergency Response Facilities
- Conclusions


Emergency Planning

- Regulations
 - 10 CFR 50.47(a)(1)(ii) – Reasonable assurance finding
 - 10 CFR 50.47(a)(2) – FEMA offsite finding, NRC onsite finding
 - 10 CFR 50.47(b) – 16 Planning Standards
 - Appendix E to 10 CFR Part 50
 - 10 CFR 50.33(g) – State and local emergency plans and EPZ
- Guidance
 - Regulatory Guide 1.101 - EP
 - NUREG-0654 / FEMA-REP-1 (Rev 1) – Criteria for 16 planning standards
 - NUREG-0396 / EPA 520/1-78-016 – Planning Basis
 - NUREG-0800 SRP – Section 13.3 EP

Emergency Planning

- No Open Items
- Approximately 30 Confirmatory Action Items
- Post-COL Activities
 - EP ITAAC
 - EP Implementation Milestones (i.e., schedule for submittal of Emergency Plan Implementing Procedures)
 - Emergency Action Levels (NEI 07-01)
 - Finalized Letters of Agreement
 - Exercise to demonstrate response capabilities in the event of emergency at LNP and CR3
 - Initial distribution of emergency information to the public

Emergency Planning Zones



Emergency Response Facilities

- Technical Support Center
 - No Departure from AP1000 DCD
- Operational Support Center
 - No Departure from AP1000 DCD
- Emergency Operations Facility
 - Existing facility approved for use by CR3
 - Proposed shared facility between LNP and CR3

Emergency Planning

- Conclusions
 - Reasonable assurance exists for the offsite plans
 - LNP COL application includes post-COL activities, including EP ITAAC that are necessary and sufficient to provide reasonable assurance for onsite plans
 - With the additional information and proposed textual revisions provided in response to the staff's requests for additional information, the NRC staff finds that the applicant addressed the required information relating to EP

**Levy Nuclear Plant
FSAR 13, 14, 16 & 18
Conduct of Operations
Initial Test Program
Tech Specs
Human Factors**

**Bob Kitchen - Manager
NGPP Licensing**



Chapter 13 Excluding 13.3

Conduct of Operations

- DCD Incorporated by Reference
- Standard material incorporated
- Site-specific
 - ◆ Organizational Structure

Chapter 14

Initial Test Program

- DCD Incorporated by reference.
- Standard Material Incorporated
- Site specific ITAAC identified
 - ◆ Emergency Plan and Security
 - ◆ Structures, systems and components
 - ◆ Non-system based design

Section 14.3

Certified Design Material

- Site Specific System Based ITAAC added per STD SUP 14.3-1
 - Transmission Switchyard and Offsite Power System
- Non-system Based Site-specific ITAAC
 - ◆ Roller Compacted Concrete Bridging Mat
 - ◆ Waterproof Membrane
 - ◆ Drilled shafts for Turbine Building, Radwaste Building and Annex Building

Chapter 16

Technical Specifications

- 16.1 – Technical Specifications
 - ◆ DCD Incorporated by Reference
 - ◆ Integrated Generic and Plant-Specific Technical Specifications and Bases provided in COLA, Part 4
- 16.2 Design Reliability Assurance Program (DRAP)
 - ◆ DCD Incorporated by Reference
- 16.3 Investment Protection
 - ◆ DCD Incorporated by Reference
 - ◆ Standard material incorporated
- Part 4 of the LNP COLA reflects the LNP Technical Specifications
 - ◆ Standard and site specific material incorporated

Levy Chapter 18

Human Factors

- DCD Included by Reference
- Standard material incorporated



United States Nuclear Regulatory Commission

Protecting People and the Environment

Presentation to the ACRS Subcommittee

Levy Nuclear Plant Units 1 and 2

COL Application Review

ASE Chapter 13 – Conduct of Operations

ASE Chapter 14 – Initial Test Programs

ASE Chapter 16 – Technical Specifications

ASE Chapter 18 – Steam and Power Conversion System

October 18 - 19, 2011

Levy County FSAR Chapter 13

Conduct of Operations

FSAR Section	Site-Specific Evaluations
13.1 Organizational Structure of Applicant	<ul style="list-style-type: none"> • LNP COL 13.1-1, Organizational Structure • LNP COL 9.5-1, Fire Protection • LNP COL 18.6-1, Qualifications of the nuclear plant technical support personnel • LNP COL 18.10-1, Responsibilities of the manager in charge of nuclear training
13.2 Training	<ul style="list-style-type: none"> • None*
13.3 Emergency Planning	<ul style="list-style-type: none"> • Presented (10/19/11)
13.4 Operational Programs	<ul style="list-style-type: none"> • None*
13.5 Plant Procedures	<ul style="list-style-type: none"> • LNP COL 13.5-1, Position Titles
13.7 Fitness for Duty	<ul style="list-style-type: none"> • None*
13.8 Cyber Security	<ul style="list-style-type: none"> • None*

* This section is entirely IBR or IBR/Standard

Levy County FSAR Chapter 16

Technical Specifications

FSAR Section	Site-Specific Evaluations
16.1 Technical Specifications	<ul style="list-style-type: none">• LNP COL 16.1-1 related to technical specifications for use as a guide in development of the plant-specific technical specifications.
16.2 Design Reliability Assurance Program	<ul style="list-style-type: none">• None*
16.3 Investment Protection	<ul style="list-style-type: none">• None*

* This section is entirely IBR or IBR/Standard

Levy County FSAR Chapter 14

Initial Test Program

FSAR Section	Site-Specific Evaluations
14.1 Specific Information To Be Included In Preliminary/Final Safety Analysis Reports	<ul style="list-style-type: none"> • None*
14.2 Specific Information To Be Included In Standard Safety Analysis Reports	<ul style="list-style-type: none"> • None*
14.3 Certified Design Material	<ul style="list-style-type: none"> • LNP SUP 14.3-2 ITAAC Screening Summary for Additional Site-Specific Systems • LNP SUP 14.3-3 Roller Compacted Concrete Bridging Mat ITAAC • LNP SUP 2.5-17 Waterproof Membrane ITAAC

*This section is entirely IBR or IBR/Standard

Levy County FSAR Chapter 18

Human Factors Engineering

FSAR Section	Site-Specific Evaluations
18.1 Overview	<ul style="list-style-type: none">• None*
18.2 HFE Program Management	<ul style="list-style-type: none">• LNP COL 18.2-2, Location of the Emergency Operations Facility
18.3–18.7	<ul style="list-style-type: none">• None*
18.8 Human-System Interface Design	<ul style="list-style-type: none">• None*
18.9–18.14	<ul style="list-style-type: none">• None*

* This section is entirely IBR or IBR/Standard

Response to Queries Related to Vernon Faults

K. L. Hanson (AMEC Geomatrix)

October 19, 2011

Vernon (1951) Postulated Faults

- FSAR Sections 2.5.1.1.4.3.4 and 2.5.1.2.4
 - Vernon (1951) inferred faults to be steeply-dipping, normal dip-slip shear faults bounding graben depressions and horst ridges associated with the Ocala “Uplift” (inferred to be tectonic structure)
 - No direct observations regarding dip or downdip extent. Steep dip inferred from linear trace of topographic and vegetation lineaments used to map the faults.
 - Vertical displacements on individual faults range from 6 m (20 ft.) to 49 m (160 ft.)
 - Vernon cited field evidence including apparent displacements inferred from widely-spaced outcrop and subsurface data from boreholes and wells, and limited field observations due to the minimal exposures along the fault traces.

Vernon Postulated Faults (cont.)

- LNP FSAR Observations:
 - Ocala “Uplift” is not a true uplift (tectonic uplift)
 - Florida Geological Survey (FGS) refers to it as the Ocala platform
 - Pre- Middle Eocene units are not warped or deformed.
 - Apparent deformation of younger units are currently interpreted to be due to sedimentologic processes or differential compaction of Middle Eocene units.
 - Vernon faults parallel and are not distinct from other regional lineaments (joint) sets that are observed throughout the site region
 - The postulated faults identified by Vernon in the site vicinity are not apparent in regional scale Landsat imagery or in more detailed aerial photograph mosaics (1949 black and white, 1:20,000 scale) that cover the site vicinity and area, respectively.

Vernon Postulated Faults (cont.)

- LNP FSAR Observations (cont.):
 - Recent geologic maps and structure contour maps on Tertiary subsurface units (e.g., Arthur et al., 2008) do not show evidence for faulting.
 - FGS concluded that many features observed in quarries inferred to be evidence for surface faulting were karst-related deformation features.
 - FGS also noted that many of the Vernon faults were inferred based on apparent offsets in the top of the Ocala Formation, a karstified unconformable surface that may have as much as 50 m (164 ft.) or more of relief.

Vernon Postulated Faults

- LNP COLA conclusion:
 - The postulated faults identified by Vernon likely do not exist, and there is no evidence to suggest that they have been active in the Quaternary. Therefore, none of these postulated faults are considered to be capable tectonic sources, as defined in Regulatory Guide 1.208, Appendix C.
 - Specific features or targets in the Site Area that would warrant additional investigation (e.g., subsurface geophysical surveys or drilling) were not identified.

Levy Nuclear Plant FSAR Section 2.5.2 Comparison of USGS 2002 and 2008 Seismic Source Models for Charleston

Dr. Robert Youngs
AMEC Geomatrix



Only One Difference between 2002 and 2008 USGS Models

USGS 2002 Model


- 550 year mean repeat time of earthquakes
- Maximum magnitude distribution 6.8 [0.2], 7.1 [0.2], 7.3 [0.45], 7.5 [0.15]
- Two equally weighted alternative seismic source geometries
 - ◆ Narrow areal zone along Woodstock lineament
 - ◆ **Broad areal zone with limited offshore extent**

USGS 2008 Model

- 550 year mean repeat time of earthquakes
- Maximum magnitude distribution 6.8 [0.2], 7.1 [0.2], 7.3 [0.45], 7.5 [0.15]
- Two equally weighted alternative seismic source geometries
 - ◆ Narrow areal zone along Woodstock lineament
 - ◆ **Broad areal zone extending offshore to the Helena Banks faults**


Source Zone Difference between 2002 and 2008 USGS Models

2002



To Levy Site

2008




To Levy Site

Conclusion

- Only difference between 2002 and 2008 USGS models is shape of large source zone
- Difference in shape does not affect distance to Levy Site
- 2002 USGS model was reviewed as part of the development of the UCSS model developed for Vogtle ESP and used in Levy PSHA
- Vogtle UCSS model allows for Charleston source to be closer to the Levy site than the USGS model

USGS 2002 Source Zone



Vogtle UCSS Source Zone

