



RADIOCAT®

Centers For
The Treatment
of Feline
Hyperthyroidism

4015 E. Cactus Rd.
Phoenix, AZ 85032

5610 Kearny Mesa Rd.
San Diego, CA 92111

251 N. Amphlett Blvd.
San Mateo, CA 94401

730 Randolph Rd.
Middletown, CT 06457

1212 E. Newport Pike
Wilmington, DE 19804

9220 Estero Park Commons Blvd.
Suite 7
Estero, FL 33928

630 N. Cobb Parkway
Marietta, GA 30062

312 W. Northwest Highway
Arlington Heights, IL 60004

8250 Bash Street
Indianapolis, IN 46250

32-A Mellor Ave.
Baltimore, MD 21228

180 Bear Hill Rd.
Waltham, MA 02154

9937 Big Bend Blvd.
St. Louis, MO 63021

250 Central Ave.
White Plains, NY 10606

223 Siebert Rd.
Pittsburgh, PA 15237

393 Woods Lake Rd.
Greenville, SC 29607

6651 Backlick Rd.
Springfield, VA 22150

1-800-323-9729
radiocat@erols.com
www.radiocat.com

November 7, 2011

Dennis Lawyer dennis.lawyer@nrc.gov
Division of Nuclear Materials Safety
U.S. Nuclear Regulatory Commission, Region I
475 Allendale Road
King of Prussia, PA 19406

RE: LICENSE NUMBER 45-25330-01

Dear Mr. Lawyer:

This letter is in response to your telephone request for additional information regarding Radiocat's October 5, 2011 amendment request. The exhaust rate at 7712 Crosspoint Commons, Fishers, IN 46038 will be a minimum of 340 cfm.

If you have any questions or require additional information, please call me at 847-965-1999.

Sincerely,

Eli A. Port, CHP, CIH, P.E.

Attachments

ec: Rand Wachsstock, DVM

H:\HOME\400001 Health Physics\RADIOCAT\NRC\NRC26.doc