

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
Subcommittee on Fermi 3: Open Session

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Friday, October 21, 2011

Work Order No.: NRC-1219

Pages 1-197

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 SUBCOMMITTEE ON FERMI 3

6 + + + + +

7 OPEN SESSION

8 + + + + +

9 FRIDAY

10 OCTOBER 21, 2011

11 + + + + +

12 ROCKVILLE, MARYLAND

13 + + + + +

14 The Subcommittee met at the Nuclear
15 Regulatory Commission, Two White Flint North, Room
16 T2B1, 11545 Rockville Pike, at 8:30 a.m., Michael
17 Corradini, Chairman, presiding.

18 SUBCOMMITTEE MEMBERS PRESENT:

19 MICHAEL CORRADINI, Chairman

20 SAID ABDEL-KHALIK

21 J. SAM ARMIJO

22 CHARLES H. BROWN, JR.

23 GORDON R. SKILLMAN

24 JOHN W. STETKAR

25

CONSULTANTS TO THE SUBCOMMITTEE PRESENT:

THOMAS S. KRESS

GRAHAM B. WALLIS

NRC STAFF PRESENT:

CHRISTOPHER BROWN, Designated Federal
Official

ADRIAN MUNIZ

JERRY HALE

TIM STEINGASS

JOEL JENKINS

CRAIG HARBUCK

RAJ ANAND

SYED HAIDER

GREG MAKAR

JOHN MCKIRGAN

STEVEN DOWNEY

TODD HILSMEIER

GEORGE LIPSCOMB

MARK CARUSO

JIM XU

1 ALSO PRESENT:

2 PETER SMITH

3 STEVE THOMAS

4 DAVE HARWOOD

5 RYAN PRATT

6 GARY MILLER

7 ALAN BEARD

8 MICHAEL BRANDON

9 WALTER SCHUMTISCH

10 NICK LATZY

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

T-A-B-L-E O-F C-O-N-T-E-N-T-S

1		
2		
3	Opening Remarks and Objectives	5
4	Staff Opening Remarks	8
5	Discussion of ACRS Questions	9
6	Chapter 5, Detroit Edison Company	24
7	Chapter 5, NRO	36
8	Chapter 16, Detroit Edison	58
9	Chapter 16, NRO	67
10	Chapter 6, Detroit Edison	86
11	Chapter 6, NRO	93
12	Chapter 17, Detroit Edison	123
13	Chapter 17, NRO	134
14	Chapter 18, Detroit Edison	151
15	Chapter 19, NRO	168
16	Discussion among Subcommittee members	185

17

18

19

20

21

22

23

24

25

P R O C E E D I N G S

8:28 a.m.

CHAIR CORRADINI: The meeting will come to order.

This is a meeting of the Advisory Committee on Reactor Safeguards and it's Subcommittee on Fermi Unit 3, the Reference COLA.

My name is Mike Corradini, I'm Chair of the Subcommittee. The Subcommittee members in attendance are Dr. Said Abdel-Khalik, Dr. Sam Armijo, Mr. John Stetkar, Mr. Dick Skillman, Mr. Charlie Brown and our consultants Dr. Tom Kress and Graham Wallis.

The purpose of this meeting is to discuss SERs for Chapters 5 the Reactor Coolant System, Chapter 6 the Engineered Safety Features, Chapter 16 Technical Specs, Chapter 17 Quality Assurance and Chapter 19 the PRA and the Loss of Large Areas Associated with the Fermi 3 COLA.

The Subcommittee will hear presentations by and hold discussions with representatives of the NRC staff and the Applicant, the Detroit Edison Company, regarding these matters.

The Subcommittee will gather information, analyze relevant issues and facts and formulate proposed positions and actions as appropriate for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

1 deliberation by the full Committee.

2 Christopher Brown is our Designated
3 Federal Official for this meeting.

4 The rules for participation in today's
5 meeting have been announced as part of the notice of
6 this meeting previously published in the *Federal*
7 *Register* on October 11, 2011. And as noted in the
8 *Federal Register* notice, a portion of this meeting
9 will be closed to discuss security-related
10 information. At the time Mr. Brown will check the
11 room to ensure that only designated NRC and DTE
12 personnel are present.

13 A transcript of the meeting is being kept
14 and will be made available as stated in the *Federal*
15 *Register* notice.

16 It's requested that speakers first
17 identify themselves and speak with sufficient clarity
18 and volume so that they can be readily heard.

19 Also, be silence all iPhones, iPads, other
20 things and other personal devices so no jiggling or
21 wiggling or dangling occurs.

22 We have not received any requests from
23 members of the public to make oral statements or
24 written comments at this time. And there is a bridge
25 line setup for Detroit Edison personnel to call in if

1 the DTE folks in the room want to get advice or
2 information from their colleagues.

3 We have the bridge line setup, is that
4 correct, Chris?

5 DESIGNATED FEDERAL OFFICIAL BROWN: That
6 is correct.

7 CHAIR CORRADINI: So the only thing I
8 wanted to mention in terms of reminding everybody that
9 just due to scheduling and how things have evolved,
10 we're going to have a series of meetings. We've had
11 the first one in late May, I think it was May 25th,
12 where we covered a series of four chapters primarily
13 were incorporated by reference chapters. A large
14 portion of the day is going to be similarly that.
15 We're going to start off with Detroit Edison telling
16 us about some issues or questions that we had raised,
17 and they're going to inform us more about certain
18 things from the May meeting.

19 We're going to have another meeting on
20 November 30th, again with a number of chapters, it'll
21 have a number of things incorporated by reference. And
22 then we're planning a meeting sometime in early 2012
23 which will pick up the chapters where there's a number
24 of deviations from the standard DCD or specific
25 additions because of the site. And that has yet to be

1 precisely scheduled, but we'll get back to everybody
2 about that and those details.

3 So, I'd like to now proceed and call on
4 Mark. Are you going to be our kickoff or is Adrian
5 going to do it? So I'll call on Adrian Muniz as the
6 Lead Project Manager for Fermi 3 to start us off.

7 Adrian?

8 MR. MUNIZ: Good morning.

9 My name is Adrian Muniz, NRC Lead Project
10 Manager for the Fermi COLA.

11 And I would like to thank the Committee
12 for the opportunity for the staff to discuss their
13 findings as documented in the Safety Evaluation Report
14 with no open items.

15 As Dr. Corradini mentioned, there were
16 several questions raised by the ACRS Members on the
17 May 26th ACRS meeting and Detroit Edison has prepared
18 a presentation to address those questions.

19 Just a point of clarification on Chapter
20 11 which is going to be presented on November 30th,
21 that chapter contains a departure, that's being
22 characterized as a departure not requiring prior
23 approval. And that's the sole departure as of right
24 now that is contained in the COLA.

25 So with that, I would like to turn it over

1 to Detroit Edison for their presentation.

2 CHAIR CORRADINI: So their first
3 presentation will be given by Detroit Edison basically
4 answering questions that we've raised from our May
5 meeting. And, Peter, are you going to kick us off?

6 MR. SMITH: Yes, I am.

7 CHAIR CORRADINI: Okay. I was looking for
8 you there. I'm sorry.

9 MR. SMITH: I moved.

10 CHAIR CORRADINI: Yes. I knew you were
11 there a second ago. All right. Go ahead. I'm sorry.

12 MR. SMITH: I saw you move.

13 CHAIR CORRADINI: Yes, we tend to shift
14 around so you can't find us easily.

15 MR. SMITH: Anyway, my name is Peter Smith
16 from Detroit Edison and I've been the COLA Lead since
17 the inception of our project.

18 Last time I went through an extensive set
19 of introductions of people. We have the same cast as
20 we had previously, plus one other that I'll add here.
21 That's Stan Stasek who is our Director of Quality
22 Management from a previous meeting.

23 Anyways, so the first thing I wanted to do
24 was I wanted to go through what we distilled down to
25 two items from our Chapter 8 review from the May

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 meeting. And the first question relates to whether or
2 not the switchyard breakers have one or two closing
3 coils. And the second question related to the
4 description of the overall off-site transmission
5 system and it related to the fact that Fermi 2 and
6 Fermi 3 share the same transmission corridor for a
7 period and I was not able to adequately describe it,
8 so I've brought some pictures this time that I think
9 will help.

10 So, next slide, please.

11 So the first thing is related to the
12 switchyard breaker closing coils. The breakers have
13 single closing coils. We have yet to find someone who
14 manufacturers breaks with more than one, and I'm
15 convinced them we will.

16 MEMBER STETKAR: Good luck.

17 MR. SMITH: Yes. So anyways, but what we
18 did take away from the meeting was the need to be able
19 to optimally restore off-site power following a loss
20 of off-site power event. And so we went off and we
21 investigated what our practices were in Detroit Edison
22 and we actually owned the transmission system and what
23 ITC has subsequently continued to do, and also through
24 our engineering firm B&V and others that they support.
25 And what we have found in our system and in ITC's is

1 that in the switchyard they use a single battery for
2 restoration of all the breakers, which is not an
3 optimal scheme, and so I was going to talk about that.

4 So, we have a breaker and a half
5 configuration of our switchyard. So in our particular
6 configuration you could reach success by closing a
7 single breaker if you have the right off-site line --

8 MEMBER STETKAR: Right. Excellent.

9 MR. SMITH: -- incoming line and the right
10 alternate preferred power source or normal preferred
11 power source aligned to that breaker. And then the
12 numbers of breakers you have to close go up from
13 there.

14 MEMBER STETKAR: Depending on -- yes.

15 MR. SMITH: So we are committed to IEEE
16 765 which in general talks about preferred power
17 supply reliability. And we also recognize that the
18 switchyard configuration, and often when we're
19 configuring two batteries because we will have two
20 batteries --

21 MEMBER STETKAR: Yes. The good news is
22 you have two batteries out there.

23 MR. SMITH: Yes.

24 MEMBER STETKAR: So in principle you just
25 need to figure out --

1 MR. SMITH: We just need to figure what
2 the right --

3 MEMBER STETKAR: --and thinking about at
4 which battery supplies which set of breakers so you
5 have, you know a reasonable chance of getting one line
6 back if you do have a battery dead.

7 MR. SMITH: So what we're doing to address
8 this is right now in our relationship with ITC we have
9 an interconnect agreement that has a stop point in it
10 and we have to give a go ahead when we actually decide
11 to build a plant, and that will kickoff the detailed
12 design. And at that time when we get into that
13 contract we're going to put in these requirements
14 relative to performing an evaluation to optimally
15 configure our switchyard.

16 MEMBER STETKAR: Good.

17 MR. SMITH: And utilizing the two
18 batteries for restoration.

19 MEMBER STETKAR: Good.

20 MR. SMITH: And we've got that tracked in
21 our commitment management system associated with a
22 milestone for kicking off that interaction with ITC.

23 MEMBER STETKAR: Thank you.

24 MR. SMITH: Next slide.

25 So the second question related again to

1 the description of the Fermi 2 and Fermi 3
2 transmission corridor. And then there was also a
3 related question regarding a physical separation
4 between circuits from Fermi 2 and Fermi 3 since the
5 circuits are strung on the same towers.

6 So next slide, please.

7 So just as a recap from our last meeting,
8 the Fermi 2 transmission system; Fermi 2 is supplied
9 by 345 kV and 120 kV from the ITC transmission system.

10 There's two 345 kV circuits that are on
11 separate towers and three 120 kV circuit that service
12 the plant that provides a second course of off-site
13 power. When leaving the plant these circuit are all
14 in a common right of way and they're spaced
15 sufficiently such that the collapse of either of the
16 345 kV towers would not interrupt the other 345 line,
17 and that's a statement out of the Firma Unit 2 FSAR.

18 In Fermi 3 we have three 345 kV lines
19 leaving our site. They're in a common right of way and
20 share that common right of way with the Fermi 2
21 transmission system for a portion. Ultimately, Firma
22 2's 345 kV goes through a Brownstown Station, and I'll
23 point that out when we get to the next slide and Firma
24 3 goes to the Milan Station. And again we have
25 sufficient spacing such that any one 345 kV tower or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pole failure, and I'll explain that in a minute, can
2 at most disrupt and cause the loss of that line or the
3 adjacent circuit, but not all three.

4 MEMBER STETKAR: Not all three?

5 MR. SMITH: Not all three, correct.

6 MEMBER STETKAR: You can get the two?

7 MR. SMITH: Yes, you can get two.

8 So, next slide.

9 So, I'm going to see if I can drive the
10 mouse here so I can point this out.

11 So, this is just the overall diagram.
12 Fermi 3 is located where the mouse pointer is. And
13 the transmission corridor leaves the site and proceeds
14 down this red and green, and this break point here
15 where the green turns over the Fermi 2 345 kV circuit,
16 that's approximately Interstate 75. And the Fermi 2
17 lines then proceed up by I-75 corridor up to the
18 Brownstone Station which is located to the north and
19 east.

20 The Fermi 3 corridor continues out a
21 developed corridor up to the Sumter area and then
22 proceeds west toward Milan. Now as the developed
23 corridor ends here and there's about 11 miles at the
24 end that are undeveloped at this point in time,
25 although we planned 40 years ago to support the

1 original Fermi 3 that we had a construction permit
2 for.

3 Next slide.

4 CHAIR CORRADINI: Just so I understand, so
5 the solid red ends with a dashed red and it ends there
6 because there's a substation or ends there because
7 there's been just simply no development to this date?

8 MR. SMITH: No, there's not a substation
9 there, but I believe the route to those lines
10 continues in a different path. So we only showed the
11 only path to that point.

12 CHAIR CORRADINI: Okay. Thank you.

13 MEMBER STETKAR: Peter, I was just trying
14 to find my notes.

15 The co-located red/green path --

16 MR. SMITH: Yes?

17 MEMBER STETKAR: -- what's that distance?
18 It's a few miles.

19 MR. SMITH: It's about 3½ miles.

20 MEMBER STETKAR: Three and a half miles?

21 MR. SMITH: I think.

22 MEMBER STETKAR: I couldn't find it in my
23 notes, but I thought it was something like that.

24 MR. THOMAS: If you look at the scale on
25 the bottom of the figure --

1 MEMBER STETKAR: Oh. That would be too
2 easy.

3 MR. THOMAS: -- it's about 3½ miles.

4 MR. SMITH: I need better glasses to see
5 the scale at the bottom.

6 MEMBER STETKAR: I'm too used to asking
7 simple questions, so --

8 CONSULTANT WALLIS: So an airplane could
9 take out all the lines?

10 MR. SMITH: Yes, conceivably.

11 CONSULTANT WALLIS: So that sort of common
12 failure would take out everything?

13 MR. SMITH: Yes.

14 So here's the configuration of the
15 corridor --

16 CHAIR CORRADINI: So Graham asked that
17 question, can we go back?

18 MR. SMITH: Certainly.

19 CHAIR CORRADINI: So where's the Detroit
20 Airport? I was trying to understand this because
21 whenever I fly to Detroit I look for Fermi.

22 MR. SMITH: Oh. So, the Detroit Metro
23 Airport is about -- I want to say --

24 CHAIR CORRADINI: It's to the northwest,
25 I know, but I'm trying to figure out where it is in

1 relationship to this.

2 MR. SMITH: It's about 20 miles.

3 CHAIR CORRADINI: Okay.

4 MEMBER STETKAR: We haven't talked about
5 aircraft crashes. Twenty miles is one thing. Where
6 the air traffic control corridor is and are you on
7 either a take off -- whatever?

8 CHAIR CORRADINI: They don't fly over at
9 all.

10 MEMBER STETKAR: Okay.

11 CHAIR CORRADINI: After five wonderful
12 years coming to and from Washington for this joyful
13 experience, I've never seen it get close to it.

14 MEMBER STETKAR: I mean, they tend to
15 route them around.

16 CHAIR CORRADINI: There's Fermi and then
17 there's also a fossil plant up north and a small
18 airfield to the east of that. And essentially all the
19 aircraft routing from Detroit DTW avoids all three of
20 those empirically.

21 MEMBER STETKAR: Okay.

22 MR. SMITH: And we'll talk about that in
23 Chapter 2. We've updated that analysis for Fermi 3.

24 So, here's the configuration of the
25 corridor. So on the outside are the two 345 kV towers

1 that are currently existing. The outside arms have
2 one circuit of 345 kV on this tower for Fermi 2. The
3 other has one circuit of 345 kV for Fermi 2.

4 These arms are currently not strung. They
5 were originally planned, as I said, for the original
6 Fermi 3.

7 And then in the center of the corridor are
8 three circuits on wooden H towers for the 120 kV to
9 supply Fermi 3. And the distances are all on the
10 bottom.

11 MEMBER STETKAR: Those are wooden?

12 MR. SMITH: The center ones are wooden,
13 yes. We'll show you in the next figure, though,
14 that's slowly being changed.

15 CHAIR CORRADINI: And the center ones are
16 for local distribution? I don't think I appreciate
17 the difference. I'm sorry.

18 MR. SMITH: Okay.

19 CHAIR CORRADINI: The purpose of those?

20 MR. SMITH: So the 120 kV -- Fermi 2 has
21 two off-site sources. One is the 345 kV system, the
22 second off-site storage system, the 120 kV system
23 which actually predates Fermi 2. It was associated
24 with the original Fermi 1 plant.

25 MEMBER STETKAR: Ahh.

1 MR. SMITH: And then we have a series of
2 speakers that were installed on the site in the early
3 '60s.

4 MEMBER STETKAR: Right. You had said that
5 early on. I forgot.

6 MR. SMITH: Okay. And then the third
7 circuit for Fermi 3 will be on a pole tower that will
8 be installed somewhere in the center of the 120 kV
9 corridor.

10 MEMBER STETKAR: Details. Go on. Thanks.

11 CONSULTANT WALLIS: It's a long way to the
12 other towers, it's in the middle.

13 MR. SMITH: It is. When you --

14 CONSULTANT WALLIS: So the likelihood of
15 it taking out the other towers is pretty small?

16 MR. SMITH: So, the next --

17 CHAIR CORRADINI: The answer is yes.

18 CONSULTANT WALLIS: But it says here, it
19 says "could at most disrupt one adjacent line." Okay.

20 MR. SMITH: So on the next slide, I have
21 a couple of photographs. And so that really gives you
22 kind of the real perspective of it.

23 So, this next slide is on an
24 uncharacteristically sunny day --

25 CHAIR CORRADINI: This is the way Michigan

1 always is, isn't it?

2 MR. SMITH: If you wait long enough it is.

3 CHAIR CORRADINI: This was taken on July
4 3rd, 1063.

5 MR. SMITH: So you can see the
6 configuration as was described in the drawing
7 previously. And so the pole towers on the outside
8 that have the 345 kV circuits, the unhung on the pole
9 towers and then you can see the wooden Hs for the 120
10 kV system.

11 And then you'll notice this pole that's
12 right close to us, that's a recently replaced H tower.
13 So ITC has been going through a program where they've
14 had to replace the H wooden towers they've gone to
15 metal pole towers.

16 CONSULTANT WALLIS: Out of curiosity, do
17 you have any de-icing on these, or does the power line
18 de-ice itself?

19 MEMBER STETKAR: Ice gets heavy enough it
20 falls off.

21 CONSULTANT WALLIS: Just curious.

22 MR. HARWOOD: No, there's no de-ice.

23 CHAIR CORRADINI: If you say anything, you
24 have to come up to a microphone. Identify yourself
25 and speak with sufficient clarity. Sorry. It's

1 transcript problems.

2 MR. HARWOOD: That's okay. Dave Harwood,
3 Project Manager for Firma 3.

4 There is no de-icing.

5 CONSULTANT WALLIS: So another cause of
6 common failure would be a major ice storm? Could be?

7 MR. SMITH: Could be.

8 Next slide.

9 And so this then is the opposite way of
10 looking into the sun on the sunny day toward the Fermi
11 plant, and you can see the little towers in the
12 background, but it's basically the same configuration.

13 CONSULTANT WALLIS: But a breeze, too with
14 plumes like that?

15 MR. SMITH: I'm sorry?

16 CONSULTANT WALLIS: There's quite a breeze
17 with the plumes are horizontal like that.

18 MR. SMITH: Yes.

19 MEMBER ARMIJO: Just to follow-up on
20 Professor Wallis' question, have you ever had failures
21 of transmission lines due to heavy icing into the
22 Fermi plants?

23 MR. SMITH: I don't know of an instance of
24 icing. But we have had lines disrupted by tornado. We
25 had a tornado --

1 MEMBER STETKAR: June 6th.

2 MEMBER ARMIJO: Thank you.

3 MR. SMITH: And then the final portion of
4 the question related to the configuration of the off-
5 site power was related to how far apart the conductors
6 are between the Fermi 2 and Fermi 3 sites. It depends
7 on which arm. They're 30 feet, the minimum of 45
8 between conductor to conductor.

9 CONSULTANT KRESS: All these common cause
10 things, you account for those in your historical
11 frequencies and loss of off-site power --

12 MR. SMITH: Yes. Correct.

13 CONSULTANT KRESS: -- in your PRA?

14 MR. SMITH: Yes.

15 MEMBER STETKAR: We'll talk about that
16 when we get to Chapter 19 today.

17 MR. SMITH: Yes.

18 CONSULTANT KRESS: Okay. Okay.

19 MEMBER STETKAR: That's why I knew about
20 June 6th.

21 MR. SMITH: All right. Any other
22 questions?

23 CHAIR CORRADINI: No. Keep on going,
24 you're doing fine.

25 MR. SMITH: That was the last slide on

1 this. So, this concludes the follow-ups that we did
2 from the last meeting.

3 CHAIR CORRADINI: Okay. Okay. Any
4 questions about the Subcommittee members?

5 MEMBER STETKAR: No. I think that answers
6 the basic information. The takeaway is that a tower
7 failure can take out -- not including much about how
8 you're actually going to reconfigure the 120 and 345
9 down the center. But at most you can take out two of
10 the 345 Unit 3, one of the 345 Unit 2 and some 120 --

11 MEMBER BROWN: One or two of them.

12 MEMBER STETKAR: -- Unit 2.

13 MEMBER BROWN: A shared right of way.

14 MEMBER STETKAR: I mean a couple. So, you
15 could -- you know a tower failure, you still have at
16 least one circuit for each unit and probably a 120 for
17 Unit 2 also.

18 MEMBER BROWN: And an aircraft could take
19 all of them out if it came --

20 CHAIR CORRADINI: There's a number of
21 common causes.

22 MEMBER STETKAR: I mean, there are a
23 number of things that -- whenever you have a shared
24 right of way like this, you know that's --

25 CHAIR CORRADINI: Other questions? Okay.

1 Thank you.

2 MR. SMITH: Thank you.

3 CHAIR CORRADINI: So we can proceed I
4 think with today's discussion of Chapter 5 I assume is
5 what you guys are going to start with?

6 MR. SMITH: Yes. So I'm going to turn
7 this over to Ryan Pratt, who is an engineer who works
8 in my organization and he's going to go through
9 Chapter 5.

10 CHAIR CORRADINI: Okay. Thank you.

11 MR. PRATT: Good morning. As Peter said,
12 my name is Ryan Pratt. I'm a licensing engineer for
13 Detroit Edison. Today I'll be discussing Chapter 5,
14 Reactor Coolant System and Connected Systems.

15 As we've done with our previous
16 presentations on the secure side here, we list the
17 chapters where we added additional information to the
18 COLA. And this chapter information was added to three
19 sections:

20 Section 5.2 Integrity of Reactor Coolant
21 Pressure Boundary;

22 Section 5.3 Reactor Vessel; and

23 Section 5.4 Component and Subsystem
24 Design.

25 And also of note, all of the COL items in

1 this chapter are standard items, and all the standard
2 items were included in the previous ESBWR R-COLA.

3 Next slide.

4 Starting with Section 5.2 Integrity of
5 Reactor Coolant Pressure Boundary, the first standard
6 supplemental item identifies ASME codes that are
7 applicable to preservice and inservice inspection and
8 testing programs. And the FSAR identifies these same
9 code additions as those that are identified in the
10 DCD.

11 The next COL item identifies that all
12 Class 1 austenitic or dissimilar metal welds are
13 included in the referenced certified design.

14 And the third COL item provides
15 descriptions of the preservice and inservice
16 inspection and testing programs and implementation
17 milestones. The PSI program is to be completed prior
18 to plant startup and the ISI program is to be
19 implemented prior to commercial service.

20 We also state that the ISI program
21 incorporates the latest addition and addenda of ASME
22 codes approved in 10 CFR 50.55(a) 12 months prior to
23 fuel load.

24 Next slide.

25 Continuing with Section 5.2, we describe

1 the processes that we've preserved: Accessibility to
2 piping systems to enable nondestructive examination of
3 Class 1 welds. But accessibility to these systems is
4 incorporated into the plant design and the licensee's
5 responsibility is to ensure that that accessibility is
6 maintained.

7 And finally, the last final standard COL
8 item in Section 5.2 describes the procedures that will
9 be used for leak detection monitoring.

10 Section 5.3 Reactor Vessel. This section
11 also incorporates the DCD by reference with additional
12 standard information.

13 We describe our commitment to develop the
14 pressure-temperature curves in accordance with the
15 PTLR, Pressure Temperature Limit Report and our
16 commitment is to update the pressure-temperature
17 curves prior to fuel load to reflect the plant's
18 specific material properties, if required.

19 CONSULTANT KRESS: You have samples inside
20 your vessel to measure the neutron fluence?

21 MR. PRATT: Yes, that's right. We have in
22 accordance with the Reactor Vessel Material
23 Surveillance Program we have four sets of samples.

24 CONSULTANT KRESS: How many samples does
25 that include?

1 MR. PRATT: There's four different sets,
2 four different --

3 CONSULTANT KRESS: You take them out and
4 look at them about every two years or so?

5 MR. PRATT: The first set is after six
6 full-power years.

7 CONSULTANT KRESS: Six years?

8 MR. PRATT: And then 20 full-power years,
9 and then the third set comes out prior to the 60 full-
10 power years. And the last set is based upon the three
11 previous sets.

12 CONSULTANT KRESS: And based on those you
13 may adjust your pressure-temperature limits?

14 MR. PRATT: Right.

15 CONSULTANT KRESS: Okay.

16 MR. PRATT: And as I said, the next
17 standard COL item describes the Reactor Vessel
18 Material Surveillance Program.

19 And lastly, we state that the plant
20 operating procedures will be developed to implement
21 the pressure-temperature curves.

22 Next slide.

23 Section 5.4 Component and Subsystem
24 Design. Section 5.4 contains one standard
25 supplemental item which describes the operating

1 procedures by which water hammer will be precluded.
2 And these procedures will be developed to be similar
3 to current BWR procedures.

4 CONSULTANT WALLIS: Does the DCD address
5 water hammer?

6 MR. PRATT: It does.

7 CONSULTANT WALLIS: It does?

8 MR. PRATT: And water hammer preclusion is
9 incorporated into the design.

10 CONSULTANT WALLIS: I just wondered who
11 has the expertise to know what to do to preclude water
12 hammer? Is it you or GEH?

13 CHAIR CORRADINI: You're talking operating
14 procedures, I assume.

15 CONSULTANT WALLIS: I just wondered who
16 knows how to write those procedures. Do you have your
17 own piping that's different from the DCD?

18 MR. SMITH: No.

19 MR. PRATT: No, but the principles and
20 concepts will be similar to BWR procedures. Some of
21 the details may be different.

22 CONSULTANT WALLIS: So it's a standard
23 thing? It's not something that's different about your
24 plant?

25 MR. PRATT: Right.

1 CONSULTANT WALLIS: That's what I'm trying
2 to get at.

3 MR. SMITH: Correct. So the COL item is
4 really -- the DCD addresses design.

5 CONSULTANT WALLIS: Yes.

6 MR. SMITH: And the development of
7 procedures to preclude has made a COL item that we --

8 CONSULTANT WALLIS: You had different
9 piping and some reason?

10 MR. SMITH: No, no. So we would have a
11 discussion --

12 CHAIR CORRADINI: But there will be
13 difference with piping of isolation condensers, for
14 example.

15 MR. SMITH: Yes.

16 CHAIR CORRADINI: And that's somewhere
17 that you might worry about it.

18 Can I rephrase Graham's question a
19 different way? So you'll potentially have to consult
20 back with GEH in terms of the piping --

21 MR. SMITH: Analysis --

22 CHAIR CORRADINI: -- runs are different.

23 MR. SMITH: Yes.

24 CHAIR CORRADINI: Okay. To essentially
25 inform your procedure?

1 CONSULTANT WALLIS: Well details matter,
2 and sometimes the slope of a pipe matters; all kinds
3 of little things matter when you're dealing with water
4 hammers.

5 MR. SMITH: We've had considerable
6 industry experience, so --

7 CONSULTANT WALLIS: Yes, I know. I was
8 involved in some of that. Some of it is really
9 interesting.

10 MR. PRATT: The last item addressed in
11 Chapter 5 is Reactor Coolant System Vents and the
12 human factors analysis of the control room displays
13 for the RCS vents is included in DCD Chapter 18.

14 And the operating procedures will be
15 developed prior to fuel load to govern those vents.

16 CONSULTANT WALLIS: Which means opening
17 them occasionally when you have to? When the gases
18 build up in some sort of a place where, unfortunately,
19 you collect them and then you let them out; that's
20 what the procedures are? There's no automatic
21 venting, it has to be done by the operator?

22 CHAIR CORRADINI: You know, I think when
23 we reviewed I don't think that was the case. I don't
24 think that was the case.

25 CONSULTANT WALLIS: I'm trying to

1 remember. Right.

2 MEMBER STETKAR: The reactor vessels never
3 have --

4 CONSULTANT WALLIS: But there's a sensor.
5 There is a sensor. There has to be a sensor in there.

6 CHAIR CORRADINI: Can we get some
7 information from GEH?

8 MR. SMITH: Gary Miller.

9 MR. MILLER: This is Gary Miller, GE
10 Hitachi.

11 Could you repeat the question, please?

12 CONSULTANT WALLIS: Well, it says
13 "operating procedures," and I was trying to figure out
14 would the operator get some kind of a signal which
15 says something about the level of the noncondensibles
16 in the pipe or something? What is it that the
17 operator gets in this procedure?

18 MR. MILLER: This is in relation to the
19 isolation condenser system?

20 CONSULTANT WALLIS: Well, whatever. It
21 just says "vents." There are several vents, aren't
22 there?

23 CHAIR CORRADINI: I was going to say, a
24 number.

25 CONSULTANT WALLIS: Yes.

1 MR. BEARD: Alan Beard, GE Hitachi.

2 The answer is for the reactor pressure
3 vessel itself we're continuously venting the top head.

4 CONSULTANT WALLIS: Continuously?

5 MR. BEARD: Yes. We have a differential
6 pressure that's established between the vessel and
7 then just downstream of the immediate flow element,
8 you know the venturi that we have. It's about a 45
9 pound differential pressure there so we continuously
10 have that driving that.

11 And then on the isolation condensers we're
12 continuously venting those as well using that same
13 differential pressure to make sure that we don't
14 accumulate noncondensable gases in either of those
15 places.

16 CONSULTANT WALLIS: There are also vents
17 in emergency cooling, aren't there?

18 CHAIR CORRADINI: I think Graham is
19 thinking general, he's not thinking -- I think you've
20 answered it for isolation of the vessel, but I guess
21 you're thinking like the GDCS; is that what you're
22 thinking?

23 CONSULTANT WALLIS: Well, for the main
24 system it's done all the time.

25 CHAIR CORRADINI: Yes.

1 CONSULTANT WALLIS: So the operator
2 doesn't have to do anything.

3 CHAIR CORRADINI: Right.

4 CONSULTANT WALLIS: But there are things
5 like ECC systems, which are not used a lot --

6 CHAIR CORRADINI: Well, in this case then
7 I think you're thinking the GDCS, for example.

8 CONSULTANT WALLIS: Yes, something like
9 that.

10 CHAIR CORRADINI: Okay.

11 CONSULTANT WALLIS: Yes. Absolutely.

12 CHAIR CORRADINI: So in those cases is it
13 a set of procedures that's going to be developed so
14 that you would go on a periodic basis to make sure?
15 I don't think there are sensors. As I remember the
16 DCD there are not sensors.

17 CONSULTANT WALLIS: There are no sensors.
18 So how do you know when to vent?

19 MR. BEARD: Well, the systems are
20 continuously filled and kept solid. There wouldn't be
21 the ability to accumulate noncondensable gases there.

22 CONSULTANT WALLIS: Ah.

23 CHAIR CORRADINI: I was hoping you'd
24 answer that differently.

25 CONSULTANT WALLIS: So there's no

1 procedure for that either? I'm just wondering what
2 these procedures are that he's talking about.

3 CHAIR CORRADINI: I think where Professor
4 Wallis is going is that given that you've determined
5 once you fill the system it's solid, you're going to
6 have to go on some sort of periodic basis to verify,
7 reverify that things are solid up to some sort of
8 sampling point. And -- go ahead. Am I on the right
9 page?

10 CONSULTANT WALLIS: That's right. Yes,
11 I'm trying to figure out what these procedures are
12 based on and all I've heard here is that either you
13 don't need to do it or it's done all the time. That
14 doesn't sound like an operating procedure.

15 MR. SMITH: So having not developed these
16 procedures yet but going back to our existing plant
17 experience and the examples that you've addressed such
18 as an example in operating plants today, technical
19 specifications require periodic venting as part the
20 use of surveillance --

21 CONSULTANT WALLIS: Do require periodic
22 venting?

23 MR. SMITH: Yes. So you would have
24 operating procedures --

25 CONSULTANT WALLIS: Even though you think

1 it's solid, you still have a --

2 MR. SMITH: Right, to verify that the
3 lines are solid. I don't -- but we can look --

4 MR. BEARD: This is Alan Beard again.

5 I'd like to point out that we did make
6 design commitments on the pitch of those GDCS lines
7 such that from the isolation point they pitch
8 positively up in both directions.

9 CONSULTANT WALLIS: Yes, I remember that.

10 MR. BEARD: So they come down to a low
11 point, and then we have positive pitch going back to
12 the GDCS pool and positive pitch going back to the
13 reactor pressure vessel.

14 CONSULTANT WALLIS: That's all very good.
15 There is still some procedure to check, right?

16 MR. SMITH: Correct. So any procedure
17 would have the controls and the procedure for opening
18 and the storing and --

19 MR. PRATT: That concludes my
20 presentation. Any further questions?

21 CHAIR CORRADINI: Any member of the
22 Committee? Okay.

23 So I want to ask now will staff come up?

24 MR. SMITH: Yes.

25 CHAIR CORRADINI: Okay.

1 (Whereupon, at 8:59 a.m. off the record
2 until 9:00 a.m.)

3 CHAIR CORRADINI: So who is going to start
4 us off? Jerry, are you going to start us off?

5 MR. HALE: Well, good morning. Jerry
6 Hale, Project Manager in Fermi Application.

7 We're here to present the SER for Chapter
8 5 with no open items of the reactor coolant system and
9 connected systems.

10 Section 5.1 was a summary description, it
11 was IBR.

12 Section 5.2 Integrity of Reactor Coolant
13 Pressure Boundary included Sections 5.2.1, 5.2.2,
14 5.2.3 and 5.2.5. These are all IBR sections.

15 I'd like to move now into the sections of
16 plant-specific starting with Section 5.2.4 Preservice
17 and Inservice Inspection and Testing. Tim Steingass
18 will present on that. He was the technical reviewer
19 of that section.

20 MR. STEINGASS: Good morning, Mr.
21 Chairman and ACRS members.

22 It says here my name is Tim Steingrass,
23 but that's not correct. It's Steingass as in gasoline,
24 okay?

25 I'm the lead technical reviewer for all

1 the ISI and PSI programs for Section 5.2.4 and 6.6.
2 So I'll have the pleasure of coming up in sitting for
3 you again for Section 6.6.

4 Let's see, next slide please.

5 I took a look at the COL and information
6 and supplemental items. COL item 5.2-1-A involved PSI
7 and ISI programs for the reactor coolant and pressure
8 boundary.

9 COL item 5.2-3-A involved accessibility.
10 We asked the Applicant for additional information to
11 assure that accessibility with all the valves and
12 components would be maintained throughout the course
13 of construction. And the Applicant provided
14 additional information to satisfy us that that would
15 be maintained so that the regulations involving
16 accessibility to perform PSI and ISI examinations that
17 are required by ASME code can be conducted throughout
18 the course of construction and during operation.

19 Supplemental item 5.2-1 involved system
20 leakage and hydrostatic pressure testing. The COL
21 Applicant provided the additional information that we
22 required to meet the Standard Review Plan on that, and
23 we had no further issues with that.

24 Post combined license activities involving
25 PSI and ISI, there were commitments made by the

1 Applicant that assured us that a series of schedule
2 information would be provided to the NRC so that we
3 could perform inspections throughout the construction
4 such that if any issues were identified real time,
5 they would be identified immediately and corrected
6 throughout the course of construction rather than
7 waiting until just before fuel load and then finding
8 that there's a major issue to have to be dealt with.

9 So, basically I came to the conclusion
10 that the Applicant has adequately addressed the COL
11 and supplemental information regarding Fermi 3 COL
12 FSAR, and I had no issues.

13 Are there any additional questions?

14 MEMBER STETKAR: Tim, I had one, one that
15 I kind of stumbled over and maybe it's just because I
16 don't understand. There's a statement in -- it's a
17 COL item 5.2-3-A, I guess. It says "During
18 construction phase of the project anomalies in
19 construction issues are addressed using the change-
20 control procedures. Procedures that require changes
21 to approved design documents including field changes
22 and modifications are subject to the same review and
23 approval process as the original design."

24 How does the staff get involved in that?
25 What I'm concerned about is fuel changes that subtly

1 affect things back from the DCD that you need to go
2 reverify. I mean, the folks who did the original
3 certified design thought about an awful lot of things,
4 and we have some experience from construction projects
5 where people make field changes that seemed like a
6 good idea to address the specific problem that they're
7 facing during actual construction, but that may indeed
8 affect other issues that they weren't thinking about
9 necessarily: Pipe stresses, you know hanger locations
10 or, you know supports. How does that process really
11 work and that statement about "will receive the same
12 review and approval as the original design" is what
13 caught my attention.

14 Well, I mean it's nice if they've got the
15 hook in there saying they're going to look at it, you
16 know --

17 MR. STEINGASS: Yes.

18 MEMBER STETKAR: -- that they're going to
19 pay attention to field changes. And I didn't ask
20 Detroit Edison. You know, I wanted to ask you guys
21 because the word "review" is in there.

22 MR. STEINGASS: Sure. Well, there's a
23 variety of controls that are in place. One, of
24 course, is the regulations that involved exemptions
25 and things of that nature.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Yes.

2 MR. STEINGASS: Okay. So we're got the
3 regulations behind us to make certain that if these
4 folks are going to change anything, they have to
5 request an exemption; anything that has to do with the
6 design so to speak.

7 MEMBER STETKAR: Yes.

8 MR. STEINGASS: Okay? So, you've got the
9 exemption process. But one of the things that I've
10 been involved in is writing or assisting the
11 construction inspection program people with some of
12 the guidance that they're going to need while they're
13 doing the inspections during construction.

14 What I did was I put tags that go from
15 some of the important things that I'm really concerned
16 about, such as accessibility.

17 MEMBER STETKAR: Yes.

18 MR. STEINGASS: The ability to be able to
19 get at dissimilar metal welds and be able to perform
20 ultrasonics on them. And all those tags are actually
21 written into the construction inspectors' guidance.
22 So --

23 CHAIR CORRADINI: So what you're saying is
24 you use your judgment to inform the inspectors in some
25 manner so they look for things that you have, shall I

1 say, issues that you always are looking at if you were
2 there?

3 MR. STEINGASS: And my judgment is based
4 on the lessons learned from --

5 CHAIR CORRADINI: Right. Right. Yes.

6 MR. STEINGASS: -- from all the issues
7 that we've had to deal with over the years.

8 MEMBER STETKAR: Okay.

9 MEMBER ABDEL-KHALIK: How detailed is the
10 SRP guidance on accessibility?

11 MR. STEINGASS: I'm sorry, I didn't hear
12 you.

13 MEMBER ABDEL-KHALIK: How detailed is the
14 SRP guidance on accessibility?

15 MR. STEINGASS: Well, to be honest with
16 you, the SRP talks about the ASME code for
17 accessibility. And the ASME code for accessibility,
18 frankly, is inadequate. It talks about the ability to
19 get into areas by erecting scaffolding and things of
20 that nature, and lighting. But when we're talking
21 about accessibility what's more important is as the
22 regulation say, that the plant needs to be designed
23 and construction such that accessibility to enable the
24 performance of preservice and inservice inspections is
25 maintained. So, I guess that's why I'm here.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: Well, I'm trying to
2 get to the underlying question is: What's involved in
3 your review of Section 5.2-3-A?

4 MR. STEINGASS: Okay. And since you
5 brought up the words "accessibility," I want to make
6 sure that they can actually do the preservice and
7 inservice inspections that are required by the ASME
8 code. My major concern, as I've said before, is the
9 dissimilar metal welds, austenitic welds; welds that
10 are susceptible to ICSCC.

11 With my background as an NDE Level 3 in
12 ultrasonics I know that there are certain distances
13 that need to be maintained such both physical and in
14 the design and selection of materials so that the
15 ultrasonic examination can be performed.

16 There's also guidance in the regulations
17 under the modifications sections that tell us and that
18 tell the applicants that they have to be able to prove
19 that they can actually perform an ultrasonic
20 examination by demonstrating that they can do a UT
21 from one side and find a similar type of defect.

22 So, what's involved is, frankly, knowledge
23 of the regulations, experience and the fact that we do
24 need to update the SRP to be more definitive on
25 accessibility.

1 CONSULTANT KRESS: Do you review all the
2 piping drawings and --

3 MR. STEINGASS: Well you see, that's why
4 I asked for the Applicant to give us added assurance
5 that they would maintain accessibility and also there
6 are in some of the DCDs, and I can't remember everyone
7 of them because I've looked at all of them, there are
8 keys in there that say you're going to meet this
9 regulation, or we intend, or we make a commitment to
10 meet this regulations and that that regulation is in
11 the modification section that says, as I said before,
12 you have to prove that you can find a defect, a
13 similar defect from one side. You have to actually
14 demonstrate the adequacy of it. And if you don't,
15 then you have to look at it from two sides. And if
16 you're going to look at it from two sides, then you
17 have to design for access on two sides.

18 MEMBER STETKAR: I don't remember because
19 I get lost with all of the different designs we look
20 at.

21 MR. STEINGASS: So do I. So do I.

22 MEMBER STETKAR: But is the final piping
23 design covered on DAC for this plant? I'll ask
24 Detroit.

25 MR. STEINGASS: Well, first of all, I

1 don't think I answered your question. I don't have
2 any design.

3 MEMBER STETKAR: That's the reason I
4 brought up the DAC issue is --

5 MR. STEINGASS: I don't have any. So what
6 I look for are commitments to meet certain
7 requirements and regulations, and that's the best I
8 can do.

9 MEMBER STETKAR: I mean, that's a bit of
10 the problem at this stage because at the COL stage you
11 don't have a detailed design --

12 CONSULTANT KRESS: Well, then the DAC will
13 take care of looking at that is what I was thinking.

14 MEMBER STETKAR: The DAC and the
15 inspection process; that's why the construction
16 inspection process -- you know, why you had to rely on
17 construction inspection to address these design
18 issues.

19 MR. STEINGASS: That's exactly why we're
20 so adamant about a milestone schedule that comes
21 within six months of getting the license so that we
22 can schedule the inspections and do the inspections
23 real time as the drawings and the systems are being
24 put together and constructed and welded and
25 nondestructive examinations are performed.

1 MEMBER ABDEL-KHALIK: So the review of
2 item 5.2-3-A is essentially a review of the
3 commitments made as to maintain accessibility?

4 MR. STEINGASS: Yes, sir. Yes, sir. Yes.
5 I asked for additional wordage from these folks to
6 assure me that extra effort would be put into the
7 design and during the construction such that
8 accessibility to perform the NDE would be there.

9 MEMBER STETKAR: And what's what the
10 second half of the paragraph I quoted from says:
11 "Control of accessibility for inspectability and
12 testing during licensee design activities affecting
13 Class 1 components is provided via procedures for
14 design control and plant modification." So I think
15 that that's the assurance that Tim was looking for, at
16 least at the COL, saying that they would have
17 procedures which I guess in this process is about all
18 the staff can do.

19 MR. STEINGASS: At this point, yes sir.

20 CHAIR CORRADINI: Any other questions?

21 MEMBER ARMIJO: I have a question. You
22 mentioned IGSCC as one of the reasons why you want
23 accessibility of the welds so you can inspect them.
24 This system, I believe, in the DCD does not have a
25 built-in hydrogen water chemistry system as part of

1 the cert by design. Now, I don't recall whether
2 Detroit Edison intends to have such a system, so that
3 would be outside of the DCD. So this may not be the
4 right chapter, but when will we review what you folks
5 are going to do about that issue?

6 CHAIR CORRADINI: You're talking back to
7 DTE?

8 MEMBER ARMIJO: Right. Detroit Edison,
9 yes.

10 MR. SMITH: So this is Peter Smith. And
11 I'll give you my recollection and then I'm going to do
12 a lookup for you.

13 MEMBER ARMIJO: Okay.

14 MR. SMITH: I believe what the Design
15 Center Working Group agreed upon was that we were
16 going to implement noble chem as part and parcel of
17 the standard COL and that hydrogen water chemistry, I
18 believe our experience was is that everyone has added
19 it under a changed process, such as 50.59. And that's
20 what we would intend to do.

21 Now we also are participating in the EPRI
22 New Plant Chemistry Guidelines Working Group. And
23 that is a recommendation within the current state of
24 that.

25 MEMBER ARMIJO: So in the case for Detroit

1 Edison for this plant would you make those changes in
2 the course of building the plant? Is that going to be
3 part of the R-COLA or would you build the plant and
4 then do a 50.59 change afterwards?

5 MR. SMITH: It would a post-license
6 change, not necessarily after the plant is built.
7 Because in the --

8 CHAIR CORRADINI: It's during the
9 construction I think.

10 MR. SMITH: Right. So the other thing I
11 wanted to point out here too, is that the change
12 control process for new plants once the COL is issued
13 is different than it was during plants that were built
14 with construction permits and subsequent operating
15 licenses. So field changes are significantly more
16 controlled to the same degree as what are done to
17 changes done by licensees of operating plants. And
18 there is industry guidance being developed by NEI with
19 the staff on change control process.

20 CHAIR CORRADINI: I think you have help.

21 MR. SMITH: Okay. Thank you.

22 MR. THOMAS: My name is Steve Thomas. I
23 work for Black & Veatch. And we do have a hydrogen
24 water chemistry system that is described in Chapter 9.
25 And we'll get to that. I think that's scheduled for

1 the November 30th meeting. But we do have a hydrogen
2 water chemistry system.

3 MEMBER ARMIJO: Okay. That is part of it,
4 but it's not in the DCD.

5 MR. THOMAS: It's an option in the DCD
6 that we're implementing.

7 MEMBER ARMIJO: It is an option?

8 MR. THOMAS: Yes.

9 MEMBER STETKAR: Oh, yes. They have an
10 option.

11 CHAIR CORRADINI: But they've chosen to
12 exercise that option.

13 MR. THOMAS: Correct.

14 MEMBER ARMIJO: Okay. Thank you. I'll
15 just wait until we get to Chapter 9 then.

16 CHAIR CORRADINI: Anything else for Tim?

17 MR. STEINGASS: Thank you.

18 MR. HALE: Joel Jenkins will present the
19 technical review starting with Section 5.3-1 Reactor
20 Vessel Materials.

21 MR. JENKINS: Yes. My name is Joel
22 Jenkins. I'm a Materials Engineer on the staff with
23 the Office of New Reactors. And I reviewed Section
24 5.3.

25 Starting with Section 5.3.1 Reactor Vessel

1 Materials. Fermi incorporates by reference ESBWR DCD
2 Section 5.3.1 with the following departures and
3 supplements that are listed on this slide:

4 Section 5.3.6 of the DCD describes the
5 reactor vessel surveillance program, sometimes
6 abbreviated as RVSP, but in the ESBWR DCD this is a
7 short and a very generic description of the program.
8 Certain specifics such as specimen preparation, lead
9 factors and quantity of specimens are not provided in
10 great detail, or at all, in the ESBWR DCD.

11 So the first bullet, COL item 5.3-2-A
12 provides this level of detail for the RVSP. And it's
13 provided as a supplement to the generic requirements
14 of the ESBWR DCD.

15 The second bulleted item, COL 16.01-1-A
16 5.6.4-A, which is actually a COL item from the tech
17 specs, is mentioned in subsection 5.3.1.5 which
18 discusses compliance with the fracture toughness
19 requirements of 10 CFR Appendix G. Now this COL item
20 deals with the topic of pressure-temperature limits,
21 and I will discuss this topic in the next slide.

22 A post combined license activity
23 associated with the first COL item states that if
24 fracture toughness test results indicate that change
25 in the technical specs is required, the expected date

1 for the submittal of the revised technical specs will
2 be provided with the Summary Technical Report. And
3 the Summary Technical Report is that report which is
4 required to be submitted after capsules are pulled.

5 The Applicant also identified the
6 following license condition: The complete reactor
7 vessel surveillance program will be developed prior to
8 fuel load.

9 In conclusion: The Applicant has
10 adequately addressed COL and Supplemental Information
11 regarding the Fermi 3 COL FSAR.

12 And that concludes my presentation on this
13 slide.

14 CHAIR CORRADINI: Questions?

15 MR. JENKINS: Okay. Section 5.3.2 deals
16 with Pressure-Temperature Limits. Fermi incorporates
17 by reference ESBWR DCD Section 5.2 which provides
18 representative pressure-temperature limit curves. Now
19 the first bullet to item on this slide, COL item 16.0-
20 1-A 5.6.4-1 which I mentioned in the previous slide,
21 says that the pressure-temperature limit curves are
22 developed in accordance with the Pressure-Temperature
23 Limits Report, and this report is sometimes termed the
24 PTLR. And this is a technical report which is
25 submitted by the Applicant. This report has been

1 submitted and reviewed. The staff has reviewed the
2 PTLR and finds it conforms to the technical criteria
3 Generic Letter 96-93 and is compatible with the
4 technical specs. But, it should be noted that PTLR
5 provides generic not plant-specific heat up and
6 cooldown pressure-temperature curves based on bounding
7 material properties and projected fluence.

8 To address the submittal of plant-specific
9 pressure-temperature limits, the COL Applicant has
10 provided the following commitment, and this commitment
11 stated on the slide that prior to fuel load, the
12 pressure-temperature limit curves will be updated to
13 reflect plant-specific material properties, if
14 required.

15 In conclusion, the Applicant has
16 adequately addressed COL and Supplemental Information
17 regarding Fermi 3 COL FSAR.

18 MEMBER SKILLMAN: I'm Dick Skillman. I'd
19 like to ask a question, please, Joel.

20 MR. JENKINS: Yes. Sure.

21 MEMBER SKILLMAN: Please explain that
22 little phrase "if required." What does that mean?
23 What would be the basis for requiring the curves to be
24 updated, please? This is pretty important. This is
25 what sets the whole map for heat up and cooldown in

1 the control room.

2 MR. JENKINS: Right.

3 MEMBER SKILLMAN: So what is it that would
4 be a change to which one would respond if required,
5 please?

6 MR. JENKINS: I'm not really sure if I
7 know the best way to answer that.

8 MEMBER BROWN: Well, you just said that
9 all you got was a generic.

10 MR. JENKINS: Well, it's --

11 MEMBER BROWN: So it's not right now--

12 MR. JENKINS: We don't know that a plant-
13 specific --

14 MEMBER ARMIJO: Well, the material
15 properties are the vessel properties and there's
16 generic information on what those properties should
17 be.

18 MR. JENKINS: Right.

19 MEMBER ARMIJO: And when this the vessel
20 for this particular plant is built and the properties
21 measured if they're within that boundary --

22 MR. JENKINS: Well, if they're within the
23 bounds, then there's no adjustment.

24 MEMBER ARMIJO: But if you had something
25 unusual about that material that --

1 CHAIR CORRADINI: You mean something out
2 of spec?

3 MEMBER ARMIJO: Well, just didn't have the
4 fracture toughness you expected --

5 CHAIR CORRADINI: From the testing?

6 MEMBER ARMIJO: Yes. Then you'd have to
7 do something, or that's the way I interpret this
8 commitment.

9 MEMBER SKILLMAN: Well, I do too. I wanted
10 to hear that from NRO.

11 MEMBER ARMIJO: Yes.

12 MEMBER SKILLMAN: That's what I was hoping
13 to hear.

14 MEMBER BROWN: Who makes the decision,
15 though, that it's within the bounds? I mean, does
16 Detroit Edison? Are they supposed to submit something
17 that says hey, these are the material properties and
18 we consider these within the boundaries of the generic
19 PTLR --

20 MR. JENKINS: That's their -- no, that's
21 their commitment. They would need to submit that, but
22 we would review that and we would determine.

23 MR. HALE: I'll help you out on this one.
24 It is the Applicant's responsibility to determine and
25 to clearly state what the material properties are of

1 the actual material that's being used for
2 construction. At that point they would need to make
3 a decision is it within the bounding analysis that's
4 in the generic PTLR. If it is, you know, then they're
5 within that analysis. If it's not for some material,
6 then they're going to have to recalculate the curves
7 and they're going to have to notify us based on this
8 commitment of what those changes are.

9 MEMBER BROWN: Their conclusion it's
10 within the boundaries, boundaries of the generic
11 curve, do they have to submit those to the NRC for
12 confirmation?

13 MR. JENKINS: Yes.

14 MEMBER BROWN: So you all can see those?
15 In other words, they just don't make the decision and
16 you all not in the loop? In other words, they have to
17 tell you, yes, we consider these okay. Here's the
18 values and this is the limits that we have to deal
19 with and therefore we consider them okay; do you
20 approve?

21 MR. HALE: I think that's the expectation
22 is that --

23 MEMBER BROWN: Do you have to formally
24 respond in an agreement or do you just get the piece
25 of paper and if not answer comes out --

1 CHAIR CORRADINI: From a process
2 standpoint, I guess I personally don't -- as long as
3 you guys know and are comfortable with it.

4 MEMBER BROWN: Well, I don't know about
5 that, Mike. I mean, the P-T curves are the most
6 important set of curves you operate with.

7 MR. HALE: Well, remember --

8 MEMBER BROWN: Sending it into a black
9 hole just seems kind of meaningless.

10 MR. HALE: Remember we reviewed and
11 accepted a generic PTLR. And if they're going to
12 either acknowledge that the values that are in that
13 report are correct actual material or they're going to
14 acknowledge that the values outside those bounds and
15 need to be updated, then I think the assumption is
16 that they report it and we acknowledge that either:
17 (a) there is no change it's within the bounds or (b)
18 we acknowledge that, yes, they're outside the bounds,
19 we've looked at it, we've reviewed it and we verified
20 the fact that the calculations are appropriate and
21 acceptable.

22 MEMBER BROWN: The key word is
23 "acknowledge," and that's what I was looking for. Do
24 you formally acknowledge that you got them and you
25 agree with the conclusion or not. And you said you

1 do, so I'm taking you at your word.

2 MR. HALE: We would need to review what
3 they submit to ensure that --

4 MEMBER BROWN: And answer.

5 MR. HALE: -- it does in fact meet the
6 requirements, regardless of whether it's within the
7 bounds of the original generic report or outside the
8 bounds.

9 MEMBER BROWN: Okay. So you acknowledge
10 back to them either way?

11 MR. MUNIZ: This is Adrian Muniz.

12 We'll take that as an action item and
13 we'll get back to you as to the right process that we
14 use, whether the letter contains saying they're
15 bounded or not bounded. But we'll respond to that
16 question.

17 MEMBER BROWN: Okay. Thank you. Thank
18 you.

19 MR. MUNIZ: Sure.

20 CHAIR CORRADINI: Okay. Go ahead, or are
21 you done?

22 MR. JENKINS: I can't remember if I
23 mentioned the staff conclusion.

24 CHAIR CORRADINI: I thought you did, but
25 go ahead and repeat it.

1 MR. JENKINS: I'll repeat it again and one
2 final request for questions before we move on to the
3 next group.

4 In conclusion, the Applicant has
5 adequately addressed COL and Supplemental Information
6 regarding Fermi 3 COL FSAR.

7 Any other questions?

8 Okay. I have one more slide. Section
9 5.3.3 Reactor Vessel Integrity. Fermi incorporates by
10 reference ESBWR DCD Section 5.3.3. Included in this
11 section of the DCD is a discussion of operating
12 conditions. And in the discussion of operating
13 conditions is a requirement that procedural controls
14 are implemented to hold thermal stress within
15 acceptable ranges and to meet pressure-temperature
16 limits. In this context SUP item 5.3-1 states that
17 development of plant procedures is addressed in
18 Section 13.5 and these procedures requires compliance
19 with the technical specifications. This ensures that
20 the pressure-temperature limits identified in Section
21 5.3.2 are not exceeded during normal operating
22 conditions and anticipated plant transients.

23 In conclusion, the Applicant has
24 adequately addressed COL and Supplemental Information
25 regarding Fermi 3 COL FSAR.

1 That concludes my presentation.

2 CHAIR CORRADINI: Questions from the
3 Committee?

4 Okay. Let's move on. So we're on to
5 Chapter 16.

6 Just for everybody, for the Committee,
7 because of just staff flowing in and out we're going
8 to do Chapter 6 after 16 and do 17 after lunch, all
9 right?

10 Do DTE is back up.

11 CHAIR CORRADINI: You can g.

12 MR. SMITH: Okay. So Michael Brandon, my
13 Licensing Manager is going to do the Chapter 16
14 presentation.

15 MR. BRANDON: Okay. Thanks, Peter.

16 As Peter said, my name is Michael Brandon.
17 I'm the Licensing Manager on the project. I've been
18 with the project for about seven months. And I
19 appreciate the opportunity to come here today and talk
20 about Chapter 16, which is the Fermi 3 tech specs.

21 As I'm sure you guys know, the Fermi 3
22 tech specs were developed based on the generic tech
23 specs that were established in the ESBWR DCD. Those
24 generic tech specs were modeled primarily after NUREG-
25 1434, which is the BWR/6 Tech Spec Rev. 3, which is

1 the current standard with modifications made to
2 address the design differences between the BWR/6 and
3 the ESBWR.

4 The generic tech specs did include a
5 number of standard COL items and a few site-specific
6 items, and those items were addressed in accordance
7 with the Interim Staff Guidance 8.

8 The next slide.

9 Just as an overview, there were 52 total
10 COL items that address 23 topics. Of these 23, there
11 were basically three that we consider site-specific.
12 And the next couple of slides I will present will
13 cover those 23 different topics.

14 Next slide.

15 Really, this slide and the next slide I
16 just have a bulleted list of the 23 different topics
17 that were standard COL items. The Fermi 3 plan was
18 pretty straightforward. None of the approaches we
19 took were controversial or particularly noteworthy.
20 In my slides I just provided the list of the 23
21 between this slide and the next slide. I don't really
22 provide a detailed breakdown of each of these items,
23 so we'll be address any questions you might have. I
24 will address the three specific items in some detail
25 towards the end of the presentation.

1 On this particular slide there are two
2 site-specific. One is the hazardous chemicals and one
3 is the plant location.

4 The next slide.

5 This is just the balance of the 23 items.
6 On this page the one point specific is the multi-unit
7 reporting item. And like I said, I'll be talking
8 about those three site-specific items in the following
9 slide.

10 Next slide.

11 These are the three site-specific items
12 that we addressed as part of our application. The
13 first one deals with hazardous chemicals. We did do a
14 site-specific evaluation for hazardous chemicals.
15 That evaluation determined that there were no toxic
16 chemical hazards that would require us to have any
17 type of safety-related instrumentation to monitor for
18 those toxic hazards. Nick is going to talk in some
19 detail about that evaluation in his presentation on
20 Chapter 6 which will be later on today.

21 So from a tech spec perspective, the
22 implication of that is we don't have any type of
23 safety-related instrument in the tech spec in the
24 instruction section that addresses toxic chemical
25 hazard.

1 CHAIR CORRADINI: And where will this be
2 discussed? And you said it and I didn't --

3 MR. BRANDON: Oh, Chapter 6 which Nick
4 will be talking about that.

5 CHAIR CORRADINI: Okay. Fine. Okay.
6 Because I guess then just as a preview what I'm trying
7 to understand is the logic is to at what boundary --
8 at what distance what do you stop worrying about in
9 terms of distance away in terms of activities near the
10 plant? But we'll wait for 6.

11 MR. BRANDON: Okay. That's fine.

12 It is worth probably noting that for the
13 confirmed boundary and protection to the operators,
14 the Rev 3 of 1434, which is the basis for our tech
15 specs, did not incorporate TSTF-448 which is a TSTF
16 that was written in response to Generic Letter 2003-01
17 that talked about basically maintaining a confirmed
18 boundary consistent with this licensing basis. The
19 Firma 3 tech specs have incorporated TSTF-448. There
20 is a program in Chapter 5 of the tech spec that was
21 the standard program for ensuring the confirmed
22 boundary maintains its integrity, requires the tracer
23 gas test and so it will ensure that confirm in its
24 design is maintained consistent with the licensing
25 basis.

1 The last two items are the plant's
2 location. The plant is located in Frenchtown Township
3 in Monroe County, Michigan.

4 And the third plant-specific item deals
5 with a couple of different requirements for annual or
6 radiological requirements. And basically the option
7 there is we can make a single report for two units and
8 we opted to pursue that particular option.

9 MEMBER ABDEL-KHALIK: Are there any tech
10 spec limits on vacuum breaker leaks?

11 MR. BRANDON: Yes.

12 MEMBER ABDEL-KHALIK: And where are these?

13 MR. BRANDON: They're in Chapter -- let's
14 see. This is between the special pull on the --

15 MEMBER ABDEL-KHALIK: Yes.

16 MR. BRANDON: Chapter 6. They are
17 generic.

18 MEMBER ABDEL-KHALIK: So what are you
19 doing to ensure compliance with those tech spec when
20 it's --

21 MR. BRANDON: It's Spec 3616. And there
22 are some items requirements that drive periodic
23 monitoring on those.

24 MR. SMITH: Is your question from the
25 standpoint of maintenance?

1 MEMBER ABDEL-KHALIK: Well, my question is
2 really adequacy of those surveillance requirements.

3 CHAIR CORRADINI: So you catch it if it's
4 leaking more than the spec, I think is what --

5 MR. BRANDON: That's correct. There's
6 surveillance for functional testing them, there's
7 surveillance for verifying the leak rate, which is
8 basically an integrated leak rate test.

9 CONSULTANT WALLIS: Well, by a device yet
10 to be designed and proven?

11 CHAIR CORRADINI: That's a comment. Keep
12 on going.

13 MR. BRANDON: It's no different than a --
14 well, it is similar to the BWR/6 design.

15 CONSULTANT WALLIS: Well, this is an issue
16 that's still in the air, isn't it?

17 CHAIR CORRADINI: They have a commitment
18 from the DCD and construction in terms of a set of
19 testing that they're going to do relative to what I
20 think, if I remember back to the fun of last year, the
21 temperature sensors and all the associated logic,
22 right, Graham? Is that right --

23 CONSULTANT WALLIS: So you're dependent on
24 GEH for this really?

25 MR. BRANDON: Yes.

1 MEMBER STETKAR: Actually, I'm looking at
2 3616 and I don't immediately find a surveillance
3 requirement if you find a leakage.

4 MR. BRANDON: There is a surveillance --

5 MEMBER STETKAR: I see an opening
6 fracture.

7 MR. BRANDON: Right.

8 MEMBER STETKAR: I see the fact that they
9 are closed, which I guess might imply no leakage
10 depending on what you define as closed. "Verify each
11 vacuum breaker is closed." I can look at lights,
12 but--

13 MR. SCHUMITSCH: I think it's 3.6.1.1.3.

14 MEMBER STETKAR: 6.1.1 -- I'm sorry.

15 MR. SCHUMITSCH: 3.6 --

16 CHAIR CORRADINI: Identify yourself,
17 please.

18 MR. SCHUMITSCH: This is Skip Schumitsch
19 from GE Hitachi.

20 3.6.1.1.3 I believe is what you're looking
21 for.

22 MEMBER STETKAR: And, indeed, you're
23 correct.

24 MR. BRANDON: That's the CIV.

25 MEMBER STETKAR: Vacuum breaker leakage is

1 less then or equal to 15 percent of design basis over
2 square root of K.

3 MR. BRANDON: Whatever that means.

4 MEMBER STETKAR: Yes.

5 MR. BRANDON: We know what that means.

6 CONSULTANT WALLIS: How do you measure a
7 hole size? A vacuum break, it's a rather weird -- and
8 that K is the measure of the hole size at the leak.
9 So that's a strange thing to measure. You've really
10 got to measure something -- and then it has to be
11 converted, I suppose. Because it depends on the
12 pressures and all kinds of things.

13 Anyway, this is a thing we're going to do
14 at another time.

15 CHAIR CORRADINI: I don't want to
16 misrepresent. They have a commitment to the staff to
17 clear this up relative to testing so that this then
18 locks into a numerical value based on their testing.

19 So, go ahead and finish.

20 MEMBER ABDEL-KHALIK: So the surveillance
21 are yet to be determined, the surveillance techniques,
22 methodologies?

23 MR. BRANDON: The details.

24 MEMBER ABDEL-KHALIK: The criteria?

25 MR. BRANDON: I can't tell you. I did look

1 at Grand Gulf a number of years ago in the BWR/6
2 design. And the way they did the tests there was an
3 integrated leak rate test where they would pressurize
4 the --

5 CHAIR CORRADINI: They put, like, a hood
6 over it and do a pressurization test?

7 MR. BRANDON: Right. Basically you
8 wouldn't necessarily know which valve may be leaking,
9 but you would have an acceptance criteria or an
10 integrated acceptance criteria if you had some leakage
11 where you failed that thing and you'd have to go
12 through and do individual repairs for individual
13 valves.

14 CHAIR CORRADINI: And this is during
15 refueling?

16 MR. BRANDON: Yes, sir. That's a 24-month
17 surveillance.

18 CHAIR CORRADINI: Okay. That at least
19 helps. But details to be determined is what I think
20 we're still hearing, right?

21 MR. BRANDON: Right. That will be a
22 surveillance or a surveillance procedure that will
23 drive the performance of this test.

24 That was all that I had.

25 CHAIR CORRADINI: Are we done then?

1 MR. BRANDON: We're done, yes.

2 CHAIR CORRADINI: Okay. Questions by any
3 members?

4 All right. Let's move on to the staff.

5 MR. HALE: Okay. This will be a
6 presentation of Chapter 16 SER with no open items
7 technical specifications. And Craig Harbuck will
8 present the staff's review of the plant-specific
9 portions including COLA Part 4.

10 MR. HARBUCK: And I'm Craig Harbuck in the
11 Technical Specifications Branch of NRO.

12 And the presentation is going to
13 essentially follow the structure of the Safety
14 Evaluation. And some of the material will be
15 repetitive of what you've already heard. And I'll
16 just start right in on it.

17 The DCD Chapter 16 for ESBWR is unique in
18 terms of how it handles the technical specification
19 COL items. They provide a table in the introductory
20 part of the Chapter to define what those items are and
21 to provide instructions on how to complete them for an
22 applicant. In other design centers you may or may not
23 have specific enumeration of the items and there may
24 or may not be a reviewer's note within the body of the
25 tech specs or basis that tells you what to do. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this is a good approach for the ESBWR.

2 Well, before I move to the next slide, I
3 just want to point out that the site-specific
4 information to complete the tech specs were supported
5 by these other review grantees listed on the second
6 bullet.

7 Okay. Next slide.

8 Most items were resolved by just providing
9 the information that was the correct site-specific
10 information. And this was done in a variety of ways.

11 There were a number of items that were
12 essentially bracketed options that would if the
13 Applicant had an analysis to support adopting that
14 option, they could do it. Fermi has not adopted any
15 of those so there's those that we call operational
16 flexibility not adopted.

17 Then there's a number of items where the
18 information didn't apply in this instance. And the
19 one on hazard chemicals, that affects the tech specs
20 primarily in some language in an actual requirement
21 for the control room boundary and in the program for
22 maintaining the control room boundary it covers the
23 governance of testing, that sort of thing.

24 They don't have any unprotected outdoor
25 liquid rad-waste tanks. And since they didn't adopt

1 any of the second sub-bullet items related to taking
2 an MCPR penalty, there were no additional LCOCs under
3 the COLR administrative control. Had no exceptions
4 from their containment leak rate test program,
5 exceptions to RG 1.163.

6 And Firma is going to be a stand-alone
7 ESBWR unit so they're not going to share staff with
8 the other unit. And so there was no need to use part
9 of the notes relating to the staffing issue in the
10 administrative control specification.

11 Okay. For a good part of the review of
12 the design cert GEH had been pursuing using a valve-
13 regulated lead-acid battery. But I think around Rev
14 6 they switched back to the more familiar standard
15 vented acid battery and they provided then a large
16 number of bracketed items related to those parameters
17 were put into the DCD and they have satisfied and
18 completed on those.

19 And the other ones you've heard about from
20 the other presentations.

21 MEMBER ABDEL-KHALIK: I just have a
22 question about the previous slide. Why are the
23 provisions for hazardous chemicals not applicable for
24 this site?

25 MR. HARBUCK: I would have to defer to the

1 analysis in the FSAR that addressed that. There was
2 an open item, I'll mention that later about this --
3 well not an open item, but an RAI that staff asked.
4 And basically the conclusion was that there was no
5 need to provide any automatic capability to isolate
6 the control room based on toxic gas.

7 CHAIR CORRADINI: Is that because of what
8 -- I mean, this kind of follows up. That's on-site
9 and as well as off-site possibilities?

10 MR. HARBUCK: I'm not familiar with the
11 details.

12 CHAIR CORRADINI: But maybe we can turn
13 to--

14 MR. THOMAS: Once again, my name is Steve
15 Thomas.

16 And, yes, that includes both on-site and
17 off-site within a five mile radius consistent with RG
18 1.78.

19 MEMBER ABDEL-KHALIK: So how far is I-75?

20 MR. THOMAS: I-75 is within that five mile
21 radius. So we looked at potential transportation
22 accidents on I-75.

23 MEMBER ABDEL-KHALIK: And based on that
24 you just concluded that these were not --

25 MR. THOMAS: Based on that we did not need

1 it, no. Correct. We did not need the toxic gas
2 monitoring.

3 CONSULTANT KRESS: What is the status of
4 Fermi 1 on-site? Does it still have sodium in it?

5 MR. THOMAS: No.

6 CONSULTANT KRESS: It's being removed off-
7 site? Okay.

8 MEMBER STETKAR: Those analyses documented
9 in Chapter 2 of the FSAR?

10 MR. THOMAS: Correct. Chapter 2 contains
11 the list of all the chemicals that were considered
12 both on-site and off-site and the transportation
13 events.

14 MEMBER ARMIJO: You did address nitrogen
15 and C/O₂ as asphyxiants --

16 MR. THOMAS: Right.

17 MEMBER ARMIJO: -- in your analysis and
18 concluded that wouldn't affect the control room?

19 MR. THOMAS: Correct. We concluded that
20 the control room would still be habitable, or that the
21 carbon dioxide issue, that the carbon dioxide
22 concentration would be below the limits. And for the
23 nitrogen that it would not reduce the -- because
24 nitrogen, that was not a toxic gas it's an asphyxiant.
25 So you're concerned about reducing the oxygen level.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And it would not reduce the oxygen level sufficiently
2 to be a hazard to the operators.

3 MEMBER ARMIJO: Okay.

4 MEMBER ABDEL-KHALIK: Roughly when do we
5 expect to review Chapter 2?

6 CHAIR CORRADINI: Let's ask that of
7 Adrian.

8 MR. HALE: Yes, I'll leave that to Adrian
9 to answer that.

10 CHAIR CORRADINI: Is that a fair question
11 for you at this point?

12 MR. MUNIZ: We've issued the schedule
13 alert to affirm the approximate time when the full
14 Chapter 2 will be around August time frame of next
15 year. But we may -- we're available to possibly come
16 meet with ACRS and there's the other parts not related
17 to the SSI in Chapter 2 before then.

18 CHAIR CORRADINI: For the Committee, it
19 was a decision by staff they wanted to complete
20 Chapter 2. There was some issues relative to soils
21 and testing that has delayed this. So, we can take
22 that offline. But I think that was the reason.
23 Originally it was going to be like January time frame,
24 but just because of what's there versus the standard
25 reference it's been pushed back.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: I'm asking,
2 obviously, because discussion about hazardous
3 chemicals.

4 CHAIR CORRADINI: Okay. We have great
5 memories. We'll remember all of this when we'll see
6 you again.

7 MEMBER SKILLMAN: This is Dick Skillman.
8 I'd like to ask a question, please.

9 This question of hazardous chemicals has
10 come up several times here in the last 45 minutes.
11 And what I believe I heard is that there will not be
12 a safety-grade device or alarm in the control room to
13 warn the operators that there is a hazardous chemical
14 release or that there is something that is hazardous
15 penetrating the control room boundary. I believe
16 that's what I heard.

17 Taking the safety issue aside, is DTE
18 going to have something in that control room that
19 tells the operators heads up there's something in the
20 air that you should be aware of? Just from a
21 practical perspective, as I see this, this is maybe a
22 \$7 billion plant. You've got 25/30 people involved in
23 operations. You have a lot of people involved in
24 security. You got a lot of people involved in the
25 admin. So it's 2:00 in the morning, 4:00 in the

1 morning and something happens I-75 and while it's all
2 been analyzed and DTE is comfy, isn't there something
3 that tells the operators heads up team there's
4 something going on that you should be aware of,
5 safety-grade or not safety-grade?

6 MR. SMITH: So I don't have an answer for
7 you right at the moment.

8 MEMBER SKILLMAN: Okay. Thank you. I
9 just raise the issue because I've spent a lot of time
10 in control rooms and a lot of time in hazardous
11 chemical areas. It just seems that for a .25 cent
12 trinket there could be a way to preserve life and to
13 land the plant safely.

14 Thank you.

15 CHAIR CORRADINI: Don't take that as a
16 thought process to come back to. We'll see them
17 again.

18 MEMBER SKILLMAN: Thank you. Thank you.

19 MR. HARBUCK: Okay. We'll go to the next
20 slide.

21 There were a number of items which were
22 addressed using the bounding value or information
23 approach. The one that has the most information on
24 this slide is the P-T limits. As we heard before from
25 Chapter 5 presentation the methodology that's been

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 approved that was submitted by Firma was based on, I
2 guess, whatever the limits are on material properties
3 that would be judged to be the bounding case, they
4 expect that the material that they'll actually put
5 into the plant will have better properties than that,
6 I presume, so that the bounding curves are adequate
7 for operation. They may end up being conservative.
8 And if that is shown to be the case and if they wanted
9 to modify their report, that would be at their
10 discretion. But they wouldn't have to in order to
11 operate the plant. Therefore, we can conclude that
12 they provided useable bounding information relative to
13 the PTLR.

14 As just a matter of convention, all the
15 COL items related to the PTLR and the DCD, all of
16 those COL items were just judged to be part of this
17 bounding as just as a way of not trying to split it
18 up. Just made it easier for discussion.

19 Are there any questions about the PTLR
20 resolution? Okay.

21 CONSULTANT KRESS: I have maybe one.

22 MR. HARBUCK: Okay.

23 CONSULTANT KRESS: There's concern about
24 the copper/nickel content of material. How do you
25 know what it is when you get it and get ready to put

1 it in the vessel and put your welds in the right
2 place? Do you have some way to actually measure that
3 content or do you get it as a spec from the place that
4 provides you the materials? Just how do you know what
5 your material is?

6 MR. SMITH: Do you guys want to speak to
7 that at all or --

8 CHAIR CORRADINI: So repeat your question,
9 Tom. I'm sorry.

10 CONSULTANT KRESS: You know, for these
11 pressurized pressure-temperature limits you're
12 concerned about the copper/nickel content. And, you
13 know you go and get this material, it's showed up and
14 you're going to put it in the vessel and weld it
15 together. I just wondered how you knew what it was.

16 CHAIR CORRADINI: You mean the pedigree of
17 what arrives on site?

18 CONSULTANT KRESS: Yes, the pedigree of
19 what the material is. How do you go about knowing or
20 how does NRC know what it has in it, how do they
21 inspect it? Just the whole question of how do you
22 assure that you got the right materials?

23 MR. HALE: We can take that item.

24 MR. SMITH: Yes, let's take that item.

25 MEMBER ARMIJO: You've addressed that in

1 the DCD. This vessel doesn't have axial welds.

2 CONSULTANT KRESS: Right.

3 MEMBER ARMIJO: That's one of the things.

4 And --

5 CONSULTANT KRESS: That would help.

6 MEMBER ARMIJO: That helps in the modern
7 steel making steel making practice and low -- you know
8 the issue of carbon contamination of the welds. I
9 mean, copper that's all been addressed and it's in
10 the--

11 CONSULTANT KRESS: It's addressed in the
12 DCD.

13 MEMBER ARMIJO: At least I recall it
14 being--

15 CHAIR CORRADINI: So you're thinking about
16 -- you're talking from a QA standpoint of what arise
17 on site that they can verify what --

18 CONSULTANT KRESS: That was my question,
19 yes.

20 CHAIR CORRADINI: -- that it's within the
21 scope of --

22 CONSULTANT KRESS: But basically it's
23 addressed in the DCD.

24 MEMBER ARMIJO: Yes, on the vessel
25 acceptance would be the place where you'd make that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 decision. If you found a problem at that point --

2 MEMBER STETKAR: You've got to accept the
3 vessel.

4 CONSULTANT KRESS: You've got a big
5 problem.

6 MEMBER ARMIJO: But you know the risk is
7 pretty low that that's going to happen. But, you
8 know, these aren't the old vessel making techniques
9 that they're using.

10 CONSULTANT KRESS: That's the ones out of
11 Toledo?

12 MEMBER ARMIJO: Yes.

13 MEMBER ABDEL-KHALIK: The staff will
14 follow-up.

15 CHAIR CORRADINI: All right.

16 MR. HARBUCK: There was a COL item on the
17 ones that attached to your battery charger. And the
18 test duration is eight hours and that is judged to be
19 sufficient to meet the manufacturer's requirement that
20 having enough time to reach a steady state temperature
21 and condition and maintain that for two hours. That
22 all being acceptable, of course. And I think we have
23 any -- we got some documentation from the vendor that
24 supports that.

25 And then the last is the control rod scram

1 accumulator and minimum pressure limit. There's a
2 couple of places where that value is used. And what
3 Fermi's done is they took the value from the ABWR and
4 provided a discussion, the basis of the tech specs
5 that explains why that number is acceptable and
6 bounding to what they anticipate the number would be
7 once the system is installed and after testing,
8 determined what the appropriate pressure, minimum
9 pressure would need to be. However, I should point out
10 that normally the pressure in those accumulators are
11 maintained above that number. The tech spec is just a
12 minimum. And so that's -- do we have anything to add
13 to that?

14 All right. And for all the items on this
15 slide they were handled with bounding information.
16 The Reactor Systems Branch and the Electrical
17 Engineering Branch were totally involved and concur in
18 that conclusion. They were acceptable.

19 MEMBER STETKAR: Craig?

20 MR. HARBUCK: Yes.

21 MEMBER STETKAR: And this may be for
22 Detroit. I'm not a boiling water reactor guy, so I'm
23 not quite sure how things are done there. But do you
24 do scram-time tests for BWRs?

25 MR. SMITH: Yes.

1 MEMBER STETKAR: Do you do those at
2 minimum pressure in the scram accumulators? I mean,
3 that's one way of making sure that the minimum
4 pressure doesn't --

5 MR. HARBUCK: I don't know the answer to
6 your question. That's an operational thing. I just
7 don't know.

8 MEMBER STETKAR: Okay. Thanks.

9 MR. HARBUCK: I don't what the basis--

10 MEMBER STETKAR: Yes. I should have the
11 arguments about well, you know, we took it from the
12 ABWR and these rods are lighter --

13 MR. HARBUCK: Yes, but your question is a
14 little bit -- is just asking how do you -- during the
15 testing that may be discussed in the basis in the
16 specification that discusses --

17 MEMBER STETKAR: Well, I didn't look at
18 that. But it's just one of these things of assurance
19 for the actual as-built/as-operated plant. If you can
20 meet the scram-time tests with that pressure in there,
21 one would pressure that that's some sort of
22 verification that that limit is okay.

23 MR. HARBUCK: And should they determine
24 that a minimum pressure or a lower value is
25 acceptable, it's up to them to propose an amendment to

1 get that --

2 MEMBER STETKAR: Right. Right. I'm just
3 more concerned about is that value -- you know, if it
4 actually gets down to that value are you still okay
5 since it's sort of -- I don't want to use the term
6 "inferred" because it's stronger than that, but it's
7 a derived value, I guess.

8 MR. HARBUCK: Okay. The last slide had to
9 do with the Option 3. Now this ISG-08 was developed
10 during the design cert reviews and COL reviews for
11 South Texas and the ESBWR. And so that the items in
12 the tech specs that potentially needed to be resolved
13 using Option 3 were resolved within the context of the
14 design cert. So Fermi did not need to use the Option
15 3, however I just have listed what those items that
16 were fixed are and have to do with the status of the
17 two programs that are incorporated by reference in the
18 DCD. And those were the Setpoint Control Program and
19 then the Post-Accident Monitoring Instrumentation
20 Program.

21 It turns out when we wrote RG 1.98 Rev 4,
22 we wrote it in such a way that you have to have the
23 plant up and operating and already have taken the
24 procedures anyways for operating in order to -- for
25 abnormal procedures, emergency procedures in order to

1 determine what your Type A, B and C variable are as
2 defined in this new version. So in lieu of doing that
3 we said, well the RG itself which references an
4 industry document provides the methodology for
5 determining what those things are. So as long as the
6 actual requirements appropriate, we don't need to
7 include a list of instruments in the tech spec. We
8 can maintain them in accordance with this
9 administrative program. So that's how we handled the
10 post-accident monitoring on Fermi. And then on the
11 ESBWR

12 And then the Setpoint Control Program,
13 there is a COL item related to that, but it's handled
14 using Option 1 because it's just a reference to the
15 approved methodology. And so that's listed there
16 under the second bullet.

17 Okay. Last slide. Just briefly to mention
18 there were not very many RAIs on Chapter 16, but these
19 were the main ones. I believe some of these were
20 mentioned, some were not. But essentially I think the
21 key one is the one that's labeled #2. There was a
22 question about whether 30 amps is an indication of
23 full charge on float current was an appropriate value
24 since it was greater than what we've normally seen.
25 And so there was a response that demonstrated that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this value was an appropriate one. And do you have
2 anything to elaborate on that?

3 MR. SMITH: No, other than it was based on
4 vendor-supplied data.

5 MR. HARBUCK: Right. And Branch staff
6 looked at that, and actually it was their question.

7 Okay.

8 CHAIR CORRADINI: Can I ask about the
9 fourth bullet?

10 MR. HARBUCK: Yes. Sure.

11 CHAIR CORRADINI: So is this more control
12 room related or is this just -- I'm trying to
13 understand. Is this just inventory on site? What is
14 the 2.2.3-5 again? I don't remember from the --

15 MR. HARBUCK: I think this was a question
16 for more information concerning the Applicant's
17 conclusion about the need for --

18 CHAIR CORRADINI: Okay. So it's back to--

19 MR. HARBUCK: Yes, it's the same issue
20 before. Right.

21 CHAIR CORRADINI: -- that Dick had brought
22 up.

23 MR. HARBUCK: And it came up in the write-
24 up for this Chapter because there are some bracketed
25 items related to hazardous chemical protection.

1 And let's see --

2 CHAIR CORRADINI: So, to put it a
3 different way, it may not rise to a safety issue but
4 it may rise to good practice?

5 MR. HARBUCK: Right. I mean, there
6 certainly would need to be some means of responding to
7 any kind of an airborne --

8 CHAIR CORRADINI: That's fine. I just
9 wanted to make sure the two were linked. That's what
10 I was trying to --

11 MR. HARBUCK: Yes. And again, it's the
12 FSAR Section 6.4.5 has the evaluation description for
13 this issue.

14 There's one confirmatory item, just to
15 make sure we get in the next revision to the
16 application, just to make sure that the correct
17 revisions for these two typical reports are included.
18 The one for the setpoint methodology is correct. I
19 think the one for the P-T limits there was an update
20 right at the time of the latest revision, so that
21 still needs to be updated.

22 Okay. So conclusions and findings. We
23 find that the generic tech specs and bases have been
24 added, properly incorporated by reference. That the
25 COL items have been resolved in a described manner and

1 they're acceptable. And therefore, this Chapter of
2 the Fermi FSAR the tech specs and bases, plant-
3 specific tech specs and bases are acceptable and
4 complete for use in the operation of the unit.

5 And we also conclude it meets all of the
6 regulations that are applicable to the tech specs.

7 Questions?

8 CHAIR CORRADINI: Other questions from the
9 Committee? Charlie, John, any questions?

10 MEMBER STETKAR: No.

11 CHAIR CORRADINI: You guys are all right?

12 Okay. Thank you.

13 Why don't we take our break now and we'll
14 come back to Chapter 6. Is that correct, Adrian?

15 MR. MUNIZ: Yes.

16 CHAIR CORRADINI: Okay. Good. So we'll
17 take a short break until 10:30 a.m.

18 (Whereupon, at 10:11 a.m. off the record
19 until 10:27 a.m.)

20 CHAIR CORRADINI: Okay. Why don't we get
21 started and talk about Chapter 6.

22 MR. SMITH: Nick Latzy my Licensing
23 Supervisor is going to go through the Chapter 6
24 presentation.

25 MR. LATZY: Thank you, Peter. My name is

1 Nick Latzy. I'm the Engineering Supervisor for the
2 Fermi 3 project and today I'm going to be presenting
3 the Chapter 6 engineering and safety features.

4 On the first slide we'll see the sectional
5 breakdown of the Chapter. 6.4 and 6.6 contain
6 standard and site-specific COL information. Sections
7 6.1 and 6.2, 6.3 and 6.5 were all incorporated by
8 reference.

9 Next slide, please.

10 Section 6.4 on the Control Room
11 Habitability, the first COL item the procedures and
12 training for the control room habitability they
13 address the applicable aspects of NRC Generic Letter
14 2003-01 and are consistent with the intent of
15 Generic Issue 83.

16 The implementation milestones for the
17 training and procedures. Training programs are to be
18 implemented 18 months prior to fuel load and
19 procedures are developed six months prior to fuel
20 load.

21 For the next item, the Supplemental
22 Information site-specific we evaluated the impact of
23 a postulated design bases accident on Fermi 2 on the
24 Fermi 3 control room. We performed that evaluation by
25 using conservatively calculated atmospheric dispersion

1 factors at the Fermi 3 main control room intakes. We
2 performed a review of the Fermi 2 LOCA as described in
3 the Fermi 2 FSAR. And based on this evaluation and
4 review the resulting control room operator dose is
5 bounded by the Fermi 3 DBA.

6 The final bullet on that page for the COL
7 we performed a toxic gas analysis, as previously
8 stated, to confirm that the external release of
9 hazardous chemicals do not impact the control room
10 habitability. An off-site evaluation of potentially
11 hazardous off-site chemicals was performed in
12 accordance with RG 1.178, and that would be at a
13 distance of 8 kilometers or five miles from the Fermi
14 3 site. And this evaluation determined that there
15 were no significant impact to the Fermi 3 control room
16 from a postulated release of hazardous chemicals
17 stored or used off-site.

18 An on-site evaluation of potentially
19 hazardous chemicals was also performed with accordance
20 with RG 1.178. That habit analysis for nitrogen and
21 carbon dioxide shows a max concentration within the
22 control would pose no hazard for controlling
23 habitability.

24 Therefore, as previously stated and
25 discussed here, no Seismic Category 1 safety-related

1 toxic gas monitoring instrumentation was required.

2 MEMBER STETKAR: Nick, before you go to
3 the next slide, there's a statement in the FSAR that
4 says "calculations performed to evaluate the
5 habitability of the control room for accidental
6 releases of hydrogen or oxygen in the hydrogen water
7 chemistry system indicate control room personnel are
8 not subject to hazard or breathing air with
9 insufficient oxygen inside the control room due to a
10 release of hydrogen." That tells me that you've
11 determined that I can live in whatever environment is
12 created if I have a release of hydrogen from the
13 hydrogen water chemistry system. Did you look at
14 flammable or detonable concentrations of hydrogen in
15 either the control room or any of the surrounding
16 areas around the control room envelope that contain
17 all of the digital I&C equipment both safety-related
18 and nonsafety-related stuff?

19 MR. LATZY: Steve?

20 MR. THOMAS: This is Steve Thomas Black &
21 Veatch.

22 And as described in Section 6.4 we're
23 looking at, the explosion or the detonation or the
24 explosion at the storage facilities, and those are
25 located sufficiently far away so that it's not going

1 to impact --

2 MEMBER STETKAR: I understand that. I'm
3 talking about a leak from the stuff that's inside the
4 plant getting up to the control room.

5 MR. THOMAS: We did not -- I'll have to
6 get back to you on that one.

7 MEMBER STETKAR: And it's not your fire
8 hazards analysis --

9 MR. THOMAS: Right.

10 MEMBER STETKAR: -- because fire hazardous
11 analysis is generic for the DCD and it doesn't include
12 that whole system.

13 CHAIR CORRADINI: What sort of inventory
14 do you have within the plant?

15 MEMBER STETKAR: It's a hydrogen water
16 chemistry system, so it's a constant feed.

17 MEMBER ABDEL-KHALIK: That's probably a
18 lot more hydrogen for the generator coolers.

19 MEMBER STETKAR: Yes, but that's up in the
20 control room --

21 MEMBER ARMIJO: It depends what you put it
22 in where it's stored.

23 MR. SMITH: Alan or Gary, can you speak to
24 the hydrogen question?

25 CHAIR CORRADINI: You can get back to us

1 if you want, but I do think that it would be good that
2 we get a clarification on this.

3 MEMBER ARMIJO: When you do that, just
4 kind of give us an idea of where the system is, how
5 much hydrogen --

6 MEMBER STETKAR: I mean, I'm assuming
7 because the way the system is carefully worded that
8 it, indeed, the hydrogen can get from the system to
9 the control room because --

10 MEMBER ARMIJO: Not supposed to, but --

11 MEMBER STETKAR: Well, but it didn't say
12 it's -- in other cases they've sort of dismissed it
13 saying it can't get there basically. This one it says
14 you can't get a concentration that's enough to
15 essentially kill somebody because of respiratory
16 problems.

17 CONSULTANT WALLIS: But if it's enough to
18 displace the oxygen, it's probably enough for a bang.

19 MEMBER STETKAR: Huh?

20 CONSULTANT WALLIS: It seems to me that if
21 it's enough to diminish the oxygen so you can't
22 breath--

23 MEMBER STETKAR: No. They conclude you
24 can't get that amount, but at some smaller
25 concentration it could get warm in there --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CONSULTANT WALLIS: Yes, at some smaller
2 concentration --

3 MEMBER STETKAR: -- for a short period of
4 time.

5 CONSULTANT WALLIS: You might have an
6 ignition source in the control room.

7 MEMBER STETKAR: And, you know there are
8 sources of sparks and things.

9 MEMBER ARMIJO: Right, even before it got
10 there.

11 MEMBER STETKAR: And the key is that it's
12 not analyzed in their fire hazardous analysis because
13 it's an optional system that's installed plant-
14 specific. So the fire hazardous analysis, at least
15 the quick check I did, you know --

16 MEMBER ARMIJO: Isn't what it should have
17 been.

18 MR. SMITH: Well, we'll follow up.

19 MEMBER STETKAR: Okay. Thanks.

20 MR. LATZY: Next slide, please.

21 In Section 6.6 Preservice and Inservice
22 Inspection and Testing of Class 2 and Class 3
23 Components and Piping, the first COL item there's a
24 description of the PSI/ISI program description for
25 Class 3 and 3 components as provided in the DCD

1 Section 6.6. And the implementation milestones for
2 the PSI program are to be completed prior to initial
3 plant startup. And the ISI program is to be
4 implemented prior to commercial service.

5 The ISI program incorporates the latest
6 addition and addenda of the ASME code and 10 CFR
7 50.55(a) 12 months prior to fuel load.

8 Additionally, the flow accelerated
9 corrosion program description is provided in FSAR 6.7.
10 Can you go back to those? Thank you.

11 The FAC program is based on the EPRI
12 Guidelines of NSAC-202L recommendations for an
13 effective flow accelerated corrosion program.

14 The second bullet for the standard COL
15 item, the accessibility for non-destructive
16 examination of Class 2 and 3 austenitic and dissimilar
17 welds. As previously discussed this will be
18 maintained through procedures for design control and
19 plant modifications. These procedures will include
20 provisions to assure accessibility for inspections and
21 testing and ultrasonic techniques will be the
22 preferred NDE method for all PSI and ISI volumetric
23 examinations.

24 Is there any questions before moving on?

25 CHAIR CORRADINI: Other questions?

1 MR. LATZY: Next slide, please.

2 And the last slide on Class 2 and 3
3 components and piping the COL item was on system
4 leakage and hydrostatic pressure tests. These will
5 meet all requirements of ASME code for Class 2 and
6 Class 3 components including the limitations of 10 CFR
7 50.55(a).

8 And that concludes my presentation for
9 Chapter 6.

10 CHAIR CORRADINI: Any other questions from
11 the Committee? Okay.

12 MR. LATZY: Thank you very much.

13 CHAIR CORRADINI: Staff will join us up
14 front.

15 MR. ANAND: Good morning. My name is Raj
16 Anand. I'm one of the project managers working on the
17 Fermi 2 COL application. I thank Detroit Edison for
18 making their presentation on Chapter VI. The Staff
19 agrees with Detroit Edison's presentation.

20 I had planned to discuss with you Chapter
21 VI engineere safety features of the Fermi 3 COL
22 application. This SER has no open items. Section
23 6.1, Section 6.2, Section 6.3 and 6.5 are IBR
24 sections, which incorporate by reference with no
25 departure or supplement of the ESBWR DCD, Rev. 9.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Rulemaking for ESBWR DCD is in progress.
2 The topics of interest are Section 6.4, the control
3 room habitability, and Section 6.6, pre-service and
4 in-service instruction and testing of Class II and
5 Class III components and piping.

6 With this, I turn it over to Syed to go to
7 the next slide of control room habitability, Section
8 6.4.

9 MR. HAIDER: Thanks, Raj. Good morning,
10 my name is Syed Haider. I am a technical reviewer in
11 the containment and ventilation branch. I will
12 present the safety findings for Section 6.4 on control
13 room habitability systems, as documented by the staff
14 in the Fermi 3 FSAR.

15 The Fermi 3 FSAR incorporates Section 6.4
16 of the referenced ESBWR DCD, with the exception of two
17 COL items that I will present. A Section 6.4 related
18 supplemental item will be covered by David Brown from
19 the Siting and Accident Consequences Branch. Next
20 slide, please?

21 The standard COL item 6.4-1-A directs the
22 applicant to address the procedures and training on
23 control room habitability area. As required by the
24 DCD, the applicant has stated in the FSAR that the
25 operators are provided with training and procedures

1 for control room habitability that address the
2 applicable aspects of NRC Generic Letter 2003-01 and
3 are consistent with the intent of Generic Issue 83.

4 Training and procedures are developed and
5 implementd in accordance with Sections 13.2 and 13.5.
6 As discussed in FSAR Sections 13.4 and 13.5, the
7 applicant has identified both COL activities to track
8 three implementation milestones for operator training
9 and procedures for control room habitability.

10 These milestones include the development
11 of non-licensed plant staff training programs, reactor
12 operator training programs, and operator procedures.
13 The applicant has made commitments to achieve these
14 milestones at least six to eighteen months prior to
15 the scheduled fuel loading.

16 The staff concludes that the information
17 provided by the applicant for the standard COL item
18 6.4-1-A is acceptable.

19 MEMBER ABDEL-KHALIK: Now, in reviewing
20 this part of Chapter 6, did you as a reviewer know
21 that the applicant has opted to select the hydrogen
22 water chemistry option?

23 MR. HAIDER: Yes, I was. I was aware of
24 that. And in the Containment and Ventilation Branch,
25 we did not review the flammability aspects of hydrogen

1 for the control room habitability. Because our focus
2 was on inside the control room, while Chapter II
3 reviewers reviewed the dispersion and modeling, and
4 the phenomena that occurred outside the control room.
5 And inside the control room, the concentration never
6 went to the flammability -- never went high enough to
7 invoke toxicity or asphyxiation, that we were
8 concerned about.

9 MEMBER ABDEL-KHALIK: But not detonation?

10 MR. HAIDER: Not detonation.

11 MEMBER ARMIJO: What kind of levels of
12 hydrogen would be considered toxic if they got in
13 there? How much percent, or parts per million or
14 what's the toxic concentration that would concern you?

15 MR. HAIDER: I know that the general
16 asphyxiation limit for any gas is somewhere between
17 16,000 ppm percent or 16,000 -- depending on the
18 source that you draw this information from. But I
19 know --

20 CHAIR CORRADINI: What's the value again?
21 I'm sorry.

22 MR. HAIDER: 60,000 ppm to 76,000 ppm
23 depending on --

24 CHAIR CORRADINI: So 60,000-ish? So
25 almost any sort of gas?

1 MR. HAIDER: Yes, any gas. This is
2 asphyxiation. Because if you look at the OSHA
3 definition of asphyxiation, the standards define that
4 if the oxygen concentration in a space drops from
5 20.95 percent to 19.5 percent, then it's an oxygen
6 deficient environment. And that translates into
7 roughly seven percent of any gas.

8 CHAIR CORRADINI: So that's about six
9 percent by weight?

10 CONSULTANT WALLIS: Yes.

11 MR. HAIDER: By volume. By volume.

12 CONSULTANT WALLIS: Very strange.

13 CHAIR CORRADINI: By volume or by --

14 MR. HAIDER: Yes, by volume.

15 CHAIR CORRADINI: Oh, by volume? You said
16 -- I'm sorry. When you said ppm, I was guessing weight
17 ppm. It's not.

18 MR. HAIDER: No, no. No, ppms in this
19 context are really defined to the best of my knowledge
20 on volumetric basis.

21 CHAIR CORRADINI: Okay. So that's very
22 close to a flammability limit. Not that it matters
23 for what we're talking about, but I just wanted to
24 make sure I understood. So 60,000 in terms of by
25 volume.

1 MR. HAIDER: 60,000 in terms of volume.
2 That was the figure that was quoted by North Anna.
3 But if you look at what the Applicant's test quoted,
4 it's about 87.7 milligram per meter cubed. It
5 translates into about 76,000 ppm. I mean, I'm not
6 really --

7 CHAIR CORRADINI: I understand that.

8 MR. HAIDER: But that's the range.

9 CHAIR CORRADINI: So that's the limit and
10 then --

11 MR. HAIDER: Asphyxiation.

12 CHAIR CORRADINI: Excuse me. Okay.
13 Right. So then just to follow on Professor Abdel-
14 Khalik's question, so then were there calculations
15 done to show that they're well within that limit?
16 What I'm trying to understand is that's the limit so
17 what was the value that you compared to?

18 MR. HAIDER: You mean for hydrogen?

19 CHAIR CORRADINI: Yes.

20 MR. HAIDER: That what we screened out at
21 the Chapter 2 stage. We ran the analysis only for
22 nitrogen and carbon dioxide that whose concentration
23 exceeded the control room intake. So, in other
24 words--

25 CHAIR CORRADINI: So, I don't understand

1 when you say that was screened out. Can you kind of
2 explain a bit more about that?

3 MR. HAIDER: Yes.

4 MR. BROWN: David Brown. I'm with the
5 Siting and Accident Consequences Branches.

6 One of the responsibilities of my branch
7 to do that screening in Chapter 2.

8 CHAIR CORRADINI: Okay. Okay.

9 MR. BROWN: Our reviewer for Chapter 2 is
10 not here today.

11 CHAIR CORRADINI: Okay. So we can come
12 and return back to that?

13 MR. BROWN: Yes.

14 CHAIR CORRADINI: But can you at least
15 give us sort of a preview so we're clear what's --

16 MR. BROWN: The process is we would look
17 at hazards within five miles including on-site
18 hazards. I don't know precisely whether this system
19 was considered, I'd have to refer to the reviewer, to
20 see if the immediately dangerous to life and health
21 values are exceeded at the intake. If they are, then
22 we refer that to the Containment and Ventilation
23 Systems Branch, they could further analyze that.

24 CHAIR CORRADINI: Okay. So this is what
25 you mean by screened out? You guys did some sort of

1 analysis on both on-site and off-site --

2 MR. BROWN: Yes.

3 CHAIR CORRADINI: -- and this fell within
4 the bounds that they didn't have to pass it on?

5 MR. BROWN: Right. It may have, I'd have
6 to refer to the --

7 CHAIR CORRADINI: I get the main part now.
8 We'll remember that part.

9 MEMBER BROWN: Can I just make sure I
10 understand on what you just said?

11 CHAIR CORRADINI: Sure.

12 MEMBER BROWN: The hydrogen storage
13 facility is listed in the FSAR as to being 750 feet
14 away from the main control room. So you evaluate that
15 to screen that whether he needs to look at it, is that
16 correct?

17 MR. BROWN: Right.

18 MEMBER BROWN: I mean, you release the
19 entire thing and the wind blows it all up the intake.

20 MR. BROWN: Right.

21 MEMBER BROWN: Then you determine whether
22 the concentration is suitable for the Ventilation
23 Branch to have to evaluate that?

24 MR. BROWN: Right. We would look at the
25 explosion --

1 MEMBER BROWN: Yes, the explosion and/or--

2 MR. BROWN: --flammable gas type hazards
3 and asphyxiation or toxicity hazard all from the same
4 chemical, assuming the chemical posed all three
5 hazards we would look at all of those.

6 CHAIR CORRADINI: So let me actually
7 follow-up because Charlie asked the question that I
8 was thinking, which is the details of how the hydrogen
9 water chemistry thing is going to be physically placed
10 and designed for this plant is to be determined or has
11 been set? I assume it's more to be determined,
12 turning back to DTE?

13 MR. SMITH: I believe it's to be
14 determined.

15 CHAIR CORRADINI: Okay.

16 MEMBER BROWN: Well, the FSAR says "in
17 excess of 750 feet from the control room" both
18 hydrogen and oxygen storage facilities.

19 MEMBER STETKAR: That is the bulk storage
20 tank?

21 CHAIR CORRADINI: That's the bulk storage.

22 MEMBER BROWN: Yes, the bulk storage tank.

23 CHAIR CORRADINI: But I think what John's
24 point is that's not necessarily where the hydrogen
25 water chemistry would be taken from necessarily. It

1 depends on the --

2 MEMBER BROWN: I understand that part.

3 CHAIR CORRADINI: Okay.

4 MEMBER BROWN: I mean, I was just looking
5 at from the total release of all the stuff in the tank
6 for some reason. That's two football fields away.
7 Not a big, big distance.

8 CHAIR CORRADINI: Okay. I think we
9 understand now. We'll remember it.

10 MEMBER BROWN: Okay. For Chapter 2.

11 MEMBER STETKAR: Yes, they've looked at
12 the big storage tank. They've not looked at the
13 piping and releases within the pipe welds.

14 CHAIR CORRADINI: Right. Right. And
15 that's where John's question came from, right? Okay.
16 Keep on going.

17 MR. HAIDER: The second COL item 6.4.020A
18 directs the Applicant to identify and analyze
19 potential on-site and off-site toxic gas sources
20 within five miles of the plant to confirm that any
21 extended release of hazardous chemicals would not
22 impact the control room habitability.

23 The Applicant provide the site-specific
24 toxic gas information and evaluation to meet the
25 requirements of GDC 19 and the TMI Action Plan. The

1 Applicant used the RG 1.78 screening and analysis
2 criteria on various hazardous chemical sources that
3 will look at it on the off-site industrial facilities
4 and transportation routes, and on the Fermi 2 and
5 Fermi 3 sites.

6 Going through an RAI round with the staff
7 the Applicant identified a Fermi 2 cryogenic nitrogen
8 tank and a Fermi 3 carbon dioxide tank as potentially
9 hazardous. The Applicant's evaluation showed that the
10 concentrations of nitrogen or carbon dioxide outside
11 the control room at the control room habitability area
12 intake would exceed their asphyxiation or toxicity
13 limit allowed in RG 1.78. However, their
14 concentrations inside the control room will be
15 significantly lower than their allowable safety
16 limits.

17 The staff --

18 CONSULTANT KRESS: What is that?

19 MR. HAIDER: I'll explain that.

20 The staff reviewed the list of all
21 hazardous chemicals and their detailed evaluations
22 provided in the FSAR Section 2.2.3 and the related RAI
23 response and found the Applicant's conclusions to be
24 acceptable even though the Applicant used the HABIT
25 code to conduct the toxic gas analysis. The staff ran

1 the confirmatory analyses using both HABIT and ALOHA
2 codes and also considered the heavy gas effects. All
3 the HABIT and ALOHA ones were made with the extremely
4 conservative assumption that nitrogen and carbon
5 dioxide are instantaneously released as a vapor cloud
6 due to tank rupture.

7 The staff found that the safety margins
8 inside the control room habitability area were
9 enormous for both nitrogen and carbon dioxide
10 concentrations for all distances.

11 Investigator: "The maximum concentrations
12 of nitrogen and carbon dioxide predicted by both HABIT
13 and ALOHA codes inside the control room were much
14 lower than their asphyxiation or toxicity limits.
15 This finding is primarily due to the short residence
16 time for when the chemical cloud would be at its peak
17 concentration at the control room intake. Therefore,
18 the nitrogen and carbon dioxide release does not pose
19 any threat to the control room operators."

20 The staff concludes that the information
21 provided by the Applicant in the COL item is
22 acceptable and there are no significant control room
23 habitability impacts due to potential sources within
24 five miles of the plant. As a result, no Seismic
25 Category 1 safety-related toxic gas monitoring

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 instrumentation is required.

2 CONSULTANT KRESS: How do you determine
3 the residence time? Is it the wind speed?

4 MR. HAIDER: Actually we ran a sensitivity
5 analysis that changed wind speed -- changed the
6 temperature from minus 19 to 32 degrees celsius.

7 CONSULTANT KRESS: So you did a
8 sensitivity analysis?

9 MR. HAIDER: Yes. And also --

10 CONSULTANT KRESS: It's the worst end of
11 it?

12 MR. HAIDER: Exactly. And we also
13 considered a range of -- and everywhere the
14 concentration was somewhere from 100 -- but if you
15 look at the toxicity limit of carbon dioxide it is
16 40,000 ppm and the typical asphyxiation limit, which
17 is about 60,000 ppms to 75,000 ppms, everything by
18 order of magnitude smaller. So carbon dioxide and
19 nitrogen they are not threats.

20 So this finished my slide.

21 CONSULTANT KRESS: Under the second
22 bullet, the second sub-bullet it should say something
23 like for a short period of time. I mean, we would see
24 it long enough to make any difference.

25 MR. HAIDER: Yes, but technically it did

1 exceed and it did raise the red flag that the Section
2 review was supposed to come into to us.

3 CONSULTANT KRESS: Okay.

4 MR. BROWN: That is true.

5 CONSULTANT KRESS: You kind of lose that
6 when you read it.

7 MR. HAIDER: So that finishes my
8 presentation.

9 CHAIR CORRADINI: Any questions? Any
10 questions of Mr. Haider before we pass it on?

11 MR. HAIDER: No, I don't.

12 CHAIR CORRADINI: Questions? Okay.

13 MR. BROWN: I'm David Brown. I'm a
14 License Reviewer in the Siting and Accident
15 Consequences Branch. I'll talk briefly about the
16 consideration of radiological habitability in the Unit
17 3 control room, which has mainly two parts, first of
18 which is to ensure that the site metrology was bounded
19 by the metrology that was assumed for the DCD. And it
20 is. And so the control room does use that as reported
21 in the DCD are bounded for this site.

22 The Applicant also provided Supplemental
23 Information about the potential for a design bases
24 accidents at Unit 2 and its potential effects on
25 habitability at Unit 3. The staff evaluated that

1 concluding the chi over qs, the atmospheric diversions
2 that were calculated from Unit 2 to Unit 3. Agree
3 with the Applicant's conclusion that the design basis
4 accidents at Unit 2 are essentially bounded by those
5 at Unit 3. So the habitability criteria in GDC 19
6 continue to be met.

7 That's what I have on the radiological
8 aspects of 6.4. And that concludes our presentation
9 on 6.4 unless you have any questions.

10 CONSULTANT KRESS: What design basis
11 source term did you use?

12 MR. BROWN: Source terms that were
13 considered for the Supplemental Information were the
14 LOCA and at Unit 2.

15 CONSULTANT KRESS: However, it's been
16 thought the release over a longer period of time in
17 the second?

18 MR. BROWN: Right. This is essentially a
19 dose that can be incurred over 30 days.

20 CONSULTANT KRESS: Thirty days?

21 CHAIR CORRADINI: That's the integrated
22 time, but it's essentially a LOCA source term?

23 MR. BROWN: It's a LOCA source term.

24 CONSULTANT KRESS: Yes.

25 CHAIR CORRADINI: Other questions?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BROWN: Thank you.

2 MR. ANAND: I would request him to come
3 over.

4 CHAIR CORRADINI: Okay. I was trying to
5 understand. So somebody's going to have to change
6 out.

7 MR. BROWN: Well, I'll change out.

8 CHAIR CORRADINI: All right. Got it.
9 You look familiar.

10 MR. STEINGASS: Good morning, gentlemen,
11 again.

12 I'm going to talk about Section 6.6 of the
13 Fermi 3 COL FSAR. This section incorporates by
14 reference Section 6.6 of the ESBWR DCD Tier 2,
15 Revision 9 and provides additional information on the
16 following COL item.

17 I just want you to understand that this is
18 just a continuation of Section 5.2.4. Section 6.6
19 covers Class 2 and 3 components under the ASME
20 Section 11. And 5.2.4 was Class 1. So this is a
21 continuation of the PSI/ISI program.

22 Next slide, please.

23 Similarly -- yes, sir?

24 CHAIR CORRADINI: No. I was just going to
25 say watch out for the microphone.

1 MR. STEINGASS: To continue, COL 5.2-1-A
2 is a continuation of the COL information item that was
3 involved with the Class 1 components. So additional
4 information was provided by the COL Applicant for the
5 Class 2 and 3 components involving the ASME code and
6 the limitations under 10 CFR 50.55(a).

7 I've concluded that the additional
8 information agrees with the limitations for pressure
9 testing of Class 1, 2 and 3 components within 10 CFR
10 50.55(a), and therefore is acceptable.

11 Next slide.

12 Augmented Inservice Inspection.
13 Additional information was provided in Section 6.6.2,
14 provided a more detailed description of the PSI and
15 the ISI programs under Section 5.2.4.

16 Milestones for the program are added under
17 Section 13.4. That milestones involves a license
18 condition that states something to the effect that
19 these folks will provide to us within six months after
20 receiving their license, a detailed schedule that
21 indicates how the plant is going to be built for Class
22 1, 2 and 3 systems so that we can schedule our
23 inspections.

24 Let's see. And that's consistent with all
25 the other COL applicants that it's a license condition

1 to provide us a detailed schedule so that we can look
2 at all these systems as they're being built real time.

3 Finally, in Section 6.6.7.1 the Applicant
4 addresses the flow accelerated corrosion program.
5 Typically that's done in another area of the FSAR, but
6 since it's an augmented ISI program we've moved it
7 under Section 6.6. I did not evaluate the flow
8 accelerated corrosion program, but if you have any
9 questions about the flow accelerated corrosion
10 program, Dr. Greg Makar is here to address any of
11 those questions.

12 Next slide, please.

13 So, the commitment was made that under the
14 conclusion section of Section 6.6 that the ISI and the
15 PSI programs would be implemented or in fact
16 generated, so to speak, prior to plant startup. And
17 the staff concludes that the PSI and the ISI and the
18 flow accelerated programs, or more accurately stated
19 their program description meet the SRP guidance
20 provided at Section 6.6 of NUREG-0800 and is therefore
21 acceptable.

22 MEMBER SKILLMAN: Tim, my name is Dick
23 Skillman. I would like to ask a question.

24 MR. STEINGASS: Yes, sir.

25 MEMBER SKILLMAN: You communicated that

1 you did not review the FAC program description.

2 MR. STEINGASS: That's correct.

3 MEMBER SKILLMAN: Did I believe you?

4 Again, if I did, another gentleman did.

5 MR. STEINGASS: Yes.

6 MEMBER SKILLMAN: Is that an accurate
7 characterization?

8 MR. STEINGASS: Yes. There's the man.

9 MEMBER SKILLMAN: Thank you. I just
10 wanted to ensure --

11 CHAIR CORRADINI: Did you have a question
12 to the gentleman?

13 MEMBER SKILLMAN: No, I don't. I wanted
14 to make sure that it had been reviewed.

15 MR. STEINGASS: No. I reviewed Sections
16 6.6. And, Greg, which section is the flow accelerated
17 corrosion program under?

18 CHAIR CORRADINI: You got to come to a
19 microphone, please.

20 MR. MAKAR: I'm Greg Makar from the Office
21 of New Reactors Component Integrity Performance and
22 Testing Branch.

23 There's staff guidance and acceptance
24 criteria in both 10.3.6 and 6.6 of the SRP. And in
25 some cases we review the FAC program under 10.3.6.

1 And as Tim said, it's appropriate in this case to do
2 it under 6.6. It wasn't a COL item as augmented
3 inspection program for this DCD and was described in
4 this COL application in that section.

5 MEMBER SKILLMAN: Thank you.

6 CHAIR CORRADINI: Thank you.

7 MR. STEINGASS: Yes, sir.

8 Where are we at here? Thank you.

9 Similarly, with the Section 5.2.4 that it
10 was a continuation for Class 2 and Class 3 to ask
11 these folks to provide discussion about preserving
12 accessibility for the welds to meet the ASME code
13 requirements and the e-coverage requirements. So
14 therefore it makes sense that Section 6.6 apps that
15 they do the same for the Class 2 and 3 stuff.

16 The additional information discusses the
17 use of radiography to obtain the examination coverage
18 and basically it expounds on the fact that ultrasonic
19 examination is the approved method. But if coverage
20 cannot be obtained by ultrasonic examination, then
21 radiography will be used. The point being that the
22 staff wanted to make sure that the regulations are met
23 and that a 100 percent of the coverage is obtained as
24 required by the code because for this new fleet of
25 plants we are not going to accept relief requests from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the code requirements due to design and accessibility.

2 Is the one for everybody, Raj? Okay.

3 So we concluded -- or I concluded that the
4 additional information met the SRP guidance provided
5 in Section 6.6 of NUREG-0800 and is therefore
6 acceptable. Okay.

7 So, I'm going to conclude for all
8 respectfully Section 6.6. just so that we don't have
9 too many of the staff members getting out of their
10 chairs and running up here. Conclusion: The staff's
11 finding related to information provided by reference
12 is in NUREG-1966.

13 We reviewed the COL information items and
14 the additional information provided by the Applicant
15 in Chapter 6 of the COL FSAR and found those items to
16 be acceptable.

17 And finally, there are no open items
18 involved with our review of Chapter 6.

19 Are there any additional questions?

20 MEMBER SKILLMAN: Yes, I do. Dick
21 Skillman again.

22 MR. STEINGASS: Yes, sir.

23 MEMBER SKILLMAN: So, you've made a very
24 strong comment that for this new fleet there will be
25 no relief requests granted?

1 MR. STEINGASS: No, sir. For the initial
2 ISI interval. Okay?

3 MEMBER SKILLMAN: So can you tell us,
4 please, where is that codified on record, where is
5 that promulgated to the applicants, please?

6 MR. STEINGASS: The regulations state that
7 the plant will be designed and provided with access to
8 enable the performance of the ISI examinations. And
9 then the regulations also state something to the
10 effect that you're going to design the plant to the
11 latest addition and addenda of the code in effect
12 endorsed 12 months prior to fuel load. So if the
13 regulations say you're going to design to enable the
14 performance of an inservice inspection, why on earth
15 would I or anyone grant relief from the examinations?
16 You can't.

17 Now, for the second ten year interval
18 because the design's locked in, say for instance in
19 the next ten year interval the regulations change or
20 the ASME code requirements change and for a
21 complainant that's developed some kind of a new
22 failure mechanism but it's not designed to perform a
23 specific type of NDE that needs to be applied to that
24 component, well the regulations exclude for second,
25 third, fourth interval, or whatever, the designing for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 access because it's locked in.

2 I mean, for the first interval it's locked
3 it. You know ahead of time. You know what the
4 requirements are. You know what you got to design that
5 plant to in order to enable the performance of the
6 examinations. But ten years down the road don't know
7 and the regulations recognize that requirements may
8 change.

9 MEMBER SKILLMAN: Okay. If I can respond.
10 What I heard you say is is --

11 MR. STEINGASS: So -- well, let me finish.
12 I forgot to follow through.

13 So for the first ten year interval we
14 won't grant any relief period from a code requirement.
15 But later on for the second, third and forth we may.
16 They would be within their rights to ask for that,
17 granting relief.

18 MEMBER SKILLMAN: Is the regulation clear
19 that no waivers will be granted? That's a very strong
20 statement. I understand what it means from a practical
21 perspective if we've already poured the concrete and
22 the target is at eight feet in either direction from
23 a boundary, I find cutting out concrete may be is what
24 you're communicating.

25 MR. STEINGASS: I hear what you're saying.

1 I hear what you're saying.

2 MEMBER SKILLMAN: I think this carries
3 over to the previous discussion an hour ago when we
4 were asking about accessibility during the
5 construction process. And so it brings up a whole
6 agenda of --

7 MR. STEINGASS: Sure.

8 MEMBER SKILLMAN: -- ensuring that those
9 welds by golly are available for inspection.

10 MR. STEINGASS: To answer your question,
11 looking at the broad spectrum of the design centers,
12 some of the design centers say there will be no
13 requests for relief. And I like to see that.

14 Some of the design centers know that my
15 strong statements aren't supported by the regulation
16 and they have said we will make every effort to design
17 the plant to enable the performance of ISI, but there
18 may be unforeseen circumstances where we may request
19 relief, and I've had to accept that.

20 What we have done is at public meetings
21 and conferences senior management has made the strong
22 statements that we will be hard-pressed to entertain
23 granting of relief, but we all understand that there
24 may be limited instances where one may ask for it.
25 But part of that request for relief would have to show

1 us that they've made every effort to try and design
2 the limitation due to materials or type of NDE, or
3 construction and they don't want us for that.

4 So, the answer is it's not supported by a
5 regulation that we will not grant relief, but we've
6 made a pretty strong case throughout the industry and
7 in all the DCDs that you better design it to enable
8 the performance of ISI to meet the regulations. And
9 frankly, they can request exemption from any
10 regulation. You know, that's in there too.

11 MEMBER SKILLMAN: Thank you.

12 MR. STEINGASS: Yes, sir.

13 CHAIR CORRADINI: Other questions from the
14 Committee?

15 MEMBER ABDEL-KHALIK: Will the Applicant
16 promise to follow-up with Chapter 6 regarding the
17 possible from a control room habitability standpoint
18 detonation of hydrogen? Will the staff make the same
19 follow-up.

20 MR. McKIRGAN: This is John McKirgan,
21 Ventilation Branch.

22 Yes, the staff will follow-up on that as
23 well.

24 MEMBER ABDEL-KHALIK: Thank you.

25 CHAIR CORRADINI: Other questions?

1 Okay. At this point I'll thank the
2 Chapter 6 group and turn to Adrian. We're a bit ahead
3 of schedule. Given just who is coming, who is going,
4 is this lunchtime or is this start Chapter 17?

5 MR. MUNIZ: No. I think we want to delay
6 17 for after lunch. However, the staff would like to
7 address your previous questions, if possible.

8 CHAIR CORRADINI: Good. Okay. Good. All
9 right. So whoever needs to get up front, please do.

10 MR. ANAND: Thank you very much.

11 CHAIR CORRADINI: Thank you very much,
12 Raj. Thank you. You'll hang out, right?

13 MR. ANAND: Yes.

14 CHAIR CORRADINI: As their lone
15 representative?

16 Okay. Jerry?

17 MR. HALE: Okay. I think Joel has some
18 further information.

19 CHAIR CORRADINI: We're talking about the
20 materials spec question?

21 MR. HALE: Yes, Section 5.3.2. We're
22 going to try to pull the slide up if possible.

23 CHAIR CORRADINI: Okay. Just for a few
24 minutes ahead of schedule if we can clear this one up
25 or other ones, this is a good time to do it.

1 MR. JENKINS: Yes. I believe Member
2 Skillman had a question on the post combined license
3 activities. But before I start, I'd like to recognize
4 a colleague out in the audience who worked with me on
5 this section, Pressure-Temperature Limits. Mr. Steven
6 Downey heavily involved in the review. I would like
7 to answer Mr. Skillman's question, but Steve feel free
8 to jump at anytime if you would like.

9 CHAIR CORRADINI: He can come up, too. We
10 have a seat.

11 MR. JENKINS: I'll leave that up to him.

12 Let me read the post-combined license
13 activity again. "Prior to fuel load the pressure-
14 temperature limit curves will be updated to reflect
15 plant-specific material properties if required." And
16 the question hinged on what does the "if required"
17 mean.

18 Well, I want to start off with the way
19 that the pressure-temperature limit curves are
20 calculated. They're calculated from using a certain
21 methodology and based on material spec chemistries.

22 Now we know that the reactor vessel is
23 going to be constructed from ASME SA508 forgings and
24 ASME SA533 plates. And those specs have certain
25 limiting chemistries. And these limiting chemistries

1 are used along with the methodology to derive limiting
2 pressure-temperature curves. But at this time we
3 don't know what the actual chemistry from the procured
4 material is going to be.

5 So, for instance, the spec may give a
6 maximum of one percent nickel. But when they purchase
7 the material, it might be .5 percent nickel. So when
8 the Applicant purchases the material if they plug the
9 actual chemistries into the methodology that's been
10 approved, they're going to get different curves. And
11 so that's -- and it says "if required." On the off
12 chance that the material chemistries match exactly the
13 limiting spec chemistries, then your results are going
14 to be the same and you don't need to recalculate. But
15 the probabilities of that happening are very low.

16 And when the Applicant does the
17 recalculation they will let us know through a letter
18 and they will update the PTLR. As long as they don't
19 change their methodology we're not required to
20 reapprove the PTLR. If they change their methodology,
21 we're required to reapprove the Pressure-Temperature
22 Limits Report.

23 CHAIR CORRADINI: Does that help you?

24 MEMBER SKILLMAN: Maybe. I understand you
25 to say if they change their methodology, then you

1 review it. What if they find the material properties
2 are scandalously different?

3 MR. JENKINS: Scandalously different from
4 the spec?

5 MEMBER SKILLMAN: Yes.

6 CHAIR CORRADINI: I sure hope they don't
7 accept the vessel for installation.

8 MR. JENKINS: I would hope they're not
9 using out of spec material.

10 MEMBER SKILLMAN: I would hope so, too,
11 and that's why I asked about the "if required" hook
12 that's in that statement.

13 MR. JENKINS: Well, regardless of whether
14 the material is within spec or without of spec, if
15 it's different from the limits they absolutely have to
16 recalculate.

17 MEMBER SKILLMAN: Thank you.

18 MR. JENKINS: But I mean if they're out of
19 spec, that raises different questions.

20 MEMBER SKILLMAN: Yes, I assure you I
21 understand this very, very thoroughly.

22 MR. JENKINS: Right.

23 MEMBER SKILLMAN: I understand what it
24 means in terms of building the vessel and having the
25 pressure-temperature limits for the specific vessel.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. JENKINS: Right.

2 MEMBER SKILLMAN: But the phrase "if
3 required" triggered in my mind what would drive that
4 action? What is it that drives the action? And
5 you've answered it, and I thank you.

6 MR. JENKINS: Okay.

7 MEMBER SKILLMAN: But I assure you I am
8 very familiar with this. I'm curious how the staff
9 was going to handle the "if required" hook that is in
10 that phrase, hence my question.

11 MR. JENKINS: All right.

12 MEMBER SKILLMAN: Thank you.

13 MR. JENKINS: That's all I have.

14 MEMBER BROWN: You said "if they follow
15 the methodology." I'm going to bounce back. In other
16 words, you said it's a slim, very, very slim that they
17 won't have to recalculate if they will meet the
18 definitions within the DCD exactly or within whatever
19 the narrow band is?

20 MR. JENKINS: Yes.

21 MEMBER BROWN: And the comment or
22 statement was then that they then have to recalculate
23 and they submit that result and report back to NRC.

24 MR. JENKINS: Right.

25 MEMBER BROWN: But as long as they say we

1 used the same method you don't even have to look at
2 it. If they used the same method, you get the report
3 -- this is not a nasty comment.

4 MR. JENKINS: No, I know.

5 MEMBER BROWN: It's just a regulatory
6 you're not required to and you're not required to
7 answer them. In other words, you don't have to--

8 MR. JENKINS: We're not required to answer
9 them, that's correct.

10 MEMBER BROWN: And you may not even check
11 that they applied the methodology correctly since they
12 didn't do it, is that correct also? I mean, they just
13 say they followed the method that's --

14 MR. JENKINS: I think my colleagues have
15 some comments.

16 MR. DOWNEY: This is Steve Downey.

17 Yes, if they update their pressure-
18 temperature limits with the plant-specific materials
19 from the procured vessel, we don't have to review the
20 Pressure-Temperature Report, write a safety evaluation
21 or what have you. But when they submit that updated
22 information, we will check to make sure that the
23 methodology has not changed that would not trigger a
24 review.

25 MEMBER BROWN: I understand the

1 methodology issue. But I mean you don't even check to
2 see that the numbers that they plugged in and the
3 methodology they used you end up getting the same
4 results and nobody checks it. Whereas, when you were
5 doing the DCD you actually went through, or at least--

6 CHAIR CORRADINI: They audited it. They
7 didn't check every calculation. Let's be clear.

8 MEMBER BROWN: And here he didn't even say
9 they were audited. So I'm just -- you know, it was
10 audited at one time. It's just a matter of the numbers
11 changed and nobody outside DTE looks at it, has to
12 look at it or audit it or anything else unless they
13 change the methodology.

14 So, you answered my question.

15 MR. JENKINS: Okay.

16 MEMBER BROWN: I didn't say I agreed with
17 it; just you answered my question. Okay? Thank you.

18 MR. HALE: Any further questions?

19 CHAIR CORRADINI: Nothing for you guys.
20 So let me turn back to Adrian.

21 Those other things that you were going to
22 get, or I have nothing immediate that you were going
23 to get back to us on. There are some other things
24 that are going to take longer. But does GEH or anybody
25 have any other things that they want to mention at

1 this point or are we going to stop for the moment?

2 MR. MUNIZ: I think we are going to stop
3 for the moment.

4 CHAIR CORRADINI: Okay. So we'll get back
5 together after lunch at 12:30. So we'll take a lunch
6 break. Be back at 12:30. Thanks.

7 (Whereupon, at 11:20 a.m. a lunch recess
8 until 12:28 p.m.)
9
10
11
12
13
14
15
16
17
18
19
20
21
22

A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N

12:28 p.m.

CHAIR CORRADINI: Okay. Why don't we get started? We're going to start off with Chapter 17 from Detroit Edison.

MR. SMITH: Next page.

As we've done in other sections, these are the sections that we had COL items. The rest of them were Supplemental Information of Chapter 17. So next one, and I'll go through each one.

So Section 17.1 the Quality Assurance During Design. It ends up referring to Chapter 17.5, which is the Quality Assurance Program applied during the COLA preparation and site-specific design activities. And that ultimately ends up referring to the Quality Assurance Program description that's in 17.88.

Next slide, please.

Quality Assurance During Construction and Operations. Again, also refers to 17.5 or the QA Program. And that also refers to the 17.5 for the QA Program applied to design activities required to adopt the certified design deferment for a specific plant implementation.

Everything's governed by the same Quality

1 Assurance Program description is, I think, the bottom
2 line here.

3 17.3, which is the Quality Assurance
4 Program description, it refers to Section 17.5 again
5 to provide a Quality Assurance Program description
6 describing the overall project or assurance program.

7 So in 17.4, this is where we get into
8 Reliability Assurance Program during the design phase.
9 And we addressed an RAI associated with this and we
10 had a standard COL item that basically said we had no
11 site-specific structure systems or components that
12 would be within the scope of the Reliability Assurance
13 Program beyond those that are already included within
14 the scope of the DCD.

15 We had a description of the Operational
16 Reliability Assurance Program that referenced other
17 programs. There was an issue identified with the
18 standard COL item as far as its implementation date
19 for the Design Reliability Assurance Program in that
20 it had an original implementation milestone of prior
21 to fuel load, which when you look at it in retrospect
22 doesn't make any sense. But I think my predecessor
23 also had had that same foible in it. So we went
24 through the round of RAIs and the ultimate resolution,
25 again, was that there are no site-specific structure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 systems and components beyond the scope of the DCD
2 that should be in the Design Reliability Assurance
3 Program.

4 MEMBER STETKAR: There is a silence here.
5 Okay. I just wanted to make sure everybody stopped
6 talking.

7 I'm going to hold off. I have an opinion
8 on the site-specific issue of that. I've got a
9 different question, though. It's my understanding, I
10 went back and I looked a Revision 9 of the DCD last
11 night just to make sure I didn't misspeak.

12 It's my understanding that the DCD process
13 to populate the RTNSS list, essentially the scope of
14 things that we're talking about here, used numerical
15 screening criteria from the risk assessment and the
16 values of those screening criteria were Fussell-Vesely
17 importance greater than or equal to 0.01 or a Risk
18 Achievement Worth greater than five. And that's
19 documented in DCD Rev 5, Rev 9 Section 17.4.26. So
20 those were the numerical values that they used.

21 We questioned GEH about those numerical
22 values. We questioned the staff about those numerical
23 values to some extent during our review of the DCD,
24 and I don't need to go into details of those
25 discussions.

1 The question is that not all, because I'm
2 aware of one that I believe with the exception of
3 ESBWR and perhaps one other is one center, everybody
4 else in the design certification process is using
5 screening criteria of Fussell-Vesely importance of
6 .005, a factor of two lower and a Risk Achievement
7 Worth of two, a factor of 2½ lower. Meaning that if
8 they apply those criteria in principle to your RTNSS
9 list or the population of equipment, you're
10 controlling them to the Reliability Assurance Program
11 would be larger -- could be larger -- might be larger.
12 We don't know, you know because we haven't actually
13 seen those numerical values or how they were done.
14 There's also qualitative input from a group, so we
15 didn't go and investigate that process.

16 Now the question I have is you committed
17 to the Maintenance Rule Program, obviously.

18 MR. SMITH: Yes.

19 MEMBER STETKAR: You've committed to an
20 NEI document basically that describes the template for
21 the Maintenance Rule Program. To my knowledge
22 everybody who has applied the Maintenance Rule Program
23 uses the screening criteria .005 and 2.0. The
24 question is when you transition from this list of
25 things that you've included from the DCD by reference,

1 incorporated by reference, to a Maintenance Rule
2 Program will you have different screening criteria and
3 what implications does that have about this transition
4 of the reliability assurance from the generic DCD to
5 a plant-specific operating Reliability Assurance
6 Program? That's sort of the generic concern.

7 Now a specific question that you may have
8 to go back what screening criteria is Unit 2 using?

9 MR. SMITH: I don't know offhand. Sorry.

10 MEMBER STETKAR: Okay. I'd be really
11 curious because --

12 CHAIR CORRADINI: You're not just look for
13 a value, you're looking for consistency?

14 MEMBER STETKAR: Both, indeed, yes. Yes.
15 Because if something is important, you know it's a
16 relative importance measure. If something has this
17 relative importance of .005 to risk at Unit 2 and
18 that's deemed as important, why should something that
19 is of equal relative importance on Unit 3 not be
20 deemed also risk-significant regardless of what your
21 absolute measure is? So I'm looking for this relative
22 thing, because I'm aware that most -- I can't say
23 everybody because I obviously haven't looked at
24 everybody in the Maintenance Rule Programs. But every
25 time I see those numbers, they're the .005 Fussell-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Vesely and 2.0 for Risk Achievement Worth. So that's
2 sort of my question that, you know moving from this
3 point forward do we run into inconsistencies perhaps?

4 MR. SMITH: Do you have a comment?

5 MR. MILLER: Okay. You know, we did
6 discuss this at pretty good length during the DCD
7 discussions, right? And I believe at that point we
8 mentioned that if you use the standard values with a
9 new plant with very low core damage frequency, then at
10 one half of one percent of the importance gets you
11 down to where essentially everything that's in the PRA
12 model is now risk-significant. And the concern there
13 was, which is a valid concern for the Maintenance
14 Rule, is you want to differentiate low risk and high
15 risk. If you have everything in the high risk, then
16 your resource allocations are not necessarily --

17 MEMBER STETKAR: And the Maintenance Rule
18 tends to throw everything into the high risk category.

19 MR. MILLER: Yes.

20 MEMBER STETKAR: Because it's just easy
21 enough to do that.

22 MR. MILLER: Yes. So because PRA is one
23 part of the Maintenance Rule, right, and that there
24 are other criteria deterministic that all get wrapped
25 up by the expert panel, then it's really the expert

1 panel with the NEI guidance is the final deciding
2 factor on it.

3 MEMBER STETKAR: Yes, I understand that.
4 And I think where we left on the DCD is we took a look
5 at the list of things that are cited in, I think, it's
6 19A of the DCD, and that list at least qualitatively
7 seemed reasonable and since we weren't making any
8 progress on the numerical screening values. So, sort
9 of the reasonableness of that list I think was the
10 basis for our coming to a conclusion that it was
11 probably okay for the DCD. But I'm now a little bit
12 more concerned. You know, there's this whole issue of
13 D-RAP versus -- D- versus O-RAP versus Maintenance
14 Rule. So this transition process going forward I want
15 to understand a little bit more because it is in the
16 context of sort of a couple of different parts of
17 Chapter 17, but it is addressed in Chapter 17.

18 MEMBER ABDEL-KHALIK: John, I'm sort of
19 curious as to your concern about consistency with Unit
20 2 given that both units will have totally different
21 risk profiles.

22 MEMBER STETKAR: I don't care what the
23 risk profile is. I care about if something is deemed
24 to be risk-significant -- let me go away from the
25 absolute numbers so when we talk about numbers we

1 understand.

2 If something contributes ten percent of
3 the risk of my plant and I determine that that is
4 risk-significant, then if something that is ten
5 percent of the risk at my plant, something is ten
6 percent of the risk at your plant. You got a PWR, I
7 got a BWR. It doesn't make any difference; it's a
8 determination that something that accounts for ten
9 percent of the risk is determined to be risk-
10 significant regardless of the absolute value, whether
11 it's ten to the minus two core damage frequency or ten
12 to the minus 20 core damage frequency --

13 MEMBER ABDEL-KHALIK: And I'm not sure I
14 agree with that.

15 MEMBER STETKAR: Okay. But there are
16 differences of opinion and that gets into the whole
17 risk method --

18 CHAIR CORRADINI: That's where we had our
19 fun discussion previously.

20 MEMBER STETKAR: That's right. That's
21 right. I mean, they understand, and it's honestly a
22 little bit more of a concern for me in terms of
23 transitioning from the DCD RTNSS list and what
24 criteria were applied to populate that list. And if
25 you're wholesale adopting the Maintenance Rule Program

1 which has a lot of history now in terms of consistency
2 of application and programmatic backing, if there are
3 differences in those selection criteria, you know in
4 principle you could get into the Maintenance Rule and
5 say "Oh, my God, you know we have to either change the
6 population of the equipment that's under the
7 Maintenance Rule or do something about categorizing
8 things in high risk or low risk categories, or
9 something. So I'm curious about how that's going to
10 be done so that we avoid this notion of, you know a
11 step change, for example from the certified design
12 RTNSS list versus the eventual Reliability Assurance
13 list.

14 MR. MILLER: So I understand you, is that
15 the question?

16 MEMBER STETKAR: The question is how will
17 that list of equipment, what criteria will be used
18 going forward, numerical criteria? Because there's
19 some bullets in there that says, you know obviously
20 the risk importance measures, they're not cited in the
21 FSAR. It's simply a goal if it says if it's one of
22 the attributes that you use, and it is. It's only one
23 of the attributes. But it's the only numerical. How
24 will they be used at Firma Unit 3 going forward when
25 you transition from the DCD RTNSS list that you've

1 incorporated by reference at least for the COL going
2 forward into the Operating Reliability Assurance
3 Program or, you know the Maintenance Rule.

4 MR. MILLER: Okay. Well if I can just
5 state, that whole process of course is directed by 10
6 CFR 50.65, right? So that it would be subject to
7 inspection by that. And there they recommend you
8 follow a certain guidance. The decisions at that
9 point would be made by DTE and their expert panel.
10 And they have the ability through their guys as to
11 what they decide on what is high and low risk-
12 significant.

13 MEMBER STETKAR: I mean, you know
14 obviously floating around here in the background is
15 suppose that panel when they do that determines that
16 it is, I'll use the word "prudent" to double the size
17 of the list of equipment that's in the Maintenance
18 Rule Program? What implications are there then
19 looking back? Should there have been some sort of
20 quality assurance placed on all of your nonsafety
21 Quality Assurance Program in terms of procurement of
22 those components at this stage of the game? You know,
23 which is the whole reason why the staff wanted these
24 claims about do you have any site-specific items at
25 the COL stage so that they could be tracked.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MILLER: Okay. So what you're talking
2 about is --

3 MEMBER STETKAR: I just want to make sure
4 that there's going to be a consistent approach going
5 forward and that people have thought about that.

6 MR. MILLER: All right.

7 MEMBER STETKAR: And how you're going to
8 wrestle with that. Because, as you said, in principle
9 if you do apply the numerical values that I cited, the
10 RTNSS list as it exists now could be -- I don't know
11 how much larger it would be. I honestly don't.

12 MR. MILLER: The D-RAP list includes RTNSS
13 and risk-significant, just for verification.

14 MEMBER STETKAR: Okay.

15 MR. MILLER: Yes, I know what you're
16 talking about. Okay.

17 CHAIR CORRADINI: Okay? Let's move on.

18 MEMBER STETKAR: I don't think we're going
19 to go through it today.

20 CHAIR CORRADINI: We should move on.

21 MEMBER STETKAR: As long as they
22 understand the kind of concern, we got it. So,
23 thanks.

24 MR. SMITH: All right. Next slide.

25 So 17.5 Quality Assurance Program

1 description during design certification, Early Site
2 Permits and new license applicants. So we report to
3 the DCD Section 17.1 for the Quality Assurance for the
4 design certification activities. And we've provided
5 a summary of quality assurance applied during the
6 preparation of the Fermi pre-COLA and the QAPD for the
7 plant-specific implementation -- plant-specific
8 implementation, construction and operations follows
9 the NEI template on Quality Assurance Program
10 description.

11 And then finally the Maintenance Rule
12 Program which we've touched on a little bit. Again,
13 we've incorporated the generic NEI template for new
14 plants and we've described them as supplements, the
15 relationships with other programs and we also have a
16 reference to the Cable Monitoring Program that we
17 talked about when we talked about Chapter 8 in the
18 last meeting.

19 And that's all I have in Quality Assurance
20 in Chapter 17.

21 CHAIR CORRADINI: Questions by other
22 members? Okay.

23 Let's move on to the staff. Jerry, are
24 you going to kick us off.

25 MR. HALE: We're here to present SER

Chapter 17 with no open items, Quality Assurance. I'm here with George Lipscomb and Todd Hilsmeirs. They'll be presenting the site-specific portions of this.

Section 17.0 Introduction. 17.1 Quality Assurance During Design. 17.2 Quality Assurance During Construction and Operations. 17.3 Quality Assurance Program Description. These sections were all IBR. Some of this will also be discussed later as we move into the 17.5, the Quality Assurance Program Description.

So, moving right along to 17.4 the Reliability Assurance Program with Todd Hilsmeier.

MR. HILSMEIER: Thank you, Jerry.

FSAR Section 17.4 incorporated by reference Section 17.4 the ESBWR DCD and also addressed the two COL items, which will be discussed in the next two slides.

Section 17.4 of the SER has no open items and one notable confirmatory item related to COL item 17.4-1-A on the site-specific list of risk-significant SSCs.

Next slide.

This slide presents the staff's review of COL item 17.4-1-A. Under this COL item the list of risk-significant SSCs in the DCD or the RAP list

1 should be updated for the site plant-specific
2 information and design features. And in the FSAR the
3 Applicant specified a commitment to address the COL
4 item prior to initial fuel load. However, this should
5 be addressed prior to the detailed design in
6 construction phases of the plant because the
7 nonsafety-related RAP SSCs are subjected to the
8 Quality Assurance controls in accordance with SRP
9 Section 17.5 Part D.

10 Therefore the staff proposed an RAI
11 requesting the Applicant to update the RAP list for
12 site and plant-specific information and design
13 features. And in response to the RAI the Applicant
14 stated that the Fermi RAP list is incorporated by
15 reference to the DCD and that new additional RAP SSCs
16 were identified because the ESBWR PRA bounds the
17 Fermi's site and plant-specific information and design
18 features. And this was confirmed under the Chapter 19
19 review.

20 Furthermore, no departures from the DCD
21 impacted the PRA or RAP list.

22 And lastly, the RAP SSCs are subjected to
23 the Quality Assurance controls in accordance with the
24 Quality Assurance Program description. And then the
25 staff found Applicant's response was acceptable and

1 the FSAR would be revised accordingly, which is
2 Confirmatory item 17.04-2.

3 MEMBER STETKAR: Todd, when I read through
4 the section of the FSAR I think there was also a
5 mention that there's a -- and I think it was repeated
6 in the SER during the discussion. I don't have it
7 right here in front of me. But something to the
8 effect that the list of risk-significant SSCs will be
9 confirmed via ITAAC. The quote actually is in your
10 SER.

11 MR. HILSMEIER: Right.

12 MEMBER STETKAR: What does that mean "will
13 be confirmed via ITAAC"? That means after the COL
14 before fuel load somebody goes out and confirms the
15 list of risk-significant SSCs.

16 MR. HILSMEIER: Right.

17 MEMBER STETKAR: That sort of feeds into
18 a little bit of what I was just talking about, that at
19 some point between the COL and fuel load somebody will
20 confirm, whatever that means, the list of risk-
21 significant SSCs. The Applicant, or at that time the
22 Licensee, will then transition into a Maintenance Rule
23 Program that has a list of things that are monitored
24 under the Maintenance Rule.

25 MR. HILSMEIER: Right.

1 MEMBER STETKAR: So I'm curious about what
2 that word "confirm" means and how that transition
3 process works, and more importantly from the staff
4 perspective. I was just mentioning suppose during
5 either that confirmation, whatever that means, or
6 during the implementation of the Maintenance Rule
7 Program the list gets bigger?

8 MR. HILSMEIER: Right.

9 MEMBER STETKAR: What implications are
10 there to the staff? Is that a concern?

11 MR. HILSMEIER: As we discussed in many
12 previous ACRS meetings, that RAP list --

13 CHAIR CORRADINI: Nice going, but the
14 Detroit people weren't here to hear it, so they can
15 hear it.

16 MR. HILSMEIER: Yes. It's a live list, so
17 as updates are made to the PRA or design changes made
18 to the plant, the RAP list needs to be updated. And
19 that's part of D-RAP process. And the D-RAP ITAAC the
20 main purpose is to ensure that the RAP SSCs are
21 subjected to the D-RAP activities. And if we inspect
22 that D-RAP ITAAC, we would also be ensuring that the
23 D-RAP list is kept up to date since it is a live list.
24 And that's what I interpret as the confirmed.

25 MEMBER STETKAR: I think the original

1 process envisioned that the list would start out this
2 big because there is a lot of uncertainties in
3 simplified PRA.

4 MR. HILSMEIER: Right.

5 MEMBER STETKAR: And as you got more into
6 the design, more design details, more refined PRA that
7 the inference was that perhaps the population of
8 equipment in that list would reduce such that, you
9 know you might be conservatively applying QA
10 requirements during the initial phases of procurement
11 that perhaps you could lax later.

12 MR. HILSMEIER: Yes.

13 MEMBER STETKAR: I don't think the process
14 originally envisioned that it might start out small
15 and get bigger.

16 MR. HILSMEIER: That can happen, and for
17 some design centers it most likely will happen because
18 the design certification developed a very conservative
19 list of risk-significant SSCs.

20 CHAIR CORRADINI: Does "conservative" mean
21 smaller than it might be or does "conservative" mean
22 larger than it should be?

23 MR. HILSMEIER: Certainly that the design
24 certification list is larger than it most likely could
25 be. And for the very early design center, one of the

1 first ones, the list is smaller than what it is
2 expected to be. And so --

3 CHAIR CORRADINI: And not just this design
4 center?

5 MR. HILSMEIER: No, not this design
6 center. I don't know if I should say the design
7 center.

8 CHAIR CORRADINI: No, no, no, no.

9 MEMBER STETKAR: We sort of know which one
10 it is.

11 CHAIR CORRADINI: Yes, we're aware.

12 MR. HILSMEIER: However, the COL that's
13 referencing that design center has a process to update
14 the list, which will make it bigger. For the ESBWR I
15 expect the list to stay relatively the same, not
16 change too much.

17 CHAIR CORRADINI: But John's question, I
18 mean this is a whole realm that I don't get. But
19 John's question is if something wasn't on the list but
20 falls into the list by this analysis, just a thing --

21 MR. HILSMEIER: Right.

22 CHAIR CORRADINI: -- then how do you kind
23 of back out the QA relative to what wasn't there and
24 now it --

25 MR. HILSMEIER: The Applicant, or at this

1 time the Licensee, would need to ensure that the
2 quality assurance controls are met for any new RAP
3 SSCs added.

4 CHAIR CORRADINI: And back in time, right?

5 MR. HILSMEIER: Right. They would need to
6 make sure that -- an analogy would be similar to like
7 the commercial dedication process. Taking a
8 commercial piece of equipment and ensuring that it
9 meets quality assurance controls. A similar process
10 to that.

11 CHAIR CORRADINI: Okay.

12 MR. HILSMEIER: You raised a point during
13 the Applicant's presentation about Maintenance Rule
14 using risk-important criteria as different from the
15 ESBWR. And that was in my mind when we reviewed the
16 ESBWR. And it's on my mind, I mean it's not just
17 applicable to Maintenance Rule and RAP.

18 In PRA-land there's different
19 methodologies for identifying risk-significant
20 components for different applications. Like the 10
21 CFR 56.09 process has one methodology for identifying
22 risk-significant SSCs. The Maintenance Rule has
23 another process. So there's a lot of inconsistencies.

24 CHAIR CORRADINI: Okay.

25 MR. HILSMEIER: Office of New Reactors has

1 an ongoing effort to update our endorsements of NUMARC
2 93-01 and 10 CFR 50.69 for new reactors to address
3 these issues like the different risk-important
4 measures that are used between new reactors and
5 operating reactors. That's an ongoing effort. And so
6 it's possible that for NUMARC 93-01 it may be updated.

7 MEMBER STETKAR: But at the moment, I mean
8 they've essentially incorporated because they've
9 incorporated any 7-A, or whatever it is, which
10 incorporates NUMARC 93-01, it references it.

11 MR. HILSMEIER: Right. Right.

12 CHAIR CORRADINI: And so right now Detroit
13 is tied into whatever is in those documents.

14 MR. HILSMEIER: Right.

15 CHAIR CORRADINI: Because that's basically
16 what they characterize their Maintenance Rule Program
17 as.

18 MR. HILSMEIER: Yes. And it shouldn't
19 interfere with the Maintenance Rule process because
20 basically the SSCs in scope of Maintenance Rule would
21 be the RAP SSCs which uses a RAW of 5 and a Fussell-
22 Vesely of .001. But then it would also include SSCs
23 based on NUMARC 93-01 which is a RAW of 2 and a
24 Fussell-Vesely .005.

25 MEMBER STETKAR: Right. And then -- well,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you've said enough. You've at least given me some
2 confidence. The staff is obviously aware of the
3 issue.

4 MR. HILSMEIER: Yes.

5 MEMBER STETKAR: And it's evolving,
6 apparently.

7 MR. HILSMEIER: The next slide presents
8 the staff's review of COL item 71.4-2-A. And under
9 this COL item the Applicant should describe a process
10 for integrating RAP into the operational programs to
11 maintain their reliability, the availability of the
12 RAP SSCs during plant operation. And the Applicant
13 proposed to integrate RAP into the Maintenance Rule
14 Program consistent with RG 1.160 which endorses NUMARC
15 93-01. And also the Applicant proposed to integrated
16 RAP into the Quality Assurance Program in accordance
17 with the Quality Assurance Program description. And
18 also integrate RAP into inservice inspection,
19 inservice testing, surveillance testing and
20 maintenance programs. And the staff found this
21 process to be acceptable and meets recommendations
22 contained in the RAP guidance.

23 And the next section is Section 17.5 that
24 will be presented by George.

25 MR. HALE: Are there any questions on the

1 Reliability Assurance Program?

2 CHAIR CORRADINI: I think we're okay.

3 MR. LIPSCOMB: I'm George Lipscomb, Office
4 of New Reactors in the Quality and Vendor Branch.

5 I was asked to talk for just a few minutes
6 to try to answer a question from earlier. Do you want
7 to go ahead and do that first before I go onto 17.5?

8 My understanding of the question, I wasn't
9 here when it was asked, but my understanding of the
10 question had to do with what types of steps is the NRC
11 taking, what kind of a plan down the road for how
12 we're going to look at receipt of safety-critical
13 items. And I think the example I was given was like
14 a reactor pressure vessel. And so that's my
15 understanding of the question, so hopefully --

16 CHAIR CORRADINI: Anybody want to hone
17 that question? I think you got it approximately
18 right.

19 MR. LIPSCOMB: Approximately right?

20 CHAIR CORRADINI: Yes.

21 MR. LIPSCOMB: Sound good?

22 CHAIR CORRADINI: Yes.

23 MR. LIPSCOMB: Okay. So basically it's
24 going to be a combination of inspection activities
25 from the NRC perspective, because there will be

1 regional folks, residents that will be site. What
2 we'll be using is a inspection manual chapters.
3 There's primarily going to be the ITAAC procedure,
4 which falls under inspection manual chapter 2503. But
5 then there's also the program part of it with the
6 Quality Program which falls under 2504.

7 Primarily, if you're looking at the
8 receipt of something, that would be under a quality
9 program, an Appendix B program. We would be looking
10 at in the ITAAC matrix. And to give you an example of
11 how we would be doing that from a reactor pressure
12 vessel example if you look at inspection procedure 65-
13 001 there's a lot of attachments to that. It's a
14 fairly big matrix, if you want to think of it that
15 way, where there's about 20 different areas that get
16 into the design, those kinds of things. And then the
17 other part of the matrix has to do with how you're
18 going to look at things: The verification, the
19 receipt if you will.

20 So, these attachments within 65-001 have to do
21 with the specific inspections.

22 So to give you an example for like a
23 pressure vessel if you were to pull the inspection
24 procedure for that and take a look at the various
25 areas under ITAAC, you'd be looking at verifying that:

1 The purchased RPV and internal components
2 were in accordance with the design, that's one area;

3 That the RPV was properly stored and
4 handled in accordance with approved procedures;

5 The install was within accordance with
6 design drawings;

7 That the procedures for protecting the
8 installed vessel were being followed.

9 So those are kind of examples along with
10 the documentation and identification of problems that
11 would go with that. So that would be kind of an
12 example of how we as the NRC would be providing that
13 oversight. Of course, then the Licensee or the
14 Applicant -- the Licensee at that point would have the
15 primary responsibility under Appendix B with our
16 oversight.

17 Does that kind of answer the question?

18 CHAIR CORRADINI: It does for me.

19 MEMBER ARMIJO: Pretty straightforward.

20 CHAIR CORRADINI: Yes.

21 MR. LIPSCOMB: Okay. For 17.5 I just want
22 to take a couple of minutes and talk about the
23 contents of the application, go into what we did for
24 review and then the conclusions that we drew from that
25 review.

1 As far as the contents, by reference the
2 ESBWR DCD Section 17.5 is incorporated. There are
3 three COL informational items. They basically all have
4 to do with putting together a program for the various
5 different phases whether it's design or construction
6 and operations. And then there is a supplemental
7 information, Supplement 17.5-2 which provides quite a
8 bit of amplifying Quality Assurance Program
9 information and the time period that that information
10 is supplied by the Applicant for us from the
11 beginning of the project in January of 2007 through
12 December of 2009.

13 One important item of note is that the
14 QAPD that was supplied is based on the NEI template,
15 NEI 06-14A, Revision 7. And that particular revision
16 the staff determined that was acceptable format and
17 adequate guidance for a QA Program to meet the
18 requirements of Appendix B. And that's documented by
19 a staff SER.

20 Next slide.

21 So far as the review if you want to think
22 about we kind of looked at two different areas, if you
23 will. One is the QAPD itself and since it's based on
24 the NEI template, if there was deviations from that
25 approved template that the staff had looked at.

1 And then the second area had to do with
2 some areas that were kind of outside the scope of that
3 QAPD. These might be, like, preapplication
4 activities. And to give you an example it would be,
5 like, did it meet the intent of RG 1.206, which I'll
6 go over in a few minutes, and also do we have adequate
7 assurance that Appendix B was met. So we used a
8 combination of both licensing RAIs and inspection
9 activity to take a look at those two main areas.

10 So, to give you an example of the first
11 couple of bullets, first like three bullets on here,
12 have to do with the QAPD. We compared the QAPD to the
13 NEI template, looked for deviations from the template.
14 As part of that we were confirming that the COL items
15 have been addressed and the ESBWR DCD was further
16 addressed by the Applicant. And that it had adequate
17 program guidance.

18 So, those three areas were handled kind of
19 in the review of the QAPD. And of the RAIs we issued,
20 probably about half of them were issued in that
21 particular area.

22 The other two bullets have to do with the
23 other areas kind of outside, if you will. One of them
24 was meeting the intent of RG 1.206, specifically
25 Regulatory Position C.1.17.5.3 which has to do with

1 oversight and control of contractor activities.
2 Specifically it says that the FSAR will delineate the
3 QA functions delegated to other organizations. In
4 addition, it must describe how the Applicant will
5 retain responsibility for and maintain control over
6 portions of the QA Program delegated to other
7 organizations.

8 So, when we looked at that in the case of
9 the Fermi application, we wanted to see that there was
10 that control, and that would be both pre-application
11 and post-application. And we wanted to ensure that the
12 appropriate Appendix B criteria had been met.

13 So we used a combination of RAIs in this
14 area to get additional information and inspection
15 activity. We concluded an inspection in August of
16 2009. And then we resolved those inspection violations
17 that were issued as a result of that inspection
18 through the inspection process. So there was a
19 combination of RAIs and inspection.

20 Next.

21 As a result of considering all the
22 information both in the licensing and the inspection
23 realm, we determined that:

24 The FSAR met the regulatory requirements;

25 That the oversight activities had met the

1 intent of RG 1.206, Regulatory Position C.1.17.5.3;

2 They addressed the COL items;

3 And that the inspection violations were
4 appropriately closed; and

5 There were no open or confirmatory items
6 in 17.5

7 MR. HALE: Any questions on the QAPD?

8 CHAIR CORRADINI: Okay.

9 MR. HALE: If not, move onto 7.6
10 Maintenance Rule. Todd?

11 MR. HILSMEIER: Yes. FSAR Section 17.6
12 is incorporated by reference to the generic template
13 in NEI 07-02A, which is a generic template for Section
14 17.6 in a COL application. And NEI 07-02A meets the
15 requirements of FSAR 17.6 and has been approved by
16 NRC.

17 And there's no open items or confirmatory
18 items associated with this section.

19 MR. HALE: Any question on the Maintenance
20 Rule?

21 CHAIR CORRADINI: Committee members? No.
22 Let's move on.

23 MR. HALE: Thank you. That concludes the
24 staff presentation of Chapter 17.

25 CHAIR CORRADINI: So we'll move on to 19.

1 First we'll do everything but the Appendix in open
2 session. So the Detroit DTE people are back up.

3 What we'll probably do is we'll go through
4 the open session, take a break so we can close the
5 session for addressing the Appendix. Okay?

6 MR. SMITH: Okay. So we're going to now
7 talk about Chapter 19 Probability Risk Assessment and
8 Severe Accidents. And this is a list of Chapter
9 topics. I'm not going to read through the list.

10 Go to the next page.

11 Section 19.2 PRA Results and Insights.

12 The first one was related to the as-built such as the
13 systems and components, seismic margin capability.
14 And we have a comparison analysis that we've committed
15 to do prior to fuel load in the as-built
16 configuration.

17 Next slide.

18 And then summary of the plant-specific PRA
19 review. As a supplemental item we looked at a number
20 of things that we compared with the ESBWR PRA:

21 Loss of preferred power frequency;

22 Loss of service water frequency;

23 Seismic fragilities;

24 Other known site-specific issues such as
25 unique off-site consequences; and

1 Internal flooding associated with the Yard
2 Area.

3 And our review concluded that the risk
4 ESBWR PRA provides a reasonable representation of the
5 Fermi 3 site parameters and conditions.

6 Next slide, please.

7 So our conclusions. We have no departures
8 from the DCD that affect the ESBWR PRA. The only
9 departure we have is related to the configuration of
10 the low level of the radwaste building to expand below
11 over radwaste storage capacity.

12 And our plant-specific review is
13 summarized in Appendix 19AA of the FSAR.

14 MEMBER STETKAR: Okay. If you could go
15 back to -- this is going to take a while.

16 MR. SMITH: Okay.

17 MEMBER STETKAR: You're going to go back
18 to slide 4.

19 MR. SMITH: Right.

20 MEMBER STETKAR: Let's talk about the
21 first bullet: Loss of preferred power frequency. How
22 many times has Firma Unit 2 lost off-site power from
23 any cause during its operation?

24 MR. SMITH: During its total operation
25 life?

1 MEMBER STETKAR: Yes.

2 MR. SMITH: I don't know the total.

3 MEMBER STETKAR: I'd be interested. I know
4 you lost it at least once during the Northeast
5 Blackout.

6 MR. SMITH: Yes.

7 MEMBER STETKAR: It was characterized as
8 a partial lost during the tornadoes. I didn't go all
9 the way back to '8 to find out.

10 MR. SMITH: Yes.

11 MEMBER STETKAR: And just one event in the
12 years of its operation gives you a mean frequency that
13 is somewhat higher than the frequency that's used in
14 the DCD PRA. That one event gives you a somewhat
15 higher frequency. If you've had two events, you'll be
16 more than twice as high and from a different mix of
17 causes.

18 MR. SMITH: Yes.

19 MEMBER STETKAR: So I'm really interested
20 from the actual operating experience how many times
21 you've lost off-site power. That's just a question to
22 kind of give --

23 MR. SMITH: Okay.

24 MEMBER STETKAR: Because you said you did
25 a frequency comparison, but I don't have any numbers

1 or anything.

2 MR. SMITH: Can you speak to that or do we
3 need to take this back?

4 MEMBER STETKAR: And I know where all your
5 numbers came from.

6 MR. SMITH: Yes.

7 MEMBER STETKAR: I know where the DCD
8 numbers --

9 MR. MILLER: That's right. You know where
10 the DCD numbers came from.

11 Let me just go over the process. Of
12 course, we look at it generically. The DTE PRA staff
13 assessed their plant-specific history and compared it
14 against that of --

15 MEMBER STETKAR: Yes. That's what I'm
16 asking about is I'd like to see what that comparison
17 is.

18 MR. MILLER: Okay. Well, that would be
19 within the DTE staff. I would just like to add,
20 though, that the requirement for a plant-specific PRA
21 prior to fuel load would incorporate any new operating
22 experience, it would incorporate any new loss of off-
23 site power events.

24 MEMBER STETKAR: I guess, and I'm going to
25 ask the staff when they come up, I'm troubled by this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 notion of this thing is being called a plant-specific
2 PRA. It is not a plant-specific PRA. It has nothing to
3 do whatsoever with a plant-specific PRA. It is the
4 design certification PRA accepted by this COL
5 Applicant.

6 MR. MILLER: Purely.

7 MEMBER STETKAR: They will have a plant-
8 specific PRA before fuel load when indeed they meet
9 all of the requirements to do a real PRA.

10 MR. MILLER: That's the one I'm referring
11 to.

12 MEMBER STETKAR: Yes. Okay. Well,
13 they're calling this a plant-specific PRA, the thing
14 that is right now is called in the COL FSAR a plant-
15 specific PRA. The term is "incorporation of DCD
16 Chapter --" this is in the COL FSAR. "Incorporation
17 of DCD Chapter 18 into the FSAR satisfies the
18 requirement of 10 CFR 52.79(a)(46) for a description
19 of the plant-specific PRA and its results." So this
20 is being characterized as the plant-specific PRA and
21 its results. I don't believe that, but those are just
22 words.

23 What I want to do is examine whether or
24 not what level of reviews of both the plant
25 information that I can glean, how that information was

1 indeed compared with the DCD PRA to form the basis for
2 the conclusions, at least on three of the five bullets
3 that are on the slide in front of us. So I've asked
4 about the loss of off-site power. I'd like to see that
5 comparison.

6 The second one is the loss of service
7 water frequency. I'm not so much concerned about the
8 loss of service water initiating event frequency. I'm
9 concerned about the fact that the DCD PRA has
10 absolutely no relevance to the actual configuration
11 and operation of the plant service water system as I
12 understand the way it will be operated. In fact, there
13 are qualitative statements in the FSAR that say "Well,
14 we're probably more reliable than the DCD PRA because
15 we normally cool through the normal cooling tower."
16 I don't know if that's true, but there's a statement
17 that says you do that.

18 The DCD PRA does not model that line. It
19 does not model the status of the valves in the line
20 that connect the return flow either to the normal
21 cooling tower basin or to the mechanical draft cooling
22 tower fans. So I ask you, are you going to keep the
23 PSWS aligned to the mechanical draft cooling towers
24 during normal operation or not? If the answer is no,
25 then the DCD PRA is completely wrong because it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 assumes that one mechanical draft cooling tower is
2 always running. You know, it doesn't have start
3 failures for those fans. It assumes that all of the
4 valves and all of the cross-tie lines are always
5 normally open. Those valves are modeled at all. They
6 can't all be normally open if you're going to the
7 normal cooling tower, which there's a statement in the
8 FSAR that says that you will normally be aligned to
9 the normal cooling tower.

10 So it's not at all clear. And I can glean
11 this from looking at what's written. I don't actually
12 know how you're going to operate the system, but it's
13 pretty clear that the DCD PRA model for that system is
14 inconsistent with at least information I can glean
15 from both the DCD and your Chapter 9 information on
16 the PSWS in the FSAR.

17 MR. MILLER: Okay.

18 MEMBER STETKAR: Now, do I believe that
19 the differences affect the use of that DCD PRA to give
20 me some general assurance that the level of risk from
21 the plant is much lower than the level of risk of
22 currently operating plants? No, I don't think the
23 differences would affect that generic conclusion.

24 If I wanted to get really precise about
25 how different it is, then it would affect that generic

1 conclusion and I can't say that the DCD PRA is
2 necessarily conservative because I have no idea of
3 what the stuff that is not modeled or the different
4 configurations might contribute. And that's a bit of
5 my concern about characterizing this thing as a plant-
6 specific PRA because if it doesn't model the
7 alignments that seem to be documented in the FSAR,
8 then it's not even a design-specific PRA.

9 So that's an area of concern that I think
10 you need to look at, in particular for the PSWS. Not
11 the loss of service water frequency. I didn't some
12 back of the envelope calculations and they're about
13 right. They're okay.

14 CHAIR CORRADINI: So, John, can I -- I
15 assume that DTE stipulates what the characterization
16 is, that this is still the generic DCD PRA until they-
17 - MEMBER STETKAR: Well, they characterize
18 it as a plant-specific PRA.

19 CHAIR CORRADINI: But it's not. It can't
20 be.

21 MEMBER STETKAR: No, it's not. It can't
22 be.

23 CHAIR CORRADINI: You guys agree?

24 MEMBER STETKAR: And it's the result of a
25 plant-specific PRA, and that there's nothing from any

1 specific features of their design that would change
2 the conclusions on the DCD PRA.

3 MR. MILLER: So the intent of what they
4 performed here was a review of the plant-specific
5 features that may be different than what is in the
6 generic certified PRA, okay?

7 And just for clarification, another thing
8 I'd like to clarify is that the DCD, you've
9 characterized the modeling of the service water in the
10 DCD as inadequate. And I believe you mean with
11 respect to the plant-specific features at Fermi 3.

12 MEMBER STETKAR: No. It's inadequate with
13 respect to the design features that I can look at at
14 the DCD deadline. Cross-tie valves are not modeled at
15 all.

16 MR. MILLER: Yes. But the problem is
17 because it is a design certification PRA. Every plant
18 has a unique service water design. That is up to the
19 plant owner, okay? We cannot possibly model all of
20 those, so we develop a general model.

21 MEMBER STETKAR: I'm sorry, Gary. I'm
22 staring at identical drawings in the DCD Chapter 9 and
23 the FSAR Chapter 9. They are precisely identical with
24 the exception that in the DCD Chapter 9 there's a
25 little bubbly thing around the part that doesn't have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the bubbly thing around it. They're absolutely
2 identical. So there was no need in the DCD PRA to say
3 we don't know what the done design is going to look
4 like, because you could have at least modeled the
5 design that was in the bubbly thing.

6 MR. MILLER: I'm not sure I understand.
7 I mean, this is representing every plant. This is the
8 design certification for every ESBWR.

9 MEMBER STETKAR: I understand that. The
10 design certificate PRA models the plant service water
11 system, a plant service water system, the design
12 certification plant service water system. But it is
13 not a complete model of that system.

14 MR. MILLER: Okay.

15 MEMBER STETKAR: Because it does not
16 include a number of valves in that system. Now, you
17 know if Detroit Edison had decided to reconfigure that
18 system, then they would have needed to go look at
19 their actual configuration. If they wanted to put in
20 12 pumps and 800 valves or two pumps and no valves,
21 that obviously would have been a departure. There is
22 actually no departure from the certified design in the
23 configuration of the plant service water system in
24 terms of numbers of pumps, numbers of valves,
25 configuration of piping, numbers of cooling towers.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 There's no difference. What there seems to be,
2 though, is a difference in the actual operating
3 configuration of that system --

4 MR. MILLER: Okay.

5 MEMBER STETKAR: -- as it's characterized
6 in the FSAR compared to the assumptions about the
7 operating configuration of that system that are made
8 in the DCD PRA. There's some very, very explicit
9 assumptions about this.

10 MR. MILLER: Yes, there will be
11 differences. So --

12 MEMBER STETKAR: And the question is do
13 the differences make a difference? I don't know.

14 MR. MILLER: Well, I think you hinted
15 earlier that you didn't think they did, but --

16 MEMBER STETKAR: You know, it's my own
17 personal opinion and it's certainly not ACRS,
18 certainly not anyone on the Subcommittee. For the
19 purpose of the DCD PRA to give the staff, to give the
20 ACRS, to give the public confidence that the level of
21 safety for the ESBWR is significantly improved from
22 current operating plants. And I didn't say a factor
23 of 101.23. I just said significantly improved.

24 MR. MILLER: Yes.

25 MEMBER STETKAR: I don't personally

1 believe that the differences in this particular system
2 would affect that conclusion.

3 MR. MILLER: Yes.

4 MEMBER STETKAR: Numerically I do believe
5 the difference, you could measure the differences
6 between 101.23 versus 85.62.

7 MR. MILLER: Okay.

8 MEMBER STETKAR: But that's a difference.

9 MR. MILLER: Right.

10 MEMBER STETKAR: Whether it's significant,
11 you know that's somebody else's. My argument about
12 characterizing this as a plant-specific PRA and that
13 there is no difference is a bit of a concern, given
14 the nature of the DCD PRA.

15 So, I guess what I'm asking Detroit is in
16 the same sense of the loss of off-site power, the
17 LOPP, loss of preferred power frequency I'd like to
18 see how you did that comparison. I'd like a little
19 bit more confidence about how you compared the
20 operating configuration, at least as I understand from
21 the system that you're planning to install compared to
22 the assumptions that are built into the design
23 certification PRA, and how you did that.

24 MR. MILLER: Okay.

25 MEMBER STETKAR: Because all I can read in

1 the FSAR is some pretty high level qualitative stuff.

2 Now, the third one that I have to be
3 honest is a little bit more concern. This is
4 something I can point to --

5 CHAIR CORRADINI: So, John, I'm trying to
6 capture this because you guys went back and forth and
7 I was there, and then I digressed.

8 MEMBER STETKAR: The concern is that
9 Detroit Edison has made an assertion that there are no
10 significant differences.

11 CHAIR CORRADINI: And you want to see the
12 analysis that shows it?

13 MEMBER STETKAR: I want to see what's the
14 basis for that conclusion.

15 CHAIR CORRADINI: Right. Okay.

16 MEMBER STETKAR: It would be more obvious
17 if the actual configuration, you know the number of
18 pumps were different were the actual configuration of
19 the system were different. But even within this
20 context the normal alignments seem to be different.
21 And the normal alignments being different could
22 introduce drastically different failure modes,
23 drastically different success criteria even compared
24 to what's applied in the DCD PRA.

25 MR. MILLER: Drastically different?

1 MEMBER STETKAR: Yes, yes. Because the DCD
2 PRA basically says the success criteria are any two
3 pumps to any one cooling tower which presumes that
4 both the discharge cross-tie valves are always open
5 and can never be closed and the return cross-tied
6 valves between the cooling towers are always open and
7 cannot never be closed. Otherwise, the success
8 criteria don't match up. You get combinations of pumps
9 that don't line up with cooling load. The Train A
10 pumps can be successful, but they're isolated from the
11 Train B cooling loads, you don't have cooling to Train
12 B.

13 MR. MILLER: Right.

14 MEMBER STETKAR: And vice versa on the
15 return trip.

16 MR. MILLER: Again, but it was the intent
17 for the plant-specific or the design certification
18 PRA--

19 CHAIR CORRADINI: For the GEH DCD one to
20 match any particular site.

21 MR. MILLER: Yes. Right.

22 CHAIR CORRADINI: Just so I capture it,
23 your point is that you want to see the basis by which
24 there's not a concern?

25 MEMBER STETKAR: I want to see the basis

1 for -- right. I want to see what evaluation Detroit
2 Edison made --

3 CHAIR CORRADINI: Right.

4 MEMBER STETKAR: -- now that they've
5 adopted this flow path picture and they've made
6 statements about how that system will be normally
7 configured that is the only way it can work
8 consistently with their statements is it leads to
9 inconsistencies in the PRA model.

10 CHAIR CORRADINI: Right.

11 MEMBER STETKAR: Or, you know, the
12 applicability of the DCD PRA model to that normal
13 alignment.

14 MR. MILLER: But you had another one?

15 MEMBER STETKAR: I do. On what's
16 characterized as internal flooding associated with the
17 Yard Area, I will characterize that as external
18 flooding.

19 The DCD PRA explicitly does not model
20 external flooding, doesn't quantify external flooding.
21 There's a statement that says "external flooding
22 events are reasonably precluded from the ESBWR
23 Probabilistic Flood analysis based on adherence to
24 the design conditions set forth in the envelope of
25 ESBWR Standard Plant Site Parameters of DCD Tier 2.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR CORRADINI: Chapter 2.

2 MEMBER STETKAR: They didn't quantify
3 external flooding.

4 The discussion of Yard flooding in the
5 FSAR says: "Consideration of site-specific external
6 flooding would have no impact on the PRA results and
7 conclusions."

8 CHAIR CORRADINI: Yard flooding means
9 between the switchyard and the plant?

10 MEMBER STETKAR: Think of Lake Erie making
11 the site look like a big Lake Erie.

12 CHAIR CORRADINI: Got it.

13 MEMBER STETKAR: I mean, it's
14 characterized as the Yard because the Yard is a site-
15 specific feature. But it's --

16 CHAIR CORRADINI: Whether it's off-site or
17 on-site, your point is it's a controlled area but it's
18 flooded.

19 MEMBER STETKAR: The Yard is outside, and
20 they said the Yard is outside.

21 CHAIR CORRADINI: Okay.

22 MEMBER STETKAR: Now, the qualitative
23 arguments that are made in the FSAR are that the only
24 things that might be affected in the Yard are a couple
25 of stand pipes for the fire protection system and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 they're above design basis flood level and plant grade
2 is above design basis flood level. Well, PRA doesn't
3 care about design basis flood level. PRA cares about
4 a flooding hazard curve: What is the frequency of
5 flooding up to a certain elevation and at some point
6 the water spills over into buildings. Now, if that
7 frequency is ten to the minus 200, that's fine. But
8 that's a site-specific analysis. It depends on your
9 flooding hazard sources, it depends on metrology, it
10 depends on whether you've got the world's worst
11 biggest dam next to your site, which you don't.

12 And I'm interested here, too, in seeing
13 what type of an evaluation was done of the site-
14 specific flooding hazard to reach the conclusion that
15 essentially it's impossible to have a flood at the
16 site that can flow water into buildings that contain
17 any equipment in the PRA. And I will tell you that
18 the condensate and feedwater systems are in the PRA,
19 and they're in the turbine building. So it's not
20 related to only safety-related buildings. It's kind
21 of flood damage anything that's in the PRA.

22 And if there's some measurable frequency
23 of that occurring, then I'm not sure about the
24 conclusion that consideration of external flooding can
25 have no impact on the PRA results. So I'm curious,

1 again, you know it's sort of the same thing of what
2 technical analysis were performed to look at the site-
3 specific flooding characteristics at the Fermi site to
4 draw that conclusion that there was no need to add
5 external flooding into the DCD PRA.

6 MR. SMITH: Understand. Thanks.

7 CHAIR CORRADINI: So, can I just
8 interject? So in all three cases we're going to have
9 to see something you're going to have to go off and
10 gather or at least get to us so that we understand
11 better.

12 MEMBER STETKAR: Right.

13 CHAIR CORRADINI: Okay. Do you have more?

14 MEMBER STETKAR: No, I'm done.

15 CHAIR CORRADINI: Other questions? Okay.

16 MEMBER STETKAR: Oh --

17 CHAIR CORRADINI: That's why I waited with
18 baited breathe here.

19 MEMBER STETKAR: No, I don't think I do.
20 Hold on just a second. It's a good thing about taking
21 notes is I don't forget. The bad thing is -- no, I do
22 not have any more. Thank you.

23 CHAIR CORRADINI: Okay. Staff will be
24 coming up and have their turn.

25 Is Steve -- not Steve. Is Raj going to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 start us off? Who is going to start us off?

2 MR. ANAND: Me.

3 CHAIR CORRADINI: Okay.

4 MR. ANAND: My name is Raj Anand. I'm one
5 of the Project Managers working on the Fermi 3 COL
6 application.

7 Today we plan to discuss Fermi Chapter 19,
8 the PRA Results and Severe Accidents Evaluation and
9 LOLA SER Review.

10 These SERs have no open items.

11 Chapter 19 provides the Fermi PRA and a
12 severe accident evaluation and corresponding
13 regulatory requirements.

14 Attachment 19-A to Chapter 19 SER is loss
15 of large area of the plant due to explosion or fire is
16 in a public domain.

17 Attachment 19-B LOLA SER is a non-public
18 as well as some of the documents which are referenced
19 in Attachment 19-A includes security-related
20 information. The staff plans to discuss the non-
21 public portion of the LOLA SER after the break in a
22 closed-door meeting.

23 The technical review of the Chapter 19 PRA
24 and severe accident is Mark Caruso and Jim Xu is an
25 expert on seismic is also joining us on the table.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Now I would turn it over to Mark to
2 discuss Chapter 19 PRA and the severe accident
3 evaluation.

4 MR. CARUSO: Thank you, Raj.

5 Do you want to go to the next slide?

6 The first slide here is a summary of the
7 pertinent regulations that apply. The only one I
8 really want to talk about here is the second one,
9 52.79(d) where it basically says that if the COL is
10 referencing a design certification, then at COL
11 licensing time he's required to start with the DCD
12 design PRA and update to address site and design
13 specific parameters and features.

14 The other area requirements -- so that's
15 really been the focus of this review is on the --
16 those specific parameters and features that are --
17 those features and parameters that are site/design-
18 specific. The other requirements here are addressed
19 by the Applicant by way of incorporating a ESBWR DCD
20 by reference.

21 The next slide summarizes the guidance.
22 I think you're all familiar with Interim Staff
23 Guidance COL/DC-ISG-03. I think we've discussed that
24 with you in the past. It supplements the guidance
25 that's in the SRP and Regulatory Guide 1.206.

1 What we're showing for the site that
2 margins evaluation, we have values for application
3 COL-DC-ISG-20, and Jim Xu joins me and we'll be taking
4 about the seismic margins analysis in a little bit.

5 MEMBER STETKAR: Mark, Detroit Edison will
6 do a quantitative seismic PRA before fuel load, is
7 that correct? Because, you know it's required
8 basically under 50.71(h)(1).

9 MR. CARUSO: If there's a consensus
10 standard.

11 MEMBER STETKAR: And there is for seismic.

12 MR. CARUSO: Then there will be.

13 MEMBER STETKAR: Okay.

14 MR. CARUSO: It's required.

15 MEMBER STETKAR: For the seismic margins
16 discussion, I mean it's something they have to do
17 because it's required, but that's this interim stopgap
18 comparison until the seismic people perform some type
19 of--

20 MR. CARUSO: I think that's going on.

21 MEMBER STETKAR: Okay.

22 MR. CARUSO: So this slide is a summary,
23 basically sort of in review. The Applicant
24 incorporated a Certified Design PRA and Severe
25 Accident Evaluation by reference. And in their

1 application they initially indicated that -- they cite
2 site-specific parameters and design features were
3 enveloped out by a Certified Design PRA. But there
4 were no detail at all on that, they issued RAIs to
5 obtain supporting site-specific evaluation. And the
6 Applicant provided a discussion of what those
7 parameters were and features and their reasons for
8 concluding that they were bounded by a Certified
9 Design PRA.

10 And we looked at those bases. Now these
11 are the plant-specific parameters and features that we
12 were just talking about with the Applicant. Well,
13 they describe their bases.

14 And they looked at this loss of off-site
15 power frequency for Unit 2 and they compared it with
16 was in the DCD, and found that it was lower and
17 concluded that it was bounding. Now they didn't
18 provide us the numbers --

19 MEMBER STETKAR: You just said they found
20 it was lower. It can't be lower. The value that's
21 used in the DCD is 3.59 times ten to the minus two per
22 year from all causes. If I just take one event, the
23 great Northeast Blackout in August 14, 2003 and divide
24 it -- I'll even give them that they've operated
25 through 2011; in 23 years of operating experience that

1 comes out to be 4.35 times ten to the minus two, which
2 is larger than 3.59. So if they're indicating -- and
3 that's from only grid-related events. I don't want to
4 get into the four different categories.

5 So if their comparison concluded that it's
6 smaller, I'm even more interested to think-- to see
7 what that comparison was. Because that event alone,
8 had there been no other events.

9 MR. CARUSO: Well, I agree. I didn't ask
10 them. I didn't probe that.

11 MEMBER STETKAR: Okay.

12 MR. CARUSO: I felt that they were
13 probable capable of figuring out what their loss of
14 off-site power frequency was and it didn't occur to me
15 to dig deep into that.

16 MEMBER STETKAR: Anyway, you've gone
17 through it.

18 MR. CARUSO: And, I mean the idea that
19 well what if it was a little bit higher, would I care?
20 Right. I would care, but how much would I care? So,
21 you know I considered how important it was the loss of
22 off-site power in ESBWR. And, of course, this plant
23 is a passive plant and so it's not so important as it
24 is in other plants.

25 MEMBER STETKAR: Exactly.

1 MR. CARUSO: And for all these parameters,
2 my focus was do I have, you know reasonable confidence
3 that they're not way far off. Because to me the
4 review at this point in time is really about is there
5 something really different about this plant compared
6 to the ESBWR design that I would be concerned about.
7 And that tempered the depth of our review.

8 And I also considered, you know the
9 particular planning that we're talking about, you know
10 in the scheme of things in terms of risk, how
11 important is it? How important is service water
12 failure? When does it come in? Basically it comes
13 into the FAPCS. The FAPCS needs service water to run
14 because FAPCS runs on the diesels and stuff.

15 The thing about service water is that it's
16 running out of time, so it's not a system where you --

17 MEMBER STETKAR: It is, but if it has to
18 be reconfigured for certain events, you get valve
19 failures in there that are modeled at all in PRA. And
20 we don't need to take up the Subcommittee's time on
21 certain discussions of members. I think that's kind of
22 pointless. But the question is that I heard then
23 comparisons that were done to draw certain
24 conclusions. And I guess what I'm doing is
25 challenging a bit about the level of depth that went

1 into those comparisons and to support those
2 conclusions. You know, do I believe that the
3 unavailability of plant service water is going to
4 increase by a factor of a 1,000 or could it change
5 same? It probably would -- you know would it be
6 higher? I don't know. But that's the --

7 MR. CARUSO: I felt their description of
8 their system in terms of arguments about the
9 attributes of their liabilities were good ones, were
10 strong ones compared to what's out there, which was
11 basically modeled --

12 MEMBER STETKAR: But again, that's
13 comparisons of absolute, it's not necessarily
14 relatively in the context of this particular PRA.

15 MR. CARUSO: The other thing is that we
16 don't -- you know, in this particular review we don't
17 -- you know we're not reviewing the PRA. It's not our
18 charter to --

19 MEMBER STETKAR: I understand.

20 MR. CARUSO: -- dig in and say did they
21 get the exact right number for the loss of off-site
22 power frequency

23 MEMBER STETKAR: Understood.

24 MR. CARUSO: So I guess I'm trying to give
25 you a sense of the area we're coming from in terms of

1 our review and what our objectives are and what drives
2 us. And not that I -- you know, I mean I value that
3 you're challenging these things, too. I mean, I don't
4 think they provided us all that much. They certainly
5 didn't provide us with vigorous technical analysis
6 to--

7 MEMBER STETKAR: Well, honestly, Mark, in
8 terms of the three things that raised I'm personally
9 a bit more interested in the last one about external
10 flooding --

11 MR. CARUSO: Okay.

12 MEMBER STETKAR: -- that could have -- I
13 don't know. I have to be careful about what I
14 hypothesized, but of the three issues the external
15 flooding could conceivable have a large numerical
16 impact on the overall assessed risk. You know, I'm
17 not inferring that it would challenge the notion that
18 the plant is much safer than currently operating
19 designs, but in terms of site-specific issues that
20 could affect your understanding of the results of the
21 design certification risk assessment and the
22 contributors to that risk, the external flooding to me
23 is -- I'm not going to talk about seismic stuff
24 because we're all well aware of the seismic issues.
25 But that is the one area where numerically it could be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 different.

2 MR. CARUSO: Well, and we looked into
3 Chapter 2 to the design of the plant and the flooding
4 evaluation that was there and considered that in terms
5 of likelihood of expectation of something, some
6 flooding condition quite drastic that would be pouring
7 into buildings and that sort of thing. And I think
8 our feeling was that their discussion of the flood
9 zones and what they expected in the flood zones was
10 reasonable. And there's nothing out there, like you
11 say. The issue is not what's in the Yard, because
12 there's nothing in the Yard that has any power.

13 MEMBER STETKAR: There's nothing in the
14 Yard. That's right.

15 MR. CARUSO: It's is it going to go to
16 buildings and what it's going to take out. And,
17 again, you start to think about ESBWR and you think
18 about how it's designed.

19 We spent a fair amount of time considering
20 right after Fukushima what flooding issues there might
21 be with the ESBWR in particular batteries, that sort
22 of thing. And if you look at the overall design,
23 again you find that they're very well protected
24 against flooding.

25 MR. TONACCI: Mr. Chairman --

1 MR. CARUSO: And so --

2 MR. TONACCI: Can we have IOU to come to
3 back on these topics?

4 MEMBER STETKAR: We don't need to belabor
5 the issues.

6 MR. CARUSO: Okay. Fine.

7 CHAIR CORRADINI: You guys were having a
8 discussion. We will let it go on for a minute or
9 more. Okay. Let's keep on going.

10 MR. CARUSO: All right. So the seismic
11 margins evaluation Jim was the reviewer on that and
12 he's going to present.

13 MR. XU: I think there's confusion about
14 this type of plant-specific PRA. I think that the
15 scope for COL was to satisfy 52.79(d)(1) which is
16 actually the DCD PRA to incorporate the site-specific
17 features.

18 MEMBER STETKAR: The terminology is --

19 MR. XU: I know, but they're not required
20 to do PRA per 50.79(h)(1) you know before fuel.

21 MEMBER STETKAR: That's right. And that
22 will be a plant-specific --

23 MR. XU: That will be a plant-specific
24 PRA. This is just the gap we need to fill, you know
25 between the --

1 MEMBER STETKAR: There's one applicant
2 that characterizes this thing as the COL PRA.

3 MR. XU: Yes. That's probably not the--

4 MEMBER STETKAR: That's actually the term
5 that they use.

6 MR. XU: Right. So for seismic margins,
7 the scope of the COL is to accurately achieve a PRA
8 base to estimate and to incorporate the site-specific
9 features. In this case the Fermi site is hard rock
10 which is very simple and meaningful one. And the GMLS
11 for Fermi is fully enveloped by the CSDRS per the
12 ESBWR DC. So in this case their seismic margins is
13 covered by the extended design and geotechnical
14 characteristic for the site are also falling into the
15 generic site profile of the DC.

16 So, you know based on that -- you know,
17 according to our guidance, the ISG-20, that satisfies
18 the steps that need to be taken to operate the DC --
19 to bring the DC towards the zero state. So that's how
20 we conclude their analysis, although it's very
21 minimal, is satisfactory. Although the HCLPF values
22 for all the structure systems components and the
23 sequences will have to be confirmed prior to fuel
24 load. That activity the Licensee will have fulfill.

25 MEMBER STETKAR: Well, I mean, they'll

1 have to have fragility curves and they're have to have
2 hazard curves --

3 MR. XU: Yes. They will have to develop
4 fragility curves and other things.

5 MEMBER STETKAR: That's down the line.

6 MR. XU: And do a rock bound.

7 So that's pretty much discussed for
8 seismic margins.

9 MR. CARUSO: We talked about flooding the
10 Yard. The plant-specific surface water flooding. In
11 the ESBWR they assume that there's just one flood zone
12 and all the pumps are failed, which needs to be
13 bounded.

14 So the conclusions are the Applicant has
15 addressed the required information related to PRA
16 results and insights, and Severe Accidents evaluation.
17 And we concluded the Chapter 19 is acceptable, it
18 confirms to regulatory requirements.

19 CHAIR CORRADINI: Other questions by the
20 Committee?

21 MEMBER BROWN: Yes.

22 CHAIR CORRADINI: Charlie?

23 MEMBER BROWN: It's not a question.

24 CHAIR CORRADINI: Go ahead.

25 MEMBER BROWN: It's an observation.

1 CHAIR CORRADINI: I asked for questions,
2 not observations.

3 MEMBER BROWN: It's a concern. A concern.
4 Okay. And I'm going to roll it back to a discussion
5 that we had from yesterday. And I've listened to the
6 interchange on the PRAs and the fact, you know the
7 unrelated number that was used apparently didn't
8 reflect --

9 MEMBER STETKAR: Well, be careful.

10 MEMBER BROWN: Well, I mean it's a small
11 number, but I mean it's a number. The number was
12 higher than it was in the DCD or whatever the quoted
13 number was. And yet and here's "the site-specific
14 PRA" coming around and they used the process that the
15 numbers were wrong, at least for that one particular
16 piece.

17 So if they're using the process, then we
18 don't have to check to make sure that it's okay that
19 it was applied properly and that the numbers and the
20 inputs and the assumptions are valid based on the
21 actual plant-specific, it's not checked.

22 The same thing applied I heard earlier on
23 the PTLR report that as long as they use the method
24 and they do their plant-specific PTLR curves,
25 hazardous material characteristics, but as long as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 they use the method we don't have to look at them, and
2 we don't because it's assumed that they got the
3 values.

4 Now I'm going to step back into the sort
5 of discussion that we had yesterday on this plant, the
6 Detroit plant using this or at least they proposed
7 this as the risk-informed issues under tech specs.
8 And one of the arguments there is if they get into a
9 potential system out of service or maintenance,
10 whatever they have to do with it and they can't
11 complete it in time, as long as it's within a certain
12 period of time they do an analysis based on the PRA
13 that they have for the systems, that they can extend
14 that completion time up to a certain other time.

15 So the PRAs are being used for decision
16 processes. I don't know how many circumstances, but at
17 least in that circumstance but yet nobody has checked
18 to see that the PRA that was initially inspected with
19 has actually used the proper assumptions, the numbers
20 were plugged in correctly, et cetera, et cetera, or
21 even audited. Now they can be, but it doesn't mean
22 that they have been. And the story was that as long
23 as you use the method or as long as they use the
24 process they're not checked.

25 So consistent with our concern and

1 observation about how these things are being used --

2 CHAIR CORRADINI: So just to move --

3 MEMBER BROWN: It's not an action item,

4 Mike.

5 CHAIR CORRADINI: I understand.

6 MEMBER BROWN: I'm just making that at an
7 observation.

8 CHAIR CORRADINI: But I mean this is
9 observation, correct?

10 MR. CARUSO: Well, for risk-informed tech
11 specs, I mean any risk-informed application we will
12 look at the PRA for that.

13 Now I think if you're talking about --
14 this is not newly -- this is not Firma --

15 MEMBER STETKAR: Yes, I was going to say
16 this discussion is --

17 CHAIR CORRADINI: I don't know if it's
18 germane to this.

19 MEMBER BROWN: It's a new reactor.

20 CHAIR CORRADINI: Okay. But I don't want
21 to --

22 MR. CARUSO: I think your other examples
23 are right on the money. But that one I'm not --

24 MEMBER BROWN: Look, all these vast realm
25 of methods, processes and regulations, have been on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the Committee for a little over three years, so I
2 don't pretend to know all those nuances. I hear
3 process. I hear methods and all the rest of it and
4 decisions are being made with that, yet I don't get a
5 lot of comfort out of how much that the applicants or
6 doing, or the licensees is then having their changes
7 from the design basis checked after the fact. I just
8 don't hear a lot about that. It's a concern to me.

9 IT may not be a concern to the other
10 members, but it is to.

11 Mike, that's the observation I had over
12 the last two days and after listening to the
13 discussion today on at least two technical subjects.

14 CHAIR CORRADINI: Okay. Point taken.

15 Other members comments or questions?

16 All right. Before we go to break, I was
17 just informed that we have members of the public on
18 line that may have questions, comments.

19 MR. BROWN: It's open.

20 CHAIR CORRADINI: It's open? I'm sorry.
21 I didn't hear the beep.

22 So is there a member of the public that
23 needs to make a statement? Okay.

24 MEMBER STETKAR: Ask if there's anybody
25 out there.

1 CHAIR CORRADINI: Is there anybody out
2 there?

3 MEMBER STETKAR: If there's anybody on the
4 line, just say something, make some noise so we know
5 the line is actually open.

6 CHAIR CORRADINI: Okay. So nobody's out
7 there either.

8 MEMBER STETKAR: Well, maybe but the line
9 may be closed.

10 CHAIR CORRADINI: It is open.

11 MR. BROWN: You can hear the noise. Yes.

12 CHAIR CORRADINI: All right. There are no
13 comments. There is nobody out there.

14 At this point we'll take a break until
15 2:15 in closed session.

16 (Whereupon, a 1:55 p.m. a recess to resume
17 at 2:11 p.m. in Closed Session until 3:21 p.m.)

18 CHAIR CORRADINI: So we're in open
19 session.

20 So, here's what I've got. In terms of
21 Chapter 5 -- let me just -- well, while I compare
22 notes, let me take notes and let me go around the room
23 first with the Committee and see if there's additional
24 things that either amplify what I've written down or
25 review things that I've missed. Can we start with Tom

1 and we'll just go around.

2 CONSULTANT KRESS: You don't want general
3 comments now, you just want to know --

4 CHAIR CORRADINI: No, I want general
5 comments, specific things that you're concerned about,
6 anything that's on your mind.

7 CONSULTANT KRESS: Oh, okay. Well, I can
8 do that.

9 CHAIR CORRADINI: Well, then I'd welcome
10 it.

11 CONSULTANT KRESS: Okay. Well, my first
12 comment is I think we were little hard on staff. I
13 think they did a good job of knowing what the
14 regulations are and what the guidance on these for
15 COLAs are, and that they did a pretty good job of
16 actually reviewing the things and showing the
17 appropriate things we're doing. So, I didn't want to
18 leave the impression that the staff had not done a
19 good job.

20 One of the issues that I was particularly
21 interested in following up on is the hydrogen problem,
22 particularly burning and how much hydrogen gets to the
23 control room. And I'd like to know more about how
24 it's calculated, what are the chi over q values for
25 hydrogen.

1 CHAIR CORRADINI: Tom, this is in general.
2 Just for clarification, this is in general or
3 particularly because of the issue we raised with the
4 hydrogen water chemistry system?

5 CONSULTANT KRESS: It's in general.

6 CHAIR CORRADINI: General. Okay.

7 CONSULTANT KRESS: And then the hydrogen
8 water chemistry is probable high on my list.

9 CHAIR CORRADINI: Okay. That's fine.
10 Thank you.

11 CONSULTANT KRESS: I think I agree with
12 John Stetkar on the question of consistency and use of
13 importance factor to determine RTNSS and SSCs. I
14 think I'd like to see that consistency.

15 And I agree with him on the concept of
16 you're interested in preserving relative risk and not
17 absolute.

18 I don't have much to say about LOLAs. I
19 didn't want to say too much. But one of the things
20 that I don't know if it exists or not, I think there
21 should be some general sense of requirements that are
22 not specific but such things as, you know they're okay
23 to have a defense-in-depth requirement. You need to
24 have a list of things, like you need to be able to
25 possibly restore power and you need to be able to get

1 water on-site and pump it. You need to be able to
2 have a communication with the various responders. You
3 need to have a designated leader in case you have a
4 catastrophic event. You need to have the off-site
5 ability to track events, which may have to do with
6 having portable measurement equipment to know what's
7 happening.

8 CHAIR CORRADINI: These are things that
9 may or may not be NEI guidance?

10 CONSULTANT KRESS: No. I don't know what's
11 in NEI guidance.

12 CHAIR CORRADINI: That's what I was trying
13 to get at.

14 CONSULTANT KRESS: These are a list of
15 general things. I think such list needs to exist, but
16 I haven't seen it.

17 Let's see if I have anymore things. I
18 think that's about all I have.

19 CHAIR CORRADINI: Graham?

20 CONSULTANT WALLIS: Well, I thought until
21 we got to the LOLA, everything was pretty
22 straightforward really. I mean, I don't think we gave
23 the staff a hard time.

24 CHAIR CORRADINI: Okay.

25 CONSULTANT WALLIS: I think we gave them

1 an easier time than usual.

2 CONSULTANT KRESS: Oh, okay.

3 CONSULTANT WALLIS: Because everything was
4 sort of straightforward, really. There was very
5 little--

6 CHAIR CORRADINI: Tom's getting soft. He
7 thought you were being too --

8 CONSULTANT WALLIS: Nothing of any concern
9 until we got to the closed session.

10 CHAIR CORRADINI: Okay. Sorry, did you
11 have more?

12 CONSULTANT WALLIS: That's it, no.

13 CHAIR CORRADINI: Sam?

14 MEMBER ARMIJO: I agree with Graham. I
15 think the idea of an incorporation by reference is the
16 right way -- you know it's worked here. We forgot. We
17 started asking question that we had already asked
18 previously on the design certification work. It's
19 okay to raise them again, but those are settled,
20 particularly things like the vessel and embrittlement
21 and things like that. It's all in the DCD, so we just
22 got to look at them again.

23 Except for the Chapter 19, which is pretty
24 murky to me and it will probably always stay murky.
25 The best I can say there is you put together a list of

1 equipment and actions that will be nice to do, good to
2 have in the event of some event that you can't predict
3 and you got to be flexible. And that's the best I can
4 say from that. You're probably going to see more of
5 that with response for Fukushima. But that's it.

6 CHAIR CORRADINI: Okay. Said?

7 MEMBER ABDEL-KHALIK: I have no additional
8 comments.

9 CHAIR CORRADINI: Nothing.

10 MEMBER STETKAR: Nothing.

11 MEMBER STETKAR: Nothing more. I'm not
12 going to say what I've already said three times a
13 fourth time.

14 CHAIR CORRADINI: Charlie?

15 MEMBER BROWN: Nothing more.

16 CHAIR CORRADINI: Okay. So let me tell
17 you what I've got down here.

18 On Chapter 5 I did not have anything that
19 either DTE or staff were going to come back to us.
20 It's just notes to myself about things such they've
21 committed to the hydrogen water chemistry.

22 In Chapter 16 what I heard was that there
23 are tech specs and surveillance for vacuum breakers,
24 but they're going to be determined by testing that has
25 been committed to by GEH. So it's nothing to come

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 back to us, I just want to keep that on the burner as
2 we come back when our next Subcommittee meeting will
3 be on, I think, Chapter 9 and 3 will be there. I'm
4 looking at Adrian. I can't remember what's on November
5 30th.

6 MR. MUNIZ: Chapter 9, 11, 12 and 13.

7 CHAIR CORRADINI: Okay. So not 3? Three
8 is still to come. So everyone remind themselves in
9 2012 they'll have the fun of Chapter 3.

10 Hazardous gases, Dick had to depart, but
11 he wanted to make sure the comment was that even though
12 staff feels that given the analyses in terms of
13 hydrogen transport and associated control room
14 habitability issues are set, even though it may not
15 even be safety-grade, it may make good sense and good
16 practice to have some sort of monitoring of that.
17 Again, noting that comes out of that.

18 Material specs we talked about.

19 And the hydrogen water chemistry system
20 and hydrogen transport, just to generalize what Tom
21 said, I think we are owed something there. And what
22 I've written down, I think I've captured it, was that
23 we want to have something relative to analysis of the
24 hydrogen water chemistry, its impact in terms of
25 release whether it be due to habitability which they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 say is not a problem, but potential combustion. All
2 right? And what I heard and DTE can correct me if I
3 misheard, was that a lot of this is still roughly
4 designed, generally designed so details are yet to be
5 determined. But we would like to hear more about
6 that, particularly in terms of combustion.

7 For Chapter 17 I wrote down the kV and
8 risk-importance measures and I put it as a comment.
9 I didn't hear as anything they have to come back and
10 talk about.

11 MEMBER STETKAR: Well, I'd like to hear
12 how they've thought through that process of
13 transitioning from --

14 CHAIR CORRADINI: In terms of?

15 MEMBER STETKAR: -- the existing D-RAP
16 list that's incorporated by reference at this stage to
17 the Maintenance Program --

18 CHAIR CORRADINI: Okay.

19 MEMBER STETKAR: -- which they have a firm
20 commitment. I mean, they've made references to NEI
21 guidance and documents that are in turn endorsed by
22 that guidance that indeed have different numerical
23 criteria, at least as they're applied. I mean, how
24 they're going to make the transition --

25 CHAIR CORRADINI: I'm sorry, you're right.

1 MEMBER STETKAR: -- is something I'd like
2 to hear about.

3 And then finally in Chapter 19 I think the
4 biggest set of things is we wanted to hear a little
5 bit more about the justification, the bases by which
6 loss of off-site power, loss of service water and
7 particularly flooding. I don't know whether it's
8 internal or external. Let's say flooding on the
9 property are not a concern.

10 CHAIR CORRADINI: We want to see more of
11 the technical basis.

12 MEMBER STETKAR:

13 You know, decisions were reached. We want to
14 know what were the actual basis for that conclusion.

15 CHAIR CORRADINI: Right.

16 MEMBER STETKAR: And some of them were
17 more detailed than the quite qualitative arguments
18 that are at least present in the FSAR and echoed in
19 the SER.

20 CHAIR CORRADINI: Okay. So in terms of
21 Chapter 6 with hydrogen and in terms of Chapter 19
22 about that, I think those are the two things that are
23 kind of open to hear back from DTE when they're ready
24 to discuss it with us.

25 Other than that, I want to thank Detroit

1 Edison and the staff again. I think it went pretty
2 well. And I don't have any other issues or questions.

3 Our next Subcommittee meeting is November
4 30th. As Adrian said, we're going over 9, 11, 12 and
5 13 and that's on the morning of the 30th.

6 I just want to remind everybody that
7 sounds like a light load, but Chapter 9 is cats, dogs;
8 it's a lot of stuff. Okay. So please, it's going to
9 be a large thing to look through and be ready.

10 We have it arranged so that we can
11 actually go a little bit into the afternoon before we
12 start the Thermal Hydraulics Subcommittee. All right?

13 Other than that, thank you all. Meeting is
14 adjourned.

15 (Whereupon, at 3:32 the Subcommittee
16 meeting was adjourned.)

17

18

19

20

21

22

23

24

25

DTE Energy®



**Fermi 3 COLA
Presentation to ACRS Subcommittee
Resolution to Chapter 8
Open ACRS Questions**



Chapter 8, Electrical, Open ACRS Questions

Chapter 8 Open ACRS Questions

- *Do the switchyard breakers have one or two closing coils?*
- *Provide description of off-site transmission system, including the following:*
 - *Describe the routing where Fermi 2 and Fermi 3 share a common transmission corridor.*
 - *Identify the physical separation between the Fermi 2 and the Fermi 3 transmission lines where the lines share common transmission towers.*



Chapter 8, Electrical, Open ACRS Questions

Do the switchyard breakers have one or two closing coils?

- Each switchyard breaker has a single closing coil.

Considerations for restoring off-site power

- Switchyard is arranged in a breaker and a half configuration.
- Design of the Switchyard minimizes probability of single incidence of equipment failure causing the simultaneous or subsequent loss of both preferred power circuits (PPS) – IEEE 765-2002, “IEEE Standard for Preferred Power Supply (PPS).”
 - The design process will include detailed evaluations of system restoration.
 - Evaluations will include considerations of the ability to restore off-site power from at least one transmission line to the unit.



Chapter 8, Electrical, Open ACRS Questions

Provide description of off-site transmission system, including the following:

- *Describe the routing where Fermi 2 and Fermi 3 share a common transmission corridor. Include figure(s) that show locations, spacing and orientation.*
- *Identify the physical separation between the Fermi 2 and the Fermi 3 transmission lines where the lines share common transmission towers.*



Chapter 8, Electrical, Open ACRS Questions

Fermi 2 Transmission System

- 345 kV Transmission System
- 120 kV Transmission System
- Common Right of Way
- Sufficient spacing of the lines such that collapse of either of the 345 kV towers would not interrupt the other 345 kV line


Fermi 3 Transmission System

- 345 kV Transmission System
- Common Right of Way
- Sufficient spacing such that failure of any one 345 kV tower or pole due to structural failure can at most disrupt and cause loss of power distribution to itself and an adjacent line



Chapter 8, Electrical, Open ACRS Questions


Transmission System Routing (345 kV Lines)





Chapter 8, Electrical, Open ACRS Questions

Fermi 2 and 3 Common Corridor Tower Spacing





Chapter 8, Electrical, Open ACRS Questions

Fermi 2 and 3 Common Corridor – Looking West





Chapter 8, Electrical, Open ACRS Questions

Fermi 2 and 3 Common Corridor – Looking East





Chapter 8, Electrical, Open ACRS Questions

Fermi 2 and Fermi 3 Common Transmission Tower

- Fermi 2 and Fermi 3 Lines are Hung on Opposite Sides of 345 kV Transmission Tower.
- Separation between Fermi 2 and Fermi 3 345 kV transmission lines on common transmission tower are either 30 (shortest arms) or 45 feet (longer arms).
- Separation meets National Electrical Safety Code and ITC *Transmission* requirements.

DTE Energy®



**Fermi 3 COLA
Presentation to ACRS Subcommittee
Chapter 5**

Chapter 5, Reactor Coolant System and Connected Systems

Chapter Topics



Addresses the following sections (Incorporates the DCD by Reference with Standard COL Items and Standard Supplemental Information).

5.2 Integrity of Reactor Coolant Pressure Boundary

5.3 Reactor Vessel

5.4 Component and Subsystem Design

Chapter 5, Reactor Coolant System and Connected Systems

Supplemental Information



5.2 Integrity of Reactor Coolant Pressure Boundary

- STD SUP Identifies ASME Codes applicable to preservice and inservice inspection and testing programs. Same Code Editions as specified in the DCD.
- STD COL Identifies that all Class 1 austenitic or dissimilar metal welds are included in the referenced certified design.
- STD COL Provides preservice and inservice inspection and testing program descriptions and implementation milestones.

Chapter 5, Reactor Coolant System and Connected Systems

Supplemental Information



5.2 Integrity of Reactor Coolant Pressure Boundary (continued)

- STD COL Describes processes to preserve accessibility to piping systems to enable nondestructive examination (NDE) of ASME Code Class 1 austenitic and dissimilar metal welds during inservice inspection.
- STD COL Describes procedures that will be used for leak detection monitoring.

Chapter 5, Reactor Coolant System and Connected Systems

Supplemental Information



5.3 Reactor Vessel

- STD COL The pressure-temperature curves are developed in accordance with the Pressure Temperature Limit Report (PTLR). Commitment to update pressure-temperature curves prior to fuel load to reflect the plant specific material properties, if required.
- STD COL Describes the reactor vessel material surveillance program.
- STD SUP Plant operating procedures will be developed to implement the pressure-temperature curves.

Chapter 5, Reactor Coolant System and Connected Systems

Supplemental Information



5.4 Component and Subsystem Design

STD SUP Descriptions included for:

- Operating procedures will provide guidance to preclude water hammer in Reactor Water Cleanup/Shutdown Cooling System.
- Reactor Coolant System (RCS) Vents.
 - Human factors analysis of the control room displays for the RCS vents is included in DCD Chapter 18.
 - Operating procedures will be developed to govern use of the vents.

Presentation to the ACRS Subcommittee

Fermi Unit 3 COL Application Review

SER Chapter 5 with No Open Items “Reactor Coolant System and Connected Systems”

October 21, 2011

Summary of Technical Discussion Points for Fermi 3 COL Chapter 5

FSAR Section		Summary of Supplemental Information
5.1	Summary Description	J. Hale (IBR Section)
5.2	Integrity of Reactor Coolant Pressure Boundary	J. Hale (IBR Sections 5.2.1, 5.2.2, 5.2.3, & 5.2.5)
5.2.4	Preservice & Inservice Inspection & Testing of Reactor Coolant Pressure Boundary	T. Steingass (Site-Specific)
5.3.1	Reactor Vessel Materials	J. Jenkins (Site-Specific)
5.3.2	Pressure-Temperature Limits	J. Jenkins (Site-Specific)
5.3.3	Operating Conditions	J. Jenkins (Site-Specific)
5.4	Reactor Coolant System Component & Subsystem Design	J. Hale (IBR Section)

Section 5.2.4 – Integrity of Reactor Coolant Pressure Boundary

- **Staff's Review of COL & Supplemental Items:**
 - COL Item 5.2-1-A: Preservice and Inservice Inspection and Testing of Reactor Coolant Pressure Boundary
 - COL Item 5.2-3-A: Accessibility
 - SUP Item 5.2-1: System Leakage & Hydrostatic Pressure Tests
 - Post Combined License Activities:
 - ISI – Implemented prior to commercial service (COM 13.4-024)
 - PSI – Completion prior to initial plant startup (COM 13.4-026)
 - Staff Conclusion:
 - The applicant has adequately addressed COL and Supplemental information regarding Fermi 3 COL FSAR.

Section 5.3.1 – Reactor Vessel Materials

- **Staff's Review of COL & Supplemental Items:**
 - COL Item 5.3-2-A: Supplemented RVSP Description
 - COL Item 16.01-1-A 5.6.4-1: Pressure-Temperature Limit Curves.
 - **Post Combined License Activity:**
 - **If the test (RVSP) results indicate a change in the Technical Specifications is required, the expected date for submittal of the revised Technical Specification will be provided with the (Summary Technical) report. (COM 5.3.001)**
 - **The applicant identified the following license condition:**
 - **A complete reactor vessel material surveillance program will be developed prior to fuel load.**
- **Staff Conclusion:**
 - **The applicant has adequately addressed COL and Supplemental information regarding Fermi 3 COL FSAR.**

Section 5.3.2 – Pressure-Temperature Limits

- **Staff's Review of COL & Supplemental Items:**
 - COL Item 16.0-1-A 5.6.4-1: Pressure-Temperature Limit Curves
 - Pressure-Temperature Limit Report (Technical Report) submitted by the applicant.
 - Post Combined License Activities:
 - Prior to fuel load, the pressure-temperature limit curves will be updated to reflect plant-specific material properties, if required (COM 5.03-002).
 - Staff Conclusion:
 - The applicant has adequately addressed COL and Supplemental information regarding Fermi 3 COL FSAR.

Section 5.3.3 – Reactor Vessel Integrity

- **Staff's Review of COL & Supplemental Items:**
 - SUP Item 5.3-1: Operating Conditions
 - Development of plant procedures is addressed in Section 13.5, "Plant Procedures", and requires compliance with Technical Specifications to ensure that P-T limits are not exceeded.
 - Staff Conclusion:
 - The applicant has adequately addressed COL and Supplemental information regarding Fermi 3 COL FSAR.

Chapter 5 – Conclusions

In conclusion, with the exception of the confirmatory items identified, the staff has confirmed that the applicant has addressed the relevant information as specified in the referenced ESBWR DCD. In addition, the staff concludes that the applicant has met the applicable regulations and is in conformance with applicable guidance with respect to Reactor Coolant Pressure Boundary, Reactor Vessel Materials, Pressure-Temperature Limits, and Reactor Coolant System Components and Subsystems.

SER with No Open Items

Chapter 5.0

Questions/Comments

DTE Energy®



**Fermi 3 COLA
Presentation to ACRS Subcommittee
Chapter 16**



Chapter 16, Technical Specifications

Fermi 3 Technical Specifications implement the generic technical specifications (GTS) in the ESBWR Design Certification.

Fermi 3 addresses the COL items in the GTS consistent with the guidance of Interim Staff Guidance (ISG) DC/COL-ISG-08, “Necessary Content of Plant-Specific Technical Specifications When a Combined License is Issued.”



Chapter 16, Technical Specifications

COL Items Addressed in Fermi 3 Technical Specifications

- Fifty-two (52) total COL Items that address twenty-three (23) topics.
- Of the 23 topics, three (3) are considered site-specific.
- Remaining topics are addressed as standard COL items.



Chapter 16, Technical Specifications

Topics Addressed in Fermi 3 Technical Specifications COL Items

- Flexibility for Slow Control Rod Scram Times
- Concentration of Sodium Pentaborate
- Hazardous Chemicals
- Pressure and Temperature Limits Report (PTLR)
- Minimum Critical Power Ratio – Main Turbine Bypass System
- Main Turbine Bypass Valve
- Minimum Critical Power Ratio – SCRR/SRI
- Plant Location
- Non-licensed Operators for Two Units
- Minimum Qualification Standards for Unit Staff
- Guidance Documents for Procedures



Chapter 16, Technical Specifications

Topics Addressed in Fermi 3 Technical Specifications COL Items (continued)

- Temporary Outdoor Liquid Storage Tanks
- Exemptions for Regulatory Guide 1.163
- Multi-Unit Site Reporting Options
- Annual Radiological Environmental Operating Report Format
- Additional Core Operating Limits for COLR
- Response Time Testing
- Minimum and Nominal Control Rod Scram Accumulator Pressure
- Acceptance Criteria for Battery Charger Testing
- Acceptance Criteria for Verification for Fully Charged Battery
- Battery Cell Parameters
- Battery Margin for Aging Factor and State of Charge Uncertainty
- Setpoint Control Program Methodology and Implementation



Chapter 16, Technical Specifications

Site-Specific COL Items

- Hazardous Chemicals – Based on site-specific analyses Fermi 3 does not require safety-related instrumentation to monitor the control room for toxic hazards.
- Plant Location – The location of Fermi 3 is provided.
- Multi-Unit Site Reporting Options – Allows for a single submittal for a multiple-unit station for the annual radiological environmental operating report and radioactive effluent release report.



Presentation to the ACRS Subcommittee

(PM SLIDE)

Fermi Unit 3 COL Application Review

Chapter 16.0 SER with no Open Items “Technical Specifications”

October 21, 2011

Discussion Points for Technical Specifications (TS) Fermi Unit 3

Topic	Presenter
COLA Part 2 — FSAR Section 16.0 (IBR Section) <ul style="list-style-type: none">• Supplemental information (STD SUP)	J. Hale
COLA Part 4 — Plant-specific TS (PTS) & bases <ul style="list-style-type: none">• COL Information Item 16.0-1-A<ul style="list-style-type: none">➤ STD COL Items and EF3 COL Items• Use of site-specific information• Use of bounding information• Use of NRC-approved methodology and administrative program specification	C. Harbuck
Requests for Additional Information (RAIs)	C. Harbuck
Conclusions	C. Harbuck

COL Information Item 16.0-1-A

- **DCD Table 16.0-1-A, “COL Applicant Open Items”**
 - Lists 52 sets of bracketed site-specific information covering 23 topics
 - Provides guidance (Reviewer’s Notes) for completing each set of site-specific bracketed information
- **Staff review of PTS focused on acceptability of site-specific information; contributing branches:**
 - **DE:** EEB, ICE2, EMB2
 - **DSRA:** SRSB, SBCV, SBPB
 - **DCIP:** CTSB, CHPB, CQVB

COL Item Resolution with Site Specific Information Option 1 of DC/COL-ISG-08

- **Operational flexibility not adopted - bracketed info. omitted**
 - Removal of response time testing for specified components
 - Apply MCPR penalty as alternate means to meet LCO
 - Relaxed action or surveillance requirements
- **Non-applicable bracketed placeholders omitted**
 - Provisions for hazardous chemicals
 - Provisions for unprotected outdoor liquid rad-waste storage tanks
 - Reference to additional COLR-related LCOs
 - Exceptions to RG 1.163 in containment leakage rate test program
 - Minimum non-licensed staff for two units

COL Item Resolution with Site Specific Information Option 1 of DC/COL-ISG-08 (continued)

- Battery cell parameters
- Battery margin and aging factor for state of charge uncertainty
- Plant location description
- Administrative Controls
 - Minimum qualification standards for unit staff
 - Guidance documents for procedures
 - Annual radiological environmental operating report format for multiple unit site
 - Radioactive effluent release report format for multiple unit site

COL Item Resolution with Useable Bounding Information Option 2 of DC/COL-ISG-08

- **RCS Pressure-Temperature (P-T) Limits**
 - Definition of P-T limits report (PTLR) – PTS 1.1 and PTS 3.4.4
 - RCS temperature at or below which SR 3.4.4.4 and SR 3.4.4.5 require verifying reactor vessel flange and head flange temperatures are within limits in MODE 5
 - PTLR administrative control – PTS 5.6.4
 - Reference to NRC-approved P-T limits methodology NEDC-33441P, Rev 5 – PTS 5.6.4.b and PTS 3.4.4 bases
 - Confirmatory Item 16-1 to update citations from Rev 4 to Rev 5
- **Battery charger test minimum duration – PTS 3.8.1**
- **Control rod scram accumulator minimum pressure limit – PTS 3.1.5 and PTS 3.9.5**

COL Item Resolution with NRC Approved Methodology Option 3 of DC/COL-ISG-08

- Site-specific (or COL) information identified during DC review as candidates for resolution using Option 3
 - Limiting Safety System Settings (e.g., allowable [as-found actuation settings] values)
 - List of instrumentation functions for post-accident monitoring (PAM) variables (Type A, B, and C variables as defined in RG 1.97, Rev 4)
- Generic TS specify the following administrative control programs, which reference NRC approved methodologies
 - GTS 5.5.11, “Setpoint Control Program” includes a bracketed reference to be confirmed by the COL applicant —using Option 1
 - NEDE-33304P-A, “GEH ESBWR Setpoint Methodology,” Rev 4 dated May 2010
 - GTS 5.5.14, “Post-accident Monitoring Instrumentation Program”

COL Item Resolution

Requests for Additional Information

- **RAI 16-1** (ICE2) – Incorporate by reference PAM specifications (GTS 3.3.3.2, “PAM,” GTS 5.5.14, “PAM Instrumentation Program,” and GTS 5.6.5, “PAM Report”)
- **RAI 16-2** (EEB) – Provide supporting documentation for battery float current value of 30 amps as indication of full charge
- **RAI 16-4** (CTSB) – Provide correct revision of
 - NEDE-33304P-A, “GEH ESBWR Setpoint Methodology” in GTS 5.5.11, “Setpoint Control Program” – Rev 4 dated May 2010
 - NEDC-33441P-A, “GE Hitachi Nuclear Energy Methodology for the Development of ESBWR Reactor Pressure Vessel Pressure-Temperature Curves,” – Rev 5 dated February 2011
- **RAI 2.2.3-5** (SBPB) – Justify not including technical specification provisions for protecting against hazardous chemicals

CONCLUSIONS AND FINDINGS

Fermi 3 FSAR Chapters 16 & 16B

Plant-specific TS and Bases

- The Staff finds that Fermi 3 FSAR Chapters 16 and 16B
 - Correctly incorporate by reference ESBWR generic DCD Chapters 16 and 16B;
 - Include acceptable site-specific TS and bases to resolve COL Information Item 16.0-1-A; and
 - Provide acceptable and complete plant-specific TS and bases.
- The Staff finds that the Fermi 3 plant-specific TS and bases are adequate for use in the operation of EF3.
- The Staff concludes that the Fermi 3 plant-specific TS and bases satisfy 50.36, 50.36a, 52.79(a)(30), and Section IV.A.2, paragraphs c and e, of the draft ESBWR DC rule appendix to 10 CFR Part 52.

SER with No Open Items

Chapter 16.0


Questions/Comments

DTE Energy®



**Fermi 3 COLA
Presentation to ACRS Subcommittee
Chapter 17**

Chapter 17, Quality Assurance, Chapter Topics



- 17.1 Quality Assurance During Design
- 17.2 Quality Assurance During Construction and Operations
- 17.3 Quality Assurance Program Description
- 17.4 Reliability Assurance During Design Phase
- 17.5 Quality Assurance Program Description – Design Certification, Early Site Permits and New License Applicants
- 17.6 Maintenance Rule Program



Chapter 17, Quality Assurance

17.1 Quality Assurance During Design

EF3 SUP Refers to Section 17.5 for Quality Assurance (QA) program applied during COLA preparation and site specific design activities.



Chapter 17, Quality Assurance

17.2 Quality Assurance During Construction and Operation

EF3 COL Refers to Section 17.5 for QA program applied during construction and operations phases.

EF3 COL Refers to Section 17.5 for QA program applied to design activities required to adapt the certified plant design to Fermi 3 plant-specific implementation.



Chapter 17, Quality Assurance

17.3 Quality Assurance Program Description

EF3 COL Refers to Section 17.5 to provide a Quality Assurance Program Description (QAPD) describing the overall project QA program.



Chapter 17, Quality Assurance

17.4 Reliability Assurance Program During Design Phase

- STD COL There are no site-specific SSCs within the scope of the Reliability Assurance Program (RAP) and the quality elements for all SSCs within the scope of the Design-RAP (D-RAP) are in accordance with the QAPD.
- STD COL Provides a description of operational reliability assurance activities. Objectives are integrated into QA, maintenance, and other operational programs (e.g., ISI/IST).



Chapter 17, Quality Assurance

17.5 Quality Assurance Program Description - Design Certification, Early Site Permits, and New License Applicants

- EF3 COL Refers to DCD Section 17.1 for the Quality Assurance for Design Certification activities.
- EF3 SUP Provides a summary of Quality Assurance applied during preparation of the Fermi 3 COLA.
- EF3 COL The QAPD for plant specific implementation, construction and operations is based on NEI 06-14A, "Quality Assurance Program Description."



Chapter 17, Quality Assurance

17.6 Maintenance Rule Program

- STD COL Describes the Maintenance Rule Program by incorporating by reference NEI 07-02A, “Generic FSAR Template Guidance for Maintenance Rule Program Description for Plants Licensed Under 10 CFR Part 52.”
- STD SUP Describes the relationship of the Maintenance Rule Program with reliability assurance activities.
- STD SUP Describes the condition monitoring program for underground cables.

Presentation to the ACRS Subcommittee

Fermi Unit 3 COL Application Review

**SER Chapter 17 with No Open Items
“Quality Assurance”**

October 21, 2011

Summary of Technical Discussion Points for Fermi 3 COL Chapter 17

FSAR Section		Summary of Supplemental Information
17.0	Introduction	J. Hale (IBR Section)
17.1	Quality Assurance During Design	J. Hale (IBR Section)
17.2	Quality Assurance During Construction & Operations	J. Hale (IBR Section)
17.3	Quality Assurance Program Description	J. Hale (IBR Section)
17.4	Reliability Assurance Program During Design Phase	T. Hilsmeier (Site-Specific)
17.5	Quality Assurance Program Description – Design Certification, Early Site Permits, & New License Applicants	G. Lipscomb (Site Specific)
17.6	Maintenance Rule Program	T. Hilsmeier (IBR Section to NEI 07-02A)

Section 17.4 – Reliability Assurance Program During Design Phase

- **Summary of FSAR Section 17.4:**
 - Incorporated by reference ESBWR DCD, Section 17.4
 - Addressed COL information items:
 - COL Item 17.4-1-A
 - COL Item 17.4-2-A
- **Status of SER Section 17.4:**
 - No open items
 - One notable confirmatory item (17.04-2)

Section 17.4 – Reliability Assurance Program During Design Phase

- **Staff's Review of COL Item 17.4-1-A:**
 - COL Item 17.4-1-A: Identify site-specific RAP SSCs
 - FSAR specified Commitment 17.4-001 to identify the site-specific RAP SSCs prior to initial fuel load
 - RAI 17.04-2: Site-specific RAP SSCs are subjected to QA controls and should be identified in COL application
 - Applicant's response (May 25, 2011):
 - FSAR incorporates by reference the list of RAP SSCs in ESBWR DCD, Section 17.4
 - No additional RAP SSCs identified due to the bounding nature of ESBWR PRA and no departures impacting PRA
 - RAP SSCs subjected to QA controls in accordance with QAPD
 - FSAR text to be revised accordingly (Confirmatory Item 17.04-2)

Section 17.4 – Reliability Assurance Program During Design Phase

- **Staff's Review of COL Item 17.4-2-A:**
 - COL Item 17.4-2-A: Describe process for integrating RAP into operational programs for the operations phase of the plant
 - FSAR states that the RAP will be integrated into the following operational programs:
 - Maintenance Rule Program consistent with RG 1.160
 - QA Program for safety-related SSCs established through Appendix B to 10 CFR Part 50 requirements
 - QA controls for non-safety-related RAP SSCs established in accordance with Part V of SRP Section 17.5
 - Inservice inspection, inservice testing, surveillance testing, and maintenance programs

Section 17.5 – Quality Assurance Program

- **COL Application Contains:**
 - ESBWR DCD Section 17.5 (IBR)
 - COL Information Items:
 - COL 17.2-1-A: QA Program for the Construction and Operations Phases
 - COL 17.2-2-A: QA Program for Design Activities
 - COL 17.3-1-A: QA Program Document (QAPD)
 - Supplemental Information:
 - SUP 17.5-2: amplifying QA program information January 2007 – December 2009
 - QAPD based on NEI 06-14A, Revision 7

Section 17.5 – Quality Assurance Program Description – Design Certification, Early Site Permits, & New License Applications

- **COL Review Included:**
 - Comparison of QAPD to NEI 06-14A, Revision 7
 - Confirmation that all COL Information Items identified in the ESBWR DCD are addressed
 - Assessment of adequate QA program guidance contained in the Fermi Unit 3 COL FSAR
 - Assessment of meeting the intent of RG 1.206, Regulatory Position C.I.17.5.3 (oversight and control of contractor activities)
 - Resolution of inspection violations (inspection conducted in August 2009)

Section 17.5 – Quality Assurance Program Description – Design Certification, Early Site Permits, & New License Applications

- **Conclusions and status of SER Section 17.5:**
 - FSAR met regulatory requirements
 - Oversight activities met the intent of RG 1.206, Regulatory Position C.I.17.5.3
 - Addressed COL items
 - Closed inspection violations
 - No open or confirmatory items

Section 17.6 – Maintenance Rule Program

- **Applicant Submitted FSAR Section 17.6**
 - Incorporated by reference NEI 07-02A, “Generic FSAR Template Guidance for Maintenance Rule Program Description for Plants Licensed Under 10 CFR Part 52”
 - No open items or confirmatory items

Chapter 17 – Conclusions

In conclusion, with the exception of the confirmatory items identified, the staff has confirmed that the applicant has addressed the relevant information as specified in the referenced ESBWR DCD. In addition, the staff concludes that the applicant has met the applicable regulations and is in conformance with applicable guidance with respect to the QA Programs, the RAP, QAPD and Maintenance Rule Programs.

SER with No Open Items

Chapter 17.0

Questions/Comments

DTE Energy®



**Fermi 3 COLA
Presentation to ACRS Subcommittee
Chapter 6**

Chapter 6, Engineered Safety Features: Chapter Topics



Incorporates the DCD by Reference with Standard and Site Specific COL Items – denoted with * in the following List of Sections

- 6.1 Design Bases Accident Engineered Safety Feature Materials
- 6.2 Containment Systems
- 6.3 Emergency Core Cooling Systems
- 6.4 Control Room Habitability Systems*
- 6.5 Atmosphere Cleanup Systems
- 6.6 Preservice and Inservice Inspection and Testing of Class 2 and 3 Components and Piping*

Chapter 6, Engineered Safety Features: Supplemental Information



6.4 Control Room Habitability Systems:

- STD COL Procedures and training for control room habitability address NRC GL 2003-01, "Control Room Habitability."
- EF3 SUP Evaluated impact of Fermi 2 Design Bases Accident to the Fermi 3 Control Room personnel.
- EF3 COL Performed toxic gas analysis of potentially hazardous chemicals and concluded that safety-related toxic gas monitoring is not required.

Chapter 6, Engineered Safety Features: Supplemental Information



- 6.6 Preservice and Inservice Inspection and Testing of Class 2 and 3 Components and Piping
- STD COL Describes PSI/ISI programs and Flow Accelerated Corrosion (FAC) monitoring program, including implementation milestones.
- STD COL Describes plan for maintaining accessibility for PSI/ISI Non-Destructive Examination (NDE) of Class 2 and 3 austenitic and dissimilar metal welds, including the preferred NDE method.

Chapter 6, Engineered Safety Features: Supplemental Information



6.6 Preservice and Inservice Inspection and Testing of Class 2 and 3 Components and Piping (continued)

STD COL System leakage and hydrostatic pressure tests will meet applicable requirements of ASME Code for Class 2 and Class 3 Components.



Fermi 3 COL FSAR

Chapter 6 Engineered Safety Features

October 21, 2011

Overview of Chapter 6 Review

- **6.1 Design Basis Accident Engineered Safety Feature Materials (IBR)**
- **6.2 Containment Systems and related Appendices (IBR)**
- **6.3 Emergency Core Cooling Systems (IBR)**
- **6.4 Control Room Habitability Systems**
- **6.5 Atmosphere Cleanup Systems (IBR)**
- **6.6 Preservice and Inservice Inspection and Testing of Class 2 and 3 Components and Piping**

STD COL 6.4-1-A:

Control Room Habitability Area (CRHA) Procedures and Training

- **Generic Letter 2003-01 and Generic Issue 83**
 - **COM 13.4-028 Non-Licensed plant staff training program**
 - **COM 13.4-016 Reactor operator training program**
 - **COM 13.5-002 Operating Procedures**
- **Applicant's Information Acceptable**

EF3 COL 6.4-2-A: Toxic Gas Analysis

- **GDC 19, TMI Action Plan III.D.3.4, Reg Guide 1.78**
- **COL FSAR Information**
 - **N₂ (Fermi 2) and CO₂ (Fermi 3) identified (Section 2.2)**
 - **Concentrations at CRHA intake exceed the limits (RG 1.78)**
 - **CRHA concentrations significantly lower than the limits**
- **Staff Review**
 - **RAI 02.02.03-5 (ML092750405)**
 - **List of all toxic chemicals**
 - **Details of toxic gas evaluations**
- **Applicant's Conclusions Acceptable**
 - **N₂ and CO₂ release do not pose any threat to the CR operators**
 - **No Seismic Category I safety-related toxic gas monitors required**

Section 6.4 - Radiological Control Room Habitability

EF3 SUP 6.4-1

Impact of Unit 2 DBA on Unit 3 Control Room

- **Fermi 3 control room doses from Fermi 2 DBAs are less than the doses from Fermi 3 DBAs.**
- **The Fermi 3 control room meets GDC-19.**

ASME CLASS 2 AND 3 PSI/ISI

- **Section 6.6 of the Fermi 3 COL FSAR addresses Preservice and Inservice Inspection and Testing of Class 2 and 3 components and piping.**
- **This section incorporates by reference (Section 6.6 of the ESBWR DCD, Tier 2, Revision 9) and provides additional information on the following COL items**

STD COL 5.2-1-A

System Pressure Tests

- **The additional information states that the system leakage and hydrostatic tests will meet all requirements of the ASME Code and the limitations under 10 CFR 50.55a**
- **The staff concludes that the additional information agrees with the limitations for pressure testing of Class 1, 2, and 3 components in 10 CFR 50.55a and is acceptable to the staff**

STD COL 6.6-1-A

Augmented Inservice Inspection

- **Additional information is provided in Section 6.6 to address a full description of the PSI/ISI programs and augmented programs under Section 5.2.4**
- **Milestones for the program are added under Section 13.4 – Operational Programs Required by NRC Regulations**
- **In Section 6.6.7.1 of the FSAR, the applicant addresses FAC Program Description**

STD COL 6.6-1-A
Augmented Inservice Inspection (cont.)

- **ISI - Implemented prior to commercial service (COM 13.4-024)**
- **PSI – Completion prior to plant startup (COM 13.4-026)**
- **Staff concludes that the PSI/ISI and FAC programs meets SRP guidance provided in Section 6.6 of NUREG-0800, and is therefore acceptable**

STD COL 6.6-2-A **PSI/ISI Accessibility**

- **The applicant provided a discussion about preserving accessibility of welds to meet ASME Code nondestructive examination coverage requirements**
- **The additional information discusses the use of radiography to obtain the examination coverage**
- **Staff concludes that the additional information meets SRP guidance provided in Section 6.6 of NUREG-0800 and is therefore acceptable**

Conclusion

- **Staff's finding related to information incorporated by reference is in NUREG-1966 (ESBWR FSER)**
- **Staff reviewed the COL information items and additional information provided by the applicant in Chapter 6 of the COL FSAR and found them to be acceptable**
- **There are no open items in the staff's review of COL FSAR Chapter 6**

Questions/Comments

DTE Energy®



**Fermi 3 COLA
Presentation to ACRS Subcommittee
Chapter 19**

Chapter 19, Probabilistic Risk Assessment and Severe Accidents



Chapter Topics:

- PRA Results and Insights
- Severe Accident Evaluations
- PRA Maintenance
- Conclusions
- Regulatory Treatment of Non-Safety Systems
- Availability Controls Manual
- Deterministic Analysis for Containment Pressure Capability
- Probabilistic Analysis for Containment Pressure Fragility
- Assessment of Malovent Aircraft Impact
- Summary of Plant-Specific PRA Review

Chapter 19, Probabilistic Risk Assessment and Severe Accidents



19.2 PRA Results and Insights

STD COL Commitment to compare as-built SSC High Confidence Low Probability of Failures (HCLPFs) to those assumed in the ESBWR seismic margin analysis.

- DCD seismic margin for HCLPF is 1.67 times the Certified Seismic Design Response Spectra.
- Comparison and analyses will be completed prior to fuel load.

Chapter 19, Probabilistic Risk Assessment and Severe Accidents



19AA Summary of Plant-Specific PRA Review

EF3 SUP

Site-specific PRA attributes were compared to the ESBWR PRA:

- Loss of Preferred Power frequency
- Loss of Service Water frequency
- Seismic Fragilities
- Other known site-specific issues such as unique offsite consequence issues (terrain, meteorological)
- Internal flooding associated with the Yard Area.

The review concluded that the ESBWR PRA provides a reasonable representation of the Fermi 3 site parameters and conditions.

Chapter 19, Probabilistic Risk Assessment and Severe Accidents



19.5 Conclusions

EF3 SUP No departures are taken from the DCD that affect the ESBWR PRA.

Plant specific review is summarized in Appendix 19AA.

Incorporation of DCD Chapter 19 into the FSAR satisfies the requirement for a description of the plant-specific PRA.

Presentation to the ACRS Subcommittee

Fermi Unit 3 COL Application Review

Chapter 19

PRA Results and Severe Accidents Evaluation

October 21, 2011



Staff Review Team

- **Project Managers**
 - **Adrian Muniz, Lead PM, DNRL/BWR**
 - **Raj Anand, Chapter PM, DNRL/BWR**
- **Technical Staff**
 - **Mark Caruso, Sr. Reliability & Risk Engineer, DSRA/SPRA**
 - **Jim Xu, Sr. Structural Engineer, DE/SEB2**

Regulations and Review Guidance

- 10 CFR 52.79(a)(46)
 - describe plant-specific PRA and results
- 10CFR 52.79(d)(1)
 - may reference design cert PRA and update to reflect site/design specific parameters and features
- 10 CFR 52.79(a)(17)
 - show compliance with relevant TMI requirements
- 10 CFR 50.34(f)(i) – TMI Requirement
 - Do a plant/site specific PRA to seek improvements in reliability of core and containment cooling capability
- NUREG-0800 Section 19.0 (SRP)

Regulations and Review Guidance (continued)

- Interim Staff Guidance COL/DC-ISG-03 (PRA)
- Interim Staff Guidance COL/DC-ISG-20 (Seismic Margins)
- Regulatory Guide 1.206



Discussion of Technical Review

- Plant Specific PRA & Severe Accident Evaluations

Plant Specific PRA & Severe Accidents Evaluation

- Application incorporated Certified Design PRA and Severe Accident Evaluation by reference and stated site-specific and plant-specific design features and design parameters were enveloped in Certified Design PRA.
- RAIs issued to obtain supporting site-specific evaluation.
- Applicant provided its site-specific evaluation and included results into FSAR.
- Staff reviewed applicant's site-specific evaluation and agrees with conclusion.

Plant Specific PRA – Review Issues

- loss of preferred power (LOPP) frequency
 - bounded by frequency in Certified Design PRA
- loss of service water frequency
 - bounded by frequency in Certified Design PRA
- site-specific terrain and meteorological data
 - high winds analysis in Certified Design PRA is bounding

Plant Specific PRA – Review Issues

- Seismic Margins
 - site ground motion response spectra and foundation input response spectra enveloped by ESBWR CSDRS
 - geotechnical profiles are characterized as a hard rock site
 - site characteristics are bounded by the ESBWR site parameters
 - Certified design Seismic Margins Analysis bounding
 - Fermi must confirm plant-specific HCLPF values bounded by values in Certified Design analysis prior to fuel load

Plant Specific PRA – Review Issues

- **Plant-specific flooding of the yard**
 - yard flood zone includes all outside areas of the site
 - components in yard that support a safety function are manual fire hose connections for refilling ICS/PCCS pools; connections not credited in PRA
 - Certified Design PRA flooding analysis bounding
- **Plant-specific service water (SW) building flooding**
 - Certified Design PRA treats SW building as one flood zone
 - all SW pumps assumed to fail for any flooding in zone
 - Certified Design PRA flooding analysis is bounding

Conclusions

- The applicant has addressed the required information relating to PRA results and insights, and Severe Accidents evaluation.
- The staff concludes that Fermi 3 FSAR Chapter 19 is acceptable and conform to regulatory requirements.



Questions/Comments