

DISTRIBUTION AFTER ISSUANCE OF OPERATING LICENSE

NRC FORM 195
(2-76)

U.S. NUCLEAR REGULATORY COMMISSION

DOCKET NUMBER

50-263

FILE NUMBER

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

TO: Mr. Victor Stello

FROM: NSP
Minneapolis, Minnesota 55401
L. O. MayerDATE OF DOCUMENT
09/27/77DATE RECEIVED
09/30/77☒ LETTER
☒ ORIGINAL
☐ COPY☐ NOTORIZED
☒ UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

40 CC signed

DESCRIPTION

ENCLOSURE

Consists of additional information to 09/19/77 submittal of License Amendment Request to revise Table 4.6.1 of Appendix Tech Specs, "In-Service Inspection Requirements for Monticello concerning control rod housing pressure boundary welds....

1p

2p

PLANT NAME: MONTICELLO
jcm 09/30/77

40 CYS ENCL Rec'd *

SAFETY

FOR ACTION/INFORMATION

BRANCH CHIEF: (7)

DAVIS

INTERNAL DISTRIBUTION

REG FINE

NRC-PDR

I & E (2)

OELD

HANAUER

CHECK

STELLO

EISENHUT

SHAO

BAER

BUTLER

GRIMES

J. COLLINS

EXTERNAL DISTRIBUTION

CONTROL NUMBER

LPDR: MINNEAPOLIS, MINN.

TIC


NSIC

16 CYS ACRS SENT CATEGORY B

442730151

NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401



September 27, 1977

Mr Victor Stello, Director
Division of Operating Reactors
c/o Distribution Services Branch, DDC, ADM
U S Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr Stello:

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

Supplement No. 1 to
License Amendment Request Dated September 19, 1977

On September 19, 1977 we submitted a License Amendment Request to revise Table 4.6.1 of the Appendix A Technical Specifications, "In-Service Inspection Requirements for Monticello." One of the requested changes would substitute an examination during system pressure tests for the volumetric examination now specified for control rod housing pressure boundary welds. This change is consistent with Section XI of the ASME Code (1974 Edition through Summer 1975 Addenda).

We have been requested to supply additional information to justify our determination that these welds are exempt from volumetric and surface examination by Article IWB-1220(b)(1) of Section XI of the Code. The purpose of this Supplement is to provide that information.

Attached you will find a drawing of the weld in question and a summary of the analysis showing that under postulated conditions of loss of coolant from the component during normal reactor operation, the reactor can be shut down and cooled down in an orderly manner assuming makeup is provided using normal systems supplied by onsite power.

Yours very truly,

David Musolf for

L O Mayer, PE
Manager of Nuclear Support Services

LOM/DMM/ak

cc: J G Keppler
G Charnoff
MPCA - Attn: J W Ferman
MECCA - Attn: R J Hatling
S J Gadler

Attachments

772730151

Control Rod Housing Pressure Boundary Weld - IWB-1220(b)(1) Analysis Summary

Refer to Figure (1). Failure of control rod housing to internal nozzle weld results in maximum break area of:

$$D_1 = \text{Maximum internal nozzle diameter} = 6.000 \text{ inch}$$

$$D_2 = \text{Minimum CRD housing outside diameter} = 5.985 \text{ inch}$$

$$A_m = \frac{\pi}{4} (D_1 + D_2)(D_1 - D_2) = 0.14 \text{ in}^2$$

The CRD support structure (Reference 1) prevents the housing from dropping far enough to clear the vessel penetration.

The maximum two-phase vessel blowdown through this break area (Reference 2, Figure 2-4) assuming saturated liquid at 1025 psia is 7.8 lb_m/sec.

The capacity of the RCIC system is 400 gallons/minute of water (Reference 3). Assuming a water temperature of 140°F, this corresponds to a makeup rate of 54 lb_m/sec. The coolant loss through a failure of the control rod housing weld is therefore well within the capacity of the system.

References:

1. Van Zylstra, E. H., "Analysis of Potential Control Rod Drive System Failures Resulting in Control Rod Withdrawal," General Electric Topical Report GEGR-5089, March, 1966.
2. Moody, F. J., "Maximum Two-Phase Vessel Blowdown from Pipes," General Electric Topical Report APED-4827, April 20, 1965.
3. Monticello Final Safety Analysis Report, Table 10-2-3, page 10-2.13.




Figure 1 CRD Housing Welds

* Refer to Table 4.6.1, "In-Service Inspection Requirements for Monticello," of the Appendix A Technical Specifications for the Monticello Nuclear Generating Plant.