AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL (TEMPORARY FORM)

۰.

. . 1

A

CONTROL NO: 7190

						LTP	· · · · · · · · · · · · · · · · · · ·	
FROM: Northern States Powe Minneapolis, Minnese	er Company ota 55401	DATE OF DOC	DATE	REC'D	LTR	MEMO	RPT	OTHER
L. U. Mayer		9-13-73	9-26-	-73	x			
TO:		ORIG	CC	OTHER		SENT A	EC PDR	X
y olt						SENT I	LOCAL P	DR X
Mr. O'Leary		3 signed						
CLASS UNCLASS	PROP INFO	INPUT	NO CY	S REC'D		DOCKET	C NO:	
XX	·	XXX		40		50-263		·
DESCRIPTION:			ENCLO	SURES:	1			· · ·
Ltr trans the follow:	ing:	Appondix A of the Tor			zation	to Unai	nge /	
		$9_{-1}3_{-7}3$ $W/A+t_{-1}$		ecn spe	ch Specs, notarized			
	·		Safa	-/J tv Valvo	Setnoi	acheu K nt Incr	pr, m	Successo -
			Jare	cy varve	berbor	ne mer	ease .	
	·				-> -	10711	היות ב <mark>ח</mark>	ecn
			( 40	cys rec'	d)	AUNN	JMLLU	ULU
PLANT NAME: Montice	110					Dô	Not R	emove
·			-			DU_	INCL IN	
		FOR ACTION/IN	FORMAT	ION		. 9	-26-73	AB
BUTLER(L) SCHW	VENCER(L)	ZIEMANN(L)		REGAN	E)			
W/ Copies W/	Copies	W/9 Copies		W/ Co	Dies	÷		
CLARK(L) STOI	LZ(L)	DICKER(E)			F			
W/ Copies W/	Copies	W/ Copies		W/ Co	pies			
GOLLER(L) VASS	SALLO(L)	KNIGHTON (E)	)		•			
N/ Copies W/	Copies	W/ Copies		W/ Co	pies			
KNIEL(L) SCHE	EMEL(L)	YOUNGBLOOD	(E)					
N/ Copies W/	Copies	W/ Copies		W/ Co	pies			
<u> </u>	· · · · · · · · · · · · · · · · · · ·							
REC FILE	FCH PEVIEU	DENTON	XI BUTIC	JN			T THE	
AFC PDR F	TENDRIE	CRIMES	LI	C ASST			ATTMAN	
		GITTUD				DA CA	Τ ΤΖΜΔΝ	
DGC ROOM P-506A S	CHROEDER	CAMMILL	. 🗥					
DGC, ROOM P-506A S	SCHROEDER ACCARY	GAMMILL		LGGS (L) EARTN (L)		ол	LI LOPIAN	
DGC, ROOM P-506A S AUNTZING/STAFF M CASE K	SCHROEDER IACCARY NIGHT	GAMMILL KASTNER BALLARD	GI GI	EGGS (L) EARIN (L) DULBOURNE	(L)	DA PT	ANS	
DGC, ROOM P-506A S MUNTZING/STAFF M CASE K MAMBUSSO P	SCHROEDER MACCARY NIGHT PAWLICKI	GAMMILL KASTNER BALLARD SPANGLER	GI GI GI LI	EGGS (L) EARIN (L) DULBOURNE EE (L)	(L)	PL MC	ANS	
DGC, ROOM P-506A S MUNTZING/STAFF M CASE K JIAMBUSSO P 30YD S	SCHROEDER IACCARY NIGHT PAWLICKI SHAO	GAMMILL KASTNER BALLARD SPANGLER	D GI GC LI M/	EGGS (L) EARIN (L) DULBOURNE EE (L) AIGRET (L	(L) )	PL MC	ANS DONALD BE	
DGC, ROOM P-506A S MUNTZING/STAFF M CASE K GIAMBUSSO P BOYD S 100RE (L)(BWR) S	SCHROEDER MACCARY INIGHT PAWLICKI SHAO STELLO	GAMMILL KASTNER BALLARD SPANGLER ENVIRO	D GI GC LI M/ SI	EGGS (L) EARIN (L) DULBOURNE SE (L) AIGRET (L ERVICE (L	(L) )	PL MC	ANS DONALD BE	
DGC, ROOM P-506ASMUNTZING/STAFFMCASEKSIAMBUSSOP30YDS400RE (L) (BWR)SDEYOUNG (L) (PWR)H	SCHROEDER MACCARY INIGHT PAWLICKI SHAO STELLO HOUSTON	GAMMILL KASTNER BALLARD SPANGLER <u>ENVIRO</u> MULLER	GI GI LI M/ SI SI	EGGS (L) EARIN (L) DULBOURNE SE (L) AIGRET (L ERVICE (L EPPARD (	(L) ) ) E)	PL MC V DU	<u>ANS</u> DONALD BE FO	
DGC, ROOM P-506ASMUNTZING/STAFFMCASEKSIAMBUSSOPBOYDSMOORE (L)(BWR)SDEYOUNG(L)(PWR)HKOVHOLT (L)N	SCHROEDER MACCARY INIGHT PAWLICKI SHAO STELLO HOUSTON MOVAK	GAMMILL KASTNER BALLARD SPANGLER <u>ENVIRO</u> MULLER DICKER	UD GI GO LI M/ SI SI SI	EARIN (L) DULBOURNE EE (L) AIGRET (L ERVICE (L HEPPARD ( HITH (L)	(L) ) ) E)	PL MC V DU IN C.	ANS DONALD BE FO MILES	
DGC, ROOM P-506ASMUNTZING/STAFFMCASEKGIAMBUSSOFBOYDS100RE (L) (BWR)SDEYOUNG (L) (PWR)HSKOVHOLT (L)N. COLLINSR	SCHROEDER IACCARY INIGHT PAWLICKI SHAO STELLO IOUSTON IOVAK ROSS	GAMMILL KASTNER BALLARD SPANGLER <u>ENVIRO</u> MULLER DICKER KNIGHTON	UD GI GI LI MA SI SI SI TT	EGGS (L) EARIN (L) DULBOURNE EE (L) MIGRET (L ERVICE (L HEPPARD ( MITH (L) EETS (L)	(L) ) ) E)	PL MC DU IN C.	ANS DONALD BE FO MILES LEN CAE	BELL(Ltr)
DGC, ROOM P-506ASMUNTZING/STAFFMCASEKSIAMBUSSOFBOYDS400RE (L) (BWR)SDEYOUNG (L) (PWR)H3KOVHOLT (L)N?. COLLINSR	SCHROEDER IACCARY INIGHT PAWLICKI SHAO STELLO IOUSTON IOVAK ROSS IPPOLITO	GAMMILL KASTNER BALLARD SPANGLER <u>ENVIRO</u> MULLER DICKER KNIGHTON YOUNGBLOOD	UD GI GI LI MA SI SI SI VA	EGGS (L) EARIN (L) DULBOURNE EE (L) AIGRET (L ERVICE (L EPPARD ( MITH (L) EETS (L) ADE (E)	(L) ) ) E)	PL MC DU <u>IN</u> C.	ANS DONALD BE <u>FO</u> MILES LEN CAE	BELL(Ltr)
DGC, ROOM P-506A       S         MUNTZING/STAFF       M         CASE       K         GIAMBUSSO       P         BOYD       S         400RE (L)(BWR)       S         DEYOUNG(L)(PWR)       H         SKOVHOLT (L)       N         COLLINS       I <u>REG OPR</u> T	SCHROEDER MACCARY INIGHT PAWLICKI SHAO STELLO HOUSTON HOUSTON HOVAK ROSS IPPOLITO TEDESCO	GAMMILL KASTNER BALLARD SPANGLER <u>ENVIRO</u> MULLER DICKER KNIGHTON YOUNGBLOOD REGAN	UD GI GI LI MI SI SI SI VI WI	EGGS (L) EARIN (L) DULBOURNE EE (L) AIGRET (L ERVICE (L EEPPARD ( HITH (L) EETS (L) ADE (E) LLLIAMS (	(L) ) E) E)	PL MC DU <u>IN</u> C.	ANS DONALD BE <u>FO</u> MILES LEN CAE	ELL(Ltr)
DGC, ROOM P-506ASMUNTZING/STAFFMCASEKGIAMBUSSOPBOYDS400RE (L) (BWR)SDEYOUNG (L) (PWR)HSKOVHOLT (L)NCOLLINSRLLCOPRTTLE & REGION (3)L	SCHROEDER MACCARY INIGHT PAWLICKI SHAO STELLO HOUSTON NOVAK ROSS IPPOLITO TEDESCO LONG	GAMMILL KASTNER BALLARD SPANGLER <u>ENVIRO</u> MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDF	CI GI GI GI MI SI SI SI SI SI VI WI X	EGGS (L) EARIN (L) DULBOURNE EE (L) AIGRET (L ERVICE (L EPPARD ( HEPPARD ( HITH (L) EETS (L) ADE (E) ELLIAMS ( LLSON (L)	(L) ) E) E)	PL MC DU IN C.	ANS DONALD BE FO MILES LEN CAE	BELL(Ltr)
DGC, ROOM P-506ASMUNTZING/STAFFMCASEKSIAMBUSSOFBOYDS400RE (L) (BWR)SDEYOUNG (L) (PWR)HSKOVHOLT (L)NCOLLINSRRIREG OPRT'ILE & REGION (3)LIORRISL	SCHROEDER IACCARY INIGHT PAWLICKI SHAO STELLO IOUSTON IOVAK ROSS IPPOLITO TEDESCO JONG AINAS	GAMMILL KASTNER BALLARD SPANGLER <u>ENVIRO</u> MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDF	CI GI GI GI M/ SI SI SI SI SI SI SI SI SI SI SI SI SI	EGGS (L) EARIN (L) DULBOURNE EE (L) AIGRET (L ERVICE (L HEPPARD ( HITH (L) EETS (L) ADE (E) ILLIAMS ( LLSON (L)	(L) ) E) E)	PL MC DU IN C.	ANS DONALD BE <u>FO</u> MILES LEN CAE	BELL(Ltr)
DGC, ROOM P-506ASMUNTZING/STAFFMCASEKSIAMBUSSOFBOYDS400RE (L) (BWR)SDEYOUNG (L) (PWR)HSKOVHOLT (L)NCOLLINSRLLCORRISLIORRISLSTEELEB	SCHROEDER IACCARY INIGHT PAWLICKI SHAO STELLO IOUSTON IOVAK ROSS IPPOLITO TEDESCO IONG AINAS BENAROYA	GAMMILL KASTNER BALLARD SPANGLER ENVIRO MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDF HARLESS	CI GI GI GI SI SI SI SI SI SI SI SI SI SI SI SI SI	EGGS (L) EARIN (L) DULBOURNE EE (L) AIGRET (L ERVICE (L EPPARD ( HITH (L) EETS (L) ADE (E) LLLIAMS ( LLSON (L)	(L) ) E) E)	PL MC DU IN C.	ANS DONALD BE <u>FO</u> MILES LEN CAE	ELL(Ltr)
DGC, ROOM P-506A       S         MUNTZING/STAFF       M         CASE       K         GIAMBUSSO       P         BOYD       S         400RE (L)(BWR)       S         DEYOUNG(L)(PWR)       H         SKOVHOLT (L)       N         P. COLLINS       R         ILE & REGION(3)       L         IORRIS       L         TTEELE       B	SCHROEDER MACCARY INIGHT PAWLICKI SHAO STELLO HOUSTON HOVAK ROSS IPPOLITO TEDESCO LONG LAINAS SENAROYA OLLMER	GAMMILL KASTNER BALLARD SPANGLER <u>ENVIRO</u> MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDF HARLESS	CI GI GI GI M/ SI SI SI SI SI SI SI SI SI SI SI SI SI	EGGS (L) EARIN (L) DULBOURNE EE (L) AIGRET (L RVICE (L HEPPARD ( HEPPARD ( HITH (L) EETS (L) ADE (E) LLLIAMS ( LLSON (L)	(L) ) E) E)	PL MC DU IN C. ALI	ANS DONALD BE FO MILES LEN CAE	SELL(Ltr)
DGC, ROOM P-506A       S         MUNTZING/STAFF       M         CASE       K         GIAMBUSSO       F         BOYD       S         400RE (L) (BWR)       S         DEYOUNG (L) (PWR)       H         SKOVHOLT (L)       N         ?. COLLINS       R         YILE & REGION (3)       L         10RRIS       L         YTEELE       B         V       V	SCHROEDER MACCARY INIGHT PAWLICKI SHAO STELLO HOUSTON HOVAK ROSS PPOLITO TEDESCO JONG AINAS BENAROYA OLLMER	GAMMILL KASTNER BALLARD SPANGLER <u>ENVIRO</u> MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDF HARLESS EXTERNAL DISTF		EGGS (L) EARIN (L) DULBOURNE EE (L) AIGRET (L) AIGRET (L) EETS (L) ADE (E) ILLIAMS ( LLIAMS ( LLIAMS (L)	(L) ) E) E)	PL MC DU IN C. ALI	ANS DONALD BE FO MILES LEN CAE	BELL(Ltr)
DGC, ROOM P-506A       S         MUNTZING/STAFF       M         CASE       K         SIAMBUSSO       F         BOYD       S         400RE (L) (BWR)       S         DEYOUNG (L) (PWR)       H         SKOVHOLT (L)       N         P. COLLINS       R         I       I         STEELE       B         V       V         I - LOCAL PDR Minnear	SCHROEDER MACCARY INIGHT PAWLICKI SHAO STELLO HOUSTON HOVAK ROSS PPOLITO TEDESCO JONG JAINAS SENAROYA OLLMER	GAMMILL KASTNER BALLARD SPANGLER ENVIRO MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDF HARLESS EXTERNAL DISTR		EGGS (L) EARIN (L) DULBOURNE EE (L) AIGRET (L ERVICE (L HEPPARD ( HITH (L) EETS (L) ADE (E) ILLIAMS ( LSON (L)	(L) ) E) E)	PL MC DU IN C. ALI	ANS DONALD BE <u>FO</u> MILES LEN CAE	BELL(Ltr)
DGC, ROOM P-506A       S         MUNTZING/STAFF       M         CASE       K         SIAMBUSSO       P         BOYD       S         400RE (L) (BWR)       S         DEYOUNG (L) (PWR)       H         SKOVHOLT (L)       N         P. COLLINS       R         I       I         XEG OPR       T         YILE & REGION (3)       L         10RRIS       L         STEELE       B         V       V         I       - LOCAL PDR Minnear         NSIC (PUCHANAN)       N	SCHROEDER MACCARY INIGHT PAWLICKI SHAO STELLO HOUSTON HOVAK ROSS PPOLITO TEDESCO LONG AINAS BENAROYA YOLLMER	GAMMILL KASTNER BALLARD SPANGLER ENVIRO MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDF HARLESS EXTERNAL DISTR	CIBUTIC	AB'S	(L) ) E) E)	PL MC DU IN C. ALI	ANS DONALD BE FO MILES LEN CAE	ELL(Ltr)
DGC, ROOM P-506A       S         MUNTZING/STAFF       M         CASE       K         GIAMBUSSO       P         BOYD       S         400RE (L) (BWR)       S         DEYOUNG (L) (PWR)       H         SKOVHOLT (L)       N         P. COLLINS       R         I       I         NCOLLINS       L         IORRIS       L         STEELE       B         V       V         I - LOCAL PDR Minnear       V         I - DTIE (ABERNATHY)       - NSIC (BUCHANAN)         ASLB (VODE (SAVEE (SAVE	CHROEDER MACCARY NIGHT PAWLICKI PAWLICKI SHAO STELLO HOUSTON HOVAK ROSS PPOLITO TEDESCO ONG AINAS BENAROYA OLLMER	GAMMILL KASTNER BALLARD SPANGLER <u>ENVIRO</u> MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDF HARLESS EXTERNAL DISTE (1) (2)(10)-NATIO 1-R.Sch	CIBUTIC	AB'S	(L) ) E) E)	PL MC DU IN C. ALI	ANS DONALD BE FO MILES LEN CAE	SELL(Ltr)
DGC, ROOM P-506A S MUNTZING/STAFF M CASE K GIAMBUSSO P BOYD S 400RE (L) (BWR) S DEYOUNG (L) (PWR) H SKOVHOLT (L) N P. COLLINS R I REG OPR T 'ILE & REGION (3) L 10RRIS L STEELE B V - LOCAL PDR Minnear - DTIE (ABERNATHY) - NSIC (BUCHANAN) - ASLB (YORE / SAYRE/ WOODARD / "H" ST	CHROEDER MACCARY INIGHT PAWLICKI SHAO STELLO HOUSTON HOVAK ROSS PPOLITO TEDESCO LONG AINAS BENAROYA OLLMER	GAMMILL KASTNER BALLARD SPANGLER <u>ENVIRO</u> MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDF HARLESS EXTERNAL DISTF (1)(2)(10)-NATIO 1-R.Sch 1-W. PH	CIBUTIC	AB'S Corn, CC, GT	(L) ) E) E)	PL MC DU IN C. ALI	ANS DONALD BE FO MILES LEN CAE DR-SAN ERALD I OKHAVEN	SELL(Ltr)
DGC, ROOM P-506A S MUNTZING/STAFF M CASE K GIAMBUSSO F BOYD S 400RE (L) (BWR) S DEYOUNG (L) (PWR) H SKOVHOLT (L) N P. COLLINS R I REG OPR T YILE & REGION (3) L 10RRIS L STEELE B V I - LOCAL PDR Minnear I - DTIE (ABERNATHY) - NSIC (BUCHANAN) - ASLB (YORE / SAYRE / WOODARD /"H" ST. - CYS ACRS HOLDING	SCHROEDER MACCARY INIGHT PAWLICKI SHAO STELLO HOUSTON HOVAK ROSS PPOLITO TEDESCO JONG AINAS SENAROYA OLLMER	GAMMILL KASTNER BALLARD SPANGLER ENVIRO MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDF HARLESS EXTERNAL DISTF (1)(2)(10)-NATIO 1-R.Sch 1-W. PH 1-CONSU	CIBUTIC	AB'S CARIN (L) DULBOURNE SE (L) AIGRET (L) AIGRET (L) AIGRET (L) AIGRET (L) ADE (E) ILLIAMS ( ILLIAMS ( ILSON (L) DN AB'S Cer, OC, GT FON, Rm E S ME (ACDAR	(L) ) E) E) ,D-323 -201 G	PL MC DU IN C. ALI	ANS DONALD BE FO MILES LEN CAE DR-SAN, ERALD I OKHAVEN GMED (WA	ELL(Ltr)

*.....* 



#### NORTHERN

#### MINNEAPOLIS, MINNESOTA 55401

DOCKETED USAEC

SEP 26 1973

GULATORY

DOCKET CLERK

CTION

September 13, 1973

Mr. J F O'Leary, Director Directorate of Licensing Office of Regulation U S Atomic Energy Commission Washington, D C 20545

Dear Mr. O'Leary:

MONTICELLO NUCLEAR GENERATING PLANT Docket No. 50-263 License No. DPR-22

### Change Request Dated September 13, 1973

Attached are three signed originals and 37 conformed copies of a request for a change of Technical Specifications, Appendix A, of the Provisional Operating License, DPR-22, for the Monticello Nuclear Generating Plant. This change request has been reviewed by the Operations Committee and the Safety Audit Committee.

We request these changes as a result of a reanalysis of pressure transients for the end of cycle fuel exposures. We believe that these proposed changes do not introduce concerns not previously raised or reviewed by the Commission.

Also included in this transmittal are 40 copies of a report prepared by General Electric Company which presents transient analyses in support of the requested change in Technical Specifications. This report is provided to supplement your review. It should be noted, however, that this report is based on arreference exposure threshold of 2400 MWD/STU. This exposure threshold was determined as a refinement of the 2250 MWD/ STU figure reported in our June 1, 1973 letter. Concomitant with the preparation of the attached analysis, information was obtained indicating that the assumed relief valve delay time may not be conservative. A new figure of 2000 MWD/STU based on a longer delay in initial valve opening time was reported in an August 1, 1973 letter. Subsequently, in lieu of more refined calculations verifying that figure, conservative estimating techniques have identified an even lower exposure threshold of 1640 MWD/

- 2 -

STU. Rod patterns have been fixed at Monticello, as of September 13, 1973 at a conservative exposure level of 1540 MWD/STU in the manner discussed in our August 21, 1973 letter. This 1640 MWD/STU threshold is currently being used as a basis for operating limitations. The exposure threshold is increased by the change in safety valve set points discussed herein and a reanalysis to determine the revised threshold is currently in preparation. This updated analysis will account for the planned modifications to the relief valves to reduce the delay time and the new safety valve set points, and will be submitted in support of operation to the end of cycle 2. (The reanalysis is expected to justify extension of the limiting exposure threshold to about 2680 MWD/STU.) It should be recognized that plant operations at Monticello are being conducted conservatively in response to new information relating to end-of-cycle transients. Information received subsequent to the attached report has notcaltered the validity of the report with respect to the bases for changes in the safety valve set points.

A second aspect requiring clarification relates to the safety valve sizing transients and associated safety valve margins. Safety valves were initially sized assuming no credit for scram. After the Code was changed to allow indirect scram, reanalysis indicated that only two safety valves were required. NSP arbitrarily elected that four, of the originally planned twelve, safety valves be retained. At that time, it was considered prudent to retain some of the margin gained through the Code change. However, no attempts were made to take credit for the additional valves since there was no obligiation to provide margins beyond that required by the Code. It should be noted that the reported allowable end of cycle power level of 91% of rated power is based on the relief valve capacity. Calculations to verify sufficient capacity of the four safety valves show extensive margin for a main steamline isolation transient occurring at rated power. Should credit for the safety valves be limited to present requirements, this sizing transient would not be controlling with respect to power level.

Yours very truly,

L. O. Mayer

L O Mayer, PE Director of Nuclear Support Services

LOM/DWJ/br

cc: J G Keppler G Charnoff Minnesota Pollution Control Agency Attn K Dzugan Ľ

## UNITED STATES ATOMIC ENERGY COMMISSION

#### NORTHERN STATES POWER COMPANY

Monticello Nuclear Generating Plant

Docket No. 50-263

U.S.

ATOMIC ENERGY COMMISSION Regulatory Mail Section

REQUEST FOR AUTHORIZATION OF A CHANGE IN TECHNICAL SPECIFICATIONS OF APPENDIX A

PROVISIONAL OPERATING LICENSE NO. DPR-22

(Change Request Dated September 13, 1973)

Northern States Power Company, a Minnesota corporation, requests authorization for changes to the Technical Specifications as shown on the attachments labeled Exhibit A and Exhibit B. Exhibit A describes the proposed changes along with reasons for change. Exhibit B is a copy of the Technical Specifications revised to incorporate the proposed changes.

This request contains no restricted or other defense information.

NORTHERN STATES POWER COMPANY

Bv

Wade Larkin Group Vice President - Power Supply

On this 13 day of 1973, before me a notary public in and for said County, personally appeared Wade Larkin, Group Vice President - Power Supply, and being first duly sworn acknowledged that he is authorized to execute this document in behalf of Northern States Power Company, that he knows the contents thereof and that to the best of his knowledge, information and belief, the statements made in it are true and that it is not interposed for delay.

John J/Smith Notary Public, Hennepin County, Minnesota

JOHN J. SMITH Notary Public, Hennepin County, Minnesota My Commission Expires March 3, 1976



## EXHIBIT A

### MONTICELLO NUCLEAR GENERATING PLANT DOCKET NO. 50-263

#### CHANGE REQUEST DATED SEPTEMBER 13, 1973

## PROPOSED CHANGES TO THE TECHNICAL SPECIFICATIONS APPENDIX A OF PROVISIONAL OPERATING LICENSE NO. DPR-22

Pursuant to 10CFR50.59, the holders of the above-mentioned license hereby propose the following changes to Appendix A, Technical Specifications.

#### 1. PROPOSED CHANGE

- On page 16, Bases: 2.1, first paragraph, fourth line, change '(4,5)" to read "(4,5,6,7)."
- On bottom of page 16, add "(6) Supplement on Transient Analyses submitted by NSP to the AEC, February 13, 1973" and "(7) Letter from NSP to AEC, 'Planned Reactor Operation From 2000 MWD/T to End of Cycle 2,' dated August 21, 1973."

#### REASON FOR CHANGE

This will document in the Technical Specifications the additional studies completed on the effects of operational transients.

## 2. PROPOSED CHANGE

- On page 20, Bases: 2.3.A, end of third paragraph, change " .... page 22." to read " .... page 18."
- On page 21, Bases: 2.3.B, end of second paragraph, change " .... page 22." to read " .... page 18."
- On page 21, Bases: 2.3.C, end of fourth paragraph, change " .... page 22." to read " .... page 18."
- On page 26, Bases: 2.4, third paragraph, third and sixth lines, change ".... page 22." to read ".... page 18."

### REASON FOR CHANGE

These changes correct typographical errors.

#### 3. PROPOSED CHANGE

ć.

- On page 24, Bases: 2.2, move the last paragraph to the top of page 25.

#### REASON FOR CHANGE

To have all of this paragraph on the same page.

#### 4. **PROPOSED CHANGE**

- On page 23, T.S.2.4.C, change "2 valves at ≤1210 psig." and "2 valves at ≤1220 psig." to read "4 valves at ≤1240 psig."
- On page 25, Bases: 2.2, in the second sentence, delete the words "from rated power." In the third sentence, change ".... is 1183 psig." to read ".... is limited to 1214 psig." In the fifth sentence, change ".... to 1283 psig .... " to read ".... to 1308 psig .... "
- On page 26, Bases: 2.4, second paragraph, line 8, change " .... about 1283." to read " .... about 1308 psig." On line 10, change " .... of five valves (2 safety valves and 3 dual purpose safety/ relief valves) set .... " to read " .... of eight valves (4 safety valves and 4 dual purpose safety/relief valves) set .... "
- On page 118, T.S.3.6.E.1, fourth line, change " .... three safety valves .... " to read " .... four safety valves .... "
- On page 119, T.S.4.6.E.1, last sentence, delete everything after ".... nominal popping point of the .... " (including tabulation) and add ".... four safety values shall be set at ≤ 1240 psig."
- On page 134, Bases: 3.6.E/4.6.E, last paragraph, line 4, change ".... to total 50% (35% relief and 15% safety) of .... " to read ".... to total 83.9% (47% relief and 36.9% safety) of .... " On line 5, change ".... assuming that three of the four relief/safety valves (35%) and two of the four safety valves (18%) operated." to read ".... assuming that four safety/relief valves (47%) and four safety valves (36.9%) operated." Delete the last sentence of the paragraph.

- 3 -

### REASON FOR CHANGE

The transients discussed in our February 13, 1973 submittal were reanalyzed as reported in our letter to the AEC entitled, "Planned Reactor Operation From 2000 MWD/T to the End of Cycle 2," dated August 21, 1973. The reanalysis examines the effects of a change in the scram reactivity insertion rate which takes place with increasing exposure and results in higher peak pressures during transients. These changes to the Technical Specifications reflect the assumptions and results of the reanalysis plus additional analysis performed subsequently. One of the objectives of the analysis was to examine means of extending Cycle 2 operations at power levels closer to rated after the limiting exposure threshold is reached. With the proposed increase in safety valve settings, the recommended 25 psi margin between the transient peak is not compromised by a turbine trip without bypass with all rods out at 91% of rated power. When the limiting exposure threshold is reached, control rods will be maintained in a fixed pattern which will result in a power coastdown. The power coastdown will continue to the power threshold (i.e. 91%) after which additional control rods can be withdrawn to maintain power no greater than 91%.

### 5. PROPOSED CHANGE

- On page 85, Bases: 3.3.C/3.4.C, line 8, change the sentence beginning with "The limiting power transient .... " to read " The limiting operational transient is that resulting from a turbine stop valve closure with failure of the turbine bypass system."

#### REASON FOR CHANGE

This change restores the original statement erroneously changed in our Technical Specification Change Request Dated June 1, 1973. The MSIV closure with indirect scram is not an operational transient as defined in the FSAR since multiple failures are assumed to occur. The MSIV closure with indirect scram is studied only to satisfy code requirements for safety valve sizing.

# 6. <u>PROPOSED CHANGE</u>

- On page 134, Bases: 3.6.E/4.6.E, first paragraph, line 3, change ".... ±1% of design pressure." to read ".... ±1% of the set pressure.

#### REASON FOR CHANGE

This change correctly states the pressure from which the tolerance band of the safety and safety/relief values is determined.

## EXHIBIT B

This exhibit consists of the following pages revised to incorporate the proposed changes:

Page 16 Page 20 Page 21 Page 23 Page 24 Page 25 Page 26 Page 85 Page 118 Page 119

Page 134

2.1 During transient operation, the heat flux would lag behind the neutron flux due to the inherent heat transfer time constant of the fuel which is 8-9 seconds. Also, the limiting safety system scram settings are at values which will not allow the reactor to be operated above the safety limit during normal operation or during other plant operating situations which have been analyzed in detail (4,5,6,7). In addition, control rod scrams are such that for normal operating transients the neutron flux transient is terminated before a significant increase in surface heat flux occurs. Scram times of each control rod are checked each refueling outage to assure the insertion times are adequate. Exceeding a neutron flux scram setting and a delay in the control rod action to reduce neutron flux to less than the scram setting within 0.95 seconds does not necessarily imply that fuel is damaged; however, for this specification a safety limit violation will be assumed anytime a neutron flux scram setting of the APRM's is exceeded for longer than 0.95 seconds.

Analysis within the nominal uncertainty range of all appropriate significant parameters, show that if the scram occurs such that the neutron flux dwell time above the limiting safety system setting is less than 0.95 seconds, the safety limit will not be exceeded for normal turbine or generator trips, which are the most severe normal operating transients expected.

The computer provided with Monticello has a sequence annunciation program which will indicate the sequence in which scrams occur such as neutron flux, pressure, etc. This program also indicates when the scram set point is cleared. This will provide information on how long a scram condition exists and thus provide some measure of the energy added during a transient. Thus, computer information normally will be available for analyzing scrams; however, if the computer information should not be available for any scram analysis, Specification 2.1.C.2 will be relied on to determine if a safety limit has been violated.

During periods when the reactor is shut down, consideration must also be given to water level requirements due to the effect of decay heat. If reactor water level should drop below the top of the active fuel during this time, the ability to cool the core is reduced. This reduction in core cooling capability could lead to elevated cladding temperatures and clad perforation. The core will be cooled sufficiently to prevent clad melting should the water level be reduced to two-thirds the core height. Establishment of the safety limit at 12 inches above the top of the fuel provides adequate margin. This level will be continuously monitored whenever the recirculation pumps are not operating.

- (4) FSAR Volume I, Section III-2.2.3
- (5) FSAR Volume III, Sections XIV-5
- (6) Supplemenent on Transient Analyses submitted by NSP to the AEC February 13, 1973
- (7) Letter from NSP to the AEC, "Planned Reactor Operation from 2,000 MWD/T to end of cycle 2", dated August 21,1973

2.3 For operation in the startup mode while the reactor is at low pressure, the IRM scram setting of 15% of rated power provides adequate thermal margin between the setpoint and the safety limit, 18% of rated. The margin is adequate to accommodate anticipated maneuvers associated with power plant startup. Effects of increasing pressure at zero or low void content are minor, cold water from sources available during startup is not much colder than that already in the system, temperature coefficients are small, and control rod patterns are constrained to be uniform by operating procedures backed up by the rod worth minimizer. Worth of individual rods is very low in a uniform rod pattern. Thus, of all possible sources of reactivity input, uniform control rod withdrawal is the most probable cause of significant power rise. Because the flux distribution associated with uniform rod withdrawals does not involve high local peaks, and because several rods must be moved to change power by a significant percentage of rated power, the rate of power rise is very slow. Generally the heat flux is in near equilibrium with the fission rate. In an assumed uniform rod withdrawal approach to the scram level, the rate of power rise is no more than five percent of rated power per minute, and the IRM system would be more than adequate to assure a scram before the power could exceed the safety limit. The IRM scram remains active until the mode switch is placed in the run position. This switch occurs when reactor pressure is greater than 850 psig.

The analysis to support operation at various power and flow relationships has considered operation with either one or two recirculation pumps. During steady-state operation with one recirculation pump operating the equalizer line shall be open. Analysis of transients from this operating condition are less severe than the same transients from the two pump operation.

The operator will set the APRM neutron flux trip setting no greater than that shown in Figure 2.3.1. However, the actual set point can be as much as 3% greater than that shown on Figure 2.3.1 for recirculation driving flows less than 50% of design and 2% greater than that shown for recirculation driving flows greater than 50% of design due to the deviations discussed on page 18.

B. <u>APRM Control Rod Block Trips</u> - Reactor power level may be varied by moving control rods or by varying the recirculation flow rate. The APRM system provides a control rod block to prevent rod withdrawal beyond a given point at a given recirculation flow rate, and thus protects against exceeding a MCHFR of 1.0. This rod block set point, which is automatically varied with recirculation flow rate, prevents an increase in the reactor power level to excessive values due to control rod withdrawal. The specified flow variable set point provides substantial margin from fuel damage, assuming steady state operation at the set point, over the entire recirculation flow range. The margin to the safety limit increases as the flow decreases for the specified trip point vs. flow relationship, therefore.

20 REV

2.3 the worst case MCHFR during steady state operation is at 110% of rated power. Peaking factors as specified in Section 3.2 of the FSAR were considered. The total peaking factor was 3.08. The actual power distribution in the core is established by specified control rod sequences and is monitored continuously by the in-core LPRM system. As with the APRM scram setting, the APRM rod block setting is adjusted downward if peaking factors greater than 3.08 exist. This assures a rod block will occur before MCHFR becomes less than 1.0 even for this degraded case. The rod block setting is changed by changing the intercept point of the flow bias curve (keeping the slope constant); thus, the entire curve will be shifted downward.

The operator will set the APRM rod block trip settings no greater than that shown in Figure 2.3.1. However, the actual set point can be as much as 3% greater than that shown on Figure 2.3.1 for recirculation driving flows less than 50% of design and 2% greater than that shown for recirculation driving flows greater than 50% of design due to the deviations discussed on Page 18.

C. <u>Reactor Low Water Level Scram</u> - The reactor low water level scram is set at a point which will assure that the water level used in the bases for the safety limit is maintained.

The operator will set the low water level trip setting no lower than 10'6" above the top of the active fuel. However, the actual set point can be as much as 6 inches lower due to the deviations discussed on Page 18.

D. <u>Reactor Low Low Water Level ECCS Initiation Trip Point</u> - The emergency core cooling subsystems are designed to provide sufficient cooling to the core to dissipate the energy associated with the loss of coolant accident and to limit fuel clad temperature to well below the clad melting temperature to assure that core geometry remains intact and to limit any clad metal-water reaction to less than 1%. The design of the ECCS components to meet the above criterion was dependent on three previously set parameters: the maximum break size, the low water level scram set point, and the ECCS initiation set point. To lower the set point for initiation of the ECCS could prevent the ECCS components from meeting their criterion. To raise the ECCS initiation set point would be in a safe direction, but it would reduce the margin established to prevent actuation of the ECCS during normal operation or during normally expected transients.

> 21 REV

# 2.0 SAFETY LIMITS

## 2.2 REACTOR COOLANT SYSTEM

## Applicability:

Applies to limits on reactor coolant system pressure.

## Objective:

To establish a limit below which the integrity of the reactor coolant system is not threatened due to an overpressure condition.

## Specification:

The reactor vessel pressure shall not exceed 1335 psig at any time when irradiated fuel is present in the reactor vessel

## LIMITING SAFETY SYSTEM SETTINGS

## 2.4 REACTOR COOLANT SYSTEM

## Applicability:

Applies to trip settings of the instruments and devices which are provided to prevent the reactor system safety limits from being exceeded.

## Objective:

To define the level of the process variables at which automatic protective action is initiated to prevent the safety limits from being exceeded.

## Specification:

- A. Reactor Coolant High Pressure Scram shall be ≤ 1075 psig.
- B. Reactor Coolant System Safety/Relief Valves Initiation shall be as follows:

23 REV

4 valves at  $\leq$  1080 psig.

C. Reactor Coolant System Safety Valves Nominal Settings shall be as follows:

4 Valves at 5 1240 psig.

2.2/2.4

2.2 The reactor coolant system integrity is an important barrier in the prevention of uncontrolled release of fission products. It is essential that the integrity of this system be protected by establishing a pressure limit to be observed for all operating conditions and whenever there is irradiated fuel in the reactor vessel.

The pressure safety limit of 1335 psig as measured in the vessel steam space is equivalent to 1375 psig at the lowest elevation of the reactor coolant system. The 1375 psig value was derived from the design pressures of the reactor pressure vessel, coolant piping, and recirculation pump casing. The respective design pressures are 1250 psig at 575°F, 1148 psig at 562°F, and 1400 psig at 575°F. The pressure safety limit was chosen as the lower of the pressure transients permitted by the applicable design codes: ASME Boiler and Pressure Vessel Code Section III-A for the pressure vessel, ASME Boiler and Pressure Vessel Code Section pump casing, and the USAS Piping Code Section B31.1 for the reactor coolant system piping. The ASME Code permits pressure transients up to 10 percent over the vessel design pressure (110% x 1250 = 1375 psig) and the USAS Code permits pressure transients up to 20 percent over the piping design pressure (120% x 1148 = 1378 psig).

The design basis for the reactor pressure vessel makes evident the substantial margin of protection against failure at the safety pressure limit of 1375 psig. The vessel has been designed for a general membrane stress no greater than 26,700 psi at an internal pressure of 1250 psig and temperature of 575°F; this is more than a factor of 1.5 below the yield strength of 42,300 psi at this temperature. At the pressure limit of 1375 psig, the general membrane stress increases to 29,400 psi, still safely below the yield strength.

24

REV

The reactor coolant system piping provides a comparable margin of protection at the established pressure safety limit.

Bases:

2.2 Bases

2.2 The normal operating pressure of the reactor coolant system is approximately 1025 psig. The turbine trip with failure of the bypass system represents the most severe primary system pressure increase resulting from an abnormal operational transient. The peak pressure in this transient is limited to 1214 psig. The safety valves are sized assuming no direct scram during MSIV closure. The only scram assumed is from an indirect means (high flux) and the pressure at the bottom of the vessel is limited to 1308 psig in this case. Reactor pressure is continuously monitored in the control room during operation on a 1500 psig full scale pressure recorder.

25 REV

#### Bases:

2.4 The settings on the reactor high pressure scram, reactor coolant system safety/relief valves, turbine control valve fast closure scram, and turbine stop valve closure scram have been established to assure never reaching the reactor coolant system pressure safety limit as well as assuring the system pressure does not exceed the range of the fuel cladding integrity safety limit. The APRM neutron flux scram and the turbine bypass system also provide protection for these safety limits. In addition to preventing power operation above 1075 psig, the pressure scram backs up the APRM neutron flux scram line isolation type transients.

The reactor coolant system safety values offer yet another protective feature for the reactor coolant system pressure safety limit. In compliance with Section III of the ASME Boiler and Pressure Vessel Code, 1965 edition, the safety values must be set to open at a pressure no higher than 105 percent of design pressure, and they must limit the reactor pressure to no more than 110 percent of design pressure. The safety values are sized according to the code for a condition of MSIV closure while operating at 1670 MWt, followed by no MSIV closure scram but scram from an indirect (high flux) means. With the safety values set as specified herein, the maximum vessel pressure (at the bottom of the pressure vessel) would be about 1308 psig. See FSAR Section 4.4.3 and supplemental information submitted February 13, 1973. Evaluations presented indicate that a total of eight values (4 safety values and 4 dual purpose safety/relief values) set at the specified pressures maintain the peak pressure during the transient within the code of allowable and safety limit pressure.

The operator will set the reactor coolant high pressure scram trip setting at 1075 psig or lower. However, the actual setpoint can be as much as 10 psi above the 1075 psig indicated set point due to the deviations discussed in the basis of Specification 2.3 on Page I8. In a like manner, the operator will set the reactor coolant system safety/relief valve initiation trip setting at 1080 psig or lower. However, the actual set point can be as much as 11 psi above the 1080 psig indicated set point due to the deviations discussed in the basis of Specification 2.3 on Page 18.

A violation of this specification is assumed to occur only when a device is knowingly set outside of the limiting trip setting, or when a sufficient number of devices have been affected by any means

#### Bases Continued 3.3 and 4.3:

consequences of reactivity accidents are functions of the initial neutron flux. The requirement of at least 3 counts per second assures that any transient, should it occur, begins at or above the initial value of 10% of rated power used in the analyses of transients from cold conditions. One operable SRM channel would be adequate to monitor the approach to criticality using homogeneous patterns of scattered control rod withdrawal. A minimum of two operable SRM's are provided as an added conservatism.

5. The consequences of a rod block monitor failure have been evaluated and reported in the Dresden II SAR Amendments 17 and 19. These evaluations, equally applicable to Monticello, show that during reactor operation with certain limiting control rod patterns, the withdrawal of a designated single control rod could result in one or more fuel rods with MCHFR's less than 1.0. During use of such patterns, it is judged that testing of the RBM system prior to withdrawal of such rods to assure its operability will assure that improper withdrawal does not occur. It is the responsibility of the Engineer, Nuclear, to identify these limiting patterns and the designated rods either when the patterns are initially established or as they develop due to the occurrence of inoperable rods in other than limiting patterns.

#### C. Scram Insertion Times

The control rod system is designed to bring the reactor subcritical at a rate fast enough to prevent fuel damage; i.e., to prevent the MCHFR from becoming less than 1.0. This requires the negative reactivity insertion in any local region of the core and in the over-all core to be equivalent to at least one dollar within 0.75 second. The required average scram times for three control rods in all two by two arrays and the required average scram times for all control rods are based on inserting this amount of negative reactivity locally and in the overall core, respectively, within 0.75 second. Under these conditions, the thermal limits are never reached during the transients requiring control rod scram as presented in the FSAR. The limiting operational transient is that resulting from a turbine stop valve closure with failure of the turbine bypass system. Analysis of this transient shows that the negative reactivity rates resulting from the scram with the average response of all the drives as given in the above Specification, provide the required protection, and MCHFR remains greater than 1.8. In the analytical treatment of the transients, 290 milliseconds are allowed between a neutron sensor reaching the scram point and the start of motion of the control rods.

3.3/4.3 BASES

85 rev

3.0	LIMITING CONDITION S FOR OPERATION	4.0	SUF	RVEILLANCE REQUIREMENTS		
· ·				(b) When the continuous conductivity moni- tor is inoperable, a reactor coolant sample should be taken at least once per shift and analyzed for conductiv- ity and chloride ion content.		
·	<ul> <li>4. If Specification 3.6.C.1, 3.6.C.2, and 3.6.</li> <li>C.3 are not met, normal orderly shutdown shall be initiated.</li> </ul>					
D.	Coolant Leakage		D.	Coolant Leakage		
·	Any time irradiated fuel is in the reactor vessel, and reactor coolant temperature is above 212°F, reactor coolant leakage into the primary contain- ment from unidentified sources shall not exceed 5 gpm. In addition, the total reactor coolant system leakage into the primary containment shall not exceed 25 gpm. If these conditions cannot be met, initiate an orderly shutdown and have the re- actor placed in the cold shutdown condition within 24 hours.			Reactor coolant system leakage into the dry- well shall be checked and recorded at least once per day.		
E.	Safety and Relief Valves		E.	Safety and Relief Valves		
ł	<ol> <li>During power operating conditions and whenever the reactor coolant pressure is greater than 110 psig and temperature greater than 345°F, four safety valves and the safety valve func-</li> </ol>		.ons and whenever .s greater than ;er than 345°F,1. A minimum of two safety valves sh bench checked or replaced with a checked valve each refueling outa four valves shall be checked or r			
	3.6/4.6			118 REV		
	•		•			

3.0 LIMITING CONDITIONS FOR OPERATION	4.0 SURVEILLANCE REQUIREMENTS				
tion of four safety/relief values shall be operable. The solenoid activated relief function of the safety/relief val- ves shall be operable as required by Spec- ification 3.5.E.	every two refueling outages. The nominal popping point of the four safety valves shall be set at ≤ 1240 psig.				
2. If specification 3.6.E.l is not met, ini- tiate an orderly shutdown and have coolant pressure and temperature reduced to 110 psig or less and 345°F or less within 24 hours.	2. a. A minimum of two safety/relief values shall be bench checked or replaced with a bench checked value each refueling outage. All four values shall be checked or replaced every two refueling outages. The popping point of the safety/relief values shall be set as follows:				
	Number of Valves Set Point (psig)				
	4 < 1080				
	b. At least one of the safety/relief valves shall be disassembled and inspected each refueling outage.				
	c. The integrity of the safety/relief valve bellows shall be continuously monitored.				
	d. The operability of the bellows monitoring				
3.6/4.6	119 REV				

.

#### Bases Continued 3.6 and 4.6:

#### D. Coolant Leakage

The former 15 gpm limit for leaks from unidentified sources was established assuming such leakage was coming from the primary system. Tests have been conducted which demonstrate that a relationship exists between the size of a crack and the probability that the crack will propagate. From the crack size a leakage rate can be determined. For a crack size which gives a leakage of 5 gpm, the probability of rapid propagation is less than 10-5. Thus, an unidentified leak of 5 gpm when assumed to be from the primary system had less than one chance in 100,000 of propagating, which provides adequate margin. A leakage of 5 gpm is detectable and measurable. The 24 hour period allowed for determination of leakage is also based on the low probability of the crack propagating.

The capacity of the drywell sump pumps is 100 gpm and the capacity of the drywell equipment drain tank pumps is also 100 gpm. Removal of 25 gpm from either of these sumps can be accomplished with considerable margin.

The performance of the reactor coolant leakage detection system, including an evaluation of the speed and sensitivity of detection, will be evaluated during the first 18 months of plant operating, and the conclusions of this evaluation will be reported to the AEC. Modifications, if required, will be performed during the first refueling outage after AEC review. In addition, other techniques for detecting leaks and the applicability of these techniques to the Monticello Plant will be the subject of continued study.

#### E. Safety and Relief Valves

Experience in safety value operation shows that a testing of 50% of the safety values per refueling outage is adequate to detect failures or deterioration. A tolerance value is specified in Section III of the ASME Boiler and Pressure Vessel Code as ±1% of the set pressure. An analysis has been performed which shows that with all safety values set 1% higher than the set pressure, the reactor coolant pressure safety limit of 1375 psig is not exceeded. Safety/relief values are used to minimize activation of the safety values. The operator will set the pressure settings at or below the settings listed. However, the actual setpoints can vary as listed in the basis of Specification 2.4.

The required safety value steam flow capacity is determined by analyzing the pressure rise accompanying the main steam flow stoppage resulting from a MSIV closure with the reactor at 1670 MWt. The analysis assumes no MSIV closure scram, but a reactor scram from indirect means (high flux). The relief and safety value capacity is assumed to total 83.9% (47% relief and 36.9% safety) of the full power steam generator rate. This capacity corresponds to assuming that four safety/relief values (47%) and four safety values (36.9%) operated. MONTICELLO - SAFETY VALVE SETPOINT INCREASE

# I. INTRODUCTION

Regulatory

II.

တု ်

DOCKETED

USAEC

SEP 26 1973 REGULATORY MAIL SECTION Analysis of the recent change to the exposed core scram reactivity insertion curve (GE December 1972 curve, curve C, Fig. 1) has resulted in the inability of Mon ticello to satisfy, near the end of cycle, the GE recommended 25 psi margin between the "worst case" pressurization type transient (turbine trip without bypass, i.e., relief valve sizing transient) and the setpoint of the first spring safety valve (1210 psig).

Received w/Ltr Datas 9-13-

Calculations performed previously have shown that the current scram reactivity insertion curve (GE Generic '72, curve B, Fig. 1) will remain valid until a core exposure (R-1 reload) of 2400 MWD/T. The transient analyses based on this curve and submitted to the AEC on February 13, 1973, adequately describes the effects of the transients.

Beyond an exposure of 2400 MWD/T, additional measures are required to ensure the margins of the February 13, 1973 analysis are met. Of the short range remedies studied, a reduction in reactor power to 84% will adequately meet the requirement. A second alternative, increasing the spring safety valve setpoints, could also assist in maintaining the transient margins.

This report is intended to provide the analytical and administrative justifications for the safety valve setpoint change.

# CONCLUSION AND RECOMMENDATIONS

The setpoints of all four spring safety values can and should be reset to 1240 psig prior to a core exposure (R-1 reload) of 2400 MWD/T. This setpoint increase can be effected within appropriate codes and regulations, and maintains the required and recommended margins described in earlier documents.

<sup>≩gulatory</sup> I Section With the four spring safety values set at 1240 psig and the four combination relief/safety values set at 1080 psig (present setpoint), the reactor can be operated at 91% power from which the margin between peak pressure resulting from the relief value sizing transient and the first safety value will be 26 psi. This satisfies the GE recommended design guideline margin (25 psi).

The safety value sizing analysis assumed a power level of 100% and yields a margin of 67 psi from the 1375 psig limit; operation at 91% (limited by the RV sizing transient) would result in larger margins. In conjunction with the setpoint change, Tech Specs must also be modified to include the settings and their bases.

## III. DISCUSSION

# A. Basis for Change

On February 13, 1973, NSP submitted to the AEC a report prepared by General Electric entitled "Results of Transient Reanalysis for Monticello Nuclear Generating Plant with End-of-Cycle Core Dynamic Characteristics." This report described the changes to the abnormal operational transient analysis as described in the FSAR caused by a shift in the scram reactivity feedback curve for exposed core conditions. Also included in that report were the proposed changes necessary to meet the General Electric guideline which is to maintain a margin of 25 psi between the peak pressure resulting from the "worst case" pressurization type transient (turbine trip without bypass, i.e., relief valve sizing transient) and the setpoint of the first spring safety valve.

On June 1, 1973, NSP submitted a proposed change to the Technical Specifications incorporating the results and recommendations of the February 13 report.

General Electric, on the basis of refined analytical techniques, informed NSP earlier this year that the shift in the scram reactivity curve is a function of core exposure, i.e., the present curve (Fig. 1, GE's generic '72, Curve B) does not fully represent the final end-of-cycle core condition. GE has determined that Curve B will define the scram reactivity function to a core exposure (R-1 reload) of 2400 MWD/T. Postulated transients using the assumptions from the analyses and occurring up to that exposure would not result in peak pressures in excess of that described in previous submittals. Beyond an exposure of 2400 MWD/T, additional measures are required to ensure satisfaction of the GE recommended design objective of a 25 psi margin between peak transient pressure and the safety valve setpoints. The margin between peak pressure and the reactor vessel pressure limit following the safety valve sizing transient (MSIV closure) remains well above the 25 psi required design margin; therefore, no safety limit is affected whether or not additional measures are taken.

General Electric has determined an "all rods out" scram reactivity curve (Fig. 1, Curve C) to define the worst case core conditions between 2400 MWD/T and the end of the current cycle for Monticello. Although actual conditions do not reach Curve C until the all-rodsout end-of-cycle exposure, Curve C was applied to determine what measures were necessary to ensure maintenance of the effects of transients throughout the remainder of the cycle in conformance with the earlier analysis.

Evaluations have been made for a rod movement "freeze" until power coasts down to 84% at 2400 MWD/T; this is sufficient to meet the 25 psi margin in the relief valve sizing transient. This operational restriction maintains the validity of the earlier transient analyses. Other measures such as the change discussed in this

- 3-

report, are being developed; their application may aid further in mitigating the overall effects of the newer curves.

4.

B. Assumptions Used in Analysis

The same generic assumptions as those used in the February 1973 submittal were applied to the transients described in this report.

Conservative assumptions, such as a multiplier on the void coefficient, a multiplier on the scram reactivity curve, and average control rod scram times equivalent to the '67 Product Line BWR, were used.

Because the new scram reactivity curve (Curve C) represents an exposed core condition, the new analyses were done with end-ofcycle inputs for consistency and to ensure that a realistic worst case would be defined. For example, the void coefficient is reduced at the end of the cycle and this will tend to reduce the peak of the pressurization transients.

The scram reactivity curve (Curve C) is a function of core exposure and will not be approached until near the end of cycle; however, the curve is assumed to apply from 2400 MWD/T to the cycle end for the determination of 100% power transient effects.

In the analyses of this report, the four combination relief/safety valves are assumed operable as described in the February 1973 report. The four spring safety valves are also assumed operable with a setpoint of 1240 psig.

Because a complete set of transient analyses is not required, only the transients of most concern were redone. These were the turbine trip without bypass transient for checking relief value adequacy and the MSLIV closure with indirect scram for checking safety value adequacy.

### с.

# Transients Not Reanalyzed

-5-

The FSAR included about 20 analyses of worst case abnormal transients in six categories of events. These categories are primary system pressure increases, moderator temperature decreases, reactivity insertions, core coolant inventory decreases, core coolant flow increase, and core coolant flow decreases. These were all reviewed to determine those which might be significantly affected by the new end-of-cycle core characteristics assumptions. The breakdown of categories, events, and logic for those in which only a review was deemed to be adequate, is described in the analysis submitted in February 1973. Reiteration of that discussion is unnecessary here.

# D. Results of Transients Reanalyses

# 1. Scope of Reanalyses

The following transients were reanalyzed in order to determine the specific changes that might occur to the previous analytical results:

Turbine trip without bypass (Relief valve adequacy check)

Main Steam Isolation Valve Closure, (includes delayed scram case for safety valve adequacy check)

Specific write-ups for these analyses are included herein.

The original FSAR analysis used the turbine trip without bypass with flux scram for the safety value sizing transient. However, analyses of later plants revealed that the main steam line isolation with flux scram could be more severe. During the reanalyses work reported in February 1973, this possibility was checked by performing both analyses and the results showed a somewhat higher peak pressure with main steam isolation value closure. This analysis is used for checking safety value adequacy in this report as well.

# 2. <u>Turbine Trip Without Bypass - Relief Valve Adequacy</u> <u>Transient</u>

- 6 -

Reactor operating at 91% of rated, core flow 100%, 67 product line scram times (data interpolated from several cases run from 85 to 100% power):

A scram signal is initiated at the same time a turbine trip occurs by position switches on the turbine stop valves. This transient causes a rapid pressure increase in the reactor pressure vessel. Primary system relief valves are provided to remove sufficient energy from the reactor to prevent safety valves from lifting. Reanalysis showed that peak pressure in the steam line at the safety valve location did not meet the GE margin of 25 psi to the first safety valve setpoint (1210 psig). However, a peak pressure in the steam line of 1214 psig at the safety valve location provides an adequate margin of 26 psi to 1240 psig, the recommended first safety valve setpoint. Thus, the adequacy of the four relief valves was confirmed for these conditions. Using the parameters associated with the end of life conditions, four relief/safety valves are required to operate as described in the February 1973 report to prevent this pressure transient from exceeding the safety valve setpoint. The rapid pressure rise due to

rapid closure (0.10 sec.) of the turbine stop valve without bypass operation causes core voids to collapse and neutron flux peaks at 262 percent of design in 0.92 sec. (Figure 3) before the scram shuts down the reactor. Peak surface heat flux is 100.3% at 1.36 sec. MCHFR and other pertinent parameters remain within acceptable limits.

3. <u>Closure of All Main Steam Line Isolation Valves</u> (Flux Scram) - Safety Valve Adequacy Transient The ASME Nuclear Boiler and Pressure Vessel Code requires that each vessel designed to meet Section III be protected from the consequence of pressure and temperature in excess of design conditions. The ASA Code for Pressure Piping also requires overpressure protection. The setpoints of the safety valves comply with the ASME pressure vessel code taking into account static heads and dynamic losses.

This was discussed at length in the February 1973 report and is included here for completeness.

The change in safety valve setpoints described in this report will meet appropriate codes and regulations (ASME NB & PV Code Sect. XI).

- 7 -

a. The reactor is at 1670 MWt,

- b. The reactor experiences its worst main steam isolation transient,
- c. Direct reactor scram is neglected (based on isolation valve position switches),
- d. The backup scram due to high neutron flux shuts down the reactor,

e. The Target Rock relief values act as safety values with low setpoints.

Both a turbine trip without bypass and closure of all main steam line isolation valves produce severe overpressure transients. Analyses for these two events have shown that the 3 second closure of the isolation valves is slightly more severe for the final plant configuration when direct reactor scram is neglected. This results because the longer steam lines, allowing more volume for steam compression, more than compensates for the faster acting turbine stop valves in the former transient when compared with MSLIV closure. The latter transient is therefore provided here as the basis for determining the adequacy of the safety valves.

Pressure increases follow this reactor isolation until limited by the opening of the safety valves. The peak allowable pressure is 1375 psig (according to ASME Section III, equal to 110 percent of the vessel design pressure of 1250 psig). The Target Rock setpoints are  $\leq$  1080 psig and the spring safety valve setpoints are at 1240 psig (4 valves). Thus the ASME code specifications that the lowest safety valve be set at or below vessel design

-8-

pressure, and the highest safety value be set to open at or below 105 percent of vessel design pressure are satisfied. The four spring values together have a capacity of greater than 35 percent of turbine design flow.

The resulting transient assuming the capacity of the 4 safety/ relief valves (47% of main steam generation rate) and the 4 safety valves (36.9% of main steam generation rate) is shown in Figure 4. An abrupt pressure and power rise occurs as soon as the isolation becomes effective. Neutron flux causes the scram at approximately 1.8 seconds thereby initiating reactor shutdown. Flux peaks at a value of 644 percent in 2.14 sec. The assumed safety valve capacity (Target Rock plus spring safety capacities) keeps the peak vessel pressure 67 psi below the peak allowable ASME overpressure of 1375 psig. Therefore, the relief valves plus the spring safety valves provide adequate protection against excessive overpressurization of the nuclear system process barrier with an adequate margin.

# IV TECHNICAL SPECIFICATION CHANGES

## A. Scope of Changes

The principle changes of interest concern the safety valve setpoints. This is needed to be consistent with the new assumptions used in the transient reanalyses and is discussed in detail in Section III. B. Other changes are those associated with the results of the transient reanalyses discussed in Section III. D. None of these are of a crucial safety nature and mostly affect statements about margins for various pressurization transients. Tech Spec changes submitted to the AEC June 1, 1973, are considered to be in effect; errors or omissions related to the February 1973 report and June 1, 1973 submittal have been corrected or added. Specific Changes

	Item	Location	Change	Reason
	Bases statement for 2.1	Pg. 16	Add reference to the February 1973 submittal and this analysis	Indicates documentation of discussions on this topic.
	Bases statement for 2.3.A	Pg. 20 - end of third para.	Change "Pg. 22." to " Pg. 18."	Corrects typographical error
	Bases statement for 2.3.B	Pg. 21 - end of second para.	Change " Pg. 22." to " Pg. 18."	Corrects typographical error
•	Bases statement for 2.3.C	Pg. 21 - end of second para.	Change "Pg. 22." to " Pg. 18."	Corrects typographical error
		•		
	Tech. Spec. 2.4.C	Pg. 23	Change "2 values at $\leq 1210$ psig." and "2 values at $\leq 1220$ psig" to "4 values at $\leq 1240$ psig."	This change reflects an assumption of this analysis.
	Bases statement for 2.2	Pg. 24 last para. Pg. 25 top of pg.	Change to read as follows: "The normal operating pres- sure of the reactor coolant system is approximately 1025 psig. The turbine trip from 91% power with failure of the bypass system represents the most severe primary system pressure increase resulting from an abnormal operational transient.	This change provides the basi for the valve configuration used in this analysis
			transient is 1214 psig.	

-4

.

· · · · ·

.

в.

.

.

# Location

## Change

In addition, the safety valves are sized on the basis of a closure of all Main Steam Isolation Valves (MSIV Closure) where  $\infty$  ram is assumed to be indirect (high flux) rather than from the MSIV position switches. In this transient, assuming rated power, the pressure at the bottom of the vessel is 1308 psig.

Reactor pressure is continuously monitored in the control room during operation on a 1500 psig full-scale pressure recorder.

Change 1283 psig to 1308psig

Change to read: "... a total of eight valves (4 safety valves and 4 dual purpose safety relief valves) set at..."

Change "... Page 22" to "... Page 18." This change reflects the results of this analysis.

This change reflects an assumption of this analysis.

Corrects typographical error

Basis statement for 2.4

Line 9

Pg. 26, Para 2,

Pg. 26, Para 2, Line 10

Pg. 26, Para 3, Lines 3 and 6

Reason

	Item	Location	Change	Reason_
· · · · · · · · · · · ·	Basis statement for 3.3.C/4.3.C	Pg. 85, Lines 8 and 9	Change to read: "The limiting power transient is that resulting from a turbine stop valve closure with failure of the turbine bypass system."	Restores original statement erroneously changed in February 1973 submittal.
	Tech. Spec. 3.6.E.1	Page 118, Last Line	Change " three safety valves " to " four safety valves"	This change reflects an assumption in this analyses
	Tech Spec 4.6.E.1	Pg. 119	Change to read as follows: " every two refueling outages. The nominal pop- ping point of the four safety valves shall be set at $\leq 1240$ psig."	This change reflects an assumption in this analysis
	Bases statement for 3.6.E/4.6.E	Pg. 134, Last Para., Line 4	Change RV/SV capacity as follows: "to total 83.9% (47% relief and 36.9% safety) of"	These changes reflect
		Line 5	"assuming that four relief safety valves (47%) and four safety valves (36.9%) operated.	11
		Lines 6 and 7	Delete entire last sentence.	
· · ·			· · ·	

# Figure 1

# MONTICELLO

B (Generic 1972)----->

A (FSAR Curve)->/

- **AK** 

0

# C ~(December 1972)

ROD POSITION OR TIME



FIGURE 2. CONTROL ROD DRIVE SCRAM TIMES - MONTICELLO



Figure 3

MONT RLD7C TT W/O BP, 80% 67PL SCRM, 47% RV .8DLY, 1.28 VOID MULT W/2 PUMP TRIP

90 15010 040673 01+33  $\bigcirc$ 



MONT RLD100 ALL MSIV CLS FLUX SCRM 47% RLF 1096SP 37% SV 1268SP .8SEC DLY 67PL 37% SAFETY

JPU 15300 053973 20+48