ACCESSION NBR:8003170377 DOC.DATE: 79/12/18 NOTARIZED: NO FACIL:50-263 Monticello Nuclear Generating Plant, Northern States AUTH.NAME AUTHOR AFFILIATION MACDOUGALL, E.A. Brookhaven National Laboratory

DOCKET # 05000263

RECIP.NAME RECIPIENT AFFILIATION
Plant Systems Branch


SUBJECT: Discusses fire protection review, Item 3.1,10A(4), re proposal to reroute diesel fuel piping to bypass intake structure pump room. Util 791004 proposal should be accepted.

DISTRIBUTION CODE: A006S COPIES RECEIVED:LTR / ENCL O SIZE: / TITLE: Fire Protection Information (After Issuance of OP. Lic.)

NOTES:

ACTION:	ID	ECIPIENT CODE/NAME BC ORB#3	COPI LITTR 4	ES ENCL 4		RECIPIENT: D CODE/NAME:	COP: LITTR	IES Encl
INTERNAL	09 14	REG FILE 18E: PLANT: SYS BR MURANAKA,R	1 2 5 1	1 20 17	12	NRC POR AUXILESYS BR WAMBACH LD	1 2 1 1	17
EXTERNAL:		LPDR ACRS	1 16	10	04	NSIC	1	

CAR 19 1980





BROOKHAVEN NATIONAL LABORATORY

ASSOCIATED UNIVERSITIES, INC.

Upton, New York 11973

(516) 345-2362

Department of Nuclear Energy

December 18, 1979

50-263

Mr. Robert L. Ferguson
Plant Systems Branch
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

RE: Monticello Nuclear Generating Plant - Fire Protection Review SER Item 3.1.10.A(4)

Dear Bob:

The referenced item identifies Northern States Power Company's proposal to reroute diesel fuel piping so that it does not pass through the intake structure pump room.

The utility's letter dated October 4, 1979 describes their proposed method of rerouting these lines. The outlined method of accomplishing this by routing the lines throughtthe access tunnel and protecting fuel lines by steel guard pipes adequately mitigates the concern for this hazard and we recommend that it be accepted.

Very truly yours,

Col

Edward A. MacDougall Reactor Engineering Analysis

EAM:sd

cc.: R. Cerbone

R. Hall

W. Kato

V. Panciera

E. Sylvester

10/2/0