Period: Jul - Dec 1981

License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Supplemental Information

- 1. Regulatory Limits Qtrly Levels Requiring Report to NRC
 - A. Noble Gases:

```
50*(QTV*NBARV+QTS*NBARS) = 1 AND 25*(QTV*MBARV+QTS*MBARS) = 1
```

QTV = Noble Gas Release Rate from Bldg Vents (Ci/sec)
QTS = Noble Gas Release Rate from Plant Stack (Ci/sec)
NBARV = Vent Avg Gamma Air Dose Factor (Rad/yr per Ci/sec)
NBARS = Stack Avg Gamma Air Dose Factor (Rad/yr per Ci/sec)
MBARV = Vent Avg Beta Air Dose Factor (Rad/yr per Ci/sec)
MBARS = Stack Avg Beta Air Dose Factor (Rad/yr per Ci/sec)

B. Iodines and Particulates:

50*(3.7E05*QV+2.5E04*QS) = 1

QV = Building Vent Release Rate of Iodines and Particulates
with Half-Lives Greater than 8 Days (Ci/sec)

QS = Plant Stack Release Rate of Iodines and Particulates
 with Half-Lives Greater than 8 Days (Ci/sec)

C. Liquid Effluents:

Concentration - 10CFR20, App B, Table II, Col 2, and notes thereto

Total Quantity - 2.5 Ci/Quarter

2. Average Dose Factors for Noble Gases (Rem/yr per Ci/sec and Rad/yr per Ci/sec:

	•	Vent Re	eleases	Stack Releases		
	·	1ST Qtr	2ND Qtr	1ST Qtr	2ND Qtr	
KBAR	(Boby Gamma)	6.03E 00	1.47E 00	1.40E 00	1.30E 00	
LBAR	(Skin Beta)	4.74E 01	1.23E 01	1.55E 00	1.45E 00	
MBAR	(Air Beta)	5.01E 01	1.60E 01	1.66E 00	1.55E 00	
NBAR	(Air Gamma)	6.37E 00	1.62E 00	1.45E 00	1.36E 00	

-3. Average Energy:

(Not Applicable)

Period: Jul - Dec 1981

License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Supplemental Information (continued)

- 4. Measurements and Approximations of Total Radioactivity:
 - A. Noble Gases: Continuous gross activity monitors in Reactor Building Vent and plant stack exhaust streams. Weekly isotopic analysis of steam jet air ejector stream. Monthly analysis of storage tank contents.
 - B. Iodines in Gaseous Effluent: Continuous monitoring with charcoal cartridges in Reactor Building vent and plant stack exhaust streams with weekly analysis.
 - C. Particulates in Gaseous Effluent: Continuous monitoring with particulate filters in Reactor Building vent and plant stack exhaust streams with weekly analysis.
 - D. Tritium in Gaseous Effluent: Continuous monitoring with silica gel cartridges in Reactor Building vent and plant stack exhaust streams with biweekly analysis.
 - E. Liquid Effluents: Tank sample analyzed prior to each planned release and continuous monitoring of gross activity during planned release.
- 5. Batch Releases:
 - A. Liquid:

١.	Number	οf	Batch	Release	es		•
	m _ + _ 1 _ r	n 3			n - 1 - 1-	n - 1	,

- 2. Total Time Period For Batch Releases 3.50E '01 Min
- 3. Maximum Time Period for a Batch Release 3.50E 01 Min
- 4. Average Time Period for a Batch Release 3.50E 01 Min
- 5. Minimum Time Period for a Batch Release 3.50E 01 Min
- 6. Average River Flow During Releases 3.95E 03 Cf/sec
- B. Gaseous:

1.	Number of Ba	tch Releas	ses	0	
2.	Total Time P	eriod for	Batch Rele	eases NA	Min
3.	Maximum Time	Period fo	or a Batch	Release NA	Min

4. Average Time Period for a Batch Release NA Min 5. Minimum Time Period for a Batch Release NA Min

- 6. Abnormal Releases:
 - A. Liquid: 1
 - 1. Number of Releases
 - 2. Total Activity Released 4.17E-03 Ci
 - B. Gaseous:
 - 1. Number of Releases
 - 0.0 2. Total Activity Released Ci

Level for Long-Lived Iodines and

Particulates

Α.

в.

C.

Period: Jul - Dec 1981

License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 1A Gaseous Effluents - Summation of all Releases

	Units	1st 2tr	2nd Qtr	Pont Est Error
Noble Gases:				
 Total Release: A. Elevated Release B. Building Vent Release C. Total 	Ci Ci Ci		3.50E 02 6.08E 02 9.58E 02	5.00E 01
2. Average Release Rate:A. Elevated ReleaseB. Building Vent ReleaseC. Total	uCi/sec	8.69E 01 5.34E 01 1.40E 02	7.65E 01	5.00E 01
3. Percent Tech Spec 2trly Reporting Level	· .	7.04E 00	3.22E 00	
Iodines:				
 Total I-131: A. Elevated Release B. Building Vent Release C. Total Average I-131 Release Rate: A. Elevated Release B. Building Vent Release C. Total 	uCi/sec	1.27E-03	2.36E-03 1.49E-04 1.48E-04	
Long Lived Particulates and Gross Al	pha Relea	ıses:		
1. Total Particulates:				,
A. Elevated Release B. Building Vent Release C. Total	Ci Ci Ci	2.12E-03	1.16E-03 2.97E-03 4.13E-03	5.00E 01
2. Average Release Rate:A. Elevated ReleaseB. Building Vent ReleaseC. Total	uCi/sec	2.98E-04 2.67E-04 5.65E-04	3.73E-04	5.00E 01
3. Percent Tech Spec 2trly Reporting	· .	8.63E-01	1.00E 00	· .

Period: Jul - Dec 1981

License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 1A Gaseous Effluents - Summation of All Releases (Continued)

	Units	1st Qtr	2nd 2tr	Pont Est Error
4. Gross Alpha Radioactivity:	,			
A. Elevated Release	Ci	2.29E-04	2.49E-06	
B. Building Vent Release	Ci	1.98E-04	1.52E-04	
C. Total	Ci	4.27E-04	1.54E-04	1.00E 02
Tritium:				
1. Total Release:				
A. Elevated Release	Ci	4.93E-01	2.72E-01	
B. Building Vent Release	Ci	4.31E 00	4.91E 01	•
C. Total	CI	4.80E 00	4.94E 01	5.00E 01
2. Average Release Rate:				
A. Elevated Release	uCi/sec	6.20E-02	3.42E-02	
B. Building Vent Release	uCi/sec	5.42E-01	6.18E 00	
C. Total	uCi/sec	6.04E-01	6.21E 00	5.00E 01

Period: Jul - Dec 1981

License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 1B Gaseous Effluents - Elevated Release

			Continuo	us Mode	Batch Mo			
Nuc	lides Released	Units	1st Qtr	2nd Qtr	1st Qtr	2nd 2tr		
								
1.	Noble Gases:			·				
	y - 400	a :	0.045.01	6 2FB 64	. ,	0 0		
		Ci		6.35E 01		0.0		
	Xe 135	Ci		3.63E 00		0.0		
	Kr85M	Ci	1.48E 00	6.75E-01		0.0		
	Kr88	Ci	4.57E 00	2.09E 00		0.0		
	Kr87	Ci	8.67E 00	4.01E 00	0.0	0.0		
	Xe138	Ci	1.62E 02	7.70E 01		0.0		
	Kr90	Ci	5.29E 00	2.47E 00		0.0		
	Xe 139	Ci	1.57E 01	7.35E 00	0.0	0.0		
	Kr89	Ci	1.55E 02	7.26E 01		0.0		
	Xe 137	Ci	2.03E 02	9.46E 01	0.0	0.0		
	Xe135M	Ci	1.18E 01	5.50E 00	0.0	0.0		
	Kr83M	Ci	1.57E 00	7.24E-01	0.0	0.0		
	Xe133M	Ci	2.88E-01	2.85E-01	0.0	0.0		
	Xe 131M	Ci	6.25E-01	4.41E-01	0.0	0.0		
	Kr85	Cà	1.31E 01	1.53E 01	0.0	0.0		
	Total for Period	Ci	6.90E 02	3.50E 02	0.0	0.0		
2.	Iodines:				2			
·	I-131	Ci	2.34E-03	1.18E-03	0.0	0.0		
	I-133	Ci	1.17E-02	4.24E-03	0.0	0.0		
	I-135	Ci	8.51E-03	1.77E-03	0.0	0.0		
	Total	Ci	2.26E-02	7.19E-03	0.0	0.0		

Period: Jul - Dec 1981

License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 1B Gaseous Effluents - Elevated Release (Continued)

•		Continuo		Batch Mo	atch Mode	
Nuclides Released	Units	1st Qtr	2nd 2tr	1st 2tr	2nd Qtr	
	the time time time time time time					
3. Particulates:						
Ce 144	Ci	0.0	1.38E-06	0.0	0.0	
Ce 141	Ci	2.14E-06	1.95E-06	0.0	0.0	
Ba140	Ci	1.63E-03	5.46E-04	0.0	0.0	
Cs137	Ci	1.39E-05	6.67E-06	0.0	0.0	
Cs134	Ci	0.0	8.81E-08	0.0	0.0	
Ru 103	Ci	0.0	3.63E-08	0.0	0.0	
нь 95	Ci	0.0	5.18E-08	0.0	0.0	
Sr90	Ci	8.14E-06	1.01E-04	0.0	0.0	
Sr89	Ci `	7.08E-04	5.00E-04	0.0	0.0	
Zn65	Ci	0.0	2.79E-06	0.0	0.0	
Co60	Ci	1.51E-06	3.53E-06	0.0	0.0	
Mn54	Ci	3.34E-07	7.38E-07	0.0	0.0	
Total	Ci	2.37E-03	1.16E-03	0.0	0.0	

Period: Jul - Dec 1981

License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 1C Gaseous Effluents - Building Vent Release

			Continuous Mode		Batch Mode	
Nи	clides Released	Units	1st 2tr	2nd Qtr	1st 2tr	2nd Qtr
1.	Noble Gases:	•				
	Xe 133	Ci	5.19E-01	2.91E 02	0.0	0.0
	Xe 135	Ci		1.60E 00		0.0
	Kr85M	Ci	1.12E 00			0.0
	Kr88	Ci	3.44E 00			0.0
	Kr87	Ci	6.53E 00		0.0	0.0
	Xe 138	Ci	1.22E 02	3.43E 01	0.0	0.0
	Kr90	Ci	3.99E 00		0.0	0.0
	Xe 139	Ci	1.19E-02		0.0	0.0
	Kr89	Ci	1.17E 02		0.0	0.0
	Xe 137	Ci	1.53E 02		0.0	0.0
	Xe 135M	Ci	8.93E 00	2.43E 00	0.0	0.0
	Kr83M	Ci	1.18E 00	3.18E-01	0.0	0.0
	Xe 133M	Ci	2.18E-02	1.14E 00	0.0	0.0
	Xe 131M	Ci	9.77E-04	2.49E 00	0.0	0.0
	Kr85	Ci	7.63E-03	1.97E 02	0.0	0.0
	Total for Period	Ci	4.24E 02	6.08E 02	0.0	0.0
2.	Iodines:					
	I-131	Ci	1.27E-03	1.17E-03	0.0	0.0
	I-133	Ci	1.01E-02	3.42E-03	0.0	0.0
	I-135	Ci	4.59E-03	3.62E-03	0.0	0.0
	Total	Ci	1.60E-02	8.22E-03	0.0	0.0

Period: Jul - Dec 1981

License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 1C Gaseous Effluents - Building Vent Releases (Continued)

		Continuo	us Mode	Batch Mode		
Nuclides Released	Units	1st Qtr	2nd Qtr	1st Qtr	2nd 2tr	
3. Particulates:						
Ce 144	Ci	0.0	8.93E-06	0.0	0.0	
Ce 141	Ci	0.0	4.84E-05	0.0	0.0	
Ba140	Ci	1.13E-03	4.92E-04	0.0	0.0	
Cs 137	Ci	1.59E-04	2.18E-04	0.0	0.0	
Cs136	Ci	0.0	1.51E-06	0.0	0.0	
Cs134	Ci	1.67E-05	2.00E-05	0.0	0.0	
Ru 103	Ci	0.0	3.09E-05	0.0	0.0	
Zr95	Ci	0.0	1.45E-05	0.0	0.0	
иь95	Ci	0.0	3.22E-05	0.0	0.0	
Sr90	Ci	1.37E-05	3.27E-05	0.0	0.0	
Sr89	Ci	2.01E-04	9.74E-05	0.0	0.0	
Zn65	Ci	2.30E-04	4.58E-04	0.0	0.0	
Co60	Ci	2.17E-04	1.14E-03	0.0	0.0	
Fe59	Ci	9.51E-07	4.58E-05	0.0	0.0	
Co58	Ci	0.0	2.19E-05	0.0	0.0	
Mn54	Ci	2.40E-05	1.47E-04	0.0	0.0	
Cr51	Ci	1.24E-04	1.60E-04	0.0	0.0	
Total	Ci	2.12E-03	2.97E-03	0.0	0.0	

Period: Jul - Dec 1981

License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 2A Liquid Effluents - Summation of All Releases

		Units	1st Qtr	2nd Qtr	Pont Est Error
Α.	Fission and Activation Products:				
	1. Total Release (Except H-3, Gases, and Alpha)	Ci	3.11E-06	0.0	5.00E 01
	 Avg Diluted Concentration Percent Qtrly Tech Spec Reporting Level 		8.21E-06 1.24E-04		
҈В.	Tritium:				· .
	 Total Release Avg Diluted Concentration Percent 2trly Tech Spec Reporting Level 	uCi/ml	4.17E-03 1.10E-02 NA		2.50E 01
c.	Dissolved and Entrained Gases:				
	 Total Release Avg Diluted Concentration Percent 2trly Tech Spec Reporting Level 	Ci uCi/ml	0.0 0.0 NA	0.0 0.0 NA	0.0
D.	Gross Alpha Radioactivity:	. 1			
	1. Total Release	Ci	0.0	0.0	0.0
E.	Volume of Waste Released	Liters	3.79E 02	0.0	2.50E 01
F.	Volume of Dilution Water Used	Liters	0.0	0.0	0.0

Period: Jul - Dec 1981

License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 2B Liquid Effluents

			Continuou	ıs Mode	Batch Mod	.e
Nuclides	Released	Units	1st 2tr	2nd 2tr	1st Qtr	2nd Qtr
I-131		Ci	0.0	0.0	2.48E-07	0.0
I-133		Ci	0.0	0.0	1.03E-06	0.0
Cs 137		Ci	0.0	0.0	1.99E-07	0.0
C060		Ci	0.0	0.0	1.63E-06	0.0

Period: Jul - Dec 1981

License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 3 Solid Waste and Irradiated Fuel Shipments

- A. Solid Waste Shipped Offsite For Burial or Disposal:
 - 1. Type of Waste:

None

	•	Units		Total		Pont Est Error	
A. Spent Resins, Fi Evaporator Botto	-	Cu l	Meter	5.24E 1.65E		5.00E	01
B. Dry Compressible Contaminated Equ		Cu l Ci		3.01E 8.68E		5.00E	0 1
C. Irradiated Compo Control Rods, Ec		Cu l	Meter	0.0		0.0	
D. Other (described	below):						

2. Estimate of Major Nuclide Composition by Type of Waste:

TYPE	Nuclide	Percent
•		
A	Ba140	4.45E 00
	Cs137	4.20E 01
	Cs 134	5.05E 00
	Zn65	1.51E 01
	Co60	1.84E 01
	Mn54	2.04E 00
,	Cr51	2.14E 00
	La140	4.49E 00
	I 131	4.44E 00
В	Ce 141	1.54E 00
	Ba 140	3.17E-01
	Cs 137	2.37E 01
	Cs 134	2.28E 00
·	Ru103	1.45E-02
	Sr90	1.42E-01
	Zn65	1.27E 01
	Co60	5.06E 01
	Mn54	7.89E-01
	Cr51	2.83E 00
13	La140	2.89E-01
	I 131	1.06E 00

Period: Jul - Dec 1981

License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 3 Solid Waste and Irradiated Fuel Shipments (Continued)

3. Solid Waste Disposition:

Number of Shipments	Mode	Destination
10	Truck	Chem-Nuc Inc., Barnwell, SC
14	Truck	US Ecology, Richland, WA
B. Irradiated Fuel Shipments:		
Number of Shipments	Mode	Destination

None

Period: Jul - Dec 1981

License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Notes:

1. Release of individual noble gas isotopes from the plant stack was determined using an isotopic analysis at the steam jet air ejector. Xe133, Xe135, Kr85M, Kr88, Kr87, AND Xe138 were measured and used to characterize the mode of gas release from the fuel. Other significant noble gases were determined using known ratios, the measured total offgas holdup system delay time, and the known fraction of the offgas stream released via the gland exhauster.

- 2. An isotopic analysis for noble gases is normally not possible at the building vents. Individual isotopes are generally below their lower limit of detection (LLD). Therefore, for reactor building vent releases, the noble gas isotopic mixture is assumed to be the same as the mixture determined at the steam jet air ejector.
- 3. Information specified in Regulatory Guide 1.21 which is not applicable to the Monticello plant is indicated by 'NA'.
- 4. Nuclides not detected in plant effluents (those below the LLD of the analysis) are not included in the quantities reported released. LLD values are recorded and must be less than the minimum LLD values stated in the Monticello Technical Specifications.