Period: Jul - Dec 1983 License No. DPR-22

#### EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

#### Supplemental Information

- 1. Regulatory Limits Quarterly levels requiring reporting to Nuclear Regulatory Commission
  - A. Noble Gases:

5 mrad/quarter gamma radiation
10 mrad/quarter beta radiation

- B. Long Lived Iodines, Particulates, and Tritium:
  - 7.5 mrem/quarter to any organ
- C. Liquid Effluents:
  - 1.5 mrem/quarter dose to the total body5.0 mrem/quarter dose to any organ
- 2. Maximum Permissible Concentrations:
  - A. Noble Gases:
    10 CFR Part 20, Appendix B, Table II, Column 1
  - B. Long Lived Iodines, Particulates, and Tritium: 10 CFR Part 20, Appendix B, Table II, Column 1
  - C. Liquid Effluents: 10 CFR Part 20, Appendix B, Table II, Column 2 2 E-04 uci/ml for dissolved and entrained gases
- 3. Average Energy:

(Not Applicable)

8403130087 840301 PDR ADOCK 05000263 PDR

Period: Jul - Dec 1983 License No. DPR-22

#### EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

#### Supplemental Information (continued)

- 4. Measurements and Approximations of Total Radioactivity:
  - A. Noble Gases:
    - Continuous gross activity monitors in Reactor Building Vent and plant stack exhaust streams. Weekly isotopic analysis of steam jet air ejector stream. Monthly analysis of storage tank contents.
  - B. Iodines in Gaseous Effluent: Continuous monitoring with charcoal cartridges in Reactor Building vent and plant stack exhaust streams with weekly analysis.
  - C. Particulates in Gaseous Effluent: Continuous monitoring with particulate filters in Reactor Building vent and plant stack exhaust streams with weekly analysis.
  - D. Tritium in Gaseous Effluent: Continuous monitoring with silica gel cartridges in Reactor Building vent and plant stack exhaust streams with biweekly analysis.
  - E. Liquid Effluents:
    Tank sample analyzed prior to each planned release and continuous
    monitoring of gross activity during planned release.
- 5. Batch Releases:

_	_				٠	-	
A.	L	1	Œ	u	1	ď	:

1. Number of Batch Releases	0	
2. Total Time Period For Batch Releases	0.0	Min
3. Maximum Time Period for a Batch Release	0.0	Min
4. Average Time Period for a Batch Release	0.0	Min
5. Minimum Time Period for a Batch Release	0.0	Min
6. Average River Flow During Releases	0.0	Cf/sec

#### B. Gaseous:

1.	Number of Batch Releases	0	
2.	Total Time Period for Batch Releases	NA	Min
3.	Maximum Time Period for a Batch Release	NA	Min
4.	Average Time Period for a Batch Release	НĀ	Min
5.	Minimum Time Period for a Batch Release	NА	Min

#### 6. Abnormal Releases:

A. L	iq	ui	d	:
------	----	----	---	---

Ι.	Number of Releases	0	
2.	Total Activity Released	0.0	Ci

### B. Gaseous:

1.	Number of Releases	0	
2.	Total Activity Released	0.0	Ci

Period: Jul - Dec 1983 License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

## Table 1A Gaseous Effluents - Summation of all Releases

		Units	1st Qtr	2nd 2tr	Pont Est Error
A. No	ble Gases:			~~~~~	****
1.	Total Release:				•
	A. Elevated Release	Ci	5.15E+02	5.32E+02	
	B. Building Vent Release	Ci	1,07E+02		
	C. Total	Ci		6.52E+02	
2.	Average Release Rate:				
	A. Elevated Release	uCi/sec	6.48E+01	6 605+01	
	B. Building Vent Release		1.34E+01		
	C. Total		7.82E+01		5.00E+0
3.	Percent Tech Spec 2trly Report.	i na			
	Level				
	Gamma Radiation		2.36E+00	2.84E+00	
	Beta Radiation			1.74E+00	
B. Io	dines:				
1.	Total I-131:	,			
	A. Elevated Release	Ci	3.38E-03	1 875-03	
	B. Building Vent Release	Ci		2.74E-03	
	C. Total	Ci		4.62E-03	5.00E+0
2	Average I-131 Release Rate:				
	A. Elevated Release	uCi /sag	4.25E-04	2 265-04	
	B. Building Vent Release		3.64E-04		
	C. Total		7.89E-04		5.00E+0
C. Lo	ng Lived Particulates and Gross	Alpha Relea	ses:		
٦.	Total Particulates:				
	A. Elevated Release	Ci	1.36E-03	1.77E-03	
	B. Building Vent Release	Ci		1.75E-03	
	C. Total	Ci		3.52E-03	
, <b>2</b> .	Average Release Rate:		, •		
	A. Elevated Release	uCi/sec	1.71E-04	2.23E-04	
	B. Building Vent Release		2.69E-04		
	a. Dattatud Asur Kelesse			/ /     -   -	

Patriculates, and Tritium

D.

Period: Jul - Dec 1983 License No. DPR-22

# EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

## Table 1A Gaseous Effluents - Summation of All Releases (Continued)

	٠,	Units	1st Qtr	2nd Qtr	Pont Est Error
	Cross links Dedicartinitus				
7	. Gross Alpha Radioactivity:				
	A. Elevated Release	Ci		1.43E-05	
	B. Building Vent Release	Ci	5.18E-05	2.78E-05	
	C. Total	Ci	8.78E-05	4.21E-05	1.00E+02
. 1	ritium:			·	•
1	. Total Release:				
	A. Elevated Release	Ci	1.43E+00	3.26E-01	
	B. Building Vent Release	Ci		5.39E+00	
	C. Total	CI		5.71E+00	5.00E+01
2	. Average Release Rate:				
	A. Elevated Release	uCi/seć	1.79E-01	4.10E-02	
	B. Building Vent Release		1.34E+00		
	C. Total	uCi/sec		7.19E-01	5.00E+01
	ercent Tech Spec 2trly Reporting evel for Long Lived Iodines,	,	1.41E+00	1.69E+00	

Period: Jul - Dec 1983

License No. DPR-22

### EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

## Table 1B Gaseous Effluents - Elevated Release

•		Continuo	Continuous Mode		de
Nuclides Released	Unit	s 1st Qtr	2nd Qtr	1st 2tr	2nd 2tr
		***			
1. Noble Gases:	·				
Xe 133	Ci	9.42E+01	8.71E+01	0.0	0.0
Xe 135	Ci	3.60E+00			0.0
Kr85M	Ci	7.33E-01	7.08E-01	0.0	0.0
Kr88	Ci	2.35E+00			0.0
Kr87	Ci	3.48E+00	3.26E+00	0.0	0.0
Xe138	Ci	1.25E+02	1.12E+02	0.0	0.0
Kr90	Ci	3.39E+00	3.82E+00	0.0	0.0
Xe 139	Ci		1.14E+01		0.0
K <b>r8</b> 9	Ci	9.90E+01	1.11E+02	0.0	0.0
Xe 137	Ci	1.29E+02	1.45E+02		0.0
Xe 135M	Ci	7.44E+00			0.0
Kr83M	Ci		1.09E+00		0.0
Xe 133M	Ci	1.94E-01			0.0
Xe 131M	Ci		1.09E+00		0.0
Kr <b>85</b>	Ci	3.43E+01			0.0
Total for Period	Ci	5.15E+02	5.32E+02	0.0	0.0
2. Iodines:	n na				
I-131	Ci	3.38E-03	1.87E-03	0.0	0.0
I-133	Ci	1.75E-02			0.0
I-135	Ci		2.07E-03		0.0
Total	Ci	3.81E-02	1.25E-02		0.0

Period: Jul - Dec 1983

License No. DPR-22

# EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

# Table 1B Gaseous Effluents - Elevated Release (Continued)

Nuclides Released		Units	Continuous Mode 1st Qtr 2nd Qtr		Batch Mode 1st 2tr 2nd 2+	
	•					
3. Part	iculates:					
Ce 14	4	Ci	1.25E-05	1.15E-05	0.0	0.0
Ce 14	1	Ci	2.46E-06	2.55E-07	0.0	0.0
Ba 14	0	Ci	1.14E-03	1.26E-03	0.0	0.0
Cs 13	7	Ci	8.61E-06	1.18E-05	0.0	0.0
sr90		Ci	7.31E-06	2.60E-05	0.0	0.0
Sr89		Ci	1.89E-04	4.61E-04	0.0	0.0
C060		Ci	0.0	7.88E-07	0.0	0.0
Tota	1	Ci	1.36E-03	1.77E-03	0.0	0.0

Period: Jul - Dec 1983 License No. DPR-22

# EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

# Table 1C Gaseous Effluents - Building Vent Release

N.		Continuous Mode		Batch Mode	
Nuclides Released	Units	1st Qtr	2nd Qtr	1st 2tr	2nd Qtr
	,				
1. Noble Gases:	. *				
Xe 133	Ci	2.20E-01	1.83E-01	0.0	0.0
Xe 135	Ci	1.02E+00			0.0
Kr85M	Ci	2.10E-01			0.0
Kr88	Ci	6.75E-01			0.0
Kr87	Ci	9.67E-01	9.68E-01		0.0
Xe 138	°Ci	3.47E+01		0.0	0.0
Kr90	Ci	9.39E-01	1.14E+00	0.0	0.0
Xe 139	Ci	2.79E+00	3.39E+00	0.0	0.0
Kr89	Ci	2.73E+01	3.32E+01	0.0	0.0
Xe 137	Ci	3.55E+01		0.0	0.0
Xe 135M	Ci	2.05E+00			0.0
Kr83M	Ci	2.68E-01			0.0
Xe 133M	Ci		9.29E-03		0.0
Xe 131M	Ci		7.04E-04		0.0
Kr85		7.99E-03			0.0
Total for Period	. Ci	1.07E+02	1.20E+02	0.0	0.0
2. Iodines:		•			•
I-131	Ci	2.89E-03	2.74E-03	0.0	0.0
I-133	Ci	2.13E-02			0.0
I-135	Ci	0.0	3.02E-03		0.0
Total	Ci	2.42E-02	2.59E-02	0.0	0.0

Period: Jul - Dec 1983

License No. DPR-22

## EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 1C Gaseous Effluents - Building Vent Releases (Continued)

Nuclides Released	Units	Continuous Mode 1st Qtr 2nd Qtr		Batch Mode 1st Qtr 2nd Qt	
•					
3. Particulates:					
Ce 141	Ci	0.0	5.21E-07	0.0	0.0
Ba140	Ci	1.21E-03	9.03E-04	0.0	0.0
Cs 137	Ci	3.52E-04	8.36E-05	0.0	0.0
Cs 134	Ci	8.35E-06	0.0	0.0	0.0
sr90	Ci	8.54E-06	5.86E-05	0.0	0.0
Sr89	Ci	3.99E-05	1.12E-04		0.0
Zn65	Ci	3.10E-04	2.86E-04	0.0	0.0
C060	Ci	1.77E-04	1.51E-04	0.0	0.0
Co58	Ci	2.07E-05	2.45E-05	0.0	0.0
Mn 54	Ci	8.21E-06	0.0	0.0	0.0
Cr51	Ci	0.0	1.28E-04	0.0	0.0
Total	Ci	2.14E-03	1.75E-03	0.0	0.0

Period: Jul - Dec 1983 License No. DPR-22

### EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

## Table 2A Liquid Effluents - Summation of All Releases

		Units	1st 2tr	2nd 2tr	Pont Est Error
A.	Fission and Activation Products:				
	<ol> <li>Total Release</li> <li>(Except H-3, Gases, and Alpha)</li> </ol>	Ci	0.0	0.0	0.0
	2. Avg Diluted Concentration	uCi/ml	0.0	0.0	
В.	Tritium:				
	1. Total Release	Ci	0.0	0.0	0.0
	2. Avg Diluted Concentration	uCi/ml	0.0	0.0	
c.	Dissolved and Entrained Gases:				
	1. Total Release	Ci	0.0	0.0	0.0
	2. Avg Diluted Concentration	uCi/ml	0.0	0.0	
Ď.	Percent Qtrly Tech Spec Reporting Level				
	Whole Body Dose		0.0	0.0	
	Organ Dose		0.0	0.0	
E.	Gross Alpha Radioactivity:			•	
	1. Total Release	Ci	0.0	0.0	0.0
F.	Volume of Waste Released	Liters	0.0	0.0	0.0
G.	Volume of Dilution Water Used	Liters	0.0	0.0	0.0

Page 10

MONTICELLO NUCLEAR GENERATING PLANT NORTHERN STATES POWER COMPANY

Period: Jul - Dec 1983

License No. DPR-22

### EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 2B Liquid Effluents

Nuclides Released

Continuous Mode Batch Mode Units 1st Qtr 2nd Qtr 1st Qtr 2nd Qtr

None Released This Period

Pont Est

MONTICELLO NUCLEAR GENERATING PLANT NORTHERN STATES POWER COMPANY

Period: Jul - Dec 1983 License No. DPR-22

# EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 3 Solid Waste and Irradiated Fuel Shipments

- A. Solid Waste Shipped Offsite For Burial or Disposal:
  - 1. Type of Waste:

		Units	Total	Error	
	Spent Resins, Filter Sludges, Evaporator Bottoms, Ect.	Cu Meter Ci	7.36E+01 3.95E+02	5.00E+01	
В.	Dry Compressible Waste, Contaminated Equip, Ect.	Cu Meter Ci	1.16E+02 1.32E+00	5.00E+01	
c.	Irradiated Components, Control Rods, Ect.	Cu Meter Ci	2.44E+00 7.80E+03	5.00E+01	

D. Other (described below):

None

Period: Jul - Dec 1983

License No. DPR-22

# EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 3 Solid Waste and Irradiated Fuel Shipments (Coontinued)

2. Measured Major Nuclide Composition by Type of Waste:

TYPE		Nuclide	Percent
A		Ce141	2.41E-02
		Ba140	2.75E+00
	·	Cs 137	3.15E+01
		Cs 134	3.12E+00
		Zn65	2.46E+01
		Co60	2.32E+01
		Co58	7.34E-01
	,	Mn54	2.46E+00
		Cr51	8.25E+00
		La140	3.87E-01
		I 131	1.95E+00
В		Ba140	7.34E-02
		Cs 137	9.55E+00
		Cs 134	1.03E+00
	•	Sr90	1.84E-01
	·	Zn65	1.16E+01
		C060	6.78E+01
	<u>.</u>	Co58	4.86E-01
		Mn54	6.09E+00
	•	Cr51	3.02E+00
		La140	7.34E-02
C		Co60	9.55E+01
		Mn 54	4.49E+00

Period: Jul - Dec 1983

License No. DPR-22

### EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 3 Solid Waste and Irradiated Fuel Shipments (Continued)

3. Solid Waste Disposition:

Number of Shipments	Mode	Destination
2	Truck	Chem-Nuc Inc., Barnwell, SC
4	Truck	US Ecology, Richland, WA
13	Rail	US Ecology, Richland, WA

B. Irradiated Fuel Shipments:

Number of Shipments Mode Destination

None

. منت

4

4.

•

.

.

.

.

=

Period: Jul - Dec 1983

License No. DPR-22

### EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 3 Solid Waste and Irradiated Fuel Shipments (Continued)

C. Shipping Container and Solidification Method:

No.		-		Container Code	Solidification Code
	~~~~~				
(83-50)	5.66E+00	3.29E+01	A	A	C
(83-53)	5.66E+00	2.60E+01	A	A	C
(83-54)	5.66E+00	3.55E+01	A	A	C
(83-55)	5.66E+00	3.38E+01	A	A	C
(83-56)	5.66E+00	2.71E+01	A	A	C
(83-57)	3.81E+01	3.84E-01	В	L	_
(83-58)	5.66E+00	3.93E+01	A	A	С
(83-60)	1.53E+01	3.46E-02	В	L	_
		2.72E+01	A	A	C
(83-61)	5.66E+00	2.72E+01	A	· A	Ċ
(83-63)	5.66E+00	2.48E+01	A	A	Č
		3.45E+01	A	A	Č
		5.00E+03	C	В	-
(83-70)	5.66E+00	4.06E+01	A		C
		4.60E-01	В	L	•
		2.80E+03	C	<b>B</b> ,	
		2.09E+01		A	C
		2.48E+01		A .	C
	2.45E+01		B	L	•
	- · · · · · · · · · · · · · · · · · · ·			. <del></del> .	

CONTAINER CODES:

L - LSA

A - Type A

B - Type B

2 - Large Quantity

SOLIFICATION CODES: C - Cement

U - Urea Formaldehyde

Period: Jul - Dec 1983 License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

#### Nootes:

II. Release of individual noble gas isotopes from the plant stack was determined using an isotopic analysis at the steam jet air ejector. Xe133, Xe135, Kr85M, Kr88, Kr87, and Xe138 were measured and used to characterize the mode of gas release from the fuel. Other significant noble gases were determined using known ratios, the measured total offgas holidup system delay time, and the known fraction of the offgas stream released via the gland exhauster.

- 2. An isotopic analysis for noble gases is normally not possible at the building vents. Individual isotopes are generally below their lower limit of detection (LLD). Therefore, for reactor building vent releases, the noble gas isotopic mixture is assumed to be the same as the mixture determined at the steam jet air ejector.
- 3. Information specified in Regulatory Guide 1.21 which is not applicable to the Monticello plant is indicated by 'NA'.
- 4. Nuclides not detected in plant effluents (those below the LLD of the analysis) are not included in the quantities reported released. LLD values are recorded and must be less than the minimum LLD values stated in the Monticello Technical Specifications.