U.S. NUCLEAR REGULATORY COMMISSION

REGION III

Report No: 50-263/86005(DRS)

Docket No. 50-263

License No.: DPR-22

Licensee:

Northern States Power Company

414 Nicollet Mall

Minneapolis, MN 55401

Facility Name: Monticello Nuclear Generating Plant

Inspection At: Monticello Site, Monticello, MN

Inspection Conducted: June 30, 1986

D. H. Danielson, Chief

Materials & Processes Section

Inspection Summary

<u>Inspection on June 30 1986 (Report No. 50-263/86005(DRS))</u>
<u>Areas Inspected</u>: Routine unannounced inspection of the resolution of an IE

Bulletin.

Results: No violations or deviations were identified.

Details

1. Persons Contacted

Northern States Power Company (NSP)

*B. Day, Superintendent, Operations Engineering

*S. Engelke, Lead Production Engineer

*A. Ward, Engineer II

U.S. Nuclear Regulatory Commission (NRC)

P.Hartmann, Senior Resident Inspector

*Denotes those present at the exit interview on June 30, 1986.

2. Licensee Action on an IE Bulletin

(Closed) IE Bulletin (346/83-03-BB) IE Bulletin 83-03, "Check Valve Failures in Raw Water Cooling Systems of Diesel Generators."

The inspector reviewed the licensee's final response dated April 10, 1986. Ten valves were included in the IST program which was modified to satisfy the testing requirements of the bulletin. Check Valves No. SW-101, 102, 103, and 104 were granted relief requests from forward flow testing and are reverse flow tested only. Initial integrity testing was performed and no failures were found.

3. Exit Interview

The inspector met with site representatives (denoted in persons contacted paragraph) at the conclusion of the inspection. The inspector summarized scope and findings of the inspection noted in this report. The inspector also discussed the likely informational content of the inspection report with regard to documents or processes reviewed by the inspector during the inspection. The licensee did not identify any such documents/processes as proprietary.