

HNP-2 ACTIVE PAGE LIST

<u>Page</u>	<u>Rev</u>	<u>Page</u>	<u>Rev</u>
Table of Contents			
i thru cxiv	27	Table 2.3-14, shs 1 thru 4	19
Chapter 1		Table 2.3-15, shs 1 thru 48	19
1.1-1 thru 1.1-5	22	Table 2.3-16, shs 1 thru 48	19
Table 1.1-1, shs 1 thru 20	28	Table 2.3-17	19
1.2-1 thru 1.2-27	27	Table 2.3-18	19
Table 1.2-2, shs 1 and 2	22	Table 2.3-19	19
Figure 1.2-1	26	Table 2.3-20	19
Figure 1.2-2	22	Table 2.3-21	19
Figure 1.2-3	22	Table 2.3-22	19
Figure 1.2-4	26	Table 2.3-23, shs 1 and 2	19
Figure 1.2-5	22	Table 2.3-24, shs 1 and 2	19
Figure 1.2-7	22	Table 2.3-25	19
1.3-1	22	Figure 2.3-1	19
Table 1.3-1, shs 1 thru 11	19	Figure 2.3-2	19
1.4-1 thru 1.4-5	21	Figure 2.3-3	19
1.5-1	19	Figure 2.3-4	19
1.6-1	19	Figure 2.3-5	19
Table 1.6-1, shs 1 thru 4	19	Figure 2.3-6	19
Chapter 2		Figure 2.3-7	19
2.1-1 thru 2.1-7	19	Figure 2.3-8	19
Figure 2.1-1	19	Figure 2.3-9	19
Figure 2.1-2	19	Figure 2.3-10	19
Figure 2.1-3	19	Figure 2.3-11	19
Figure 2.1-4	19	Figure 2.3-12, shs 1 thru 8	19
Figure 2.1-5	19	Figure 2.3-13	19
Figure 2.1-6	19	Figure 2.3-14	19
2.2-1 thru 2.2-7	22	Figure 2.3-15, shs 1 thru 4	19
Figure 2.2-1	19	Figure 2.3-16	19
2.3-1 thru 2.3-24	25	2.4-1 thru 2.4-31	21
Table 2.3-1	19	Table 2.4-1	19
Table 2.3-2	19	Table 2.4-2, shs 1 thru 6	19
Table 2.3-3, shs 1 and 2	19	Table 2.4-3	19
Table 2.3-4	19	Table 2.4-4	19
Table 2.3-5	19	Table 2.4-5	19
Table 2.3-7, shs 1 thru 3	20	Table 2.4-6	19
Table 2.3-9, shs 1 thru 4	19	Table 2.4-7, shs 1 and 2	19
Table 2.3-10, shs 1 thru 4	19	Table 2.4-8, shs 1 thru 4	29
Table 2.3-11	19	Table 2.4-9	19
Table 2.3-12	19	Table 2.4-10	19
Table 2.3-13, shs 1 thru 4	19	Figure 2.4-1	19
		Figure 2.4-2	19
		Figure 2.4-3	19
		Figure 2.4-4	19

HNP-2-FSAR

HNP-2 ACTIVE PAGE LIST

<u>Page</u>	<u>Rev</u>	<u>Page</u>	<u>Rev</u>
Figure 2.4-5	19	Table 2.5-4, shs 1 thru 3	19
Figure 2.4-6	19	Table 2.5-5, shs 1 thru 3	19
Figure 2.4-7	19	Figure 2.5-1	19
Figure 2.4-8	19	Figure 2.5-2	19
Figure 2.4-9	19	Figure 2.5-3	19
Figure 2.4-10	19	Figure 2.5-4	19
Figure 2.4-11	19	Figure 2.5-5	19
Figure 2.4-12	19	Figure 2.5-6	19
Figure 2.4-13	19	Figure 2.5-7	19
Figure 2.4-14	19	Figure 2.5-8	19
Figure 2.4-15	19	Figure 2.5-9	19
Figure 2.4-16	19	Figure 2.5-10	19
Figure 2.4-17	19	Figure 2.5-11	19
Figure 2.4-18	19	Figure 2.5-12	19
Figure 2.4-19	19	Figure 2.5-13	19
Figure 2.4-20	19	Figure 2.5-14	19
Figure 2.4-21	19	Figure 2.5-15	19
Figure 2.4-22	19	Figure 2.5-16	19
Figure 2.4-23	19	Figure 2.5-17	19
Figure 2.4-24	19	Figure 2.5-18	19
Figure 2.4-25	19	Figure 2.5-19	19
Figure 2.4-26	19	Figure 2.5-20	19
Figure 2.4-27	19	Figure 2.5-21	19
Figure 2.4-28	19		
Figure 2.4-29	19	Supplement 2A	
Figure 2.4-30	19	2A-1 thru 2A-41	26
Figure 2.4-31	19	Table 2A-1, shs 1 thru 6	19
Figure 2.4-32	19	Table 2A-2, shs 1 and 2	19
Figure 2.4-33	19	Table 2A-3	19
Figure 2.4-34	19	Table 2A-4, shs 1 thru 3	19
Figure 2.4-35	19	Table 2A-5, shs 1 and 2	19
Figure 2.4-36	19	Table 2A-6	19
Figure 2.4-37	19	Table 2A-7, shs 1 and 2	19
Figure 2.4-38	19	Table 2A-8	19
Figure 2.4-39	19	Table 2A-9	19
Figure 2.4-40	19	Table 2A-10, shs 1 and 2	19
Figure 2.4-41, shs 1 thru 6	19	Table 2A-11	19
Figure 2.4-42, shs 1 thru 9	19	Table 2A-12	19
Figure 2.4-43	19	Table 2A-13	19
2.5-1 thru 2.5-49	19	Table 2A-14	19
Table 2.5-1, shs 1 thru 8	19	Table 2A-15	19
Table 2.5-2, shs 1 thru 3	19	Table 2A-16	19
Table 2.5-3	19	Table 2A-17	19

HNP-2-FSAR

HNP-2 ACTIVE PAGE LIST

<u>Page</u>	<u>Rev</u>	<u>Page</u>	<u>Rev</u>
Table 2A-18	19	Figure 2A-37	19
Table 2A-19	19	Figure 2A-38, shs 1 thru 9	19
Table 2A-20	19	Figure 2A-39	19
Table 2A-21	19	Figure 2A-40	19
Table 2A-22	19	Figure 2A-41	19
Table 2A-23, shs 1 and 2	19	Figure 2A-42	19
Table 2A-24	19	Figure 2A-43	19
Table 2A-25	19	Figure 2A-44	19
Figure 2A-1, shs 1 and 2	19	Figure 2A-45	19
Figure 2A-2	19	Figure 2A-46	19
Figure 2A-3, shs 1 thru 7	19	Figure 2A-47	19
Figure 2A-4	19	Figure 2A-48	19
Figure 2A-5	19	Figure 2A-49	19
Figure 2A-6	19	Figure 2A-50	19
Figure 2A-7	19	Figure 2A-51	19
Figure 2A-8, shs 1 thru 34	19	Figure 2A-52	19
Figure 2A-9, shs 1 thru 4	19	Figure 2A-53	19
Figure 2A-10	19	Figure 2A-54	19
Figure 2A-11, shs 1 thru 5	19	Figure 2A-55	19
Figure 2A-12	19		
Figure 2A-13	19	Supplement 2B	
Figure 2A-14	19	Figure 2B-1	19
Figure 2A-15	19	Figure 2B-2	19
Figure 2A-16	19	Figure 2B-3	19
Figure 2A-17, shs 1 thru 7	19	Figure 2B-4	19
Figure 2A-18, shs 1 thru 3	19	Figure 2B-5	19
Figure 2A-19	19	Figure 2B-6	19
Figure 2A-20	19	Figure 2B-7	19
Figure 2A-21	19	Figure 2B-8	19
Figure 2A-22, shs 1 and 2	19	Figure 2B-9	19
Figure 2A-23	19	Figure 2B-10	19
Figure 2A-24	19	Figure 2B-11	19
Figure 2A-26	19	Figure 2B-12	19
Figure 2A-27	19	Figure 2B-13	19
Figure 2A-28	19	Figure 2B-14	19
Figure 2A-29, shs 1 thru 13	19	Figure 2B-15	19
Figure 2A-30	19	Figure 2B-16	19
Figure 2A-31	19	Figure 2B-17	19
Figure 2A-32	19	Figure 2B-18	19
Figure 2A-33	19	Figure 2B-19	19
Figure 2A-34	19	Figure 2B-20	19
Figure 2A-35	19	Figure 2B-21	19
Figure 2A-36	19	Figure 2B-22	19

HNP-2-FSAR

HNP-2 ACTIVE PAGE LIST

<u>Page</u>	<u>Rev</u>	<u>Page</u>	<u>Rev</u>
Figure 2B-23	19	Figure 2B-66	19
Figure 2B-24	19	Figure 2B-67	19
Figure 2B-25	19	Figure 2B-68	19
Figure 2B-26	19	Figure 2B-69	19
Figure 2B-27	19	Figure 2B-70	19
Figure 2B-28	19	Figure 2B-71	19
Figure 2B-29	19	Figure 2B-72	19
Figure 2B-30	19	Figure 2B-73	19
Figure 2B-31	19	Figure 2B-74	19
Figure 2B-32	19	Figure 2B-75	19
Figure 2B-33	19	Figure 2B-76	19
Figure 2B-34	19	Figure 2B-77	19
Figure 2B-35	19	Figure 2B-78	19
Figure 2B-36	19	Figure 2B-79	19
Figure 2B-37	19	Figure 2B-80	19
Figure 2B-38	19	Figure 2B-81	19
Figure 2B-39	19	Figure 2B-82	19
Figure 2B-40	19	Figure 2B-83	19
Figure 2B-41	19	Figure 2B-84	19
Figure 2B-42	19	Figure 2B-85	19
Figure 2B-43	19	Figure 2B-86	19
Figure 2B-44	19	Figure 2B-87	19
Figure 2B-45	19	Figure 2B-88	19
Figure 2B-46	19	Figure 2B-89	19
Figure 2B-47	19	Figure 2B-90	19
Figure 2B-48	19	Figure 2B-91	19
Figure 2B-49	19	Figure 2B-92	19
Figure 2B-50	19	Figure 2B-93	19
Figure 2B-51	19	Figure 2B-94	19
Figure 2B-52	19	Figure 2B-95	19
Figure 2B-53	19	Figure 2B-96	19
Figure 2B-54	19	Figure 2B-97	19
Figure 2B-55	19	Figure 2B-98	19
Figure 2B-56	19	Figure 2B-99	19
Figure 2B-57	19	Figure 2B-100	19
Figure 2B-58	19	Figure 2B-101	19
Figure 2B-59	19	Figure 2B-102	19
Figure 2B-60	19	Figure 2B-103	19
Figure 2B-61	19	Figure 2B-104	19
Figure 2B-62	19	Figure 2B-105	19
Figure 2B-63	19	Figure 2B-106	19
Figure 2B-64	19	Figure 2B-107	19
Figure 2B-65	19	Figure 2B-108	19

HNP-2-FSAR

HNP-2 ACTIVE PAGE LIST

<u>Page</u>	<u>Rev</u>	<u>Page</u>	<u>Rev</u>
Figure 2B-109	19	Figure 3.3-1	19
Figure 2B-110	19	3.4-1 thru 3.4-3	20
Figure 2B-111	19	Table 3.4-1	19
Figure 2B-112	19	Figure 3.4-1	19
Figure 2B-113	19	3.5-1 thru 3.5-14	27
Figure 2B-114	19	Table 3.5-1	19
Figure 2B-115	19	Table 3.5-2	19
Figure 2B-116	19	Table 3.5-3	19
Figure 2B-117	19	Table 3.5-4, shs 1 and 2	19
Figure 2B-118	19	3.6-1 thru 3.6-20	19
Figure 2B-119	19	Figure 3.6-1	19
Figure 2B-120	19	Figure 3.6-2	19
Figure 2B-121	19	Figure 3.6-3	19
Figure 2B-122	19	Figure 3.6-4	19
Figure 2B-123	19	3.7A-1 thru 3.7A-20	19
Figure 2B-124	19	Table 3.7A-1	19
Figure 2B-125	19	Table 3.7A-2, shs 1 and 2	19
Figure 2B-126	19	Table 3.7A-3, shs 1 and 2	19
Figure 2B-127	19	Table 3.7A-4	19
Figure 2B-128	19	Figure 3.7A-1	19
Figure 2B-129	19	Figure 3.7A-2	19
Figure 2B-130	19	Figure 3.7A-3	19
Figure 2B-131	19	Figure 3.7A-4	19
Figure 2B-132	19	Figure 3.7A-5	19
Figure 2B-133	19	Figure 3.7A-6	19
Figure 2B-134	19	Figure 3.7A-7	19
Figure 2B-135	19	Figure 3.7A-8	19
Figure 2B-136	19	Figure 3.7A-9	19
Figure 2B-137	19	Figure 3.7A-10	19
Figure 2B-138	19	Figure 3.7A-11	19
		Figure 3.7A-12	19
		Figure 3.7A-13	19
Chapter 3		Figure 3.7A-14	19
3.1-1 thru 3.1-53	27	Figure 3.7A-15	19
Table 3.1-1	19	Figure 3.7A-16	19
Table 3.1-2	19	Figure 3.7A-17	19
3.2-1 thru 3.2-10	27	Figure 3.7A-18	19
Table 3.2-1, shs 1 thru 11	29	Figure 3.7A-19	19
Table 3.2-2, shs 1 thru 3	29	Figure 3.7A-20	19
Table 3.2-3	29	Figure 3.7A-21	19
Table 3.2-4, shs 1 thru 4	27	Figure 3.7A-22	19
Table 3.2-6, shs 1 and 2	19	Figure 3.7A-23	19
3.3-1 thru 3.3-8	21	3.7A.A-1 thru 3.7A.A-7	19
Table 3.3-1	19		

HNP-2-FSAR

HNP-2 ACTIVE PAGE LIST

<u>Page</u>	<u>Rev</u>	<u>Page</u>	<u>Rev</u>
Figure 3.7A.A-1	19	Figure 3.8-7	19
3.7A.B-1 thru 3.7A.B-9	19	Figure 3.8-8	19
Table 3.7A.B-1	19	Figure 3.8-9	19
Table 3.7A.B-2	19	Figure 3.8-10	19
Table 3.7A.B-3	19	Figure 3.8-11	19
Table 3.7A.B-4	19	Figure 3.8-12	19
Table 3.7A.B-5	19	Figure 3.8-13	19
Table 3.7A.B-6	28	Figure 3.8-14	19
Figure 3.7A.B-1	19	Figure 3.8-15	19
Figure 3.7A.B-2	19	Figure 3.8-16	19
Figure 3.7A.B-3	19	Figure 3.8-17	19
Figure 3.7A.B-4	19	Figure 3.8-18	19
Figure 3.7A.B-5	19	Figure 3.8-19	19
3.7B-1 thru 3.7B-24	19	Figure 3.8-20	19
Table 3.7B-1	19	Figure 3.8-21	19
Table 3.7B-2	19	Figure 3.8-22	19
Table 3.7B-3	19	Figure 3.8-23	19
Figure 3.7B-1	19	Figure 3.8-24	19
Figure 3.7B-2	19	Figure 3.8-25	19
Figure 3.7B-3	19	Figure 3.8-26	19
3.8-1 thru 3.8-104	27	Figure 3.8-27	19
Table 3.8-2, shs 1 thru 11	19	Figure 3.8-28	19
Table 3.8-3, shs 1 thru 6	19	Figure 3.8-29	19
Table 3.8-4	19	Figure 3.8-30	19
Table 3.8-8	19	Figure 3.8-31	19
Table 3.8-9, shs 1 and 2	19	Figure 3.8-32	19
Table 3.8-10	19	Figure 3.8-33	19
Table 3.8-11	19	Figure 3.8-34	19
Table 3.8-12	19	Figure 3.8-35	19
Table 3.8-13, shs 1 and 2	19	Figure 3.8-36	19
Table 3.8-14	19	Figure 3.8-37	19
Table 3.8-15	19	Figure 3.8-38	19
Table 3.8-16	19	Figure 3.8-39	19
Table 3.8-17	19	Figure 3.8-40	19
Table 3.8-18	19	Figure 3.8-41	19
Table 3.8-19	19	Figure 3.8-42	19
Table 3.8-20, shs 1 thru 13	19	Figure 3.8-43	19
Figure 3.8-1	19	Figure 3.8-44	19
Figure 3.8-2, shs 1 thru 4	19	Figure 3.8-45	19
Figure 3.8-3	19	Figure 3.8-46	19
Figure 3.8-4	19	Figure 3.8-47	19
Figure 3.8-5	19	Figure 3.8-48	19
Figure 3.8-6	19	Figure 3.8-49	19

HNP-2-FSAR

HNP-2 ACTIVE PAGE LIST

<u>Page</u>	<u>Rev</u>	<u>Page</u>	<u>Rev</u>
3.8A-1 thru 3.8A-4	19	Table 3.9-38, shs 1 thru 5	19
3.8B-1 thru 3.8B-4	24	Table 3.9-39, shs 1 thru 5	19
Table 3.8B-1, shs 1 and 2	19	Table 3.9-40, shs 1 thru 5	19
3.8C-1 thru 3.8C-25	19	Table 3.9-41, shs 1 thru 5	19
3.8D-1 thru 3.8D-19	19	Table 3.9-42, shs 1 thru 5	19
3.9-1 thru 3.9-55	29	Table 3.9-43	19
Table 3.9-1	19	Table 3.9-44	19
Table 3.9-2, shs 1 and 2	22	Table 3.9-45	19
Table 3.9-3, shs 1 thru 4	19	Table 3.9-46	19
Table 3.9-4, shs 1 thru 9	19	Table 3.9-47	19
Table 3.9-5	19	Table 3.9-48, shs 1 and 2	19
Table 3.9-6	22	Table 3.9-49, shs 1 thru 3	19
Table 3.9-7	19	Table 3.9-50, shs 1 and 2	19
Table 3.9-8, shs 1 and 2	19	Table 3.9-51	19
Table 3.9-9, shs 1 thru 4	27	Table 3.9-52, shs 1 thru 3	19
Table 3.9-10, shs 1 and 2	22	Table 3.9-53	19
Table 3.9-11	19	Table 3.9-54	19
Table 3.9-12, shs 1 and 2	19	Table 3.9-55, shs 1 thru 4	19
Table 3.9-13, shs 1 thru 5	19	Table 3.9-56, shs 1 thru 3	19
Table 3.9-14, shs 1 thru 14	19	Table 3.9-57	19
Table 3.9-15, shs 1 thru 3	19	Table 3.9-58, shs 1 thru 3	19
Table 3.9-16, shs 1 thru 8	19	Table 3.9-59, shs 1 thru 3	19
Table 3.9-17	19	Table 3.9-60, shs 1 thru 3	19
Table 3.9-18, shs 1 thru 3	19	Table 3.9-61, shs 1 and 2	19
Table 3.9-19, shs 1 and 2	19	Table 3.9-62	29
Table 3.9-20, shs 1 thru 3	19	Table 3.9-63	19
Table 3.9-21, shs 1 and 2	19	Table 3.9-64	19
Table 3.9-22, shs 1 and 2	19	Figure 3.9-1	19
Table 3.9-23, shs 1 thru 3	19	3.10-1 thru 3.10-35	29
Table 3.9-24, shs 1 and 2	19	Table 3.10-1, shs 1 thru 5	19
Table 3.9-25, shs 1 thru 3	19	Table 3.10-2	19
Table 3.9-26, shs 1 and 2	19	Table 3.10-3, shs 1 thru 3	19
Table 3.9-27, shs 1 thru 3	19	Table 3.10-4, shs 1 and 2	19
Table 3.9-28	19	Table 3.10-5	19
Table 3.9-29, shs 1 and 2	19	Table 3.10-6	19
Table 3.9-30, shs 1 and 2	19	Table 3.10-7	19
Table 3.9-31, shs 1 and 2	19	Table 3.10-8	19
Table 3.9-32, shs 1 and 2	19	Table 3.10-9, shs 1 and 2	19
Table 3.9-33, shs 1 thru 16	29	Table 3.10-10	19
Table 3.9-34, shs 1 and 2	19	Table 3.10-11	19
Table 3.9-35, shs 1 thru 5	29	Table 3.10-12, shs 1 and 2	19
Table 3.9-36, shs 1 thru 5	19	Table 3.10-13, shs 1 and 2	19
Table 3.9-37, shs 1 thru 5	19	Table 3.10-14	19

HNP-2-FSAR

HNP-2 ACTIVE PAGE LIST

<u>Page</u>	<u>Rev</u>	<u>Page</u>	<u>Rev</u>
Table 3.10-15, shs 1 and 2	19	Table 4.2-11	22
Table 3.10-16	19	Figure 4.2-1	19
Table 3.10-17	19	Figure 4.2-2	19
Table 3.10-18	19	Figure 4.2-3	19
Table 3.10-19	19	Figure 4.2-4	19
Table 3.10-20	19	Figure 4.2-5	19
Table 3.10-21	19	Figure 4.2-6	19
Table 3.10-22, shs 1 and 2	19	Figure 4.2-7	19
Figure 3.10-1	19	Figure 4.2-8	19
Figure 3.10-2	19	Figure 4.2-9	19
Figure 3.10-3	19	Figure 4.2-10	19
Figure 3.10-4	19	Figure 4.2-11	19
Figure 3.10-5	19	Figure 4.2-12	19
Figure 3.10-6	19	Figure 4.2-13	19
Figure 3.10-7	19	Figure 4.2-14	19
Figure 3.10-8, shs 1 thru 4	19	Figure 4.2-15	26
Figure 3.10-9, shs 1 thru 4	19	Figure 4.2-16	26
Figure 3.10-10	19	Figure 4.2-17	24
Figure 3.10-11	19	Figure 4.2-18	26
Figure 3.10-12	19	Figure 4.2-19	26
Figure 3.10-13	19	4.3-1 thru 4.3-6	29
Figure 3.10-14, shs 1 thru 6	19	Table 4.3-1	22
3.11-1 thru 3.11-6	27	4.4-1 thru 4.4-8	28
Table 3.11-1, shs 1 and 2	28	Table 4.4-1	19
Figure 3.11-1	27	4.5-1 thru 4.5-3	19
		Figure 4.5-1	19
		4A-1	19
Chapter 4		Table 4A-1	19
4.1-1 thru 4.1-7	29	Table 4A-2, shs 1 and 2	19
Figure 4.1-1	19	Figure 4A-1	19
Figure 4.1-2	19	Figure 4A-2	19
Figure 4.1-3	19		
Figure 4.1-4	19	Chapter 5	
4.2-1 thru 4.2-57	29	5.1-1 thru 5.1-3	19
Table 4.2-1	19	Figure 5.1-1	22
Table 4.2-2, shs 1 and 2	19	5.2-1 thru 5.2-56	29
Table 4.2-3	19	Table 5.2-1, shs 1 thru 3	19
Table 4.2-4	19	Table 5.2-3	21
Table 4.2-5, shs 1 thru 3	19	Table 5.2-4	29
Table 4.2-6, shs 1 thru 3	19	Table 5.2-5	22
Table 4.2-7, shs 1 thru 3	19	Table 5.2-6, shs 1 and 2	19
Table 4.2-8	19	Table 5.2-7, shs 1 and 2	22
Table 4.2-9	19	Table 5.2-8	19
Table 4.2-10	22		

HNP-2-FSAR

HNP-2 ACTIVE PAGE LIST

<u>Page</u>	<u>Rev</u>	<u>Page</u>	<u>Rev</u>
Table 5.2-9, shs 1 and 2	19	6.2-1 thru 6.2-64	27
Table 5.2-10, shs 1 and 2	24	Table 6.2-1	22
Table 5.2-11	21	Table 6.2-2, shs 1 thru 3	23
Figure 5.2-1	19	Table 6.2-3, shs 1 and 2	27
Figure 5.2-2	29	Table 6.2-4	19
Figure 5.2-3	19	Table 6.2-6, shs 1 and 2	27
Figure 5.2-4	19	Table 6.2-7	27
Figure 5.2-5	19	Table 6.2-8	19
Figure 5.2-6	19	Table 6.2-9	19
5.3-1	19	Table 6.2-10, shs 1 thru 8	22
5.4-1 thru 5.4-9	22	Table 6.2-11	27
Table 5.4-1	19	Table 6.2-14, shs 1 and 2	19
Figure 5.4-1	19	Table 6.2-15, shs 1 and 2	19
Figure 5.4-2	21	Table 6.2-16	27
5.5-1 thru 5.5-48	27	Table 6.2-17	27
Table 5.5-1, shs 1 and 2	22	Table 6.2-18	27
Table 5.5-3	19	Figure 6.2-1	19
Table 5.5-4, shs 1 thru 4	19	Figure 6.2-2	19
Table 5.5-5, shs 1 thru 8	19	Figure 6.2-3	19
Table 5.5-6	19	Figure 6.2-4	19
Figure 5.5-1	19	Figure 6.2-5	19
Figure 5.5-2	19	Figure 6.2-6	22
Figure 5.5-3	19	Figure 6.2-7	22
Figure 5.5-4	19	Figure 6.2-8	22
Figure 5.5-5	19	Figure 6.2-9	22
Figure 5.5-6	19	Figure 6.2-10	22
Figure 5.5-8	27	Figure 6.2-11	22
Figure 5.5-9	22	Figure 6.2-12	22
Figure 5.5-10	19	Figure 6.2-13	19
Figure 5.5-11	19	Figure 6.2-14	19
Figure 5.5-12	19	Figure 6.2-15	19
5.6-1 thru 5.6-2	19	Figure 6.2-16	19
5A-1 thru 5A-7	19	Figure 6.2-17	22
Figure 5A-1	19	Figure 6.2-18	22
Figure 5A-2, shs 1 and 2	19	Figure 6.2-19	22
Figure 5A-3, shs 1 and 2	19	Figure 6.2-20	22
Figure 5A-4, shs 1 and 2	19	Figure 6.2-21	27
Figure 5A-5	19	Figure 6.2-22	27
Figure 5A-6	19	Figure 6.2-23	27
		Figure 6.2-24	22
Chapter 6		Figure 6.2-28	22
6.1-1 thru 6.1-2	27	Figure 6.2-31	22
Table 6.1-1	19	Figure 6.2-34	19

HNP-2-FSAR

HNP-2 ACTIVE PAGE LIST

<u>Page</u>	<u>Rev</u>	<u>Page</u>	<u>Rev</u>
Figure 6.2-35	19	Figure 6A-6	19
Figure 6.2-36	19	Figure 6A-7	19
Figure 6.2-37	19	Figure 6A-8	19
Figure 6.2-49	27	Figure 6A-9	19
Figure 6.2-50	27	Figure 6A-10	19
Figure 6.2-51	27	Figure 6A-11	19
Figure 6.2-52	27	Figure 6A-12	19
Figure 6.2-53	27	Figure 6A-13	22
Figure 6.2-54	27	Figure 6A-14	22
Figure 6.2-55	27	Figure 6A-15	22
Figure 6.2-56	27	Figure 6A-16	19
6.3-1 thru 6.3-35	27	Figure 6A-17	19
Table 6.3-1	27	Figure 6A-18	19
Table 6.3-2	21	Figure 6A-19	19
Table 6.3-3	27	Figure 6A-20	19
Table 6.3-4, shs 1 and 2	26	Figure 6A-21	19
Table 6.3-5	27	Figure 6A-22	19
Figure 6.3-1	21	Figure 6A-23	19
Figure 6.3-2	21	Figure 6A-24	19
Figure 6.3-5	27	Figure 6A-25	19
Figure 6.3-6	27	Figure 6A-26	19
6.4-1 thru 6.4-7	26	Figure 6A-27	19
Table 6.4-1, shs 1 and 2	19	Figure 6A-28	19
Table 6.4-2	26	Figure 6A-29	19
6A-1 thru 6A-23	22	Figure 6A-30	19
Table 6A-1	19	Figure 6A-31	19
Table 6A-2	19	Figure 6A-32	19
Table 6A-3	19	Figure 6A-33, shs 1 thru 3	19
Table 6A-4, shs 1 and 2	22	Figure 6A-34, shs 1 thru 3	19
Table 6A-5, shs 1 and 2	22	Figure 6A-35	19
Table 6A-6, shs 1 and 2	19	Figure 6A-36, shs 1 thru 4	19
Table 6A-7, shs 1 thru 3	19	Figure 6A-37	19
Table 6A-8, shs 1 thru 3	19	Figure 6A-38	19
Table 6A-9	19	Figure 6A-39	19
Table 6A-10	19	Figure 6A-40	19
Table 6A-11, shs 1 thru 4	19	Figure 6A-41	19
Table 6A-12, shs 1 and 2	19	Figure 6A-42	19
Table 6A-13	19	Figure 6A-43	19
Figure 6A-1	19	Figure 6A-44	19
Figure 6A-2	19	Figure 6A-45	19
Figure 6A-3	19	Figure 6A-46	19
Figure 6A-4	19	Figure 6A-47, shs 1 and 2	19
Figure 6A-5	19	Figure 6A-48	19

HNP-2-FSAR

HNP-2 ACTIVE PAGE LIST

<u>Page</u>	<u>Rev</u>	<u>Page</u>	<u>Rev</u>
Figure 6A-49	19	Figure 7.3-2	19
Figure 6A-50	22	Figure 7.3-3	19
Figure 6A-51	22	Figure 7.3-4	19
Figure 6A-52	22	Figure 7.3-5	19
Figure 6A-53	22	Figure 7.3-6	19
Figure 6A-54	19	Figure 7.3-7	19
Figure 6A-55	19	Figure 7.3-8	19
Figure 6A-56	19	Figure 7.3-9	19
Figure 6A-57	19	Figure 7.3-10	19
Figure 6A-58	19	Figure 7.3-11	19
Figure 6A-59	19	Figure 7.3-12	19
Figure 6A-60	19	7.4-1 thru 7.4-33	20
Figure 6A-61, shs 1 thru 3	19	Table 7.4-1	19
Figure 6A-62	19	Table 7.4-2	19
		Figure 7.4-1	19
Chapter 7		Figure 7.4-2	19
7.1-1 thru 7.1-13	27	Figure 7.4-3	19
Table 7.1-1, shs 1 and 2	27	7.5-1 thru 7.5-20	25
Table 7.1-2, shs 1 and 2	19	Table 7.5-1, shs 1 thru 34	26
Table 7.1-3, shs 1 and 2	19	7.6-1 thru 7.6-84	29
7.2-1 thru 7.2-23	27	Table 7.6-1, shs 1 and 2	26
Table 7.2-1	19	Table 7.6-2	19
Table 7.2-2	21	Table 7.6-3	19
Table 7.2-3	19	Table 7.6-4	19
Table 7.2-4	19	Table 7.6-5	19
Figure 7.2-1	22	Table 7.6-7	19
Figure 7.2-2	19	Table 7.6-8	19
Figure 7.2-3	19	Table 7.6-9, shs 1 and 2	19
Figure 7.2-4, shs 1 and 2	19	Table 7.6-10	19
Figure 7.2-5	19	Table 7.6-11	19
Figure 7.2-6	19	Table 7.6-12	24
Figure 7.2-7	19	Table 7.6-13	19
7.3-1 thru 7.3-67	29	Figure 7.6-1	19
Table 7.3-1	19	Figure 7.6-2	19
Table 7.3-2	19	Figure 7.6-3	19
Table 7.3-3	19	Figure 7.6-4	19
Table 7.3-4	19	Figure 7.6-5	19
Table 7.3-5	19	Figure 7.6-6	19
Table 7.3-6	19	Figure 7.6-7, shs 1 thru 5	19
Table 7.3-7	19	Figure 7.6-8, shs 1 and 2	19
Table 7.3-8	19	Figure 7.6-9	19
Table 7.3-9, shs 1 thru 3	19	Figure 7.6-10	19
Figure 7.3-1	19	Figure 7.6-11	19

HNP-2 ACTIVE PAGE LIST

<u>Page</u>	<u>Rev</u>	<u>Page</u>	<u>Rev</u>
Figure 7.6-12	19	Figure 8.3-1	22
Figure 7.6-13	19	Figure 8.3-2	19
Figure 7.6-14	19	Figure 8.3-3	19
Figure 7.6-15	19	Figure 8.3-4	19
Figure 7.6-16	19	Figure 8.3-5	28
7.7-1 thru 7.7-25	27	Figure 8.3-7	19
Table 7.7-1, shs 1 and 2	19	Figure 8.3-8	19
Figure 7.7-1	19	Figure 8.3-9	20
Figure 7.7-2	27	8.4-1 thru 8.4-7	22
Figure 7.7-3	27	Table 8.4-1	19
7.8-1 thru 7.8-7	19	Table 8.4-2	20
Table 7.8-1, shs 1 thru 7	19		
Figure 7.8-1	19	Chapter 9	
7.9-1 thru 7.9-5	29	9.1-1 thru 9.1-36	29
7.10-1 thru 7.10-4	22	Table 9.1-2	19
		Table 9.1-3	19
Chapter 8		Table 9.1-4, shs 1 and 2	19
8.1-1 thru 8.1-5	19	Figure 9.1-1	19
8.2-1 thru 8.2-3	27	Figure 9.1-2	29
Figure 8.2-1	19	Figure 9.1-3, shs 1 and 2	19
Figure 8.2-2	19	Figure 9.1-4, shs 1 and 2	19
Figure 8.2-3	19	Figure 9.1-5	19
Figure 8.2-4	19	Figure 9.1-6, shs 1 thru 3	19
8.3-1 thru 8.3-52	29	9.2-1 thru 9.2-23	29
Table 8.3-1, shs 1 and 2	28	Table 9.2-1	26
Table 8.3-3	22	Table 9.2-2, shs 1 and 2	27
Table 8.3-4	19	Table 9.2-4, shs 1 and 2	19
Table 8.3-5	25	Table 9.2-5	19
Table 8.3-6	19	Table 9.2-6	23
Table 8.3-7	19	Table 9.2-7	19
Table 8.3-8	19	Table 9.2-8	19
Table 8.3-9	19	Table 9.2-9	19
Table 8.3-10	19	Table 9.2-10	19
Table 8.3-11	19	Table 9.2-11	19
Table 8.3-12	20	Table 9.2-12	19
Table 8.3-13	20	Table 9.2-13	19
Table 8.3-14	19	Table 9.2-14	19
Table 8.3-15	20	Table 9.2-15	19
Table 8.3-16	20	Table 9.2-16	19
Table 8.3-17	19	Table 9.2-17	19
Table 8.3-18	19	Table 9.2-18	19
Table 8.3-19	20	Figure 9.2-1	19
Table 8.3-20	20	Figure 9.2-2	26

HNP-2-FSAR

HNP-2 ACTIVE PAGE LIST

<u>Page</u>	<u>Rev</u>	<u>Page</u>	<u>Rev</u>
Figure 9.2-3	19	Figure 9.5-1, shs 1 and 2	19
Figure 9.2-4	19		
Figure 9.2-5	19	Chapter 10	
Figure 9.2-6	19	10.1-1 thru 10.1-3	22
Figure 9.2-7	19	10.2-1 thru 10.2-11	27
Figure 9.2-8	19	Table 10.2-1	22
Figure 9.2-9	19	Table 10.2-2	19
Figure 9.2-10	19	Table 10.2-3	19
Figure 9.2-11	27	Figure 10.2-1	19
Figure 9.2-12	19	Figure 10.2-2	19
Figure 9.2-13	19	Figure 10.2-3	19
Figure 9.2-14	19	10.2A-1 thru 10.2A-3	27
9.3-1 thru 9.3-22	25	Figure 10.2A-1	27
Table 9.3-1	19	Figure 10.2A-2	27
Table 9.3-2, shs 1 and 2	19	Figure 10.2A-3	27
9.4-1 thru 9.4-41	29	Figure 10.2A-4	27
Table 9.4-1	19	Figure 10.2A-5	19
Table 9.4-2, shs 1 and 2	22	10.3-1 thru 10.3-3	19
Table 9.4-3, shs 1 thru 4	25	10.4-1 thru 10.4-24	28
Table 9.4-4, shs 1 thru 5	19	Figure 10.4-1	24
Table 9.4-5	25		
Table 9.4-6, shs 1 and 2	19	Chapter 11	
Table 9.4-7, shs 1 and 2	25	11.1-1 thru 11.1-14	22
Table 9.4-8, shs 1 and 2	19	Table 11.1-1	19
Table 9.4-9	19	Table 11.1-2	22
Table 9.4-10, shs 1 thru 3	19	Table 11.1-3, shs 1 and 2	22
Table 9.4-11	19	Table 11.1-4	22
Table 9.4-12, shs 1 thru 3	19	Table 11.1-5	22
Table 9.4-13, shs 1 and 2	19	Table 11.1-6	22
Table 9.4-14, shs 1 thru 6	29	Table 11.1-7	22
Table 9.4-15, shs 1 thru 8	29	Table 11.1-8	22
Table 9.4-16	19	Table 11.1-9	19
Table 9.4-17, shs 1 and 2	19	Table 11.1-10	22
Table 9.4-18, shs 1 and 2	19	Table 11.1-11, shs 1 thru 4	22
Table 9.4-19, shs 1 and 2	29	Figure 11.1-1	19
Table 9.4-20	19	Figure 11.1-2	19
Figure 9.4-1	19	Figure 11.1-3	19
9.5-1 thru 9.5-24	22	11.2-1 thru 11.2-17	19
Table 9.5-1	19	Table 11.2-1	19
Table 9.5-2	19	Table 11.2-2, shs 1 thru 3	19
Table 9.5-3	19	Table 11.2-3	22
Table 9.5-4, shs 1 and 2	19	Table 11.2-4, shs 1 thru 4	22
Table 9.5-5	22	Table 11.2-5	19

HNP-2-FSAR

HNP-2 ACTIVE PAGE LIST

<u>Page</u>	<u>Rev</u>	<u>Page</u>	<u>Rev</u>
Figure 11.2-3	19	Table 12.4-1	19
11.3-1 thru 11.3-14	22	Table 12.4-2	19
Table 11.3-1	19	Table 12.4-3	19
Table 11.3-2, shs 1 thru 4	19	12.5-1 thru 12.5-13	28
Table 11.3-3, shs 1 and 2	19	Table 12.5-1, shs 1 thru 3	23
Table 11.3-4, shs 1 and 2	19	Table 12.5-2	19
Table 11.3-5, shs 1 thru 3	19		
Table 11.3-6, shs 1 thru 3	22	Chapter 13	
Table 11.3-7	22	13.1-1 thru 13.1-17	29
Figure 11.3-1	28	Figure 13.1-1	29
11.4-1 thru 11.4-27	27	Figure 13.1-2	29
Table 11.4-1, shs 1 thru 4	26	Figure 13.1-3	29
Table 11.4-2	19	Figure 13.1-4	19
Table 11.4-3	19	13.2-1 thru 13.2-6	27
Table 11.4-4	19	13.3-1	19
Table 11.4-5	19	13.4-1 thru 13.4-2	26
Table 11.4-6	19	13.4A-1	26
Table 11.4-7	19	13.4B-1	26
11.5-1 thru 11.5-8	26	13.5-1 thru 13.5-5	26
Table 11.5-1	19	13.6-1 thru 13.6-4	27
Table 11.5-2	19	13.7-1 thru 13.7-6	25
Table 11.5-3	19	Figure 13.7-1	25
Table 11.5-4	19		
Table 11.5-5	19	Chapter 14	
Figure 11.5-1	19	14.1-1 thru 14.1-22	19
11.6-1	19	Table 14.1-1	19
		Table 14.1-2	19
Chapter 12		Table 14.1-3, shs 1 thru 4	19
12.1-1 thru 12.1-11	25	Figure 14.1-1	19
Table 12.1-1, shs 1 and 2	19	Figure 14.1-2	19
12.2-1 thru 12.2-6	19	Figure 14.1-3	19
Table 12.2-1	19	Figure 14.1-4	19
Table 12.2-2, shs 1 and 2	19	Figure 14.1-5	19
12.3-1 thru 12.3-14	22	Figure 14.1-6	19
Table 12.3-1, shs 1 and 2	19	Figure 14.1-7	19
Table 12.3-2	19	Figure 14.1-8	19
Figure 12.3-1	19	Figure 14.1-9	19
Figure 12.3-2	19	Figure 14.1-10, shs 1 and 2	19
Figure 12.3-4	19	Figure 14.1-11	19
Figure 12.3-5	19	Figure 14.1-12	19
Figure 12.3-6	19	14.2-1 thru 14.2-5	19
Figure 12.3-7	19	14A-1 thru 14A-84	27
12.4-1 thru 12.4-3	19	14B-1 thru 14B-50	19

HNP-2-FSAR

HNP-2 ACTIVE PAGE LIST

<u>Page</u>	<u>Rev</u>	<u>Page</u>	<u>Rev</u>
Chapter 15		Table 15.3-1	19
15.1-1 thru 15.1-24	29	Table 15.3-2	19
Table 15.1-1, shs 1 thru 5	29	Table 15.3-3	19
Table 15.1-2, shs 1 thru 3	22	Table 15.3-4	19
Table 15.1-3, shs 1 thru 6	21	Table 15.3-5	19
Table 15.1-4	19	Table 15.3-6	19
Figure 15.1-1	19	Table 15.3-7	19
Figure 15.1-2	19	Table 15.3-8	19
Figure 15.1-3	22	Table 15.3-9	19
15.2-1 thru 15.2-46	27	Table 15.3-10	19
Table 15.2-1	22	Figure 15.3-1	19
Table 15.2-2, shs 1 and 2	19	Figure 15.3-2	19
Table 15.2-3	19	15.4-1 thru 15.4-39	28
Table 15.2-4	19	Table 15.4-1	22
Table 15.2-5	19	Table 15.4-2	22
Figure 15.2-1	19	Table 15.4-3	19
Figure 15.2-2	19	Table 15.4-4	19
Figure 15.2-3	19	Table 15.4-5	19
Figure 15.2-4	19	Table 15.4-6	26
Figure 15.2-5	19	Table 15.4-7	19
Figure 15.2-6	19	Figure 15.4-1	19
Figure 15.2-7	19	Figure 15.4-2	19
Figure 15.2-8	19	Figure 15.4-3	19
Figure 15.2-9	19	Figure 15.4-4	19
Figure 15.2-10	19	Figure 15.4-5	19
Figure 15.2-11	19	Figure 15.4-6	19
Figure 15.2-12	19		
Figure 15.2-13	19	Supplement 15A	
Figure 15.2-14	19	15A-1 thru 15A-52	28
Figure 15.2-15	19	Table 15A-1	19
Figure 15.2-16	19	Table 15A-2	27
Figure 15.2-17	19	Table 15A-3, shs 1 thru 3	19
Figure 15.2-18	19	Figure 15A-1	22
Figure 15.2-19	19	Figure 15A-2	19
Figure 15.2-20	19	Figure 15A-3	19
Figure 15.2-21	19	Figure 15A-4	19
Figure 15.2-22	19	Figure 15A-6	19
Figure 15.2-23	19	Figure 15A-9	19
Figure 15.2-24	19	Figure 15A-10	19
Figure 15.2-25	19	Figure 15A-11	19
Figure 15.2-26	19	Figure 15A-12	19
15.3-1 thru 15.3-43	29	Figure 15A-13	19
		Figure 15A-14	19

HNP-2-FSAR

HNP-2 ACTIVE PAGE LIST

<u>Page</u>	<u>Rev</u>	<u>Page</u>	<u>Rev</u>
Figure 15A-15	19	Figure 15C-24	19
Figure 15A-16	19	Figure 15C-25	19
Figure 15A-17	19	Figure 15C-26	19
		Figure 15C-27	19
Supplement 15A.A		Figure 15C-28	19
15A.A-1 thru 15A.A-5	22	Figure 15C-29	19
		Figure 15C-30	19
Supplement 15C		Figure 15C-31	25
15C-1 thru 15C-79	29	Figure 15C-32	19
Table 15C-1	19	Figure 15C-33	19
Table 15C-2, shs 1 and 2	19	Figure 15C-34	19
Table 15C-3, shs 1 and 2	19	Figure 15C-35	25
Table 15C-4	19	Figure 15C-36	19
Table 15C-5, shs 1 thru 3	19	Figure 15C-37	19
Table 15C-6, shs 1 thru 3	19	Figure 15C-38	19
Table 15C-7, shs 1 and 2	26	Figure 15C-39	19
Table 15C-8, shs 1 and 2	19	Figure 15C-40	19
Table 15C-9	25	Figure 15C-41	19
Table 15C-10	19	Figure 15C-42	19
Table 15C-11, shs 1 and 2	25	Figure 15C-43	19
Figure 15C-1	19	Figure 15C-44	19
Figure 15C-2	19	Figure 15C-45	19
Figure 15C-3	19	Figure 15C-46	19
Figure 15C-4	19	Figure 15C-47	19
Figure 15C-5	19	Figure 15C-48	19
Figure 15C-6	19	Figure 15C-49	19
Figure 15C-7	19	Figure 15C-50	19
Figure 15C-8	19	Figure 15C-51	19
Figure 15C-9	19	Figure 15C-52, shs 1 and 2	19
Figure 15C-10	19	Figure 15C-53	19
Figure 15C-11	19	Figure 15C-54	25
Figure 15C-12	19	Figure 15C-55	25
Figure 15C-13	19	Figure 15C-56	25
Figure 15C-14	19	Figure 15C-57	25
Figure 15C-15	19	Figure 15C-58	25
Figure 15C-16	19	Figure 15C-59	25
Figure 15C-17	19		
Figure 15C-18	19	Chapter 16	
Figure 15C-19	19	16.1-1	19
Figure 15C-20	19		
Figure 15C-21	19	Chapter 17	
Figure 15C-22	19	17.1-1	19
Figure 15C-23	19	17.2-1	26

HNP-2 ACTIVE PAGE LIST

<u>Page</u>	<u>Rev</u>	<u>Page</u>	<u>Rev</u>
Table 17.2-1	26	A.27-1	28
Table 17.2-2, shs 1 thru 10	27	A.28-1	28
Figure 17.2-1	26	A.29-1	28
17.2A-1	26	A.30-1	28
Table 17.2A-1	19	A.31-1 thru A.31-2	28
		A.32-1	28
Chapter 18		A.33-1 thru A.33-2	28
18.1-1 thru 18.1-5	20	A.34-1	28
18.2-1 thru 18.2-27	28	A.35-1	28
18.3-1 thru 18.3-10	20	A.36-1	28
Table 18.3.1-1	20	A.37-1	28
18.4-1 thru 18.4-13	28	A.38-1	28
18.5-1 and 18.5-2	20	A.39-1	28
Table 18.5-1	20	A.40-1	28
18.6-1 thru 18.6-4	28	A.41-1	28
		A.42-1	28
Appendix A		A.43-1	28
A.1-1	28	A.44-1	28
A.2-1	28	A.45-1 thru A.45-2	28
A.3-1	28	A.46-1	28
A.4-1	28	A.47-1 thru A.47-2	28
A.5-1	28	A.48-1 thru A.48-2	28
A.6-1	28	A.49-1	28
A.7-1	28	A.50-1	28
A.8-1	28	A.51-1	28
A.9-1	28	A.52-1 thru A.52-3	28
A.10-1	28	A.53-1	28
A.11-1	28	A.54-1	28
A.12-1	28	A.55-1	28
A.13-1	28	A.56-1	28
A.14-1	28	A.57-1	28
A.15-1	28	A.58-1	28
A.16-1	28	A.59-1	28
A.17-1	28	A.60-1	28
A.18-1	28	A.61-1	28
A.19-1	28	A.62-1 thru A.62-2	28
A.20-1	28	A.63-1	28
A.21-1	28	A.64-1	28
A.22-1	28	A.65-1	28
A.23-1	28	A.66-1	28
A.24-1	28	A.67-1	28
A.25-1	28	A.68-1 thru A.68-6	28
A.26-1	28	A.69-1	28

HNP-2-FSAR

HNP-2 ACTIVE PAGE LIST

<u>Page</u>	<u>Rev</u>	<u>Page</u>	<u>Rev</u>
A.70-1	28		
A.71-1	28		
A.72-1	28		
A.73-1	28		
A.74-1	28		
A.75-1	28		
A.76-1	28		
A.77-1	28		
A.78-1 thru A.78-2	28		
A.79-1	28		
A.80-1	28		
A.81-1	28		
A.82-1	28		
A.83-1	28		
A.84-1	28		
A.85-1	28		
A.86-1	28		
A.87-1	28		
A.88-1	28		
A.89-1	28		
A.90-1	28		
A.94-1	28		
A.97-1	28		
A.105-1	28		
A.116-1	28		
A.123-1	28		
A.143-1	28		
A.144-1	28		
A.146-1	28		
A.155-1	28		

TABLE OF CONTENTS

CHAPTER 1 INTRODUCTION AND GENERAL DESCRIPTION OF PLANT

1.1 Introduction

- 1.1.1 License Requested
- 1.1.2 Number of Plant Units
- 1.1.3 *Plant Location*
- 1.1.4 *Nuclear Steam Supply System*
- 1.1.5 *Containment Structure*
- 1.1.6 *Power Output*
- 1.1.7 *Schedule for Completion and Commercial Operation*
- 1.1.8 Organization of Contents
 - 1.1.8.1 Subdivisions
 - 1.1.8.2 Standard Format
 - 1.1.8.3 References (HNP-1 and HNP-2)
 - 1.1.8.4 Tables, Figures, and Drawings (HNP-1 and HNP-2)
 - 1.1.8.5 Numbering of Pages (HNP-1 and HNP-2)
 - 1.1.8.6 Amending the FSAR (HNP-1 and HNP-2)
 - 1.1.8.7 Historical Information (HNP-1 and HNP-2)

1.2 General Plant Description

- 1.2.1 *Site Characteristics (HNP-1 and HNP-2)*
 - 1.2.1.1 *Location (HNP-1 and HNP-2)*
 - 1.2.1.2 *Site Ownership*
 - 1.2.1.3 *Access to the Site*
 - 1.2.1.4 *Site Environs*
 - 1.2.1.5 *Geology*
 - 1.2.1.6 *Seismology and Design Response Spectra*
 - 1.2.1.7 *Hydrology*
 - 1.2.1.8 *Meteorology*
 - 1.2.1.9 *Environmental Radiation Monitoring*
- 1.2.2 Facility Arrangement (HNP-1 and HNP-2)
- 1.2.3 Nuclear System (HNP-1 and HNP-2)
 - 1.2.3.1 Reactor Primary Vessel and Internals
 - 1.2.3.2 Reactor Core and Control Rods
 - 1.2.3.3 Reactor Recirculation System (RRS)
 - 1.2.3.4 Residual Heat Removal (RHR) System
 - 1.2.3.5 Reactor Water Cleanup (RWC) System

TABLE OF CONTENTS (CONTINUED)

1.2.4 Power Conversion Systems (HNP-1 and HNP-2)

- 1.2.4.1 Turbine-Generator (HNP-1 and HNP-2)
- 1.2.4.2 Turbine Bypass System (HNP-1 and HNP-2)
- 1.2.4.3 Main Condenser (HNP-1 and HNP-2)
- 1.2.4.4 Main Condenser Air Ejector (HNP-1 and HNP-2)
- 1.2.4.5 Turbine Steam Sealing System (HNP-1 and HNP-2)
- 1.2.4.6 Circulating Water System (HNP-1 and HNP-2)
- 1.2.4.7 Condensate Demineralizer System (HNP-1 and HNP-2)
- 1.2.4.8 Condensate and Reactor Feedwater Systems (HNP-1 and HNP-2)
- 1.2.4.9 CROSSFLOW™ System (HNP-1 and HNP-2)

1.2.5 Electrical Power System (HNP-1 and HNP-2)

1.2.6 Radioactive Waste Systems (HNP-1 and HNP-2)

- 1.2.6.1 Liquid Radwaste System
- 1.2.6.2 Solid Radwaste System
- 1.2.6.3 Gaseous Radwaste System (GRS)

1.2.7 Nuclear Safety Systems and Engineered Safeguards (HNP-1 and HNP-2)

- 1.2.7.1 Reactor Protection System (RPS) (HNP-1 and HNP-2)
- 1.2.7.2 Neutron Monitoring System (NMS) (HNP-1 and HNP-2)
- 1.2.7.3 Control Rod Drive System (HNP-1 and HNP-2)
- 1.2.7.4 Pressure Relief System (HNP-1 and HNP-2)
- 1.2.7.5 Reactor Core Isolation Cooling (RCIC) System (HNP-1 and HNP-2)
- 1.2.7.6 Primary Containment (HNP-1 and HNP-2)
- 1.2.7.7 Primary Containment and Reactor Vessel Isolation Control Systems (HNP-1 and HNP-2)
- 1.2.7.8 Secondary Containment (HNP-1 and HNP-2)
- 1.2.7.9 Main Steam Line Isolation Valves (MSIVs) (HNP-1 and HNP-2)
- 1.2.7.10 Main Steam Line Flow Restrictors (HNP-1 and HNP-2)
- 1.2.7.11 Emergency Core Cooling System (ECCS) (HNP-1 and HNP-2)
- 1.2.7.12 Containment Spray and Suppression Pool Cooling (HNP-1 and HNP-2)
- 1.2.7.13 (Deleted)
- 1.2.7.14 Control Rod Velocity Limiter (HNP-1 and HNP-2)
- 1.2.7.15 Control Rod Drive Housing Supports (HNP-1 and HNP-2)
- 1.2.7.16 Standby Electric Power Systems (HNP-1 and HNP-2)
- 1.2.7.17 dc Power Supply (HNP-1 and HNP-2)
- 1.2.7.18 Plant Service Water (PSW) System (HNP-1 and HNP-2)
- 1.2.7.19 Residual Heat Removal Service Water (RHRSW) System (HNP-1 and HNP-2)
- 1.2.7.20 Main Steam Line Radiation Monitoring System (HNP-1 and HNP-2)
- 1.2.7.21 Reactor Building Isolation and Control System (HNP-1 and HNP-2)

HNP-2-FSAR

TABLE OF CONTENTS (CONTINUED)

- 1.2.7.22 Combustible Gas Control System (CGCS) (HNP-2)
- 1.2.7.23 Main Control Room Environmental Control (MCREC) System (HNP-1 and HNP-2)
- 1.2.7.24 Equipment Area Cooling Systems (HNP-1 and HNP-2)
- 1.2.7.25 Low-Low Set (LLS) Relief Logic System (HNP-2)
- 1.2.8 Special Safety Systems (HNP-1 and HNP-2)
 - 1.2.8.1 Standby Liquid Control System (HNP-1 and HNP-2)
 - 1.2.8.2 Shutdown Capability Outside the Main Control Room (HNP-1 and HNP-2)
- 1.2.9 Process Control and Instrumentation (HNP-1 and HNP-2)
 - 1.2.9.1 Nuclear System Process Control and Instrumentation
 - 1.2.9.2 Power Conversion Systems Process Control and Instrumentation (HNP-1 and HNP-2)
 - 1.2.9.3 Electrical Power System Process Control (HNP-1 and HNP-2)
 - 1.2.9.4 Radiation Monitoring and Control (HNP-1 and HNP-2)
- 1.2.10 Auxiliary Systems (HNP-1 and HNP-2)
 - 1.2.10.1 Auxiliary ac Power (HNP-1 and HNP-2)
 - 1.2.10.2 Plant Service Water System (HNP-1 and HNP-2)
 - 1.2.10.3 Fire Protection System (FPS) (HNP-1 and HNP-2)
 - 1.2.10.4 Drywell Pneumatic System (HNP-1 and HNP-2)
 - 1.2.10.5 Torus Drainage and Purification System (HNP-1 and HNP-2)
 - 1.2.10.6 Heating, Ventilation, and Air-Conditioning Systems (HNP-1 and HNP-2)
 - 1.2.10.7 New and Spent-Fuel Storage (HNP-1 and HNP-2)
 - 1.2.10.8 Fuel Pool Cooling and Filtering System, (HNP-1 and HNP-2)
 - 1.2.10.9 Service and Instrument Air Systems (HNP-1 and HNP-2)
 - 1.2.10.10 Makeup Water Treatment System (HNP-1 and HNP-2)
 - 1.2.10.11 Potable and Sanitary Water System (HNP-1 and HNP-2)
 - 1.2.10.12 Plant Equipment and Floor Drainage System (HNP-1 and HNP-2)
 - 1.2.10.13 Reactor Building Closed Cooling Water System (HNP-1 and HNP-2)
 - 1.2.10.14 Process Sampling System (HNP-1 and HNP-2)
 - 1.2.10.15 Plant Communication System (HNP-1 and HNP-2)
 - 1.2.10.16 Plant Lighting System (HNP-1 and HNP-2)
- 1.2.11 Shielding (HNP-1 and HNP-2)
- 1.2.12 Implementation of Loading Criteria (HNP-1 and HNP-2)
 - 1.2.12.1 Seismic Category I (HNP-1 and HNP-2)
 - 1.2.12.2 Other Than Seismic Category I (HNP-1 and HNP-2)

TABLE OF CONTENTS (CONTINUED)

- 1.3 *Comparison Tables*
 - 1.3.1 *Comparison With Similar Facility Designs (HNP-1 and HNP-2)*
- 1.4 *Identification of Agents and Contractors*
 - 1.4.1 *Introduction*
 - 1.4.2 *Applicants (HNP-1 and HNP-2)*
 - 1.4.2.1 *Georgia Power Company*
 - 1.4.2.2 *Oglethorpe Power Corporation*
 - 1.4.2.3 *Municipal Electric Authority of Georgia*
 - 1.4.2.4 *City of Dalton, Georgia*
 - 1.4.2.5 *Georgia Power Company*
 - 1.4.2.6 *Southern Nuclear Operating Company*
 - 1.4.3 *Architect/Engineer (HNP-1 and HNP-2)*
 - 1.4.3.1 *General*
 - 1.4.3.2 *Technical Qualifications*
 - 1.4.4 *Nuclear Steam Supply System Supplier (HNP-1 and HNP-2)*
 - 1.4.4.1 *General*
 - 1.4.4.2 *Technical Qualifications*
 - 1.4.5 *Division of Responsibility*
 - 1.4.5.1 *Design Stage*
 - 1.4.5.2 *Procurement Stage*
- 1.5 *(Deleted)*
- 1.6 *Referenced Topical Reports*

CHAPTER 2 SITE CHARACTERISTICS

- 2.1 Geography and Demography (HNP-1 and HNP-2)
 - 2.1.1 Site Location and Description
 - 2.1.1.1 Specification of Location
 - 2.1.1.2 Site Area Map
 - 2.1.1.3 Boundaries for Establishing Effluent Release Limits

TABLE OF CONTENTS (CONTINUED)

- 2.1.2 Exclusion Area Authority and Control
 - 2.1.2.1 Authority
 - 2.1.2.2 Control of Activities Unrelated to Plant Operation
 - 2.1.2.3 Arrangements for Traffic Control
- 2.1.3 Population Distribution
 - 2.1.3.1 Population Within 10 Miles
 - 2.1.3.2 Population Between 10 and 50 Miles
 - 2.1.3.3 Transient Population
 - 2.1.3.4 Low-Population Zone
 - 2.1.3.5 Population Center
- 2.2 Nearby Industrial, Transportation, and Military Facilities
 - 2.2.1 Locations and Routes
 - 2.2.2 Descriptions
 - 2.2.2.1 Description of Facilities
 - 2.2.2.2 Description of Products and Materials
 - 2.2.2.3 Pipelines
 - 2.2.2.4 Waterways
 - 2.2.2.5 Airports
 - 2.2.2.6 Projections of Industrial Growth
 - 2.2.3 Evaluation of Potential Accidents
 - 2.2.3.1 Determination of Design Basis Events
 - 2.2.3.2 Effects of Design Basis Events
- 2.3 Meteorology (HNP-1 and HNP-2)
 - 2.3.1 Regional Climatology
 - 2.3.1.1 Data Sources
 - 2.3.1.2 General
 - 2.3.1.3 Severe Weather
 - 2.3.2 Local Meteorology
 - 2.3.2.1 Data Sources
 - 2.3.2.2 Normal and Extreme Values of Meteorological Parameters
 - 2.3.2.3 Potential Influence of the Plant and Its Facilities on Local Meteorology

TABLE OF CONTENTS (CONTINUED)

- 2.3.2.4 Topographical Description
- 2.3.3 Onsite Meteorological Measurement Program
- 2.3.4 Short-Term (Accident) Diffusion Estimates
 - 2.3.4.1 Objective
 - 2.3.4.2 Calculations
- 2.3.5 Long-term (Routine) Diffusion Estimates
 - 2.3.5.1 Objective
 - 2.3.5.2 Calculations
- 2.3.6 Accident Diffusion Estimates for MCR and Technical Support Center
- 2.4 *Hydrologic Engineering*
 - 2.4.1 *Hydrologic Description (HNP-1 and HNP-2)*
 - 2.4.1.1 *Site and Facilities*
 - 2.4.1.2 *Hydrosphere*
 - 2.4.2 *Floods (HNP-1 and HNP-2)*
 - 2.4.2.1 *Flood History*
 - 2.4.2.2 *Flood Design Considerations*
 - 2.4.2.3 *Effects of Local Intense Precipitation*
 - 2.4.3 *Probable Maximum Flood (HNP-1 and HNP-2)*
 - 2.4.3.1 *Probable Maximum Precipitation*
 - 2.4.3.2 *Precipitation Losses*
 - 2.4.3.3 *Runoff Model*
 - 2.4.3.4 *PMF Flow*
 - 2.4.3.5 *Water-Level Determination*
 - 2.4.3.6 *Coincident Wind/Wave Activity*
 - 2.4.4 *Potential Dam Failures*
 - 2.4.4.1 *Reservoir Description*
 - 2.4.4.2 *Dam Failure Permutations*
 - 2.4.4.3 *Unsteady Flow Analysis of Potential Dam Failure*
 - 2.4.4.4 *Water Level at Plant Site*
 - 2.4.5 *Probable Maximum Surge and Seiches Flooding*

TABLE OF CONTENTS (CONTINUED)

- 2.4.6 *Probable Maximum Tsunamis Flooding*
- 2.4.7 *Ice Flooding*
- 2.4.8 *Cooling-Water Canals and Reservoirs*
- 2.4.9 *Channel Diversions*
- 2.4.10 *Flooding Protection Requirements*
- 2.4.11 *Low-Flow Consideration*
 - 2.4.11.1 *Low Flow in the Altamaha River*
 - 2.4.11.2 *Low Water Resulting from Surges, Seiches, or Tsunamis*
 - 2.4.11.3 *Historical Low Water*
 - 2.4.11.4 *Future Control*
 - 2.4.11.5 *Plant Requirements*
 - 2.4.11.6 *Heat Sink Dependability*
- 2.4.12 *Environmental Acceptance of Effluents*
- 2.4.13 *Ground Water*
 - 2.4.13.1 *Description and Onsite Use*
 - 2.4.13.2 *Sources*
 - 2.4.13.3 *Accident Effects*
 - 2.4.13.4 *Monitoring or Safeguard Requirements*
 - 2.4.13.5 *Design Bases for Subsurface Hydrostatic Loading*
- 2.5 *Geology and Seismology (HNP-1 and HNP-2)*
 - 2.5.1 *Basic Geologic and Seismic Information*
 - 2.5.1.1 *Regional Geology*
 - 2.5.1.2 *Site Geology*
 - 2.5.2 *Vibratory Ground Motion*
 - 2.5.2.1 *Site Geologic Conditions*
 - 2.5.2.2 *Underlying Tectonic Structures*
 - 2.5.2.3 *Behavior During Prior Earthquakes*
 - 2.5.2.4 *Engineering Properties of Site Materials*
 - 2.5.2.5 *Earthquake History*
 - 2.5.2.6 *Correlation of Epicenters with Geologic Structures*
 - 2.5.2.7 *Identification of Active Faults*
 - 2.5.2.8 *Description of Active Faults*
 - 2.5.2.9 *Maximum Earthquake*
 - 2.5.2.10 *Design Basis Earthquake*
 - 2.5.2.11 *Operating Basis Earthquake (OBE)*

TABLE OF CONTENTS (CONTINUED)

2.5.3 *Surface Faulting*

- 2.5.3.1 *Geologic Conditions of the Site*
- 2.5.3.2 *Evidence of Fault Offset*
- 2.5.3.3 *Identification of Active Faults*
- 2.5.3.4 *Earthquakes Associated With Active Faults*
- 2.5.3.5 *Correlation of Epicenters With Active Faults*
- 2.5.3.6 *Description of Active Faults*
- 2.5.3.7 *Faulting Investigation Zone*
- 2.5.3.8 *Justification for Nonexistence of Surface Faulting*

2.5.4 *Stability of Subsurface Materials*

- 2.5.4.1 *Geologic Features*
- 2.5.4.2 *Properties of Underlying Materials*
- 2.5.4.3 *Plot Plan*
- 2.5.4.4 *Soil and Rock Characteristics*
- 2.5.4.5 *Excavations and Backfill*
- 2.5.4.6 *Ground Water Conditions*
- 2.5.4.7 *Dynamic Loading Response*
- 2.5.4.8 *Liquefaction Potential*
- 2.5.4.9 *Earthquake Design Basis*
- 2.5.4.10 *Static Analyses*
- 2.5.4.11 *Criteria and Design Methods*
- 2.5.4.12 *Techniques to Improve Subsurface Conditions*

2.5.5 *Slope Stability*

- 2.5.5.1 *Slope Characteristics*
- 2.5.5.2 *Design Criteria and Analyses*
- 2.5.5.3 *Logs of Core Borings*
- 2.5.5.4 *Compaction Specifications*

SUPPLEMENT 2A SUBSURFACE INVESTIGATION AND FOUNDATIONS

2A.1 *Field Exploration*

- 2A.1.1 *Plant Location*
- 2A.1.2 *Reconnaissance*
- 2A.1.3 *Boring, Sampling, and Groundwater Investigation*
- 2A.1.4 *Geophysical Exploration*

TABLE OF CONTENTS (CONTINUED)

- 2A.2 *Site Conditions*
 - 2A.2.1 *Topography and Drainage*
 - 2A.2.2 *Soil Conditions*
 - 2A.2.2.1 *Central Area*
 - 2A.2.2.2 *Eastern Area*
 - 2A.2.2.3 *Intermediate Area*
 - 2A.2.2.4 *Floodplain*
 - 2A.2.2.5 *Plant Location Soil Conditions*
- 2A.3 *Laboratory Testing (HNP-1 and HNP-2)*
 - 2A.3.1 *Routine Classification*
 - 2A.3.2 *X-Ray Diffraction Tests*
 - 2A.3.3 *Consolidation and Swell Tests*
 - 2A.3.4 *Triaxial Shear Tests*
 - 2A.3.5 *Cyclic Triaxial Compression Tests*
- 2A.4 *Structural Data*
 - 2A.4.1 *Site Grading*
 - 2A.4.2 *Reactor Building*
 - 2A.4.3 *Turbine and Control Building*
 - 2A.4.4 *Radwaste Building*
 - 2A.4.5 *Intake Structure*
 - 2A.4.6 *Main Stack*
 - 2A.4.7 *Diesel Generator Building*
 - 2A.4.8 *Service Water Piping and Electrical Ducts*
- 2A.5 *Foundation Evaluation*
 - 2A.5.1 *Plant Foundations*
 - 2A.5.1.1 *Reactor Building*
 - 2A.5.1.2 *Turbine and Control Buildings*
 - 2A.5.1.3 *Radwaste Building*
 - 2A.5.1.4 *Intake Structure*
 - 2A.5.1.5 *Main Stack*
 - 2A.5.1.6 *Diesel Generator Building*
 - 2A.5.2 *Soil Liquefaction Potential*

TABLE OF CONTENTS (CONTINUED)

- 2A.5.3 Building Settlement Monitoring
 - 2A.5.3.1 Total Settlement
 - 2A.5.3.2 Differential Settlement Across Structures
 - 2A.5.3.3 Penetration Differential Settlement
- 2A.6 *Slope Stability*
 - 2A.6.1 *Liquefaction Potential of Loose Zone*
 - 2A.6.2 *Slope Stability Analysis*
- 2A.7 *Lateral Earth Pressures*
- 2A.8 *Excavation and Backfill*
- 2A.9 *Excavation and Replacement of Backfill for the Intake Structure Buried Piping and Concrete Ducts*
 - 2A.9.1 *Introduction*
 - 2A.9.2 *Assessment of In Situ Backfill*
 - 2A.9.2.1 *Phase I Findings*
 - 2A.9.2.2 *Phase II Findings*
 - 2A.9.2.3 *Chronology of Intake Structure Construction*
 - 2A.9.2.4 *Evaluations*
 - 2A.9.2.5 *Conclusions*
 - 2A.9.2.6 *Structural Properties of K-Krete*
 - 2A.9.3 *Design, Construction, and Backfilling*
 - 2A.9.3.1 *Excavation and Backfilling Construction*
 - 2A.9.3.2 *Dewatering System*
 - 2A.9.3.3 *Limits of Excavation in the South End*
 - 2A.9.3.4 *Final Grade Preparation*

SUPPLEMENT 2B TEST BORING RECORD BORING NUMBERS

CHAPTER 3 DESIGN OF STRUCTURES, COMPONENTS, EQUIPMENT, AND SYSTEMS

3.1 *Conformance With Nuclear Regulatory Commission (NRC) General Design Criteria*

TABLE OF CONTENTS (CONTINUED)

- 3.2 Classification of Structures, Components, and Systems
 - 3.2.1 Seismic Classification
 - 3.2.1.1 Definitions
 - 3.2.1.2 Seismic Category I Structures
 - 3.2.1.3 Seismic Category I Mechanical Components and Systems
 - 3.2.1.4 Seismic Category I (Class 1E) Electrical Equipment
 - 3.2.1.5 Seismic Category Instrumentation and Control Systems Equipment
 - 3.2.2 System Quality Group Classifications
- 3.3 Wind and Tornado Loadings
 - 3.3.1 Wind Loadings (HNP-1 and HNP-2)
 - 3.3.1.1 Design Wind Velocity
 - 3.3.1.2 Basis for Wind Velocity Selection
 - 3.3.1.3 Vertical Velocity Distribution and Gust Factor
 - 3.3.1.4 Determination of Applied Forces
 - 3.3.2 Tornado Loadings
 - 3.3.2.1 Applicable Design Parameters
 - 3.3.2.2 Critical Load Combination for Tornado Load
 - 3.3.2.3 Depressurization and Blowout Panels
 - 3.3.2.4 Structural Strength Considerations
 - 3.3.2.5 Determination of Forces on Structures
 - 3.3.2.6 Ability of Seismic Category I Structures to Perform Despite Failure of Structures Not Designed for Tornado Loads
- 3.4 Water Level (Flood) Design (HNP-1 and HNP-2)
 - 3.4.1 Flood Protection
 - 3.4.2 Analysis Procedures
- 3.5 Missile Protection
 - 3.5.1 Missile Barriers and Loadings
 - 3.5.1.1 Accident/Incident-Generated Missiles (Inside Primary Containment)
 - 3.5.1.2 Internally Generated Missiles (Outside Primary Containment)
 - 3.5.1.3 Environmentally Generated Missiles
 - 3.5.1.4 *Site Proximity Missiles*

TABLE OF CONTENTS (CONTINUED)

- 3.5.2 Missile Selection
 - 3.5.2.1 Accident/Incident-Generated Missiles (Inside Primary Containment)
 - 3.5.2.2 Internally Generated Missile Selection (Outside Primary Containment)
 - 3.5.2.3 Environmentally Generated Missile Selection
- 3.5.3 Selected Missiles
 - 3.5.3.1 Selected Accident/Incident-Generated Missiles (Inside Primary Containment)
 - 3.5.3.2 Selected Internal Missiles (Outside Primary Containment)
 - 3.5.3.3 Selected Environmentally Generated Missiles
 - 3.5.3.4 Turbine-Generated Missiles
- 3.5.4 Barrier Design Procedures
- 3.5.5 Missile Barrier Features
- 3.6 Protection Against Dynamic Effects Associated With the Postulated Rupture of Piping
 - 3.6.1 Systems in Which Design Basis Piping Breaks Occur
 - 3.6.2 Design Basis Piping Break Criteria
 - 3.6.2.1 Postulated Failure Characteristics
 - 3.6.2.2 Location of Postulated High-Energy Piping Failures
 - 3.6.2.3 Moderate-Energy Piping Failures
 - 3.6.3 Design Loading Combinations
 - 3.6.3.1 Design of Pipe Whip Restraints
 - 3.6.3.2 Jet Impingement Forces
 - 3.6.4 Dynamic Analyses
 - 3.6.4.1 Design Bases for GE Recirculation Loop Pipe Whip Restraints
 - 3.6.4.2 Dynamic Analysis (PDA Code)
 - 3.6.4.3 Bechtel-Designed Restraints
 - 3.6.5 Protective Measures
 - 3.6.5.1 Pipe Restraints
 - 3.6.5.2 Protective Barriers
 - 3.6.5.3 Physical Separation

TABLE OF CONTENTS (CONTINUED)

SUPPLEMENT 3.7A SEISMIC DESIGN

3.7A.1 Seismic Input

- 3.7A.1.1 Design Response Spectra
- 3.7A.1.2 Synthetic Time Histories
- 3.7A.1.3 Damping Values
- 3.7A.1.4 Bases for Site Dependent Analysis
- 3.7A.1.5 Soil-Supported Seismic Category I Structures
- 3.7A.1.6 Soil-Structure Interaction

3.7A.2 Seismic System Analysis

- 3.7A.2.1 Seismic Analysis Methods
- 3.7A.2.2 Natural Frequencies and Response Loads
- 3.7A.2.3 Procedures Used to Lump Masses
- 3.7A.2.4 Rocking and Translational Response Summary
- 3.7A.2.5 Methods Used to Couple Soil with Seismic-System Structures
- 3.7A.2.6 Development of Floor Response Spectra
- 3.7A.2.7 Differential Seismic Movement of Interconnected Components
- 3.7A.2.8 Effects of Variations on Floor Response Spectra
- 3.7A.2.9 Use of Constant Vertical Load Factors
- 3.7A.2.10 Methods Used to Account for Torsional Effects
- 3.7A.2.11 Comparison of Responses
- 3.7A.2.12 Methods for Seismic Analysis of Dams
- 3.7A.2.13 Methods to Determine Seismic Category I Structure Overturning Moment
- 3.7A.2.14 Analysis Procedure for Damping

3.7A.3 Seismic Subsystem Analysis

- 3.7A.3.1 Determination of Number of Earthquake Cycles
- 3.7A.3.2 Basis for Selection of Forcing Frequencies
- 3.7A.3.3 Root Mean Square Basis
- 3.7A.3.4 Procedures for Combining Modal Responses
- 3.7A.3.5 Significant Dynamic Response Modes
- 3.7A.3.6 Design Criteria and Analytical Procedures for Piping
- 3.7A.3.7 Bases for Computing Combined Response
- 3.7A.3.8 Amplified Seismic Responses
- 3.7A.3.9 Use of Simplified Dynamic Analysis
- 3.7A.3.10 Modal Period Variation
- 3.7A.3.11 Torsional Effects of Eccentric Piping
- 3.7A.3.12 Piping Outside Containment
- 3.7A.3.13 Interaction of Other Piping with Seismic Category I Piping
- 3.7A.3.14 Location of Supports and Restraints

TABLE OF CONTENTS (CONTINUED)

- 3.7A.3.15 Seismic Analysis for Fuel Elements, Control Rod Assemblies, and Control Rod Drives
- 3.7A.3.16 Seismic Analysis of Cable Tray Supports
- 3.7A.4 Seismic Instrumentation Program
 - 3.7A.4.1 Comparison with Nuclear Regulator Commission Guide 1.12
 - 3.7A.4.2 Location and Description of Instrumentation
 - 3.7A.4.3 MCR Operator Notification
 - 3.7A.4.4 Comparison of Measured and Predicted Responses
- 3.7A.5 Seismic Design Control
 - 3.7A.5.1 General Electric-Supplied Equipment and Components
 - 3.7A.5.2 Bechtel Power Corporation Specified Equipment and Components
 - 3.7A.5.3 Southern Company Services, Inc., Specified Equipment and Components

SUPPLEMENT 3.7A.A CRITERIA FOR SEISMIC QUALIFICATION OF SEISMIC CATEGORY I EQUIPMENT AND PIPING

- 3.7A.A.1 Scope
- 3.7A.A.2 Definition
- 3.7A.A.3 Procedure
- 3.7A.A.4 Documentation
- 3.7A.A.5 Add the Following New Paragraph as 6.0 to IEEE Standards 344

SUPPLEMENT 3.7A.B ANALYSIS OF LONG-BURIED STRUCTURES

- 3.7A.B.1 Introduction
- 3.7A.B.2 Revised Stress Analysis of Intake Structure Buried Piping and Concrete Ducts

SUPPLEMENT 3.7B SEISMIC DESIGN – NUCLEAR STEAM SUPPLY SYSTEM

- 3.7B.1 Seismic Input
 - 3.7B.1.1 Design Response Spectra
 - 3.7B.1.2 Design Response Spectra Deviation
 - 3.7B.1.3 Critical Damping Values

TABLE OF CONTENTS (CONTINUED)

- 3.7B.1.4 Bases for Site-Dependent Analysis
- 3.7B.1.5 Soil-Supported Seismic Category I Structure
- 3.7B.1.6 Soil-Structure Interactions

- 3.7B.2 Seismic System Analysis
 - 3.7B.2.1 Seismic Analysis Methods
 - 3.7B.2.2 Natural Frequencies and Response Loads
 - 3.7B.2.3 Procedures Used to Lump Masses
 - 3.7B.2.4 Rocking and Translational Response Summary
 - 3.7B.2.5 Methods Used to Couple Soil With Seismic-System Structures
 - 3.7B.2.6 Development of Floor Response Spectra
 - 3.7B.2.7 Differential Seismic Movement of Interconnected Components
 - 3.7B.2.8 Effects of Variations on Floor Response Spectra
 - 3.7B.2.9 Use of Constant Vertical Load Factors
 - 3.7B.2.10 Methods Used to Account for Torsional Effects
 - 3.7B.2.11 Comparison of Responses
 - 3.7B.2.12 Methods for Seismic Analysis of Dams
 - 3.7B.2.13 Methods Used to Determine Seismic Category I Structure
Overturning Movements
 - 3.7B.2.14 Analysis Procedure for Damping

- 3.7B.3 Seismic Subsystem Analysis
 - 3.7B.3.1 Determination of Number of Earthquake Cycles
 - 3.7B.3.2 Basis for Selection of Forcing Frequencies
 - 3.7B.3.3 Square-Root-of-the-Sum-of-the-Squares
 - 3.7B.3.4 Procedure for Combining Modal Responses
 - 3.7B.3.5 Significant Dynamic Response Modes
 - 3.7B.3.6 Design Criteria and Analytical Procedures for Piping
 - 3.7B.3.7 Basis for Computing Combined Response
 - 3.7B.3.8 Amplified Seismic Responses
 - 3.7B.3.9 Use of Simplified Dynamic Analysis
 - 3.7B.3.10 Modal Period Variation
 - 3.7B.3.11 Torsional Effects of Eccentric Masses
 - 3.7B.3.12 Piping Outside Containment Structure
 - 3.7B.3.13 Interaction of Other Piping with Seismic Category I Piping
 - 3.7B.3.14 Field Location of Supports and Restraints
 - 3.7B.3.15 Seismic Analysis for Fuel Assemblies, Controls, Rods, and CRDs

- 3.7B.4 Seismic Instrumentation Program

TABLE OF CONTENTS (CONTINUED)

- 3.7B.5 Seismic Design Control
 - 3.7B.5.1 Seismic Input Data of Purchase Specification for Seismic Category I Components and Equipment
 - 3.7B.5.2 Program for Auditing Vendor Seismic Analysis and Tests of Seismic Category I Components and Equipment
 - 3.7B.5.3 Equipment Testing and Test Evaluation
 - 3.7B.5.4 Acceptance

- 3.8 Design of Seismic Category I Structures
 - 3.8.1 Concrete Containment
 - 3.8.2 Steel Containment System (American Society of Mechanical Engineers (ASME) Class MC Components)
 - 3.8.2.1 Description of the Containment
 - 3.8.2.2 Applicable Codes, Standards, and Specifications
 - 3.8.2.3 Loads and Loading Combinations
 - 3.8.2.4 Design and Analysis Procedures
 - 3.8.2.5 Structural Acceptance Criteria
 - 3.8.2.6 Design Loading Combination Stress Limits
 - 3.8.2.7 Materials, Quality Control, and Special Construction Techniques
 - 3.8.2.8 Testing and Inservice Surveillance Requirements

 - 3.8.3 Containment Internal Structures
 - 3.8.3.1 Description of Internal Structures
 - 3.8.3.2 Applicable Codes, Standards, and Specifications
 - 3.8.3.3 Loads and Loading Combinations
 - 3.8.3.4 Design and Analysis Procedures
 - 3.8.3.5 Structural Acceptance Criteria
 - 3.8.3.6 Materials, Quality Control, and Special Construction Techniques
 - 3.8.3.7 Testing and Inservice Surveillance Requirements

 - 3.8.4 Other Seismic Category I Structures
 - 3.8.4.1 Description of Structures
 - 3.8.4.2 Applicable Codes, Standards, and Specifications
 - 3.8.4.3 Loads and Loading Combinations
 - 3.8.4.4 Design and Analysis Procedures
 - 3.8.4.5 Structural Acceptance Criteria
 - 3.8.4.6 Materials, Quality Control, and Special Construction Techniques
 - 3.8.4.7 Testing and Inservice Surveillance Requirements

TABLE OF CONTENTS (CONTINUED)

- 3.8.5 Foundations and Concrete Support
 - 3.8.5.1 Description of Foundations and Supports
 - 3.8.5.2 Applicable Codes, Standards, and Specifications
 - 3.8.5.3 Loads and Loading Combinations
 - 3.8.5.4 Design and Analysis Procedures
 - 3.8.5.5 Structural Acceptance Criteria
 - 3.8.5.6 Materials, Quality Control, and Special Construction Techniques
 - 3.8.5.7 Testing and Inservice Surveillance Requirements

- 3.8.6 Responses to United States Nuclear Regulatory Commission (USNRC) Inspection and Enforcement (IE) Bulletins (HNP-1 and HNP-2)
 - 3.8.6.1 Summary of Responses to USNRC IE Bulletin 80-11, "Masonry Wall Design"
 - 3.8.6.2 Summary of Responses to IE Bulletin 79-02, "Pipe Support Base Plate Designs Using Concrete Expansion Anchor Bolts"

- 3.8.7 Seismic Evaluation of Radwaste Facilities Buildings (HNP-1 and HNP-2)
 - 3.8.7.1 Seismic Model
 - 3.8.7.2 Modal Analysis
 - 3.8.7.3 Response Spectrum Technique
 - 3.8.7.4 Time-History Analysis
 - 3.8.7.5 Computer Programs
 - 3.8.7.6 Structural Evaluation
 - 3.8.7.7 Seismic Evaluation of Charcoal Adsorbers (HNP-1 and HNP-2)

SUPPLEMENT 3.8A MECHANICAL SPLICING OF REINFORCING BARS USING THE CADWELD PROCESS

- 3.8A.1 Scope
- 3.8A.2 Process
- 3.8A.3 Qualifications of Operators
- 3.8A.4 Procedure
- 3.8A.5 Onsite User Tests
- 3.8A.6 Joint Acceptance Standards
- 3.8A.7 Repairs

SUPPLEMENT 3.8B PLANT-UNIQUE ANALYSIS OF MARK I CONTAINMENT SYSTEM

- 3.8B.1 Introduction
- 3.8B.2 Plant Unique Analysis Report

TABLE OF CONTENTS (CONTINUED)

- 3.8B.3 Description of LTP Modifications
- 3.8B.4 *Expanded Operating Domain Operation*
- 3.8B.5 *Power Uprate Operation*
- 3.8B.6 Operation During Period of Extended Operation

SUPPLEMENT 3.8C DESIGN CRITERIA FOR REEVALUATION OF CONCRETE MASONRY WALLS

- 3.8C.1 General
 - 3.8C.1.1 Purpose
 - 3.8C.1.2 Scope
- 3.8C.2 Governing Code
- 3.8C.3 Loads and Load Combinations
- 3.8C.4 Design Allowables
- 3.8C.5 Analysis and Design
 - 3.8C.5.1 General
 - 3.8C.5.2 Structural Response of Masonry Walls
 - 3.8C.5.3 Structural Strength of Masonry Walls
- 3.8C.6 Justification of Selected Items in Design Criteria
 - 3.8C.6.1 Purpose
 - 3.8C.6.2 Damping
 - 3.8C.6.3 In-Plane Acceptance Criteria
 - 3.8C.6.4 Out-of-Plane Drift Effect
 - 3.8C.6.5 Allowable Stresses
- 3.8C.7 Computer Reevaluation of Reinforced Concrete Masonry Walls
 - 3.8C.7.1 Introduction
 - 3.8C.7.2 Analytical Procedure
 - 3.8C.7.3 Computer Program

SUPPLEMENT 3.8D DETERMINATION OF EXPANSION ANCHOR BOLT LOADS IN PIPE SUPPORT BASE PLATES

- 3.8D.1 Summary

TABLE OF CONTENTS (CONTINUED)

- 3.8D.2 Method of Analysis for Anchor Bolt Loads
 - 3.8D.2.1 Introduction
 - 3.8D.2.2 Analysis
 - 3.8D.2.3 Assumptions
- 3.8D.3 Four-Bolt Pattern: Moment-and Tension-Loading Cases
- 3.8D.4 Eight-Bolt Pattern: Moment-Loading Case
- 3.8D.5 Six-Bolt Pattern: Moment-Loading Case
- 3.8D.6 Six- and Eight-Bolt Patterns: Tension-Loading Case
 - 3.8D.6.1 Eight-Bolt Patterns: Tension-Loading Case
 - 3.8D.6.2 Six-Bolt Pattern: Tension-Loading Case
 - 3.8D.6.3 Comparison of Results
 - 3.8D.6.4 Tabulated Results
- 3.9 Mechanical Systems and Components
 - 3.9.1 Dynamic System Analysis and Testing
 - 3.9.1.1 Vibration Operational Test Program
 - 3.9.1.2 Dynamic Testing Procedures
 - 3.9.1.3 Dynamic System Analysis Methods for Reactor Internals
 - 3.9.1.4 Correlations of Reactor Internals Vibration Tests With the Analytical Results
 - 3.9.1.5 Analysis Methods Under LOCA Loadings
 - 3.9.1.6 Analytical Methods for ASME Code Class I Components
 - 3.9.1.7 Fatigue Monitoring of ASME Code, Section III Class 1 Piping
 - 3.9.2 ASME Code Class 2 and 3 Components
 - 3.9.2.1 Plant Conditions and Design Loading Combinations
 - 3.9.2.2 Design Loading Combinations
 - 3.9.2.3 Design Stress Limits
 - 3.9.2.4 Analytical and Empirical Methods for Design of Pumps and Valves
 - 3.9.2.5 Design and Installation Criteria, Pressure-Relieving Devices
 - 3.9.2.6 Stress Levels for Seismic Category I Components
 - 3.9.2.7 Field Run Piping Systems
 - 3.9.2.8 Inspection and Testing
 - 3.9.2.9 Computer Programs
 - 3.9.3 Components Not Covered by ASME Code
 - 3.9.3.1 General
 - 3.9.3.2 Fuel Mechanical Design and Analytical Procedures

TABLE OF CONTENTS (CONTINUED)

- 3.9.3.3 Control Rod Drive Operability and Control Rod Insertability Under LOCA and Seismic Loadings
- 3.9.3.4 HPCI and RCIC Turbines
- 3.9.3.5 HVAC Equipment (Safety-Related)
- 3.9.4 Power Upgrades
- 3.10 Seismic Design of Seismic Category I Instrumentation and Electrical Equipment
 - 3.10.1 Seismic Design Criteria
 - 3.10.1.1 General
 - 3.10.1.2 Emergency Power System and Engineered Safety Features Actuation System
 - 3.10.1.3 Compliance With Institute of Electrical and Electronic Engineers (IEEE) Standard 344-1971
 - 3.10.2 Seismic Analysis, Testing Procedures, and Restraint Measures
 - 3.10.2.1 Equipment Other Than NSSS
 - 3.10.2.2 NSSS Equipment
- 3.11 Environmental Design of Mechanical and Electrical Equipment
 - 3.11.1 Equipment Identification
 - 3.11.2 Qualification Tests and Analysis
 - 3.11.2.1 Qualification Tests and Analyses for Equipment Supplied by General Electric
 - 3.11.2.2 Qualification Tests and Analysis for Equipment Not Supplied by General Electric
 - 3.11.3 Qualification Test Results
 - 3.11.3.1 Qualification Test Results for Equipment Supplied by General Electric
 - 3.11.3.2 Qualification Test Results for Equipment Not Supplied by General Electric
 - 3.11.4 Procurement of New Equipment
 - 3.11.5 Loss of Ventilation

TABLE OF CONTENTS (CONTINUED)

CHAPTER 4 REACTOR

4.1 Reactor Summary Description (HNP-1 and HNP-2)

4.1.1 Reactor Pressure Vessel

4.1.2 Reactor Internal Components

4.1.2.1 Reactor Core

4.1.2.2 Shroud

4.1.2.3 Shroud Head and Separators

4.1.2.4 Steam Dryer Assembly

4.1.3 Reactivity Control Systems

4.1.3.1 Operation

4.1.3.2 Description of Control Rods

4.1.3.3 Supplementary Reactivity Control

4.1.4 Analysis Techniques

4.1.4.1 Reactor Internal Components

4.1.4.2 Fuel Rod Thermal Analysis

4.1.4.3 Reactor Systems Dynamics and Nuclear Analysis

4.1.4.4 Neutron Fluence Calculations

4.1.4.5 Thermal-Hydraulic Calculations

4.2 Mechanical Design (HNP-1 and HNP-2)

4.2.1 Fuel System Design

4.2.1.1 General Design Description

4.2.1.2 Design Bases

4.2.1.3 Results of Thermal Mechanical Evaluations

4.2.1.4 Operating and Developmental Experience

4.2.1.5 Inspection, Testing, and Surveillance

4.2.2 Reactor Core Support Structures and Internals Mechanical Design

4.2.2.1 Design Bases

4.2.2.2 Description

4.2.2.3 Safety Evaluation

4.2.2.4 Design Bases Criteria

TABLE OF CONTENTS (CONTINUED)

- 4.2.3 Reactivity Control System
 - 4.2.3.1 Control Rods
 - 4.2.3.2 CRD System
 - 4.2.3.3 Supplementary Reactivity Control
 - 4.2.3.4 SLCS
- 4.3 Nuclear Design (HNP-1 and HNP-2)
 - 4.3.1 Design Bases
 - 4.3.1.1 Safety Design Bases
 - 4.3.2 Description
 - 4.3.2.1 Nuclear Design Description
 - 4.3.2.2 Power Distribution
 - 4.3.2.3 Reactivity Coefficients
 - 4.3.2.4 Control Requirements
 - 4.3.2.5 Control Rod Patterns and Reactivity Worth
 - 4.3.2.6 Criticality of Reactor During Refueling
 - 4.3.2.7 Stability
 - 4.3.2.8 Vessel Irradiation
 - 4.3.3 Analytical Methods
 - 4.3.4 Final Loading Pattern
- 4.4 Thermal and Hydraulic Design (HNP-1 and HNP-2)
 - 4.4.1 Design Bases
 - 4.4.1.1 Safety Design Bases
 - 4.4.1.2 Power Generation Design Bases
 - 4.4.1.3 Requirements for Steady-State Conditions
 - 4.4.1.4 Requirements for Anticipated Operational Occurrences (AOOs)
 - 4.4.1.5 Summary of Design Bases
 - 4.4.2 Description of Thermal-Hydraulic Design of Reactor Core
 - 4.4.2.1 Critical Power Ratio
 - 4.4.2.2 Average Planar Linear Heat Generation Rate (APLHGR)
 - 4.4.2.3 Core Coolant Flow Distribution and Orificing Pattern
 - 4.4.2.4 Void Fraction Distribution
 - 4.4.2.5 Core Pressure Drop and Hydraulic Loads
 - 4.4.2.6 Correlation and Physical Data

TABLE OF CONTENTS (CONTINUED)

- 4.4.2.7 Thermal Effect of AOOs
- 4.4.2.8 Uncertainties in Estimates
- 4.4.2.9 Flux Tilt Considerations
- 4.4.2.10 Thermal-Hydraulic Uncertainties
- 4.4.2.11 Gross Power Tilt Considerations

- 4.4.3 Description of Thermal and Hydraulic Design of Reactor Coolant System
 - 4.4.3.1 Plant Configuration Data
 - 4.4.3.2 Operating Restrictions on Pumps
 - 4.4.3.3 Power-to-Flow Map

- 4.4.4 Evaluation
 - 4.4.4.1 Critical Power
 - 4.4.4.2 Core Hydraulics
 - 4.4.4.3 Influence of Power Distribution
 - 4.4.4.4 Core Thermal Response
 - 4.4.4.5 Analytical Methods

- 4.4.5 Instrumentation Requirements

- 4.5 Control Rod Drive Housing Supports (HNP-1 and HNP-2)
 - 4.5.1 Safety Design Bases
 - 4.5.2 Description
 - 4.5.3 Safety Evaluation
 - 4.5.4 Inspection and Testing

SUPPLEMENT 4A INITIAL CORE (HNP-1 AND HNP-2)

4A.1 General

4A.2 Fuel Configuration

4A.3 Nuclear Design

CHAPTER 5 REACTOR COOLANT SYSTEM AND CONNECTED SYSTEMS

5.1 Summary Description

- 5.1.1 Schematic Flow Diagram
- 5.1.2 Piping and Instrumentation Diagram

TABLE OF CONTENTS (CONTINUED)

- 5.1.3 Elevation Drawing
- 5.2 Integrity of Reactor Coolant Pressure Boundary (RCPB)
 - 5.2.1 Design of RCPB Components
 - 5.2.1.1 Performance Objectives
 - 5.2.1.2 Design Parameters
 - 5.2.1.3 Compliance with 10 CFR 50, Section 50.55a
 - 5.2.1.4 Applicable Code Cases
 - 5.2.1.5 Design Transients
 - 5.2.1.6 Identification of Active Pumps and Valves
 - 5.2.1.7 Design of Active Pumps and Valves
 - 5.2.1.8 Inadvertent Operation of Valves
 - 5.2.1.9 Stress and Pressure Limits
 - 5.2.1.10 Stress Analysis for Structural Adequacy
 - 5.2.1.11 Analysis Method for Faulted Condition
 - 5.2.1.12 Protection Against Environmental Factors
 - 5.2.1.13 Compliance With Code Requirements
 - 5.2.1.14 Stress Analysis for Emergency and Faulted Condition Loadings
 - 5.2.1.15 Stress Levels in Seismic Category I Systems
 - 5.2.1.16 Analytical Methods for Stresses in Pumps and Valves
 - 5.2.1.17 Analytical Methods for Evaluation of Pump Speed and Bearing Integrity
 - 5.2.1.18 Operation of Active Valves Under Transient Loadings
 - 5.2.1.19 Field Run Piping
 - 5.2.2 Overpressurization Protection
 - 5.2.2.1 Location of Pressure Relief Devices
 - 5.2.2.2 Mounting of Pressure Relief Devices
 - 5.2.2.3 Report on Overpressure Protection
 - 5.2.3 General Material Considerations
 - 5.2.3.1 Material Specifications
 - 5.2.3.2 Compatibility With Reactor Coolant
 - 5.2.3.3 Compatibility With External Insulation and Environmental Atmosphere
 - 5.2.3.4 Chemistry of Reactor Coolant
 - 5.2.4 Fracture Toughness (HNP-1 and HNP-2)
 - 5.2.4.1 Compliance With 10 CFR 50, Appendix G, Fracture Toughness Requirements

TABLE OF CONTENTS (CONTINUED)

5.2.4.2	Adjusted Reference Temperature at 54 EFPYs
5.2.4.3	Pressure-Temperature Curves
5.2.4.4	Compliance With 10 CFR 50, Appendix H, Reactor Vessel Material Surveillance Program Requirements
5.2.4.5	Reactor Pressure Vessel Annealing
5.2.5	Austenitic Stainless Steel
5.2.5.1	<i>Cleaning and Contamination Protection Procedures</i>
5.2.5.2	Solution Heat Treatment Requirements
5.2.5.3	<i>Material Inspection Program</i>
5.2.5.4	Unstabilized Austenitic Stainless Steels
5.2.5.5	Avoidance of Sensitization
5.2.5.6	Retesting Unstabilized Austenitic Stainless Steels Exposed to Sensitizing Temperatures
5.2.5.7	Control of Delta Ferrite
5.2.6	Pump Flywheels
5.2.7	Reactor Coolant Pressure Boundary Leak Detection System
5.2.7.1	Design Basis
5.2.7.2	Leak Detection Methods
5.2.7.3	Indication in Main Control Room
5.2.7.4	Limits for Reactor Coolant Leakage
5.2.7.5	Unidentified Leakage
5.2.7.6	Maximum Allowable Total Leakage
5.2.7.7	Differentiation Between Identified and Unidentified Leaks
5.2.7.8	Sensitivity and Operability Tests
5.2.8	Preservice and Inservice Inspection Programs
5.2.8.1	<i>Preservice Inspection Program</i>
5.2.8.2	Inservice Inspection Program
5.3	Thermal-Hydraulic System Design
5.3.1	Analytical Methods and Data
5.3.2	Operating Restrictions on Pumps
5.3.3	Power-To-Flow Operating Map
5.3.4	Temperature-Power Operating Map for Pressurized Water Reactor
5.3.5	Load Following Characteristics
5.3.6	Transient Effects
5.3.7	Thermal and Hydraulic Characteristics Summary Table

TABLE OF CONTENTS (CONTINUED)

- 5.4 Reactor Pressure Vessel and Appurtenances
 - 5.4.1 Protection of Closure Studs
 - 5.4.2 Special Processes for Fabrication and Inspection
 - 5.4.3 Features for Improved Reliability
 - 5.4.4 Quality Assurance Surveillance
 - 5.4.5 Materials and Inspections
 - 5.4.6 Reactor Pressure Vessel Design
 - 5.4.6.1 Safety Design Bases
 - 5.4.6.2 Power Generation Design Basis
 - 5.4.6.3 Description
 - 5.4.6.4 Safety Evaluation
 - 5.4.7 Reactor Pressure Vessel Schematic
- 5.5 Component and Subsystem Design
 - 5.5.1 RRS and Pumps
 - 5.5.1.1 Safety Design Bases
 - 5.5.1.2 Power Generation Design Bases
 - 5.5.1.3 System Description
 - 5.5.1.4 Safety Evaluation
 - 5.5.1.5 Tests and Inspections
 - 5.5.2 Steam Generators
 - 5.5.3 Reactor Coolant Piping
 - 5.5.4 Main Steam Line Flow Restrictors
 - 5.5.4.1 Safety Design Bases
 - 5.5.4.2 Description
 - 5.5.4.3 Safety Evaluation
 - 5.5.4.4 Tests and Inspections
 - 5.5.5 Main Steam Line Isolation Valves
 - 5.5.5.1 Safety Design Basis
 - 5.5.5.2 Description
 - 5.5.5.3 Safety Evaluation
 - 5.5.5.4 Tests and Inspections
 - 5.5.6 RCIC System
 - 5.5.6.1 Safety Design Bases

TABLE OF CONTENTS (CONTINUED)

5.5.6.2	Power Generation Design Bases
5.5.6.3	System Description
5.5.6.4	Safety Evaluation
5.5.6.5	Tests and Inspections
5.5.7	RHR System
5.5.7.1	Safety Design Basis
5.5.7.2	Power Generation Design Bases
5.5.7.3	System Description
5.5.7.4	Safety Evaluation
5.5.7.5	Tests and Inspections
5.5.8	RWC System
5.5.8.1	Design Basis
5.5.8.2	System Description
5.5.8.3	Safety Evaluation
5.5.8.4	Tests and Inspections
5.5.9	Main Steam Lines and Feedwater Piping
5.5.9.1	Design Bases
5.5.9.2	Description
5.5.9.3	Safety Evaluation
5.5.9.4	Tests and Inspections
5.5.10	Pressurizer
5.5.11	Pressurizer Relief Tank
5.5.12	Valves
5.5.12.1	Design Bases
5.5.12.2	Description
5.5.12.3	Safety Evaluation
5.5.12.4	Tests and Inspections
5.5.12.5	Motor-Operated Valves Performance Testing
5.5.13	Safety and Relief Valves
5.5.13.1	Safety Design Bases
5.5.13.2	Description
5.5.13.3	Safety Evaluation

TABLE OF CONTENTS (CONTINUED)

- 5.5.14 Component Supports
 - 5.5.14.1 Design Bases
 - 5.5.14.2 Description
 - 5.5.14.3 Safety Evaluation
 - 5.5.14.4 Tests and Inspections
- 5.5.15 Other Systems With Components Within RCPB
- 5.5.16 Recirculation Pump Trip System
 - 5.5.16.1 Safety Design Bases
 - 5.5.16.2 System Description
 - 5.5.16.3 Safety Evaluation
 - 5.5.16.4 Tests and Inspections
- 5.5.17 Low-Low Set Relief Logic System
 - 5.5.17.1 Design Bases
 - 5.5.17.2 System Description
 - 5.5.17.3 Safety Evaluation
 - 5.5.17.4 Tests and Inspections
- 5.6 Instrumentation Requirements
 - 5.6.1 Neutron Monitoring System
 - 5.6.2 Reactor Pressure Vessel (RPV) Instrumentation
 - 5.6.2.1 RPV Temperature
 - 5.6.2.2 RPV Water Level
 - 5.6.2.3 RPV Coolant Flowrates and Differential Pressures
 - 5.6.2.4 RPV Internal Pressure
 - 5.6.2.5 RPV Top Head Flange Leak Detection

*SUPPLEMENT 5A SUMMARY TECHNICAL REPORT OF REACTOR VESSEL
OVERPRESSURE PROTECTION (HNP-1 AND HNP-2)*

5A.1 Introduction

5A.2 Design Basis

5A.2.1 Safety Relief Valve Sizing

5A.2.2 Availability Index

5A.3 Method of Analysis

TABLE OF CONTENTS (CONTINUED)

5A.4 *System Design*

- 5A.4.1 *Operating Conditions*
- 5A.4.2 *Transients*
- 5A.4.3 *Scram*
- 5A.4.4 *Safety Relief Valve Transient Analysis Specifications*
- 5A.4.5 *Safety Relief Valve Sizing*
- 5A.4.6 *Availability Index (I_A)*

5A.5 *Evaluation of Results*

- 5A.5.1 *Safety Relief Valve Sizing*
- 5A.5.2 *Availability Index (I_A)*

5A.6 *Safety Relief Valve Characteristics*

- 5A.6.1 *Schematic Arrangement*
- 5A.6.2 *Pressure Drop in Inlet and Discharge*
- 5A.6.3 *Safety Relief Valve Description*

5A.7 *Conclusion*

CHAPTER 6 ENGINEERED SAFETY FEATURES

6.1 General

6.2 Containment Systems

6.2.1 Containment Functional Design

- 6.2.1.1 Safety Design Bases
- 6.2.1.2 System Description
- 6.2.1.3 Instrumentation Application
- 6.2.1.4 Tests and Inspections
- 6.2.1.5 Materials

6.2.2 Containment Heat Removal System

- 6.2.2.1 Safety Design Bases
- 6.2.2.2 System Description
- 6.2.2.3 Instrumentation Application
- 6.2.2.4 Safety Evaluation
- 6.2.2.5 Tests and Inspections
- 6.2.2.6 Materials

TABLE OF CONTENTS (CONTINUED)

- 6.2.3 Safety Evaluation for Containment Functional Design (HNP-1 and HNP-2)
 - 6.2.3.1 Containment LOCA Analysis
- 6.2.4 Standby Gas Treatment System
 - 6.2.4.1 Design Bases
 - 6.2.4.2 System Description
 - 6.2.4.3 Instrumentation Application
 - 6.2.4.4 Safety Evaluation
 - 6.2.4.5 Tests and Inspections
- 6.2.5 Containment Isolation System
 - 6.2.5.1 Safety Design Bases
 - 6.2.5.2 System Description
 - 6.2.5.3 Safety Evaluation
 - 6.2.5.4 Tests and Inspections
 - 6.2.5.5 Materials
 - 6.2.5.6 Control of Combustible Gas Concentrations in Containment Following a LOCA (HNP-1 and HNP-2)
- 6.3 Emergency Core Cooling System (ECCS)
 - 6.3.1 Safety Design Bases
 - 6.3.1.1 Range of Coolant Ruptures and Leaks
 - 6.3.1.2 Fission Product Decay Heat
 - 6.3.1.3 Reactivity Required for Cold Shutdown
 - 6.3.1.4 Capability to Meet Functional Requirements
 - 6.3.2 System Description
 - 6.3.2.1 Schematic Piping and Instrumentation Diagrams
 - 6.3.2.2 Equipment and Component Descriptions
 - 6.3.2.3 Applicable Codes and Classification
 - 6.3.2.4 Materials Specifications and Compatibility
 - 6.3.2.5 Design Pressures and Temperatures
 - 6.3.2.6 Coolant Quantity and Quality
 - 6.3.2.7 Pump Characteristics
 - 6.3.2.8 Heat Exchanger Characteristics
 - 6.3.2.9 ECCS Pump Suction Strainers
 - 6.3.2.10 ECCS Flow Diagrams
 - 6.3.2.11 Relief Valves and Vents

TABLE OF CONTENTS (CONTINUED)

- 6.3.2.12 System Reliability
- 6.3.2.13 Protection Provisions
- 6.3.2.14 MOVs and Controls
- 6.3.2.15 Materials
- 6.3.2.16 Instrumentation Requirements (HNP-1 and HNP-2)
- 6.3.2.17 Tests and Inspections (HNP-1 and HNP-2)
- 6.3.3 Performance Evaluation (HNP-1 and HNP-2)
 - 6.3.3.1 Acceptance Criteria for ECCS Performance
 - 6.3.3.2 Conclusions
 - 6.3.3.3 Single-Failure Considerations
 - 6.3.3.4 LOCA Analysis Procedures and Input Variables
 - 6.3.3.5 Break Spectrum Calculations
 - 6.3.3.6 Alternate Operating Modes
 - 6.3.3.7 LOCA Analysis Peak-Cladding Temperatures
 - 6.3.3.8 ECCS Suction Line Analysis (HNP-1 and HNP-2)
 - 6.3.3.9 Net Positive Suction Head Analysis (HNP-1 and HNP-2)
 - 6.3.3.10 ECCS Pump Suction Strainers Analysis (HNP-1 and HNP-2)
- 6.4 Habitability Systems (HNP-1 and HNP-2)
 - 6.4.1 Habitability Systems Functional Design
 - 6.4.1.1 Safety Design Bases
 - 6.4.1.2 System Description
 - 6.4.1.3 Instrumentation Application
 - 6.4.1.4 Safety Evaluation
 - 6.4.1.5 Tests and Inspections

SUPPLEMENT 6A SUBCOMPARTMENT PRESSURIZATION STRUCTURAL ANALYSIS

6A.1 Introduction

6A.2 Analysis

- 6A.2.1 Computer Code
- 6A.2.2 Dynamic Model
- 6A.2.3 Load Inputs
 - 6A.2.3.1 Asymmetrical Pressure Loads
 - 6A.2.3.2 Jet Reaction Load on RPV
 - 6A.2.3.3 Pipe Whip Restraint Load

TABLE OF CONTENTS (CONTINUED)

- 6A.2.3.4 Jet Impingement Loads
- 6A.2.3.5 Acoustic Load
- 6A.2.4 Static Analysis
- 6A.3 Results
 - 6A.3.1 Recirculation Outlet Line Break
 - 6A.3.2 Feedwater Line
 - 6A.3.3 Summary of Results
- 6A.4 Subcompartment Pressurization Analysis Within Sacrificial Shield Annulus and Drywell Area
 - 6A.4.1 Sacrificial Shield Annulus and Drywell Head Areas
 - 6A.4.2 Nodalization Sensitivity Studies
 - 6A.4.3 Drywell Area

CHAPTER 7 INSTRUMENTATION AND CONTROL

- 7.1 Introduction
 - 7.1.1 Identification and Classification of Safety-Related and Power Generation Systems
 - 7.1.1.1 Safety-Related Systems
 - 7.1.1.2 Power Generation Systems
 - 7.1.2 Identification of Safety and Power Generation Criteria
 - 7.1.2.1 Design Bases
 - 7.1.2.2 Independence of Redundant Safety-Related Systems
 - 7.1.2.3 Physical Identification of Safety-Related Equipment
 - 7.1.2.4 Conformance to IEEE 317-1972
 - 7.1.2.5 Conformance to IEEE 323-1971
 - 7.1.2.6 Conformance to IEEE 336-1971
 - 7.1.2.7 Conformance to IEEE 338-1971
 - 7.1.2.8 Conformance to IEEE 344-1971
 - 7.1.2.9 Conformance to IEEE 379-1972
 - 7.1.2.10 Conformance to Regulatory Guide 1.22
 - 7.1.2.11 Conformance to Regulatory Guide 1.47
 - 7.1.2.12 Conformance to Regulatory Guide 1.53
 - 7.1.2.13 Conformance to Regulatory Guide 1.62

TABLE OF CONTENTS (CONTINUED)

- 7.2 Reactor Protection System (RPS)
 - 7.2.1 Design Bases
 - 7.2.1.1 General Functional Requirements
 - 7.2.1.2 Regulatory Requirements
 - 7.2.2 Description
 - 7.2.2.1 System Identification and Classification
 - 7.2.2.2 Initiating Circuits
 - 7.2.2.3 Logic
 - 7.2.2.4 Bypasses and Interlocks
 - 7.2.2.5 Actuated Devices
 - 7.2.2.6 Redundancy, Diversity, and Separation
 - 7.2.2.7 Power Supply
 - 7.2.2.8 Testability
 - 7.2.2.9 Environmental Considerations
 - 7.2.2.10 Operational Considerations
 - 7.2.3 Analysis
 - 7.2.3.1 General
 - 7.2.3.2 Conformance With Functional Requirements
 - 7.2.3.3 Conformance to Specific Regulatory Requirements
- 7.3 Engineered Safety Feature Systems
 - 7.3.1 Emergency Core Cooling System
 - 7.3.1.1 Design Bases
 - 7.3.1.2 System Descriptions
 - 7.3.1.3 Analysis of the Emergency Core Cooling System
 - 7.3.2 Primary Containment and RPV Isolation Control System
 - 7.3.2.1 Design Basis
 - 7.3.2.2 System Description
 - 7.3.2.3 Analysis
 - 7.3.3 (Deleted)
 - 7.3.4 (Deleted)

TABLE OF CONTENTS (CONTINUED)

- 7.3.5 Main Control Room Environmental Control System
 - 7.3.5.1 Design Bases
 - 7.3.5.2 System Description
 - 7.3.5.3 Analysis
- 7.3.6 Standby Gas Treatment System
 - 7.3.6.1 Design Bases
 - 7.3.6.2 System Description
 - 7.3.6.3 Analysis
- 7.4 Systems Required for Safe Shutdown
 - 7.4.1 Reactor Core Isolation Cooling (RCIC) System
 - 7.4.1.1 Design Bases
 - 7.4.1.2 System Description
 - 7.4.1.3 Analysis
 - 7.4.2 Standby Liquid Control System (SLCS)
 - 7.4.2.1 Design Bases
 - 7.4.2.2 System Description
 - 7.4.2.3 Analysis
 - 7.4.3 Reactor Shutdown Cooling System
 - 7.4.3.1 Design Bases
 - 7.4.3.2 System Description
 - 7.4.3.3 Analysis
 - 7.4.4 Low-Low Set Relief Logic System
 - 7.4.4.1 Design Bases
 - 7.4.4.2 System Description
 - 7.4.4.3 Analysis
 - 7.4.5 Residual Heat Removal Service Water (RHRSW) System
 - 7.4.5.1 Design Bases
 - 7.4.5.2 System Description
 - 7.4.5.3 Analysis

TABLE OF CONTENTS (CONTINUED)

- 7.5 Safety-Related and Power Generation Display Instrumentation
 - 7.5.1 Description
 - 7.5.1.1 Normal Operation
 - 7.5.1.2 Anticipated Operational Occurrences (AOOs)
 - 7.5.1.3 Accidents
 - 7.5.1.4 Special Event – MCR Uninhabitability
 - 7.5.2 Analysis
 - 7.5.2.1 Normal Operation
 - 7.5.2.2 AOOs
 - 7.5.2.3 Accidents
 - 7.5.2.4 Special Event – Shutdown from Outside the MCR
 - 7.5.3 Information Systems Important to Safety (HNP-1 and HNP-2)
 - 7.5.3.1 Introduction
 - 7.5.3.2 Description of Information Systems
 - 7.5.3.3 Variable Types
 - 7.5.3.4 Variable Categories
 - 7.5.3.5 Description of Variables
- 7.6 Other Systems Required for Safety and Power Generation
 - 7.6.1 Refueling Interlocks
 - 7.6.1.1 Design Bases
 - 7.6.1.2 System Description
 - 7.6.1.3 Analysis
 - 7.6.2 Neutron Monitoring System (NMS)
 - 7.6.2.1 Design Basis
 - 7.6.2.2 System Description
 - 7.6.2.3 Analysis
 - 7.6.3 Essential Process Radiation Monitors
 - 7.6.3.1 Main Steam Line Radiation Monitor
 - 7.6.3.2 Reactor Building Ventilation Exhaust Radiation Monitoring System
 - 7.6.3.3 Refueling Floor Ventilation Exhaust Radiation Monitoring System

TABLE OF CONTENTS (CONTINUED)

- 7.6.4 Primary Containment Atmosphere Monitors
 - 7.6.4.1 Fission Products Monitor
 - 7.6.4.2 Drywell and Torus Gamma Radiation Monitor
 - 7.6.4.3 Hydrogen/Oxygen Analyzer
 - 7.6.4.4 Primary Containment Temperature Monitors
 - 7.6.4.5 Primary Containment Pressure Monitor
 - 7.6.4.6 Torus Water Level Indicator System
- 7.6.5 (Deleted)
- 7.6.6 Reactor Water Cleanup System
 - 7.6.6.1 Design Basis
 - 7.6.6.2 System Description
 - 7.6.6.3 Analysis
- 7.6.7 RPV Power Generation Instrumentation
 - 7.6.7.1 Design Basis
 - 7.6.7.2 System Description
 - 7.6.7.3 Analysis
- 7.6.8 Process Computer System (HNP-1 and HNP-2)
 - 7.6.8.1 Power Generation Objective
 - 7.6.8.2 Power Generation Design Bases
 - 7.6.8.3 System Description
 - 7.6.8.4 Analysis
- 7.6.9 Leak Detection System
 - 7.6.9.1 Design Bases
 - 7.6.9.2 System Description
 - 7.6.9.3 Analysis
- 7.6.10 Recirculation Pump Trip (HNP-1 and HNP-2)
 - 7.6.10.1 System Identification
 - 7.6.10.2 Power Sources
 - 7.6.10.3 Equipment Design
 - 7.6.10.4 Environmental Considerations
 - 7.6.10.5 Operational Considerations
 - 7.6.10.6 Specific Regulatory Requirement Conformance
 - 7.6.10.7 ATWS-RPT

TABLE OF CONTENTS (CONTINUED)

- 7.6.11 Post-Accident Sampling System (PASS)
 - 7.6.11.1 Design Bases
 - 7.6.11.2 System Description
 - 7.6.11.3 Analysis
 - 7.6.11.4 Safety Evaluation
- 7.6.12 Plant Service Water System
 - 7.6.12.1 Design Bases
 - 7.6.12.2 System Description
 - 7.6.12.3 Analysis
- 7.7 Control Systems Not Required for Safety
 - 7.7.1 Reactor Manual Control System
 - 7.7.1.1 Design Basis
 - 7.7.1.2 System Description
 - 7.7.1.3 Analysis
 - 7.7.2 Recirculation Flow Control System
 - 7.7.2.1 Design Basis
 - 7.7.2.2 System Description
 - 7.7.2.3 Analysis
 - 7.7.3 Feedwater Control System
 - 7.7.3.1 Design Basis
 - 7.7.3.2 System Description
 - 7.7.3.3 Analysis
 - 7.7.4 Pressure Regulator and Turbine-Generator Control System
 - 7.7.4.1 Design Bases
 - 7.7.4.2 System Description
 - 7.7.4.3 Analysis
- 7.8 Analog Transmitter Trip System (ATTS)
 - 7.8.1 Design Bases
 - 7.8.1.1 Design Features

TABLE OF CONTENTS (CONTINUED)

- 7.8.2 System Description
 - 7.8.2.1 General
 - 7.8.2.2 Equipment Description and Design
 - 7.8.2.3 Power Sources
 - 7.8.2.4 Initiating Circuits
 - 7.8.2.5 Logic and Sequencing
 - 7.8.2.6 Bypasses, Interlocks, and Alarms
 - 7.8.2.7 Redundancy, Diversity, and Separation
 - 7.8.2.8 Actuated Devices
 - 7.8.2.9 Testability
 - 7.8.2.10 Environmental Considerations
 - 7.8.2.11 Operational Considerations
- 7.8.3 Analysis
 - 7.8.3.1 Conformance to General Functional Requirements
 - 7.8.3.2 Conformance to Specific Regulatory Requirements
- 7.9 Safety Parameter Display System/Emergency Response Data System/NRC Emergency Response Data System (HNP-1 and HNP-2)
 - 7.9.1 Design Considerations
 - 7.9.2 System Description
 - 7.9.2.1 SPDS/ERDS Hardware
 - 7.9.2.2 Technical Support Center Data System
 - 7.9.2.3 Emergency Operations Facility Data System
 - 7.9.3 NRC Emergency Response Data System (ERDS)
 - 7.9.3.1 System Description
 - 7.9.3.2 NRC ERDS Data Point Library
 - 7.9.3.3 NRC ERDS Communications
- 7.10 Rod Worth Minimizer (RWM) (HNP-1 and HNP-2)
 - 7.10.1 Description
 - 7.10.2 Design Objective
 - 7.10.3 Related Systems
 - 7.10.4 RWM Operation
 - 7.10.5 NUMAC-RWM Functions

TABLE OF CONTENTS (CONTINUED)

CHAPTER 8 ELECTRIC POWER

8.1 Introduction

- 8.1.1 Utility Grid Description
- 8.1.2 Sources of Power for Auxiliary Systems
- 8.1.3 Safety- and Nonsafety-Related Loads
- 8.1.4 Design Bases

8.2 Offsite Power System

- 8.2.1 System Description (HNP-1 and HNP-2)
- 8.2.2 Analysis
 - 8.2.2.1 Electrical Power Systems
 - 8.2.2.2 Inspection and Testing of Electrical Power Systems
 - 8.2.2.3 Analysis of Grid Power Supply

8.3 Onsite Power System

- 8.3.1 The ac Power System
 - 8.3.1.1 Description
 - 8.3.1.2 Analysis of ac Systems
 - 8.3.1.3 Conformance With Quality Assurance Standards
 - 8.3.1.4 Independence of Redundant Systems
 - 8.3.1.5 Physical Identification of Safety-Related Equipment
- 8.3.2 The dc Power System
 - 8.3.2.1 Description
 - 8.3.2.2 Analysis of dc Systems
 - 8.3.2.3 Conformance with Appropriate QA Standards
 - 8.3.2.4 Independence of Redundant Systems
 - 8.3.2.5 Physical Identification of Safety-Related Equipment

8.4 Station Blackout (SBO) (HNP-1 and HNP-2)

- 8.4.1 Introduction
- 8.4.2 SBO Coping Evaluation
 - 8.4.2.1 SBO Coping Duration
 - 8.4.2.2 SBO Coping Analysis Assumptions
 - 8.4.2.3 SBO Coping Capabilities

TABLE OF CONTENTS (CONTINUED)

CHAPTER 9 AUXILIARY SYSTEMS

9.1 Fuel Storage and Handling

9.1.1 New-Fuel Storage (HNP-1 and HNP-2)

- 9.1.1.1 Design Bases
- 9.1.1.2 Description
- 9.1.1.3 Safety Evaluation
- 9.1.1.4 Tests and Inspections

9.1.2 Wet Spent-Fuel Storage (HNP-1 and HNP-2)

- 9.1.2.1 Design Bases
- 9.1.2.2 Description
- 9.1.2.3 Safety Evaluation
- 9.1.2.4 Tests and Inspections

9.1.3 Fuel Pool Cooling and Cleanup System (HNP-1 and HNP-2)

- 9.1.3.1 Design Bases
- 9.1.3.2 System Description
- 9.1.3.3 Instrumentation Application
- 9.1.3.4 Safety Evaluation
- 9.1.3.5 Tests and Inspections

9.1.4 Fuel-Handling System

- 9.1.4.1 Reactor Building Crane
- 9.1.4.2 Fuel-Servicing Equipment and Servicing Aids
- 9.1.4.3 Fuel-Handling System
- 9.1.4.4 Refueling Procedure

9.1.5 Dry Spent-Fuel Storage (HNP-1 and HNP-2)

- 9.1.5.1 Spent-Fuel Cask
- 9.1.5.2 Spent-Fuel Cask Lift Yoke
- 9.1.5.3 Spent-Fuel Cask Handling

9.2 Water Systems

9.2.1 Plant Service Water (PSW) System

- 9.2.1.1 Design Bases
- 9.2.1.2 System Description

TABLE OF CONTENTS (CONTINUED)

- 9.2.1.3 Instrumentation Application
- 9.2.1.4 Safety Evaluation
- 9.2.1.5 Tests and Inspections

- 9.2.2 Reactor Building Closed Cooling Water (RBCCW) System
 - 9.2.2.1 Design Bases
 - 9.2.2.2 System Description
 - 9.2.2.3 Safety Evaluation
 - 9.2.2.4 Tests and Inspections

- 9.2.3 Makeup Demineralized Water System (HNP-1 and HNP-2)
 - 9.2.3.1 Design Bases
 - 9.2.3.2 System Description
 - 9.2.3.3 Instrumentation Application
 - 9.2.3.4 Safety Evaluation
 - 9.2.3.5 Tests and Inspections

- 9.2.4 Potable and Sanitary Water System (HNP-1 and HNP-2)
 - 9.2.4.1 Design Basis
 - 9.2.4.2 System Description
 - 9.2.4.3 Instrumentation Application
 - 9.2.4.4 Safety Evaluation
 - 9.2.4.5 Tests and Inspections

- 9.2.5 Ultimate Heat Sink
 - 9.2.5.1 Design Bases
 - 9.2.5.2 System Description
 - 9.2.5.3 Instrumentation Application
 - 9.2.5.4 Safety Evaluation
 - 9.2.5.5 Tests and Inspections

- 9.2.6 Condensate Storage and Transfer System
 - 9.2.6.1 Design Bases
 - 9.2.6.2 System Description
 - 9.2.6.3 Safety Evaluation
 - 9.2.6.4 Tests and Inspections

TABLE OF CONTENTS (CONTINUED)

- 9.2.7 Residual Heat Removal Service Water (RHRSW) System
 - 9.2.7.1 Design Bases
 - 9.2.7.2 System Description
 - 9.2.7.3 Instrumentation Application
 - 9.2.7.4 Safety Evaluation
 - 9.2.7.5 Tests and Inspections
- 9.3 Process Auxiliaries
 - 9.3.1 Compressed Air Systems
 - 9.3.1.1 Design Bases
 - 9.3.1.2 System Description
 - 9.3.1.3 Instrumentation Application
 - 9.3.1.4 Safety Evaluation
 - 9.3.1.5 Tests and Inspections
 - 9.3.2 Process Sampling System
 - 9.3.2.1 Design Bases
 - 9.3.2.2 System Description
 - 9.3.2.3 Instrumentation Application
 - 9.3.2.4 Safety Evaluation
 - 9.3.2.5 Tests and Inspections
 - 9.3.3 Equipment and Floor Drainage System
 - 9.3.3.1 Design Bases
 - 9.3.3.2 System Description
 - 9.3.3.3 Instrumentation Application
 - 9.3.3.4 System Evaluation
 - 9.3.3.5 Tests and Inspections
 - 9.3.4 Chemical, Volume Control, and Liquid Poison Systems
 - 9.3.5 Failed Fuel Detection System
 - 9.3.6 Drywell Pneumatic System
 - 9.3.6.1 Power Generation Design Bases
 - 9.3.6.2 Safety Design Bases
 - 9.3.6.3 System Description
 - 9.3.6.4 Instrumentation Application
 - 9.3.6.5 Safety Evaluation
 - 9.3.6.6 Tests and Inspections

TABLE OF CONTENTS (CONTINUED)

- 9.3.7 Torus Drainage and Purification System
 - 9.3.7.1 Design Bases
 - 9.3.7.2 System Description
 - 9.3.7.3 Instrumentation Application
 - 9.3.7.4 Safety Evaluation
 - 9.3.7.5 Tests and Inspections

- 9.3.8 Auxiliary Steam (HNP-1 and HNP-2)
 - 9.3.8.1 Design Bases
 - 9.3.8.2 System Description
 - 9.3.8.3 Instrumentation Application
 - 9.3.8.4 Safety Evaluation
 - 9.3.8.5 Tests and Inspections

- 9.4 Air-Conditioning, Heating, Cooling, and Ventilation Systems
 - 9.4.1 Main Control Room (HNP-1 and HNP-2)
 - 9.4.1.1 Design Bases
 - 9.4.1.2 System Description
 - 9.4.1.3 Safety Evaluation
 - 9.4.1.4 Tests and Inspections

 - 9.4.2 Reactor Building
 - 9.4.2.1 Design Bases
 - 9.4.2.2 System Description
 - 9.4.2.3 Safety Evaluation
 - 9.4.2.4 Tests and Inspections

 - 9.4.3 Radwaste Building
 - 9.4.3.1 Design Bases
 - 9.4.3.2 System Description
 - 9.4.3.3 Safety Evaluation
 - 9.4.3.4 Tests and Inspections

 - 9.4.4 Turbine Building
 - 9.4.4.1 Design Bases
 - 9.4.4.2 System Description
 - 9.4.4.3 Safety Evaluation
 - 9.4.4.4 Tests and Inspections

TABLE OF CONTENTS (CONTINUED)

- 9.4.5 Diesel Generator Building
 - 9.4.5.1 Design Bases
 - 9.4.5.2 System Description
 - 9.4.5.3 Safety Evaluation
 - 9.4.5.4 Tests and Inspections
- 9.4.6 Primary Containment (Drywell) Cooling
 - 9.4.6.1 Design Bases
 - 9.4.6.2 System Description
 - 9.4.6.3 Safety Evaluation
 - 9.4.6.4 Tests and Inspections
- 9.4.7 Control Building
 - 9.4.7.1 Design Bases
 - 9.4.7.2 System Description
 - 9.4.7.3 Safety Evaluation
 - 9.4.7.4 Tests and Inspections
- 9.4.8 Waste Gas Treatment Building
 - 9.4.8.1 Design Bases
 - 9.4.8.2 System Description
 - 9.4.8.3 Safety Evaluation
 - 9.4.8.4 Tests and Inspections
- 9.4.9 Technical Support Center
 - 9.4.9.1 Design Basis
 - 9.4.9.2 System Description
 - 9.4.9.3 Safety Evaluation
 - 9.4.9.4 Tests and Inspections
- 9.4.10 River Intake Structure (HNP-1 and HNP-2)
 - 9.4.10.1 Design Bases
 - 9.4.10.2 System Description
 - 9.4.10.3 Safety Evaluation
- 9.5 Other Auxiliary Systems
 - 9.5.1 Fire Protection System

TABLE OF CONTENTS (CONTINUED)

9.5.2	Plant Communication System (HNP-1 and HNP-2)
9.5.2.1	Safety Objective
9.5.2.2	Safety Design Basis
9.5.2.3	Description
9.5.2.4	Safety Evaluation
9.5.2.5	Inspection and Tests
9.5.3	Plant Lighting System (HNP-1 and HNP-2)
9.5.3.1	Safety Objective
9.5.3.2	Safety Design Basis
9.5.3.3	Description
9.5.3.4	Safety Evaluation
9.5.3.5	Inspection and Tests
9.5.4	Diesel Generator Fuel Oil Storage and Transfer System
9.5.4.1	Safety Design Bases
9.5.4.2	System Description
9.5.4.3	Instrumentation Application
9.5.4.4	Safety Evaluation
9.5.4.5	Tests and Inspections
9.5.5	Diesel Generator Cooling Water System
9.5.5.1	Safety Design Bases
9.5.5.2	System Description
9.5.5.3	Instrumentation Application
9.5.5.4	Safety Evaluation
9.5.5.5	Tests and Inspections
9.5.6	Diesel Generator Starting System
9.5.6.1	Safety Design Bases
9.5.6.2	System Description
9.5.6.3	Instrumentation Application
9.5.6.4	Safety Evaluation
9.5.6.5	Tests and Inspections
9.5.7	Diesel Generator Lubrication System
9.5.7.1	Safety Design Bases
9.5.7.2	System Description

TABLE OF CONTENTS (CONTINUED)

- 9.5.7.3 Instrumentation Application
- 9.5.7.4 Safety Evaluation
- 9.5.7.5 Tests and Inspections

- 9.5.8 Turbine Building Crane
 - 9.5.8.1 Design Bases
 - 9.5.8.2 Description
 - 9.5.8.3 Safety Evaluation
 - 9.5.8.4 Tests and Inspections

- 9.5.9 GEZIP Passive Zinc Injection System
- 9.5.10 Main Steam Isolation Valve Leakage Treatment System

CHAPTER 10 STEAM AND POWER CONVERSION SYSTEMS

10.1 Summary Description

10.2 Turbine-Generator

- 10.2.1 Design Bases and Objective
- 10.2.2 System Description
- 10.2.3 Turbine Missiles
 - 10.2.3.1 Turbine-Missile Analysis and Evaluation
 - 10.2.3.2 Turbine Wheel Cracks and Missile Prevention

- 10.2.4 Safety Evaluation

SUPPLEMENT 10.2A GENERAL ELECTRIC TURBINE OVERSPEED PROTECTION

- 10.2A.1 Introduction
- 10.2A.2 Overspeed Protection
- 10.2A.3 Emergency Trip System
- 10.2A.4 (Deleted)
- 10.2A.5 (Deleted)
- 10.2A.6 Turbine Steam Valves
- 10.2A.7 Hydraulic Power Supply
- 10.2A.8 (Deleted)

- 10.3 Main Steam Supply System
 - 10.3.1 Design Bases

TABLE OF CONTENTS (CONTINUED)

- 10.3.2 Description
- 10.3.3 Safety Evaluation
- 10.3.4 Inspection and Testing
- 10.3.5 Water Chemistry (Pressurized Water Reactor)

- 10.4 Other Features of the Steam and Power Conversion System
 - 10.4.1 Main Condenser
 - 10.4.1.1 Design Bases
 - 10.4.1.2 System Description
 - 10.4.1.3 Safety Evaluation
 - 10.4.1.4 Tests and Inspections*
 - 10.4.1.5 Instrumentation Application

 - 10.4.2 Main Condenser Evacuation System
 - 10.4.2.1 Design Bases
 - 10.4.2.2 System Description
 - 10.4.2.3 Safety Evaluation
 - 10.4.2.4 Tests and Inspections*
 - 10.4.2.5 Instrumentation Application

 - 10.4.3 Turbine Gland-Sealing System
 - 10.4.3.1 Design Bases
 - 10.4.3.2 System Description
 - 10.4.3.3 Safety Evaluation
 - 10.4.3.4 Tests and Inspections*
 - 10.4.3.5 Instrumentation Application

 - 10.4.4 Turbine Bypass System
 - 10.4.4.1 Design Bases
 - 10.4.4.2 System Description
 - 10.4.4.3 Safety Evaluation
 - 10.4.4.4 Tests and Inspections*
 - 10.4.4.5 Instrumentation Application

 - 10.4.5 Circulating Water System (HNP-1 and HNP-2)
 - 10.4.5.1 Design Bases
 - 10.4.5.2 System Description
 - 10.4.5.3 Safety Evaluation
 - 10.4.5.4 Tests and Inspections

TABLE OF CONTENTS (CONTINUED)

- 10.4.5.5 Instrumentation Application
- 10.4.6 Condensate Polishing Demineralizer System
 - 10.4.6.1 Design Bases
 - 10.4.6.2 System Description
 - 10.4.6.3 Safety Evaluation
 - 10.4.6.4 Tests and Inspections
 - 10.4.6.5 Instrumentation Application
- 10.4.7 Condensate and Feedwater System
 - 10.4.7.1 Design Bases
 - 10.4.7.2 System Description
 - 10.4.7.3 Feedwater Controls
 - 10.4.7.4 Safety Evaluation
 - 10.4.7.5 Tests and Inspections
 - 10.4.7.6 Instrumentation Application
- 10.4.8 Hydrogen Water Chemistry System (HNP-1 and HNP-2)
 - 10.4.8.1 Power Generation Objective
 - 10.4.8.2 Power Generation Design Basis
 - 10.4.8.3 Description
 - 10.4.8.4 Safety Evaluation
- CHAPTER 11 RADIOACTIVE WASTE MANAGEMENT
 - 11.1 Source Terms
 - 11.1.1 Reactor Coolant and Secondary Side Activity
 - 11.1.1.1 Design Basis Model
 - 11.1.1.2 Realistic Model
 - 11.2 Liquid Radwaste System
 - 11.2.1 Design Bases and Objectives
 - 11.2.2 System Description
 - 11.2.2.1 Liquid Radwaste Subsystems
 - 11.2.2.2 Process Equipment Description
 - 11.2.2.3 Design for Keeping Activity Discharges ALARA

TABLE OF CONTENTS (CONTINUED)

- 11.2.3 Instrumentation Application
 - 11.2.3.1 System Performance Instrumentation
 - 11.2.3.2 Drywell Sumps Control
 - 11.2.3.3 Reactor and Turbine Building Sumps Control
 - 11.2.3.4 Control of Discharge to the Environment
- 11.2.4 Safety Evaluation
 - 11.2.4.1 Normal Operation
 - 11.2.4.2 Accident Analysis
- 11.2.5 Tests and Inspections
- 11.3 Gaseous Effluent Treatment Systems
 - 11.3.1 Design Bases and Objectives
 - 11.3.2 System Descriptions
 - 11.3.2.1 Off-Gas Recombiner Charcoal (RECHAR) System
 - 11.3.2.2 Other Gaseous Effluent Treatment Systems
 - 11.3.3 Instrumentation Application
 - 11.3.3.1 Off-Gas System Performance Instrumentation
 - 11.3.3.2 Off-Gas System Flow Measurements
 - 11.3.3.3 Off-Gas System Radiation Measurements
 - 11.3.4 Safety Evaluation
 - 11.3.4.1 Normal Operation
 - 11.3.4.2 Accident Analysis
 - 11.3.5 Tests and Inspections
- 11.4 Process and Effluent Radiological Monitoring
 - 11.4.1 Design Objectives
 - 11.4.2 Continuous Monitoring
 - 11.4.2.1 General Design Criteria
 - 11.4.2.2 Basis for Detector Location Selection
 - 11.4.2.3 Radiation Levels
 - 11.4.2.4 Quantity Measured
 - 11.4.2.5 Detector Type, Sensitivity, and Range

TABLE OF CONTENTS (CONTINUED)

- 11.4.2.6 Setpoints
- 11.4.2.7 Annunciators and Alarms
- 11.4.2.8 Continuous Monitoring Systems
- 11.4.2.9 Description of Liquid Monitors
- 11.4.3 Sampling
 - 11.4.3.1 Process Sampling
 - 11.4.3.2 Effluent Sampling
 - 11.4.3.3 Analytical Procedures
- 11.4.4 Inspection, Calibration, and Maintenance
 - 11.4.4.1 Inspections and Tests
 - 11.4.4.2 Calibration
 - 11.4.4.3 Maintenance
 - 11.4.4.5 Audits and Verifications
- 11.5 Solid Radwaste System
 - 11.5.1 Design Objectives
 - 11.5.2 System Inputs
 - 11.5.2.1 Wet Solid Waste Inputs
 - 11.5.2.2 Dry Solid Waste Inputs
 - 11.5.2.3 Irradiated Reactor Component Inputs
 - 11.5.2.4 Waste Oil Inputs
 - 11.5.3 Equipment Description
 - 11.5.3.1 Resin Processing Equipment
 - 11.5.3.2 Hydraulic Press
 - 11.5.4 Volumes
 - 11.5.5 Packaging
 - 11.5.6 Storage Facilities
 - 11.5.7 Shipment
- 11.6 Offsite Radiological Environmental Monitoring Program

CHAPTER 12 RADIATION PROTECTION

- 12.1 Assuring Occupational Radiation Exposures Are As Low As Reasonably Achievable

TABLE OF CONTENTS (CONTINUED)

- 12.1.1 Policy Considerations
- 12.1.2 Design Considerations
- 12.1.3 Operational Considerations
 - 12.1.3.1 Operating Procedures
 - 12.1.3.2 Radiation and Contamination Control
- 12.2 Radiation Sources
 - 12.2.1 Contained Sources
 - 12.2.1.1 General
 - 12.2.1.2 Radiation for Reactor Core
 - 12.2.1.3 Activity in Steam and Condensate
 - 12.2.1.4 Activity in Reactor Water Cleanup (RWC) and Condensate Demineralizer Systems
 - 12.2.1.5 Shutdown Sources
 - 12.2.1.6 Spent-Fuel Sources
 - 12.2.1.7 Condensate Storage Tank
 - 12.2.1.8 Miscellaneous Sources
 - 12.2.2 Airborne Radioactive Material Sources
 - 12.2.3 Radiation Sources in Wet Spent-Fuel Storage Area
- 12.3 Radiation Protection Design Features
 - 12.3.1 Facility Design Features
 - 12.3.1.1 Plant Layout and Arrangement
 - 12.3.1.2 Design
 - 12.3.1.3 Radiation Zones and Access Control (HNP-1 and HNP-2)
 - 12.3.2 Shielding
 - 12.3.2.1 Design Objective (HNP-1 and HNP-2)
 - 12.3.2.2 Design Description
 - 12.3.2.3 Plans and Procedures
 - 12.3.2.4 Inspection and Performance Analysis
 - 12.3.3 Ventilation
 - 12.3.3.1 Design Objectives
 - 12.3.3.2 Design Description

TABLE OF CONTENTS (CONTINUED)

- 12.3.4 Area Radiation and Airborne Radioactivity Monitoring Instrumentation
 - 12.3.4.1 Area Radiation Monitoring
 - 12.3.4.2 Airborne Radioactivity Monitoring
- 12.4 Dose Assessment
 - 12.4.1 Estimates of Direct Exposure
 - 12.4.2 Estimates of Exposure Due to Inhalation
 - 12.4.3 Site Boundary and Plant Area Dose Rates
 - 12.4.3.1 Skyshine
 - 12.4.3.2 Off-Gas
 - 12.4.3.3 Yearly Doses
 - 12.4.4 Total Annual Exposure
- 12.5 Health Physics/Chemistry Program
 - 12.5.1 Organization
 - 12.5.2 Equipment, Instrumentation, and Facilities
 - 12.5.2.1 Facilities
 - 12.5.2.2 Respiratory Equipment
 - 12.5.2.3 Protective Clothing
 - 12.5.2.4 Portable Instrumentation
 - 12.5.2.5 Laboratory Equipment
 - 12.5.2.6 Personnel Radiation Monitoring Instrumentation
 - 12.5.2.7 Emergency Instrumentation
 - 12.5.3 Procedures
 - 12.5.3.1 Radiation Surveys
 - 12.5.3.2 Personnel Dosimetry
 - 12.5.3.3 Radiation Work Permits
 - 12.5.3.4 Radiation Protection Training
 - 12.5.3.5 Contamination Control
 - 12.5.3.6 Respiratory Protection
 - 12.5.3.7 Radioactive Material Safety Program (HNP-1 and HNP-2)

CHAPTER 13 CONDUCT OF OPERATIONS

- 13.1 Organizational Structure (HNP-1 and HNP-2)

TABLE OF CONTENTS (CONTINUED)

- 13.1.1 Corporate Organization
 - 13.1.1.1 Corporate Functions, Responsibilities, and Authorities
 - 13.1.1.2 Corporate Management and Technical Support
 - 13.1.1.3 Interrelationships with Contractors and Suppliers
 - 13.1.1.4 Nuclear Operations Organization
 - 13.1.1.5 Qualifications
- 13.1.2 Operating Organization
 - 13.1.2.1 Plant Organization
 - 13.1.2.2 Personnel Functions, Responsibilities, and Authorities
 - 13.1.2.3 Shift Crew Composition
- 13.1.3 Qualification Requirements for Nuclear Plant Personnel
 - 13.1.3.1 Minimum Qualification Requirements
- 13.2 Training Program (HNP-1 and HNP-2)
 - 13.2.1 Program Description
 - 13.2.1.1 Program Content
 - 13.2.1.2 Licensed Plant Personnel Training and Retraining
 - 13.2.1.3 Nonlicensed Departmental Training
 - 13.2.1.4 General Employee Training
 - 13.2.2 Responsible Individual
- 13.3 Emergency Planning (HNP-1 and HNP-2)
- 13.4 Review and Audit (HNP-1 and HNP-2)
 - 13.4.1 Review and Audit - Construction
 - 13.4.2 Review and Audit - Test and Operation
 - 13.4.2.1 Qualified Reviewer (Deleted)
 - 13.4.2.2 Administration of Plant Review Board
 - 13.4.2.3 Administration of Safety Review Board
 - 13.4.3 Review and Audit - ISFSI

TABLE OF CONTENTS (CONTINUED)

SUPPLEMENT 13.4A EDWIN I. HATCH PLANT REVIEW BOARD CHARTER
(HNP-1 AND HNP-2)

SUPPLEMENT 13.4B EDWIN I. HATCH SAFETY REVIEW BOARD
(HNP-1 AND HNP-2)

13.5 Plant Procedures (HNP-1 and HNP-2)

- 13.5.1 System or Plant Procedures
- 13.5.2 Administrative Procedures
- 13.5.3 Normal Operating Procedures
- 13.5.4 Annunciator Response Procedures
- 13.5.5 Surveillance Procedures
- 13.5.6 Emergency Procedures
- 13.5.7 Instrument Calibration Procedures
- 13.5.8 Maintenance Procedures
- 13.5.9 Chemical Control Procedures
- 13.5.10 Radiation Protection Procedures
- 13.5.11 Core Calculations and Fuel-Handling Procedures
- 13.5.12 Miscellaneous Procedures

13.6 Plant Records (HNP-1 and HNP-2)

- 13.6.1 Plant History
- 13.6.2 Operating Records
- 13.6.3 Event Records
- 13.6.4 Startup Report
- 13.6.5 Record Retention

13.7 Security (HNP-1 and HNP-2)

13.7.1 Personnel and Plant Design

- 13.7.1.1 Employee Selection
- 13.7.1.2 Employee Evaluation
- 13.7.1.3 Security Training

13.7.2 Security Plan

- 13.7.2.1 Access Control
- 13.7.2.2 Control of Personnel by Categories
- 13.7.2.3 Access Control During Emergencies

TABLE OF CONTENTS (CONTINUED)

- 13.7.2.4 Surveillance of Vital Equipment
- 13.7.2.5 Potential Security Threats
- 13.7.2.6 Administrative Procedures

CHAPTER 14 INITIAL TESTS AND OPERATION

14.1 Test Program

14.1.1 Administrative Procedures (Testing)

- 14.1.1.1 Purpose of the Startup Manual*
- 14.1.1.2 Responsibilities and Interfaces of Onsite Organizations*
- 14.1.1.3 Equipment and System Turnover Procedures*
- 14.1.1.4 Construction Acceptance Test Phase Procedures*
- 14.1.1.5 Preoperational Test Procedures*
- 14.1.1.6 Startup Test Program Procedures*

14.1.2 Administrative Procedures (Modifications)

14.1.3 Test Objectives and Procedures

- 14.1.3.1 General Objectives of the Testing Phase*
- 14.1.3.2 Objectives of the Preoperational Testing Phase – Discussion of Preoperational Tests*

14.1.4 Fuel Load and Initial Operation - Startup Phase

- 14.1.4.1 Fuel Loading and Open Vessel Tests*
- 14.1.4.2 Initial Heatup to Rated Pressure and Temperature*
- 14.1.4.3 Power Testing From Rated Temperature and Pressure to Licensed Output*
- 14.1.4.4 Warranty Demonstration*
- 14.1.4.5 General Discussion of Startup Tests*
- 14.1.4.6 Startup Test Procedure Preparation, Approval, and Modifications*
- 14.1.4.7 Startup Test Execution*
- 14.1.4.8 Startup Test Results Approval and Approvals for Power Escalation*

14.1.5 Administrative Procedures (System Operation)

14.2 Nuclear System Startup Organizations and Responsibility

- 14.2.1 Organizational Functions, Responsibilities, and Authorities*
- 14.2.2 Interrelationships and Interfaces*

- 14.2.2.1 GPC Production Department*
- 14.2.2.2 GPC Production - GPC Construction Department*

TABLE OF CONTENTS (CONTINUED)

- 14.2.2.3 *GPC Production - GE*
- 14.2.2.4 *PC Production Field Quality Assurance (Engineering and Construction)*
- 14.2.2.5 *GPC Production - Consultants*

- 14.2.3 *Personnel Functions, Responsibilities, and Authorities*
- 14.2.4 *Personnel Qualification*

SUPPLEMENT 14A PREOPERATIONAL TESTS

- 14A.1 *Emergency Core Cooling System Integrated Preoperational Test (2A81-3510)*
- 14A.2 *Nuclear Boiler System Preoperational Test (2B21-3510)*
- 14A.3 *Reactor Recirculation System (Including Motor-generator sets) Preoperational Tests (2B31-3510)*
- 14A.4 *Reactor System Hydrostatic Test (HNP-2-10007)*
- 14A.5 *Control Rod Drive Manual Control System Preoperational Test (2C11-3510)*
- 14A.6 *CRD Hydraulic System Preoperational Test (2C11-3520)*
- 14A.7 *Feedwater Control System Preoperational Test (2C32-3510)*
- 14A.8 *Standby Liquid Control System Preoperational Test (2C41-3510)*
- 14A.9 *Neutron Monitoring System Preoperational Test (2C51-3510)*
- 14A.10 *Primary Containment Isolation System (2C61-3510)*
- 14A.11 *RPS Preoperational Test (2C71-3510)*
- 14A.12 *Remote Shutdown System (2C82-3510)*
- 14A.13 *Process Computer Interface System Preoperational Test (2C91-3510)*
- 14A.14 *Rod Worth Minimizer System Preoperational Test (2C91-3520)*
- 14A.15 *Off-Gas Radiation Monitor (2D11-3510)*
- 14A.16 *Main Steam Line Radiation Monitor (2D11-3520)*
- 14A.17 *Process Liquid Radiation Monitor System (2D11-3530)*
- 14A.18 *Reactor Building Exhaust Radiation Monitoring (2D11-3550)*

TABLE OF CONTENTS (CONTINUED)

- 14A.19 *Traversing Incore Probe System Preoperational Test (2D12-3510)*
- 14A.20 *Area Radiation Monitoring System Preoperational Test (2D21-3510)*
- 14A.21 *Fission Products Monitor (2D23-3510)*
- 14A.22 *Residual Heat Removal System Preoperational Test (2E11-3510)*
- 14A.23 *RHRSW System Preoperational Test (2E11-3520)*
- 14A.24 *Core Spray System Preoperational Test (2E21-3510)*
- 14A.25 *Jockey Pump System (2E21-3520)*
- 14A.26 *High-Pressure Coolant Injection System Preoperational Test (2E41-3510)*
- 14A.27 *RCIC System Preoperational Test (2E51-3510)*
- 14A.28 *Fuel-Handling And Vessel-Servicing Equipment Preoperational Test (2F11-3510)*
- 14A.29 *Liquid And Solid Radwaste System Preoperational Test (2G11-3510)*
- 14A.30 *Reactor Water Cleanup System Preoperational Test (2G31-3510)*
- 14A.31 *Fuel Pool Cooling And Cleanup System Preoperational Test (2G41-3510)*
- 14A.32 *Torus Drainage And Purification System (2G51-3510)*
- 14A.33 *Fire Protection System Preoperational Test (2L43-3510)*
- 14A.34 *Seismic Monitoring System Preoperational Test (2L46-3510)*
- 14A.35 *Controlled Access Barriers (2L48-3510)*
- 14A.36 *Condensate System Preoperational Test (2N21-3510)*
- 14A.37 *Reactor Feedwater System Preoperational Test (2N21-3520)*
- 14A.38 *Turbine And Auxiliaries Preoperational Test (2N30-3510)*
- 14A.39 *Extraction And Feedwater Heater Controls (2N36-3510)*
- 14A.40 *Generator And Auxiliaries (2N40-3510)*
- 14A.41 *Condenser And Auxiliaries (2N61-3510)*

TABLE OF CONTENTS (CONTINUED)

- 14A.42 *Off-Gas System Preoperational Test (2N62-3510)*
- 14A.43 *Circulating Water System Preoperational Test (2N71-3510)*
- 14A.44 *Condensate Storage System Preoperational Test (2P11-3510)*
- 14A.45 *Hydrogen And Oxygen Analyzer System (2P33-3510)*
- 14A.46 *PSW System Preoperational Test (2P41-3510)*
- 14A.47 *RBCCWS Preoperational Test (2P42-3510)*
- 14A.48 *Plant Heating System (2P44-3510)*
- 14A.49 *Service Air System (2P51-3510)*
- 14A.50 *Instrument Air System (2P52-3510)*
- 14A.51 *Turbine Building Chilled Water System Preoperational Test (2P63-3510)*
- 14A.52 *Reactor Building And Drywell Chilled Water System (2P64-3510)*
- 14A.53 *Drywell Pneumatic System (2P70-3510)*
- 14A.54 *Grounding (2R34-3510)*
- 14A.55 *24-48 V-dc Power System Preoperation Test (2R41-3510)*
- 14A.56 *125-250 V-dc Power System (2R42-3510)*
- 14A.57 *125 V-dc Diesel Auxiliary Power System (2R42-3510)*
- 14A.58 *Standby Diesel And Standby ac Power System (2R43-3510)*
- 14A.59 *Diesel Fuel Oil Supply (2R43-3520)*
- 14A.60 *HVAC - Diesel Generator Building (2R43-3530)*
- 14A.61 *20-240-V Vital ac Power System (2R44-3510)*
- 14A.62 *Communication And Evacuation Alarm System Preoperational Test (2R51-3510)*
- 14A.63 *Lighting - 277-480 V-ac (2R52-3510)*
- 14A.64 *4160 V-ac System (2R71-3510)*

TABLE OF CONTENTS (CONTINUED)

- 14A.65 *600-V-ac System (2R71-3520)*
- 14A.66 *120/208-V-ac Instrument Power System (2R71-3530)*
- 14A.67 *Primary Containment Leak Rate Preoperational Test (2T23-3510)*
- 14A.68 *MSIV Leakage Control System (2E32-3510)*
- 14A.69 *Reactor Building Heating And Ventilation System Preoperational Test (2T41-3510)*
- 14A.70 *Refueling Floor Ventilation System (2T41-3520)*
- 14A.71 *CS and RHR Room Ventilation (2T41-3540)*
- 14A.72 *HPCI Room Ventilation (2T41-3550)*
- 14A.73 *RCIC Room Ventilation (2T41-3560)*
- 14A.74 *CRD Room Ventilation (2T41-3570)*
- 14A.75 *Leak Detection System (2T45-3510)*
- 14A.76 *SGTS Preoperational Test (2T46-3510)*
- 14A.77 *Primary Containment Cooling System Preoperational Test (2T47-3510)*
- 14A.78 *Primary Containment Atmosphere Control System Preoperational Test (2T48-3510)*
- 14A.79 *Turbine Building Crane (2U31-3510)*
- 14A.80 *Turbine Building Heating And Ventilation System Preoperational Test (2U41-3510)*
- 14A.81 *Radwaste Building Ventilation System Preoperational Test (2V41-3150)*
- 14A.82 *Cooling Towers (2W24-3510)*
- 14A.83 *Control Building HVAC Systems Preoperational Test (2Z41-3510)*
- 14A.84 *Combustible Gas Control System (2T49-3510)*
- 14A.85 *Reactor Internal Flow-Induced Vibration Test And Inspection*

TABLE OF CONTENTS (CONTINUED)

SUPPLEMENT 14B STARTUP TESTS

- 14B.1 Chemical And Radiochemical Tests (STI-1)*
- 14B.2 Radiation Measurements (STI-2)*
- 14B.3 Fuel Loading (STI-3)*
- 14B.4 Shutdown Margin (STI-4)*
- 14B.5 Control Rod Drive (STI-5)*
- 14B.6 Source Range Monitor Performance And Control Rod Sequence (STI-6)*
- 14B.7 Rod Sequence Exchange (STI-8)*
- 14B.8 Water Level Measurement (STI-9)*
- 14B.9 Intermediate Range Monitor Performance (STI-10)*
- 14B.10 Local Power Range Monitor Calibration (STI-11)*
- 14B.11 Average Power Range Monitor Calibration (STI-12)*
- 14B.12 Process Computer (STI-13)*
- 14B.13 Reactor Core Isolation Cooling System (STI-14)*
- 14B.14 High-Pressure Coolant Injection (STI-15)*
- 14B.15 Selected Process Temperatures (STI-16)*
- 14B.16 System Expansion (STI-17)*
- 14B.17 Core Power Distribution (STI-18)*
- 14B.18 Core Performance (STI-19)*
- 14B.19 Steam Production (STI-20)*
- 14B.20 Core Power-Void Mode Test (STI-21)*
- 14B.21 Pressure Regulator (STI-22)*
- 14B.22 Feedwater Control System (STI-23)*

TABLE OF CONTENTS (CONTINUED)

- 14B.23 *Turbine Valve Surveillance (STI-24)*
- 14B.24 *Main Steam Line Isolation Valves (STI-25)*
- 14B.25 *Safety Relief Valves (STI-26)*
- 14B.26 *Turbine Trip And Generator Load Rejection (STI-27)*
- 14B.27 *Shutdown From Outside The MCR (STI-28)*
- 14B.28 *Flow Control (STI-29)*
- 14B.29 *Recirculation System (STI-30)*
- 14B.30 *Loss of Turbine-Generator and Offsite Power (STI-31)*
- 14B.31 *Drywell Piping Vibration (STI-33)*
- 14B.32 *Recirculation System Flow Calibration (STI-35)*
- 14B.33 *RWC System (STI-70)*
- 14B.34 *RHR System (STI-71)*
- 14B.35 *Off-Gas (STI-74)*
- 14B.36 *MSIV Leakage Control System*
- 14B.37 *Hydrogen Recombiners*
- 14B.38 *Primary Containment Cooling System (STI-44)*
- 15.0 SAFETY ANALYSIS (HNP-1 AND HNP-2)
- 15.1 General
 - 15.1.1 Analytical Approach
 - 15.1.2 Probabilistic Safety Assessments
 - 15.1.3 Selection of Events
 - 15.1.3.1 AOOs
 - 15.1.3.2 Accidents
 - 15.1.3.3 Special Events
 - 15.1.4 Event Analysis Format

TABLE OF CONTENTS (CONTINUED)

- 15.1.5 Event Acceptance Limits
 - 15.1.5.1 AOOs
 - 15.1.5.2 Accidents
 - 15.1.5.3 Special Events
- 15.1.6 Single Failure
 - 15.1.6.1 Application of Single-Failure Criteria
 - 15.1.6.2 Single Failures as Event Initiators
- 15.1.7 Analysis Methods
- 15.1.8 Analysis Inputs
- 15.1.9 Increase In Rated Thermal Power
- 15.1.10 Performance Improvement Features
- 15.2 Analyses of Anticipated Operational Occurrences
 - 15.2.1 Decrease in Core Coolant Temperature
 - 15.2.1.1 Loss of Feedwater Heating (Event 1)
 - 15.2.1.2 Inadvertent Start of the HPCI Pump (Event 2)
 - 15.2.1.3 Shutdown Cooling (RHR) Malfunction – Decreasing Temperature (Event 3)
 - 15.2.2 Increase in Core Coolant Temperature
 - 15.2.2.1 Loss of RHR Shutdown Cooling (Event 4)
 - 15.2.2.2 Compliance with GDC 34
 - 15.2.3 Increase in Reactor Pressure
 - 15.2.3.1 Generator Load Rejection with No Bypass (Event 5)
 - 15.2.3.2 Generator Load Rejection with Bypass (Event 6)
 - 15.2.3.3 Turbine Trip with No Bypass (Event 7)
 - 15.2.3.4 Loss of Condenser Vacuum (Event 8)
 - 15.2.3.5 Turbine Trip with Bypass (Event 9)
 - 15.2.3.6 Closure of All MSIVs (MSIVD) (Event 10)
 - 15.2.3.7 Closure of One MSIV (Event 11)
 - 15.2.3.8 Pressure Regulator Failure - Closed (Event 12)
 - 15.2.4 Decrease in Reactor Core Coolant Flowrate
 - 15.2.4.1 Trip of One Recirculation Pump (Event 13)
 - 15.2.4.2 Trip of Two Recirculation Pumps (Event 14)

TABLE OF CONTENTS (CONTINUED)

- 15.2.4.3 Recirculation Flow Control Failure - Decreasing Flow (Event 15)
- 15.2.5 Increase in Reactor Core Coolant Flowrate
 - 15.2.5.1 Recirculation Flow Control Failure - Increasing Flow (Event 16)
 - 15.2.5.2 Startup of Idle Recirculation Pump (Event 17)
- 15.2.6 Reactivity and Power Distribution Anomalies
 - 15.2.6.1 RWE During Power Operation (Event 18)
 - 15.2.6.2 Control Rod Removal Error During Refueling (Event 19)
 - 15.2.6.3 Fuel Assembly Insertion Error During Refueling (Event 20)
- 15.2.7 Increase in Reactor Coolant Inventory
 - 15.2.7.1 Feedwater Controller Failure – Maximum Demand (Event 21)
- 15.2.8 Decrease In Reactor Coolant Inventory
 - 15.2.8.1 Inadvertent Opening of an SRV (Event 22)
 - 15.2.8.2 Pressure Regulator Failure - Open (Event 23)
 - 15.2.8.3 Loss of Auxiliary Power (Event 24)
 - 15.2.8.4 Loss of Feedwater Flow (Event 25)
- 15.3 Analyses of Accidents
 - 15.3.1 Introduction
 - 15.3.1.1 Analysis Reference
 - 15.3.2 CRDA (Radiological Consequences) (Event 31)
 - 15.3.2.1 Identification of Causes
 - 15.3.2.2 Starting Conditions and Assumptions
 - 15.3.2.3 Accident Description
 - 15.3.2.4 Analysis of Effects and Consequences
 - 15.3.3 LOCA (Radiological Consequences) (Event 32)
 - 15.3.3.1 Identification of Causes
 - 15.3.3.2 Starting Conditions and Assumptions
 - 15.3.3.3 Accident Description
 - 15.3.3.4 Analysis of Effects and Consequences
 - 15.3.3.5 Evaluation of Exclusion Area and LPZ Distance

TABLE OF CONTENTS (CONTINUED)

- 15.3.4 MSLBA (Radiological Consequences) (Event 33)
 - 15.3.4.1 Identification of Causes
 - 15.3.4.2 Starting Conditions and Assumptions
 - 15.3.4.3 Accident Description
 - 15.3.4.4 Analysis of Effects and Consequences
- 15.3.5 Fuel-Handling Accident (Event 34)
 - 15.3.5.1 Identification of Causes
 - 15.3.5.2 Starting Conditions and Assumptions
 - 15.3.5.3 Accident Description
 - 15.3.5.4 Analysis of Effects and Consequences
- 15.3.6 Fuel Assembly Loading Error (Event 35)
 - 15.3.6.1 Identification of Causes
 - 15.3.6.2 Analysis of Effects and Consequences
- 15.3.7 Recirculation Pump Seizure (Event 36)
 - 15.3.7.1 Identification of Causes
 - 15.3.7.2 Analysis of Effects and Consequences
- 15.3.8 Feedwater Line Break (Radiological Consequences) (Event 37)
 - 15.3.8.1 Identification of Causes
 - 15.3.8.2 Starting Conditions and Assumptions
 - 15.3.8.3 Accident Description
 - 15.3.8.4 Analysis of Effects and Consequences
- 15.4 Analyses of Special Events
 - 15.4.1 Stability (Event 41)
 - 15.4.2 Overpressure Protection (Event 42)
 - 15.4.3 Shutdown Without Control Rod Insertion (SLCS Capability) (Event 43)
 - 15.4.4 MCR Uninhabitability (Event 44)
 - 15.4.4.1 Identification of Causes
 - 15.4.5 ATWS (Event 45)
 - 15.4.6 Generator Load Rejection With Flux Scram and No Bypass or RPT (Event 46)
 - 15.4.7 Turbine Trip With Flux Scram and No Bypass or RPT (Event 47)

TABLE OF CONTENTS (CONTINUED)

- 15.4.8 Loss of One dc System (Event 48)
 - 15.4.8.1 Identification of Causes
 - 15.4.8.2 125-250-V-dc Power System
 - 15.4.8.3 125-V-dc Diesel Auxiliary Power System
- 15.4.9 Loss of Instrument Air (Event 49)
 - 15.4.9.1 Identification of Causes
 - 15.4.9.2 Analysis of Effects and Consequences
- 15.4.10 Loss of Service Water System (Event 50)
 - 15.4.10.1 Identification of Causes
 - 15.4.10.2 Analysis of Effects and Consequences
- 15.4.11 Fire (Event 51)
- 15.4.12 Miscellaneous Small Releases Outside Containment (Event 52)
- 15.4.13 Instrument Line Break (Event 53)
 - 15.4.13.1 Identification of Causes
 - 15.4.13.2 Event Description
 - 15.4.13.3 Analysis of Nonradiological Effects and Consequences
 - 15.4.13.4 Analysis of Radiological Effects and Consequences
- 15.4.14 Liquid Radwaste Tank Failure (Radiological Consequences)(Event 54)
 - 15.4.14.1 Identification of Causes
 - 15.4.14.2 Starting Conditions and Assumptions
 - 15.4.14.3 Event Description
 - 15.4.14.4 Analysis of Effects and Consequences
- 15.4.15 Gaseous Radwaste Tank Failure (Event 55)
 - 15.4.15.1 Offgas System Failure
 - 15.4.15.2 Failure of SJAE Lines (Radiological Consequences)
 - 15.4.15.3 Malfunction of Turbine Gland-Sealing System (Radiological Consequences)
- 15.4.16 SBO (Event 56)

TABLE OF CONTENTS (CONTINUED)

SUPPLEMENT 15A DESIGN AGAINST HIGH-ENERGY PIPE BREAKS OUTSIDE THE
PRIMARY CONTAINMENT

15A.1 Purpose

15A.2 Introduction

15A.3 General Design Evaluation

15A.3.1 Evaluation With Respect to AEC Criteria

15A.3.2 Inherent Plant Safety Features with Respect to Design Against High-Energy
Pipe Failures

15A.4 Methods of Analysis and Assumptions

15A.4.1 Identification of High-Energy Fluid Systems

15A.4.1.1 High-Energy Lines Identified

15A.4.1.2 Moderate-Energy Lines Identified

15A.4.2 High-Energy Piping System Failure Assumptions

15A.4.2.1 High-Energy Line Breaks

15A.4.2.2 High-Energy and Moderate-Energy Line Cracks

15A.4.2.3 Other Failure Assumptions

15A.4.2.4 Piping Penetrating Containment

15A.4.3 Jet Impingement and Pipe Whip Analysis

15A.4.4 Compartment Pressure-Temperature Analysis

15A.4.4.1 General Approach and Assumptions

15A.4.4.2 The Mathematical Model

15A.4.4.3 COPATTA

15A.5 Detailed System Analyses

15A.5.1 Main Steam Line Break

15A.5.1.1 MSLB in Main Steam Pipe Chase

15A.5.1.2 MSLB in Turbine Building

15A.5.1.3 Analysis of Shutdown Capability

15A.5.2 Feedwater Line Break

15A.5.2.1 Feedwater Line Break in Main Steam Pipe Chase

TABLE OF CONTENTS (CONTINUED)

- 15A.5.2.2 Feedwater Line Break in Turbine Building
- 15A.5.2.3 Analysis of Shutdown Capability
- 15A.5.3 HPCI Steam Line Break
 - 15A.5.3.1 Pressure-Temperature Analysis
 - 15A.5.3.2 Analysis of Shutdown Capability
- 15A.5.4 RCIC Steam Line Break
 - 15A.5.4.1 Pressure-Temperature Analysis
 - 15A.5.4.2 Analysis of Shutdown Capability
- 15A.5.5 RWC Line Break
 - 15A.5.5.1 Pressure-Temperature Analysis
 - 15A.5.5.2 Analysis of Shutdown Capability
- 15A.5.6 Moderate-Energy Line Cracks
 - 15A.5.6.1 CRD Return Line Cracks
 - 15A.5.6.2 Auxiliary Steam Line Cracks
 - 15A.5.6.3 RHRSW Line Cracks
 - 15A.5.6.4 Sampling Lines
- 15A.5.7 Radiological Considerations
- 15A.6 Summary of Plant Modifications
 - 15A.6.1 Modifications as a Result of Pressure-Temperature
 - 15A.6.2 Barriers Provided to Protect Against Jet Impingement
- 15A.7 Conclusions
- SUPPLEMENT 15A.A RESPONSE TO NRC QUESTION A&PCSB-1
 - 15A.A.1 Background
 - 15A.A.2 Additional High-Energy Lines Analyzed
 - 15A.A.2.1 RCIC Injection Line
 - 15A.A.2.2 RCIC Turbine Steam Exhaust Line
 - 15A.A.2.3 RWC System Piping in the Pipe Nest Room and Filter Demineralizer Room
 - 15A.A.2.4 CRD Return Line to the Reactor Pressure Vessel
 - 15A.A.2.5 Condensate System

TABLE OF CONTENTS (CONTINUED)

- 15A.A.2.6 SJAE Off-Gas Lines
- 15A.A.3 (Deleted)
- 15A.A.4 Additional Moderate-Energy Lines Needed to Be Analyzed

- SUPPLEMENT 15C NUCLEAR SAFETY OPERATIONAL ANALYSIS AND SETPOINT METHODOLOGY (HNP-1 and HNP-2)

- 15C.1 Analytical Approach
 - 15C.1.1 NSOA and Setpoint Methodology Objectives
 - 15C.1.2 NSOA Relationship to Safety Analysis

- 15C.2 NSOA Method of Analysis
 - 15C.2.1 Operational Criteria
 - 15C.2.2 Analysis Assumptions/Initial Conditions
 - 15C.2.2.1 Operating States
 - 15C.2.2.2 Operating Modes
 - 15C.2.2.3 Planned Operation
 - 15C.2.2.4 Key Bounding Parameters for Planned Operation
 - 15C.2.3 Required Actions
 - 15C.2.4 Event Analysis Rules

- 15C.3 NSOA Results
 - 15C.3.1 Event Evaluations and Diagrams
 - 15C.3.2 Auxiliary System Evaluation and Diagrams
 - 15C.3.3 Summary Matrices

- 15C.4 Event Evaluations
 - 15C.4.1 Anticipated Operational Occurrences
 - 15C.4.1.1 Decrease in Reactor Coolant Temperature
 - 15C.4.1.2 Increase in Reactor Coolant Temperature
 - 15C.4.1.3 Increase in Reactor Pressure
 - 15C.4.1.4 Decrease in Reactor Coolant Flowrate
 - 15C.4.1.5 Increase in Reactor Coolant Flowrate
 - 15C.4.1.6 Reactivity and Power Distribution Anomalies
 - 15C.4.1.7 Increase in Reactor Coolant Inventory

TABLE OF CONTENTS (CONTINUED)

- 15C.4.1.8 Decrease in Reactor Coolant Inventory
- 15C.4.2 Accidents
 - 15C.4.2.1 Control Rod Drop Accident (CRDA) (Event 31)
 - 15C.4.2.2 Loss of Coolant Accident (LOCA) (Event 32)
 - 15C.4.2.3 Main Steam Line Break Accident (MSLBA) (Event 33)
 - 15C.4.2.4 Fuel-Handling Accident (Event 34)
 - 15C.4.2.5 Fuel Assembly Loading Error (Event 35)
 - 15C.4.2.6 Recirculation Pump Seizure (Event 36)
 - 15C.4.2.7 Feedwater Line Break Accident (Event 37)
- 15C.4.3 Special Events
 - 15C.4.3.1 Stability (Event 41)
 - 15C.4.3.2 Overpressure Protection (Event 42)
 - 15C.4.3.3 Shutdown Without Control Rod Insertion (SLCS Capability) (Event 43)
 - 15C.4.3.4 MCR Uninhabitability (Event 44)
 - 15C.4.3.5 Anticipated Transient Without Scram (ATWS)(Event 45)
 - 15C.4.3.6 Generator Load Rejection With Flux Scram and No Bypass or RPT (Event 46)
 - 15C.4.3.7 Turbine Trip With Flux Scram and No Bypass or RPT (Event 47)
 - 15C.4.3.8 Loss of One dc System (Event 48)
 - 15C.4.3.9 Loss of Instrument Air (Event 49)
 - 15C.4.3.10 Loss of Service Water System (Event 50)
 - 15C.4.3.11 Fire (Event 51)
 - 15C.4.3.12 Miscellaneous Small Releases Outside Containment (Event 52)
 - 15C.4.3.13 Instrument Line Break (Event 53)
 - 15C.4.3.14 Liquid Radwaste Tank Failure (Event 54)
 - 15C.4.3.15 Gaseous Radwaste Tank Failure (Event 55)
 - 15C.4.3.16 Station Blackout (SBO) (Event 56)
- 15C.5 SETPOINT METHODOLOGY
 - 15C.5.1 Setpoint Methodology
 - 15C.5.2 Relationship to NSOA and Safety Analysis
 - 15C.5.3 Safety Analysis-Related Setpoints and Uncertainties
 - 15C.5.4 Setpoint Clarification
 - 15C.5.4.1 Technical Specifications
 - 15C.5.4.2 Safety Limits and Limiting Safety System Settings
 - 15C.5.4.3 Limiting Conditions for Operation and Surveillance Requirements
 - 15C.5.4.5 Technical Requirements Manual

TABLE OF CONTENTS (CONTINUED)

- 15C.5.4.6 Safety Analysis Inputs
- 15C.5.5 Setpoint Identification Process and Bases
 - 15C.5.5.1 Limiting Safety System Settings
 - 15C.5.5.2 Technical Specification Automatic Trips Assumed in Safety Analysis
 - 15C.5.5.3 EOP Setpoints Assumed in Safety Analysis
 - 15C.5.5.4 Technical Requirement Manual Automatic Trips Assumed in Safety Analysis
 - 15C.5.5.5 Safety Analysis Inputs
 - 15C.5.5.6 Technical Specification Automatic Trips Not Credited in Safety Analysis
 - 15C.5.5.7 EOP Setpoints for Contingency Actions
 - 15C.5.5.8 Technical Requirement Manual Automatic Trips Not Credited in Safety Analysis
- 15C.5.6 Setpoint Calculation Process
 - 15C.5.6.1 Calculation Process Overview
 - 15C.5.6.2 Instrument Setpoint Calculation
 - 15C.5.6.3 Simplified Setpoint Methodology

CHAPTER 16 TECHNICAL SPECIFICATIONS

CHAPTER 17 QUALITY ASSURANCE

- 17.1 (Deleted)
- 17.2 Quality Assurance During the Operations Phase

SUPPLEMENT 17.2A QUALITY ASSURANCE OF THE INDEPENDENT SPENT FUEL STORAGE INSTALLATION

CHAPTER 18 AGING MANAGEMENT PROGRAMS/ACTIVITIES (HNP-1 AND HNP-2)

- 18.1 Introduction (HNP-1 and HNP-2)
 - 18.1.1 Background
 - 18.1.2 Aging Management Programs
 - 18.1.3 Time-Limited Aging Analyses

TABLE OF CONTENTS (CONTINUED)

18.2 Programs/Activities - Group I

- 18.2.1 Reactor Water Chemistry Control
- 18.2.2 Closed Cooling Water Chemistry Control
- 18.2.3 Diesel Fuel Oil Testing
- 18.2.4 Plant Service Water and RHR Service Water Chemistry Control
- 18.2.5 Fuel Pool Chemistry Control
- 18.2.6 Demineralized Water and Condensate Storage Tank Chemistry Control
- 18.2.7 Suppression Pool Chemistry Control
- 18.2.8 Corrective Actions Program
- 18.2.9 Inservice Inspection Program
- 18.2.10 Overhead Crane and Refueling Platform Inspections
- 18.2.11 Torque Activities
- 18.2.12 Component Cyclic or Transient Limit Program
- 18.2.13 Plant Service Water and RHR Service Water Inspection Program
- 18.2.14 Primary Containment Leakage Rate Testing Program
- 18.2.15 Boiling Water Reactor Vessel and Internals Program
- 18.2.16 Wetted Cable Activities
- 18.2.17 Reactor Pressure Vessel Materials Surveillance Program
- 18.2.18 Diesel Generator Maintenance Activities

18.3 Programs/Activities - Group II

- 18.3.1 Fire Protection Activities
- 18.3.2 Flow Accelerated Corrosion Program
- 18.3.3 Protective Coatings Program
- 18.3.4 Equipment and Piping Insulation Program
- 18.3.5 Structural Monitoring Program

18.4 Programs/Activities - Group III

- 18.4.1 Galvanic Susceptibility Inspections
- 18.4.2 Treated Water Systems Piping Inspections
- 18.4.3 Gas Systems Components Inspections
- 18.4.4 Condensate Storage Tank Inspections
- 18.4.5 Passive Components Inspection Activities
- 18.4.6 RHR Heat Exchanger Augmented Inspection and Testing Program
- 18.4.7 Torus Submerged Components Inspection Program
- 18.4.8 Insulated Cables and Connections Program

TABLE OF CONTENTS (CONTINUED)

18.5 Time Limited Aging Analyses Credited for License Renewal

18.5.1 Time Limited Aging Analyses

18.5.1.1 Stress Analysis Calculations

18.5.1.2 Equipment Qualification Report Evaluations

18.6 References

APPENDIX A CONFORMANCE WITH NUCLEAR REGULATORY COMMISSION (NRC)
REGULATORY GUIDES

- A.1 Regulatory Guide 1.1 – Net Positive Suction Head for ECCS and Containment Heat Removal System Pumps (Safety Guide 1, November 2, 1970)
- A.2 Regulatory Guide 1.2 – Thermal Shock to Reactor Pressure Vessels (Safety Guide 2, November 2, 1970)
- A.3 Regulatory Guide 1.3 – Assumptions Used for Evaluation of the Potential Radiological Consequences of the LOCA for BWRs (Revision 2, June 1974)
- A.4 Regulatory Guide 1.4 – Assumptions Used for Evaluating the Potential Radiological Consequences of a Loss-of-Coolant Accident for Pressurized Water Reactors (Revision 2, June 1974)
- A.5 Regulatory Guide 1.5 – Assumptions Used for Evaluating the Potential Radiological Consequences of a Steam Line Break Accident for BWRs (Safety Guide 5, March 10, 1971)
- A.6 Regulatory Guide 1.6 - Independence Between Redundant Standby (Onsite) Power Sources and Between Their Distribution Systems (Safety Guide 6, March 10, 1971)
- A.7 Regulatory Guide 1.7 - Control of Combustible Gas Concentrations in Containment Following a Loss-of-Coolant Accident (March 10, 1971)
- A.8 Regulatory Guide 1.8 - Personnel Selection and Training (March 10, 1971)
- A.9 Regulatory Guide 1.9 - Selection of Diesel Generator Set Capacity for Standby Power Supplies (March 10, 1971)
- A.10 Regulatory Guide 1.10 - Mechanical (Cadmium) Splices in Reinforcing Bars of Category I Concrete Structures (Revision 1, January 2, 1973)

TABLE OF CONTENTS (CONTINUED)

- A.11 Regulatory Guide 1.11 – Instrument Lines Penetrating Primary Reactor Containment (Safety Guide 11, March 10, 1971, Supplement to Safety Guide 11, Backfitting Considerations, February 10, 1972)
- A.12 Regulatory Guide 1.12 – Instrumentation for Earthquakes (Revision 1, April 1974)
- A.13 Regulatory Guide 1.13 – Fuel Storage Facility Design Basis (March 10, 1971)
- A.14 Regulatory Guide 1.14- Reactor Coolant Pump Flywheel Integrity (October 27, 1971)
- A.15 Regulatory Guide 1.15 – Testing of Reinforcing Bars for Category I Concrete Structures (Revision 1, December 28, 1972)
- A.16 Regulatory Guide 1.16 – Reporting of Operating Information – Appendix A Technical Specifications (January 1975)
- A.17 Regulatory Guide 1.17 – Protection of Nuclear Power Plants Against Industrial Sabotage (June 1973)
- A.18 Regulatory Guide 1.18 – Structural Acceptance Test for Concrete Primary Reactor Containments (Revision 1, December 28, 1972)
- A.19 Regulatory Guide 1.19 – Nondestructive Examination of Primary Containment Liner Welds (Safety Guide 19, August 11, 1972)
- A.20 Regulatory Guide 1.20 – Vibration Measurements on Reactor Internals (December 29, 1971)
- A.21 Regulatory Guide 1.21 - Measuring, Evaluating, and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents From Light-Water-Cooled Nuclear Power Plants (Revision 1, June 1974)
- A.22 Regulatory Guide 1.22 – Periodic Testing of Protection System Actuation Functions (Safety Guide 22, February 17, 1972)
- A.23 Regulatory Guide 1.23 – Onsite Meteorological Programs (Safety Guide 23, February 17, 1972)
- A.24 Regulatory Guide 1.24 – Assumptions Used for Evaluating the Potential Radiological Consequences of a Pressurizer Water Reactor Gas Storage Tank Failure (Safety Guide 24, March 23, 1972)
- A.25 Regulatory Guide 1.25 – Assumptions Used for Evaluating the Potential Radiological Consequences of a Fuel Handling Accident in the Fuel Handling and Storage Facility for Boiling and Pressurized Water Reactors (Safety Guide 25, March 23, 1972)

TABLE OF CONTENTS (CONTINUED)

- A.26 Regulatory Guide 1.26 – Quality Group Classifications and Standards (September 1974)
- A.27 Regulatory Guide 1.27 – Ultimate Heat Sink for Nuclear Power Plants (Revision 1, March 1974)
- A.28 *Regulatory Guide 1.28 – Quality Assurance Program Requirements (Design and Construction) (Revision 2, February 1979)*
- A.29 Regulatory Guide 1.29 – Seismic Design Classification (Revision 1, August 1973)
- A.30 Regulatory Guide 1.30 – Quality Assurance Requirements for the Installation, Inspection and Testing of Instrumentation and Electric Equipment (Safety Guide 30, August 11, 1972)
- A.31 Regulatory Guide 1.31 – Control of Stainless Steel Welding (June 1973)
- A.32 Regulatory Guide 1.32 – Use of IEEE Standard 308-1971, Criteria for Class 1 Electric Systems for Nuclear Power Generating Stations (August 11, 1972)
- A.33 Regulatory Guide 1.33 – Quality Assurance Program Requirements (Operation) Conformance (Revision 2, February 1978)
- A.34 Regulatory Guide 1.34 – Control of Electroslag Weld Properties (December 28, 1972)
- A.35 Regulatory Guide 1.35 – Inservice Inspection of UngROUTED Tendons in Prestressed Concrete Containment Structures (Revision 1, June 1974)
- A.36 Regulatory Guide 1.36 – Nonmetallic Thermal Insulation for Austenitic Stainless Steel (February 23, 1973)
- A.37 Regulatory Guide 1.37 – Quality Assurance Requirements for Cleaning of Fluid Systems and Associated Components of Water-Cooled Nuclear Power Plants (March 16, 1973)
- A.38 Regulatory Guide 1.38 – Quality Assurance Requirements for Packaging, Shipping, Receiving, Storage, and Handling of Items for Water-Cooled Nuclear Power Plants (March 16, 1973)
- A.39 Regulatory Guide 1.39 – Housekeeping Requirements for Water-Cooled Nuclear Power Plants (March 16, 1973)
- A.40 Regulatory Guide 1.40 – Qualification Tests of Continuous-Duty Motors Installed Inside the Containment of Water-Cooled Nuclear Power Plants (March 16, 1973)
- A.41 Regulatory Guide 1.41 – Preoperational Testing of Redundant Onsite Electric Power Systems to Verify Proper Load Group Assignments (March 16, 1973)

TABLE OF CONTENTS (CONTINUED)

- A.42 Regulatory Guide 1.42 – Interim Licensing Policy on as Low-As-Practical for Gaseous Radioiodine Releases from Light-Water-Cooled Nuclear Power Reactors (Revision 1, March 1974)
- A.43 Regulatory Guide 1.43 – Control of Stainless Steel Weld Cladding of Low-Alloy Steel Components (May 1973)
- A.44 Regulatory Guide 1.44 – Control of the Use of Sensitized Stainless Steel (May 1973)
- A.45 Regulatory Guide 1.45 – Reactor Coolant Pressure Boundary Leakage Detection Systems (May 1973)
- A.46 Regulatory Guide 1.46 – Protection Against Pipe Whip Inside Containment (May 1973)
- A.47 Regulatory Guide 1.47 – Bypassed and Inoperable Status Indication for Nuclear Power Plant Safety Systems (May 1973)
- A.48 Regulatory Guide 1.48 – Design Limits and Loading Combinations for Seismic Category I Fluid System Components (May 1973)
- A.49 Regulatory Guide 1.49 – Power Levels of Water-Cooled Nuclear Power Plants (December 1973)
- A.50 Regulatory Guide 1.50 – Control of Preheat Temperature for Welding of Low-Alloy Steel (May 1973)
- A.51 Regulatory Guide 1.51 – Inservice Inspection of ASME Code Classes 2 and 3 Nuclear Power Plant Components (May 1973)
- A.52 Regulatory Guide 1.52 – Design, Testing, and Maintenance Criteria for Atmosphere Cleanup System Air Filtration and Adsorption Units of Light-Water-Cooled Nuclear Power Plants {June 1973 (Rev. 0), March 1978 (Rev. 2)}
- A.53 Regulatory Guide 1.53 – Application of the Single-Failure Criterion to Nuclear Power Plant Protection Systems (June 1973)
- A.54 Regulatory Guide 1.54 – Quality Assurance Requirements for Protective Coatings Applied to Water-Cooled Nuclear Power Plants (June 1973)
- A.55 Regulatory Guide 1.55 – Concrete Placement in Category I Structures (June 1973)
- A.56 Regulatory Guide 1.56 – Maintenance of Water Purity in Boiling Water Reactors (June 1973)

TABLE OF CONTENTS (CONTINUED)

- A.57 Regulatory Guide 1.57 – Design Limits and Loading Combinations for Metal Primary Reactor Containment System Components (June 1973)
- A.58 Regulatory Guide 1.58 – Qualifications of Nuclear Power Plant Inspection, Examination, and Testing Personnel (August 1973)
- A.59 Regulatory Guide 1.59 – Design Basis Floods for Nuclear Power Plants (August 1973)
- A.60 Regulatory Guide 1.60 – Design Response Spectra for Seismic Design of Nuclear Power Plants (Revision 1, December 1973)
- A.61 Regulatory Guide 1.61 – Damping Values for Seismic Design of Nuclear Power Plants (October 1973)
- A.62 Regulatory Guide 1.62 – Manual Initiation of Protective Actions (October 1973)
- A.63 Regulatory Guide 1.63 – Electric Penetration Assemblies in Containment Structures for Water-Cooled Nuclear Power Plants (October 1973)
- A.64 Regulatory Guide 1.64 – Quality Assurance Requirements for the Design of Nuclear Power Plants (Revision 2, June 1976)
- A.65 Regulatory Guide 1.65 – Materials and Inspections for Reactor Vessel Closure Studs (October 1973)
- A.66 Regulatory Guide 1.66 – Nondestructive Examination of Tubular Products (October 1973)
- A.67 Regulatory Guide 1.67 – Installation Overpressure Protection Devices (October 1973)
- A.68 Regulatory Guide 1.68 – Preoperational and Initial Startup Test Programs for Water-Cooled Power Reactors (November 1973)
- A.68.1 Regulatory Guide 1.68.1 - Preoperational and Initial Startup Testing of Feedwater and Condensate Systems for Boiling Water Reactor Power Plants
- A.69 Regulatory Guide 1.69 – Concrete Radiation Shields for Nuclear Power Plants (December 1973)
- A.70 Regulatory Guide 1.70 – Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants (Revision 1, October 1972)
- A.71 Regulatory Guide 1.71 – Welder Qualification for Areas of Limited Accessibility (December 1973)

TABLE OF CONTENTS (CONTINUED)

- A.72 Regulatory Guide 1.72 – Spray Pond Plastic Piping (December 1973)
- A.73 Regulatory Guide 1.73 – Qualification Tests of Electric Valve Operators Installed Inside the Containment of Nuclear Power Plants (January 1974)
- A.74 Regulatory Guide 1.74 – Quality Assurance Terms and Definitions (February 1974)
- A.75 Regulatory Guide 1.75 – Physical Independence of Electric Systems (February 1974)
- A.76 Regulatory Guide 1.76 – Design Basis Tornado for Nuclear Power Plants (April 1974)
- A.77 Regulatory Guide 1.77 – Assumptions Used for Evaluating A Control Rod Ejection Accident for Pressurized Water Reactors (May 1974)
- A.78 Regulatory Guide 1.78 – Assumptions for Evaluating the Habitability of a Nuclear Power Plant Control Room During a Postulated Hazardous Chemical Release (June 1974)
- A.79 Regulatory Guide 1.79 – Preoperational Testing of Emergency Core Cooling Systems for Pressurized Water Reactors (June 1974)
- A.80 Regulatory Guide 1.80 – Preoperational Testing of Instrument Air Systems (June 1974)
- A.81 Regulatory Guide 1.81 – Shared Emergency and Shutdown Electric Systems for Multi-Unit Nuclear Power Plants (June 1974)
- A.82 Regulatory Guide 1.82 – Sumps for Emergency Core Cooling and Containment Spray System (June 1974)
- A.83 Regulatory Guide 1.83 – Inservice Inspection of Pressurized Water Reactor Steam Generator Tubes (June 1974)
- A.84 Regulatory Guide 1.84 – Code Case Acceptability ASME Section III, Design and Fabrication (June 1974)
- A.85 Regulatory Guide 1.85 – Code Case Acceptability ASME III Material (June 1974)
- A.86 Regulatory Guide 1.86 – Termination of Operating Licenses for Nuclear Reactors (June 1974)
- A.87 Regulatory Guide 1.87 – Construction Criteria for Class 1 Components in Elevated Temperature Reactors (Supplement to ASME Section III Code Cases 1592, 1593, 1594, 1595, and 1596) (June 1974)
- A.88 Regulatory Guide 1.88 – Collection, Storage, and Maintenance of Nuclear Power Plant Quality Assurance Records (August 1974)

TABLE OF CONTENTS (CONTINUED)

- A.89 Regulatory Guide 1.89, Revision 1 – Environmental Qualification of Certain Electric Equipment Important to Safety for Nuclear Plants (June 1984)
- A.90 Regulatory Guide 1.90 – Inservice Inspection of Prestressed Concrete Containment Structures With Grouted Tendons (November 1974)
- A.94 Regulatory Guide 1.94 – Quality Assurance Requirements for Installation, Inspection, and Testing of Structural Concrete and Structural Steel During the Construction Phase of Nuclear Power Plants (Revision 1, April 1976)
- A.97 Regulatory Guide 1.97 – Instrumentation for Light Water Cooled Nuclear Power Plant to Assess Plant and Environs Conditions During and Following an Accident (Revision 2, December 1980)
- A.105 Regulatory Guide 1.105 – Instrument Setpoints (Revision 1, July 1976)
- A.116 Regulatory Guide 1.116 – Quality Assurance Requirements for Installation, Inspection, and Testing of Mechanical Equipment and Systems (Revision O through R, May 1977)
- A.123 Regulatory Guide 1.123 – Quality Assurance Requirements for Control of Procurement of Items and Services for Nuclear Power Plants (Revision 1, July 1977)
- A.143 Regulatory Guide 1.143 – Design Guidance for Radioactive Waste Management Systems, Structures, and Components Installed in Light-Water-Cooled Nuclear Power Plants (Revision 1, October 1979)
- A.144 Regulatory Guide 1.144 – Auditing of Quality Assurance Programs for Nuclear Power Plants (Revision 1, September 1980)
- A.146 Regulatory Guide 1.146 – Qualification of Quality Assurance Program Audit Personnel for Nuclear Power Plants (August 1980)
- A.155 Regulatory Guide 1.155 – Station Blackout (August 1988)

HNP-2 FSAR

LIST OF TABLES

<u>Table No.</u>	<u>Table Title</u>
1.1-1	Drawings Incorporated by Reference into the FSAR (HNP-1 and HNP-2)
1.2-1	(Deleted)
1.2-2	Original and Updated Reactor Operating Conditions
1.3-1	<i>Nuclear Plants Principal Plant Design Features Comparison</i>
1.6-1	<i>Reference Topical Reports</i>
2.3-1	Meteorological Data for Savannah, Georgia
2.3-2	Meteorological Data for Macon, Georgia
2.3-3	Table of Fujita-Pearson Tornado Scale
2.3-4	Windspeed Distribution
2.3-5	Cumulative Windspeed Distribution
2.3-6	(Deleted)
2.3-7	Meteorological Instrumentation at the Plant Site (HNP-1 and HNP-2)
2.3-8	(Deleted)
2.3-9	Joint Frequency Tables of Windspeed and Direction for 75-ft Level
2.3-10	Joint Frequency Tables of Windspeed and Direction for 150-ft Level
2.3-11	Atmospheric Dispersion Factors for Accident Evaluation Based on 4 Years of Site Data (6/70 - 9/74)
2.3-12	Temperature Difference Groups for Determining Pasquill Stability Categories
2.3-13	Joint Frequency Tables of Windspeed and Direction
2.3-14	Joint Frequency Tables of Windspeed and Direction
2.3-15	Joint Frequency Tables of Windspeed and Direction
2.3-16	Joint Frequency Tables of Windspeed and Direction
2.3-17	List of Computer Runs
2.3-18	Gaseous Discharge Points (HNP-1 and HNP-2)
2.3-19	Vent Design Information (HNP-1 and HNP-2)
2.3-20	Tabulation of Input Assumptions for Calculations
2.3-21	Atmospheric Dispersion Factor for HNP
2.3-22	Atmospheric Dispersion Factors for HNP
2.3-23	Diffusion and Deposition Estimates for all Receptor Locations
2.3-24	Diffusion and Deposition Estimates for all Receptor Locations
2.3-25	X/Q Values at MCR Air Intake and TSC Intake (s/m ³)
2.4-1	<i>Access to Safety-Related Structures</i>
2.4-2	<i>Average, Maximum, Minimum Temperature of Altamaha River Water Temperature (°C)</i>
2.4-3	<i>Summary of Data on Dams</i>
2.4-4	<i>Gauging Station Records - Altamaha River Basin Altamaha at Charlotte and Baxley, Georgia Annual Flood Peaks</i>
2.4-5	<i>Summary of Flood Discharge Studies (HNP-1 and HNP-2)</i>
2.4-6	<i>Probable Maximum Precipitation Adjustment Factor Altamaha River Above Nuclear Plant Site Storm of 5-10 July 1916 (GM 1-19) Transposed for Month of October (HNP-1 and HNP-2)</i>
2.4-7	<i>Results of Local Well Survey</i>
2.4-8	<i>Piezometer Data</i>
2.4-9	<i>Permeability and Porosity Data</i>

LIST OF TABLES (CONTINUED)

<u>Table No.</u>	<u>Table Title</u>
2.4-10	<i>Water Quality Analyses</i>
2.5-1	<i>Modified Mercalli Intensity Scale, 1931</i>
2.5-2	<i>Chronological Listing of Earthquakes within 200 Miles of the Edwin I. Hatch Nuclear Plant</i>
2.5-3	<i>Data for Epicenters Shown in Figure 2.5-15</i>
2.5-4	<i>Chronological Listing of Earthquakes (Intensity III and Greater) Shown in Figure 2.5-16 (Exclusive of Charleston-Summerville Area)</i>
2.5-5	<i>Chronological Listing of Earthquakes Centered in Charleston-Summerville Area (Intensity III and Greater)</i>
2A-1	<i>Classification Data</i>
2A-2	<i>In Situ Moisture Contents</i>
2A-3	<i>X-Ray Diffraction Tests Mineral Composition (%)</i>
2A-4	<i>Consolidation and Swell Test Data</i>
2A-5	<i>Triaxial Shear Data</i>
2A-6	<i>Summary of Settlement Estimate</i>
2A-7	<i>HNP-2 Inspection Auger Borings</i>
2A-8	<i>Total Settlement Values</i>
2A-9	<i>Criteria for Determining Allowable Differential Settlements Across Structures</i>
2A-10	<i>Summary of Reference Dates and Elevations Across Structures</i>
2A-11	<i>Summary of Differential Settlements Across Structures</i>
2A-12	<i>Calculation of Moment M_D Due to Building Settlement Penetrations Between Adjacent Structures</i>
2A-13	<i>Summary of Penetration Differential Settlements - HNP-2 Reactor Building and Soil</i>
2A-14	<i>Summary of Penetration Differential Settlements - Diesel Generator Building and Soil</i>
2A-15	<i>Summary of Penetration Differential Settlements - Main Stack and Soil</i>
2A-16	<i>Summary of Penetration Differential Settlements - Intake Structure and Soil</i>
2A-17	<i>Summary of Penetration Differential Settlements - HNP-2 Reactor Building and Radwaste Building</i>
2A-18	<i>Summary of Penetration Differential Settlements - HNP-2 Reactor Building and Control Building</i>
2A-19	<i>Summary of Penetration Differential Settlements - HNP-2 Reactor Building and Turbine Building</i>
2A-20	<i>Summary of Penetration Differential Settlements - HNP-2 Reactor Building and HNP-1 Reactor Building</i>
2A-21	<i>Cyclic Triaxial Test Data from Boring 2001A</i>
2A-22	<i>Summary of Density Determinations from Thin-Walled Tube Samples</i>
2A-23	<i>Test Pit and Density Test Summary - Modified Proctor</i>
2A-24	<i>Results of Unconfined Compression Strength Tests on K-Krete Cylinders</i>
2A-25	<i>Results of Unconsolidated Triaxial Shear Tests Undrained on K-Krete</i>
3.1-1	<i>Reactor Coolant Pressure Boundary Influent Lines</i>
3.1-2	<i>Reactor Coolant Pressure Boundary Effluent Lines</i>

HNP-2 FSAR

LIST OF TABLES (CONTINUED)

<u>Table No.</u>	<u>Table Title</u>
3.2-1	Seismic Category I Systems and Mechanical Components
3.2-2	Code Requirements for BWR Components and Systems
3.2-3	Code Status of Class I Primary Pressure Boundary Components
3.2-4	System P&IDs Showing Quality Group Classifications
3.2-5	(Deleted)
3.2-6	Placement of HNP-1 Valves in Nuclear Systems in HNP-2
3.3-1	Wind Loads (HNP-1 and HNP-2)
3.4-1	Seismic Category I Structures Exterior Entrance (HNP-1 and HNP-2)
3.5-1	Selected Missiles Outside Primary Containment
3.5-2	Selected Missiles Inside Primary Containment
3.5-3	Tornado/Turbine Missile Protective Barriers
3.5-4	Tabulation of Items and Description of Protection Against Tornado Missiles
3.7A-1	Damping Factors for Seismic Analysis in Percent of Critical Damping
3.7A-2	Formulas for Equivalent Foundation Spring Constants and Damping Coefficients (Rectangular Base)
3.7A-3	Summary of Frequency and Response Loads
3.7A-4	Comparison of Responses
3.7A.B-1	Relative Movements of Various Buildings
3.7A.B-2	Stresses in Ducts Buried in the Free Field
3.7A.B-3	Stresses in Ducts Connected to Building Structures
3.7A.B-4	Stresses in Buried Pipe
3.7A.B-5	Maximum Stresses in Buried Pipes and Ducts Due to Seismic Load
3.7A.B-6	Maximum Stresses in Buried Pipes (K-Krete Backfill)
3.7B-1	Critical Damping Ratios for Different Materials
3.7B-2	Comparison of Calculated Seismic Loads to Design Seismic Loads of Seismic Category I Equipment, DBE Condition
3.7B-3	Comparison of the Maximum Seismic Loads of RPV and Internals
3.8-1	(Deleted)
3.8-2	Summary of Containment Stresses
3.8-3	Summary of Stresses at Personnel Lock Area
3.8-4	Summary of Stress Limits
3.8-5	(Deleted)
3.8-6	(Deleted)
3.8-7	(Deleted)
3.8-8	Allowable Stresses for Different Loading Combinations
3.8-9	Summary of Stresses on Pedestal Rings
3.8-10	Summary of Stress Limits on Reactor Shield
3.8-11	Basic Materials for Construction of Internal Structures
3.8-12	Water Velocity at Intake Structure
3.8-13	Live Loads on Structures

HNP-2 FSAR

LIST OF TABLES (CONTINUED)

<u>Table No.</u>	<u>Table Title</u>
3.8-14	Loading Combination and Acceptance Criteria
3.8-15	Allowable Stresses for Different Loading Combinations
3.8-16	Basic Construction Materials for Seismic Category I Structures
3.8-17	Aggregate Tests
3.8-18	Cement Tests
3.8-19	Fly Ash Tests
3.8-20	Masonry Wall Reevaluation Results
3.8B-1	LTP Modification Summary
3.9-1	Event Load Combination Criteria
3.9-2	Main Steam Line Piping System (Class 1 Pipe)
3.9-3	Loading Combinations Under Various Plant Conditions
3.9-4	RPV Internals and Associated Equipment
3.9-5	HNP-2 Load Combinations (Seismic + LOCA)
3.9-6	Recirculation Piping System (Class 1 Pipe)
3.9-7	Snubber Evaluation for LOCA and DBE
3.9-8	Load Combinations for LOCA + DBE for Class 1 RCPB Components
3.9-9	ASME Code Class 2 and 3 Components
3.9-10	Safety-Related Mechanical Components Not Covered by ASME Code
3.9-11	Fuel Assembly with 100-mil Channels
3.9-12	RPV Support Equipment
3.9-13	Main Steam Relief Valves (Target Rock)
3.9-14	Main Steam Isolation Valves
3.9-15	Recirculation Pumps
3.9-16	Structural and Mechanical Loading Criteria
3.9-17	Hydraulic Control Unit Piping
3.9-18	SLC Pump
3.9-19	SLC Tank
3.9-20	RHR Pump
3.9-21	RHR Heat Exchanger
3.9-22	Core Spray Pump
3.9-23	HPCI Turbine
3.9-24	HPCI Pump
3.9-25	RCIC Turbine
3.9-26	RCIC Pump
3.9-27	Fuel Storage Racks
3.9-28	Recirculation Pipe and Pump Restraints
3.9-29	Design Criteria for ASME Class 2 and 3 Components
3.9-30	RHRSW 14-in. Pumps
3.9-31	Standby Service Water Pump
3.9-32	PSW Pumps
3.9-33	Active Valves in RCPB and Other Seismic Category I Systems (Bechtel Supplied)
3.9-34	Active Valves in RCPB and Other Seismic Category I Systems (GE Supplied)

HNP-2 FSAR

LIST OF TABLES (CONTINUED)

<u>Table No.</u>	<u>Table Title</u>
3.9-35	Design Criteria for HVAC Components Not Covered by ASME Code
3.9-36	Core Spray 10-in. Gate Valve
3.9-37	HPCI and Core Spray 10-in. Gate Valve
3.9-38	Feedwater 18-in. Gate Valve
3.9-39	RHR Pump Suction 24-in. Angle Valve
3.9-40	RHR Pump Suction 24-in. Gate Valve
3.9-41	RWC 6-in. Gate Valve
3.9-42	RHR Pump Discharge 20-in. Gate Valve
3.9-43	RCIC Piping 4-in. Gate Valve and RHR Head Spray 4-in. Valve
3.9-44	Main Steam Drain and CRD Return Piping 3-in. Gate Valve
3.9-45	Standby Service Water 6-in. Strainer
3.9-46	RHRSW 18-in. Strainer
3.9-47	Stress Summary of PSW 30-in. Strainer
3.9-48	RHR and Core Spray Systems Jockey Pumps
3.9-49	Diesel Engine Generating Unit
3.9-50	RHR Discharge Piping 24-in. Check Valve
3.9-51	RHR and CRD Hydraulic Systems 3-in. and 4-in. Check Valves
3.9-52	HPCI Steam Piping 10-in. Check Valve
3.9-53	RHR 4-in. Globe Valve
3.9-54	CRD Hydraulic System 3-in. Check Valve
3.9-55	Feedwater 18-in. Check Valve
3.9-56	Feedwater 18-in. Check Valve
3.9-57	Drywell Pneumatic System Filter Assembly
3.9-58	Flued Head XB-12
3.9-59	Flued Heads XB-16A and B
3.9-60	Flued Heads XB-36
3.9-61	Liquid Nitrogen Storage Tank and Related Piping
3.9-62	Reactor Building Safeguard System Cooling Units
3.9-63	SGTS Blower
3.9-64	Service Water to Diesel Expansion Joints
3.10-1	NSSS Class 1E Equipment Requiring Qualification
3.10-2	NSSS Panel Types
3.10-3	Seismic Qualification Test Summary - NSSS Control Panels and Local Panels and Racks
3.10-4	Seismic Qualification of Major BOP Electrical and Mechanical Equipment
3.10-5	Test Results for 600-V-ac Motor Control Center
3.10-6	Battery Charger Test Run Descriptions and Input Accelerations
3.10-7	100-kW Inverter Test Run Descriptions
3.10-8	Basler Relays Input Acceleration
3.10-9	Excess-Flow Check Valves Input Acceleration
3.10-10	SGTS Current-to-Current Converter Input Acceleration
3.10-11	Seismic Analysis of 18-in., 900-lb OSY Gate Valve (Motor Operator)
3.10-12	Seismic Test Report Index
3.10-13	Stress Levels for Valve Components

HNP-2 FSAR

LIST OF TABLES (CONTINUED)

<u>Table No.</u>	<u>Table Title</u>
3.10-14	Natural Frequencies of Valve Components 18-in. Valve
3.10-15	Stress Levels for Valve Components
3.10-16	Natural Frequencies of Valve Components 6-in. Valve
3.10-17	Tabulation of Stresses - PSW Pumps
3.10-18	Lateral Plane Testing
3.10-19	Longitudinal Plane Testing
3.10-20	Vertical Plane Testing
3.10-21	Class 1E Equipment Comprising the ATTS
3.10-22	Seismic Qualification Test Summary for ATTS Control Panels and Local Racks
3.11-1	Area Environmental Conditions for Equipment Qualification
4.2-1	Deformation Limit (For Reactor Internal Structures Only) (HNP-1 and HNP-2)
4.2-2	Primary Stress Limit (For Reactor Internal Structures Only) (HNP-1 and HNP-2)
4.2-3	Buckling Stability Limit (For Reactor Internal Structures Only) (HNP-1 and HNP-2)
4.2-4	Fatigue Limit (For Reactor Internal Structures Only) (HNP-1 and HNP-2)
4.2-5	Core Support Structures Stress Categories and Limits of Stress Intensity for Normal and Upset Conditions (HNP-2)
4.2-6	Core Support Structures Stress Categories and Limits of Stress Intensity for Emergency Conditions (HNP-2)
4.2-7	Core Support Structures Stress Categories and Limits of Stress Intensity for Faulted Conditions (HNP-2)
4.2-8	Steam Dryer, CS Lines, and Core Structure Materials (HNP-1 and HNP-2)
4.2-9	Design Loading Conditions and Combinations (HNP-2)
4.2-10	Maximum Differential Pressures Across RPV Assembly Internals (HNP-1)
4.2-11	Maximum Differential Pressures Across RPV Assembly Internals (HNP-2)
4.3-1	<i>Estimated Dosimeter and Vessel Peak Flux and Fluence (HNP-2)</i>
4.4-1	Plant Configuration Data (HNP-1 and HNP-2)
4A-1	<i>HNP-1 Initial Core Fuel</i>
4A-2	<i>HNP-2 Initial Core Fuel</i>
5.2-1	Design Temperature and Pressure and Maximum Test Pressure for RCPB Components
5.2-2	(Deleted)
5.2-3	Reactor Vessel Material Irradiation Surveillance Schedule
5.2-4	Nuclear Steam Supply System Safety Relief Valves and Electrical Backup: Set Pressures, Capacities, and Duration of Blowdown
5.2-5	Key Analysis Input Parameters and Assumptions for Extended Power Uprate Overpressure Protection Analysis
5.2-6	Reactor Coolant Pressure Boundary Materials
5.2-7	Beltline Art Values
5.2-8	Summary of Isolation/Alarm of Systems Monitored and Detection Methods Used
5.2-9	<i>RT_{NDT} Values for Reactor Vessel Materials (HNP-1)</i>
5.2-10	Limiting RPV Material ART _{NDT}

HNP-2 FSAR

LIST OF TABLES (CONTINUED)

<u>Table No.</u>	<u>Table Title</u>
5.2-11	ISP Test Matrix
5.4-1	Reactor Pressure Vessel Design Data
5.5-1	Reactor Recirculation System Design Characteristics
5.5-2	(Deleted)
5.5-3	RWC System Equipment Design Data
5.5-4	Limiterque Seismic and Environmental Test Report Index
5.5-5	Low-Low Set FMEA for Functional Components
5.5-6	LLS SRV System for HNP-2
6.1-1	ESFs Discussed in Other FSAR Chapters
6.2-1	Primary Containment System Design Parameters
6.2-2	Tabulation of Potential Secondary Containment Bypass Leakage
6.2-3	ESF Flow Input Parameters for LOCA Analysis (HNP-1 and HNP-2)
6.2-4	Primary System Energy Distribution When Recirculation Line Break Accident Occurs (HNP-1 and HNP-2)
6.2-5	(Deleted)
6.2-6	DBA-LOCA Initial Conditions, Assumptions, and Calculated Pressure Results (HNP-1 and HNP-2)
6.2-7	Drywell Temperature Envelope for Break Sizes of 0.01 ft ² , 0.1 ft ² , and 0.5 ft ² (HNP-1 and HNP-2)
6.2-8	Reactor Energy Distribution Following Recirculation Line Break (HNP-1 and HNP-2)
6.2-9	Secondary Containment Post-LOCA Heat Loads and Corner Room Cooler Capacities
6.2-10	Secondary Containment Pressure and Temperature Response Post-LOCA
6.2-11	Parameter Values for Calculating Hydrogen and Oxygen Concentrations in Containment
6.2-12	(Deleted)
6.2-13	(Deleted)
6.2-14	SGTS Component Description
6.2-15	SGTS Failure Analysis
6.2-16	(Deleted)
6.2-17	(Deleted)
6.2-18	(Deleted)
6.3-1	ECCS Performance Results (HNP-1 and HNP-2)
6.3-2	Single-Failure Assessment (HNP-1 and HNP-2)
6.3-3	Operational Parameters for LOCA Analyses (HNP-1 and HNP-2)
6.3-4	Plant ECCS Parameters [GE14 (10x10)] (HNP-1 and HNP-2)
6.3-5	Summary of LOCA Analysis Results (HNP-1 and HNP-2)
6.4-1	MCREC System Component Description (HNP-1 and HNP-2)
6.4-2	MCREC System Failure Analysis (HNP-1 and HNP-2)

LIST OF TABLES (CONTINUED)

<u>Table No.</u>	<u>Table Title</u>
6A-1	Maximum Values of Dynamic Reaction for Recirculation Outlet Line Break
6A-2	Effect of Acoustic Load at Time of Maximum Reaction
6A-3	Maximum Values of Dynamic Reaction for Feedwater Line Break
6A-4	Blowdown Mass, Energy Release Rate, and Break Areas for Lines in Drywell
6A-5	Blowdown Mass, Energy Release Rate, and Break Areas for Recirculation Outlet and Inlet, Feedwater, and Head Spray Lines
6A-6	Feedwater Line (20 Nodes)
6A-7	Recirculation Outlet
6A-8	Recirculation Inlet
6A-9	Head Spray Line
6A-10	Peak Pressure Table (Annulus)
6A-11	Main Steam Line Break (Upper Drywell)
6A-12	RHR Discharge Line (Lower Drywell)
6A-13	Peak Pressure Table (Drywell)
7.1-1	Instrumentation and Control Systems Classification
7.1-2	Similarity to Licensed Reactors
7.1-3	Supporting Systems for Safety Systems
7.2-1	RPS Instrumentation Specifications
7.2-2	Response Times Assumed for Safety Analysis
7.2-3	Channels Required for Functional Performance of RPS (Startup Mode)
7.2-4	Channels Required for Functional Performance of RPS (Run Mode)
7.3-1	HPCI System Instrument Specifications
7.3-2	ADS Instrument Trip Settings
7.3-3	Core Spray System Instrument Specifications
7.3-4	LPCI Instrument Specifications
7.3-5	HPCI System Minimum No. of Trip Channels Required for Functional Performance
7.3-6	ADS Minimum No. of Trip Channels Required for Functional Performance
7.3-7	Core Spray System Minimum No. of Trip Channels Required for Functional Performance
7.3-8	LPCI Minimum No. of Trip Channels Required for Functional Performance
7.3-9	Primary Containment and RPV Isolation Control System Isolation Setpoints
7.4-1	RCIC Instrument Specifications
7.4-2	Reactor Shutdown Cooling Bypasses and Interlocks
7.5-1	HNP-1 and HNP-2 Equipment Variables
7.6-1	Refueling Interlock Effectiveness
7.6-2	NMS Instrument Data
7.6-3	SRM System Trips
7.6-4	IRM System Trips
7.6-5	LPRM System Trips
7.6-6	(Deleted)
7.6-7	APRM System Trips
7.6-8	RBM System Trips

LIST OF TABLES (CONTINUED)

<u>Table No.</u>	<u>Table Title</u>
7.6-9	Primary Containment Atmosphere Monitors - Instrument Data
7.6-10	RWC System - MCR Annunciation
7.6-11	Leak Detection System Instrument Data
7.6-12	(Deleted)
7.6-13	PSW Instrument Trip Settings
7.7-1	RMCS Instrument Specifications
7.8-1	ATTS Instrument Loops
8.3-1	Tabulation of Loads on 4160-V Buses
8.3-2	(Deleted)
8.3-3	Sequence for Automatically Connecting Emergency ac Loads on LOCA/LOSP
8.3-4	Standby Diesel Generator System Emergency Loads
8.3-5	Loads on 600-V Essential Buses
8.3-6	Load Distribution on Emergency Buses (LOSP and 0-10 min Post-LOCA)
8.3-7	Diesel Engine Alarms
8.3-8	Diesel Generator Alarms
8.3-9	Diesel Engine Protection
8.3-10	Diesel Generator Protection
8.3-11	Possible Load Distribution on Emergency Buses (LOSP, 10-60 min Post-LOCA, RHR Loop A Available, and Loss of Bus 2E)
8.3-12	Possible Load Distribution on Emergency Buses (LOSP, 10-60 min Post-LOCA, RHR Loop A Available, and Loss of Bus 2F)
8.3-13	Possible Load Distribution on Emergency Buses (LOSP, 10-60 min, Post-LOCA, RHR Loop A Available, and Loss of Bus 2G)
8.3-14	Possible Load Distribution on Emergency Buses (LOSP, 10-60 min Post-LOCA, RHR Loop B Available, and Loss of Bus 2E)
8.3-15	Possible Load Distribution on Emergency Buses (LOSP, 10-60 min Post-LOCA, RHR Loop B Available, and Loss of Bus 2F)
8.3-16	Possible Load Distribution on Emergency Buses (LOSP, 10-60 min Post-LOCA, RHR Loop B Available, and Loss of Bus 2G)
8.3-17	Cable and Raceway Color Codes
8.3-18	Possible Load Distribution on Emergency Buses (LOSP, 10-60 min Post-LOCA, and Loss of Diesel Generator Battery 2A)
8.3.19	Possible Load Distribution on Emergency Buses (LOSP, 10-60 min Post-LOCA, and Loss of Diesel Generator Battery 2C)
8.3-20	Possible Load Distribution on Emergency Buses (LOSP, 10-60 min Post-LOCA, and Loss of Diesel Generator Battery 1B)
8.4-1	Possible Load Distribution on Emergency Bus 1F During SBO (HNP-1)
8.4-2	Possible Load Distribution on Emergency Bus 2F During SBO (HNP-2)
9.1-1	(Deleted)
9.1-2	General Electric Single-Cell, High-Density Fuel Storage Criticality Results
9.1-3	Holtec Single-Cell, High-Density Fuel Storage Criticality Results
9.1-4	FPPCS Parameters and Equipment List

LIST OF TABLES (CONTINUED)

<u>Table No.</u>	<u>Table Title</u>
9.2-1	PSW System Equipment Data
9.2-2	PSW System Component Requirements
9.2.3	(Deleted)
9.2-4	RBCCW System Equipment Data
9.2-5	Condensate Storage and Transfer System Component Description
9.2-6	RHRSW System Design Parameter
9.2-7	Normalized Decay Heat
9.2-8	Integrated Decay Heat (HNP-2)
9.2-9	Decay Heat Rejection Rate
9.2-10	Auxiliary Heat Rejection Rate (Btu/s)
9.2-11	Integrated Auxiliary Heat Rejected
9.2-12	Sensible Heat Rejection Rate
9.2-13	Integrated Sensible Heat Rejected
9.2-14	Total Integrated Heat Rejected
9.2-15	Decay Heat Release Rate
9.2-16	Decay Heat Rejection Rate
9.2-17	Integrated Decay Heat
9.2-18	Total Integrated Heat Rejected
9.3-1	Pneumatically Operated Valves Provided with Accumulators
9.3-2	Process Sampling Systems
9.4-1	MCR Air-Conditioning and Filtration System Component Description
9.4-2	MCR HVAC Systems Failure Analysis
9.4-3	Description of Reactor Building HVAC System, and Reactor Building and Radwaste Building Chilled Water System Major Components
9.4-4	Reactor Building HVAC System, and Reactor Building and Radwaste Building Chilled Water System Failure Analyses
9.4-5	Radwaste Area HVAC System Major Components
9.4-6	Radwaste Area HVAC System Failure Analyses
9.4-7	Description of Turbine Building HVAC System Major Components
9.4-8	Turbine Building HVAC System Failure Analyses
9.4-9	Diesel Generator Building Heating and Ventilation System Components
9.4-10	Diesel Generator Building Heating and Ventilation System Failure Analyses
9.4-11	Results of Analyses on Diesel Engine Combustion Air Intake System
9.4-12	Primary Containment (Drywell) Cooling System Equipment List
9.4-13	Primary Containment (Drywell) Cooling System Failure Analyses
9.4-14	Control Building HVAC Systems Equipment List
9.4-15	Control Building HVAC Systems Failure Analyses
9.4-16	Waste Gas Treatment Building HVAC System Equipment List
9.4-17	Waste Gas Treatment Building HVAC System Failure Analysis
9.4-18	TSC HVAC System Equipment List
9.4-19	TSC HVAC System Failure Analysis
9.4-20	River Intake Structure Ventilation System Failure Analysis
9.5-1	Noise Attenuation Characteristics of Full-Length Booths (HNP-1 and HNP-2)
9.5-2	Noise Attenuation Characteristics of Scout Shelf Booths (HNP-1 and HNP-2)

HNP-2 FSAR

LIST OF TABLES (CONTINUED)

<u>Table No.</u>	<u>Table Title</u>
9.5-3	Failure Analysis of Diesel Generator Fuel Oil System
9.5-4	Diesel Generator Auxiliary Systems Quality Group Data (HNP-2)
9.5-5	Doses Resulting from MSIV Leakage Following a LOCA
10.2-1	Turbine-Generator Design Conditions
10.2-2	High-Trajectory Turbine Missile Strike Probabilities
10.2-3	Thickness of Protective Concrete and Calculated Penetration Depth for Vital Areas of Plant
11.1-1	Noble Radiogas Source Terms
11.1-2	Halogen Isotopes in Reactor Water
11.1-3	Other Fission Product Isotopes in Reactor Water
11.1-4	Coolant Activation Products in Reactor Water and Steam
11.1-5	Noncoolant Activation Products in Reactor Water
11.1-6	Major Radioisotopes in Steam at Reactor Nozzle
11.1-7	Major Radioisotopes in Main Condenser
11.1-8	Post-Operation Gamma Sources in Core (MeV/s/W)
11.1-9	Fast Neutron and Multigroup Gamma Fluxes Outside the RPV
11.1-10	Parameters Used to Describe the Boiling Water Reactor System-Realistic Basis
11.1-11	Specific Activities in Principal Fluid Streams-Realistic Basis
11.2-1	Design Codes for Major Liquid Radwaste System Components
11.2-2	Capacity and Maximum Activity Contained in Liquid Radwaste Tanks
11.2-3	Gale Input Data (BWR Gale Code Input Data File)
11.2-4	Expected Annual Releases (BWR Gale Code Output Data File)
11.2-5	Maximum Individual Doses from Liquid Effluents (mrem/year) (LADTAP Output File)
11.3-1	Estimated Process Off-Gas Release Rates from Main Condenser (with 40 sf ³ /min In-Leakage and Based on a 1971 Mixture)
11.3-2	Inventory Activities for Off-Gas RECHAR Equipment (μCi)
11.3-3	Off-Gas System Major Equipment Items
11.3-4	Off-Gas System Process Instrument Annunciators in MCR
11.3-5	Off-Gas System Equipment Malfunction Analysis
11.3-6	Gale Code Data (HNP-1 and HNP-2)
11.3-7	Maximum Doses from Gaseous Effluents (HNP-1 and HNP-2)
11.4-1	Gaseous and Airborne Radiation Monitors
11.4-2	Liquid Radiation Monitors
11.4-3	Process Radiation Monitors Environmental Design Parameters
11.4-4	Radiological Analysis Summary of Liquid Process Samples
11.4-5	Radiological Analysis Summary of Gaseous Process Samples
11.4-6	Radiological Analysis Summary of Liquid Effluent Samples
11.4-7	Radiological Analysis Summary of Gaseous Effluent Samples
11.5-1	Solid Radwaste Volumes
11.5-2	Solid Radwaste Activities

HNP-2 FSAR

LIST OF TABLES (CONTINUED)

<u>Table No.</u>	<u>Table Title</u>
11.5-3	Surface Dose Rates from Radwaste Shipping Containers
11.5-4	Percent of Isotopic Composition of Solid Radwaste at Maximum Activity
11.5-5	Curie Content of Shipping Containers
12.1-1	Radiation Control Area Classifications
12.2-1	Parameters for Calculating Airborne Radioactivity Concentrations
12.2-2	Peak Airborne Concentrations in Different Regions of Plant
12.3-1	Location and Range of Area Monitors
12.3-2	Shielding Design Bases Limitations (HNP-1 and HNP-2)
12.4-1	Estimated Annual Gamma Dose to Plant Personnel and Expected Number of Manhours of Occupancy per Year
12.4-2	Plant Staff Classification - Working Time and Zone Distribution
12.4-3	Estimated Annual Inhalation Doses to Plant Personnel Due to Airborne Radioactivity
12.5-1	Portable Health Physics Instruments
12.5-2	Fixed Laboratory Instruments
<i>14.1-1</i>	<i>Major Plant Transients</i>
<i>14.1-2</i>	<i>Stability Tests</i>
<i>14.1-3</i>	<i>Startup Test Program</i>
15.1-1	Supplemental Reload Licensing Reports
15.1-2	Major Event Updates
15.1-3	Event Acceptance Limits
15.1-4	Selected Safety Analysis Input Parameters
15.2-1	Power Uprate Transient Analysis Results
15.2-2	Notes for Figure 15.2-3
15.2-3	Analyses of AOOs Initial Conditions
15.2-4	Summary of Results for Detailed and Point Kinetics Evaluations of Continuous Rod Withdrawal in Startup Range (Initial Core)
15.2-5	Key Analysis Assumptions for Power Uprate Analysis of Loss of Feedwater Flow
15.3-1	CRDA (Event 31) Realistic Analysis Initial Core Activity Airborne in the Condenser (Ci)
15.3-2	CRDA (Event 31) Realistic Analysis Initial Core Activity Released to the Environment (Ci)
15.3-3	LOCA (Event 32) Realistic Analysis Initial Core Activity Airborne in the Primary Containment (Ci)
15.3-4	LOCA (Event 32) Realistic Analysis Initial Core Activity Airborne in the Reactor Building (Ci)
15.3-5	LOCA (Event 32) Realistic Analysis Initial Core Activity Released to the Environment (Ci)
15.3-6	LOCA (Event 32) NRC Analysis Radiological Effects (rem)
15.3-7	MSLBA (Event 33) Realistic Analysis Initial Core Activity Released to the Environment (Ci)

HNP-2 FSAR

LIST OF TABLES (CONTINUED)

<u>Table No.</u>	<u>Table Title</u>
15.3-8	MSLBA (Event 33) NRC Analysis Initial Core Radiological Effects
15.3-9	Fuel-Handling Accident (Event 34) Realistic Analysis Initial Core Activity Airborne in the Refueling Area (Ci)
15.3-10	Fuel-Handling Accident (Event 34) Realistic Analysis Initial Core Activity Released to the Environment (Ci)
15.4-1	Key Initial Conditions and Assumptions for ATWS Analysis
15.4-2	Summary of Analysis Results for ATWS
15.4-3	Summary of Analysis Results for Turbine and Generator Trips Without Bypass (No Direct Scram, No RPT) Analysis
15.4-4	Radiological Effects of Offgas (RECHAR) System Failure
15.4-5	Failure of SJAE Lines Activity Released to Environment
15.4-6	Key Initial Conditions and Assumptions for SBO Analysis
15.4-7	Summary of Analysis Results for SBO
15A-1	Moderate-and High-Energy Lines
15A-2	Blowdown Data for High-Energy Line Breaks
15A-3	Equipment Required and/or Preferred for Use in Reactor Shutdown Following a High-Energy Line Break Outside Primary Containment
15C-1	Operational Criteria
15C-2	BWR Operating States/Operating Modes
15C-3	Events Associated With Operating States
15C-4	Key Bounding Parameters for Planned Operation
15C-5	Required Actions
15C-6	Event Analysis Rules
15C-7	NSOA System/Event Matrix
15C-8	NSOA Automatic Instrument Trip/Event Matrix
15C-9	NSOA Monitored Parameter/Event Matrix for the Safety Analysis
15C-10	NSOA Auxiliary System/Event Matrix
15C-11	Limiting Safety System Settings
17.2-1	E.I. Hatch Nuclear Plant QA/QC Procedures (Deleted)
17.2-2	<i>List of Safety-Related Structures, Systems, and Components</i>
17.2A-1	Classification of Independent Spent Fuel Storage Installation's Structures, Systems, and Components (Deleted)
18.3.1-1	Activities Performed to Manage Aging Effects for Fire Protection System Components
18.5-1	Summary Listing of Calculations and Analyses Meeting the Six Time Limited Aging Analyses Criteria

HNP-2 FSAR

LIST OF FIGURES

<u>Figure No.</u>	<u>Figure Title</u>
1.2-1	Plant Property Plan
1.2-2	Reactor System Heat Balance for 100% Rated Condition or 2804 MWt (HNP-2)
1.2-3	Reactor System Heat Balance for 100% Rated Condition or 2804 MWt (HNP-1)
1.2-4	Property Plan and Principal Structures
1.2-5	Rated Turbine-Generator Heat Balance (HNP-2)
1.2-6	(Deleted)
1.2-7	Rated Turbine-Generator Heat Balance (HNP-1)
1.2-8	(Deleted)
2.1-1	Edwin I. Hatch Nuclear Plant Site
2.1-2	Local Site Environs
2.1-3	Site Property Plan
2.1-4	Population Distribution (0-10 Miles)
2.1-5	Population Distribution (10-50 Miles)
2.1-6	Population Distribution (0-5 Miles)
2.2-1	Industrial and Military Facilities Transportation and Pipeline Routings in Site Environs
2.3-1	Monthly Max., Avg., and Min. Temperature for Glennville, Ga.
2.3-2	Monthly Avg. and 24-h Precipitation for Glennville, Ga.
2.3-3	Total Number of Hail Reports 3/4 in. and Greater, 1955-1967 by 1 Degree Squares (Based on SELS Log)
2.3-4	Total Number of Hail Reports 3/4 in. and Greater, 1955-1967, by 2 Degree Squares (Based on SELS Log)
2.3-5	Total Tornadoes, 1955-1967, by 1 Degree Squares (Based on SELS Log)
2.3-6	Total Tornadoes, 1955-1967, by 2 Degree Squares (Based on SELS Log)
2.3-7	Percent of Probability of Exceeding Ordinate Value of the Windspeed
2.3-8	Calculated Tornadoes Windspeed by 5 Degree Squares for 10^{-7} Probability per Year
2.3-9	Total Windstorms, 50 Knots and Greater, 1955-1967, by 1 Degree Squares (Based on SELS Log)
2.3-10	Total Windstorms, 50 Knots and Greater, 1955-1967, by 2 Degree Squares (Based on SELS Log)
2.3-11	Regional Topography
2.3-12	Topographical Profile
2.3-13	Site Topographic Map
2.3-14	Hatch Site 150-ft Annual Wind Rose Based on 4 Years of Data
2.3-15	Hatch Site 150-ft Monthly and Seasonal Wind Roses Based on 4 Years of Site Data
2.3-16	Comparison of Measured Windspeed vs. Height
2.4-1	<i>Edwin I. Hatch Nuclear Plant Site</i>

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
2.4-2	<i>Local Site Environs</i>
2.4-3	<i>Site Topographic Map</i>
2.4-4	<i>Hatch Structures General Arrangement Plan</i>
2.4-5	<i>Location of Hatch Nuclear Plant</i>
2.4-6	<i>Altamaha Drainage Basin</i>
2.4-7	<i>Overall Site Drainage Plan</i>
2.4-8	<i>Altamaha River at HNP Stage Discharge Relation High Flows</i>
2.4-9	<i>Isohyetal Map for Probable Maximum Precipitation - Altamaha River Above Plant Site</i>
2.4-10	<i>Probable Maximum Flood Altamaha River</i>
2.4-11	<i>Hydrograph - 1948 Flood</i>
2.4-12	<i>Hydrograph - 1961 Flood</i>
2.4-13	<i>Adopted 6-h Unit Hydrograph Altamaha River at Nuclear Power Plant Site</i>
2.4-14	<i>Locations of Sections Run in 1967 for Backwater Gradient Study</i>
2.4-15	<i>Isohyetal Map</i>
2.4-16	<i>Probable Maximum Precipitation Adjustment Factor</i>
2.4-17	<i>Storm Hydrograph</i>
2.4-18	<i>Discharge Stage Frequency Curves - Altamaha River at U.S. Highway 1 Crossing Georgia</i>
2.4-19	<i>Sinclair Dam Plan and Elevation</i>
2.4-20	<i>Sinclair Dam Sections</i>
2.4-21	<i>Sinclair Dam Hydrograph During Spillway Design Flood</i>
2.4-22	<i>Lloyd Shoals Dam Plan, Elevation, and Sections</i>
2.4-23	<i>Lloyd Shoals Project General Plan and Sections</i>
2.4-24	<i>Lloyd Shoals Dam Failure Study</i>
2.4-25	<i>Sinclair Dam Generation Test Stage Curves</i>
2.4-26	<i>Sinclair Dam Generation Test Discharge Curves</i>
2.4-27	<i>Hydrograph at Baxley, Georgia from Sinclair Turbine Release (Units 1 and 2)</i>
2.4-28	<i>Wallace Dam General Plan of Development</i>
2.4-29	<i>Wallace Dam Plan and Downstream Elevation</i>
2.4-30	<i>Wallace Dam Typical Sections</i>
2.4-31	<i>Wallace Dam Reservoir Capacity Curve</i>
2.4-32	<i>Wallace Dam Spillway Rating Curve Used in 1972</i>
2.4-33	<i>Wallace Dam Spillway Design Flood</i>
2.4-34	<i>Altamaha River at HNP Stage Discharge Relation Low Flows</i>
2.4-35	<i>Profile of Principal Artesian Aquifer, NW-SE</i>
2.4-36	<i>Well Locations in Plant Vicinity</i>
2.4-37	<i>Site Piezometer and Well Locations</i>
2.4-38	<i>Detail of Site Wells</i>
2.4-39	<i>Contours of Unconfined Water Surface</i>
2.4-40	<i>Contours of Potentiometric Surface, Minor Confined Aquifer</i>
2.4-41	<i>Piezometer Levels</i>

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
2.4-42	<i>Site Piezometer Levels</i>
2.4-43	<i>Altamaha River Profile at Intake</i>
2.5-1	<i>Regional Physiographic Map</i>
2.5-2	<i>Regional Geologic Map</i>
2.5-3	<i>Regional Tectonic Map</i>
2.5-4	<i>Regional Geologic Column</i>
2.5-5	<i>Regional Geologic Profile NW-SE</i>
2.5-6	<i>Regional Geologic Profile NE-SW</i>
2.5-7	<i>Crustal Movement Map</i>
2.5-8	<i>Site Geologic Column</i>
2.5-9	<i>Contours on Top of Unit 5 Hawthorn Formation</i>
2.5-10	<i>Site Geologic Map</i>
2.5-11	<i>Area Geologic Map</i>
2.5-12	<i>Seismic Risk Map</i>
2.5-13	<i>Tectonic and Epicenter Map</i>
2.5-14	<i>Isoseismal Map of 1886 Charleston, S.C., Earthquake</i>
2.5-15	<i>Epicentral Locations Near the Goat Rock Fault</i>
2.5-16	<i>South Carolina Earthquake Epicenters 1799 to 1975</i>
2.5-17	<i>Bouguer Gravity Anomaly Map Southeastern United States</i>
2.5-18	<i>Index of Aeromagnetic Coverage Alabama, Georgia, and South Carolina</i>
2.5-19	<i>Postulated Faults in Site Vicinity</i>
2.5-20	<i>Boreholes at Bay Creek</i>
2.5-21	<i>Test Boring Record Boring Numbers D and F</i>
2A-1	<i>Foundation Borings Location Plan</i>
2A-2	<i>Boring and Profile Locations in Plant Area</i>
2A-3	<i>(Sheet 1 of 7) Subsurface Profiles A-A</i>
2A-3	<i>(Sheet 2 of 7) Subsurface Profiles B-B</i>
2A-3	<i>(Sheet 3 of 7) Subsurface Profiles C-C</i>
2A-3	<i>(Sheet 4 of 7) Subsurface Profiles D-D</i>
2A-3	<i>(Sheet 5 of 7) Subsurface Profiles E-E</i>
2A-3	<i>(Sheet 6 of 7) Subsurface Profiles F-F</i>
2A-3	<i>(Sheet 7 of 7) Subsurface profiles G-G</i>
2A-4	<i>Seismic Traverse Lines</i>
2A-5	<i>Refraction Survey Line 1</i>
2A-6	<i>Refraction Survey Line 2</i>
2A-7	<i>Surface Distribution of Geologic Formations</i>
2A-8	<i>(Sheet 1 of 34 Through Sheet 29 of 34) Grain Size Distribution</i>
2A-8	<i>(Sheet 30 of 34) Comparison of Results of Grain Size Tests with Depth for HNP-1 and HNP-2</i>
2A-8	<i>(Sheet 31 of 34) Comparison of HNP-1 and HNP-2 Grain Size Curves Between el 72 ft and 76 ft</i>

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
2A-8	<i>(Sheet 32 of 34) Comparison of HNP-1 and HNP-2 Grain Size Curves Between el 63 ft and 64 ft</i>
2A-8	<i>(Sheet 33 of 34) Comparison of HNP-1 and HNP-2 Grain Size Curves Between el 48 ft and 54 ft</i>
2A-8	<i>(Sheet 34 of 34) Comparison of HNP-1 and HNP-2 Grain Size Curves Between el 34 ft and 38 ft</i>
2A-9	<i>Consolidation Test Results</i>
2A-10	<i>Comparison of Consolidation Test Curves for HNP-1 and HNP-2</i>
2A-11	<i>Triaxial Shear Test Results</i>
2A-12	<i>Initial-to-Partial Liquefaction</i>
2A-13	<i>Complete Liquefaction</i>
2A-14	<i>Intake Foundation Inspection</i>
2A-15	<i>HNP-1 Histograms before and after Excavation</i>
2A-16	<i>HNP-2 Histograms before and after Excavation</i>
2A-17	<i>HNP-2 Building Settlement</i>
2A-18	<i>HNP-1 Building Settlement</i>
2A-19	<i>Average Elastic Moduli</i>
2A-20	<i>Elastic Moduli - Surficial Hawthorn</i>
2A-21	<i>Elastic Moduli - Upper Hawthorn</i>
2A-22	<i>Elastic Moduli - Middle Hawthorn</i>
2A-23	<i>Elastic Moduli - Lower Hawthorn</i>
2A-24	<i>Liquefaction Study</i>
2A-25	<i>(Deleted)</i>
2A-26	<i>Allowable Settlement Profile Slope Calculation Procedure</i>
2A-27	<i>Pseudostatic Stability Analysis of River Bluff for DBE</i>
2A-28	<i>Cyclic Strength for Soils at River Bluff</i>
2A-29	<i>Cyclic Triaxial Test Boring No. 2001 Sample No. UD-6 Test Sample A</i>
2A-30	<i>River Bank Soil Profile</i>
2A-31	<i>Factors of Safety Against Liquefaction for Sands at River Bluff</i>
2A-32	<i>Zero Strength Analysis of River Bluff</i>
2A-33	<i>Stability Analysis for DBE Assuming Extended Loose Zone of Soil 4</i>
2A-34	<i>Stability Analysis for DBE Extended Loose Zone of Soil 4 and Reevaluated Strength for Soil 2</i>
2A-35	<i>Stability Analysis for DBE Assuming Water in Slope at el 122 ft</i>
2A-36	<i>Earth Pressure Diagram</i>
2A-37	<i>Excavation Plan and Sections</i>
2A-38	<i>Compaction Test</i>
2A-39	<i>Location of Asphalt Pavement Failure</i>
2A-40	<i>Existing Conditions Section A-A (From Figure 2A-39)</i> <i>Summary of Phases I and II Field Investigations</i>
2A-41	<i>Subsurface Profiles</i>
2A-42	<i>Preconstruction Conditions Section A-A (From Figure 2A-39)</i>
2A-43	<i>Construction Procedure Section A-A (From Figure 2A-39)</i>

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
2A-44	<i>SPT Results for Backfill in East Side of Intake Structure</i>
2A-45	<i>SPT Results for Backfill in West Side of Intake Structure</i>
2A-46	<i>SPT Results for Backfill in South Side of Intake Structure</i>
2A-47	<i>Horizontal Plate Load Test on Sand Backfill, TP-1 18-in.-Diameter Plate at Depth of 10 ft on West Wall</i>
2A-48	<i>Horizontal Plate Load Test on Sand Backfill, TP-1 30-in.-Diameter Plate at Depth of 12 ft on East Wall</i>
2A-49	<i>Vertical Plate Load Test on Sand Backfill, TP-2 12-in. Plate at Depth of 10 ft</i>
2A-50	<i>Horizontal Plate Load Test on Sand Backfill, TP-5 12-in. Square Plate at Depth of 10 ft West Wall</i>
2A-51	<i>Horizontal Plate Load Test on Sand Backfill, TP-5 18-in.-Diameter Plate at Depth of 10 ft on East Wall</i>
2A-52	<i>7-Day Vertical Plate Load Test on K-Krete 18-in.-Diameter Plate South End of Test Slab</i>
2A-53	<i>7-Day Vertical Plate Load Test on K-Krete 30-in.-Diameter Plate South End of Test Slab</i>
2A-54	<i>Approximate Elevations of Virgin Ground Before K-Krete Backfill</i>
2A-55	<i>Intake Structure Finished Graveling and Paving Plan</i>
2B-1	<i>Test Boring Record Boring No. 102</i>
2B-2	<i>Test Boring Record Boring No. 103</i>
2B-3	<i>Test Boring Record Boring No. 109</i>
2B-4	<i>Test Boring Record Boring No. 110</i>
2B-5	<i>Test Boring Record Boring No. 300</i>
2B-6	<i>Test Boring Record Boring No. 301</i>
2B-7	<i>Test Boring Record Boring No. 306</i>
2B-8	<i>Test Boring Record Boring No. 307</i>
2B-9	<i>Test Boring Record Boring No. 309</i>
2B-10	<i>Test Boring Record Boring No. 317</i>
2B-11	<i>Test Boring Record Boring No. 318</i>
2B-12	<i>Test Boring Record Boring No. 320</i>
2B-13	<i>Test Boring Record Boring No. 401</i>
2B-14	<i>Test Boring Record Boring No. 402</i>
2B-15	<i>Test Boring Record Boring No. 403</i>
2B-16	<i>Test Boring Record Boring No. 404</i>
2B-17	<i>Test Boring Record Boring No. 405</i>
2B-18	<i>Test Boring Record Boring Nos. 406 and 407</i>
2B-19	<i>Test Boring Record Boring No. 408</i>
2B-20	<i>Test Boring Record Boring No. 409</i>
2B-21	<i>Test Boring Record Boring No. 410</i>
2B-22	<i>Test Boring Record Boring No. 411</i>
2B-23	<i>Test Boring Record Boring No. 412</i>
2B-24	<i>Test Boring Record Boring No. 413</i>

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
2B-25	<i>Test Boring Record Boring No. 415</i>
2B-26	<i>Test Boring Record Boring No. 416</i>
2B-27	<i>Test Boring Record Boring No. 417</i>
2B-28	<i>Test Boring Record Boring No. 418</i>
2B-29	<i>Test Boring Record Boring No. 419</i>
2B-30	<i>Test Boring Record Boring No. 420</i>
2B-31	<i>Test Boring Record Boring No. 421</i>
2B-32	<i>Test Boring Record Boring No. 422</i>
2B-33	<i>Test Boring Record Boring No. 423</i>
2B-34	<i>Test Boring Record Boring Nos. 424, 425, and 426</i>
2B-35	<i>Test Boring Record Boring No. 427</i>
2B-36	<i>Test Boring Record Boring No. 428</i>
2B-37	<i>Test Boring Record Boring No. 429</i>
2B-38	<i>Test Boring Record Boring No. 430</i>
2B-39	<i>Test Boring Record Boring No. 431</i>
2B-40	<i>Test Boring Record Boring No. 432</i>
2B-41	<i>Test Boring Record Boring No. 433</i>
2B-42	<i>Test Boring Record Boring No. 434</i>
2B-43	<i>Test Boring Record Boring No. 435</i>
2B-44	<i>Test Boring Record Boring No. 436</i>
2B-45	<i>Test Boring Record Boring No. 437</i>
2B-46	<i>Test Boring Record Boring No. 438</i>
2B-47	<i>Test Boring Record Boring No. 439</i>
2B-48	<i>Test Boring Record Boring No. 440</i>
2B-49	<i>Test Boring Record Boring No. 441</i>
2B-50	<i>Test Boring Record Boring Nos. 442, 443, and 444</i>
2B-51	<i>Test Boring Record Boring Nos. 445, 446, and 448</i>
2B-52	<i>Test Boring Record Boring Nos. 449, 450, and 451</i>
2B-53	<i>Test Boring Record Boring Nos. 452, 453, and 454</i>
2B-54	<i>Test Boring Record Boring No. 455</i>
2B-55	<i>Test Boring Record Boring No. 456</i>
2B-56	<i>Test Boring Record Boring No. 457</i>
2B-57	<i>Test Boring Record Boring No. 458</i>
2B-58	<i>Test Boring Record Boring No. 459</i>
2B-59	<i>Test Boring Record Boring No. 460</i>
2B-60	<i>Test Boring Record Boring Nos. 461, 462, and 463</i>
2B-61	<i>Test Boring Record Boring Nos. 464, 465, and 466</i>
2B-62	<i>Test Boring Record Boring No. 475</i>
2B-63	<i>Test Boring Record Boring No. 477</i>
2B-64	<i>Test Boring Record Boring No. 478</i>
2B-65	<i>Test Boring Record Boring No. 479</i>
2B-66	<i>Test Boring Record Boring No. 480</i>
2B-67	<i>Test Boring Record Boring No. 481</i>

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
2B-68	<i>Test Boring Record Boring No. 482</i>
2B-69	<i>Test Boring Record Boring No. 483</i>
2B-70	<i>Test Boring Record Boring Nos. 484 and 485</i>
2B-71	<i>Test Boring Record Boring Nos. 486 and 487</i>
2B-72	<i>Test Boring Record Boring Nos. 488 and 489</i>
2B-73	<i>Test Boring Record Boring No. 490</i>
2B-74	<i>Test Boring Record Boring No. 494</i>
2B-75	<i>Test Boring Record Boring No. 495</i>
2B-76	<i>Test Boring Record Boring No. 511</i>
2B-77	<i>Test Boring Record Boring No. 512</i>
2B-78	<i>Test Boring Record Boring No. 516</i>
2B-79	<i>Test Boring Record Boring No. 519</i>
2B-80	<i>Test Boring Record Boring No. 521</i>
2B-81	<i>Test Boring Record Boring No. 522</i>
2B-82	<i>Test Boring Record Boring No. 529</i>
2B-83	<i>Test Boring Record Boring No. 548</i>
2B-84	<i>Test Boring Record Boring Nos. 549 and 550</i>
2B-85	<i>Test Boring Record Boring Nos. 551 and 552</i>
2B-86	<i>Test Boring Record Boring Nos. 556 and 557</i>
2B-87	<i>Test Boring Record Boring Nos. 558 and 559</i>
2B-88	<i>Test Boring Record Boring Nos. 560 and 561</i>
2B-89	<i>Test Boring Record Boring Nos. 562 thru 567</i>
2B-90	<i>Test Boring Record Boring Nos. 568 thru 573</i>
2B-91	<i>Test Boring Record Boring Nos. 574 and 575</i>
2B-92	<i>Test Boring Record Boring No. 576</i>
2B-93	<i>Test Boring Record Boring No. 577</i>
2B-94	<i>Test Boring Record Boring Nos. 578 and 579</i>
2B-95	<i>Test Boring Record Boring Nos. 580, 581, and 584</i>
2B-96	<i>Test Boring Record Boring No. 585</i>
2B-97	<i>Test Boring Record Boring No. 586</i>
2B-98	<i>Test Boring Record Boring Nos. 587, 588, and 589</i>
2B-99	<i>Test Boring Record Boring Nos. 590, 591, and 592</i>
2B-100	<i>Test Boring Record Boring Nos. 593, 594, and 595</i>
2B-101	<i>Test Boring Record Boring Nos. 596, 597, and 598</i>
2B-102	<i>Test Boring Record Boring Nos. 599 and 600</i>
2B-103	<i>Test Boring Record Boring No. 603</i>
2B-104	<i>Test Boring Record Boring Nos. 1001, 1002, and 1003</i>
2B-105	<i>Test Boring Record Boring Nos. 1004, 1005, and 1006</i>
2B-106	<i>Test Boring Record Boring Nos. 1007, 1008, and 1009</i>
2B-107	<i>Test Boring Record Boring Nos. 1010, 1011, and 1012</i>
2B-108	<i>Test Boring Record Boring Nos. 1013, 1014, and 1015</i>
2B-109	<i>Test Boring Record Boring Nos. 1016, 1017, and 1018</i>
2B-110	<i>Test Boring Record Boring Nos. 1019, 1020, and 1021</i>

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
2B-111	<i>Test Boring Record Boring Nos. 1022, 1023, and 1024</i>
2B-112	<i>Test Boring Record Boring Nos. 1025, 1026, and 1028</i>
2B-113	<i>Test Boring Record Boring No. RFI-1</i>
2B-114	<i>Test Boring Record Boring No. RFI-2</i>
2B-115	<i>Test Boring Record Boring No. RFI-3</i>
2B-116	<i>Test Boring Record Boring No. RFI-4</i>
2B-117	<i>Test Boring Record Boring No. RFI-5</i>
2B-118	<i>Test Boring Record Boring No. RFI-6</i>
2B-119	<i>Test Boring Record Boring No. RFI-7</i>
2B-120	<i>Test Boring Record Boring No. RFI-8</i>
2B-121	<i>Test Boring Record Boring No. RFI-9</i>
2B-122	<i>Test Boring Record Boring No. RFI-10</i>
2B-123	<i>Test Boring Record Boring No. B-646</i>
2B-124	<i>Test Boring Record Boring No. B-647</i>
2B-125	<i>Test Boring Record Boring No. B-648</i>
2B-126	<i>Test Boring Record Boring No. B-649</i>
2B-127	<i>Test Boring Record Boring No. B-650</i>
2B-128	<i>Test Boring Record Boring No. B-651</i>
2B-129	<i>Test Boring Record Boring No. B-2001</i>
2B-130	<i>Test Boring Record Boring No. B-2001A</i>
2B-131	<i>Test Boring Record Boring No. B-2002</i>
2B-132	<i>Test Boring Record Boring No. B-2003</i>
2B-133	<i>Test Boring Record Boring No. IFI-1</i>
2B-134	<i>Test Boring Record Boring No. IFI-2</i>
2B-135	<i>Test Boring Record Boring No. IFI-3</i>
2B-136	<i>Test Boring Record Boring No. IFI-4</i>
2B-137	<i>Test Boring Record Boring No. IFI-5</i>
2B-138	<i>Test Boring Record Boring No. IFI-6</i>
3.3-1	Structural Grill System
3.4-1	Water Pressure on Structures
3.6-1	Recirculation Outlet Nozzle Configuration
3.6-2	Recirculation System Circumferential Break Model for GE-Designed Restraints
3.6-3	Recirculation System Longitudinal Break Model for GE-Designed Restraints
3.6-4	Steady Blowdown Force
3.7A-1	Design Spectrum for OBE
3.7A-2	Design Spectrum for DBE
3.7A-3	Modified Accelerogram
3.7A-4	Design Spectrum Compared with Response Spectrum of Modified Accelerogram for OBE with 3% Damping

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
3.7A-5	Design Spectrum Compared with Response Spectrum of Modified Accelerogram for DBE with 5% Damping
3.7A-6	Modified Response Spectrum Curve
3.7A-7	Post-Seismic Event Plant Procedures
3.7A-8	Seismic Model Reactor Bldg: Lateral
3.7A-9	Seismic Model Reactor Bldg: Vertical
3.7A-10	Seismic Model Control Bldg: Lateral
3.7A-11	Seismic Model Control Bldg: Vertical
3.7A-12	Seismic Model Diesel Generator Bldg: Lateral
3.7A-13	Seismic Model Diesel Generator Bldg: Vertical
3.7A-14	Seismic Model Intake Structure: Lateral
3.7A-15	Seismic Model Intake Structure: Vertical
3.7A-16	Seismic Model Main Stack: Lateral
3.7A-17	Seismic Model Main Stack: Vertical
3.7A-18	OBE Synthetic Accelerogram (1984)
3.7A-19	DBE Synthetic Accelerogram (1984)
3.7A-20	Design Spectrum Compared with Response Spectrum of OBE Synthetic Accelerogram (1984) for 3% Damping
3.7A-21	Design Spectrum Compared with Response Spectrum of DBE Synthetic Accelerogram (1984) for 5% Damping
3.7A-22	Damping Criteria for Seismic Analysis of Piping Systems
3.7A-23	Damping Criteria for Seismic Analysis of Cable Tray Supports
3.7A.A-1	Vibration Magnification at Resonance
3.7A.B-1	Relative Displacement
3.7A.B-2	End Movement in Direction of Member-Straight Bar
3.7A.B-3	End Movement in Direction of Member-Bent Bar
3.7A.B-4	End Movement Perpendicular to Member
3.7A.B-5	Typical Pipe Connection to Category I Structures
3.7B-1	Mathematical Model RPV and Internals
3.7B-2	Typical Dynamic Model of Steam Line Piping System
3.7B-3	Density of Stress Reversals
3.8-1	Personnel and Equipment Access Locks for Drywell and Suppression Chamber
3.8-2	(Sheet 1 of 4) Pipe Penetrations - Type 1 Accommodate Thermal Movements
3.8-2	(Sheet 2 of 4) Pipe Penetrations - Type 1A (Main Steam Line Only) Accommodate Thermal Movements
3.8-2	(Sheet 3 of 4) Pipe Penetrations - Type 1B Accommodate Thermal Movements

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
3.8-2	(Sheet 4 of 4) Pipe Penetrations - Type 1C Accommodate Thermal Movements
3.8-3	Pipe Penetrations - Type 2.1 - Thermal Movement Relatively Small (Small Bore Piping Only)
3.8-4	Pipe Penetrations - Type 2.2 - Thermal Movement Relatively Small
3.8-5	Typical Instrument Penetration
3.8-6	Typical Electrical Penetration Structural Components
3.8-7	Typical Electrical Penetration Assembly Detail
3.8-8	Traversing Incore Probe Penetration
3.8-9	Containment Geometry Shell Thickness and Stress Locations
3.8-10	Globe Valve
3.8-11	Main Steam Isolation Globe Valve
3.8-12	Control Valve
3.8-13	Butterfly Valve
3.8-14	Butterfly Valve
3.8-15	Butterfly Valve
3.8-16	Typical Type C Test Arrangement
3.8-17	2P51 Service Air System
3.8-18	2P64 Chilled Water System
3.8-19	2T48 Nitrogen Inerting System
3.8-20	2P21 Demineralized Water System
3.8-21	ILRT Connection
3.8-22	Fire Protection
3.8-23	Torus to Drywell ΔP
3.8-24	Drywell/Suppression Chamber Leak Test Containment Pressure Response with Leak Equivalent to 1-in. Diameter Orifice
3.8-25	Drywell/Suppression Chamber Leak Test Containment Differential Response with Leakage Equivalent to 1-in. Diameter Orifice
3.8-26	Details of Containment Airlock
3.8-27	Flat Development of Reactor Shield
3.8-28	Drywell Internal Structures
3.8-29	Miscellaneous Internal Structural Components
3.8-30	Reactor Building Foundation Plan and Section
3.8-31	Section of Reactor Building Foundation
3.8-32	RPV Pedestal Foundation Anchor Bolts
3.8-33	Main Stack Foundation Plan and Sections
3.8-34	Masonry Wall Single-Line Sketches - Control Building
3.8-35	Masonry Wall Single-Line Sketches - Control Building
3.8-36	Masonry Wall Single-Line Sketches - Control Building
3.8-37	Masonry Wall Single-Line Sketches - Control Building
3.8-38	Example of Wall Surveillance Sketch
3.8-39	Masonry Wall No. C-130-7A
3.8-40	Details for Masonry Wall No. C-130-7A

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
3.8-41	Details for Masonry Wall No. C-130-7A
3.8-42	Details for Masonry Wall C-130-7A
3.8.43	Details for Masonry Wall C-130-7A
3.8.44	Details for Masonry Wall C-130-7A
3.8-45	Details for Masonry Wall C-130-7A
3.8-46	Typical Masonry Wall Details
3.8-47	Typical Masonry Wall Details
3.8-48	Typical Masonry Wall Details
3.8-49	Typical Masonry Wall Details
3.9-1	Dynamic Model of RPV and Internals
3.10-1	TRS Versus RRS - Control Building el 130 (Lateral and Vertical)
3.10-2	TRS Versus RRS - Reactor Building el 130 (Lateral)
3.10-3	TRS Versus RRS - Intake Structure el 111 (Lateral)
3.10-4	TRS Versus RRS - Diesel Generator Building el 130 (Lateral)
3.10-5	TRS Versus RRS - Diesel Generator Building el 130 (Lateral)
3.10-6	TRS Versus RRS - Reactor Building el 130 (Vertical)
3.10-7	TRS Versus RRS - Intake Structure el 111 (Vertical)
3.10-8	TRS Versus RRS - Battery Charger Full-Scale Shock Spectrum
3.10-9	TRS Versus RRS - 100-kW Inverters Full-Scale Shock Spectrum
3.10-10	TRS Versus RRS - Reactor Building Vessel at el 204 (Lateral and Vertical)
3.10-11	TRS Versus RRS - Control Building el 164 (Vertical) (5-Percent Damping)
3.10-12	TRS Versus RRS - Reactor Building el 158 (Lateral)
3.10-13	TRS Versus RRS - Reactor Building el 158 (Vertical)
3.10-14	TRS Versus RRS - RPT Breakers
3.11-1	Worst-Case Accident Profile for Equipment Located in Containment
4.1-1	Reactor Vessel Cutaway
4.1-2	Core Arrangement and Lattice Configuration
4.1-3	Steam Separator
4.1-4	Steam Dryer
4.2-1	Reactor Internals Flow Paths
4.2-2	HNP-1 Fuel Support Pieces
4.2-3	HNP-2 Fuel Support Pieces
4.2-4	Jet Pump Isometric
4.2-5	Pressure Nodes for Depressurization Analysis
4.2-6	Dura Life D-190 Control Rod Assembly
4.2-7	Dura Life D-230 Control Rod Assembly
4.2-8	Control Rod Velocity Limiter
4.2-9	Advanced Longer Life Control Rod Velocity Limiter
4.2-10	Control Rod and Control Rod Drive Coupling
4.2-11	Control Rod Drive Unit
4.2-12	Control Rod Drive Unit (Schematic)
4.2-13	Control Rod Drive Unit (Cutaway)

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
4.2-14	Control Rod Drive Hydraulic Control Unit
4.2-15	Sodium Pentaborate Solution Volume-Concentration Requirements
4.2-16	Sodium Pentaborate Solution Temperature Versus Concentration Requirements
4.2-17	GE Marathon Control Rod Assembly
4.2-18	Westinghouse CR 99 Control Rod Assembly
4.2-19	Westinghouse CR 99 Boron Carbide Pin Detail
4.5-1	Control Rod Drive Housing Support
4A-1	HNP-1 Fuel Assembly
4A-2	HNP-2 Fuel Assembly
5.1-1	Reactor Coolant System Flow Diagram
5.2-1	Axial Through-Wall Crack
5.2-2	Two-Stage Safety Relief Valves
5.2-3	Response to MSIV Closure with Flux Scram
5.2-4	Adjusted Reference Temperature for Limited Beltline Materials
5.2-5	Sensitivity of Peak RPV Pressure of Initial Pressure for Code Over Pressure Protection Event
5.2-6	Calculated Leak Rate as a Function of Crack Length and Applied Hoop Stress
5.4-1	Reactor Vessel Nozzles and Penetrations
5.4-2	Reactor Vessel Schematic
5.5-1	Reactor Recirculating System Elevation and Isometric
5.5-2	Operating Principle of Jet Pump
5.5-3	Recirculation System-Core Flooding Capability
5.5-4	Main Steam Line Flow Restrictor Location
5.5-5	Main Steam Line Isolation Valve
5.5-6	Location of Relief Valve Exits in the Torus
5.5-7	(Deleted)
5.5-8	Recirculation System with Recirculation Pump Trip
5.5-9	Recirculation Pump Trip Control
5.5-10	System Response for Limiting Event with Four-Valve LLS
5.5-11	System Response for Limiting Event with Single Failure (Only Two LLS Valves Operable)
5.5-12	Suppression Pool Temperature Sensor Locations
5A-1	<i>Typical Dual Safety Relief Valve Capacity Characteristics</i>
5A-2	<i>Scram Rod Drive and Scram Reactivity Versus Time</i>
5A-3	<i>Peak Vessel Bottom Pressure Versus Safety Relief Valve Capacity</i>
5A-4	<i>Time Response of MSIV Transients</i>
5A-5	<i>Schematic Elevation</i>
5A-6	<i>Schematic Plan</i>

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
6.2-1	Suppression Chamber-to-Drywell Vacuum Breaker
6.2-2	SRV Steam Flow Characteristics
6.2-3	SRV Discharge Pipe Submerged End
6.2-4	Typical Spectacle Flange Arrangement
6.2-5	Location of Recirculation Line Break
6.2-6	Recirculation Break Blowdown Flowrates (HNP-1)
6.2-7	Recirculation Break Blowdown Flowrates (HNP-2)
6.2-8	0.1-ft ² Liquid Break - Calculated Drywell and Suppression Chamber Pressure Responses
6.2-9	0.1-ft ² Liquid Break - Calculated Drywell and Suppression Chamber Temperature Responses
6.2-10	Recirculation Line Break Calculated Containment Pressure Response
6.2-11	Recirculation Line Break Calculated Containment Temperature Response
6.2-12	Containment Response to Design Basis LOCA, Original Analysis
6.2-13	Deleted
6.2-14	Deleted
6.2-15	Deleted
6.2-16	Deleted
6.2-17	Containment Pressure Response to Design Basis LOCA, Operation at 100.5 of RTP (2818 MWt)
6.2-18	Containment Pressure Response to Design Basis LOCA, Operation at 100.5 of RTP (2818 MWt)
6.2-19	Containment Temperature Response to Design Basis LOCA, Operation at 100.5 of RTP (2818 MWt)
6.2-20	Containment Temperature Response to Design Basis LOCA, Operation at 100.5 of RTP (2818 MWt)
6.2-21	Long-Term Recirculation Line Break Calculated Containment Pressure Response
6.2-22	Long-Term Recirculation Line Break Calculated Drywell Temperature Response
6.2-23	Long-Term Recirculation Line Break Calculated Suppression Pool Temperature Response
6.2-24	Containment Temperature Response for 0.01-ft ² MSLBA
6.2-25	Deleted
6.2-26	Deleted
6.2-27	Deleted
6.2-28	Containment Temperature Response for 0.1-ft ² MSLBA
6.2-29	Deleted
6.2-30	Deleted
6.2-31	Containment Temperature Response for 0.5-ft ² MSLBA
6.2-32	Deleted
6.2-33	Deleted

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
6.2-34	Sensible Energy Transient in RPV and Internals Minimum ECCS Flow, 95°F Service Water Temperature
6.2-35	Allowable Leakage Capacity Versus Break Area
6.2-36	Containment Response to Large Primary System Breaks When Allowable Drywell-to-Suppression Chamber Leakage Capacity Exists
6.2-37	Containment Response to Small Primary System Breaks When Allowable Drywell-to-Suppression Chamber Leakage Capacity Exists
6.2-38	(Deleted)
6.2-39	(Deleted)
6.2.40	(Deleted)
6.2-41	(Deleted)
6.2-42	(Deleted)
6.2-43	(Deleted)
6.2-44	(Deleted)
6.2-45	(Deleted)
6.2-46	(Deleted)
6.2-47	(Deleted)
6.2-48	(Deleted)
6.2-49	(Deleted)
6.2-50	(Deleted)
6.2-51	(Deleted)
6.2-52	(Deleted)
6.2-53	(Deleted)
6.2-54	(Deleted)
6.2-55	(Deleted)
6.2-56	(Deleted)
6.3-1	Minimum CS System Performance Curve (SAFE/REFLOOD Analysis)
6.3-2	Minimum LPCI Performance Curve (SAFE/REFLOOD Analysis)
6.3-3	(Deleted)
6.3-4	(Deleted)
6.3-5	RHR Pump NPSH Evaluation
6.3-6	CS NPSH Evaluation
6A-1	SAMIS - Dynamic Model
6A-2	Loads for Recirculation Outlet Line Break
6A-3	Forces on RPV
6A-4	Forces on Shield Wall
6A-5	SAP Static Analysis Model
6A-6	Recirculation Outlet Line Break, Resultant Shear
6A-7	Recirculation Outlet Line Break, Resultant Moment
6A-8	Response to Recirculation Line Break, Resultant Force at Stabilizer Spring
6A-9	Feedwater Line Break, Resultant Shear
6A-10	Feedwater Line Break, Resultant Moment

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
6A-11	Feedwater Line Break, Resultant Force
6A-12	Recirculation Outlet Nozzle Configuration
6A-13	Mass Flux vs Time, Recirculation Outlet
6A-14	Mass Flux vs Time, Feedwater Upper and Lower Drywell
6A-15	Mass Flux vs Time, Recirculation Inlet
6A-16	Mass Flux vs Time, Head Spray
6A-17	Node Locations for Feedwater Line Break in Shield Annulus Region, Case A (20 Nodes)
6A-18	Feedwater Line Break Node Sensitivity Study, Case B (16 Nodes)
6A-19	Feedwater Line Break Node Sensitivity Study, Case C (28 Nodes)
6A-20	Feedwater Line Break Node Sensitivity Study, Case D (27 Nodes)
6A-21	Schematic Flow Diagram for Feedwater Line Break in Shield Annulus Region, Case A (20 Nodes)
6A-22	Schematic Flow Diagram for Recirculation Inlet Line Break in Shield Annulus Region
6A-23	Node Locations for Recirculation Inlet Line Break in Shield Annulus Region
6A-24	Schematic Flow Diagram for Recirculation Outlet Line Break in Shield Annulus Region
6A-25	Node Locations for Recirculation Outlet Line Break in Shield Annulus Region
6A-26	ΔP Between Nodes P1-P2, P1-P4 for H-2 Feedwater Break
6A-27	ΔP Between Nodes P1-P8 for H-2 Feedwater Break
6A-28	ΔP Between Nodes P1-P3 for H-2 Feedwater Break
6A-29	ΔP Between Nodes P1-P2, P1-P3, P1-P4, P1-P8 for H-2 Recirculation Inlet Break
6A-30	ΔP Between Nodes P2-P4, P2-P9 for H-2 Recirculation Inlet Break
6A-31	ΔP Between Nodes P2-P4, P2-P9 for H-2 Recirculation Outlet Break
6A-32	ΔP Between Nodes P1-P2, P1-P3, P1-P4 for H-2 Recirculation Outlet Break
6A-33	(Sheet 1 of 3) Feedwater Break Pressure in Nodes 1, 2, 3, and 4
6A-33	(Sheet 2 of 3) Feedwater Break Pressure in Nodes 5, 6, 7, 8, 9, and 10
6A-33	(Sheet 3 of 3) Feedwater Break Pressure in Nodes 11-20
6A-34	(Sheet 1 of 3) Recirculation Inlet Break Pressure in Nodes 1, 2, 3, and 4
6A-34	(Sheet 2 of 3) Recirculation Inlet Break Pressure in Nodes 5-7, 8, 9, 10, and 11
6A-34	(Sheet 3 of 3) Recirculation Inlet Break Pressure in Nodes 12-15, and 16 and 17
6A-35	Recirculation Inlet Break in Nodes 18-24
6A-36	(Sheet 1 of 4) Recirculation Outlet Break Pressure in Nodes 1-5
6A-36	(Sheet 2 of 4) Recirculation Outlet Break Pressure in Nodes 6-12
6A-36	(Sheet 3 of 4) Recirculation Outlet Break Pressure in Nodes 13-19
6A-36	(Sheet 4 of 4) Recirculation Outlet Break Pressure in Nodes 20-25
6A-37	Forces on RPV, Sacrificial Shield Feedwater Break $\sum F_x$

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
6A-38	Moments on RPV, Sacrificial Shield for Feedwater Break $\sum M_y$
6A-39	Force on RPV, Sacrificial Shield for Recirculation Inlet Break $\sum F_x$
6A-40	Moments on RPV, Sacrificial Shield for Recirculation Inlet Break $\sum M_y$
6A-41	Forces on RPV, Sacrificial Shield for Recirculation Outlet $\sum F_x$
6A-42	Moments on RPV, Sacrificial Shield Recirculation Outlet Break
6A-43	Axis Orientation
6A-44	Schematic Flow Diagram for Head Spray Line Break
6A-45	Feedwater Sparger
6A-46	Head Spray Line Break ΔP Between Compartments 1 and 2
6A-47	Inservice Inspection Doors
6A-48	Recirculation Outlet Restraint Band and Saddle Arrangement
6A-49	Mass Flux vs Time, 10-in Core Spray Line
6A-50	Mass Flux vs Time, RHR Suction
6A-51	Mass Flux vs Time, RHR Discharge
6A-52	Mass Flux vs Time MSLB, Upper and Lower Drywell
6A-53	Mass Flux vs Time, Main Steam Condensate Drain
6A-54	Mass Flux vs Time, RCIC Steam
6A-55	Mass Flux vs Time, RWC
6A-56	Mass Flux vs Time, HPCI Steam
6A-57	Node Location for MSLB
6A-58	Schematic Flow Diagram for MSLB
6A-59	Node Location for RHR Discharge Line Break
6A-60	Schematic Flow Diagram for RHR Discharge Lower Drywell
6A-61	(Sheet 1 of 3) Upper Drywell MSLB Pressure in Nodes 1-12
6A-61	(Sheet 2 of 3) Upper Drywell MSLB Pressure in Nodes 13-24
6A-61	(Sheet 3 of 3) Upper Drywell MSLB Pressure in Nodes 25-35
6A-62	Lower Drywell RHR Discharge Line Break Pressure in Nodes 1-14
7.2-1	RPS Scram Functions
7.2-2	RPS Relationship to NMS
7.2-3	RPS NMS Trip System Logic
7.2-4	Typical Arrangement of RPS Channels and Logics
7.2-5	RPS Turbine Stop Valve Closure Scram Configuration
7.2-6	RPS Main Steam Line Isolation Scram Configuration
7.2-7	Arrangement of RPS Actuators and Actuator Logics
7.3-1	ECCS Power Distribution
7.3-2	Typical Arrangement for Main Steam Line Break Detection by Flow Measurement
7.3-3	Main Steam Line High Flow Channel Schematic
7.3-4	Room Temperature Detector Arrangement (HPCI/RCIC)
7.3-5	Typical Elbow Flow-Sensing Arrangement
7.3-6	Typical High Exhaust Diaphragm Pressure Detection Arrangement (HPCI/RCIC)

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
7.3-7	RWC Break Detection by Differential Flow Measurement
7.3-8	High Ambient and High Differential Temperature Measurement (RWC)
7.3-9	MSIV Typical Isolation Control
7.3-10	MOV Typical Isolation Control
7.3-11	MSIV Schematic Control Diagram
7.3-12	High Ambient and High Differential Temperature Measurement (Suppression Pool)
7.4-1	LLS Relief Logic Diagram
7.4-2	LLS Logic for Channel C (Typical for Channels B, A, and D)
7.4-3	Channels A and C Indicators (Typical for Channels B and D)
7.6-1	Detector Drive - Schematic
7.6-2	NMS Detector Core Locations
7.6-3	NMS Instrumentation Ranges
7.6-4	SRM Functional Block Diagram
7.6-5	IRM Functional Block Diagram
7.6-6	Power Range Monitor Detector Assembly Location
7.6-7	(Sheet 1 of 5) APRM/RBM Power Distribution
7.6-7	(Sheet 2 of 5) PRNM Logic Interface Block Diagram
7.6-7	(Sheet 3 of 5) APRM/RPS Interface Block Diagram
7.6-7	(Sheet 4 of 5) APRM/RBM Configuration Block Diagram
7.6-7	(Sheet 5 of 5) Flow Reference and RBM Instrumentation
7.6-8	LPRM to RBM Assignment Scheme
7.6-9	TIP Functional Block Diagram
7.6-10	TIP Assembly
7.6-11	Control Rod Withdrawal Error Core Locations
7.6-12	Control Rod Withdrawal Error Normalized Flux Distribution
7.6-13	Envelope of Maximum APRM Deviation by Flow Control Reduction in Power
7.6-14	Envelope of Maximum APRM Deviation for APRM Tracking with On-Limits Control Rod Withdrawal
7.6-15	Simplified Schematic of SRV Position Indication System
7.6-16	Typical RBM Channel Responses (No Failed LPRMs)
7.7-1	Input Signals to Four-Rod Display
7.7-2	RRS Flow Control Illustration
7.7-3	Simplified Diagram of Turbine Pressure and Speed-Load Control System
7.8-1	Typical Trip Unit/Calibration System Elementary
8.2-1	Single-Line Diagram Plant Switchyard Connections
8.2-2	GPC Generation, Transmission and Primary Distribution System
8.2-3	Switchyard/Substation dc One-Line Diagrams (Typical)
8.2-4	24-kV Switchyard Bus Support Structure
8.3-1	4160-V Auxiliary Electrical Power System
8.3-2	600-V Auxiliary Electrical Power System

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
8.3-3	4160-V Essential Power System
8.3-4	125-250-V-dc Power System
8.3-5	125-V-dc Diesel Auxiliary Power System
8.3-6	(Deleted)
8.3-7	Diesel Generator 1B 600-208-V MCCs
8.3-8	4160-V and 600-V Essential Buses and Loads
8.3-9	ac Instrument Power Supply System
9.1-1	Fuel Storage Arrangement
9.1-2	New Fuel Storage Rack Outline
9.1-3	(Sheet 1 of 2) HNP-1 High-Density Fuel Storage Arrangement
9.1-3	(Sheet 2 of 2) HNP-2 High-Density Fuel Storage Arrangement
9.1-4	(Sheet 1 of 2) General Electric Module Support System
9.1-4	(Sheet 2 of 2) General Electric Module Support System Detail
9.1-5	Spent – Fuel Cask Lift Yoke
9.1-6	(Sheet 1 of 3) Pictorial View of a Typical Holtec Rack Module
9.1-6	(Sheet 2 of 3) Typical Array of Holtec Storage Cells
9.1-6	(Sheet 3 of 3) Elevation View of a Typical Holtec Rack Module Support Pedestal
9.2-1	PSW Flow Diagram
9.2-2	PSW Pump Characteristics
9.2-3	Integrated Decay Heat Infinite Exposure and Irradiation Time
9.2-4	Decay Heat Rejection Rate
9.2-5	Auxiliary System Heat Rejection Rate
9.2-6	Integrated Auxiliary Heat Rejected
9.2-7	Sensible Heat Rejection Rate
9.2-8	Integrated Sensible Heat Rejected
9.2-9	Total Integrated Heat Rejected
9.2-10	PSW Water Pump Required NPSH Versus Flow
9.2-11	(Deleted)
9.2-12	Decay Heat Rejection Rate
9.2-13	Integrated Decay Heat
9.2-14	Total Integrated Heat Rejected
9.4-1	Diesel Generator Exhaust
9.5-1	Intraplant Communication System Block Diagram
10.2-1	Swing Angle and Gravity Parabola
10.2-2	Descriptive Coordinates for Turbine Missile Trajectories
10.2-3	Turbine Location with Respect to Other Buildings
10.2A-1	(Deleted)
10.2A-2	(Deleted)
10.2A-3	(Deleted)

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
10.2A-4	(Deleted)
10.2A-5	Typical Arrangement of Steam Valves in Main and Extraction Line of Nuclear Turbine
10.4-1	Maximum Water Level in Station Battery Rooms With Circulating Water System Expansion Joint Failure
11.1-1	Noble Radiogas Decay Constant Exponent Frequency Histogram
11.1-2	Radiohalogen Decay Constant Exponent Frequency Histogram
11.1-3	Noble Radiogas Versus I-131 Leakage
11.2-1	(Deleted)
11.2-2	(Deleted)
11.2-3	Relative Location of Intake and Discharge Structures
11.3-1	Off-Gas System Process Flow Diagram
11.5-1	Radwaste System Process Flow Diagram
12.3-1	Shielding and Access Control - Control Building el 112 ft
12.3-2	Shielding and Access Control - Control Building el 130 ft
12.3-3	(Deleted)
12.3-4	Shielding and Access Control - Control Building el 164 ft
12.3-5	Reactor Building Exhaust Filter Train
12.3-6	Standby Gas Treatment Filter Train
12.3-7	Shielding and Access Control Technical Support Center
13.1-1	SNC Nuclear Operations Organization and HNP Technical Support Organization for HNP
13.1-2	SNC Technical Support Organization for HNP
13.1-3	Organization for Hatch Nuclear Plant
13.1-4	Minimum Control Room Manning
13.7-1	HNP Security Organization
14.1-1	Test Program Outline
14.1-2	Startup Testing - Open Vessel
14.1-3	Startup Testing Heatup - Part I
14.1-4	Startup Testing Heatup - Part II
14.1-5	Startup Testing Test Condition 1
14.1-6	Startup Testing Test Condition 2
14.1-7	Startup Testing Test Condition 3
14.1-8	Startup Testing Test Condition 4
14.1-9	Startup Testing Test Condition 5
14.1-10	Startup Testing Test Condition 6
14.1-11	Startup Testing Warranty Demonstration
14.1-12	Approximate Power Flow Map Showing Startup Test Conditions

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
15.1-1	Safety Analysis Methods (Typical)
15.1-2	Transient Analysis Methods (Typical)
15.1-3	Power-to-Flow Map RTP of 2804 MWt
15.2-1	Inadvertent HPCI Injection, Void Coefficient = -12.0
15.2-2	Summary of Paths Available to Achieve Cold Shutdown
15.2-3	ADS/RHR/CS Cooling Loops
15.2-4	Activity C1 – Division I Failed
15.2-5	Activity C2 – Division II Failed
15.2-6	Load Rejection with No Bypass (LRNBP) (100P/100F)
15.2-7	Load Rejection with No Bypass (LRNBP) (100P/105F)
15.2-8	Turbine Trip with No Bypass (TTNBP) (100P/100F)
15.2-9	Turbine Trip with No Bypass (TTNBP) (100P/105F)
15.2-10	Turbine Trip with Bypass (TTBP), Void Coefficient = -12.0
15.2-11	Closure of all MSIVs, MSIVD, Trip Scram, Void Coefficient = -12.0
15.2-12	Trip of Both Recirculation Pumps, Void Coefficient = -6.86
15.2-13	CRD, EOC 1 Scram Curve, and Scram Curve Used in Analysis
15.2-14	Recirculation Failure – Increasing Flow, Void Coefficient = -12.0
15.2-15	Startup of Idle Recirculation Loop, Void Coefficient = -12.0
15.2-16	Point Kinetics Control Rod Reactivity Insertion (Modified to Include Scram Reactivity)
15.2-17	Global Peaking Factor Versus Rod Worth from NEDO – 10527 and Detailed Analysis
15.2-18	Continuous Rod Withdrawal in Startup Range, Core Average Power Versus Time (Point Model Kinetics)
15.2-19	Continuous Rod Withdrawal from Hot Startup, Core Average Power Versus Time
15.2-20	Feedwater Controller Failure (FWCF) (100P/100F)
15.2-21	Feedwater Controller Failure (FWCF) (100P/105F)
15.2-22	Pressure Regulator Failure – Open, Void Coefficient = -12.0
15.2-23	Loss of Auxiliary Power (Transformer), Void Coefficient = -12.0
15.2-24	Loss of Auxiliary Power (All Grid Connections), Void Coefficient = -12.0
15.2-25	Loss of Feedwater Flow (LOFW) Vessel Downcomer Water Level
15.2-26	Loss of Feedwater Flow (LOFW) Vessel Pressure
15.3-1	Critical Rod Pattern and Fuel Bundle Exchange Locations for Misplaced Bundle Accident (0.0 GWd/T)
15.3-2	Seizure of One Recirculation Pump, Void Coefficient = -12.0
15.4-1	Load Rejection with No Bypass, RPT, or Direct Scram
15.4-2	CPR Versus Time for Load Rejection with No Bypass, RPT, or Direct Scram
15.4-3	RPV Pressure in Normal Shutdown
15.4-4	Mass Flowrate from Instrument Line with ¼-in Orifice (Saturated Water)
15.4-5	Vapor Temperature Versus Time Instrument Line Break
15.4-6	Pressure Versus Time Instrument Line Break

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
15A-1	MSLBA – Mass of Coolant Loss Through Break With 5-s MSIV Closing Time
15A-2	Location of MCR with Respect to Main Steam Lines (Looking East)
15A-3	Main Steam and Feedwater Lines in Main Steam Pipe Chase, Reactor Building, Elevation View (Looking South)
15A-4	Main Steam and Feedwater Lines, Main Steam Pipe Chase Reactor Building - Plan View
15A-5	(Deleted)
15A-6	HPCI Steam and RHR Lines, Pipe Penetration Room, Reactor Building el 130 ft - Plan View
15A-7	(Deleted)
15A-8	(Deleted)
15A-9	Main Steam and Feedwater Anchor Frame Details Main Steam Pipe Chase
15A-10	Flow Model – MSLB in Pipe Chase Room
15A-11	Flow Model – HPCI Steam Line Break in Torus Room
15A-12	Flow Model – HPCI Steam Line Break In Pipe Penetration Room
15A-13	Flow Model – RWC Line Break in Pump Room – Reactor Building
15A-14	Vent Room el 164 ft and Vent Area Addition from Main Steam Pipe Chase to Vent Room to Turbine Building - Reactor Building
15A-15	Vent Area Addition To Turbine Building From Main Steam Pipe Chase, Reactor Building
15A-16	Vent Area from Pipe Penetration Room, Reactor Building Floor el 130 ft to Torus Room
15A-17	Vent Area Restrictors around Drywell Penetrations
15C-1	NSOA Relationship to Safety Analysis and Design Process
15C-2	Event Diagram Format
15C-3	Auxiliary System Diagram Format
15C-4	Event Diagram Loss of Feedwater Heating
15C-5	Event Diagram Inadvertent Start of HPCI Pump
15C-6	Event Diagram Shutdown Cooling (RHR) Malfunction - Decreasing Temperature
15C-7	Event Diagram Loss of RHR Shutdown Cooling
15C-8	Event Diagram Generator Load Rejection with No Bypass
15C-9	Event Diagram Generator Load Rejection with Bypass
15C-10	Event Diagram Turbine Trip with No Bypass
15C-11	Event Diagram Loss of Condenser Vacuum
15C-12	Event Diagram Turbine Trip with Bypass
15C-13	Event Diagram Closure of All MSIVs
15C-14	Event Diagram Closure of One MSIV
15C-15	Event Diagram Pressure Regulator Failure – Closed
15C-16	Event Diagram Trip of One Recirculation Pump
15C-17	Event Diagram Trip of Two Recirculation Pumps
15C-18	Event Diagram Recirculation Flow Controller Failure – Decreasing Flow

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
15C-19	Event Diagram Recirculation Flow Controller Failure – Increasing Flow
15C-20	Event Diagram Startup of Idle Recirculation Pump
15C-21	Event Diagram Control Rod Withdrawal Error
15C-22	Event Diagram Control Rod Removal Error During Refueling
15C-23	Event Diagram Fuel Assembly Insertion Error During Refueling
15C-24	Event Diagram Feedwater Controller Failure – Maximum Demand
15C-25	Event Diagram Inadvertent Opening of an SRV
15C-26	Event Diagram Pressure Regulator Failure – Open
15C-27	Event Diagram Loss of Auxiliary Power
15C-28	Event Diagram Loss of Feedwater Flow
15C-29	Event Diagram Control Rod Drop Accident
15C-30	Event Diagram Loss of Coolant Accident
15C-31	Event Diagram Main Steam Line Break Accident
15C-32	Event Diagram Fuel-Handling Accident
15C-33	Event Diagram Fuel Assembly Loading Error
15C-34	Event Diagram Recirculation Pump Seizure
15C-35	Event Diagram Feedwater Line Break
15C-36	Event Diagram Stability
15C-37	Event Diagram Overpressure Protection
15C-38	Event Diagram Shutdown Without Control Rod Insertion (SLCS Capability)
15C-39	Event Diagram MCR Uninhabitability
15C-40	Event Diagram Anticipated Transient Without Scram
15C-41	Event Diagram Generator Load Rejection with Flux Scram and No Bypass or RPT
15C-42	Event Diagram Turbine Trip with Flux Scram and No Bypass or RPT
15C-43	Event Diagram Loss of One dc System
15C-44	Event Diagram Loss of Instrument Air
15C-45	Event Diagram Loss of Service Water System
15C-46	Event Diagram Fire
15C-47	Event Diagram Miscellaneous Small Releases Outside Containment
15C-48	Event Diagram Instrument Line Break
15C-49	Event Diagram Liquid Radwaste Tank Failure
15C-50	Event Diagram Gaseous Radwaste Tank Failure
15C-51	Event Diagram Station Blackout
15C-52	Auxiliary Systems for Front-Line Systems
15C-53	Auxiliary Systems for Other Auxiliary Systems
15C-54	NSOA, Safety Analysis, and Setpoint Methodology Relationships
15C-55	Safety Analysis-Related Setpoints and Uncertainties
15C-56	Hierarchy of Controlled Setpoints
15C-57	Setpoint Quantification Methodology
15C-58	Setpoint Analysis Process
15C-59	Simplified Setpoint Process

HNP-2 FSAR

LIST OF FIGURES (CONTINUED)

<u>Figure No.</u>	<u>Figure Title</u>
17.2-1	Quality Assurance Organization (Deleted)

1.0 INTRODUCTION AND GENERAL DESCRIPTION OF PLANT

1.1 INTRODUCTION

This Final Safety Analysis Report (FSAR) complies with the "Standard Format and Content of Safety Analysis Reports," (Rev 1) issued by the Atomic Energy Commission (AEC) in October 1972. Conformance with applicable Regulatory Guides is discussed in appendix A to the FSAR.

A discussion of the format of the FSAR is presented in subsection 1.1.8, Organization of Contents.

1.1.1 LICENSE REQUESTED

This FSAR was originally submitted in support of the application by the Georgia Power Company (GPC), the Ogelthorpe Power Corporation (OPC), the Municipal Electric Authority of Georgia, and the city of Dalton, Georgia, for a facility operating license for the Edwin I. Hatch Nuclear Plant-Unit 2 (HNP-2) at a core thermal power level of 2436 MWt, the power level equivalent to 100% of the rated steam flow. (The design steam flow is 105% of the rated steam flow and occurs at a core thermal power level of ~ 2537 MWt.) Pursuant to an application dated September 18, 1992, the NRC issued an operating license amendment on March 17, 1997, effective March 22, 1997, designating Southern Nuclear Operating Company (SNC) as the exclusive operating licensee of HNP. SNC has no ownership interest in HNP. The application was made under section 103(b) of the Atomic Energy Act of 1954, as amended, and the regulations of the Nuclear Regulatory Commission (NRC) set forth in Title 10 Code of Federal Regulations (CFR) Part 50.

In Amendment 155 to the Technical Specifications, the HNP-2 facility operating license NPF-5 was revised to increase the maximum power level from 2558 MWt to 2763 MWt. In Amendment 214 to the Technical Specifications, the HNP-1 operating license was also revised to 2763 MWt. In Amendment 180 to the Technical Specifications, the HNP-2 operating license was revised to increase the maximum power level from 2763 MWt to 2804 MWt. In Amendment 238 to the Technical Specifications, the HNP-1 operating license to the Technical Specifications was also revised to 2804 MWt.

1.1.2 NUMBER OF PLANT UNITS

HNP-2 is located adjacent to the HNP-1. The application for an operating license for HNP-1 was submitted on NRC Docket No. 50-321. HNP-1 operating license no. DPR-57 was granted August 6, 1974. The application for HNP-2 was made separately on NRC Docket No. 50-366. The HNP-2 operating license no. NPF-5 was granted on June 13, 1978. Renewed operating license no. NPF-5 for HNP-2 was granted by the NRC on January 15, 2002, in accordance with the provisions of 10 CFR 54.

1.1.3 PLANT LOCATION

The plant is located on the south side of the Altamaha River, southeast of the intersection of the river with U.S. Hwy No.1 in the northwestern sector of Appling County, Georgia. The site is ~ 11 miles north of Baxley, Georgia.

1.1.4 NUCLEAR STEAM SUPPLY SYSTEM

The HNP-2 NSSS is a BWR 4 boiling water reactor--1967 product line, 218-in. vessel--designed and supplied by General Electric Company (GE).

1.1.5 CONTAINMENT STRUCTURE

The HNP-2 containment is the Mark I BWR Containment incorporating the drywell/pressure suppression concept. The reinforced concrete secondary containment structure was designed by Bechtel Power Corporation.

1.1.6 POWER OUTPUT

The design operating thermal power level is 2804 MWt which corresponds to 100% of rated steam flow. This will yield a gross electrical output of ~ 940 MWe, a net electrical output of ~ 905 MWe.

1.1.7 SCHEDULE FOR COMPLETION AND COMMERCIAL OPERATION

Initial fuel loading of HNP-2 began in April 1978. Commercial operation of HNP-2 began on September 5, 1979.

1.1.8 ORGANIZATION OF CONTENTS

1.1.8.1 Subdivisions

The FSAR is organized into 17 chapters, each of which consists of a number of sections that are numerically identified by two numerals separated by a decimal; e.g., 3.4 is the fourth section of chapter 3. Further subdivisions are referred to as subsections and then as paragraphs.

1.1.8.2 Standard Format

The HNP-2 FSAR is written to comply with the "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants, Regulatory Guide (RG) 1.70, Revision 1, issued by the AEC in October 1972. The FSAR uses the same chapter, section, subsection, and paragraph headings as those used in the standard format, except in cases where this format was not applicable to plant design. Where appropriate, the FSAR is subdivided beyond the extent of the standard format to isolate all information specifically requested in that document. Where information is presented that is not specifically requested by the standard format and is identified numerically (chapter, section, subsection, or paragraph), this information is presented under the appropriate general headings.

In unique instances, selected HNP-2-FSAR information has been determined to apply to both HNP-1 and HNP-2. Where this condition exists, the term "(HNP-1 and HNP-2)" may be denoted, following the applicable subsection/paragraph title, to assist the FSAR reader in understanding that the subject textual information is applicable to both HNP units.

1.1.8.3 References (HNP-1 and HNP-2)

In accordance with the guidelines of Nuclear Energy Institute (NEI) 98-03, "Guidelines for Updating Final Safety Analysis Reports," Revision 1, Section A4.3, the FSAR contains two types of references:

- General References (alternatively references), and
- ***Documents Incorporated by Reference into the FSAR***

General references (alternatively references) are not considered part of the FSAR, but provide background information or additional detail on particular material presented in the FSAR. General references (alternatively references) are not subject to the FSAR update requirements of 10 CFR 50.71(e) or the change control requirements of 10 CFR 50.59.

Documents Incorporated by Reference into the FSAR are part of the FSAR and, therefore, subject to the update requirements of 10 CFR 50.71 (e) and the change control requirements of 10 CFR 50.59. When referenced in the text, ***documents incorporated by reference into the FSAR*** appear in bold, italicized type and are listed on the references page at the end of the section.

Drawings ***incorporated by reference into the FSAR*** utilize the standard FSAR font type when referenced in text and are listed in HNP-2-FSAR table 1.1-1.

1.1.8.4 Tables, Figures, and Drawings (HNP-1 and HNP-2)

Tables are identified by the section number, followed by a number according to its order of mention in the section; e.g., table 3.3-5 is the fifth table of section 3.3. Tables are located at the

HNP-2-FSAR-1

end of the applicable section. Drawings, sketches, curves, graphs, and engineering diagrams identified as figures are numbered according to the order of mention in the section; e.g., figure 3.4-2 is the second figure of section 3.4. Figures are located at the end of the applicable section.

Selected HNP-2-FSAR tables and figures have been determined to apply to both HNP-1 and HNP-2. Where this unique condition exists, the term "(HNP-1 and HNP-2)" is denoted on the applicable HNP-2-FSAR tables and figures to identify information applicability to both HNP units.

Some drawings and engineering diagrams are included, in conjunction with specific system descriptions, by reference to their drawing identification number in lieu of inclusion as figures. Table 1.1-1 lists the drawings referenced in HNP-1-FSAR and/or HNP-2-FSAR, and is provided as an aid for identifying such referenced drawings (with their applicable sheet numbers). The drawings listed in table 1.1-1 are considered ***Incorporated by Reference into the FSAR*** as discussed in HNP-2-FSAR paragraph 1.1.8.3 (i.e., the drawings are still part of the FSAR and subject to the update requirements of 10 CFR 50.71 (e) and the change control requirements of 10 CFR 50.59).

1.1.8.5 Numbering of Pages (HNP-1 and HNP-2)

Pages are numbered sequentially within each section; e.g., page 1.1-2 is the second page of section 1.1.

1.1.8.6 Amending the FSAR (HNP-1 and HNP-2)

The FSAR is amended on an annual basis in accordance with 10 CFR 50.71e.

1.1.8.7 Historical Information (HNP-1 and HNP-2)

Selected information contained in the FSAR is designated *Historical* in accordance with the guidelines of NEI 98-03, Revision 1, Section A3. Historical information is generally not expected to require updating in accordance with the requirements of 10 CFR 50.71 (e). However, based upon the particular subject content of the historical information, future updating may be required; therefore, FSAR information designated *Historical* cannot be completely ignored for possible future FSAR updating purposes. Changes to designated Historical information are still subject to the change control requirements of 10 CFR 50.59.

Historical information is identified by use of the following italicized font:

HNP-2-FSAR-1

14A.17 PROCESS LIQUID RADIATION MONITOR SYSTEM (2D11-3530)

- A. Test objective - The process liquid radiation monitor will be shown to be operable in calibration, to have correct trip settings, and to perform its required annunciator functions.*

For FSAR tables, historical information is designated by either the above unique italicized font type or by the term *Historical* located directly to the right of the table title. For FSAR figures, the term *Historical* appears directly above the figure title block.

TABLE 1.1-1 (SHEET 1 OF 20)**DRAWINGS INCORPORATED BY REFERENCE
INTO THE FSAR (HNP-1 AND HNP-2)**

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
A-21603	1 thru 18	Nameplate Engraving List for Panel 2H11-P603
A-21725	1, 2	Nameplate Engraving List for Panel 2H21-P173
A-21726	1 thru 8	Nameplate Engraving List for Panel 2C82-P001
D-11001	1	Service Water Piping at Intake Structure (P41) P&ID
D-11004	1	RHRWS System (E11) Outside Bldg P&ID
E-10173	1	General Bldg Site Plan
H-10167	1	Refueling Floor Heavy Load Paths
H-11018	1	Main and Auxiliary Steam Systems (N36) P&ID
H-11019	1	Condensate and Feedwater System (N21) P&ID
H-11020	1	Moisture Separator and Heater Drain System (N22) P&ID
H-11024	1	Service Water Piping (P41) P&ID
H-11025	1	Condenser Vacuum and Offgas System (N62) P&ID
H-11036	1 thru 3	Circulating Water System (N71/N61) P&ID
H-11037	1	Fuel Oil and Diesel Oil System (R43) P&ID
H-11039	1	Service and Instrument Air at High Pressure Air Compressors (P51) P&ID
H-11126	1	Piping - Circulating Water System
H-11142	1	Piping - Service Water at Intake Structure
H-11335	1	Piping - Chlorine System Outside and at Chlorine Bldg
H-11353	1	General Arrangement - Outside Piping (E51+00 to E55+00 and N52+00 to N57+50)
H-11354	1	General Arrangement - Outside Piping (E47+00 to E51+00 and N54+50 to N60+25)
H-11355	1	General Arrangement - Outside Piping to River (N57+50 to N60+00, and E51+00 to E54+70, N60+40, and E49+20)
H-11600	1	Service Water at Diesel Generator Bldg (P41) P&ID
H-11601	1	Main (N11) and Auxiliary Steam Systems P&ID
H-11602	1	Main (N11) and Auxiliary Steam Systems P&ID

HNP-2-FSAR-1

TABLE 1.1-1 (SHEET 2 OF 20)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
H-11603	1	Condensate and Feedwater System (N21) P&ID
H-11604	1	Condensate and Feedwater System (N21) P&ID
H-11605	1	Condensate and Feedwater System (N21) P&ID
H-11606	1	Moisture Separator and Heater Drain System (N22) P&ID
H-11607	1	Moisture Separator and Heater Drain System (N22) P&ID
H-11608	1	Moisture Separator and Heater Drain System (N22) P&ID
H-11609	1	Service Water Piping (P41) P&ID
H-11610	1	Service Water Piping (P41) P&ID
H-11611	1	Service Water Piping (P41) P&ID
H-11612	1	Condenser Vacuum and Offgas Systems (N62) P&ID
H-11613	1	Condenser Vacuum and Offgas Systems (N22/N33) P&ID
H-11631	1, 2	Diesel Generators 1A and 1C (R43) P&ID
H-11638	1, 2	Diesel Generator 1B (R43) P&ID
H-11641	1	Instrument Air at High Pressure Air Compressors (P52) P&ID
H-11646	1	Moisture Separator and Heater Drain System (N22) P & ID
H-11730	1	Hypochlorination Piping System Plan - Chlorine Bldg el 128 ft 4 in.
H-11802	1	Fire Hazards Analysis General Building Site Plan
H-11807	1	Fire Hazards Analysis Turbine Building el 164 ft 0 in.
H-11817	1	Fire Hazards Analysis Control Building Below el 164 ft 0 in.
H-11823	1	Fire Hazards Analysis Turbine Building el 164 ft 0 in.
H-11826	1	Fire Hazards Analysis Reactor Building Below el 130 ft 0 in.
H-11836	1	Fire Hazards Analysis Reactor Building el 164 ft 0 in.
H-11850	1	Fire Hazards Analysis Transformer Switch Yard
H-11860	1	Fire Hazards Analysis Reactor Building Below el 130 ft 0 in.
H-11982	1	Water Treatment System (W23) P&ID
H-12192	1	Outdoor Concrete Intake Structure - General Arrangement (W35)

HNP-2-FSAR-1

TABLE 1.1-1 (SHEET 3 OF 20)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
H-12320	1	Diesel Generator Bldg Concrete Base Slab - General Arrangement
H-12405	1	Control Building Concrete - General Arrangement - Section A-A
H-12406	1	Control Building Concrete - General Arrangement - Sections BB & CC
H-12523	1	General Arrangement - Plant Site Outdoor Benchmarks
H-12619	1	Architectural - Diesel Generator Bldg Heating and Ventilation System (X22) - General Arrangement and Parts Nos.
H-12626	1	Architectural - Turbine and Control Bldgs General Plan at el 112 ft 0 in.
H-12627	1	Architectural - Control Bldg Partial Plan at el 112 ft 0 in.
H-12628	1	Architectural - Turbine and Control Bldgs General Plan (U22/Z22) at el 130 ft 0 in.
H-12629	1	Architectural - Control Bldg Partial Plan at el 112 ft 0 in.
H-12631	1	Architectural - Control Building - Detailed Floor Plan at el 147 ft 0 in.
H-12632	1	Turbine and Control Bldgs General Plan (T22/Z22) at el 164 ft 0 in.
H-12678	1	Architectural - Chlorine Bldg Floor Plan and Elevations (Y64)
H-13350	1	Master Single-Line Diagram
H-13369	1,2	120/208-V Essential ac System MPLS (1R25-S064) Single-Line Diagram
H-13370	1	125/250-V-dc Station Service Division I (R22/R25) Single-Line Diagram
H-13370	2	125/250-V-dc Station Service Division II (R25) Single-Line Diagram
H-13371	1, 2	125-V-dc Emergency Station Service (R25) Single-Line Diagram
H-13635	1	120-V Vital ac and 24/48-V-dc System (R25/R42) Single Line Diagram
H-13850	1	General Arrangement - Outdoor Switchyard
H-13867	1	Plant Switchyard and Transmission Line Connections
H-15006	1	Reactor Bldg Drywell - Interior Vessel Protection Plans (T22)

HNP-2-FSAR-1

TABLE 1.1-1 (SHEET 4 OF 20)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
H-15650	1	Main Stack Plans and Elevations
H-15851	1	Architectural Floor Plan at el 87 ft 0 in.
H-15852	1	Architectural Floor Plan at els 130 ft 0 in. and 132 ft 4 in.
H-15854	1	General Arrangement Plant Building and Equipment Plan el 158 ft and 164 ft
H-15874	1	Architectural - Main Stack
H-15903	1	Shielding - Waste Gas Treatment Bldg
H-16000	1	Nitrogen Inerting System (T48) P&ID
H-16002	1	FPCC System (G41) P&ID
H-16003	1	Fuel Pool Filter/Demineralizer System (G41) P&ID
H-16005	1	Reactor Bldg Ventilation System (T41) P&ID
H-16007	1	Drywell Cooling System (T47) P&ID
H-16008	1	Radwaste Bldg Ventilation System (V41) P&ID
H-16009	1	RBCCW System (P42) P&ID
H-16011	1	Reactor Bldg Service Water System (P41) P&ID
H-16014	1	Reactor Bldg Refueling Floor Ventilation System (T41) P&ID
H-16020	1	SGTS (T46) P&ID
H-16022	1	Piping and Equipment Code Classification Diagram
H-16023	1	Safeguard Equipment Cooling (T41) P&ID
H-16024	1	Primary Containment Purge and Inerting System (T48) P&ID
H-16027	1	Equipment Locations - Reactor and Radwaste Bldgs Above el 144 ft 4 in.
H-16029	1	Equipment Locations - Reactor and Radwaste Bldgs at el 185 ft 0 in.
H-16030	1	Equipment Locations - Reactor Bldg at el 203 ft 0 in.
H-16031	1	Equipment Locations - Reactor Bldg at el 228 ft 0 in.
H-16032	1	Equipment Locations - Reactor Bldg Section A-A
H-16033	1	Equipment Locations - Reactor Bldg Section B-B

HNP-2-FSAR-1

TABLE 1.1-1 (SHEET 5 OF 20)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
H-16034	1	Control Bldg Radiochemical Lab and Health Physics Area Air-Conditioning (Z41/Z45) P&ID
H-16035	1	Control Bldg Computer and Water Analysis Rooms Air-Conditioning (Z41) P&ID
H-16036	1	Equipment Locations - Radwaste Bldg Addition
H-16037	1	Turbine Bldg Ventilation System (U41) P&ID
H-16040	1	Control Bldg Ventilation System (Z41) P&ID
H-16041	1	Control Bldg Ventilation System (Z41) PFD
H-16042	1	Control Bldg Control and Cable Spreading Rooms Air-Conditioning Temperature Control (Z41) Diagram
H-16061	1	SLCS (C41) P&ID
H-16062	1	Nuclear Boiler System (B21) P&ID
H-16063	1	Nuclear Boiler System (B21) P&ID
H-16064	1	CRD System (C11) P&ID
H-16065	1	CRD System (C11) P&ID
H-16066	1	RRS (B31)
H-16110	1	Unit No. 1&2 Types of Penetration Seals for Pipe
H-16145	1	Nuclear Boiler System (B21) P&ID
H-16147	1	Reactor Bldg Nitrogen Inerting System (T48) Below el 130 ft 0 in.
H-16173	1	Fission Products Monitoring System (D11) P&ID
H-16174	1	SGTS (T46) P&ID
H-16176	1	Radwaste System (G11) P&ID
H-16177	1	Radwaste System (G11) P&ID
H-16178	1	Radwaste System (G11) P&ID
H-16179	1	Radwaste System (G11) P&ID
H-16180	1	Radwaste System (G11) P&ID
H-16181	1	Radwaste System (G11) P&ID
H-16182	1	Radwaste System (G11) P&ID
H-16188	1	RWC System (G31) P&ID

TABLE 1.1-1 (SHEET 6 OF 20)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
H-16189	1	RWC System (G31) P&ID
H-16239	1 thru 9	Reactor Bldg Instrument Air System (P52) P&ID
H-16249	1	MCR Instrument and Primary Point Locations (Z99)
H-16274	1	Fission Products Monitoring System (D11) P&ID
H-16276	1	Primary Containment Atmosphere H ₂ &O ₂ Analyzer P&ID Sh 1
H-16280	1	Primary Containment Atmosphere H ₂ &O ₂ Analyzer P&ID Sh 2
H-16286	1	Drywell Pneumatic System (P70) P&ID
H-16299	1	Drywell Pneumatic System (P70) P&ID
H-16326	1, 2	Turbine Bldg Chilled Water System (P63) P&ID
H-16327	1	Turbine Bldg Chilled Water System (P63) P&ID
H-16329	1	RHR System (E11) P&ID
H-16330	1	RHR System (E11) P&ID
H-16331	1	CS System P&ID
H-16332	1, 2	HPCI System (E41) P&ID
H-16333	1	HPCI System (E41) P&ID
H-16334	1	RCIC System (E51) P&ID
H-16335	1	RCIC System (E51) P&ID
H-16339	1	ERF/SPDS (X75) Block Diagram
H-16512	1	Radwaste Bldg Addition Ventilation System (V41) P&ID
H-16517	1	Radwaste Bldg Addition Support Systems (G11) P&ID and PFD
H-16519	1	General Arrangement – Offgas Recombiner Bldg
H-16532	1, 2	Off-gas System (N62) P&ID
H-16536	1	General Arrangement - Waste Gas Treatment Bldg
H-16549	1	Waste Gas Treatment Bldg Air-Conditioning System (N62) P&ID
H-16560	1	PRNM System (C51) IED
H-16561	1	PRNM System (C51)
H-16564	1	Process Radiation Monitoring System (D11) P&ID

HNP-2-FSAR-1

TABLE 1.1-1 (SHEET 7 OF 20)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
H-16567	1	Feedwater Control System Turbine-Driven Feed Pumps (C32) IED
H-16568	1	RPS (C71) P&ID
H-17012	1	Reactor Building 600 V MCC "1E-A" & "1E-B" MPL R24-S018A & R24-S018B Single-Line Diagram
H-17791	1	RPS (C71) Elementary Diagram
H-17792	1	RPS (C71) Elementary Diagram
H-19900	1	Logic Diagrams Legend and General Notes
H-19901	1	Nuclear Boiler System (B21) Logic Diagram
H-19902	1	Nuclear Boiler System (B21) Logic Diagram
H-19903	1	Nuclear Boiler System (B21) Logic Diagram
H-19904	1	Nuclear Boiler System (B21) Logic Diagram
H-19905	1	Nuclear Boiler System (B21) Logic Diagram
H-19906	1	Nuclear Boiler System (B21) Logic Diagram
H-19907	1	Nuclear Boiler System (B21) Logic Diagram
H-19908	1	Nuclear Boiler System (B21) Logic Diagram
H-19909	1	Nuclear Boiler System (B21) Logic Diagram
H-19910	1	Nuclear Boiler System (B21) Logic Diagram
H-19911	1	Nuclear Boiler System (B21) Logic Diagram
H-19912	1	Nuclear Boiler System (B21) Logic Diagram
H-19913	1	RRS (B31) Logic Diagram
H-19914	1	RRS (B31) Logic Diagram
H-19915	1	RRS (B31) Logic Diagram
H-19916	1	RRS (B31) Logic Diagram
H-19917	1	RRS (B31) Logic Diagram
H-19918	1	CRDHS (C11) Logic Diagram
H-19919	1	CRDHS (C11) Logic Diagram
H-19920	1	CRDHS (C11) Logic Diagram
H-19921	1	CRDHS (C11) Logic Diagram

HNP-2-FSAR-1

TABLE 1.1-1 (SHEET 8 OF 20)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
H-19922	1	CRDHS (C11) Logic Diagram
H-19923	1	CRDHS (C11) Logic Diagram
H-19924	1	CRDHS (C11) Logic Diagram
H-19925	1	CRDHS (C11) Logic Diagram
H-19926	1	SLCS (C41) Logic Diagram
H-19927	1	NMS (C51) Logic Diagram
H-19928	1	NMS (C51) Logic Diagram
H-19929	1	NMS (C51) Logic Diagram
H-19930	1	NMS (C51) Logic Diagram
H-19931	1	NMS (C51) Logic Diagram
H-19932	1	NMS (C51) Logic Diagram
H-19933	1	RPS (C71) Logic Diagram
H-19934	1	RPS (C71) Logic Diagram
H-19935	1	RPS (C71) Logic Diagram
H-19936	1	RPS (C71) Logic Diagram
H-19937	1	RHR System (E11) Logic Diagram
H-19938	1	RHR System (E11) Logic Diagram
H-19939	1	RHR System (E11) Logic Diagram
H-19940	1	RHR System (E11) Logic Diagram
H-19941	1	RHR System (E11) Logic Diagram
H-19942	1	RHR System (E11) Logic Diagram
H-19943	1	RHR System (E11) Logic Diagram
H-19944	1	CS System (E21) Logic Diagram
H-19945	1	CS System (E21) Logic Diagram
H-19946	1	CS System (E21) Logic Diagram
H-19947	1	HPCI System (E41) Logic Diagram
H-19948	1	HPCI System (E41) Logic Diagram
H-19949	1	HPCI System (E41) Logic Diagram

HNP-2-FSAR-1

TABLE 1.1-1 (SHEET 9 OF 20)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
H-19950	1	HPCI System (E41) Logic Diagram
H-19951	1	HPCI System (E41) Logic Diagram
H-19952	1	HPCI System (E41) Logic Diagram
H-19953	1	HPCI System (E41) Logic Diagram
H-19954	1	HPCI System (E41) Logic Diagram
H-19955	1	RCIC System (E51) Logic Diagram
H-19956	1	RCIC System (E51) Logic Diagram
H-19957	1	RCIC System (E51) Logic Diagram
H-19958	1	RCIC System (E51) Logic Diagram
H-19959	1	RCIC System (E51) Logic Diagram
H-19960	1	RCIC System (E51) Logic Diagram
H-19961	1	RCIC System (E51) Logic Diagram
H-19962	1	RCIC System (E51) Logic Diagram
H-19963	1	RWC System (G31) Logic Diagram
H-19964	1	RWC System (G31) Logic Diagram
H-19965	1	NMS (C51) Logic Diagram
H-19966	1	NMS (C51) Logic Diagram
H-19967	1	CRDHS (C11) Logic Diagram
H-21001	1	General Arrangement - Turbine Room Base Slab at el 112 ft 0 in.
H-21002	1	General Arrangement - Turbine Room Intermediate Floor at el 130 ft 0 in.
H-21003	1	General Arrangement - Turbine Room Floor Slab at el 147 ft 0 in.
H-21004	1	General Arrangement - Turbine Room Operating Floor at el 164 ft 0 in.
H-21006	1	General Arrangement - Turbine Bldg Section A-A
H-21007	1	General Arrangement - Turbine Bldg Section B-B
H-21012	1	Main Steam System P&ID

TABLE 1.1-1 (SHEET 10 OF 20)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
H-21018	1	Condensate Polishing and Demineralizer System (N21) P&ID
H-21026	1	Turbine Bldg Circulating Water System (W23/N22/N71) P&ID
H-21028	1	Control Bldg Service Air System (P51) P&ID
H-21030	1	Turbine Bldg Condenser Vacuum and Gland Seal System (N22/N33) P&ID
H-21033	1	Turbine Bldg Service Water System (P41) P&ID
H-21037	1 thru 5	Turbine Bldg Condensate and Feedwater System (N21) P&ID
H-21038	1 thru 3	Turbine Bldg Condensate and Feedwater System (N21) P&ID
H-21039	1	RHRWS System (E11) P&ID
H-21056	1	SJAE System (N22) P&ID
H-21061	1	Turbine Bldg Floor, Equipment, and Roof Drains (U45/U55) P&ID
H-21062	1	Turbine Bldg Floor and Equipment Drains P&ID
H-21063	1	Control Bldg Floor and Equipment Drains (Z45) P&ID
H-21074	1	Diesel Engine and Fuel Oil System (R43) P&ID
H-21077	1	Turbine Bldg Instrument Air System (P52) P&ID
H-21102	1	Piping - Service Water at Intake Structure
H-21114	1	Piping - Circulating Water System
H-22250	1	Control Bldg. Concrete - General Arrangement - el 112 ft 0 in., 130 ft 0 in., 147 ft 0 in., and 164 ft 0 in.
H-22802	1	Architectural Turbine Building – Floor Plan – el 112 ft 0 in.
H-23390	1	125/250-V DC Station Service Division 1 2R42A MPL's 2R25-S001 and 2R25-S002 Single-Line Diagram
H-23635	1	24/48-V-dc System (2R42E) Single Line Diagram
H-23754	1	Communications Turbine Building el 164 ft 0 in.
H-23761	1	Communications-Wiring Diagram Turbine and Control Building el 147 ft 0 in. and 164 ft 0 in.
H-23768	1	Communications – Typical Wiring Diagram for Communications Stations

TABLE 1.1-1 (SHEET 11 OF 20)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
H-23769	1	Turbine and Control Building Communications Interconnection Diagram
H-24700	1	Logic Diagram Legends and General Notes
H-24701	1	Nuclear Boiler System (B21) Logic Diagram
H-24702	1	Nuclear Boiler System (B21) Logic Diagram
H-24703	1	Nuclear Boiler System (B21) Logic Diagram
H-24704	1	Nuclear Boiler System (B21) Logic Diagram
H-24705	1	Nuclear Boiler System (B21) Logic Diagram
H-24706	1	Nuclear Boiler System (B21) Logic Diagram
H-24707	1	Nuclear Boiler System (B21) Logic Diagram
H-24708	1	Nuclear Boiler System (B21) Logic Diagram
H-24709	1	Nuclear Boiler System (B21) Logic Diagram
H-24710	1	Nuclear Boiler System (B21) Logic Diagram
H-24711	1	Nuclear Boiler System (B21) Logic Diagram
H-24712	1	Nuclear Boiler System (B21) Logic Diagram
H-24713	1	RRS (B31) Logic Diagram
H-24714	1	RRS (B31) Logic Diagram
H-24715	1	RRS (B31) Logic Diagram
H-24716	1	RRS (B31) Logic Diagram
H-24717	1	CRDHS (C11) Logic Diagram
H-24718	1	CRDHS (C11) Logic Diagram
H-24719	1	CRDHS (C11) Logic Diagram
H-24720	1	CRDHS (C11) Logic Diagram
H-24721	1	SLCS Logic (C41) Diagram
H-24722	1	NMS (C51) Logic Diagram
H-24723	1	NMS (C51) Logic Diagram
H-24724	1	NMS (C51) Logic Diagram
H-24725	1	NMS (C51) Logic Diagram

HNP-2-FSAR-1

TABLE 1.1-1 (SHEET 12 OF 20)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
H-24726	1	NMS (C51) Logic Diagram
H-24727	1	NMS (C51) Logic Diagram
H-24728	1	RPS (C71) Logic Diagram
H-24729	1	RPS (C71) Logic Diagram
H-24730	1	RPS (C71) Logic Diagram
H-24731	1	RPS (C71) Logic Diagram
H-24732	1	RHR System (E11) Logic Diagram
H-24733	1	RHR System (E11) Logic Diagram
H-24734	1	RHR System (E11) Logic Diagram
H-24735	1	RHR System (E11) Logic Diagram
H-24736	1	RHR System (E11) Logic Diagram
H-24737	1	RHR System (E11) Logic Diagram
H-24738	1	RHR System (E11) Logic Diagram
H-24739	1	CS System (E21) Logic Diagram
H-24740	1	CS System (E21) Logic Diagram
H-24741	1	CS System (E21) Logic Diagram
H-24742	1	HPCI System (E41) Logic Diagram
H-24743	1	HPCI System (E41) Logic Diagram
H-24744	1	HPCI System (E41) Logic Diagram
H-24745	1	HPCI System (E41) Logic Diagram
H-24746	1	HPCI System (E41) Logic Diagram
H-24747	1	HPCI System (E41) Logic Diagram
H-24748	1	HPCI System (E41) Logic Diagram
H-24749	1	HPCI System (E41) Logic Diagram
H-24750	1	RCIC System (E51) Logic Diagram
H-24751	1	RCIC System (E51) Logic Diagram
H-24752	1	RCIC System (E51) Logic Diagram
H-24753	1	RCIC System (E51) Logic Diagram

HNP-2-FSAR-1

TABLE 1.1-1 (SHEET 13 OF 20)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
H-24754	1	RCIC System (E51) Logic Diagram
H-24755	1	RCIC System (E51) Logic Diagram
H-24756	1	RCIC System (E51) Logic Diagram
H-24757	1	RCIC System (E51) Logic Diagram
H-24758	1	RWC System (G31) Logic Diagram
H-24759	1	RWC System (G31) Logic Diagram
H-24760	1	RRS (B31) Logic Diagram
H-24781	1	CRDHS (C11) Logic Diagram
H-24782	1	CRDHS (C11) Logic Diagram
H-24784	1	CRDHS (C11) Logic Diagram
H-24785	1	NMS (C51) Logic Diagram
H-24786	1	NMS (C51) Logic Diagram
H-24787	1	CRDHS (C11) Logic Diagram
H-25000	1	Reactor Bldg Containment Vessel Requirements - Drywell Plans and Sections
H-25004	1	Reactor Bldg RPV Pedestal Development Elevation (Inside and Out)
H-25005	1	Reactor Bldg RPV Pedestal Sectional Plans and Sections
H-25993	1	Shielding - Floor Plan at el 87 ft 0 in.
H-25994	1	Shielding - Floor Plan at el 130 ft 0 in.
H-25995	1	Shielding - Floor Plan at el 147 ft 0 in.
H-25996	1	Shielding - Floor Plan at el 158 ft 0 in.
H-25997	1	Shielding - Floor Plan at el 185 ft 0 in.
H-25998	1	Shielding - Floor Plan at el 203 ft 0 in.
H-25999	1	Shielding - Floor Plan at el 228 ft 0 in.
H-26000	1	Nuclear Boiler System (B21) P&ID
H-26001	1	Nuclear Boiler System (B21) P&ID
H-26002	1	TSC HVAC System (X75) P&ID and PFD
H-26003	1	RRS (B31) P&ID

HNP-2-FSAR-1

TABLE 1.1-1 (SHEET 14 OF 20)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
H-26006	1	CRD System (C11) P&ID
H-26007	1	CRD System (C11) P&ID
H-26008	1	Reactor and Radwaste Bldgs Chilled Water System (P65) P&ID and PFD
H-26009	1	SLCS (C41) P&ID
H-26010	1	Area Radiation Monitoring System (D21) IED
H-26011	1	Process Radiation Monitoring System (D11) P&ID
H-26012	1	Process Radiation Monitoring System (D11) IED
H-26013	1	Process Radiation Monitoring System (D11) IED
H-26014	1	RHR System (E11) P&ID
H-26015	1	RHR System (E11) P&ID
H-26016	1	Fission Products Monitoring (D11) System P&ID
H-26017	1	Fission Products and Post-LOCA Monitoring Systems (D11) P&ID
H-26018	1	CS System (E21) P&ID
H-26019	1	Jockey Pump System P&ID and PFD for RHR and CS Systems
H-26020	1	HPCI System (E41) P&ID
H-26021	1	HPCI System (E41) P&ID
H-26023	1	RCIC System (E51) P&ID
H-26024	1	RCIC System (E51) P&ID
H-26025	1	Reactor and Radwaste Bldgs Chilled Water System (P65) P&ID and PFD
H-26026	1	Radwaste System (G11) P&ID
H-26027	1	Radwaste System (G11) P&ID
H-26028	1	Radwaste System (G11) P&ID and PFD
H-26029	1	Radwaste System (G11) P&ID
H-26030	1	Radwaste System (G11) P&ID
H-26031	1	Radwaste System (G11) P&ID
H-26032	1	Radwaste System (G11) P&ID

TABLE 1.1-1 (SHEET 15 OF 20)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
H-26035	1	Radwaste Bldg Support Systems (P&ID)
H-26036	1	RWC System (G31) P&ID
H-26037	1	RWC System (G31) P&ID
H-26039	1	FPCC System (G41) P&ID
H-26040	1	Fuel Pool Filter/Demineralizer System (G41) P&ID
H-26042	1	Torus Drainage and Purification System (G51) P&ID and PFD
H-26045	1	Offgas System (N62) P&ID
H-26046	1	Reactor and Radwaste Bldgs Condensate Storage and Transfer System (P11) Diagram
H-26048	1	Primary Containment Atmosphere H ₂ and O ₂ Analyzer System (P33) P&ID
H-26049	1	Primary Containment Atmosphere H ₂ and O ₂ Analyzer System (P33) P&ID
H-26050	1	Reactor Bldg PSW System (P41) P&ID
H-26051	1	Reactor Bldg PSW System (P41) P&ID
H-26054	1	RBCCW System (P42) P&ID
H-26055	1	RBCCW System (P42) P&ID
H-26063	1	Reactor, Radwaste, and Turbine Bldgs Auxiliary Steam System (P61) P&ID
H-26064	1	Reactor Bldg South Side Noninterruptable Instrument Air System (P52) P&ID
H-26066	1	Drywell Pneumatic System (P70) P&ID
H-26067	1	Reactor Zone Ventilation System (T41) P&ID
H-26070	1	Reactor Bldg North Side Noninterruptable Instrument Air System (P52) P&ID
H-26071	1	Safeguards Equipment Emergency Cooling System (T41) P&ID
H-26072	1	Reactor Bldg Refueling Floor Ventilation System (T41) P&ID
H-26074	1	Primary Containment Cooling System (T47) P&ID and PFD
H-26075	1	Reactor Bldg Floor Equipment and Roof Drainage System (T45) Diagram

HNP-2-FSAR-1

TABLE 1.1-1 (SHEET 16 OF 20)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
H-26076	1	Leak Detection System Instrument and Drainage Sumps (T45) P&ID
H-26078	1	SGTS (T46) P&ID
H-26080	1	Primary Containment Chilled Water System (P64) P&ID and PFD
H-26081	1	Primary Containment Chilled Water System (P64) P&ID and PFD
H-26083	1	Nitrogen Inerting System (T48) P&ID
H-26084	1	Primary Containment Purge and Inerting System (T48) P&ID
H-26086	1	Turbine Bldg Ventilation System (U41) P&ID
H-26088	1	Turbine Bldg Chilled Water System P&ID Sheet 1
H-26089	1	Turbine Bldg Chilled Water System P&ID Sheet 2
H-26090	1	Radwaste Bldg Ventilation System (V41) P&ID
H-26092	1	Radwaste Bldg Floor and Equipment Drainage System (V45) Diagram
H-26093	1	Control Bldg Ventilation System (Z41) P&ID and PFD
H-26094	1	Control Bldg - MCR Air Conditioning System (Z41) PFD
H-26095	1	Piping and Valve Code Classification Diagram
H-26096	1	General Arrangement - Reactor Bldg Below el 130 ft
H-26097	1	General Arrangement - Radwaste Bldg at el 103 ft 0 in.
H-26098	1	General Arrangement - Reactor Bldg at el 130 ft 0 in. and Radwaste Bldg at el 132 ft 4 in.
H-26099	1	General Arrangement - Drywell Area at el 148 ft 3-1/2 in., Radwaste Bldg at el 148 ft 0 in., and Hot Machine Shop at el 130 ft 0 in.
H-26100	1	General Arrangement - Reactor Bldg at el 158 ft 0 in. and Radwaste Bldg at el 164 ft 0 in.
H-26101	1	General Arrangement - Reactor Bldg at el 185 ft 0 in. and Radwaste Bldg Roof at el 178 ft 0 in.
H-26102	1	General Arrangement - Reactor Bldg Plan at el 203 ft 0 in.
H-26103	1	General Arrangement - Reactor Bldg Plan at el 228 ft 0 in.
H-26104	1	General Arrangement - Reactor Bldg Section A-A

HNP-2-FSAR-1

TABLE 1.1-1 (SHEET 17 OF 20)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
H-26105	1	General Arrangement - Reactor Bldg Section B-B
H-26106	1	General Arrangement - Radwaste Bldg Section C-C
H-26116	1	MCR Shift Supervisor's Area HVAC (Z41) P&ID and PFD
H-26128	1	HPCI System Plan View - HPCI Room and Reactor Bldg East
H-26130	1	HPCI System Sections
H-26142	1	Torus Drainage and Purification System
H-26189	1	Nuclear Boiler System (B21) P&ID
H-26191	1	ERF/SPDS (X75) Block Diagram
H-26202	1	Drywell Floor and Equipment Drainage System at el 114 ft 6 in.
H-26237	1	Reactor Bldg Ventilation System at el 203 ft 0 in. East
H-26238	1	Reactor Bldg Ventilation System at el 203 ft 0 in. West
H-26240	1	Reactor Bldg Ventilation System at el 228 ft 0 in. West
H-26260	1	Reactor Bldg Instrument Air System (P52) Plan and Sections Below el 130 ft 0 in.
H-26261	1	Reactor Bldg Instrument Air System (P52) Plan and Sections at el 130 ft 0 in.
H-26279	1	RCIC System - Reactor Bldg Below el 130 ft 0 in. West
H-26280	1	RCIC System - Reactor Bldg Below el 130 ft 0 in. East
H-26384	1	Post Accident Reactor Coolant and Containment Atmosphere Sampling System (P33) P&ID
H-26391	1	Reactor Bldg and Drywell Sumps Discharge Piping
H-26424	1	Instrument and Primary Point Locations Section A-A
H-26991	1	Feedwater Control System (C32) - Turbine-Driven Feed Pumps IED
H-26993	1	NMS IED
H-27021	1	Reactor Building 600V AC Essential MC 2E-A & MCC 2E-B MPL 2R24-S018A & 2R24-S018B Single Line Diagram
H-27057	1	Emergency Response Facility and Process Mini Computer Single-Line Diagram

HNP-2-FSAR-1

TABLE 1.1-1 (SHEET 18 OF 20)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
H-27450	1	Unit 2 Nuclear Steam Supply Shutoff System 2A71 Elementary Diagram Sheet 1
H-27460	1	Unit 2 Nuclear Steam Supply Shutoff System 2A71 Elementary Diagram Sheet 11
H-27461	1	Unit 2 Nuclear Steam Supply Shutoff System 2A71 Elementary Diagram Sheet 12
H-27612	1	RPS (C71) Elementary Diagram
H-27613	1	RPS (C71) Elementary Diagram
H-28023	1	Drywell Pneumatic System (P70) P&ID
H-28135	1	Post Accident Sampling Chemical Analysis System (P33) P&ID
H-29000	1	Reactor Bldg ISI Doors N1A and N1B
H-29026	1	Reactor Building Pipe Whip Restraint Details
H-40056	1	Control Bldg Cold Lab HVAC P&ID at el 112 ft 0 in.
H-40429	1	Architectural - Control Bldg Partial Plan at el 130 ft 0 in.
H-40430	1	Architectural - Control Bldg Partial Plan at el 130 ft 0 in.
H-43801	1	Water Treatment System (HNP-1/HNP-2) P&ID
H-44073	1	River Intake Structure HVAC P&ID
H-45458	1	Dry Cask Spent-Fuel Storage Crawler Travel Path From RR Airlock to ISFSI
H-50563	1	Reactor and Radwaste Bldgs Chilled Water System PFD
H-51178	1	Control Bldg Chilled Water System P&ID and PFD
H-51179	1	Control Bldg Chilled Water Cooling Units P&ID
H-51307	1	Panel 2H11-P603 Reactor Control Demarcation and Layout
H-51357	1	Panel 2C82-P001 Remote Shutdown Demarcation and Layout
H-51358	1	Panel 2H21-P173 Remote Shutdown Instrument Demarcation and Layout
S-15051		Information Document Piping and Instrumentation Symbols
S-15059		CRDHS PFD
S-15062		RPV Nozzle Details - GE VPF-1983-52
S-15066		RCIC System PFD

HNP-2-FSAR-1

TABLE 1.1-1 (SHEET 19 OF 20)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
S-15070		NMS Arrangement
S-15117		CS System PFD
S-15213		RPV Assembly - GE VPF-1983-63-8
S-15227		Nozzle Details for 218" I.D. BWR
S-15247		MSIV Primary Steam Piping
S-15265		General Arrangement - Suppression Chamber Field Assembly
S-15290		General Plan
S-15304		RHR System PFD
S-15305		RHR System PFD
S-15329		Earthquake Ties
S-15422		Shell Stretchout
S-15520		Suppression Chamber Penetration Schedule and Orientation
S-15523		General Arrangement - RPV Elevation - GE VPF-1983-115-4
S-15524		General Arrangement - RPV Plan - GE VPF-1983-114-2
S-15584		NMS - PRNM Unit
S-15591		SRM/IRM Unit Purchase Parts
S-15665		Penetration Schedule Orientation Below Equator
S-15666		Penetration Schedule Orientation Above Equator
S-15667		Penetration Schedule Orientation Above Equator
S-16122		HPCI System PFD
S-25124		NMS - PRNM Unit Parts List
S-25140		RHR System PFD
S-25141		RHR System PFD
S-25171		RCIC System PFD
S-25176		HPCI System PFD
S-25178		CS System PFD
S-25285		RWC System PFD
S-25311		CRDHS PFD

HNP-2-FSAR-1

TABLE 1.1-1 (SHEET 20 OF 20)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Title</u>
S-25312		Process Data for CRDHS
S-25562		SRM/IRM Unit Purchase Part
S-26583		General Arrangement - Personnel Airlock
S-26984		Arrangement - Reactor Control BB
S-26986		Arrangement - Reactor Control BB
S-27793		Water Seal Assembly Inside Drywell Cylinder
S-28220		Reactor Assembly
S-28221		Reactor Assembly
S-28222		Reactor Assembly
S-28223		Reactor Assembly
S-28224		Reactor Assembly
S-28225		Reactor Assembly
S-28345		Barrier Plates
S-40969		HDFSS Module Assembly Details - 13-in. Wide
S-55894		Traveling Water Screen
S-60192		Condensate Polisher Body Feed System Piping and Instrumentation
SX-16121		Reactor Assembly - Section 1
SX-16122		Reactor Assembly - Section 2
SX-16123		Reactor Assembly - Section 3
SX-28760		Information Document Piping Instrument Symbols

1.2 GENERAL PLANT DESCRIPTION

1.2.1 SITE CHARACTERISTICS (HNP-1 AND HNP-2)

1.2.1.1 Location (HNP-1 and HNP-2)

The plant site is located in Appling County near Baxley, Georgia. The nearest site boundary to the reactor building is 4300 ft or 1310 m for HNP-2 and 4400 ft for HNP-1. The nearest site boundary to the main plant stack is 4100 ft or 1250 m. The nearest public road is US Hwy No. 1 located about 3500 ft west of the plant. The plant is bordered on the north by the Altamaha River. A plot plan is shown on drawing no. E-10173, and the plant property plan is shown in figure 1.2-1.

1.2.1.2 Site Ownership

The site is jointly owned by the Georgia Power Company (GPC), the Oglethorpe Power Corporation (OPC), the Municipal Electric Authority of Georgia, and the city of Dalton, Georgia.

1.2.1.3 Access to the Site

Access to the plant site and all activities thereon are under the control of Southern Nuclear Operating Company.

1.2.1.4 Site Environs

The area surrounding the site is primarily wooded, with a small amount of land devoted to farming. The nearest development community and the location of the nearest industry is Baxley, located about 11 miles south of the site, with an estimated population of 4800. The nearest major city with a population approaching 25,000 is Waycross, Georgia, with a population of ~ 21,200. Waycross is 48 miles south of the plant site.

1.2.1.5 Geology

The site is within the Atlantic Coastal Plain Province and is adjacent to the Altamaha River flood plain. The geologic strata consist of Holocene to Miocene age gravel, sand, silt, and clay to a depth of about 500 ft. Below these deposits are Tertiary and Cretaceous age sedimentary rocks with a consistency primarily of limestone and sandstone ~ 3500 ft thick. These strata overlie basaltic basement rock of pre-Cretaceous age, which is over 4000 ft beneath the site. The coastal plain sediments were eroded from the older Appalachian and Piedmont provinces to the west and deposited along coastal areas in progressively seaward belts. The sediments generally dip and thicken seaward, forming a wedge-shaped deposit. The surface of the basement rock on which the coastal plain strata rest is believed to be continuous with the surface of the Piedmont Province located above the Fall Line where the overlapping coastal plain sediments wedge out.

The major structural features of the Georgia Coastal Plain are a gentle southeastward dip of the coastal plain strata and the Southeast Georgia embayment. The southeastward dip is regional in character and ranges from 5 to 50 ft/mile. The dip increases with depth as a result of seaward thickening of the coastal plain deposits. The southeast Georgia embayment is a depositional basin recessed into the Atlantic Coast between Savannah, Georgia and Jacksonville, Florida. The basin received relatively thick sequences of Cretaceous-through-Miocene age material from higher areas to the north and south. Regional cross-sections through the embayment indicate that subsidence of the basin had ceased by the end of Miocene time.

1.2.1.6 Seismology and Design Response Spectra

The seismicity of the site was evaluated on the basis of historical earthquakes, damage from earthquake shocks, and the regional and local geologic structure. No active or recent faulting has been mapped in the area of the proposed site. The area is not seismically active; however, the effects of earthquakes from distant sources have been experienced at the site. The Charleston, South Carolina earthquake of 1886, with the epicenter located ~ 150 miles from the site, is the type which would be felt at the site. The maximum epicentral intensity probably decreased to MM-VII at Savannah, located ~ 70 miles from the site, and the area of greatest damage was within 100 miles of the plant site. The intensity decreased to about MM-VI in the site area. This value is considered conservative and corresponds to a peak horizontal acceleration of 0.08 g for plant design. The plant has a capability for safe shutdown if subjected to a peak horizontal acceleration of 0.15 g. Design spectra consistent with these accelerations were used for the analysis of Category I structures and equipment.

1.2.1.7 Hydrology

The site natural grade varies between 70 ft above msl at the river to 147 ft msl at the visitors' building. The natural grade for the various plant structures varies from 118 to 147 ft msl. The maximum river level established from the flood record was ~ el 91.3 ft msl. This is based on records from a station 18.8 miles upstream. Flooding of the plant site is unlikely. Seismic Category I plant structures and equipment located on the flood plain, such as discharge and intake structures necessary for long-term safe conditions at the plant, are flood protected and designed to withstand the design flood. The design flood stage at the plant is el 105.0 ft msl.

The extrapolated hypothetical natural minimum low flow, without reservoir supplementation, is 900 ft³/s with a corresponding river elevation of 61.9 ft msl. The minimum instantaneous flow and stage of record are ~ 1200 ft³/s and el 62.4 ft msl.

The ground water in the plant vicinity exists under free and confined conditions. Field observations show that the free ground water flow is toward the river. There is an impermeable deposit overlying the deep artesian aquifers. This aquiclude in conjunction with the upward gradient of the artesian zone precludes radioactive contamination of the deep artesian zone by downward percolation. The possibility of affecting the surface well supplies is remote, since the gradient of the perched and free water is toward the river. The ground water characteristics of the site are very favorable for the construction and operation of a nuclear power plant.

1.2.1.8 Meteorology

The climate at the site is typical of that in the southern Atlantic Coastal Plan; i.e., hot and humid in the summer and mild in the winter. Maximum rainfall in a 30-year period of record at Glennville, located 24 miles east of the site, was ~ 15 in. in a 24-h period. The maximum average monthly rainfall was about 7.6 in. Prevailing winds are from the WNW, but wind directions are well distributed. Maximum windspeeds at Savannah, located about 70 miles east on the coast, in a 40-year period of record were 90 mph. Equivalent maximum speeds at the site are expected to be less since the site is inland. During 44 years of record, 24 hurricanes or post-hurricane path center lines passes within 100 miles of the site. Seven tornadoes have occurred in a 10-year period of record (1956-1965) within a 25-mile radius. This is probably typical of tornado frequency in the site region. An onsite meteorological measurement program was initiated in 1970 to provide data to assess limits to be set later on radioactive gas releases.

1.2.1.9 Environmental Radiation Monitoring

An environmental radiation monitoring program was conducted before the startup of HNP-1. The environmental radiation monitoring program is discussed in section 11.6.

1.2.2 FACILITY ARRANGEMENT (HNP-1 AND HNP-2)

The two units are arranged on the site so that the turbine-generator axes are oriented on a north-south azimuth approximately perpendicular to the Altamaha River. The reactor buildings are located on the east side of the turbine building. The main control room is shared by both units and is physically located at the north end of the HNP-2 turbine building. The radwaste equipment for each unit is housed in separate buildings adjacent to both the turbine and the reactor buildings. The administration building and the machine shop are located west of the turbine building. The diesel generator building is located on the north side of the HNP-1 turbine building.

The main plant stack is located ~ 620 ft east of the north-south centerline of the HNP-2 reactor building. The cooling towers are located east of the main plant. The independent spent fuel storage installation (ISFSI) is located south of the main plant adjacent to the main rail line serving the plant.

The plant is located a minimum distance of 4300 ft from the nearest site boundary. The nearest site boundary to the main plant stack is 4100 ft. Figures 1.2-1 and 1.2-4 show the relationship between the principal plant structures and the site boundaries.

1.2.3 NUCLEAR SYSTEM (HNP-1 AND HNP-2)

The nuclear systems use single-cycle, forced-circulation, General Electric boiling water reactors (GE-BWRs) producing steam for direct use in the steam turbine. A heat balance showing the major parameters of the nuclear system for the rated power condition is shown for HNP-2 in figure 1.2-2 and for HNP-1 in figure 1.2-3. Both units were originally rated at 2436 MWt and designed for a power level corresponding to ~ 2537 MWt. Both units are now licensed for 2804 MWt.

Table 1.2-2 compares key reactor conditions at the original rated power, uprated power, extended uprated power, thermal optimization uprated power, and reactor operating pressure increase uprated power.

1.2.3.1 Reactor Primary Vessel and Internals

Each reactor primary vessel contains the reactor core and support structure; steam separators and dryers; jet pumps; control rod guide tubes; distribution lines for the feedwater, core spray (CS), and standby liquid control (SLC) systems; and the incore instrumentation and other components. The main connections to the vessel include the steam lines, the reactor coolant recirculation lines, the reactor feedwater lines, the emergency core cooling lines, and the control rod drive (CRD) housings.

The reactor primary vessel is designed and fabricated in accordance with the applicable codes for a pressure of 1250 psig. The nominal operating pressure is 1045 psig at the steam dome. The vessel is fabricated of carbon steel, and the cylindrical portion and bottom head are clad internally with stainless steel.

The reactor core is cooled by light water which enters the lower portion of the core and boils as it flows upward around the fuel rods. The steam leaving the core is dried by steam separators and dryers located in the upper portion of the reactor primary vessel. The steam is then directed to the turbine through the main steam lines. Each main steam line is provided with two isolation valves in series, one on each side of the primary containment vessel wall.

1.2.3.2 Reactor Core and Control Rods

The fuel for the reactor core consists of slightly enriched uranium dioxide pellets contained in sealed Zircaloy-2 tubes. These fuel rods are assembled into individual fuel assemblies. The number of fuel assemblies in the complete core is 560. The fuel assembly configurations are described in *NEDE-24011-P-A, "GESTAR II - General Electric Standard Application for Reactor Fuel" (incorporated by reference into the FSAR)*.

Gross control of the core is achieved by movable, bottom-entry control rods supplemented by gadolinia-urania burnable poison rods in the initial fuel load. The control rods are of cruciform shape and are dispersed throughout the lattice of fuel assemblies. The rods are controlled by individual hydraulic drives.

1.2.3.3 Reactor Recirculation System (RRS)

Reactor power level control is augmented by controlling the reactor coolant recirculation system flowrate through the reactor core. This is accomplished by two recirculation loops external to the reactor vessel but inside the primary containment. Each loop has one motor-driven recirculation pump. The speed of the recirculation pump can be varied to allow some control of reactor power level through the effects of coolant flowrate on moderator void content.

1.2.3.4 Residual Heat Removal (RHR) System

The RHR system is a system of pumps, heat exchangers, and piping that fulfills the following functions:

- A. Removal of decay and sensible heat from the reactor core during and after shutdown.
- B. Removal of stored and decay heat from the reactor core following a design basis loss-of-coolant accident (LOCA). This system is discussed in subsection 1.2.7.
- C. Removal of heat from the primary containment following a LOCA in order to limit the increase in primary containment pressure. This is accomplished by cooling and recirculating the water inside the primary containment. The redundancy of the equipment provided for containment cooling is further extended by a separate part of the RHR system which sprays cooling water into the containment. This latter capability is discussed in paragraph 1.2.7.12.

1.2.3.5 Reactor Water Cleanup (RWC) System

A RWC system, which includes a filter-demineralizer arrangement, is provided to clean up the reactor water and to reduce the amounts of activated corrosion products in the water.

1.2.4 POWER CONVERSION SYSTEMS (HNP-1 AND HNP-2)

To produce electrical power, each unit utilizes a power conversion system which includes a turbine-generator, a turbine bypass system, a main condenser, air ejectors, air ejector condensers, a turbine gland-seal condenser, condensate demineralizers, and a feedwater heating and pumping system. The steam comes from the reactor, drives the turbine-generator, and is exhausted to the condenser. The deaerated condensate is demineralized prior to regenerative heating necessary for its return as feedwater to the reactor. The heat rejected in the main condenser is removed by a closed-loop circulating water system utilizing cooling towers as a heat sink. Figures 1.2-5 and 1.2-7 show the turbine-generator heat balance at rated load for HNP-2 and HNP-1, respectively.

1.2.4.1 Turbine-Generator (HNP-1 and HNP-2)

The turbine is a GE 1800-rpm, tandem-compound, 4-flow reheat unit with 43-in. last-stage buckets. It has a double-flow high-pressure section and two double-flow low-pressure sections. Exhaust steam from the high-pressure section passes through moisture separators and a two-stage reheater before entering the low-pressure sections of the unit. The turbine has six extraction stages for reactor feedwater system heating. Steam to drive the reactor feed pump turbines is taken from the steam path immediately after reheating but prior to passing through the low-pressure sections of the main turbine. The turbine controls include a speed governor, steam admission (control) valves, emergency stop valves, combined intermediate valves, and redundant initial pressure regulators.

The generator is a direct coupled, 60-Hz, 24,000-V synchronous unit with a water-cooled stator and a hydrogen-cooled rotor (field).

1.2.4.2 Turbine Bypass System (HNP-1 and HNP-2)

A bypass system is provided to allow passing of steam from the reactor directly to the main condenser under control of the initial pressure regulator. Steam is bypassed to the condenser whenever the steam generation rate exceeds the flowrate corresponding to the load connected to the turbine-generator. The bypass system would, for example, be used during generator synchronization or rejection of a large electrical load. The system has the capacity to pass ~ 21% for HNP-1 and ~ 20% for HNP-2 of the 100% RTP steam flowrate.

1.2.4.3 Main Condenser (HNP-1 and HNP-2)

The main condenser is of the single-pass, divided-water-box, deaerating type. It consists of two shells, one for each low- pressure turbine section. The Unit 2 hotwell is designed to provide a minimum condensate retention time of ~ 2 min., permitting decay of short-lived radioactive isotopes. Deaeration is provided in the condenser for removal of the dissolved gases from the condensate.

1.2.4.4 Main Condenser Air Ejector (HNP-1 and HNP-2)

Two twin, three-stage steam jet air ejectors (SJAEs) of 100% percent redundant capacity, complete with inter- and after-condensers, are provided for evacuating gases from the turbine and the main condenser during normal operation. One mechanical vacuum pump is provided to remove gases from the main condenser during startup and shutdown when steam is not available for the SJAEs.

1.2.4.5 Turbine Steam Sealing System (HNP-1 and HNP-2)

The turbine sealing system provides steam to the seals on the turbine valve packings and the turbine shaft packings at a pressure slightly above atmospheric. This system collects and

condenses the sealing steam and discharges air leakage to the gland holdup system. The holdup system serves mainly to allow short half-life radioactive gases to decay before being discharged to the main stack.

1.2.4.6 Circulating Water System (HNP-1 and HNP-2)

Two vertical, one-half capacity, removable-element, circulating water pumps located in the circulating water pump structure provide a continuous supply of condenser cooling water. The water is pumped from and returned to the mechanical draft cooling towers where the temperature of the water is reduced before being recirculated through the main condenser. Evaporation, drift, and blowdown losses are compensated for by makeup water taken from the Altamaha River.

1.2.4.7 Condensate Demineralizer System (HNP-1 and HNP-2)

The condensate demineralizer system consists of seven filter-demineralizers, including one spare, connected with associated piping and valving for parallel operation. Instrumentation and controls are provided to ensure proper operation and to protect against malfunction of the equipment. The system is designed to maintain a high purity reactor feedwater quality by removing ionic and particulate materials from the feedwater system.

1.2.4.8 Condensate and Reactor Feedwater Systems (HNP-1 and HNP-2)

The condensate and reactor feedwater system takes condensate from the main condenser and after six stages of heating delivers it to the reactor.

Condensate is pumped by three motor-driven vertical pumps through the steam jet air ejector inter- and after-condensers and the turbine gland-seal condenser. After leaving the turbine gland-seal condenser, the condensate passes through a full flow condensate demineralizer and the off-gas condenser. The purified condensate is then boosted in pressure by three motor-driven condensate booster pumps. The condensate is then divided into two parallel streams, each with five stages (four for HNP-1) of low-pressure feedwater heating. The feedwater is then boosted in pressure by two turbine-driven reactor feed pumps. The flow from the two reactor feed pumps is then divided into two parallel streams, each with one stage of high-pressure feedwater heating. The feedwater then flows in two streams to the reactor.

1.2.4.9 CROSSFLOW™ System (HNP-1 and HNP-2)

The reactor feedwater systems are equipped with high accuracy, ultrasonic flow measurement devices that provide a correction to the feedwater flow venturi measurement used in the reactor heat balance and core thermal power computation. The accuracy of the CROSSFLOW™ system reduces the overall power measurement uncertainty to within 0.5% and supports a 1.5% power uprate from 2763 MWt to the new rated power level of 2804 MWt. A more detailed description of the application of this system is provided in FSAR paragraph 7.6.8.3.7.2.1.

1.2.5 ELECTRICAL POWER SYSTEM (HNP-1 and HNP-2)

The generator for HNP-2 is connected to the 22.8-500-kV main step-up transformer with an isolated phase bus. The transformer is connected to the plant switchyard, which has 500-kV and 230-kV system connections and a 500/230-kV autotransformer. The HNP-1 generator is connected to the 22.8-230-kV main step-up transformer bus. This transformer is connected to the plant switchyard which has 230-kV system connections.

1.2.6 RADIOACTIVE WASTE SYSTEMS (HNP-1 and HNP-2)

The radioactive waste systems are designed to control the release of station-produced radioactive material to within the limits specified in 10 CFR 20.1001 - 20.2402. This is done by various methods such as collection, filtration, holdup for decay, and dilution. The methods employed for the controlled release of these contaminants are dependent primarily upon the state of the material: liquid, solid, or gaseous.

1.2.6.1 Liquid Radwaste System

The liquid radioactive waste control system collects, treats, stores, and disposes of all radioactive liquid wastes. These wastes are collected in sumps and drain tanks at various locations throughout the plant and then transferred to the appropriate collection tanks in the radwaste building for treatment, storage, dilution, and disposal, as necessary. Wastes are processed on a batch basis. Processed liquid wastes may be returned to the condensate system or discharged to the river by way of the discharge pipe. The liquid wastes in the discharge pipe are diluted with water from the cooling tower blowdown and with that portion of the service water in excess of normal cooling tower makeup in order to achieve a permissible concentration at the site boundary.

Equipment is selected, arranged, and shielded to permit operation, inspection, and maintenance with minimum personnel exposure. For example, tanks and processing equipment which are expected to contain significant radiation sources are located behind shielding; and similarly, sumps, pumps, instruments, and valves are located in controlled-access rooms or shielded spaces. Processing equipment is designed to require a minimum of maintenance. Protection against accidental discharge of liquid radioactive waste is provided by an automatic shutoff valve via a high-radiation signal from a radiation monitor.

1.2.6.2 Solid Radwaste System

With the solid radwaste system, solid radioactive wastes are collected, processed, and packaged for storage. Generally, these wastes are stored onsite until the short half-lived activities are insignificant so as to permit economical shielding and shipping. Process solid wastes are collected, dewatered, and otherwise prepared for storage in containers for offsite shipment. Examples of these solid wastes are:

- Filter residue.
- Spent resins.
- Paper.
- Air filter elements.
- Used clothing.

Solid wastes from equipment originating in the nuclear system, such as control rods, fuel channels, incore detectors, etc., are stored for radioactive decay in the fuel storage pool and later prepared for offsite shipment in approved shipping containers.

1.2.6.3 Gaseous Radwaste System (GRS)

The GRS collects, processes, and delivers gases from the main condenser air ejector, startup vacuum pump, and gland-seal condenser to the main stack for elevated release to the atmosphere. Noncondensable radioactive gases are removed from the main condenser by the air ejector. The normal condenser offgas system uses a high-temperature catalytic recombiner to recombine radiolytically disassociated hydrogen and oxygen from the air ejector system. After cooling to strip the condensables and reduce the volume, the remaining noncondensables are delayed in the 30-min holdup system. Essentially, the 30-min decay time allows the noble gases with short half-lives to decay completely to solid daughters. The biologically significant decay chains containing Sr-89, Sr-90, Ba-140, and Cs-137 decay to these solids, which are removed by the high-efficiency off-gas filters. As a result of these process actions and the fact that halogens remain principally in the reactor coolant and are removed by the reactor cleanup demineralizer system, radioactive particles and halogens are not released from the off-gas system in significant amounts. Holdup in this system provides ample time to prevent release of fission product gases in excess of the permissible main stack release rate limits.

During startup, air is removed from the main condenser by the mechanical vacuum pump and is discharged to the main stack via the gland-seal holdup system.

The gland-seal condenser is exhausted by a blower into shielded piping which provides 1.75-min holdup to reduce the activity of short-lived radioactive gases (N-16 and O-19), which are then discharged to the main stack.

1.2.7 NUCLEAR SAFETY SYSTEMS AND ENGINEERED SAFEGUARDS (HNP-1 AND HNP-2)

1.2.7.1 Reactor Protection System (RPS) (HNP-1 and HNP-2)

The RPS initiates a rapid, automatic shutdown (scram) of the reactor. This action is taken in time to prevent fuel-cladding damage and any nuclear system process barrier damage following abnormal operational transients. The RPS overrides all operator actions and process controls.

1.2.7.2 Neutron Monitoring System (NMS) (HNP-1 and HNP-2)

Those portions of the NMS that provide high neutron flux signals to the RPS qualify as a nuclear safety system. The intermediate range monitors (IRMs) and average power range monitors (APRMs), which monitor neutron flux via incore detectors, signal the RPS to scram in time to prevent excessive fuel cladding damage as a result of overpower transients. The oscillation power range monitor (OPRM) detects thermal-hydraulic oscillations and provides indication and annunciation in the MCR.

1.2.7.3 Control Rod Drive System (HNP-1 and HNP-2)

When a scram is initiated by the RPS, it is the CRD system that inserts the negative reactivity necessary to shut down the reactor. Each control rod is controlled individually by a hydraulic control unit. When a scram signal is received, high-pressure water from an accumulator for each rod rapidly forces each control rod into the core.

1.2.7.4 Pressure Relief System (HNP-1 and HNP-2)

A pressure relief system consisting of safety relief valves mounted on the main steam lines is provided to prevent excessive pressure inside the nuclear system following either normal operations, abnormal operational transients, or accidents.

1.2.7.5 Reactor Core Isolation Cooling (RCIC) System (HNP-1 and HNP-2)

The RCIC system provides makeup water to the reactor vessel whenever the vessel is isolated. The RCIC system uses a steam-driven turbine-pump unit and operates automatically in time and with sufficient coolant flow to maintain adequate reactor vessel water level.

1.2.7.6 Primary Containment (HNP-1 and HNP-2)

A pressure suppression primary containment houses the reactor vessel, the reactor coolant recirculating loops, and other branch connections of the reactor primary system. The primary containment system consists of the following:

HNP-2-FSAR-1

- A drywell.
- A pressure suppression chamber which stores a large volume of water.
- A connecting vent system between the drywell and the pressure suppression pool.
- A vacuum relief system.
- Isolation valves.
- Containment cooling systems.
- Other service equipment.

In the event of a process system piping failure within the drywell, reactor water and steam are released into the drywell air space. The resulting increased drywell pressure then forces a mixture of air, steam, and water through the vent system into the pool of water which is stored in the suppression chamber. The steam condenses in the suppression pool, resulting in a rapid pressure reduction in the drywell. Air which is transferred to the suppression chamber pressurizes the suppression chamber and is subsequently vented to the drywell to equalize the pressure between the two vessels. Cooling systems are provided to remove heat from the reactor core, from the drywell, and from the water in the suppression chamber, thus providing continuous cooling of the primary containment under accident conditions.

Appropriate isolation valves are actuated during this period to ensure containment of radioactive materials within the primary containment which otherwise might be released from the reactor during the course of the accident.

1.2.7.7 Primary Containment and Reactor Vessel Isolation Control Systems (HNP-1 and HNP-2)

The primary containment and reactor vessel isolation control systems automatically initiate the closure of isolation valves to close off all potential leakage paths for radioactive material to the environs. This action is taken upon indication of a potential breach in the nuclear system process barrier.

1.2.7.8 Secondary Containment (HNP-1 and HNP-2)

The reactor building is designed as a low in-leakage, elevated-release, secondary containment system which houses the primary containment system, refueling facilities, and most of the components of the nuclear steam supply system. The secondary containment system provides secondary containment when the primary containment system is closed and in service; it also provides primary containment when the primary containment system is open, as in refueling. The secondary containment system consists of the reactor building, standby gas treatment system (SGTS), reactor building isolation control system, and main stack.

In the event of a postulated pipe break inside the drywell or a fuel-handling accident, the reactor building is isolated by the reactor building isolation control system to provide a low leakage barrier. The SGTS is initiated by the same conditions that isolate the reactor building. The SGTS exhausts air from the reactor building to maintain a reduced pressure within the reactor building relative to the outside atmosphere. The system also treats the air to remove particulates and iodines and releases the air through the elevated release point, the main stack.

1.2.7.9 Main Steam Line Isolation Valves (MSIVs) (HNP-1 and HNP-2)

Although all pipelines which both penetrate the primary containment and offer a potential release path for radioactive material are provided with redundant isolation capabilities, the main steam lines, because of their large size and large mass flowrates, are given special isolation consideration. Two automatic isolation valves, each powered by both air pressure and spring force, are provided in each main steam line. These valves fulfill the following objectives:

- A. They prevent excessive damage to the fuel barrier by limiting the loss of reactor coolant from the reactor vessel resulting from either a major leak from the steam piping outside the primary containment or from a malfunction of the pressure control system resulting in excessive steam flow from the reactor vessel.
- B. They limit the release of radioactive materials by closing the nuclear system process barrier in case of a gross release of radioactive materials from the fuel to the reactor cooling water and steam.
- C. They limit the release of radioactive material by closing the primary containment barrier in case of a major leak from the nuclear system inside the primary containment.

1.2.7.10 Main Steam Line Flow Restrictors (HNP-1 and HNP-2)

A venturi-type flow restrictor is installed in each steam line close to the reactor vessel. These devices limit the loss of coolant from the reactor vessel before the MSIVs are closed in case of a main steam line break outside the primary containment and prevent uncovering of the core.

1.2.7.11 Emergency Core Cooling System (ECCS) (HNP-1 and HNP-2)

Four ECCS subsystems are provided to prevent fuel cladding melting in the event of a breach in the nuclear system process barrier that results in a loss of reactor coolant. The four ECCS subsystems are:

- High-pressure coolant injection (HPCI).
- Automatic depressurization.
- CS.
- Low-pressure coolant injection (LPCI) - an operating mode of the RHR system.

The ECCS initiation and control instrumentation is divided in two parts: the incident detection circuitry (IDC) and the control instrumentation. The IDC includes those channels which detect a need for core cooling systems operation and the corresponding trip systems which initiate the proper ECCS response.

1.2.7.11.1 High-Pressure Coolant Injection (HPCI) System (HNP-1 and HNP-2)

The HPCI system provides and maintains an adequate coolant inventory inside the reactor vessel to prevent fuel cladding melting as a result of postulated small breaks in the nuclear system process barrier, with the exception of the HPCI steam line. In the case of breaks in the HPCI steam line, other systems are available for accident mitigation. A high-pressure system is needed for such breaks because the reactor vessel depressurizes slowly, preventing low-pressure systems from injecting coolant. The HPCI system includes a turbine-pump powered by reactor steam.

1.2.7.11.2 Automatic Depressurization System (HNP-1 and HNP-2)

The ADS acts to rapidly reduce reactor vessel pressure during postulated accident situations in which the HPCI system fails to automatically maintain reactor vessel water level. The depressurization provided by the system enables the LPCI and CS systems to deliver cooling water to the reactor vessel. The ADS uses some of the safety relief valves which are part of the nuclear system pressure relief system. The ADS is initiated automatically upon conditions of high drywell pressure and low reactor vessel water level, provided either the CS system or the LPCI cooling mode of RHR is available for core cooling. In the event the reactor pressure vessel level 1 signal is present for 13 min without a concurrent high drywell pressure signal, the high drywell pressure is bypassed and the ADS timer sequence starts.

1.2.7.11.3 Core Spray System (HNP-1 and HNP-2)

The CS system consists of two independent pump loops that deliver cooling water to spray spargers over the core. The system is actuated by conditions indicating that a breach exists in the nuclear system process barrier, but water is delivered to the core only after reactor vessel pressure is reduced. This system provides the capability to cool the fuel by spraying water onto the core. Either CS loop is capable of preventing fuel cladding melting following a LOCA.

1.2.7.11.4 Low-Pressure Coolant Injection (HNP-1 and HNP-2)

The LPCI is an operating mode of the RHR system but is discussed here because the LPCI mode acts as an engineered safeguard in conjunction with the other standby cooling systems. LPCI uses the pump loops of the RHR system to inject cooling water at low pressure into a reactor recirculation loop. LPCI is actuated by conditions indicating a breach in the nuclear system process barrier, but water is delivered to the core only after reactor vessel pressure is reduced. LPCI operation, together with the core shroud and jet pump arrangement, provides the capability of core reflooding following a LOCA in time to prevent fuel clad melting.

1.2.7.12 Containment Spray and Suppression Pool Cooling (HNP-1 and HNP-2)

The suppression pool cooling subsystem of RHR is placed in operation to limit the temperature of the water in the suppression pool following a design basis LOCA. In the suppression pool cooling mode of operation, the RHR main system pumps take suction from the suppression pool and pump the water through the RHR heat exchangers where cooling takes place by transferring heat to the station cooling systems. The fluid is then discharged back to the suppression pool.

Another portion of the RHR system is provided to spray water into the containment as an augmented means of removing energy from the containment following a LOCA. This capability is in excess of the required energy removal capability and can be placed into service at the discretion of the operator.

1.2.7.13 (Deleted)

1.2.7.14 Control Rod Velocity Limiter (HNP-1 and HNP-2)

A control rod velocity limiter is attached to each control rod to limit the velocity at which a control rod can fall out of the core should it become detached from its CRD. The rate of reactivity insertion resulting from a rod drop accident is limited by this action. The limiters contain no moving parts.

1.2.7.15 Control Rod Drive Housing Supports (HNP-1 and HNP-2)

CRD housing supports are located beneath the reactor vessel near the control rod housings. The supports limit the travel of a control rod in the event a control rod housing is ruptured. The supports prevent a nuclear excursion as a result of a housing failure, thus protecting the fuel barrier.

1.2.7.16 Standby Electric Power Systems (HNP-1 and HNP-2)

The plant is designed to shut down safely and maintain a safe condition on complete loss of offsite electrical power. Standby power is supplied by diesel generators after shutdown to provide auxiliary cooling, lighting, and miscellaneous services to permit communication and access to all plant areas and also to ensure continued removal of decay heat.

1.2.7.17 dc Power Supply (HNP-1 and HNP-2)

In the event that normal plant power sources become unavailable, the plant battery system provides power for all controls vital to plant safety and for those functions required for a safe shutdown, such as:

- Closing of isolation valves.
- Operation of valves required for core cooling.
- Providing minimum required lighting.
- Providing minimum instrumentation.
 - Control rod position indicators.
 - Neutron channel to monitor the core during shutdown.

1.2.7.18 Plant Service Water (PSW) System (HNP-1 and HNP-2)

Each PSW system consists of four, one-third-capacity wet pit service water pumps which are located in the river intake structure and of distribution piping and controls. There is also one diesel standby service water pump. Portions of the system, including the pumps which are required for emergency cooling, are designed as a Seismic Category I system and meet the single-failure criteria.

1.2.7.19 Residual Heat Removal Service Water (RHRSW) System (HNP-1 and HNP-2)

Each RHRSW system supplies river water to the RHR heat exchangers to remove heat during both normal and accident conditions. The system consists of two independent loops, each with two pumps, and of the associated valves and piping. The RHRSW system pumps are located near the river in the Seismic Category I intake structure. A steel barrier exists between division 1 and division 2 of the RHRSW system pumps to provide protection from jet impingement to the RHRSW pump motors and associated equipment.

1.2.7.20 Main Steam Line Radiation Monitoring System (HNP-1 and HNP-2)

Each main steam line radiation monitoring system consists of gamma radiation monitors located externally to the main steam lines just outside the primary containment. The monitors are designed to detect a release of fission products from the fuel.

1.2.7.21 Reactor Building Isolation and Control System (HNP-1 and HNP-2)

Each reactor building isolation and control system consists of a number of radiation monitors arranged in the reactor building exhaust duct to monitor the activity level of the ventilation exhaust from the reactor building. The monitors are designed to detect release of fission products from the nuclear system. Upon detection of high radiation, the trip signals generated by the monitors are used to isolate the reactor building and to actuate the SGTS.

1.2.7.22 Containment Atmospheric Dilution (CAD) System (HNP-1 and HNP-2)

A CAD system is used to control the concentration of hydrogen and oxygen that may be generated in the drywell and torus following a postulated LOCA. The CAD system controls the combustible gases within the containment by diluting the combustible gases.

1.2.7.23 Main Control Room Environmental Control (MCREC) System (HNP-1 and HNP-2)

The MCREC system supplies heating, ventilation, and air-conditioning (HVAC) for the main control room during normal operating and accident conditions. The system consists of three 50% capacity air handling units with electric heaters, cooling coils and fans, two exhaust air fans, and two high-efficiency air filtration units complete with charcoal adsorbers. Signals from two monitors located in the outside air intake duct and inside the main control room automatically terminate the supply of outside air when conditions of high radiation exist. The main control room air is then recirculated through the air filtration ducts. The operator can manually bring outside air back into the main control room through the filter units.

1.2.7.24 Equipment Area Cooling Systems (HNP-1 and HNP-2)

Equipment area cooling systems are provided to maintain the local environment of specific areas at temperatures within normal operating temperatures for electrical components located within these areas. The system consists of a number of fan-coil coolers. The PSW system supplies water to the cooling coils and serves as the heat sink for the equipment area cooling systems.

1.2.7.25 Low-Low Set (LLS) Relief Logic System (HNP-2)

The LLS relief logic system extends the time between subsequent safety relief valve (SRV) actuations during a small- or intermediate-break LOCA. This action is taken to mitigate the postulated thrust loads and the effects of high-frequency loads on the torus shell caused by subsequent SRV actuations.

1.2.8 SPECIAL SAFETY SYSTEMS (HNP-1 AND HNP-2)

1.2.8.1 Standby Liquid Control System (HNP-1 and HNP-2)

Although not intended to provide prompt reactor shutdown, the SLCS provides a redundant, independent, and different way for the control rods to bring the nuclear fission reaction to subcriticality and to maintain subcriticality as the reactor cools. The system makes possible an orderly and safe shutdown in the event that not enough control rods can be inserted into the reactor core to accomplish shutdown in the normal manner. The system is sized to counteract the positive reactivity effect from full power to the cold shutdown condition.

1.2.8.2 Shutdown Capability Outside the Main Control Room (HNP-1 and HNP-2)

Sufficient equipment and controls are available outside the main control room to enable an operator to shut down the reactor and maintain it in a safe condition if access to the control room is lost.

1.2.9 PROCESS CONTROL AND INSTRUMENTATION (HNP-1 AND HNP-2)

1.2.9.1 Nuclear System Process Control and Instrumentation

1.2.9.1.1 Reactor Manual Control System (RMCS) (HNP-1 and HNP-2)

The RMCS provides the means by which control rods are manipulated from the control room for gross power control. The system controls valves in the control rod drive hydraulic system. Only

one control rod can be manipulated at a time. The RMCS includes the controls that restrict control rod movement--rod block--under certain conditions as a backup to procedural controls.

1.2.9.1.2 Recirculation Flow Control System (RFCS) (HNP-1 and HNP-2)

The RFCS controls the speed of the reactor recirculation pumps. Adjusting the pump speed changes the coolant flowrate through the core. This effects changes in core power level. The system is designed to allow manual adjustment of reactor power output to the load demand by adjusting the frequency of the electrical power supply for the reactor recirculation pumps.

1.2.9.1.3 Neutron Monitoring System (HNP-1 and HNP-2)

The NMS is a system of incore neutron detectors and out-of-core electronic equipment. The system provides indication of neutron flux which can be correlated to thermal power level for the entire range of flux conditions that may exist in the core. The source range monitors (SRMs) and the IRMs provide flux level indications during reactor startup and low-power operation. The local power range monitors (LPRMs) and the APRMs allow assessment of local and overall flux conditions during power range operation. Rod block monitors are provided to prevent rod withdrawal when reactor power should not be increased at the existing reactor coolant flowrate. The traversing incore probe subsystem provides a means to calibrate the LPRM system.

1.2.9.1.4 Refueling Interlocks (HNP-1 and HNP-2)

A system of interlocks that restricts the movements of refueling equipment and control rods when the reactor is in the refueling mode is provided to prevent an inadvertent criticality during refueling operations. The interlocks back up procedural controls that have the same objective. The interlocks affect the following:

- Refueling platform.
- Refueling platform hoists.
- Fuel grapple.
- Control rods.

1.2.9.1.5 Reactor Vessel Instrumentation (HNP-1 and HNP-2)

In addition to instrumentation provided for the nuclear safety systems and engineered safeguards, instrumentation is provided to monitor and transmit information that can be used to assess conditions existing inside the reactor vessel and the physical condition of the vessel itself. The provided instrumentation monitors the following:

HNP-2-FSAR-1

- Reactor vessel pressure.
- Water level.
- Surface temperature.
- Internal differential pressures.
- Coolant flowrates.
- Top head flange leakage.

1.2.9.1.6 Process Computer System (HNP-1 and HNP-2)

An online process computer is provided to monitor and log process variables and to make certain analytical computations.

1.2.9.1.7 Rod Worth Minimizer (HNP-1 and HNP-2)

The rod worth minimizer prevents rod withdrawal under low-power conditions if the rod to be withdrawn is not in accordance with a preplanned pattern. The effect of the rod block is to limit the reactivity worth of the control rods by enforcing adherence to the preplanned rod pattern. The nuclear measurement analysis and control rod worth minimizer (NUMAC-RWM) enhanced rod position indicating system (RPIS) application is described in GE Topical Report NEDO-31146.

1.2.9.2 Power Conversion Systems Process Control and Instrumentation (HNP-1 and HNP-2)

1.2.9.2.1 Pressure Regulator and Turbine Control

The pressure regulator controls both the turbine admission control valves and the turbine bypass valves and maintains constant reactor pressure. Pressure regulation is coordinated with the turbine speed and the load control systems. The turbine control utilizes an electrohydraulic control system arranged for remote operation.

1.2.9.2.2 Feedwater Control System

A three-element controller is used to regulate the feedwater system so that proper water level is maintained in the reactor vessel. The controller uses main steam flowrate, reactor vessel water level, and feedwater flowrate signals. The feedwater control signal is used to regulate the speed of the turbine-driven reactor feed pumps to adjust flow.

1.2.9.3 Electrical Power System Process Control (HNP-1 and HNP-2)

To prevent loss of system integrity due to an electrical failure of a component, high-speed automatic protective relaying is utilized to isolate the faulted component from the remainder of the system.

1.2.9.4 Radiation Monitoring and Control (HNP-1 and HNP-2)

1.2.9.4.1 Process Radiation Monitoring (HNP-1 and HNP-2)

Radiation monitors are provided on various lines to monitor either for radioactive materials released to the environs via process liquids and gases or for process system malfunctions. Monitors are provided in the following subsystems:

- Air ejector off-gas.
- Main stack.
- Reactor building ventilation.
- Main steam line.
- Process and cooling liquids.
 - Radwaste.
 - Service water.
 - RBCCW.
 - HVAC systems.

1.2.9.4.2 Area Radiation Monitors

A number of radiation monitors are provided to monitor for abnormal radiation at various locations in the reactor building, the turbine building, the radwaste building, and the main control room. These monitors annunciate alarms when abnormal radiation levels are detected.

1.2.9.4.3 Fission Products Monitoring System

The fission products monitoring system is installed to monitor samples from the primary containment atmosphere for radiation from air particulates, radioactive iodine, and noble gases. A three-channel monitor is provided for each function. The activity from each is displayed on a log rate meter located in the control room.

1.2.9.4.4 Liquid Radwaste System Control (HNP-1 and HNP-2)

The liquid radwaste system collects, treats, and stores liquid radioactive wastes on a batch basis with protection against accidental discharge provided by the design and supplemented by the procedural controls. Liquid wastes are discharged on a batch basis at a controlled rate after sampling and laboratory analysis. Instrumentation is provided with alarms to detect abnormal radioactivity concentration in the liquid radwaste discharges and to automatically isolate the liquid radwaste discharge.

1.2.9.4.5 Solid Radwaste Control (HNP-1 and HNP-2)

The solid radwaste system collects, treats, and stores solid radioactive wastes for offsite shipment. Wastes are handled on a batch basis. Radiation levels of the various batches are controlled by the operator.

1.2.9.4.6 Gaseous Radwaste System Control (HNP-1 and HNP-2)

The GRS is continuously monitored by the main stack radiation monitor and the air ejector off-gas radiation monitor. A high level signal from the air ejector off-gas radiation monitoring system, after an appropriate time delay, automatically isolates the off-gas system by closing the isolation valves between the air ejector system and the main stack.

1.2.10 AUXILIARY SYSTEMS (HNP-1 AND HNP-2)

1.2.10.1 Auxiliary ac Power (HNP-1 and HNP-2)

The unit auxiliary transformers are located outside the turbine building and are connected to the generator bus utilizing isolated phase bus. The plant startup auxiliary transformers are located

outside the turbine building and are connected to the transmission system via the 230-kV main switchyard.

The auxiliary ac power system utilizes 4160-V metal-enclosed switchgear, 600-V metal-enclosed switchgear and motor control centers, and 120/208-V metal-enclosed switchgear and distribution cabinets. All switchgear and vital, essential distribution cabinets have two separate sources of supply.

1.2.10.2 Plant Service Water System (HNP-1 and HNP-2)

Each PSW system consists of four, one-third capacity vertical wet pit service water pumps located in the river intake structure, distribution piping, and controls. Three service water pumps are required for normal operation. Three service pumps are required for plant startup, while only one pump is required for shutdown and emergency shutdown. The pumps are controlled so that if the operating pumps cannot maintain the required system pressure the standby pump or pumps start automatically.

1.2.10.3 Fire Protection System (FPS) (HNP-1 and HNP-2)

The FPS is designed to provide an adequate supply of water or chemicals to points throughout the plant area where fire fighting may be required. The water for the system is taken from two 300,000-gal tanks which are replenished automatically from deep wells. In addition to the tanks, the system consists of one electric-motor driven pump, two diesel engine pumps, one jockey-booster-pump and associated valves, piping, and hydrants. The necessary instrumentation and controls are provided to ensure proper operation of the water FPS. This system is shared by both units.

Chemical fire fighting systems are also provided as additions to or in lieu of the water fire fighting system.

1.2.10.4 Drywell Pneumatic System (HNP-1 and HNP-2)

The drywell pneumatic system provides gas of suitable quality and pressure to supply the equipment within the drywell requiring motive gas. The gas receiver storage capacity is adequate to supply equipment with gas for a minimum period of 10 min in the event that none of the supplies of nitrogen to the drywell pneumatic system are available.

1.2.10.5 Torus Drainage and Purification System (HNP-1 and HNP-2)

The torus drainage and purification system provides capability for the cleanup of suppression pool waters through a process of filtration and demineralization. The torus drainage and cleanup system can also be used in reducing or completely draining the suppression pool waters to allow inspection of the torus interior surface coating. See subsection 9.3.7 for system

design and description, and subsection 18.3.3 for a description of the protective coatings program.

1.2.10.6 Heating, Ventilation, and Air-Conditioning Systems (HNP-1 and HNP-2)

The station HVAC systems provide appropriate ambient temperature and environmental conditions for station operating personnel and equipment. Normal airflow is routed from lesser to progressively greater areas of contamination potential prior to final exhaust. The arrangement is ensured by a positive air pressure in the clean areas and a negative air pressure in the potentially contaminated areas.

1.2.10.7 New and Spent-Fuel Storage (HNP-1 and HNP-2)

New fuel is stored in a dry storage vault located adjacent to the spent-fuel pool area in the reactor building. Transport of spent fuel and irradiated channels during refueling is handled under water. Spent fuel is stored under water in the spent-fuel pool in the reactor building and at the ISFSI in dry storage casks until prepared for shipment from the site.

1.2.10.8 Fuel Pool Cooling and Filtering System (HNP-1 and HNP-2)

The spent-fuel pool cooling and demineralizer system is provided to clean the pool water and remove decay heat from the spent fuel stored in the spent fuel storage pool.

1.2.10.9 Service and Instrument Air Systems (HNP-1 and HNP-2)

The service and instrument air systems are supplied oil-free air by one 700-sf³/min and two 500-sf³/min compressors connected in parallel. Except for the drywell pneumatic system, diesel starting air, and low pressure service air, the 700-sf³/min compressor normally supplies all compressed air requirements for service air and for the pneumatic instruments and controls throughout the plant. One of the 500-sf³/min compressors is an automatic standby, and the other 500-sf³/min compressor serves as the backup. Two low-pressure air blowers provide oil-free air for other low-pressure service requirements. A separate air system is provided to start the emergency diesel generators. Another independent system provides instrument air inside the drywell. The drywell pneumatic system provides instrument motive gas inside the drywell and is normally isolated from the instrument air system.

1.2.10.10 Makeup Water Treatment System (HNP-1 and HNP-2)

The makeup water treatment system is designed to maintain a supply of treated water suitable as makeup for the station and the reactor coolant cycles and as makeup for other demineralized water requirements. Well water is processed through a filter-demineralizer and stored in a 100,000-gal demineralized water storage tank for use as needed. Other components of the system include:

HNP-2-FSAR-1

- Two 100% capacity pumps.
- Valves.
- Piping.
- Necessary instrumentation and controls to ensure proper operation of the equipment.

This system is shared by both units.

1.2.10.11 Potable and Sanitary Water System (HNP-1 and HNP-2)

The potable and sanitary water system provides water for drinking and sanitary purposes. Well water is filtered and treated to meet all applicable drinking water standards. Shower and lavatory waste water that does not contain radioactive material is directed to a sewage treatment system. This system is shared by both units.

1.2.10.12 Plant Equipment and Floor Drainage System (HNP-1 and HNP-2)

The plant equipment and floor drainage system is provided to collect and remove waste liquids from their points of origin and carry them to a suitable area for cleanup and disposal. Wastes are collected in the building sumps and pumped to the radwaste system for cleanup and eventual reuse or discharge. Section 10.13 of the HNP-1 FSAR provides further information related to the plant equipment and floor drainage systems.

1.2.10.13 Reactor Building Closed Cooling Water System (HNP-1 and HNP-2)

The RBCCW system is provided to supply a self-contained coolant to the reactor auxiliary system's equipment and accessories for heat removal during normal operating and shutdown conditions. The system consists of the following:

- Cooling loop containing three 50% capacity pumps.
- Two 100% capacity heat exchangers.
- Chemical addition tank.
- Surge tank.
- Associated valves and piping.

The RBCCW system is monitored continuously for radioactivity by the process radiation monitoring system.

1.2.10.14 Process Sampling System (HNP-1 and HNP-2)

The plant process sampling system is provided to monitor the quality of plant process flows. Information required for making operational decisions is obtained from analysis of samples from pertinent system streams.

1.2.10.15 Plant Communication System (HNP-1 and HNP-2)

Plant communications are provided through three independent systems: a public address system, a dial telephone system, and a two-way radio system. The public address and dial telephone systems are designed so that power can be provided by emergency diesel generators on loss of normal ac power.

1.2.10.16 Plant Lighting System (HNP-1 and HNP-2)

The plant lighting system consists of normal ac lighting equipment and emergency ac lighting equipment. In the event that ac power is lost, the emergency lighting equipment is automatically transferred to the station battery. This transfer to a dc power source ensures lighting continuity in the critical areas of the plant.

1.2.11 SHIELDING (HNP-1 AND HNP-2)

Shielding implemented by occupancy requirements in the various areas of the station is provided to meet the limits of applicable regulations.

1.2.12 IMPLEMENTATION OF LOADING CRITERIA (HNP-1 AND HNP-2)

Structures and equipment are designed to resist structural and mechanical damage due to loads produced by environmental and thermal forces. For the purpose of categorizing mechanical strength designs for these loads, the following definitions are established:

- Seismic Category I.
- Other than Seismic Category I.

1.2.12.1 Seismic Category I (HNP-1 and HNP-2)

This class includes those structures, pieces of equipment, and components whose failure or malfunction might cause or increase the severity of an accident which would endanger public health and safety. This category includes those structures, pieces of equipment, and components which are required for safe shutdown and isolation of the reactor.

1.2.12.2 Other Than Seismic Category I (HNP-1 and HNP-2)

This category includes those structures, pieces of equipment, and components which are important to reactor operation but are not essential for the mitigation of the consequences of these accidents. This category does not degrade the integrity of any item designated as Seismic Category I.

HNP-2-FSAR-1

DOCUMENTS INCORPORATED BY REFERENCE INTO THE FSAR

"GESTAR II - General Electric Standard Application for Reactor Fuel," NEDE-24011-P-A.

HNP-2-FSAR-1

TABLE 1.2-2 (SHEET 1 OF 2)

ORIGINAL AND UPDATED REACTOR OPERATING CONDITIONS

<u>Parameter</u>	HNP-1 Original Rated <u>Power</u>	HNP-1 Uprated <u>Power</u>	HNP-1 Extended Uprated <u>Power</u>	HNP-1 TPO Uprated <u>Power</u>	HNP-1 ROPI Uprated <u>Power</u>
Thermal power (MWt)	2436	2558	2763	2804	2804
Vessel steam flow (Mlbm/h)	10.0	10.6	11.5	11.6	11.6
Full power core flow range (% of rated)	87-105	87-105	91-105	93-105	93-105
Dome pressure (psia)	1020	1050	1050	1050	1060
Dome temperature (°F)	547	551	551	551	552
Turbine inlet pressure (psia)	950	985	1000	1002 ^(b)	1012 ^(b)
Feedwater flow ^(a) (Mlbm/h)	10.1	10.7	11.6	11.7	11.7
Feedwater temperature ^(a) (°F)	388	393	398	393	393
Core inlet enthalpy (Btu/lbm)	523.7	527.1	525.6	524.6	525.9

a. Includes RWC system flow.

b. Upstream side of TSV


HNP-2-FSAR-1

TABLE 1.2-2 (SHEET 2 OF 2)

<u>Parameter</u>	<u>HNP-2 Original Rated Power</u>	<u>HNP-2 Up-rated Power</u>	<u>HNP-2 Extended Up-rated Power</u>	<u>HNP-2 TPO Up-rated Power</u>	<u>HNP-2 ROPI Up-rated Power</u>
Thermal power (MWt)	2436	2558	2763	2804	2804
Vessel steam flow (Mlbm/h)	10.5	11.1	12.0	12.2	12.2
Full power core flow range (% of rated)	87-105	87-105	91-105	93-105	93-105
Dome pressure (psia)	1020	1050	1050	1050	1060
Dome temperature (°F)	547	551	551	551	552
Turbine inlet pressure (psia)	950	985	1000	993 ^(b)	1003 ^(b)
Feedwater flow ^(a) (Mlbm/h)	10.5	11.1	12.1	12.2	12.2
Feedwater temperature ^(a) (°F)	420	424	425	426	426
Core inlet enthalpy (Btu/lbm)	526.9	530.3	528.7	528.4	529.7

a. Includes RWC system flow.

b. Upstream side of TSV



LEGEND

- 1. Unit No. 1
- 2. Unit No. 2
- 3. Service Building
- 4. Switch House
- 5. Cooling Tower Area
- 6. Intake
- 7. Visitor Center
- 8. Plant Entrance
- 9. ISFSI PADS
- 10. Railroad
- 11. U.S. Highway No. 1
- 12. Security Building
- 13. Diesel Building
- 14. Water Treatment Building
- 15. Startup Boiler
- 16. Fire Protection Building
- 17. Condensate Storage Tank Unit No. 1
- 18. Condensate Storage Tank Unit No. 2
- 19. Offgas Stack
- 20. Waste Gas Treatment Building
- 21. Underground Oil Storage Tanks
- 22. Sewage Treatment Plant
- 23. Microwave Tower
- 24. Radwaste Storage Facility
- 25. Recreation Center
- 26. County Road 451
- 27. Sealand Storage Facility

ACAD 2010201

REV 26 9/08




SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 2

PLANT PROPERTY PLAN

FIGURE 1.2-1

Legend	
#	= Flow, lbm/hr
H	= Enthalpy, Btu/lbm
F	= Temperature, F
M	= Moisture, %
P	= Pressure, psia
Wd	= Rated Drive Flow



Core Thermal Power	2804.0
Pump Heating	7.5
Cleanup Losses	- 3.3
Other System Losses	- 1.1
Turbine Cycle Use	2807.1 MWt

REV 22 9/04




SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 2

REACTOR SYSTEM HEAT BALANCE FOR 100%
RATED CONDITION OR 2804 MWt (HNP-2)

FIGURE 1.2-2

Legend	
#	= Flow, lbm/hr
H	= Enthalpy, Btu/lbm
F	= Temperature, F
M	= Moisture, %
P	= Pressure, psia
Wd	= Rated Drive Flow



* Conditions at upstream side of TSV

Core Thermal Power	2804.0
Pump Heating	7.8
Cleanup Losses	- 3.3
Other System Losses	- 1.1
Turbine Cycle Use	2807.4 MWt


REV 22 9/04



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 2


REACTOR SYSTEM HEAT BALANCE FOR 100%
RATED CONDITION OR 2804 MWt (HNP-1)

FIGURE 1.2-3



NOTES
 N 702,000
 37 + 00
 GEORGIA GRID SYSTEM
 PLANT GRID SYSTEM

- SSF
- LEGEND
- SEISMIC CATEGORY I STRUCTURES
- CSTE CONDENSATE STORAGE TANK ENCLOSURE
 - CB CONTROL BUILDING
 - DGB DIESEL GENERATOR BUILDING
 - IS INTAKE STRUCTURE
 - MS MAIN STACK
 - RB REACTOR BUILDING
- NON SEISMIC CATEGORY I STRUCTURES
- CT COOLING TOWERS
 - METTWR METEROLOGICAL TOWER
 - MICTWR MICROWAVE TOWER
 - ORB OFFGAS RECOMGINR BLDG
 - RWB RADWASTE BUILDING
 - SB SERVICE BUILDING
 - SH SWITCH HOUSE
 - TB TURBINE BUILDING
 - VC VISITOR'S CENTER
 - WH WAREHOUSE
 - WGTB WASTEGAS TREATMENT BUILDING
 - WTP WATER TREATMENT PLANT
 - RST R/W STORAGE FACILITY
 - SSF SEALAND STORAGE FACILITY



ACAD 2010204


REV 26 9/08



SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 2

PROPERTY PLAN AND PRINCIPAL STRUCTURES

FIGURE 1.2-4



LEGEND:
 H,h - ENTHALPY - Btu/Lb
 # - FLOW - Lb/Hr
 P - PRESSURE - Psia
 F - TEMPERATURE - F DEGREES


REV 22 9/04



SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 2

RATED TURBINE GENERATOR
 HEAT BALANCE (HNP-2)

FIGURE 1.2-5



LEGEND:
 H,h - ENTHALPY - Btu/Lb
 # - FLOW - Lb/t
 P - PRESSURE - Psia
 F - TEMPERATURE - F DEGREES

REV 22 9/04



SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 2

RATED TURBINE GENERATOR
 HEAT BALANCE (HNP-1)

FIGURE 1.2-7

1.3 COMPARISON TABLES

1.3.1 COMPARISON WITH SIMILAR FACILITY DESIGNS (HNP-1 AND HNP-2)

This section highlights the principal design features of the plant and compares the major features with those of other boiling water reactor (BWR) facilities. Table 1.3-1 summarizes the initial plant design characteristics for Edwin I. Hatch Nuclear Plant-Units 1 and 2, Brunswick Steam Electric Plant-Unit 2, and Cooper Nuclear Station..

The design of these facilities is based upon proven technology attained during the development, design, construction, and operation of BWRs of similar or identical types. However, any of the data on this plant or the other plants are subject to revisions.

Table 1.3-1 does not reflect the license change to increase the rated thermal power to 2804 MWt. Key parameter differences between the original rated power of 2436 MWt and the current rated power of 2804 MWt are provided in section 1.2. Current fuel design parameters are provided in section 4.3.

TABLE 1.3-1 (SHEET 1 OF 11)

**NUCLEAR PLANTS
PRINCIPAL PLANT DESIGN FEATURES COMPARISON**

	<i>Brunswick Steam Electric Plant-Unit 2 (CP&L)</i>	<i>Cooper Nuclear Station (NPPD)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 1 (SNC)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 2 (SNC)</i>
A. Site				
1. Location	Brunswick County, NC	Nemaha County, Nebr	Appling County, Ga	Appling County, Ga
2. Size of site (acres)	1200	1090	2100	2100
3. Site ownership	Carolina Light and Power Co	NPPD	(a)	(a)
4. Plant ownership	CP & L	NPPD	(a)	(a)
5. Number of units onsite	2	1	2	2
B. Plant				
1. Reactor warranted conditions				
a. Net electrical output (MWe)	821	778	786	795
b. Gross electrical output (MWe)	849	801	813	822
c. Net heat rate (Btu/kW-h)	10,120	10,190	10,490	10,120
d. Gross heat rate (Btu/kW-h)	9788	10,142	10,218	9959
e. Feedwater temperature (°F)	420	367	387.4	424
C. Reactor Primary Vessel				
1. Inside diameter (ft-in.)	18-2 ^(b)	18-2 ^(b)	18-2 ^(b)	18-2 ^(b)
2. Overall length inside (ft-in.)	69-4 ^(b)	69-4 ^(b)	69-4 ^(b)	69-4 ^(b)
3. Design pressure (psig)	1250 ^(b)	1250 ^(b)	1250 ^(b)	1250 ^(b)
4. Wall thickness (in.)	5-17/32 ^(b)	5-17/32 ^(b)	5-17/32 ^(b)	5-17/32 ^(b)

HNP-2-FSAR-1

TABLE 1.3-1 (SHEET 2 OF 11)

	<i>Brunswick Steam Electric Plant-Unit 2 (CP&L)</i>	<i>Cooper Nuclear Station (NPPD)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 1 (SNC)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 2 (SNC)</i>
<i>D. Reactor Coolant Recirculation Loops</i>				
<i>1. Location of recirculation loops</i>	<i>Primary containment system drywell structure</i>	<i>Primary containment system drywell structure</i>	<i>Primary containment system drywell structure</i>	<i>Primary containment system drywell structure</i>
<i>2. Number of recirculation loops</i>	2	2	2	2
<i>3. Pipe size (in.)</i>	28	28	28	28
<i>4. Pump capacity, each gal/min</i>	45,200	45,200	45,200	45,200
<i>5. Number of jet pumps</i>	20	20	20	20
<i>6. Location of jet pumps</i>	<i>Inside reactor pressure vessel</i>	<i>Inside reactor pressure vessel</i>	<i>Inside reactor pressure vessel</i>	<i>Inside reactor pressure vessel</i>
<i>E. Reactor</i>				
<i>1. Reactor warranted conditions</i>				
<i>a. Thermal output (MWt)</i>	2436	2381	2436	2436
<i>b. Reactor operating pressure (psig)</i>	1005	1005	1005	1005
<i>c. Total reactor core flowrate (lb/h)</i>	78.5×10^6	74.5×10^6	78.5×10^6	78.5×10^6
<i>d. Main steam flowrate (lb/h)</i>	10.03×10^6	9.81×10^6	10.03×10^6	10.47×10^6
<i>2. Reactor core description (initial core)</i>				
<i>a. Lattice</i>	7 x 7	7 x 7, 8 x 8	7 x 7, 8 x 8	8 x 8
<i>b. Control rod pitch (in.)</i>	12.0	12.0	12.0	12.0
<i>c. Number of fuel assemblies</i>	560	548	560	560
<i>d. Number of control rods</i>	137	137	137	137

HNP-2-FSAR-1

TABLE 1.3-1 (SHEET 3 OF 11)

	<i>Brunswick Steam Electric Plant-Unit 2 (CP&L)</i>	<i>Cooper Nuclear Station (NPPD)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 1 (SNC)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 2 (SNC)</i>
2. <i>Reactor core description (initial core) (cont)</i>				
e. <i>Number of instrument tubes</i>	43	43	43	43
f. <i>Effective active fuel length (in.)</i>	144	144	144	146
g. <i>Equivalent reactor core diameter (in.)</i>	160.2	158.5	160.2	160.2
h. <i>Circumscribed reactor core diameter (in.)</i>	170.5	170.5	170.5	170.5
i. <i>Total weight UO₂ (lb)</i>	272,850	257,350	272,850	260,570
3. <i>Reactor fuel description (initial core)</i>				
a. <i>Fuel material</i>	UO ₂	UO ₂	UO ₂	UO ₂
b. <i>Fuel density (lb/ft³) @ 98.3% theoretical</i>	639	639	639	647
c. <i>Fuel pellet diameter(in.)</i>	0.487	0.487	0.487	0.416
d. <i>Fuel rod cladding material</i>	Zircaloy-2	Zircaloy-2	Zircaloy-2	Zircaloy-2
e. <i>Fuel rod cladding thickness (in.)</i>	0.082	0.082	0.082	0.082
f. <i>Fuel rod cladding process</i>	<i>Free standing loaded tubes</i>	<i>Free standing loaded tubes</i>	<i>Free standing loaded tubes</i>	<i>Free standing loaded tubes</i>
g. <i>Fuel rod outside diameter (in.)</i>	0.562	0.562	0.562	0.493
h. <i>Length of gas plenum (in.)</i>	16.0	16.0	16.0	14.0
i. <i>Fuel rod pitch (in.)</i>	0.737	0.737	0.737	0.640
j. <i>Fuel assembly channel material</i>	Zircaloy-4	Zircaloy-4	Zircaloy-4	Zircaloy-4

HNP-2-FSAR-1

TABLE 1.3-1 (SHEET 4 OF 11)

	<i>Brunswick Steam Electric Plant-Unit 2 (CP&L)</i>	<i>Cooper Nuclear Station (NPPD)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 1 (SNC)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 2 (SNC)</i>
4. <i>Reactor control</i>				
a. <i>Control rods</i>				
1. <i>Number</i>	137	137	137	137
2. <i>Shape</i>	Cruciform	Cruciform	Cruciform	Cruciform
3. <i>Material</i>	<i>B₄C granules compacted in SS tubes</i>	<i>B₄C granules compacted in SS tubes</i>	<i>B₄C granules compacted in SS tubes</i>	<i>B₄C granules compacted in SS tubes</i>
4. <i>Pitch (in.)</i>	12.0	12.0	12.0	12.0
5. <i>Poison length (in.)</i>	143.0	143.0	143.0	143.0
6. <i>Blade span (in.)</i>	9.75	9.75	9.75	9.75
7. <i>Number of control material tubes for rod</i>	84	84	84	84
8. <i>Tube dimensions(in.)</i>	0.1830Dx0.025-wall	0.1830Dx0.025-wall	0.1830Dx0.025-wall	0.1830Dx0.025-wall
9. <i>Stroke (in.)</i>	144.0	144.0	144.0	144.0
b. <i>Supplementary reactivity control</i>	<i>Gadolinia burnable poison</i>	<i>Gadolinia burnable poison</i>	<i>Gadolinia burnable poison</i>	<i>Gadolinia burnable poison</i>
5. <i>Thermal hydraulic data (initial core)</i>				
a. <i>Heat transfer area per assembly (ft²)</i>	86,513	86,513	86,513	98,93
b. <i>Reactor core heat transfer area (ft²)</i>	48,451	47,409	48,451	55,394
c. <i>Maximum heat flux^(c) (BTU/h ft²)</i>	428,308	428,308	428,308	346,600
d. <i>Average heat flux^(c) (BTU/h ft)</i>	164,740	164,740	164,740	142,600

HNP-2-FSAR-1

TABLE 1.3-1 (SHEET 5 OF 11)

	<i>Brunswick Steam Electric Plant-Unit 2 (CP&L)</i>	<i>Cooper Nuclear Station (NPPD)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 1 (SNC)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 2 (SNC)</i>
5. <i>Thermal hydraulic data (initial core) (cont)</i>				
e. <i>Maximum power per fuel^(c) rod unit length (kW/ft)</i>	18.5	18.5	18.5	13.4
f. <i>Average power per fuel rod unit length (kW/ft)^(c)</i>	7.11	7.11	7.11	5.4
g. <i>Maximum fuel temperature (°F)</i>	3290	4380	4380	3290
h. <i>Minimum critical heat flux ratio</i>	1.9	1.9	1.9	1.9
i. <i>Total heat generated in fuel (%)</i>	95.0	95.0	95.0	95.0
j. <i>Core average exit quality</i>	13.6	13.2	13.0	14.0
6. <i>Power distribution - peaking factors (peak/average) (initial core)</i>				
a. <i>Axial</i>	1.50	1.50	1.50	1.40
b. <i>Relative assembly</i>	1.40	1.40	1.40	1.40
c. <i>Local (within assembly)</i>	1.24	1.24	1.24	1.24
d. <i>Gross (1) x (2)</i>	2.10	2.10	2.10	1.96
7. <i>Nuclear design data (initial core)</i>				
a. <i>Average discharge exposure-1st core</i>	19,000 MWD/short ton U	19,000 MWD/short ton U	19,000 MWD/short ton U	15,777 MWD/short ton U
b. <i>Moderator to fuel volume ratio at total core H₂O/UO₂ cold</i>	2.41	2.41	2.41	2.45

HNP-2-FSAR-1

TABLE 1.3-1 (SHEET 6 OF 11)

	<i>Brunswick Steam Electric Plant-Unit 2 (CP&L)</i>	<i>Cooper Nuclear Station (NPPD)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 1 (SNC)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 2 (SNC)</i>
8. <i>Incore instrumentation</i>				
a. <i>Number of power range (in core) monitoring assemblies (fixed)</i>	31	31	31	31
b. <i>Number of intermediate range monitoring chambers</i>	8	8	8	8
c. <i>Number of startup range monitoring counters</i>	4	4	4	4
d. <i>Number of startup sources</i>	5	5	5	5
e. <i>Number of reactor primary vessel penetrations</i>	43	43	43	43
9. <i>Reactivity control (initial core)</i>				
a. <i>Reactivity of core with all control rods in (cold)</i>	0.95 k_{eff}	0.95 k_{eff}	0.95 k_{eff}	0.95 k_{eff}
b. <i>Reactivity of core with strongest control rod cut (cold)</i>	0.99 k_{eff}	0.99 k_{eff}	0.99 k_{eff}	0.99 k_{eff}
c. <i>Typical moderator temperature coefficient ($\Delta k/k$ °F)</i>				
• <i>Cold</i>	-5.0×10^{-5}	-5.0×10^{-5}	-1.0×10^{-5}	-5.0×10^{-5}
• <i>Hot (no voids)</i>	-39.0×10^{-5}	-39.0×10^{-5}	-39.0×10^{-5}	-39.0×10^{-5}
• <i>Operating</i>				

HNP-2-FSAR-1

TABLE 1.3-1 (SHEET 7 OF 11)

	<i>Brunswick Steam Electric Plant-Unit 2 (CP&L)</i>	<i>Cooper Nuclear Station (NPPD)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 1 (SNC)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 2 (SNC)</i>
9. <i>Reactivity control (cont)</i>				
d. <i>Typical moderator void coefficient ($\Delta k/k\%$ void)</i>				
• <i>Cold</i>				
• <i>Hot (no voids)</i>	-1.0×10^{-3}	-1.0×10^{-3}	-1.0×10^{-3}	-1.0×10^{-3}
• <i>Operating</i>	-1.5×10^{-3}	-1.5×10^{-3}	-1.5×10^{-3}	-1.5×10^{-3}
e. <i>Typical fuel temperature (Doppler) coefficient</i>				
• <i>Cold</i>	-1.3×10^{-5}	-1.3×10^{-5}	-1.3×10^{-5}	-1.3×10^{-5}
• <i>Hot (no voids)</i>	-1.2×10^{-5}	-1.2×10^{-5}	-1.2×10^{-5}	-1.2×10^{-5}
• <i>Operating</i>	-1.3×10^{-5}	-1.3×10^{-5}	-1.3×10^{-5}	-1.3×10^{-5}
F. <i>Containment Systems</i>				
1. <i>Primary containment</i>				
a. <i>Type</i>	<i>Pressure suppression</i>	<i>Pressure suppression</i>	<i>Pressure suppression</i>	<i>Pressure suppression</i>
b. <i>Construction</i>				
• <i>Drywell</i>	<i>Conical and cylindrical steel-lined concrete vessel</i>	<i>Light bulb/steel vessel</i>	<i>Light bulb/steel vessel</i>	<i>Light bulb/steel vessel</i>
• <i>Pressure suppression chamber</i>	<i>Torus/steel-lined concrete vessel</i>	<i>Torus/steel vessel</i>	<i>Torus/steel vessel</i>	<i>Torus/steel vessel</i>
c. <i>Pressure suppression chamber - internal design pressure (psig)</i>	+62	+56	+56	+56
d. <i>Pressure suppression chamber - external design pressure (psig)</i>	+2	+2	+2	+2

HNP-2-FSAR-1

TABLE 1.3-1 (SHEET 8 OF 11)

	<i>Brunswick Steam Electric Plant-Unit 2 (CP&L)</i>	<i>Cooper Nuclear Station (NPPD)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 1 (SNC)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 2 (SNC)</i>
<i>1. Primary containment (cont)</i>				
<i>e. Drywell - internal design pressure (psig)</i>	+62	+56	+56	+56
<i>f. Drywell - external design pressure (psig)</i>	+2	+2	+2	+2
<i>g. Drywell free volume (ft³) (including vent system)</i>	164,100	145,430	146,010	146,266
<i>h. Pressure suppression chamber free volume (ft³)(minimum) @ high water level</i>	124,000	109,810	112,900	109,800
<i>i. Pressure suppression pool water volume (ft³)(minimum)</i>	87,600	87,660	85,112	87,420
<i>j. Submergence of vent pipe below pressure pool surface (ft)</i>	4	4	3 ft 8 in.	4 ft 8 in.
<i>k. Design temperature of drywell (°F)</i>	281	281	281	340
<i>l. Design temperature of pressure suppression chamber (°F)</i>	281	281	281	340
<i>m. Downcomer vent pressure loss factor</i>	6.21	6.21	6.18	4.4
<i>n. Break area/total vent area</i>	0.019	0.019	0.0194	0.0202
<i>o. Drywell free volume/pressure suppression chamber free volume</i>	1.32	1.32	1.293	1.34
<i>p. Primary system volume/pressure suppression pool volume</i>	0.214	0.194	0.191	0.155

HNP-2-FSAR-1

TABLE 1.3-1 (SHEET 9 OF 11)

	<i>Brunswick Steam Electric Plant-Unit 2 (CP&L)</i>	<i>Cooper Nuclear Station (NPPD)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 1 (SNC)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 2 (SNC)</i>
<i>1. Primary containment (cont)</i>				
<i>q. Drywell free volume/primary system volume</i>	8.8	8.58	8.667	8.68
<i>r. Calculated maximum pressure after blowdown with no prepurge</i>				
• <i>Drywell (psig)</i>	46	46	46.5	57.51
• <i>Pressure suppression chamber (psig)</i>	28	28	28	26.61
<i>s. Initial pressure suppression chamber temperature rise (°F)</i>	< 50	50	50	45
<i>t. Leakage rate (percent free volume per day)</i>	0.50	0.50	1.2	1.2
<i>2. Secondary containment</i>				
<i>a. Type</i>	<i>Controlled leakage evaluated release</i>	<i>Controlled leakage evaluated release</i>	<i>Controlled leakage evaluated release</i>	<i>Controlled leakage evaluated release</i>
<i>b. Construction</i>				
<i>Lower levels</i>	<i>Reinforced concrete</i>	<i>Reinforced concrete</i>	<i>Reinforced concrete</i>	<i>Reinforced concrete</i>
<i>Upper levels</i>	<i>Steel superstructure and siding panels</i>	<i>Steel superstructure and siding panels</i>	<i>Steel superstructure and precast concrete</i>	<i>Steel superstructure and precast concrete</i>
<i>Roof</i>	<i>Steel sheeting</i>	<i>Steel sheeting</i>	<i>Steel sheeting and reinforced concrete slabs</i>	<i>Steel sheeting and reinforced concrete slabs</i>
<i>c. Internal design pressure (psig)</i>	0.25	0.25	0.25	0.25
<i>d. Design inleakage rate (percent free volume/day at 0.25 in. H₂O)</i>	100	100	100	100

HNP-2-FSAR-1

TABLE 1.3-1 (SHEET 10 OF 11)

	<i>Brunswick Steam Electric Plant-Unit 2 (CP&L)</i>	<i>Cooper Nuclear Station (NPPD)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 1 (SNC)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 2 (SNC)</i>
3. <i>Elevated release point</i>				
a. <i>Type</i>	<i>Stack</i>	<i>Stack</i>	<i>Stack</i>	<i>Stack</i>
b. <i>Construction</i>	<i>Steel</i>	<i>Steel</i>	<i>Reinforced concrete</i>	<i>Reinforced concrete</i>
c. <i>Height (above ground)</i>	<i>100 m</i>	<i>100 m</i>	<i>120 m</i>	<i>120 m</i>
G. <i>Plant Auxiliary Systems</i>				
1. <i>Emergency core cooling system (number)^(d)</i>				
a. <i>Reactor core spray cooling system</i>	<i>2 loops</i>	<i>2 loops</i>	<i>2 loops</i>	<i>2 loops</i>
b. <i>Reactor core high pressure coolant injection system</i>	<i>1 pump</i>	<i>1 pump</i>	<i>1 pump</i>	<i>1 pump</i>
c. <i>Auto-relief system</i>	<i>1</i>	<i>1</i>	<i>1</i>	<i>1</i>
d. <i>Reactor core residual heat removal system</i>				
<i>Low pressure coolant injection sub-system</i>	<i>4 pumps</i>	<i>4 pumps</i>	<i>4 pumps</i>	<i>4 pumps</i>
<i>Primary containment spray/cooling sub-system</i>	<i>1</i>	<i>1</i>	<i>1</i>	<i>1</i>
<i>Reactor shutdown cooling sub-system</i>	<i>1</i>	<i>1</i>	<i>1</i>	<i>1</i>
2. <i>Reactor auxiliary system (number)</i>				
a. <i>Spent fuel pool cooling and demineralizing system</i>	<i>1</i>	<i>1</i>	<i>2^(f)</i>	<i>1</i>
b. <i>Reactor cleanup demineralization system</i>	<i>1</i>	<i>1</i>	<i>1</i>	<i>1</i>
c. <i>Reactor core isolation cooling system</i>	<i>1</i>	<i>1</i>	<i>1</i>	<i>1</i>

HNP-2-FSAR-1

TABLE 1.3-1 (SHEET 11 OF 11)

	<i>Brunswick Steam Electric Plant-Unit 2 (CP&L)</i>	<i>Cooper Nuclear Station (NPPD)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 1 (SNC)</i>	<i>Edwin I. Hatch Nuclear Plant-Unit 2 (SNC)</i>
<i>H. Plant Electrical Power Systems</i>				
1. <i>Transmission system</i>				
a. <i>Outgoing lines</i>	7-230 kV	4-345 kV	4-230 kV	2-500 kV ^(e)
2. <i>Auxiliary power systems</i>				
a. <i>Incoming lines</i>	7-230 kV	1-69 kV	4-230 kV	2-500 kV ^(e)
b. <i>Onsite sources</i>				
<i>Auxiliary transformers</i>	2	2	2	2
<i>Startup transformers</i>	2	1	2	2
<i>Shutdown transformers</i>	0	1	0	0
3. <i>Standby diesel generator system</i>				
a. <i>Number of diesel generators</i>				
<i>Generators</i>	4	3 or 4	3	2 ^(e)

- a. See HNP-2 subsection 1.4.1.
b. The values shown are nominal and may vary slightly with vessel manufacturers.
c. These items are shown at design limits rather than design point.
d. The design capacities of the systems listed are the same for all four plants listed.
e. One of the HNP-1 units is shared with HNP-2.

1.4 IDENTIFICATION OF AGENTS AND CONTRACTORS

1.4.1 INTRODUCTION

Georgia Power Company (GPC) was the general contractor for the construction of the Edwin I. Hatch Nuclear Plant (HNP) and is the co-owner with Oglethorpe Power Corporation (OPC), the Municipal Electric Authority of Georgia (MEAG), and the city of Dalton, Georgia. GPC was the sole operator of the facility. Effective March 22, 1997, Southern Nuclear Operating Company (SNC) is the exclusive operating licensee. Southern Company Services, Inc. (SCS) was responsible for the design which was subcontracted to Bechtel Power Corporation. The nuclear steam supply system (NSSS) and the turbine-generator are designed and supplied by General Electric (GE).

GPC, a co-owner of the HNP, was responsible for the design, construction, and operation of the plant through March 21, 1997. Since March 22, 1997, as the exclusive operating Licensee, SNC is responsible for the planning, design, licensing, operation, maintenance, repair, modification, addition of, license renewal, and retirement and decommissioning of HNP pursuant to a Nuclear Operating Agreement between SNC and GPC.

1.4.2 APPLICANTS (HNP-1 AND HNP-2)

1.4.2.1 Georgia Power Company

1.4.2.1.1 General

GPC, a wholly owned subsidiary of The Southern Company, is a Co-Applicant. GPC is a public utility incorporated under the laws of the State of Georgia with its principal offices located in Atlanta, Georgia. A description of GPC, including its qualifications and history, is located in the license application.

GPC acted as the general contractor during construction of HNP and is a co-owner.

GPC has a traditional relationship with SCS within The Southern electric system in the design and construction of power generating facilities. This relationship is based on company contracts between the two companies which delegate certain design and engineering responsibilities to SCS. GPC was responsible for construction and operation. Effective March 22, 1997, SNC is the exclusive operating licensee. SNC has inputs to the design and the procurement activities to ensure that the plant concept, capacity, layout, and operating features include desired provisions and arrangements for constructibility and operability. Certain documents, such as arrangement drawings, purchase inquiries, and recommendations, are submitted to SNC for concurrence to verify that these features have been included in accordance with their requirements.

1.4.2.1.2 Technical Qualifications

GPC has participated in the development of nuclear power for more than 20 years, beginning as a member of Atomic Power Development Associates, Inc. (APDA) and Power Reactor Development Company, the designers and operators of the Enrico Fermi Atomic Power Plant-Unit 1. The participation has consisted of both financial contributions and assignment of personnel. Originally, GPC participated in the design, construction, and operation of HNP-1 and HNP-2. Effective March 22, 1997, SNC is the exclusive operating licensee.

Employees of GPC received inservice nuclear training through various courses, such as the Introduction to Nuclear Power course developed by Nuclear Utility Services. GPC employees also participated in the licensing, design, construction, and operation of HNP-1 and HNP-2. Effective March 22, 1997, SNC assumed the technical qualifications of GPC in all aspects.

The technical qualifications of SNC are further delineated in section 13.1, Organizational Structure.

1.4.2.2 Oglethorpe Power Corporation

OPC, incorporated in August 1974, is composed of the rural electric membership corporations within the state of Georgia that purchase wholesale electric energy from GPC. OPC owns a 30% undivided interest of HNP-1 and HNP-2.

1.4.2.3 Municipal Electric Authority of Georgia

MEAG was created by the 1975 Georgia General Assembly to provide electric energy to local municipal government-owned electric distribution systems within the state of Georgia. MEAG owns a 17.7% undivided interest of HNP-1 and HNP-2.

1.4.2.4 City of Dalton, Georgia

Dalton, an incorporated municipality, owns a 2.2% undivided interest of HNP-1 and HNP-2.

1.4.2.5 Georgia Power Company

GPC has the authority to make available to OPC, MEAG, and Dalton their prorated shares of the net capacity and net electric energy output.

1.4.2.6 Southern Nuclear Operating Company

Southern Nuclear Operating Company (SNC), a wholly-owned subsidiary of Southern Company, is the exclusive operating licensee of HNP and is responsible to GPC for the operation of HNP pursuant to a Nuclear Operating Agreement.

1.4.3 ARCHITECT/ENGINEER (HNP-1 AND HNP-2)

1.4.3.1 General

SCS, as the service company to the Southern Company, was responsible to SNC for certain engineering and design requirements of HNP-1 and HNP-2. As a result of the consolidation of SCS and SNC nuclear expertise, and in addition to being the licensee, SNC serves as its own architect/engineer and performs the functions previously performed by SCS.

Bechtel was engaged by SCS to perform the engineering and design of HNP-2 and also assisted SCS in the engineering and design of HNP-1.

1.4.3.2 Technical Qualifications

SCS provided engineering, design, financial, and other management services at cost to the operating companies of the Southern Company. In this capacity, SCS had extensive experience in the design of thermal, hydroelectric, and nuclear generating plants.

SCS participated in the development of nuclear power for more than 20 years, beginning as a member of APDA and Power Reactor Development Company. Personnel from SCS worked full time at APDA's facilities in Detroit, Michigan on the research and engineering for the Enrico Fermi Atomic Power Plant-Unit 1. SCS had a representative on APDA's technical and engineering committee during the entire term of its membership.

SCS was responsible for the design of HNP-1 and HNP-2 and the Alabama Power Company Joseph M. Farley Nuclear Plant, which was designed by SCS and Bechtel.

Bechtel has extensive experience in the design and construction of thermal generating units, including such domestic units as:

- Monticello-Unit 1.
- Pilgrim-Unit 1.
- Peach Bottom-Units 2 and 3.
- Duane Arnold-Unit 1.
- Limerick-Units 1 and 2.
- HNP-Units 1 and 2.

1.4.4 NUCLEAR STEAM SUPPLY SYSTEM SUPPLIER (HNP-1 AND HNP-2)

1.4.4.1 General

GE was responsible for the design, fabrication, and delivery of the direct-cycle boiling water NSSS, the fabrication of the first core and reloads of nuclear fuel, and the provision of technical direction for installation and startup of this equipment.

1.4.4.2 Technical Qualifications

GE has been engaged in the development, design, construction, and operation of boiling water reactors (BWRs) since 1955. Thus, GE has substantial experience, knowledge, and capability to design, manufacture, and furnish technical assistance for the installation and startup of BWRs.

1.4.5 DIVISION OF RESPONSIBILITY

1.4.5.1 Design Stage

GE and Bechtel were delegated the responsibility for design of the NSSS and the balance of the plant, respectively. For preparation of the FSAR, GPC, SCS, Bechtel, and GE were involved in the preparation and review of design bases and philosophies of both systems and structures. The intent of this review was to allow as much expertise as possible to contribute to the plant design.

1.4.5.2 Procurement Stage

1.4.5.2.1 General Electric Scope of Supply

All items within the GE scope of supply were the sole responsibility of GE.

1.4.5.2.2 Bechtel Scope of Supply

For the equipment under the Bechtel scope of supply, procurement procedures were established to require GPC, SCS, and Bechtel participation. Bechtel prepared the inquiries and transmitted them to GPC and SCS for approval, allowing for review to ascertain that sufficient information was contained to inform the bidders of all requirements for the supplied equipment including, but not limited to, material, documentation, and shipping requirements. From this point, Bechtel had the responsibility for sending the inquiry out for bids in accordance with a bidder's list supplied by GPC. After Bechtel reviewed the bids, prepared the requisition, and obtained approval by GPC, the purchase order was prepared by GPC.

1.4.5.2.3 Construction Stage

All construction activities at the site were under the supervision of GPC, with independent testing agencies being contracted, as necessary, to perform special testing and provide expertise in the interpretation of results.

1.4.5.2.4 Operation Stage

GPC initially had the sole responsibility for the operation of HNP-2. Effective March 22, 1997, SNC is the exclusive operating licensee of HNP-2.

1.5 (Deleted)

1.6 REFERENCED TOPICAL REPORTS

Table 1.6-1 lists the topical reports referenced in the original HNP-2 FSAR in support to the initial license application. The reports listed in table 1.6-1 are on file with the Nuclear Regulatory Commission.

Topical reports that are relevant to the current plant design and operation are referenced in the specific HNP-2-FSAR section.

TABLE 1.6-1 (SHEET 1 OF 4)
REFERENCE TOPICAL REPORTS

A. General Electric Company Reports

<u>Report No.</u>	<u>Title</u>
APED 4827	<i>Maximum Two-Phase Vessel Blowdown from Pipes (April 1965)</i>
APED 5450	<i>Design Provisions for In-Service Inspection (April 1967)</i>
APED 5458	<i>Effectiveness of Core Standby Cooling Systems for General Electric Boiling</i>
APED 5460	<i>Design and Performance of General Electric Boiling Water Reactor Jet Pumps (September 1968)</i>
APED 5499	<i>Control Rod Worth Minimizer (March 1967, revision in progress)</i>
APED 5555	<i>Impact Testing on Collet Assembly for Control Rod Drive Mechanism 7RDB144A (November 1967)</i>
APED 5640	<i>Xenon Considerations in Design of Large Boiling Water Reactors (June 1968)</i>
APED 5706	<i>In-Core Neutron Monitoring System for General Electric Boiling Water Reactor (November 1968; revised April 1969)</i>
APED 5736	<i>Guidelines for Determining Safe Test Intervals and Repair Times for Engineered Safeguards (April 1969)</i>
APED 5750	<i>Design and Performance of General Electric Boiling Water Reactor Main Steam Line Isolation Valves (March 1969)</i>
APED 5756	<i>Analytical Methods for Evaluating the Radiological Aspects of the General Electric Boiling Water Reactor (March 1969)</i>
GEAP 4059	<i>Vibration in Fuel Rods in Parallel Flow (July 1962)</i>
GEAP 4616	<i>Two-Phase Pressure Drop in Straight Pipes and Channels: Water-Steam Mixtures at 600 to 1400 psia (May 1964)</i>
GEAP 4966	<i>Vibration of SEFOR Fuel Rods in Parallel Flow (September 1965)</i>
GEAP 5620	<i>Failure Behavior in ASTM A106B Pipes Containing Axial Through-Wall Flaws (April 1968)</i>
NEDE 21156	<i>Supplemental Information for Plant Modification to Eliminate Significant In-Core Vibration, Class III (January 1976)</i>

TABLE 1.6-1 (SHEET 2 OF 4)

<u>Report No.</u>	<u>Title</u>
NEDO 11146	<i>Design Basis for New Gas Systems (July 1971) (Proprietary)</i>
NEDM 10735	<i>Fuel Densification Effects on General Electric Boiling Water Reactor Fuel, Supplements 6, 7, and 8 (August 1973)</i>
NEDO 10029	<i>An Analytical Study on Brittle Fracture of GE-BWR Vessel Subject to the Design Basis Accident (May 1969)</i>
NEDO 10139	<i>Compliance of Protection Systems to Industry Criteria: General Electric BWR Nuclear Steam Supply System (June 1970)</i>
NEDO 10173	<i>Current State of Knowledge, High Performance BWR Zircaloy-Clad UO₂ Fuel (May 1970)</i>
NEDO 10174	<i>Consequences of a Postulated Flow Blockage Incident in a BWR (May 1970)</i>
NEDO 10299	<i>Core Flow Distribution in a Modern Boiling Water Reactor as Measured in Monticello (January 1971)</i>
NEDO 10320	<i>The General Electric Pressure Suppression Containment Analytical Model (April 1971)</i>
NEDO 10329	<i>Loss-of-Coolant Accident and Emergency Core Cooling Models for General Electric Boiling Water Reactor (April 1971), Supplement 1 (April 1971), Addenda (May 1971)</i>
NEDO 10505	<i>Experience with BWR Fuel Through September 1971 (May 1972)</i>
NEDO 10527	<i>Rod Drop Accident Analysis for Large Boiling Water Reactors (March 1972), Supplement 1 (July 1972), Supplement 2 (January 1973)</i>
NEDO 10541	<i>Visual and Photographic Examination of Dresden-1 High Exposure Control Rod B87 (April 1972)</i>
NEDO 10585	<i>Behavior of Iodine in Reactor Water During Plant Shutdown and Startup (August 1972)</i>
NEDO 10602	<i>Testing of Improved Jet Pumps for the BWR/6 Nuclear System (June 1972)</i>
NEDO 10734	<i>A General Justification for Classification of Effluent Treatment System Equipment As Group D (February 1973)</i>
NEDM 10735	<i>Densification Considerations in BWR Fuel Design and Performance (December 1972)</i>

TABLE 1.6-1 (SHEET 3 OF 4)

<u>Report No.</u>	<u>Title</u>
NEDO 10751	<i>Experimental and Operational Confirmation of Off-Gas System Design Parameters (January 1973) (Proprietary)</i>
NEDO 10802	<i>Analytical Methods of Plant Transient Evaluations for the General Electric Boiling Water Reactor (April 1973)</i>
NEDO 10871	<i>Technical Derivation of BWR 1971 Design Basis Radioactive Material Source Terms (March 1973)</i>
NEDO 10899	<i>Chlorine Control in BWR Coolants (June 1973)</i>
NEDO 10958 and NEDE 10958	<i>General Electric BWR Thermal Analysis Basis (GETAB) Data, Correlation and Design Application (November 1973)</i>
NEDO 12037	<i>Summary of Gamma and Beta Energy and Intensity Data (1970)</i>
GEAP 13112	<i>Thermal Response and Cladding Performance of an Internally Pressurized, Zircaloy-Clad, Simulated BWR Fuel Bundle Cooled by Spray Under Loss of Coolant Conditions (April 1971)</i>
NEDO 20340	<i>Process Computer Performance, Evaluation Accuracy (December 1974)</i>
NEDO 20360	<i>General Electric Boiling Water Reactor Generic Reload Application for 8x8 Fuel, Rev. 1, Supplement 3 (May 1975)</i>
NEDO 20360-1P	<i>General Electric Boiling Water Reactor Generic Reload Application for 8x8 Fuel, Rev. 4 (March 25, 1976)</i>
NEDO 20377	<i>8x8 Fuel Bundle Development Support (February 1975)</i>
NEDE 20386	<i>Fuel Channel Deflections (May 1974)</i>
NEDO 20566 (Draft)	<i>General Electric Company Analytical Model for-Loss-of-Coolant Analysis in Accordance with 10CFR50, Appendix K</i>
NEDO 20922	<i>Experience with BWR Fuel Through September 1974 (June 1975)</i>
NEDO 20939	<i>Lattice Physics Methods Verification (June 1976)</i>
NEDO 20944	<i>BWR/4 and BWR/5 Fuel Design, Rev. 1, 76NED35 (October 1976)</i>
NEDO 20945	<i>3D BWR Simulator (August 1976)</i>
NEDO 20946	<i>BWR Simulator Methods Verification (August 1976)</i>

TABLE 1.6-1 (SHEET 4 OF 4)

<u>Report No.</u>	<u>Title</u>
NEDO 20948-P	<i>BWR/6 Fuel Design (June 1976)</i>
NEDO 20964	<i>Generation of Void and Doppler Reactivity Feedback for Application to BWR Plant Transient Analysis (August 1975)</i>
NEDC 20989-P	<i>Mark I Containment Evaluation Short Term Program Final Report, Addendum 2, "Loads and Their Application for Torus Support System Evaluation," June 1976</i>
NEDO 21291	<i>Group Notch Mode of the Rod Sequence Control System for Cooper Nuclear Station (June 1976)</i>

B. Bechtel Power Corporation Reports

<u>Report No.</u>	<u>Title</u>
BC-TOP-9A	<i>Design of Structures for Missile Impact Rev. 2 (September 1974)</i>
BN-TOP-1	<i>Testing Criteria for Integrated Leak Rate Testing of Primary Containment Structures for Nuclear Power Plants, Rev. 1 (November 1972)</i>
BN-TOP-2	<i>Design for Pipe Rupture Effects, Rev. 2 (May 1974)</i>
BP-TOP-1	<i>Seismic Analysis Piping System, Rev. 1 (February 1974)</i>

2.0 SITE CHARACTERISTICS

2.1 GEOGRAPHY AND DEMOGRAPHY (HNP-1 AND HNP-2)

2.1.1 SITE LOCATION AND DESCRIPTION

2.1.1.1 Specification of Location

The Hatch Nuclear Plant (HNP) site is located in Appling and Toombs Counties, Georgia, at the intersection of the Altamaha River with U.S. Hwy No. 1, as shown in figures 2.1-1 and 2.1-2. This location is ~ 98 miles southeast of Macon, Georgia, and ~ 73 miles northwest of Brunswick, Georgia. The Universal Transverse Mercator coordinates of the HNP-2 reactor, to the nearest 100 m, are Zone 17R LF 3,533,700 m N and 372,900 m E. These coordinates correspond to 82°20'39" W long. and 31°56'2" N lat. The HNP-1 reactor is located 149 ft 3 in. due north of the HNP-2 reactor.

2.1.1.2 Site Area Map

Figure 2.1-3 is a map of the HNP site area which includes 2244 acres. The site boundary and exclusion area boundary for practical purposes, coincide with the plant property line. The minimum distance from the HNP-2 reactor to the exclusion area boundary is ~ 4300 ft to the southwest. The exclusion area boundary, as determined per Title 10 Code of Federal Regulations (CFR) Part 100, for HNP is that area falling within 1250 m from the center of the plant site.

2.1.1.3 Boundaries for Establishing Effluent Release Limits

The property lines shown in figure 2.1-3 are the boundaries for determining effluent release limits. Effluent releases at the boundary do not exceed the limits specified in the Offsite Dose Calculation Manual.

As indicated in figure 2.1-3, the minimum distances to the boundary from the main plant stack and the HNP-2 reactor building vent are 4100 ft and 4300 ft, respectively. The Altamaha River traverses the site north of the HNP-1 and the HNP-2 complexes. The distance from the HNP-1 reactor building to the nearest river bank is ~ 850 ft.

Use of the wildlife refuge area and the Boy Scout camp area is allowed only with prior permission from and notification of Southern Nuclear Operating Company (SNC). Under normal circumstances, use of the highway, County Road 451, wayside park, river, recreation center, and visitor center is not controlled. (See paragraph 2.1.2.2.) In the event of emergency conditions at the plant, the Emergency Plan provides for control of these areas. Control over access to the owner-controlled area and the protected area is maintained through implementation of the Security Plan described in section 13.7 and the Emergency Plan

described in section 13.3. Such access is monitored and controlled by the plant security force, the plant staff, and the implementation of administrative procedures.

2.1.2 EXCLUSION AREA AUTHORITY AND CONTROL

2.1.2.1 Authority

Georgia Power Company (GPC) owns the entire plant exclusion area in fee simple. Pursuant to the Nuclear Operating Agreement, GPC, for itself and as agent for the co-owners, has delegated to SNC complete authority to regulate any and all access and activity within the entire plant exclusion area. Minimum distance to the exclusion area boundary is discussed in paragraph 2.1.1.2.

2.1.2.2 Control of Activities Unrelated to Plant Operation

The following areas located within the exclusion area are those in which activities unrelated to the plant operation occur:

- U.S. Hwy No. 1.
- County Road 451.
- Wayside park adjacent to U.S. Hwy No. 1.
- Altamaha River.
- Wildlife refuge area.
- Boy Scout camp area.
- Visitor center.
- Recreation center.

The locations of these areas within the exclusion area are shown in figure 2.1-3. The exclusion area outside the controlled area fence is posted and, except for the highway, County Road 451, wayside park, river, and visitor center, is closed to persons not having received permission to enter the property.

Although the Emergency Plan provides for execution of passage control if emergency plant conditions occur, GPC does not normally control passage along the portion of U.S. Hwy No.1 and County Road 451 that lies within the exclusion area. The wayside park provides simple recreational facilities for public use, in addition to parking and picnicking facilities to simultaneously accommodate ~ 10 families. Limitations are not normally imposed upon park

HNP-2-FSAR-2

use, although the Emergency Plan does provide for limitations in the event of plant emergency conditions. If emergency conditions occur, the plant security force, in conjunction with local law enforcement agencies, notify any persons within the park of the proper action to take.

GPC does not generally control passage or use of the Altamaha River within the exclusion area. The Emergency Plan provides for control over use of the river if emergency conditions occur. In the event of emergency conditions, the plant security force, in conjunction with local law enforcement agencies, notify any persons on the river of the proper action to take.

An estimate of river usage believed to be representative of peak daily usage on a given summer day was determined for Deen's Landing.^(a) Usage of that portion of the river located within the exclusion area should not differ substantially from river usage at Deen's Landing.

Persons attempting to enter the wildlife refuge area without permission are considered to be trespassing; however, this area is not in use at the present time, although efforts were made to interest ecological groups in the area for the purpose of conducting ecological studies. If such use commences in the future, groups are anticipated to be small and to remain in the refuge area for short periods of time only.

A lease agreement between GPC and the Area Council of the Boy Scouts of America allows scouting groups to use the Boy Scout camp area. The lease agreement requires that all instructions given by GPC and, specifically, plans for evacuation are promptly adhered to and obeyed. The leader of each group using the area is given a set of emergency instructions to follow in the event of plant emergency conditions. Such notification would be made by the plant security force, in conjunction with local law enforcement agencies. In the past, the area has been used on weekends by Scouts, with the number of Scouts simultaneously using the area varying between 25 and 50. These visits, which are for weekends only, are expected to continue. In the future, the Area Council of Boy Scouts may possibly hold camporees involving 400 to 500 Scouts at the Boy Scout camp area on weekends only.

The recreation center is accessed from County Road 451, which originates at U.S. Hwy No. 1. Persons using the recreation center may occupy the center, its immediate area, and the parking lot immediately adjacent to the center. In the event of emergency conditions, the Emergency Plan specifies control of access to the recreation center, and the plant security force is responsible for notifying persons in the recreation center of the proper action to take.

The visitor center is accessed from the main plant access road that originates at U.S. Hwy No. 1. Persons visiting the center may occupy the center, its immediate area, and the parking lot immediately adjacent to the center. If a plant emergency condition occurs, the procedure for proper notification of visitors, in addition to the procedures to be executed by the visitor center director or designated alternate, is provided in the Emergency Plan. For the period of

a. Of 373 recreational manhours spent at Deen's Landing, 144 were boating hours.

August 1971 to January 1975, the center accommodated ~ 56,000 visitors, with the peak number of daily visitors being 860. The peak number of visitors does not exceed 1000 daily and 52,000 annually.

2.1.2.3 Arrangements for Traffic Control

SNC has arranged with the law enforcement agencies of Appling and Toombs Counties and with the Georgia Highway Patrol for control of traffic on U.S. Hwy No. 1 and County Road 451 in the event of an emergency. Because of the remote site location, plant personnel control the traffic in an emergency until officers of the aforementioned agencies arrive.

2.1.3 POPULATION DISTRIBUTION

At the time of submittal of the FSAR to support the license application, the information on population projections was based on the 1970 Census data. For the most current information regarding the population, schools, and recreational and public areas, as well as population density within the 16 meteorological zones, consult the Emergency Plan and the Annual Radiological Environmental Operating Report. For the most current information regarding operational dose estimates, consult the Annual Radiological Environmental Operating Report and the Annual Effluent Release Report.

2.1.3.1 Population Within 10 Miles

Figure 2.1-4 shows projected populations from the center of the plant site outward to a 10-mile radius.

The population projections for the area within a 50-mile radius of the proposed plant site were based on the 1970 Census data and the county population projections developed by the Georgia Social Sciences Advisory Committee.⁽¹⁾

The total populations and the rural populations of the counties in question were obtained from the 1970 Census Report, and the rural population percentage was calculated. In the linear approximation developed, it is assumed that this percentage remained unchanged over the time interval of the study. The rural populations for the years 1980, 1990, 2000, and 2020 were determined by multiplying the rural population percentage of each county by the projected county population indicated in the aforementioned publications. Using the same formula, the rural population densities were calculated for each of these years. The rural densities for 1972, 1982, 1992, and 2012 were then determined by linear interpolation. Rural populations for each sector for these same years were determined by multiplying the rural densities for the counties involved by the appropriate area of each county falling within 1 of the 16 sectors. Total sector populations were found by adding the rural population to the projected city populations within a sector. Projected city populations were found by linearly projecting each city's 1970 population at its county's projected rate of growth. It was assumed that the growth rate for a given county would be a reasonable approximation of the growth rates of the cities within that county. Cities

were selected from the 1970 Census listing of all incorporated places and unincorporated places of 1000 or more.

After comparing the results of this method of projection for the HNP vicinity (50-mile radius) with the results of the ratio method of projection (the population ratio between the HNP vicinity and the whole U.S. population is multiplied by the projected U.S. population figures calculated by the U.S. Census Bureau), it was found that the method described in the above paragraph rendered a higher, more conservative projection.

2.1.3.2 Population Between 10 and 50 Miles

Figure 2.1-5 shows the projected population distribution between 10 and 50 miles from the plant site.

2.1.3.3 Transient Population

Within a 5-mile radius of the plant, the greatest population shifts on a daily basis should come from HNP and the Altamaha School, located ~ 4 miles SSE of the plant. The permanent HNP operating staff totals ~ 970 people, divided among 3 daily shifts. According to the Statistical Services Division of the Georgia Department of Education, the average daily attendance for the Altamaha School during the 1973-1974 school year was 313 students and 17 teachers. Because of hunting and fishing activities, some seasonal population fluctuations in this area occur; but these variations are likely to be insignificant.

2.1.3.4 Low-Population Zone

The low-population zone (LPZ), as determined per 10 CFR 100, for HNP is that area falling within 1250 meters from the center of the plant site. Figure 2.1-4 shows that this area is expected to remain sparsely populated during the anticipated life of the plant. For practical purposes, the Technical Specifications state that the LPZ coincides with the site and exclusion area boundaries.

In June 1973, GPC conducted a population survey over a 5-mile radius, the center originating at the main stack. The survey results showed a population of 1465 permanent residents within the 5-mile radius as compared to a population of ~ 840 permanent residents in 1970. The bulk of this population increase is believed to stem from the influx of construction workers, many residing in trailer parks near the site. Figure 2.1-6 shows the population breakdown per mile radius and directional sector. Also shown are the locations of the major trailer parks.

2.1.3.5 Population Center


The nearest population center, as defined in 10 CFR 100, is Savannah, Georgia, located ~ 67 miles ENE of HNP. In 1970, Savannah's population was 118,349; however, Savannah is located beyond the 50-mile radius of the HNP population study. In the period from 1960 to

HNP-2-FSAR-2

1970, Appling County experienced a population decrease of ~ 4%, while Toombs County increased in population by almost 14%. Appling County's urban population decreased by 18% during this same period, but the rural population grew nearly 3%. At the same time, the Toombs County rural population declined slightly over 2%, but its urban population climbed by almost 23%. Recent experience seems to indicate that, in coming years, urban populations will increase at the expense of rural areas.

REFERENCES

1. Lyle, C. V., Chief Economist, Southeastern Region, Federal Water Pollution Control Administration, U. S. Department of the Interior, Georgia County Population Projections as Developed by the Georgia Social Sciences Advisory Committee, Georgia Social Sciences Advisory Committee, Atlanta, Georgia, February 1968.



REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 1 AND UNIT 2

EDWIN I. HATCH NUCLEAR PLANT SITE

FIGURE 2.1-1




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

LOCAL SITE ENVIRONS

FIGURE 2.1-2




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

SITE PROPERTY PLAN

FIGURE 2.1-3



NOTE:

At the time of submittal of the FSAR to support the license application, the information on population projections was based on the 1970 Census data. For the most current information regarding the population, schools, and recreational and public areas, as well as population density within the 16 meteorological zones, consult the Emergency Plan and the Annual Radiological Environmental Operating Report.

ACAD 2020104


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 2

POPULATION DISTRIBUTION
(0-10 MILES)

FIGURE 2.1-4



NOTE:
 At the time of submittal of the FSAR to support the license application, the information on population projections was based on the 1970 Census data. For the most current information regarding the population, schools, and recreational and public areas, as well as population density within the 16 meteorological zones, consult the Emergency Plan and the Annual Radiological Environmental Operating Report.

ACAD 2020105


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 2

POPULATION DISTRIBUTION
 (10-50 MILES)

FIGURE 2.1-5



REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 1 AND UNIT 2

POPULATION DISTRIBUTION
 (0-5 MILES)

FIGURE 2.1-6

2.2 NEARBY INDUSTRIAL, TRANSPORTATION, AND MILITARY FACILITIES

2.2.1 LOCATIONS AND ROUTES

Figure 2.2-1 is a map of the site area showing the location of transportation routes and a pipeline.

2.2.2 DESCRIPTIONS

2.2.2.1 Description of Facilities

Within a 5-mile radius of Hatch Nuclear Plant-Unit 2 (HNP-2), there are no manufacturing plants, chemical plants, refineries, storage facilities, mining and quarrying operations, military bases, missile sites, transportation facilities, oil and gas wells, or underground gas storage facilities. Also, there are no known military firing or bombing ranges or aircraft low-level flight holding or landing patterns near the site area. There is truck traffic on U.S. Highway No. 1, which passes about 3500 ft west of the plant buildings. The nearest railroad passes about 10 miles southwest of the site. A spur line has been constructed to the site.

2.2.2.2 Description of Products and Materials

The cargo most frequently transported near the plant is longleaf and slash pine logs harvested from managed forest areas for pulpwood. There are no records available from either state or federal sources concerning the nature and quantities of potentially hazardous and/or explosive material that might be transported along U.S. Highway No. 1 in the vicinity of the plant site. Also, there are no apparent factors that should cause shipments along this route to differ significantly from shipments along any other federal highway. Since U.S. Highway No. 1 is a federal highway, it would be reasonable to assume that shipments of hazardous and/or explosive materials along it would conform to applicable federal and state regulations.

2.2.2.3 Pipelines

A Southern Natural Gas Company pipeline is located within ~ 4 1/2 miles of HNP-2 as shown on figure 2.2-1. The pipeline, which was designed for 1200-psi operation, carries natural gas at an operating pressure of 820 psi. The 12 3/4-in.-OD pipe ranges in wall thickness from 0.219 in. to 0.500 in. and in minimum yield strength from 35,000 psi to 52,000 psi. The pipeline was constructed in 1964 and is buried at a minimum depth of 30 in. Figure 2.2-1 shows the location with respect to HNP-2 of ASA 600 No. M and J M3 12-in. gate valves that can be used as isolation valves in the pipeline. The pipeline is not used for storage of gas at higher than normal pressure. The Southern Natural Gas Company does not anticipate using the pipeline to carry a product other than natural gas.

2.2.2.4 Waterways

There is no commercial traffic on the Altamaha River in the site region. Deen's Landing, a commercial launching facility for small boats, is located slightly over a mile upstream from the plant (figure 2.2-1).

The only barge traffic on the Altamaha River in the vicinity of the HNP site is the snagging barge operated by the Corps of Engineers. It is estimated that this barge passes the site perhaps twice a year (once going upstream and once going downstream); however, it probably passes on a less frequent schedule. Since the intake structure is located on a straight portion of the river the barge would not be involved in any maneuvers that require it to move toward the intake structure.

2.2.2.5 Airports

The nearest airport with scheduled passenger service is in Savannah, Georgia, about 67 miles northeast of HNP-2. There are small municipal fields not used for scheduled commercial service at Baxley, about 13 miles south; Hazlehurst, about 16 miles southwest; Vidalia, about 20 miles north; and Alma, about 28 miles south.

2.2.2.6 Projections of Industrial Growth

The area within 5 miles of HNP-2 is largely rural, with most of the land being used for either residential or agricultural purposes. Much of the north-south vehicular traffic that traveled U.S. Highway No. 1 in years past now moves along federal interstate highways. Other than the development of several trailer parks to accommodate the influx of construction workers associated with HNP, this area has remained relatively stable over the last several years and shows no tendencies toward any drastic changes in the foreseeable future.

2.2.3 EVALUATION OF POTENTIAL ACCIDENTS

2.2.3.1 Determination of Design Basis Events

The accident categories discussed below consider the potential for accidents at other facilities or transportation routes affecting HNP-2.

A. Explosions

There are no known facilities or activities within a 5-mile radius of HNP where the process, storage, or use of high explosives, munitions, chemicals, or liquid and gaseous fuels creates the potential for accidental detonations posing a threat to HNP-2.

HNP-2-FSAR-2

Transportation routes within the 5-mile radius include the Altamaha River, a Southern Natural Gas Company pipeline, and the road system, principally U.S. Highway No. 1. Traffic on the Altamaha River in the vicinity of HNP is not of a nature that creates the potential for accidental detonations posing a threat to HNP-2. The Southern Natural Gas Company pipeline is ~ 4 1/2 miles from HNP-2 and is sufficiently distant that potential detonations would not affect HNP-2. U.S. Highway No. 1 passes ~ 3400 ft west of the HNP-2 plant structures. Accidents involving detonation of materials or cargoes in transit on the highway would be sufficiently distant that HNP-2 would not be affected.

B. Flammable Vapor Clouds (Delayed Ignition)

Accidental releases of flammable liquids or vapors that result in the formation of unconfined vapor clouds from locations outside the 5-mile radius of HNP should be sufficiently dispersed, even under the most adverse meteorological conditions, so that the concentration, by the time the cloud reaches HNP-2, is below the flammable point. The natural gas pipeline, likewise, is sufficiently distant that the resulting cloud should be dispersed below the flammable concentration. The distance of U.S. Highway No. 1 from HNP-2 and the comparative size of shipments that travel along the highway result in an exceedingly low probability of a cloud having a flammable concentration reaching HNP-2.

C. Toxic Chemicals

Transportation of toxic chemicals along U.S. Highway No. 1 is sufficiently distant from HNP-2 that the probability of a toxic concentration resulting from a potential release reaching HNP-2 is exceedingly low.

There are no known storage or transportation facilities within a 5-mile radius of HNP-2 that pose a threat to HNP-2.

The following chemicals are stored on site in bulk quantities: acid and caustic (used for makeup water demineralization) and sodium hypochlorite (used for treatment of circulating water, sanitary water, and plant service water). The capability to store sodium bromide, a corrosion inhibitor, and a silt dispersant (for treatment of service water systems) is also provided. In normal operation, fumes from these chemicals are not toxic. However, if mixed together, sodium hypochlorite and acid could generate and release molecular chlorine gas. Precautions are, therefore, taken to make certain that only the required chemical can be put into the respective storage tank. Administrative controls have been established to ensure that chemical delivery trucks are escorted on site and are sampled prior to unloading to ensure the correct chemical is being supplied to the tank. Tank fill connection valves are kept locked closed, and the chemistry department personnel (who perform the sampling) control the keys. In addition, in the same way that caustic connections are designed, the fill connections on the water treatment chemical storage tanks are a type that is incompatible with the acid truck discharge hose connection.

HNP-2-FSAR-2

D. Fires

There are no nearby industrial, chemical, or storage facilities from which effects of fires pose a threat to HNP-2. The Southern Natural Gas pipeline is sufficiently distant that a fire associated with the pipeline should not affect HNP-2. Likewise, fires associated with transportation accidents are sufficiently distant as not to affect HNP-2. The terrain and ground cover surrounding HNP-2 are of nature that is not conducive to forest or brush fires that might otherwise affect HNP-2.

If, however, a fire in the site area causes smoke to drift to the main control room air intake, control room personnel can manually isolate the control room and initiate the recirculation mode (subsections 6.4.1 and 15.4.4). No mechanical or electrical smoke detection apparatus is provided at the intake to warn the control room operators of smoke being drawn into the intake. It is expected that an operator on duty will detect the condition long before the room becomes uninhabitable. Further it is unlikely that control room personnel would not be aware of the existence and location of a fire of sufficient magnitude to engulf the plant with smoke. Smoke particles that enter the room prior to manual isolation will probably settle as dust. If the concentration in the main control room becomes heavy, portable breathing apparatus already available within the room may be deployed during the interval preceding and immediately following manual isolation, while the smoke particles settle out or are captured by the recirculation filter system. When conditions permit, and if desired, the purge mode to remove lingering odor within the main control room can be initiated manually.

E. Collisions With Intake Structure

There is no commercial barge traffic on the Altamaha River in the vicinity of HNP-2 at present and no future traffic is anticipated.

Barge traffic on the river is required to have a permit from the U.S. Army Corps of Engineers; a permit is not required of rafting or other movement of logs under Title 33 USC Sections 554 and 555. At present, there are no permits or applications for permits from the Corps of Engineers for any barge traffic on the river. The major companies with forestry operations in the vicinity of the river upstream of the plant site do not use barge logs. Only one of these companies has used barges to move logs down the river in the past. This particular company discontinued the use of barges prior to 1972 and has since disposed of all barges, tugboats, and other equipment that was used in its barging operations. The company has no plans to use barges on the river in the future.

The Savannah District Corps of Engineers removes snags and fallen trees from the river during a period of 4 to 6 months each year. The material removed by the Corps is placed on the river bank. For this operation, the Corps uses a barge 110 ft by 30 ft with a 7-ft draft which displaces 126 long tons and a towboat 61 ft by 21 ft with a 6-ft draft which displaces 80 long tons. Maximum speed of the barge and towboat is 5 mph. The towboat and barge pass the plant site at most once moving upstream and once downstream per year and possibly as seldom as once

HNP-2-FSAR-2

every 2 or 3 years. However, as the towboat and barge pass the plant site they engage in snagging operations and move, at most, at less than maximum speed. Based on accident statistics for the years 1968 through 1973 collected by the U.S. Coast Guard,⁽¹⁾ the national average accident frequency involving all barges where damage was in excess of \$1500 was found to be 0.42 accidents per million miles.⁽²⁾ The frequency of all types of barge accidents is therefore 0.42×10^{-6} per mile. Runaway barge accidents form a small subset of all accidents since most barge accidents are caused by impact with bridges, weirs, spillways, piers, other barges, etc., but not due to runaways. A very conservative estimate of the number of runaways per total number of accidents is estimated at 0.1.⁽³⁾ In this report, runaway barges are classified as being due to material failure (e.g., broken towline) and are found to represent 4% of all barge accidents; a conservative estimate of 10% is used. Assuming that the barge can run away in any direction with equal probability results in a probability of 0.5 that it will strike the side of the river on which the intake structure is stationed. The probability that a barge would run away and strike the side of the river on which the intake structure is located, within a mile of shoreline which contains the intake structure, then becomes:

$$(0.42 \times 10^{-6}) \times (0.1) \times (0.5) = 0.21 \times 10^{-7}$$

Assuming that the barge runs away and hits the side of the river that has the intake structure, the probability of striking the intake structure is ~ equal to the ratio of the intake structure width to the width of the shoreline that the barge is assumed to strike (in this case 1 mile) which is equivalent to the intake structure width in miles (including the width of the sheet piles) or 0.03 miles. Therefore the probability that a barge passing the intake structure would run away and strike the intake structure becomes:

$$(0.21 \times 10^{-7}) \times (0.03) = 0.63 \times 10^{-9}$$

It is concluded therefore that, even if there were as many as 100 barges per year (in reality there are less than two) passing the HNP site, the probability of a barge running away and striking the intake structure is very remote (i.e., $< 10^{-7}$ occurrences per year).

The intake structure is protected, however, by sheet pile cells from a direct hit by river traffic or debris moving in the direction of the river flow. The cells are comprised of soil-filled sheet piling and are 63 ft in diameter, extend from elevation 22 ft to elevation 105 ft and weigh ~ 14,500 tons.

F. Liquid Spills

There is no commercial barge traffic on the Altamaha River in the vicinity of HNP-2 at present. The nearest industrial plant upstream of HNP-2 is located near Macon, Georgia. If any appreciable amount of corrosive, cryogenic, or coagulant oil or liquid is released into the river from an upstream location, the material should be diluted substantially before reaching the intake structure.

HNP-2-FSAR-2

Heat transfer areas of the heat exchanges might be affected initially. However, conservative sizing of heat transfer surfaces and continuous flushing of service water flow negates the effect of such materials on the heat exchangers.


2.2.3.2 Effects of Design Basis Events

Potential accidents considered above should have a negligible effect on HNP-2.

HNP-2-FSAR-2

REFERENCES

1. U.S. Coast Guard Headquarters, Computer File on All Accidents Involving Damage in Excess of \$1500, Washington, D.C., 1974.
2. U.S. Department of Commerce, "A Model Economic and Safety Analysis of the Transportation of Hazardous Materials in Bulk," Report to Office of Domestic Shipping by Arthur D. Little, Inc., Cambridge, Massachusetts, July 1974.
3. U.S. Coast Guard, "Statistical Summary of Casualties to Commercial Vessels on Western Rivers," November 1973.



ACAD 2020201

REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

INDUSTRIAL AND MILITARY FACILITIES,
TRANSPORTATION AND PIPELINE ROUTINGS
IN SITE ENVIRONS

FIGURE 2.2-1

2.3 METEOROLOGY (HNP-1 AND HNP-2)

2.3.1 REGIONAL CLIMATOLOGY

2.3.1.1 Data Sources

Climatic references used to evaluate the site meteorology are listed at the end of this section. (See references 1 through 8.)

2.3.1.2 General

The site is located in the middle coastal plain region of Georgia, which is characterized by mild, short winters; long periods of mild, sunny weather in the autumn; and somewhat more windy but mild weather in the spring. Summers are warm and humid, being affected by maritime air from the Atlantic; but long periods of extremely hot weather over 100°F are unusual.

The climate of the site area is characterized by the mean and extreme temperatures and precipitation of Glennville and Lumber City, Georgia. Glennville is located about 24 miles east of the site and Lumber City about 20 miles west of the site. Since there is close agreement in the data from these two stations and the Glennville Station has a longer period of record, only the Glennville data are shown on figures 2.3-1 and 2.3-2.

Also used in the climatic study were the first-order stations of Savannah, Georgia, 75 miles east of the site, and Macon, Georgia, 98 miles northwest of the site. Data from these cities are shown in tables 2.3-1 and 2.3-2.⁽¹⁾ These stations are the closest first-order stations and were used to provide more complete data not available at the other two stations for the site region.

During the 46-year period 1920 to 1965, for which 39 years of record are available, there have been 10 tornadoes within a 25-mile radius of the site. During the period 1956 through 1965 inclusive, there were seven tornadoes reported within this radius. The higher frequency in the latter period is probably due to improved reporting.⁽⁹⁾⁽¹⁰⁾

During the 49 years of record 1915 to 1965,⁽¹¹⁾⁽¹²⁾⁽¹³⁾ there were 29 hurricane or post-hurricane paths which passed within 100 miles of the site. Since the plant is ~ 80 miles from the coast, the hurricane windspeeds are generally lower than those further to the east or south. It is expected that the analogous windspeed at the site would have been less. High winds are discussed in paragraph 2.3.1.3.

Snow and ice storms are very rare in the region. The average annual snowfall for the region is < 1/2 in. The maximum snowfall in a 30-year period of record at Glennville was 4 in. in 1973.⁽¹⁴⁾

The area is subject to a relatively high incidence of slow-moving anticyclones associated with high air pollution potential (paragraph 2.3.1.3).

2.3.1.3 Severe Weather

A. Heavy Precipitation

The heaviest precipitation of several hours' duration usually occurs with tropical storms in the late summer and fall and with coastal storms in the winter. Heavy rains of short duration occur in thunderstorms, which average about 2 out of every 5 days from June through August.

Rainfall frequencies from 30 min to 24 h for return periods of from 1 to 100 years are shown in the following table. The figures were interpolated from maps in reference 2.

Amount of Rainfall (in.) in a Given Period

Recurrence Interval	30 min	1 h	6 h	24 h
1 year	1.4	1.8	2.5	3.4
5 years	2.0	2.5	3.8	5.4
10 years	2.2	2.8	4.5	6.2
25 years	2.5	3.2	5.2	7.0
50 years	2.8	3.5	5.8	7.8
100 years	3.0	3.8	6.5	8.8

Maximum recorded rainfall has been tabulated below for Macon and Savannah, which are the nearest first-order stations most representative of the site for periods ranging from 5 min to 24 h.⁽³⁾ The amount is an average of the Macon and Savannah amounts for the time period.

1906-1961		1899-1961	
(min)	(in.)	(h)	(in.)
5	0.77	2	5.75
10	1.23	3	6.00
15	1.65	6	6.60
30	2.55	12	8.50
60	3.95	24	10.00

The values of rainfall return amounts in the first table, paragraph 2.3.1.3A, were interpolated directly from reference 2 for the Hatch site area. The amounts in reference 2 for 1- to 10-year periods were derived using a partial-duration series, which takes the highest rainfall values for a station, regardless of year, to find frequency of occurrence. These types of data stations were used in the study: the first-order Weather Bureau stations, the recording gage hydrologic network, and the nonrecording gage data with daily observations. From 1 to 10 years, the data curves are based entirely on empirical calculation of the partial-duration series.

HNP-2-FSAR-2

For periods longer than 20 years, the Gumbel procedure was used for fitting annual series data (which uses the highest rainfall amount for each year) to the Fisher-Tippett type I distribution.⁽¹⁵⁾

Peak rainfall amounts reported in the second table, paragraph 2.3.1.3A, are an average of the two maximum rainfall amounts from the two specific recording stations (Macon and Savannah)⁽³⁾ for each time period. As expected, the resulting peaks are generally higher than for the longest return period (100 years) reported in the first table, paragraph 2.3.1.3A. However, it is not considered irregular for values in the return-period table to exceed peak values because of the statistical methods used to estimate return period values.

B. Hail

Heavy hail (greater than 3/4 in. in diameter) occurs in this area ~ 3 times in 13 years, or about once in 4 years, for a 1-degree (latitude and longitude) "square" (figure 2.3-3). For a 2-degree square, the total reports were about five for the 13-year period, which is consistent with those for the 1-degree square⁽⁴⁾ (figure 2.3-4).

C. Ice Storms

Freezing rain, resulting in occasional heavy loading, is a very rare occurrence in the site area. Based on a 9-year study, it is estimated that one storm will occur about every 9 years.⁽⁵⁾ Maximum accumulation of between a trace and 0.25 in. can be expected.

D. Thunderstorms

The number of thunderstorms in the site area is related to other weather phenomena, including strong winds (paragraph 2.3.1.3H), heavy precipitation (paragraph 2.3.1.3A), and lightning (paragraph 2.3.1.3E). Based on a 25-year period of record at Macon⁽¹⁾ and a 23-year period of record at Savannah,⁽¹⁾ the annual number of days in which thunderstorms occur for the site region is about 60 days per year (tables 2.3-1 and 2.3-2). About 40 of the thunderstorms occur during the summer months associated with the warm, humid, subtropical climate of the region. The remainder of the thunderstorms are scattered throughout the year with a minimum in the winter.

E. Lightning

The probability of lightning striking a particular point on the ground is extremely small. However, during a thunderstorm it is not uncommon for lightning to strike the ground. For example, based on National Weather Service records⁽¹⁶⁾ from Macon, Georgia, during the summer months of June, July, and August 1975, lightning was estimated to have struck the ground at some time during 55% of the thunderstorms. In about 16% of these thunderstorms, cloud-to-ground lightning

was coded as "frequent." As stated in paragraph 2.3.1.3D, about 60 thunderstorms occur annually.

F. Tornadoes

The probability of a particular point being affected by a tornado is a function of the average number of tornadoes occurring in a given area and the average area covered by a tornado. Based on a 13-year study⁽⁴⁾ from 1955 through 1967 reported in figure 2.3-5, the average number of tornadoes is about 13 (or about 1 per year) for the 1-degree square. The total number of tornadoes for a 13-year period⁽⁴⁾ for 2-degree squares is shown in figure 2.3-6.

The area encompassed by a typical tornado has been estimated by Thom to be 2.82 mi².⁽¹⁷⁾ The 1-degree square at this latitude (32°45') has an area of ~ 4050 mi². A conservative estimate of the chance that a given point will be affected by a tornado in a given year, P_s, is therefore approximately:

$$P_s = \frac{\left[\frac{13}{13} \right] \times 2.82}{4050} = 0.0007$$

Thus, a given point can be expected to be affected by a tornado about once in 1436 years, on the average.

G. Probability of High Windspeeds Due to Tornadoes

Probabilities of high windspeeds due to tornadoes have been estimated for this site, using a document issued by the NRC.⁽¹⁸⁾ The probability of strong winds in a tornado striking a specific site is a function of two factors:

1. The frequency of tornadoes in the site region.
2. The intensity probability.

The frequency has been estimated above; however, there are few actual observations of winds associated with tornadoes. Data concerning tornado intensity was collected by NOAA climatologists during 1971 and 1972.⁽¹⁸⁾ For the contiguous United States, 1612 tornadoes were graded on intensity as shown in table 2.3-3. The 1612 tornadoes are categorized into wind groups in table 2.3-4 and into cumulative probability of intensity in table 2.3-5. Tables 2.3-3, 2.3-4, and 2.3-5 are from reference 18.

The probabilities in table 2.3-5 have been plotted on log probability paper in figure 2.3-7 to show the probability of a tornado with a given windspeed.

In reference 18, it is suggested that the design basis tornado should have a probability of occurrence of about 10⁻⁷ per year. The tornado wind with a

HNP-2-FSAR-2

probability of occurrence on this order has been estimated, using the following computational procedure from reference 18.

The intensity probability, P_i , can be calculated using the following relationships:

$$\begin{aligned}P_s P_i &\leq 10^{-7} \\ \frac{1}{1436} P_i &\leq 10^{-7} \\ P_i &\leq 0.000144 \\ P_i &\leq 0.0144\%\end{aligned}$$

From figure 2.3-7, the 0.0144% probable windspeed in a tornado is about 350 mph. This would be represented by a tornado having a rotational speed of about 300 mph moving horizontally at a speed of ~ 50 mph.

Figure 2.3-8 shows calculated tornado windspeeds by 5-degree squares for 10^{-7} probability.

H. Strong Winds

The frequency of strong winds (50 knots or greater), as estimated from damage reports, has been analyzed in the WBTM FCST 12⁽⁴⁾ for the 13-year period 1955 through 1967. The results are shown in figures 2.3-9 and 2.3-10, giving frequencies for 1- and 2-degree squares, respectively. For the site, the number of occurrences in the 13-year period was ~ 11 per 1-degree square, and ~ 40 for the 2-degree square, or about 1 per year for the 1-degree square.

The occurrence of strong winds is usually in conjunction with strong cyclonic disturbances and with thunderstorms, mostly in the summer.

I. High Air Pollution Potential

The site region experiences a relatively high incidence of slow-moving anticyclones, resulting in high air pollution potential, especially in the autumn. Korshhoyer has reported on the climatology of stagnating anticyclones east of the Rocky Mountains between 1936 and 1970.⁽⁷⁾ In his study, he found that in the region of the site there were ~ 8 stagnation days per year. These forecasts are based mainly on expected duration of conditions that cause accumulation of pollutants over a large area.

2.3.2 LOCAL METEOROLOGY

2.3.2.1 Data Sources

Climatological information for the site is provided by the first-order Weather Bureau observations at the Savannah and Macon, Georgia, airports. The climate of the site region will be somewhat different due to the slight modification of the climate around Savannah by the ocean and the slight modification of the Macon area by the higher ground.

In addition, the site meteorological measurement program described in subsection 2.3.3 has been in operation since May 1970. Several years of these data have been summarized and used where appropriate in the sections which follow.

2.3.2.2 Normal and Extreme Values of Meteorological Parameters

A. Wind

The mean windspeed for each month and the most frequent wind direction are listed in table 2.3-1 for Savannah and table 2.3-2 for Macon. Maximum winds occur in the winter and spring, with maximum speeds of 9.5 mph and 9.6 mph in March at Macon and Savannah, respectively. The slowest winds occur in the summer and early fall with a minimum mean speed of 6.5 and 7.0 mph in August at Macon and Savannah, respectively. The average windspeed for the fastest mile on record (25 years ending 1973) was 70 mph in August 1961 at Macon and 90 mph in August 1940 at Savannah (33 years ending 1973). At the site region, Thom⁽⁸⁾ estimates that, at 30 ft above ground, speeds of 80 mph occur once in 50 years and speeds of 100 mph occur once in 100 years.

B. Temperatures

Table 2.3-1 lists monthly averages of the daily maximum, daily minimum, and daily mean (the arithmetic average of the maximum and minimum) temperatures for the climatological normal period 1941 through 1970, compiled from the Savannah Airport. Table 2.3-2 lists similar information for the Macon Airport. The normal daily maximum ranges from 61°F at Savannah and 59°F at Macon in January to 91°F and 92°F in July at Savannah and Macon, respectively. The average daily minimum ranges from 39°F in January and 71°F in July at Savannah, to 37°F in January and 71°F in July at Macon. At Savannah, the record maximum was 105°F in July 1879, and the record minimum was 8°F in February 1899. At Macon a record maximum temperature of 106°F was recorded in June 1954 and a record low of 3°F in January 1966.

For the 30-year period 1944 through 1973, the extreme maximum and minimum temperatures were calculated using the Lieblein Analysis⁽¹⁹⁾ for return periods of 50 and 100 years. Using data from Savannah and Macon and the reduced variate

HNP-2-FSAR-2

Lieblein Analysis, the extreme temperature values for the site region are as follows:

Savannah

<u>Return Period</u>	<u>Maximum Temperature (°F)</u>	<u>Minimum Temperature (°F)</u>
50 years	105.5	8.0
100 years	111.0	-1.4

Macon

<u>Return Period</u>	<u>Maximum Temperature (°F)</u>	<u>Minimum Temperature (°F)</u>
50 years	107.0	3.1
100 years	113.3	-7.5

Based on a 9-year period of record, there are about 70 days (80 days for Macon, 58 days for Savannah) in which the maximum temperature is 90°F or above in the site region (tables 2.3-1 and 2.3-2). Most of these days occur during the summer months.

The growing season in the site region averages about 260 days, from an average date of last freeze of March 5 to a first freeze in autumn of November 20.

C. Water Vapor

Normal relative humidities at 4 synoptic hours, based on 9 years of data, are given in tables 2.3-1 and 2.3-2. They illustrate a moderately humid climate with normal afternoon humidities around 50% in both winter and summer. The spring is the least humid time in terms of relative humidity.

D. Precipitation

Tables 2.3-1 and 2.3-2 list the normal monthly precipitation, the maximum, the minimum observed in a month, and the maximum in 24 h for the respective periods at Savannah and Macon. The maximum 24-h precipitation at Savannah was 11.44 in. in September 1928. At Macon, the maximum 24-h precipitation was 8.36 in. in August 1928.

E. Fog

Heavy fog, with visibility less than 1/4 mile, occurs annually 39 days at Savannah (table 2.3-1) and 25 days at Macon (table 2.3-2). The fog days at Macon are more representative of the site because both Macon and the site region are inland. At Macon, a maximum of about 4 heavy fog days would occur during each winter

month and a minimum of about 1 day a month during the months of April, May, June, and July.

2.3.2.3 Potential Influence of the Plant and Its Facilities on Local Meteorology

The HNP-1 cooling towers consist of four mechanical draft counter-flow cooling towers, while HNP-2 utilizes three mechanical draft cross-flow cooling towers and one counter-flow mechanical draft cooling tower to dissipate waste heat to the atmosphere. The HNP cooling towers utilize state-of-the-art drift eliminators that reduce the maximum drift loss for the cross-flow towers to 0.008% of the circulating water flow and for the counter-flow tower to 0.005% of the circulating water flow. Thus, the plant and its facilities are not expected to have any significant effect on local meteorological conditions.

Experience with cooling towers of the general type located at the plant has resulted in no significant adverse environmental effects. Sustained ground fog is not expected to occur from tower operation; however, during high winds, wisps of the visible plume may briefly intersect the ground near the towers. In the NRC's analysis⁽²⁰⁾ of the effects of the mechanical draft cooling towers at the proposed Barton Nuclear Plant, the NRC staff concluded that icing conditions were not expected to occur because of the buoyancy of the cooling tower plumes. Therefore, as a result of the small amount of drift (i.e., water droplets) emitted from the towers and the buoyancy of the cooling tower plumes, no ice deposition problem at HNP is anticipated. To protect the cooling towers from freezing during low temperature operation, the capability exists to bypass the cooling towers until the water temperature in the cooling tower flumes and basins has increased. Negligible increases in relative humidity in the site region would result from tower operation.

2.3.2.4 Topographical Description

A topographic map of the site region is shown in figure 2.3-11. Topographic cross-sections for each of the 16 direction sectors are included in figure 2.3-12. A site topographic map is shown in figure 2.3-13.

2.3.3 ONSITE METEOROLOGICAL MEASUREMENT PROGRAM

The onsite meteorological measurement program began in April 1970. The original 150-ft tower is located in a cleared area (figure 2.3-13) and now serves as a backup tower for the new primary tower. Pertinent meteorological parameter instrument elevations and descriptions are given in table 2.3-7. The meteorological tower, instrumentation, and recorders were installed and shared with Unit 1. Windspeed, direction, and vertical temperature differences are recorded in the main control room (MCR) for use by both units. Data are continuously recorded on recorders. Preventive and routine maintenance are performed by Southern Nuclear Operating Company personnel in accordance with the instrument manuals. These personnel also perform emergency repair work to minimize outages and to ensure maximum data recovery. Calibrations are performed semiannually.

HNP-2-FSAR-2

Meteorological data are normally reduced to 15-min averages centered on the hour. These data are then converted to engineering units and summarized to provide averages representative of each hour of data. These hourly averages provide the information from which monthly, seasonal, and annual summaries can be prepared as required.

For this report, 4 years of records collected from the original site tower from June 1970 through September 1974 have been used. During each of the 1-year periods, the following approximate percentages of data recovery were achieved for each parameter used in this report:

Item	Parameter	Percent Recovery			
		6/70- 5/71	9/71- 8/72	9/72- 8/73	9/73- 8/74
1	75-ft windspeed	97.8	98.1	95.7	93.7
2	150-ft windspeed	98.8	80.3	97.9	96.4
3	75-ft wind direction	99.2	97.6	96.5	96.7
4	150-ft wind direction	99.1	99.6	97.5	95.2
5	$\Delta T_{150-33 \text{ ft}}$	99.6	98.7	97.0	90.4
6	Combined 75-ft windspeed, 75-ft wind direction, $\Delta T_{150-33 \text{ ft}}$	97.3	96.2	92.0	85.3
7	Combined 150-ft windspeed, 150-ft wind direction, $\Delta T_{150-33 \text{ ft}}$	98.2	78.5	95.2	86.7

In September 1972, the lower temperature sensor was moved from 10 ft to 33 ft to avoid ground effects. For the first 2 years of data, a temperature difference correction factor was applied assuming a logarithmic relationship between temperature and elevation above grade. The correction factor for the ΔT between 150 ft and 10 ft to provide an effective ΔT between 150 ft and 33 ft was determined as follows:

$$\Delta T_{150 \text{ ft} - 33 \text{ ft}} = f \times \Delta T_{150 \text{ ft} - 10 \text{ ft}}$$

$$f = \left[\frac{\text{Ln } \frac{150}{33}}{\text{Ln } \frac{150}{10}} \right] = 0.56$$

Figure 2.3-14 is a wind rose from the 150-ft level for the 4-year period of record. Figure 2.3-15 shows wind roses for each month and season for the 150-ft data. Joint frequency of windspeed and direction by temperature difference group are shown in table 2.3-9 for the 75-ft level, and in table 2.3-10 for the 150-ft level for the period from June 1, 1970, to August 31, 1974.

HNP-2-FSAR-2

As part of the station emergency response plans, an upgraded meteorological system has been installed on site in accordance with the meteorological guidance of the Proposed Revision 1 to Regulatory Guide 1.23, "Meteorological Programs in Support of Nuclear Power Plants," and Revision 1 of NUREG-0654, "Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants." The upgraded system is capable of making reliable meteorological measurements. The new meteorological measurement program is described in the following paragraphs.

The upgraded measurement system includes a 100-m meteorological tower, designated as the primary tower, and the existing 45-m (150-ft) tower, which has been reinstrumented to serve as a backup system to the primary tower.

The new 100-m primary tower has been erected in an open field, 0.75 miles south-southwest of the power blocks within the plant boundaries, as shown in figure 2.3-13. The meteorological tower is instrumented at three levels (10 m, 60 m, and 100 m) to characterize the conditions for diffusion estimates of radiological releases at different levels. The meteorological parameters measured on the tower, models of the sensors employed, and parameter accuracy are given in table 2.3-7. The tower is equipped with a boom elevator, which eliminates climbing the tower to perform sensor maintenance.

The backup meteorological tower is instrumented at the 10-m and 45-m levels. Parameters measured on the tower and the instruments' accuracies are listed in table 2.3-7.

Both the meteorological towers and their associated equipment buildings are designed for lightning protection and are also connected to a power system that includes redundant power sources. In addition, a heating, ventilating, and air-conditioning system for each equipment building is provided to maintain building temperatures within equipment tolerance limits.

Signals from the meteorological sensors are conditioned for transmission in the associated equipment building. The signals are then transmitted independently to the recorders and the digital data acquisition system in the MCR. The recorders, which serve as backup data recording equipment to the digital data acquisition system, are located in the MCR. The recorders and data acquisition system are shared by HNP-1 and HNP-2. The required 15-min averages of meteorological parameters for diffusion estimates are reduced from data recorded by the data acquisition system.

2.3.4 SHORT-TERM (ACCIDENT) DIFFUSION ESTIMATES

2.3.4.1 Objective

In this section, estimates of atmospheric dilution factors are made based on 4 years of HNP site meteorological data. Probability distributions are drawn and values are reported which have a 5% and 50% probability of occurrence for each time period used in the safety analysis in chapter 15. Estimates of atmospheric dilution factors are applicable to HNP-1 and HNP-2.

Methods used to estimate diffusion conditions for evaluating short-term accident releases (< 1 h) are discussed in paragraph 2.3.4.2.1, and methods for assessing the consequences of longer term accident releases (from 1 h to 30 days) are discussed in paragraph 2.3.4.2.2. Diffusion conditions for the main steam line break accident (MSLBA) are also discussed in paragraph 2.3.4.2.1. However, methods used to estimate diffusion conditions for evaluating loss of coolant accident (LOCA) releases for the MCR and technical support center (TSC) are discussed in subsection 2.3.6, instead of this subsection.

2.3.4.2 Calculations

Conservative values of accident diffusion estimates are given in table 2.3-11 for both stack and ground-level releases. Derivation of these values is as follows:

2.3.4.2.1 Short-Term Accident Diffusion Estimates

A. Releases From Vents or Leaks Which Are Trapped in the Wake of Plant Structures

To determine the atmospheric dispersion appropriate for short-term (1 h or less) releases in the wake of plant structures, a plot of cumulative centerline X/Q values as a function of probability of occurrence is made for each of the 4-year periods of site hourly data. Statistical distributions plotted for the 1-h cases are constructed by computing X/Q values for each hour of the period of onsite records and then counting all of the hours that had X/Q values equal to or greater than selected values. The number of hours so obtained is then divided by the number of hours in the total period of record to obtain the probability that the selected X/Q value would be equaled or exceeded. Values found for each separate year were averaged to obtain the 4-year estimate. The resulting probabilities are independent of wind direction.

Equations and methods used to compute X/Q values are discussed in paragraph 2.3.4.2.4. Pasquill diffusion categories used for each hour are based on vertical temperature difference measurements as described in paragraph 2.3.4.2.3. Building wake is accounted for as described in paragraph 2.3.4.2.4. Calms are assumed to have a windspeed of 1.0 mph and the measured diffusion condition.

For analyses of ground-level releases, measured values of speed at 75 ft were extrapolated to the 33-ft level, using the following general equation:⁽²¹⁾

$$\bar{u}_{33\text{ft}} = \bar{u}_{75\text{ft}} \left[\frac{h}{z} \right]^n$$

where:

$$\bar{u}_{33\text{ft}} = \text{extrapolated speed at 33 ft (mph).}$$

HNP-2-FSAR-2

- \bar{u}_{75ft} = measured speed at 75 ft (mph).
- z = height at which measurement is made (75 ft).
- n = exponent based on stability.
- h = height to which extrapolation is made (33 ft).

Average values of n used for each diffusion group are assumed to be as given in the table below. These values are in accordance with reference 21 with the exception of group D, which was found to be between the reference 21 values on one tower studied.⁽²²⁾ Assuming an n value of 0.33 for group D results in lower speeds at the 33-ft level than would result using the 0.25 value for n. Therefore, use of 0.33 is conservative compared with the suggested value of 0.25 in reference 21.

<u>Diffusion Group</u>	<u>n</u>
A	0.25
B	0.25
C	0.25
D	0.33
E	0.5
F	0.5
G	0.5

B. Diffusion Estimates for Stack Releases

On the average, windspeed increases with height within the first several hundred meters above the ground. This increase has been predicted by investigators⁽²³⁾ using the exponential relationship given in paragraph 2.3.4.2.1.A. Windspeeds are known to increase more rapidly under stable conditions than for unstable conditions. Therefore, estimates of windspeed increases with height are based on measured values of ΔT from the tower.

Figure 2.3-16 shows examples of measured vertical average speed profiles from ORNL, Oyster Creek, Savannah River, Sterling, Douglas Point, Ginna, and a 400-ft tower in central Pennsylvania. The figure shows that the predicted average windspeed at 120 m (stack height) for Hatch is lower, and thus conservative, compared with measured values from other sites. Therefore, it is concluded that the method used to extrapolate 150-ft windspeed measurements to the 120-m level at the HNP site is appropriate and conservative.

For elevated releases at the stack height of 120 m, the windspeed extrapolation equation discussed in A, above, was used with $h = 120$ m and $z = 150$ ft (46 m) (the instrument height used for stack estimates). Probability plots were made using hourly values of X/Q for 4 years as in A, above. The elevated diffusion

equation given in paragraph 2.3.4.2.4 was used to estimate X/Q values. The 5% probable 1-h offsite X/Q values are given in table 2.3-11. These values are the peak computed at the site boundary (low population distance) of 1250 m.

C. Diffusion of MSLBA Releases

In a MSLBA, fission products in the steam will rise with the steam and not be entrapped in the building wake. Therefore, to estimate the appropriate diffusion conditions for such an event, the elevated diffusion model for a 30-m release was used as described in paragraph 2.3.4.2.4. The 5% probable X/Q was calculated based on the conditions given in Regulatory Guide 1.5-1971. The diffusion conditions assumed for control room operator doses due to a MSLBA are discussed in subsection 15.3.4.

2.3.4.2.2 Long-Term Accident Diffusion Estimates

For releases which occur over a longer period of time (> 1 h), it is appropriate to consider changes in wind direction, atmospheric stability, and windspeed which result in lower concentrations at any given offsite location. Using the available onsite data, a computer evaluation was made to estimate the probability that any particular average diffusion condition (or poorer one) would exist during a selected interval of time at any offsite location.

Starting with each hour of data for 1 year, the computed X/Q values are added in each of 16 direction sectors for the duration of the release time period being evaluated. The maximum integrated value of all 16 directions is stored, and a new integration period spaced 1 hour later is started. Again, the maximum value from this next integration period is stored regardless of the direction sector in which it occurred, and so on. After processing all hours of data, cumulative probability plots are made for each release time period considered. Table 2.3-11 gives these values for both the site boundary and low-population zones. Estimates in table 2.3-11 are the average of four separate 1-year runs at the given probability level. The diffusion models and assumptions are described in paragraphs 2.3.4.2.3 and 2.3.4.2.4.

2.3.4.2.3 Selection of Diffusion Condition

Table 2.3-12 gives the temperature difference categories (from Regulatory Guide 1.23-1972) used to classify the site data into Pasquill groups for use in computing σ_y and σ_z in the diffusion equations.

2.3.4.2.4 Methods for Dispersion Computations

Plume centerline values of X/Q for ground-level releases are estimated using the following model:

$$\frac{X}{Q} = \frac{1}{\bar{u}_{33}(\pi\sigma_y\sigma_z + cA)}$$

HNP-2-FSAR-2

where:

X	=	concentration ($\mu\text{Ci}/\text{m}^3$).
Q	=	release rate ($\mu\text{Ci}/\text{s}$).
\bar{u}_{33}	=	average windspeed at 33 ft (m/s).
σ_y	=	horizontal diffusion coefficient based on temperature difference and Pasquill curves (m). ⁽²⁴⁾⁽²⁵⁾
σ_z	=	vertical diffusion coefficient based on vertical temperature difference and Pasquill curves (m). ⁽²⁴⁾⁽²⁵⁾
cA	=	building wake factor (800 m^2) ($c = 0.5$ and $A = 1600 \text{ m}^2$).

Sector average X/Q values are determined using the general equation:

$$\frac{X}{Q} \text{ sector average} = \frac{2.03}{x \bar{u} \sigma_{z(\text{eff})}}$$

This is an integrated form of the Pasquill diffusion relationship⁽²⁴⁾⁽²⁵⁾ which uses an effective σ_z term to account for dilution in the vertical direction from the building wake. The symbols have the following meanings:

x	=	distance from source (m).
X	=	average concentration at ground level in the given 22 1/2-degree sector (ci/m^3).
Q	=	average release rate (ci/s).
u	=	windspeed (m/s) at the 33-ft level (extrapolated from 75-ft level).
σ_z	=	vertical diffusion coefficient (m).

Values of $\sigma_{z(\text{eff})}$ were determined for each stability group using the relationship:

$$\sigma_{z(\text{eff})} = \sqrt{(\sigma_z)^2 + \frac{cH^2}{\pi}}, \text{ with a limit of } \sqrt{3} \sigma_z$$

where:

H	=	height of plant structure (assumed 47 m).
c	=	0.5 as before.

HNP-2-FSAR-2

The Pasquill diffusion condition (for determination of σ_z) is assumed to be a function of vertical temperature difference as derived in paragraph 2.3.4.2.3.

Plume centerline X/Q values are used for post-accident time periods less than 8 h, and sector average values are used for time periods greater than 8 h. The site boundary and the low population distances are assumed to be 1250 m.

For stack releases, the elevated equation for ground-level centerline concentration was used as follows:

$$X/Q = \frac{1.0}{u\pi\sigma_y\sigma_z} e^{-\left[\frac{h^2}{2(\sigma_z)^2}\right]}$$

where parameters are as above except h is the stack height in meters and u is the windspeed at stack height in meters per second. This equation is also used for MSLB calculations of atmospheric dispersion factors. The sector average version of the elevated equation is used for time periods beyond 8 h.

The sector average diffusion model for releases from the stack is as follows:

$$X/Q = \frac{2.03}{\bar{u}\sigma_z} e^{-\left[\frac{h^2}{2(\sigma_z)^2}\right]}$$

where symbols are as before and h is the stack height. For average annual calculations, the local terrain height above plant grade (figure 2.3-12) was subtracted from the plume centerline height at each distance for which estimates were made. Only the peak offsite value is used in the averaging technique of paragraph 2.3.4.2.2 for simplicity and conservatism.

2.3.5 LONG-TERM (ROUTINE) DIFFUSION ESTIMATES

2.3.5.1 Objective

The objective of this section is to calculate annual average diffusion conditions for use in evaluating routine ground-level and elevated releases from the plant. Low-level releases into wakes of buildings are considered as ground-level releases. Annual average diffusion conditions are applicable to HNP-1 and HNP-2; and also, are used as input to dose calculations described in subsection 11.3.4.

2.3.5.2 Calculations

Data used in the analyses are presented in this section as joint frequency tables. For the HNP site, these tables were compiled for 2 levels over a 4-year period of record. Table 2.3-13 is a

joint frequency table of windspeed, wind direction, and stability group for the 150-ft level using ΔT between 150 ft and 35 ft.

These data are used for evaluations of stack effluents. An exponential speed adjustment is made to the 393-ft stack height. Table 2.3-14 is similar to Table 2.3-13 for the 75-ft level with a speed adjustment to the 33-ft level. Table 2.3-14 is used for evaluations of ground-level release effluents. A logarithmic adjustment to the ΔT to be representative of temperature difference between 150 ft and 10 ft is made for all data prior to September 1972, when the lower temperature sensor was moved to the 35-ft level for ground release calculations. Table 2.3-15 is a 150-ft level joint frequency table similar to table 2.3-13 for each of the 12 months, and table 2.3-16 is a 75-ft level joint frequency table similar to table 2.3-14 for each of the 12 months.

2.3.5.2.1 Airflow Trajectory and Terrain Influences

As indicated by the 4-year (1970-1974) 150-ft wind rose from the HNP meteorological tower, the general flow pattern in the plant site region is from the northwest to the southwest and from the east. (See figure 2.3-14.) During the fall and winter months, high-pressure systems generally passing to the north of the plant site dominate the eastern two-thirds of the United States. The clockwise circulation around these high-pressure centers produces NWW winds when to the west of the plant site and NEE winds when to the north and east of the plant site. During the spring and summer months and at various other times throughout the year, the southern U.S. comes under the influence of Gulf and South Atlantic high-pressure centers. These would produce predominately west and southwest winds when to the west of the site area and SSE winds when to the east of the site. The plant site region is influenced by a number of low-pressure centers; however, these centers generally move rapidly and affect the area only for short periods.

Topography is gently rolling in the site area and has little effect on wind trajectory. During periods of light winds, local terrain affects wind trajectory. The most pronounced terrain feature is the river depression; however, this is a relatively small, wide depression which has little influence. Since it is not considered practical at the present time to compute estimates using particle-in-cell or puff trajectory diffusion models, correction factors suggested in Regulatory Guide 1.111 for open terrain are used in this analysis. This is considered to result in diffusion estimates at distances near the plant which are very unlikely to be exceeded.

2.3.5.2.2 Description of Atmospheric Diffusion Models

Models described in this section follow those described in Regulatory Guide 1.111. The following paragraphs describe the models used in these evaluations with frequent references to Regulatory Guide 1.111, since most assumptions are identical to those in the guide. These models are used to determine routine (average) X/Q and D/Q values applicable to the site.

2.3.5.2.2.1 Atmospheric Diffusion Model. Average atmospheric dispersion evaluated using the straight line airflow model as follows:

$$\overline{\left(\frac{X}{Q'}\right)_D} = 2.032 \sum_{ij} n_{ij} \left[N x \bar{u}_i \Sigma_{zj}(x) \right]^{-1} \exp \left[-\frac{h_e^2}{2\sigma_{zj}^2}(x) \right] \quad (1)$$

where:

- h_e = the effective release height.
- n_{ij} = the length of time (hours of valid data) weather conditions are observed to be at a given wind direction, windspeed class, i, and atmospheric stability class, j.
- N = the total hours of valid data.
- \bar{u}_i = the geometrical mean of all speeds in the windspeed class, i, at a height representative of release; calms are one-half the threshold anemometer speed or less; extrapolation to higher levels, if necessary, is done by raising the ratio of the two heights to the n power, where n = 0.25, 0.33 and 0.5 for unstable, neutral, and stable conditions, respectively.
- $\sigma_{zj}(x)$ = the vertical plume spread without volumetric correction at distance, x, for stability class, j (figure 1 of Regulatory Guide 1.111) based on vertical temperature difference (ΔT) and Regulatory Guide 1.23 categorization of Pasquill Groups by ΔT .
- $\Sigma_{zj}(x)$ = the vertical plume spread with a volumetric correction for a release within the building wake cavity, at a distance, x, for stability class, j; otherwise $\Sigma_{zj}(x) = \sigma_{zj}(x)$.
- $\overline{\left(\frac{X}{Q'}\right)_D}$ = the average effluent concentration, X, normalized by source strength, Q', at distance, x, in a given downwind direction, D.
- 2.032 = $(2/\pi)^{1/2}$ divided by the width in radians of a 22.5-degree sector.

In some cases, hourly data were used and the summation over i and j in the above equation was deleted; this summation was accomplished for all hours at all distances for each direction. Dilution was decreased according to terrain correction factors in figure 2 of Regulatory Guide 1.111. These factors were multiplied by the results from equation 1 and varied in accordance with the direction and distance being evaluated.

This general Gaussian diffusion model has been used extensively for both nuclear reactor and air pollution diffusion analysis for at least 10 years; therefore, it is considered appropriate for use in this specific application. With regard to model accuracy, the greatest weakness results from determining stability using vertical temperature difference. A more appropriate representation of

turbulence and resulting diffusion could be obtained using bivariate data or some other measurement of turbulence.

Actual model input assumptions and source-term configurations are discussed below.

2.3.5.2.2.2 Source Configuration Considerations. If a release point is elevated and there are no buildings which would obstruct the plume in its normal trajectory, equation 1 is used with the height of release defined as follows (from equation 4 of Regulatory Guide 1.111):

$$h_e = h_s + h_{pr} - h_t - c \quad (2)$$

where:

- c = correction for low relative exit velocity (equation 5 of Regulatory Guide 1.111).
- h_e = effective release height.
- h_{pr} = rise of the plume above the release point based on Briggs. (See further explanation below.)
- h_s = is the physical height of the release point. (The elevation of the stack base should be assumed to be zero.)
- h_t = maximum terrain height between the release point and the point for which the calculation is made.

Values of h_{pr} are computed as follows for a jet since nuclear plant vents have an insignificant amount of buoyancy resulting from heated discharges:

$$h_{pr} = 1.44D \left(\frac{W_o}{\bar{u}} \right)^{2/3} \left(\frac{x}{D} \right)^{1/3} \quad (3)$$

up to the point where h_{pr} is the minimum of the following two equations:

$$h_{pr_{max}} = 3 \left(\frac{W_o}{\bar{u}} \right) D, \text{ or} \quad (4a)$$

$$h_{pr_{max}} = 1.5 \left(\frac{F_m}{\bar{u}} \right)^{1/3} s^{-1/6} \quad (4b)$$

where symbols are as before, and

- D = stack or vent effective inside diameter (m).

HNP-2-FSAR-2

- W_o = stack or vent exit velocity (m/s).
 \bar{u} = windspeed at discharge level (m/s).
 F_m = momentum flux (m^4/s^2).
 s = stability parameter (s^{-2}).

If the plume trajectory from a release point (vent) does not remain outside of building wake influences near large structures, all or portions of the plume are considered to be entrapped and brought to ground level in the turbulent wake of the building. The criteria for determining the portion of the plume treated as an elevated or ground release follows from equations 6, 7, and 8 of Regulatory Guide 1.111 and are repeated below for completeness:

If $W_o/\bar{u} > 5.0$, use h_e as calculated above.

If $W_o/\bar{u} \leq 1.0$, use $h_e = 0$.

If $1 < W_o/\bar{u} \leq 1.5$, $E_t = 2.58 - 1.58 \left(\frac{W_o}{\bar{u}} \right)$

If $1.5 < W_o/\bar{u} \leq 5.0$, $E_t = 0.30 - 0.06 \left(\frac{W_o}{\bar{u}} \right)$

The appropriate diffusion estimate is then computed by assuming an elevated release 100 (1 - E_t) percent of the time and by assuming ground release 100 E_t percent of the time. Calculations using this mixed model are referred to as wake-split calculations in this report. A building wake correction is computed for all ground releases near structures in accordance with the following general equation:

$$\Sigma = \sqrt{\sigma_z^2 + \frac{cH^2}{\pi}} \leq 1.73\sigma_z \quad (5)$$

where:

- Σ = effective dispersion coefficient for use in equation 1 (m).
 c = building wake coefficient ($c = 0.5$).
 H = height of the tallest structure in the nuclear plant power block (m).

2.3.5.2.2.3 Removal Mechanisms. As radioactive effluent in a plume travels downwind, it is subject to several removal mechanisms including radioactive decay, dry deposition, and wet deposition (during rain). Corrections for radioactive decay are not made in the estimates reported in this section.

Dry deposition which results in depletion of halogen and particulate isotopes from the plume is considered only to the extent suggested in Regulatory Guide 1.111, figures 3 through 6. Depletion factors in these curves are a function of height and distance; therefore, for sites where elevated releases occur, the terrain must be subtracted from the plume height before entering the curves at the appropriate distance. Each elevated or ground level, X/Q is multiplied by the depletion and the terrain correction factors before combining to give the final depleted X/Q value.

To determine relative deposition rate as a function of distance and stability, the curves given in figures 7 through 10 of Regulatory Guide 1.111 are used. Again, terrain heights are subtracted before the table lookup. Each D/Q value is multiplied by terrain correction factors, if any. Values from the curves are divided by the sector cross-width (arc) at the point of calculation.

Since seasonal rainfall is fairly uniform, dry deposition is believed to adequately represent overall deposition rates; therefore, wet deposition has not been considered.

2.3.5.2.3 Diffusion Model Inputs and Results

Computer runs have been made using site data in the diffusion models given in paragraph 2.3.5.2.2. A list of runs, input assumptions, and results are given in the following sections.

2.3.5.2.3.1 List of Computer Runs. Table 2.3-17 tabulates computer runs which used the diffusion models described in paragraph 2.3.5.2.2. Since the grazing season is assumed to exist all year, separate runs for the grazing season were not necessary.

2.3.5.2.3.2 Summary of Plant Discharges. A summary of plant vent information for each discharge point is given in tables 2.3-18 and 2.3-19. Only vents used during routine operation are considered in this evaluation. Inspection of tables 2.3-18 and 2.3-19 shows that two calculations are required to determine diffusion conditions applicable for each vent.

2.3.5.2.3.3 Input Assumptions. Table 2.3-20 tabulates all pertinent input information utilized in making the model calculations. Terrain elevations for all distances out to 10 miles are found in figure 2.3-12. Terrain height is conservatively not allowed to decrease with increasing distance or to decrease below plant grade in accordance with Regulatory Guide 1.111.

2.3.5.2.3.4 Results. Resulting X/Q and D/Q values are listed in tables 2.3-21 and 2.3-22 for each direction sector for 10 distances. These results are used as input for the dose calculations described in subsection 11.3.4. Tables 2.3-23 and 2.3-24 summarize the resulting diffusion factors for each of the receptor locations. Each table represents model results for one vent location. One set of calculations was made for the stack, and the second set of calculations was made for all other vents. Since the main plant vent has a top-hat, no vertical jet exists and

use of a wake-split model is not appropriate. Thus, all effluents were assumed to be entrapped in the building wake at ground level.

2.3.6 ACCIDENT DIFFUSION ESTIMATES FOR MCR AND TECHNICAL SUPPORT CENTER

For a loss of coolant accident (refer to subsection 15.3.3), the MCR and the technical support center (TSC) X/Q values were determined using the methodology in NUREG/CR-6331 (reference 28) and the computer code ARCON95, which was developed by Pacific Northwest Laboratory for the NRC to determine X/Q values for identified plant-specific release points. (All other accident diffusion estimates use the methodology discussed in subsection 2.3.4) The ARCON95 Code utilizes hourly meteorological data and improved methods to predict, within a 95% confidence level, dispersion in the vicinity of buildings. Under calm wind conditions, the receptor location (i.e., outdoor air intake) is assumed to be directly downwind of the release point. X/Q values are calculated for averaging periods ranging from 1 h to 30 days. These X/Q values are applicable for HNP-1 and HNP-2.

ARCON95 determines X/Q values for vent, ground-level and elevated releases. Vent releases are releases that take place through an uncapped vertical opening. Releases considered to be ground-level releases are those with release heights less than the estimated building wake cavity height. This cavity height is dependent upon the building height and the along-wind dimension of the building. Building wake effects are considered in the model for estimating X/Q values from ground-level releases. By the guidance in NUREG/CR-6331, elevated release are releases from points with a height > 2.5 times the height of the building. Elevated stack release are assumed to be transported directly toward the MCR and TSC air intakes.

ARCON95 uses hourly meteorological data account for the effects on wind direction persistence in reducing average relative concentrations for periods longer than 2 h in duration. ARCON95 treats missing data by deleting hours with missing data from the calculation of the average relative concentrations used in determining the cumulative frequency distributions.

NUREG/CR-6331 provides tolerance criteria used to determine when the number of hours of missing data makes a specific average relative concentration unacceptable. The criterion for averages ≤ 8 h is zero missing data. For longer duration averages, up to 10% missing data are acceptable.

One year (1995) of continuous hourly site meteorological data (wind speed, wind direction from the 10-m and 100-m levels, and stability class) was used in the prepared input to the ARCON95 model to calculate the X/Q values.

In computing average relative concentrations at the intake points, ARCON95 assumes the release travels directly from the release point to the intake, if the wind direction is within a window specified by the user. Thus, the direction from the receptor (i.e., air intake) to the source (i.e., release point) and the "wind direction window width" are part of the input requirements for ARCON95. As suggested in NUREG/CR-6331, the wind direction window width was chosen as ± 45 degrees.

HNP-2-FSAR-2

For some release points, if a wind direction window width of ± 45 degrees is applied, the intake will no longer be located downwind from the release due to the orientation of the turbine building. In these cases, to properly simulate the impacts the direction from the receptor to the source are adjusted such that the modified wind direction ranges have the potential to impact the air intake while maintaining the 90-degree wind direction window, as recommended in NUREG/CR-6331.

The calculated X/Q values, based upon reference 27, for the MCR and the TSC for various release paths are provided in table 2.3-25.

HNP-2-FSAR-2

REFERENCES

1. NOAA Local Climatological Data, Savannah, Georgia, Macon, Georgia, U.S. Department of Commerce, revised 1973.
2. Hershfield, D. M., Rainfall Frequency Atlas of the U.S., Technical Paper No. 40, U.S. Department of Commerce, U.S. Weather Bureau, 1963.
3. Jennings, A. J., Maximum Recorded United States Point Rainfall for Five Minutes to Twenty-Four Hours at 926 First-Order Stations, U.S. Weather Bureau, Technical Paper No. 2, 1963.
4. Pautz, M. E. (ed.), Severe Local Storm Occurrences, 1955-1967, Technical Memorandum, WBTM FSCT 12, U.S. Department of Commerce, ESSA (now NOAA), 1969.
5. Bennett, I., Glaze, Its Meteorology and Climatology, Geographical Distribution, and Economic Effects, U.S. Army, Quartermaster Research and Engineering Command, Technical Paper EP-105, 1959.
6. Wolford, L. V., Tornado Occurrences in the U.S., Technical Paper No. 20. U.S. Department of Commerce, ESSA (now NOAA), 1960.
7. Korshhover, J., Climatology of Stagnating Anticyclones East of the Rocky Mountains, 1936-1970, NOAA Technical Memorandum ERL ARL-34, 1971.
8. Thom, H. C. S., "New Distributions of Extreme Winds in the U.S.," Journal of the Standards Division, Proceedings of the American Society of Civil Engineering, Volume 94, No. ST7, pp 1787-1801, 1968.
9. Dye, Lucius W. and Grabill, Esther K., General Summary of Tornadoes, 1966, Environmental Data Service, ESSA, Washington, D.C.
10. U.S. Department of Commerce, National Oceanic and Atmospheric Administration, Environmental Data Service, Storm Data, September 1971, Volume 13.
11. Cry, G. W., Tropical Cyclones of the North Atlantic Ocean 1871-1963, Technical Paper No. 55, U.S. Department of Commerce.
12. Clark, G. B., Hurricane Season of 1965, Weather Bureau Office, Environmental Science Services Administration, Miami, Florida.
13. Frank, N. L., 1964 Hurricane Season, National Hurricane Center, U.S. Weather Bureau, Miami, Florida.
14. Climatological Data for Georgia for February 1973, U.S. Department of Commerce, July 1973.

HNP-2-FSAR-2

15. Gumbel, E. J., Statistics of Extremes, 375 pp, Columbia University Press, 1958.
16. Surface Weather Observations, Macon, Georgia, U.S. Department of Commerce, NOAA, National Weather Service.
17. Thom, H. C. S., "Tornado Probabilities," Monthly Weather Review, October-December 1963, pp. 730-736.
18. U.S. Atomic Energy Commission, Office of Regulation, "Technical Basis for Interim Regional Tornado Criteria," May 1974.
19. Thom, H. C. S., World Meteorological Organization, Some Methods of Climatological Analysis, Technical Note No. 31.
20. Draft Environmental Statement Related to the Proposed Alan R. Barton Nuclear Plant Units 1,2,3, and 4. U.S. Nuclear Regulatory Commission, April 1975.
21. Smith, Maynard (ed.), Recommended Guide for the Prediction of the Dispersion of Airborne Effluents, ASME, p. 55, 1968.
22. Jersey Central Power & Light, Forked River Nuclear Station Unit No. 1 PSAR, Amendment No. 6, p 2-7a, February 19, 1971.
23. Smith, Maynard (ed.), Recommended Guide for the Prediction of the Dispersion of Airborne Effluents, ASME, p 55, 1968.
24. Gifford, F. A., "Consequences of Activity Release," Nuclear Safety, p 57, (1960).
25. Pasquill, F., "Estimation of the Dispersion of Windborne Material," Meteorology Magazine, 90, (1963), pp. 33-49.
26. Deleted.
27. Letter HL-5333, Southern Nuclear Operating Company to NRC, "Revised Post-LOCA Doses," Docket Nos. 50-321 and 50-366, dated April 17, 1997.
28. NUREG/CR-6331, "Atmospheric Relative Concentrations in Building Wakes," May 1995.

HNP-2-FSAR-2

TABLE 2.3-3 (SHEET 1 OF 2)
TABLE OF FUJITA-PEARSON TORNADO SCALE^(a)

F-Scale Maximum Windspeed				P-Scale Path Length			P-Scale Path Width			
Scale	(mph)	(kts)	(m/s)	Scale	(mi)	(km)	Scale	(ft)	(yd)	(m)
F 0.0	40	35	18	P 0.0	0.3	0.5	P 0.0	17	6	5
0.1	43	37	19	0.1	0.4	0.6	0.1	19	6	6
0.2	46	40	21	0.2	0.4	0.6	0.2	21	7	6
0.3	49	43	22	0.3	0.5	0.7	0.3	24	8	7
0.4	52	46	23	0.4	0.5	0.8	0.4	26	9	8
0.5	56	48	25	0.5	0.6	0.9	0.5	30	10	9
0.6	59	51	26	0.6	0.6	1.0	0.6	33	11	10
0.7	63	54	28	0.7	0.7	1.1	0.7	37	13	11
0.8	66	57	30	0.8	0.8	1.3	0.8	42	14	13
0.9	70	60	31	0.9	0.9	1.4	0.9	47	16	14
F 1.0	73	64	33	P 1.0	1.0	1.6	P 1.0	53	18	16
1.1	77	67	34	1.1	1.1	1.8	1.1	59	20	18
1.2	81	70	36	1.2	1.3	2.0	1.2	66	22	20
1.3	84	73	38	1.3	1.4	2.3	1.3	74	25	23
1.4	88	77	40	1.4	1.6	2.6	1.4	84	28	26
1.5	92	80	41	1.5	1.8	2.9	1.5	94	31	29
1.6	96	84	43	1.6	2.0	3.2	1.6	105	35	32
1.7	100	87	45	1.7	2.2	3.6	1.7	118	39	36
1.8	104	91	47	1.8	2.5	4.0	1.8	133	44	40
1.9	109	94	49	1.9	2.8	4.5	1.9	149	50	45
F 2.0	133	98	50	P 2.0	3.2	5.1	P 2.0	167	56	51
2.1	117	102	52	2.1	3.5	5.7	2.1	187	62	57
2.2	121	105	54	2.2	4.0	6.4	2.2	210	70	64
2.3	126	109	56	2.3	4.5	7.2	2.3	235	78	72
2.4	130	113	58	2.4	5.0	8.1	2.4	265	88	81
2.5	135	117	60	2.5	5.6	9.0	2.5	297	99	90
2.6	139	121	62	2.6	6.3	10.2	2.6	333	111	102
2.7	144	125	64	2.7	7.1	11.4	2.7	374	125	114
2.8	148	129	66	2.8	7.9	12.8	2.8	419	140	128
2.9	153	132	68	2.9	8.9	14.3	2.9	470	157	143

HNP-2-FSAR-2

TABLE 2.3-3 (SHEET 2 OF 2)

F-Scale Maximum Windspeed				P-Scale Path Length			P-Scale Path Width			
Scale	(mph)	(kts)	(m/s)	Scale	(mi)	(km)	Scale	(ft)	(yd)	(m)
F 3.0	158	137	70	P 3.0	10.0	16.1	P 3.0	528	176	161
3.1	162	141	73	3.1	11.2	18.0	3.1	591	197	180
3.2	167	145	75	3.2	12.6	20.3	3.2	665	222	203
3.3	172	149	77	3.3	14.1	22.7	3.3	744	248	227
3.4	177	154	79	3.4	15.9	25.6	3.4	837	279	256
3.5	182	158	81	3.5	17.8	28.6	3.5	940	313	286
3.6	187	162	83	3.6	20.0	32.2	3.6	1054	351	322
3.7	192	167	86	3.7	22.4	36.0	3.7	1183	394	360
3.8	197	171	88	3.8	25.1	40.4	3.8	1326	442	404
3.9	202	175	90	3.9	28.2	45.4	3.9	1489	496	454
F 4.0	207	180	93	P 4.0	31.6	50.9	P 4.0	1670	557	509
4.1	212	184	95	4.1	35.5	57.1	4.1	1874	625	571
4.2	218	189	97	4.2	39.8	64.1	4.2	2102	701	641
4.3	223	194	100	4.3	44.7	71.8	4.3	2354	785	718
4.4	228	198	102	4.4	50.1	80.6	4.4	2646	882	806
4.5	233	203	104	4.5	56.2	90.4	4.5	2967	989	904
4.6	238	207	107	4.6	63.1	102.0	4.6	3332	1111	1.0 km
4.7	244	212	109	4.7	70.8	114.0	4.7	3738	1246	1.1
4.8	250	217	112	4.8	79.4	128.0	4.8	4194	1398	1.3
4.9	255	222	114	4.9	89.1	143.0	4.9	4704	1568	1.4
F 5.0	261	227	117	P 5.0	100	161.0	P 5.0	1.0 mi	1760	1.6
5.1	267	232	119	5.1	112	181.0	5.1	1.1	1971	1.8
5.2	272	236	122	5.2	126	203.0	5.2	1.3	2218	2.0
5.3	278	241	124	5.3	141	227.0	5.3	1.4	2482	2.3
5.4	284	246	127	5.4	159	255.0	5.4	1.6	2798	2.6
5.5	289	251	129	5.5	178	286.0	5.5	1.8	3133	2.9
5.6	295	256	132	5.6	200	321.0	5.6	2.0	3520	3.2
5.7	301	261	135	5.7	224	360.0	5.7	2.2	3942	3.6
5.8	307	267	137	5.8	251	404.0	5.8	2.5	4418	4.0
5.9	313	272	140	5.9	282	454.0	5.9	2.8	4963	4.5

a. Characteristics of a tornado can be expressed as a combination of Fujita-scale windspeed and Pearson-scale path length and width. This scale permits us to classify tornadoes between two extreme FPP scales: 0,0,0 and 5,5,5.

HNP-2-FSAR-2

TABLE 2.3-4
WINDSPEED DISTRIBUTION

<u>Windspeed Classification</u>	<u>No. of Tornadoes</u>	<u>Percent of Total</u>
F5 (windspeed > 260 mph)	2	0.12
F4 (207 to 260 mph)	34	2.1
F3 (158 to 206 mph)	115	7.2
F2 (113 to 157 mph)	430	26.6
F1 (73 to 112 mph)	710	44.0
F0 (40 to 72 mph)	321	19.9

TABLE 2.3-5
CUMULATIVE WINDSPEED DISTRIBUTION

<u>Windspeed Classification</u>	<u>No. of Tornadoes</u>	<u>Percent of Total</u>
F5 and above (windspeed > 260 mph)	2	0.12
F4 and above (> 206 mph)	36	2.2
F3 and above (> 157 mph)	151	9.3
F2 and above (> 112 mph)	581	36.0
F1 and above (> 74 mph)	1291	80.0
F0 and above (> 40 mph)	1612	100.0

HNP-2-FSAR-2

TABLE 2.3-7 (SHEET 1 OF 3)

METEOROLOGICAL INSTRUMENTATION AT THE PLANT SITE
(HNP-1 AND HNP-2)

<u>Primary Tower</u>		
<u>Height Above Tower Base (m)</u>	<u>Sensed Parameter</u>	<u>Instrument Characteristics</u>
100	Wind speed and direction	Climatronics, F460 sensor (speed), ± 0.07 m/s accuracy, 0.26 m/s threshold, 1.52 m/s distance constant, model 100075 transmitter, F460 sensor (direction), ± 2 degrees accuracy, 0.26 m/s threshold, 1.13 m/s distance constant, model 100076 transmitter with vane
	Wind direction variability	Climatronics, 101035 sigma theta computer, sampling rate 3600/h, resolution 1 part in 256
	Vertical temperature difference (100-10 m)	Climatronics, 100950-1 platinum dual ΔT translator, accuracy < ± 0.1°C, 100826 precision platinum 100-ohm 4-wire sensor
60	Wind speed and direction	(same as 100-m level)
	Wind direction variability	(same as 100-m level)
10	Wind speed and direction	(same as 100-m level)
	Wind direction variability	(same as 100-m level)
	Ambient temperature	Climatronics, 100826 platinum 100-ohm 4-wire, RTD temperature sensor, 100950 platinum temperature translator, accuracy < ± 0.1°C

HNP-2-FSAR-2

TABLE 2.3-7 (SHEET 2 OF 3)

Primary Tower

<u>Height Above Tower Base (m)</u>	<u>Sensed Parameter</u>	<u>Instrument Characteristics</u>
	Dew point	Climatronics, 100743, lithium chloride dew point sensor, $\pm 0.5^{\circ}\text{C}$ accuracy, 100089 lithium chloride dew point translator
Near tower base	Precipitation	Climatronics, 100097-1, tipping bucket gage with heater, accuracy $\pm 1\%$ up to 3 in./h, 1000 ws wind screen, 100747 precipitation integrator

HNP-2-FSAR-2

TABLE 2.3-7 (SHEET 3 OF 3)

Backup Tower

<u>Height Above Tower Base (m)</u>	<u>Sensed Parameter</u>	<u>Instrument Characteristics</u>
45	Vertical temperature difference (45-10 m)	Climatronics, 100950-1 platinum dual ΔT translator, accuracy $< \pm 0.1^\circ\text{C}$, 100826 precision platinum 100-ohm 4-wire sensors
	Wind speed and direction	Climatronics, F460 sensor (speed), ± 0.07 m/s accuracy, 0.26 m/s threshold, distance constant 1.52 m/s, 100075 transmitter, F460 sensor (direction), ± 2 degrees accuracy, 0.26 m/s threshold, distance constant 1.13 m/s, 100076 transmitter with vane
	Wind direction variability	Climatronics, 10135 computed sampling rate 3600/h, resolution 1 part in 256
10	Ambient temperature	Climatronics, 100950 platinum temperature translator, accuracy $< \pm 0.1^\circ\text{C}$, 100826 platinum sensor

HNP-2-FSAR-2

TABLE 2.3-9 (SHEET 1 OF 4)

JOINT FREQUENCY TABLES OF WINDSPEED AND DIRECTION
FOR 75-ft LEVEL

FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0
SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
TEMPERATURE DIFFERENCE BETWEEN 150 AND 33
ADJUSTED TO BE EQUIVALENT TO 150-33 FT BY MULTIPLYING BY A FACTOR OF .56
FROM 70060101 TO 72083124 , TEMP DIFF WAS MESURED BETWEEN 150-10 FT

WIND DIRECTION

SPEED (MPH)	N	NNF	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CALM+ 3.5	60	58	56	61	53	43	21	19	14	24	32	21	16	31	38	54	610	6.8
3.6- 7.5	221	176	227	335	346	184	109	81	94	141	191	185	227	281	319	216	3333	36.9
7.6- 12.5	108	121	220	263	290	231	152	99	114	186	227	254	322	398	340	148	3473	38.5
12.6- 18.5	17	21	43	45	48	57	64	43	42	165	108	101	158	260	172	46	1270	14.1
18.6- 24.5	7	8	13	11	4	7	25	21	12	24	8	14	39	59	16	7	275	3.0
24.6- 32.5	1	2	0	5	0	1	14	10	1	1	1	1	7	4	3	0	51	.6
32.6+	0	1	0	0	0	0	2	4	0	0	0	0	0	0	0	0	7	.1
TOTAL	414	387	569	720	742	523	387	277	277	481	567	576	770	973	899	473	9025	100.0
PERCENT	4.6	4.3	6.3	8.0	8.2	5.8	4.3	3.1	3.1	5.3	6.3	6.4	8.5	10.8	9.9	5.2	100.0	
AV SPD	6.6	7.2	7.8	7.6	7.6	8.4	10.7	10.8	9.4	9.9	9.1	9.4	10.3	10.3	9.2	7.6		
AVERAGE SPEED FOR THIS TABLE EQUALS 8.9																		
HOURS OF UNSTEADY WIND = 285																		

FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -.9

SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
TEMPERATURE DIFFERENCE BETWEEN 150 AND 33
ADJUSTED TO BE EQUIVALENT TO 150-33 FT BY MULTIPLYING BY A FACTOR OF .56
FROM 70060101 TO 72083124 , TEMP DIFF WAS MESURED BETWEEN 150-10 FT

WIND DIRECTION

SPEED (MPH)	N	NNE	NE	FNE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CALM+ 3.5	28	17	19	19	20	6	7	6	7	7	10	5	10	8	24	12	205	12.7
3.6- 7.5	33	40	46	61	76	43	28	25	27	33	53	45	50	38	40	22	660	41.0
7.6- 12.5	14	16	36	41	37	40	34	26	21	39	51	38	41	39	31	27	531	33.0
12.6- 18.5	1	4	10	6	6	14	11	10	12	11	15	18	19	13	15	7	171	10.6
18.6- 24.5	0	0	0	2	3	1	3	2	3	3	7	5	1	5	1	0	36	2.2
24.6- 32.5	0	0	2	0	0	1	0	0	0	0	0	0	0	0	1	0	4	.2
32.6+	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	1	.1
TOTAL	76	77	113	129	142	105	83	70	70	93	136	111	120	103	112	69	1608	100.0
PERCENT	4.7	4.8	7.0	8.0	8.8	6.5	5.2	4.4	4.4	5.8	8.5	6.9	7.5	6.4	7.0	4.2	100.0	
AV SPD	5.1	5.9	7.4	7.1	7.0	8.4	8.9	8.9	9.0	8.5	8.7	8.9	8.3	8.8	7.6	7.7		
AVERAGE SPEED FOR THIS TABLE EQUALS 7.9																		
HOURS OF UNSTEADY WIND = 53																		

HNP-2-FSAR-2

TABLE 2.3-9 (SHEET 2 OF 4)

FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -.9 BUT LESS THAN OR EQUAL TO -.8
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 33
 ADJUSTED TO BE EQUIVALENT TO 150-33 FT BY MULTIPLYING BY A FACTOR OF .56
 FROM 7006010101 TO 72083124, TEMP DIFF WAS MESURED BETWEEN 150-10 FT

WIND DIRECTION

SPEED (MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT
CALM	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	1	.1
CALM+ 3.5	17	13	11	14	10	7	9	1	7	10	12	5	8	10	6	13	153	12.4
3.6- 7.5	22	24	26	44	41	29	22	13	23	28	35	30	26	28	27	29	447	36.3
7.6- 12.5	28	19	26	25	32	31	17	13	23	33	42	32	41	30	74	18	443	36.0
12.6- 18.5	2	1	10	7	13	9	9	4	8	14	16	17	13	13	11	5	152	12.3
18.6- 24.5	0	0	1	1	0	2	1	0	1	6	5	2	4	3	4	0	70	2.4
24.6- 32.5	0	0	0	0	0	1	0	0	0	0	1	0	0	0	0	0	5	.4
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
TOTAL	69	56	74	91	96	79	58	31	62	91	111	87	92	87	82	65	1231	0.0
PERCENT	5.6	4.5	6.0	7.4	7.8	6.4	4.7	2.5	5.0	7.4	9.0	7.1	7.5	7.1	6.7	5.3	100.0	
AV SPD	6.4	6.2	7.9	7.1	7.8	8.5	8.0	8.3	8.0	8.8	9.0	9.0	9.3	9.6	9.2	6.9		
AVERAGE SPEED FOR THIS TABLE EQUALS	8.2																	
HOURS OF UNSTEADY WIND =	26																	

FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -.8 BUT LESS THAN OR EQUAL TO -.3
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 33
 ADJUSTED TO BE EQUIVALENT TO 150-33 FT BY MULTIPLYING BY A FACTOR OF .56
 FROM 7006010101 TO 72083124, TEMP DIFF WAS MESURED BETWEEN 150-10 FT

WIND DIRECTION

SPEED (MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT
CALM	8	5	5	6	5	11	7	2	5	4	3	4	2	3	7	3	80	1.0
CALM+ 3.5	89	73	86	91	119	80	67	55	48	53	62	64	59	50	56	53	1095	13.6
3.6- 7.5	155	180	214	286	322	222	199	151	186	255	294	179	173	196	145	136	3283	40.8
7.6- 12.5	94	94	154	256	165	169	147	61	108	242	301	182	146	161	134	136	2550	31.7
12.6- 18.5	15	19	41	60	49	55	42	26	52	79	103	49	49	83	78	41	841	10.5
18.6- 24.5	1	2	4	4	3	4	3	6	13	16	18	10	9	41	13	4	151	1.9
24.6- 32.5	0	0	0	0	0	0	0	0	2	1	2	8	11	13	3	3	43	.5
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
TOTAL	353	373	494	703	662	541	465	301	414	650	783	496	449	547	436	376	8043	0.0
PERCENT	4.4	4.6	6.1	8.7	8.2	6.7	5.8	3.7	5.1	8.1	9.7	6.2	5.6	6.8	5.4	4.7	100.0	
AV SPD	6.0	6.3	7.1	7.4	6.6	7.3	7.1	6.7	7.9	8.4	8.6	8.1	8.4	9.6	8.6	7.8		
AVERAGE SPEED FOR THIS TABLE EQUALS	7.7																	
HOURS OF UNSTEADY WIND =	88																	

HNP-2-FSAR-2

TABLE 2.3-9 (SHEET 3 OF 4)

FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .8
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 33
 ADJUSTED TO BE EQUIVALENT TO 150-33 FT BY MULTIPLYING BY A FACTOR OF .56
 FROM 70060101 TO 72083124 , TEMP DIFF WAS MESURED BETWEEN 150-10 FT

WIND DIRECTION

SPEED (MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT
CALM	5	10	3	8	8	7	3	4	3	6	4	3	2	8	4	3	81	1.0
CALM+ 3.5	78	77	99	92	110	112	85	83	70	70	73	74	61	63	70	58	1265	15.8
3.6- 7.5	117	128	219	295	323	312	334	290	319	410	335	217	222	205	156	122	4004	50.2
7.6- 12.5	37	36	61	63	80	139	172	124	207	285	322	172	140	107	117	90	2152	27.0
12.6- 18.5	1	6	3	20	9	12	26	13	35	61	64	32	41	57	41	20	441	5.5
18.6- 24.5	0	0	1	2	1	0	0	1	1	2	4	3	3	8	13	3	39	.5
24.6- 32.5	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	1	.0
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
TOTAL	298	257	376	480	531	582	620	515	635	834	802	501	469	449	401	293	7983	0.0
PERCENT	3.0	3.2	4.7	6.0	6.7	7.3	7.8	6.5	8.0	10.4	10.0	6.3	5.9	5.6	5.0	3.7	100.0	
AV SPD	4.8	5.3	5.3	5.6	5.3	5.9	6.5	6.2	7.0	7.4	7.6	7.0	7.2	7.7	7.6	6.6		
AVERAGE SPEED FOR THIS TABLE EQUALS 6.6																		
HOURS OF UNSTEADY WIND = 66																		

FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 2.2
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 33
 ADJUSTED TO BE EQUIVALENT TO 150-33 FT BY MULTIPLYING BY A FACTOR OF .56
 FROM 70060101 TO 72083124 , TEMP DIFF WAS MESURED BETWEEN 150-10 FT

WIND DIRECTION

SPEED (MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT
CALM	9	1	7	5	4	6	5	6	1	0	4	4	10	5	11	9	87	3.1
CALM+ 3.5	45	50	35	41	87	47	47	44	34	38	26	26	44	39	42	37	682	24.3
3.6- 7.5	52	51	69	90	106	130	123	103	116	142	144	109	116	94	72	53	1557	55.5
7.6- 12.5	4	4	11	9	8	18	24	23	55	67	83	52	36	32	21	5	452	16.1
12.6- 18.5	0	0	0	0	0	1	0	1	1	5	2	3	2	3	6	3	24	.9
18.6- 24.5	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	.0
24.6- 32.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
TOTAL	111	106	122	135	205	202	199	177	207	252	259	194	208	173	152	101	2803	0.0
PERCENT	4.0	3.8	4.4	4.8	7.3	7.2	7.1	6.3	7.4	9.0	9.2	6.9	7.4	6.2	5.4	3.6	100.0	
AV SPD	4.0	4.0	4.3	4.3	4.0	4.8	5.1	4.9	5.9	6.3	6.3	6.1	5.2	5.3	5.0	4.0		
AVERAGE SPEED FOR THIS TABLE EQUALS 5.1																		
HOURS OF UNSTEADY WIND = 27																		

HNP-2-FSAR-2

TABLE 2.3-9 (SHEET 4 OF 4)

FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 33
 ADJUSTED TO BE EQUIVALENT TO 150-33 FT BY MULTIPLYING BY A FACTOR OF .56
 FROM 70060101 TO 72083124 , TEMP DIFF WAS MESURED BETWEEN 150-10_FT

WIND DIRECTION

SPEED (MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT
CALM	5	2	10	4	6	2	4	1	7	6	3	5	3	6	8	7	79	3.3
CALM+ 3.5	56	46	40	30	42	42	34	37	27	43	46	43	60	49	72	53	713	29.5
3.6- 7.5	39	50	45	44	42	58	49	45	72	91	174	109	155	149	103	58	1287	53.3
7.6- 12.5	2	2	4	13	9	6	13	9	22	58	62	47	42	14	11	4	318	13.2
12.6- 18.5	0	0	2	0	0	0	0	1	2	1	1	0	0	5	5	1	18	.7
18.6- 24.5	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	1	.0
24.6- 32.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
32.6+	0	0	0	0	3	0	0	0	0	0	0	0	0	0	0	0	0	0.0
TOTAL	102	100	101	95	99	108	103	86	130	200	286	204	260	223	199	123	2416	0.0
PERCENT	4.2	4.1	4.2	3.9	4.1	4.5	4.1	3.6	5.4	8.3	11.8	8.4	10.8	9.2	8.2	5.1	100.0	
AV SPD	3.3	3.9	3.8	4.5	3.7	4.3	4.5	4.7	5.2	5.9	5.8	5.4	5.1	4.9	4.4	3.8		
AVERAGE SPEED FOR THIS TABLE EQUALS	4.8																	
HOURS OF UNSTEADY WIND =	24																	

HNP-2-FSAR-2

TABLE 2.3-10 (SHEET 1 OF 4)

JOINT FREQUENCY TABLES OF WINDSPEED AND DIRECTION
FOR 150-ft LEVEL

FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0																		
SITE HATCH																		
PERIOD OF RECORD FROM 70060101 TO 74083124																		
TEMPERATURE DIFFERENCE BETWEEN 150 AND 33																		
FROM 70060101 TO 72083124 ; TEMP DIFF WAS MESURED BETWEEN 150-10 FT AND																		
ADJUSTED TO BE EQUIVALENT TO 150-33 FT BY MULTIPLYING BY A FACTOR OF .56																		
WIND DIRECTION																		
SPEED (MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT
CALM	1	0	2	0	0	0	0	0	0	0	0	0	0	0	2	0	5	.1
3.6 - 7.5	59	48	49	40	38	32	27	11	12	14	11	15	24	20	30	40	470	5.2
7.6 - 12.5	174	169	206	228	202	157	97	61	57	105	138	148	162	206	260	187	2637	29.1
12.6 - 18.5	144	126	191	279	416	259	137	92	114	159	191	261	291	379	311	174	3524	38.9
18.6 - 24.5	40	23	50	59	115	81	71	48	54	110	123	163	199	238	229	114	1724	19.0
24.6 - 32.5	12	11	7	3	25	29	26	6	15	32	23	31	74	88	74	48	504	5.6
32.6+	8	7	2	1	6	30	13	1	2	4	6	4	23	32	19	6	164	1.8
TOTAL	439	385	515	610	883	605	373	219	254	424	492	622	774	968	931	570	9064	100.0
PERCENT	4.8	4.2	5.7	6.7	9.7	6.7	4.1	2.4	2.8	4.7	5.4	6.9	8.5	10.7	10.3	6.3	100.0	
AV SPD	8.2	8.0	8.0	8.2	9.3	11.3	10.8	9.9	10.4	10.9	10.4	10.7	11.6	11.8	11.1	10.1		
AVERAGE SPEED FOR THIS TABLE EQUALS 10.2																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 225																		
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -.9																		
SITE HATCH																		
PERIOD OF RECORD FROM 70060101 TO 74083124																		
TEMPERATURE DIFFERENCE BETWEEN 150 AND 33																		
FROM 70060101 TO 72083124 ; TEMP DIFF WAS MESURED BETWEEN 150-10 FT AND																		
ADJUSTED TO BE EQUIVALENT TO 150-33 FT BY MULTIPLYING BY A FACTOR OF .56																		
WIND DIRECTION																		
SPEED (MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT
CALM	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1	.1
3.6 - 7.5	15	16	13	9	16	13	10	7	5	7	8	7	8	8	18	17	177	10.7
7.6 - 12.5	32	32	40	35	48	46	28	16	21	31	27	36	33	30	41	21	517	31.2
12.6 - 18.5	39	18	24	46	60	45	38	26	25	32	48	44	43	32	28	24	563	34.0
18.6 - 24.5	7	5	12	15	22	12	11	20	11	20	26	32	30	24	28	15	290	17.5
24.6 - 32.5	4	2	2	3	4	3	11	3	9	5	6	5	8	11	7	5	88	5.3
32.6+	1	1	1	0	1	1	0	1	1	0	0	2	0	4	2	0	15	.9
TOTAL	89	74	92	109	151	122	98	73	72	95	115	126	122	113	124	82	1657	100.0
PERCENT	5.4	4.5	5.6	6.6	9.1	7.4	5.9	4.4	4.3	5.7	6.9	7.6	7.4	6.8	7.5	4.9	100.0	
AV SPD	8.2	7.1	7.8	8.8	8.7	8.7	9.6	10.2	10.5	9.6	9.8	10.4	10.1	12.0	9.4	8.8		
AVERAGE SPEED FOR THIS TABLE EQUALS 9.4																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 45																		

HNP-2-FSAR-2

TABLE 2.3-10 (SHEET 2 OF 4)

FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.9 BUT LESS THAN OR EQUAL TO -0.8

SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124

TEMPERATURE DIFFERENCE BETWEEN 150 AND 33
 FROM 70060101 TO 72083124, TEMP DIFF WAS MEASURED BETWEEN 150-10 FT AND
 ADJUSTED TO BE EQUIVALENT TO 150-33 FT BY MULTIPLYING BY A FACTOR OF .56

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT
CALM	0	0	0	1	0	0	0	0	1	0	0	0	0	0	0	0	2	.2
3.6 - 7.5	18	5	6	11	3	6	4	4	6	7	9	5	5	9	6	11	115	9.2
7.6 - 12.5	16	25	24	34	33	24	17	15	20	29	33	26	20	26	22	26	390	31.3
12.6 - 18.5	27	22	22	22	50	23	20	15	23	27	42	38	33	22	20	14	420	33.7
18.6 - 24.5	7	3	8	17	11	16	4	9	7	12	23	18	26	20	21	13	215	17.3
24.6 - 32.5	0	4	2	3	6	5	1	1	3	9	8	9	7	4	15	4	81	6.5
32.6+	0	0	0	0	1	0	0	0	0	0	0	0	3	2	4	1	18	1.4
TOTAL	68	59	62	88	105	78	47	44	60	84	117	96	95	84	89	69	1245	100.0
PERCENT	5.5	4.7	5.0	7.1	8.4	6.3	3.8	3.5	4.8	6.7	9.4	7.7	7.6	6.7	7.1	5.5	100.0	
AV SPD	7.3	8.6	8.1	8.5	9.9	10.5	8.7	9.0	8.7	9.9	10.2	10.6	11.4	10.3	12.6	8.7		

AVERAGE SPEED FOR THIS TABLE EQUALS 9.8
 HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 25

FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -0.8 BUT LESS THAN OR EQUAL TO -0.3

SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124

TEMPERATURE DIFFERENCE BETWEEN 150 AND 33
 FROM 70060101 TO 72083124, TEMP DIFF WAS MEASURED BETWEEN 150-10 FT AND
 ADJUSTED TO BE EQUIVALENT TO 150-33 FT BY MULTIPLYING BY A FACTOR OF .56

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT
CALM	4	0	1	1	1	1	0	0	1	1	2	1	1	1	3	0	18	.2
3.6 - 7.5	43	48	57	64	77	51	57	40	38	36	43	29	35	40	43	48	758	9.3
7.6 - 12.5	132	162	173	231	217	178	166	129	147	132	171	133	138	118	113	107	2447	30.3
12.6 - 18.5	113	98	176	254	258	193	152	126	135	266	315	267	178	154	169	121	2975	36.9
18.6 - 24.5	28	35	65	111	97	80	63	33	64	111	167	113	67	112	121	75	1342	16.6
24.6 - 32.5	13	3	10	9	30	25	14	16	24	36	34	20	25	43	57	18	377	4.7
32.6+	3	1	0	1	2	11	1	2	8	14	9	20	17	26	16	5	136	1.7
TOTAL	336	347	482	671	682	539	453	346	419	600	743	583	464	500	529	374	8068	100.0
PERCENT	4.2	4.3	6.0	8.3	8.5	6.7	5.6	4.3	5.2	7.4	9.2	7.2	5.8	6.2	6.6	4.6	100.0	
AV SPD	8.0	7.3	8.3	8.6	8.9	9.2	8.4	8.5	9.5	10.6	10.4	10.5	10.2	11.6	11.6	9.4		

AVERAGE SPEED FOR THIS TABLE EQUALS 9.6
 HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 103

HNP-2-FSAR-2

TABLE 2.3-10 (SHEET 3 OF 4)

FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .8
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 33
 FROM 70060101 TO 72083124, TEMP DIFF WAS MESURED BETWEEN 150-10 FT AND
 ADJUSTED TO BE EQUIVALENT TO 150-33 FT BY MULTIPLYING BY A FACTOR OF .56

WIND DIRECTION

SPEED (MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT
CALM	1	2	2	3	5	2	3	2	2	2	3	2	3	2	1	4	39	.5
CALM+ - 3.5	35	18	30	30	39	30	50	27	39	31	33	35	37	35	21	28	519	6.7
3.6 - 7.5	73	82	122	177	208	239	198	177	165	147	158	116	107	100	97	101	2265	29.3
7.6 - 12.5	66	91	157	197	220	264	266	234	325	348	378	251	292	207	170	111	3537	45.8
12.6 - 18.5	10	6	24	29	42	67	54	59	106	151	171	87	99	83	74	49	1111	14.4
18.6 - 24.5	3	1	1	6	17	18	7	13	19	21	25	13	15	30	20	5	214	2.8
24.6 - 32.5	0	0	0	0	4	2	0	0	2	5	0	0	7	4	0	0	36	.5
32.6+	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	2	.0
TOTAL	189	210	336	442	535	622	576	512	659	705	768	511	517	466	387	298	7723	100.0
PERCENT	2.4	2.6	4.4	5.7	6.9	8.1	7.5	6.6	8.5	9.1	9.9	6.6	6.7	6.0	5.0	3.9	100.0	
AV SPD	7.1	7.4	7.8	7.9	8.4	8.5	8.2	8.8	9.5	10.1	10.2	9.8	9.8	10.4	10.1	8.5		
AVERAGE SPEED FOR THIS TABLE EQUALS 9.1																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 40																		

FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 2.2
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 33
 FROM 70060101 TO 72083124, TEMP DIFF WAS MESURED BETWEEN 150-10 FT AND
 ADJUSTED TO BE EQUIVALENT TO 150-33 FT BY MULTIPLYING BY A FACTOR OF .56

WIND DIRECTION

SPEED (MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT
CALM	0	2	4	3	1	2	2	2	2	1	3	0	1	1	1	0	25	.9
CALM+ - 3.5	12	12	20	12	16	14	20	11	22	16	12	17	9	16	21	7	245	6.9
3.6 - 7.5	38	32	50	75	75	69	114	75	82	58	59	62	60	48	64	45	1006	36.7
7.6 - 12.5	25	36	44	56	87	77	73	64	96	106	120	102	111	91	56	32	1177	42.9
12.6 - 18.5	4	1	3	6	9	15	14	13	23	44	35	31	15	24	11	5	253	9.2
18.6 - 24.5	0	0	0	1	1	5	2	1	4	1	1	4	2	2	2	1	27	1.0
24.6 - 32.5	1	0	0	0	1	1	0	0	0	0	2	1	1	0	1	0	8	.3
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
TOTAL	81	83	121	153	190	183	233	166	229	226	232	217	199	182	156	90	2741	0.0
PERCENT	3.0	3.0	4.4	5.6	6.9	6.7	8.5	6.1	8.4	8.2	8.5	7.9	7.3	6.6	5.7	3.3	100.0	
AV SPD	7.0	6.6	6.5	7.1	7.6	8.2	7.0	7.5	8.2	9.1	9.1	8.9	8.8	8.8	7.4	7.2		
AVERAGE SPEED FOR THIS TABLE EQUALS 8.0																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 12																		

HNP-2-FSAR-2

TABLE 2.3-10 (SHEET 4 OF 4)

FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2																	REQUEST NUMBER	
SITE HATCH																		
PERIOD OF RECORD FROM 70060101 TO 74063124																		
TEMPERATURE DIFFERENCE BETWEEN 150 AND 33																		
FROM 70060101 TO 72083124, TEMP DIFF WAS MESURED BETWEEN 150-10 FT AND																		
ADJUSTED TO BE EQUIVALENT TO 150-33 FT BY MULTIPLYING BY A FACTOR OF .56																		
WIND DIRECTION																		
SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT
CALM	0	2	0	0	3	2	0	2	1	0	1	1	1	2	3	1	19	.8
3.6 - 7.5	18	15	14	10	18	9	12	24	13	17	22	17	25	21	21	15	271	11.0
7.6 - 12.5	76	44	46	78	61	58	69	39	50	48	80	76	111	81	77	76	1070	43.3
12.6 - 18.5	19	20	28	30	45	36	30	36	58	62	98	124	134	112	57	45	934	37.8
18.6 - 24.5	5	2	1	4	2	1	1	3	5	22	32	28	13	13	9	9	150	6.1
24.6 - 32.5	0	3	0	0	0	0	1	0	2	2	1	3	2	4	1	3	22	.9
32.6+	1	0	0	0	0	0	0	1	0	0	0	0	3	0	0	0	5	.2
TOTAL	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
PERCENT	119	86	89	122	129	106	113	105	129	151	234	249	289	233	168	149	2471	0.0
AV SPD	4.8	3.5	3.6	4.9	5.2	4.3	4.6	4.2	5.2	6.1	9.5	10.1	11.7	9.4	6.8	6.0	100.0	
AVERAGE SPEED FOR THIS TABLE EQUALS	6.3	6.3	6.2	6.5	6.3	6.4	6.3	6.5	7.6	8.5	8.3	8.5	8.0	7.8	6.9	7.1		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	4																	

HNP-2-FSAR-2

TABLE 2.3-11

**ATMOSPHERIC DISPERSION FACTORS FOR ACCIDENT EVALUATION
BASED ON 4 YEARS OF SITE DATA (6/70 - 9/74)**

Time Period (h)	Location of Release	5% Probable X/Q Values (s/m ³)			50% Probable X/Q Values (s/m ³)	
		Exclusion Area (1250 m)	Low-Population Distance (1250 m) ^(a)	Worst Condition ^(b)	Exclusion Area Site Boundary ^(a)	Low-Population Distance
0-1	Elevated for SLB (30 m)	2.8(-4) ^(c)	2.8(-4)	NA	3.7(-5)	3.7(-5)
0-1	Stack release (120 m)	2.5(-6)	2.5(-6)	NA	3.5(-7)	4.5(-7)
0-2	Stack release (120 m)	1.7(-6)	1.7(-6)	NA	4.0(-7)	4.0(-7)
2-8 ^(d)	Stack release (120 m)	NA	9.4(-7)	3.2(-6)	NA	3.4(-7)
8-24 ^(d)	Stack release (120 m)	NA	3.9(-7)	1.2(-6)	NA	1.5(-7)
24-96 ^(d)	Stack release (120 m)	NA	2.0(-7)	3.3(-7)	NA	1.0(-7)
96-720 ^(d)	Stack release (120 m)	NA	8.0(-8)	9.9(-8)	NA	5.5(-8)
0-1	Ground level in bldg wake	4.1(-4)	4.1(-4)	NA	3.7(-5)	3.7(-5)
0-2	Ground level in bldg wake	3.1(-4)	3.1(-4)	NA	3.1(-5)	3.1(-5)
2-8	Ground level in bldg wake	NA	1.7(-4)	4.3(-4)	NA	2.8(-5)
8-24	Ground level in bldg wake	NA	2.3(-5)	4.9(-5)	NA	8.5(-6)
24-96	Ground level in bldg wake	NA	1.1(-5)	1.7(-5)	NA	5.5(-6)
96-720	Ground level in bldg wake	NA	4.5(-6)	5.3(-6)	NA	3.2(-7)

a. Site boundary.

b. Highest average value calculated at low-population distance.

c. 2.8(-4) is 2.8×10^{-4} .

d. For 2-8, 8-24, 24-96, and 96-720 time periods, averaging periods of 8, 16, 72, and 624, respectively, were used.

TABLE 2.3-12
TEMPERATURE DIFFERENCE GROUPS FOR
DETERMINING PASQUILL STABILITY CATEGORIES

<u>Pasquill Category</u>	<u>AEC ΔT Model^(a) ($^{\circ}\text{F}/100 \text{ ft}$)</u>
A	$\Delta T < -1.0$
B	$-1.0 \leq \Delta T < -0.9$
C	$-0.9 \leq \Delta T < -0.8$
D	$-0.8 \leq \Delta T < -0.3$
E	$-0.3 \leq \Delta T < 0.8$
F	$0.8 \leq \Delta T < 2.2$
G	$2.2 \leq \Delta T$

a. In conversion from $^{\circ}\text{C}/100 \text{ m}$ (Regulatory Guide 1.23) to $^{\circ}\text{F}/100 \text{ ft}$, values were rounded to nearest tenth of a degree.

HNP-2-FSAR-2

TABLE 2.3-13 (SHEET 1 OF 4)

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0
 SITE HATCH
 PERIOD OF RECORD FROM 74060101 TO 74063124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

REQUEST NUMBER 604-23R2

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPD(MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNN	NW	NNW			
CALM	1	0	2	0	0	0	0	0	0	0	0	0	0	0	2	0	5	.1	0.30
CALM+ = 3.5	21	20	21	17	14	14	14	4	7	6	5	6	11	12	14	16	202	2.3	2.49
3.5 = 7.5	148	114	129	114	150	78	57	33	32	48	74	69	80	99	132	144	1521	17.4	5.47
7.5 = 12.5	136	148	202	308	381	229	119	73	77	134	165	190	222	266	276	155	3061	35.3	9.75
12.5 = 18.5	83	67	108	126	246	166	100	72	81	121	145	194	208	275	243	122	2359	27.0	14.91
18.5 = 24.5	23	12	31	23	46	33	41	23	31	66	63	92	127	141	148	80	560	11.2	20.92
24.5 = 32.5	10	7	3	3	24	33	25	7	10	30	16	24	64	74	63	41	434	5.0	27.46
32.5+	8	8	1	0	4	42	12	0	2	1	5	4	17	31	17	6	158	1.8	37.67
TOTAL	436	370	497	593	865	595	308	212	240	406	473	599	729	898	895	564	6745	100.0	9.53
PERCENT	4.9	4.3	5.7	6.8	9.9	6.8	3.5	2.4	2.7	4.6	5.4	6.9	8.3	10.3	10.2	6.5	100.0		
AV SPD	10.5	10.2	10.3	10.4	11.8	14.4	13.8	12.6	13.3	14.0	13.2	13.0	15.1	15.2	14.3	12.9			
AVERAGE SPEED FOR THIS TABLE EQUALS 13.1																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 210																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -.9
 SITE HATCH
 PERIOD OF RECORD FROM 74060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

REQUEST NUMBER 604-23P2

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPD(MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNN	NW	NNW			
CALM	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1	.1	0.30
CALM+ = 3.5	7	7	4	6	6	3	7	3	2	2	4	4	4	4	8	8	77	4.9	2.70
3.5 = 7.5	24	27	32	20	32	29	16	11	11	19	21	20	18	23	29	18	350	22.2	5.15
7.5 = 12.5	34	26	25	46	63	48	32	22	27	33	37	33	36	19	34	21	538	34.1	9.81
12.5 = 18.5	15	6	21	23	27	21	24	19	13	21	36	32	36	30	21	19	366	23.2	15.12
18.5 = 24.5	3	2	4	3	12	7	7	10	9	14	10	20	14	17	19	7	158	10.0	20.89
24.5 = 32.5	4	3	3	3	4	3	7	3	7	3	3	5	5	8	5	5	71	4.5	25.90
32.5+	1	0	0	1	1	2	0	1	1	0	0	1	0	8	2	0	18	1.1	38.17
TOTAL	88	73	89	104	145	114	93	69	70	92	109	118	113	109	118	76	1579	100.0	8.35
PERCENT	5.5	4.6	5.6	6.8	9.2	7.2	5.9	4.4	4.4	5.8	6.9	7.3	7.2	6.9	7.5	4.9	100.0		
AV SPD	10.4	9.1	10.1	11.2	11.2	11.1	12.3	13.2	13.4	12.3	12.4	13.3	13.1	15.4	12.3	11.5			
AVERAGE SPEED FOR THIS TABLE EQUALS 12.1																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 44																			

HNP-2-FSAR-2

TABLE 2.3-13 (SHEET 2 OF 4)

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE(DEG F/100FT) GREATER THAN -.9 BUT LESS THAN OR EQUAL TO .9 REQUEST NUMBER 604-23R2
 SITE MATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPD(MPH)	
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW				
CALM	0	0	0	1	0	0	0	0	1	0	0	0	0	0	0	0	0	2	.2	1.30
CALM+ - 3.5	11	1	3	6	1	3	2	3	4	3	3	1	3	6	1	6	57	4.9	2.35	
3.5 - 7.5	15	20	12	17	15	15	9	10	16	20	14	16	17	12	22	240	20.8	5.32		
7.5 - 12.5	22	18	22	24	45	20	17	13	22	28	29	21	21	17	25	17	371	32.2	9.77	
12.5 - 18.5	15	13	13	17	18	17	12	12	11	12	32	25	31	19	15	14	286	24.3	15.15	
18.5 - 24.5	4	3	4	7	6	2	4	7	11	16	11	8	9	15	6	119	10.3	20.99		
24.5 - 32.5	0	3	1	3	5	4	2	1	7	7	5	7	3	13	3	65	5.6	27.67		
32.5+	0	0	0	0	2	4	0	0	0	0	1	0	3	4	1	18	1.6	37.16		
TOTAL	67	58	35	79	93	75	44	42	56	77	108	81	89	74	55	69	1152	100.0	8.20	
PERCENT	5.8	5.0	4.8	6.9	8.1	6.5	3.8	3.6	4.9	6.7	9.4	7.0	7.7	6.4	7.4	6.0	100.0			
AV SPD	9.4	11.0	10.8	11.0	12.6	13.1	11.3	11.6	11.2	13.1	13.4	13.6	14.6	13.1	16.4	11.0				
AVERAGE SPEED FOR THIS TABLE EQUALS 12.6																				
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 25																				

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE(DEG F/100FT) GREATER THAN -.8 BUT LESS THAN OR EQUAL TO -.3 REQUEST NUMBER 604-23R2
 SITE MATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPD(MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW			
CALM	4	0	1	1	1	0	0	0	0	0	2	1	1	1	3	0	15	.2	1.30
CALM+ - 3.5	14	26	18	26	29	25	27	19	18	14	9	9	14	16	19	19	302	4.0	2.35
3.5 - 7.5	83	103	117	117	120	107	101	72	71	65	86	85	76	75	76	75	1234	16.5	5.42
7.5 - 12.5	108	165	144	225	222	165	129	105	125	143	191	129	119	111	114	96	2231	29.4	5.33
12.5 - 18.5	83	70	124	179	164	118	105	86	85	102	237	196	117	129	128	94	2110	27.8	14.54
18.5 - 24.5	17	26	49	74	63	49	46	22	46	78	107	68	42	70	89	53	897	11.6	21.00
24.5 - 32.5	14	4	10	13	27	25	15	20	27	36	38	23	29	47	58	22	403	5.4	27.70
32.5+	2	1	1	1	6	15	3	3	10	20	13	22	21	37	25	5	122	2.5	38.16
TOTAL	325	335	464	636	632	504	426	327	383	549	683	535	419	486	517	364	7585	100.0	8.71
PERCENT	4.3	4.6	6.1	8.4	8.3	6.6	5.6	4.3	5.0	7.2	9.0	7.1	5.5	6.4	6.8	4.8	100.0		
AV SPD	11.1	10.2	11.5	11.9	12.4	12.8	11.7	11.9	13.3	14.9	14.4	14.7	14.3	16.1	16.0	13.1			
AVERAGE SPEED FOR THIS TABLE EQUALS 13.3																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 95																			

HNP-2-FSAR-2

TABLE 2.3-13 (SHEET 3 OF 4)

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE(DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .8 REQUEST NUMBER 604-23R2
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GED MEAN SPD(MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW			
CALM	1	2	1	3	4	2	3	2	2	2	3	2	3	2	1	4	37	.5	.30
CALM+ = 3.5	10	6	8	9	9	8	13	5	12	12	6	12	10	8	8	146	2.0	2.25	
3.5 - 7.5	38	26	47	54	58	65	71	45	43	34	48	35	42	41	29	46	723	10.0	5.53
7.5 - 12.5	63	65	102	149	182	189	159	145	132	116	130	88	85	77	81	74	1837	25.3	9.57
12.5 - 18.5	54	60	134	167	191	217	188	175	245	260	281	193	183	158	130	88	2727	37.6	15.18
18.5 - 24.5	11	8	29	26	37	63	58	72	121	137	174	100	99	100	79	54	1158	16.1	20.91
24.5 - 32.5	3	3	6	15	20	35	26	18	34	59	73	24	41	30	38	13	441	6.1	27.44
32.5+	3	1	1	0	17	12	4	10	13	18	11	19	14	30	18	4	175	2.4	35.55
TOTAL	183	191	328	428	518	591	522	472	603	638	705	474	477	448	384	291	7254	100.0	9.56
PERCENT	2.5	2.6	4.5	5.9	7.1	8.1	7.2	6.5	8.3	8.8	9.7	6.5	6.2	5.3	4.0	100.0			
AV SPD	11.5	12.1	12.7	12.7	13.7	14.0	13.4	14.4	15.6	16.6	16.7	16.1	16.1	17.1	16.5	13.8			
AVERAGE SPEED FOR THIS TABLE EQUALS 14.9																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 35																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE(DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 2.2 REQUEST NUMBER 604-23R2
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GED MEAN SPD(MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW			
CALM	0	1	4	3	1	2	2	2	2	1	2	0	1	1	1	0	23	.9	.30
CALM+ = 3.5	4	5	5	4	4	4	7	4	6	8	6	5	3	5	3	2	77	2.9	2.20
3.5 - 7.5	18	12	22	26	27	19	39	18	32	18	16	25	18	18	29	14	351	11.2	5.51
7.5 - 12.5	32	25	43	58	66	61	100	64	68	49	52	47	52	41	56	36	681	32.0	9.63
12.5 - 18.5	17	33	35	49	74	65	58	53	65	76	90	68	78	76	47	29	934	35.2	14.53
18.5 - 24.5	6	2	7	8	9	12	14	13	36	55	47	31	37	28	11	4	320	12.0	20.65
24.5 - 32.5	2	1	0	2	5	7	5	3	6	11	3	10	3	11	4	2	75	2.8	26.55
32.5+	1	0	0	0	1	5	1	4	0	3	4	3	0	2	0	0	25	.9	36.88
TOTAL	80	79	117	151	187	175	226	158	221	218	219	210	195	180	153	87	2556	100.0	7.75
PERCENT	3.0	3.0	4.4	5.7	7.0	6.6	8.5	5.9	8.3	8.2	8.2	7.9	7.3	6.8	5.8	3.3	100.0		
AV SPD	11.5	11.0	10.7	11.5	12.4	13.3	11.4	12.1	13.3	14.8	14.7	14.5	14.4	14.3	12.1	11.7			
AVERAGE SPEED FOR THIS TABLE EQUALS 13.0																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 12																			

HNP-2-FSAR-2

TABLE 2.3-13 (SHEET 4 OF 4)

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74063124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

REQUEST NUMBER 604-23R2

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPD(MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW			
CALM	0	2	0	0	2	2	0	2	1	0	1	1	1	2	3	1	18	.7	.30
CALM+ = 3.5	7	5	0	4	6	4	4	5	5	5	8	3	5	9	7	2	86	3.5	2.32
3.6 - 7.5	29	23	28	19	27	17	25	30	19	21	36	34	43	31	33	30	445	18.1	5.56
7.6 - 12.5	60	37	27	64	49	46	56	30	41	39	58	61	93	65	62	65	553	31.7	9.76
12.6 - 18.5	16	11	24	24	41	30	28	31	40	52	60	102	116	104	49	38	798	32.5	14.85
18.6 - 24.5	3	5	4	5	3	4	1	3	9	19	47	40	24	13	6	7	103	7.5	20.70
24.6 - 32.5	3	3	0	0	0	0	0	1	2	12	3	4	2	6	7	3	45	1.9	27.61
32.6+	1	0	0	0	0	0	1	1	2	0	0	3	5	1	0	3	17	.7	37.71
TOTAL	119	86	89	121	128	103	113	103	129	148	233	248	269	231	167	149	2456	100.0	7.45
PERCENT	4.6	3.5	3.0	4.9	5.2	4.2	4.0	4.2	5.3	6.0	9.5	10.1	11.8	9.4	6.8	6.1	100.0		
AV SPD	10.1	10.2	10.1	10.6	10.3	10.5	10.2	10.4	12.3	13.7	13.4	13.8	12.9	12.7	11.2	11.5			
AVERAGE SPEED FOR THIS TABLE EQUALS										11.9									
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =										3									

HNP-2-FSAR-2

TABLE 2.3-14 (SHEET 1 OF 4)

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0

REQUEST NUMBER 604-24R2

SITE MATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPD(MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW			
CALM	0	0	0	0	1	0	0	1	0	0	0	0	1	0	1	2	6	.1	.30
CALM+ - 1.5	6	3	5	4	8	6	0	2	2	7	3	4	3	2	1	4	60	.7	1.12
1.6 - 2.5	33	40	39	36	28	19	12	9	8	11	15	14	7	11	21	24	327	3.7	2.07
2.6 - 3.5	75	61	54	70	55	46	19	16	20	23	39	20	33	52	54	64	704	7.9	2.99
3.6 - 7.5	226	126	308	431	457	250	149	114	123	193	270	259	329	401	444	239	4350	49.4	5.33
7.6 - 12.5	59	73	125	141	166	162	149	78	82	162	190	215	278	343	289	119	2652	29.8	9.34
12.6 - 18.5	10	16	24	23	10	24	35	35	29	56	37	43	92	126	65	15	644	7.2	14.50
18.6+	3	3	3	6	3	1	21	18	5	3	2	1	16	18	5	0	110	1.2	20.66
TOTAL	412	382	559	713	731	518	385	273	259	475	556	557	759	953	880	471	8893	100.0	5.47
PERCENT	4.6	4.3	6.3	8.0	8.2	5.8	4.3	3.1	3.0	5.3	6.3	6.3	8.5	10.7	9.9	5.3	100.0		
AV SPD	5.4	5.9	6.4	6.2	6.2	6.8	8.7	8.8	7.7	8.0	7.4	7.6	8.4	8.4	7.5	6.2			
AVERAGE SPEED FOR THIS TABLE EQUALS 7.2																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 280																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -.9

REQUEST NUMBER 604-24R2

SITE MATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPD(MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW			
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	3	1	0	2	1	0	1	1	0	1	1	0	0	1	1	3	16	1.0	1.10
1.6 - 2.5	16	12	10	10	8	5	6	4	5	5	9	2	7	5	16	6	125	8.0	2.03
2.6 - 3.5	16	17	16	15	20	7	3	4	9	5	9	14	11	6	17	3	172	10.9	2.95
3.6 - 7.5	36	34	54	71	83	57	35	35	30	49	66	50	57	45	47	27	775	49.4	5.24
7.6 - 12.5	4	12	30	27	22	22	29	17	14	28	34	34	34	33	22	25	387	24.6	9.25
12.6 - 18.5	1	1	0	2	4	5	7	5	10	4	15	5	9	10	8	1	87	5.5	14.41
18.6+	0	0	2	1	0	1	0	1	1	0	0	1	0	0	1	0	8	.5	21.31
TOTAL	76	77	112	128	138	97	61	67	69	92	134	106	118	100	112	65	1572	100.0	4.75
PERCENT	4.8	4.9	7.1	8.1	8.8	6.2	5.2	4.3	4.4	5.9	8.5	6.7	7.5	8.4	7.1	4.1	100.0		
AV SPD	4.2	4.8	6.1	5.8	5.7	6.9	7.3	7.3	7.3	7.0	7.1	7.2	6.8	7.3	6.2	6.4			
AVERAGE SPEED FOR THIS TABLE EQUALS 6.4																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 50																			

HNP-2-FSAR-2

TABLE 2.3-14 (SHEET 2 OF 4)

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE(DEG F/100FT) GREATER THAN -.9 BUT LESS THAN OR EQUAL TO -.8 REQUEST NUMBER 604-24R2
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPD(MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNN	NW	NNW			
CALM	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	1	.1	.30
CALM+ - 1.5	3	2	2	2	1	2	2	1	1	1	1	0	1	2	1	23	1.9	1.18	
1.6 - 2.5	7	7	2	5	6	4	3	0	5	7	7	2	4	5	3	8	75	6.3	2.01
2.6 - 3.5	10	9	9	14	7	3	7	3	4	7	8	10	9	7	8	8	123	10.4	2.94
3.6 - 7.5	38	26	31	41	53	39	25	14	30	43	49	35	33	35	34	29	555	47.0	5.29
7.6 - 12.5	10	10	24	20	21	26	18	9	15	21	30	27	33	19	26	15	324	27.4	9.32
12.6 - 18.5	0	0	2	1	2	1	3	2	4	10	9	8	9	9	7	3	70	5.9	14.44
18.6+	0	0	0	0	0	1	0	0	0	0	3	0	1	5	1	0	11	.9	20.54
TOTAL	68	54	70	83	90	76	58	29	59	89	107	84	89	81	81	64	1182	100.0	4.78
PERCENT	5.8	4.6	5.9	7.0	7.6	6.4	4.9	2.5	5.0	7.5	9.1	7.1	7.5	6.9	6.9	5.4	100.0		
AV SPD	5.3	5.1	5.6	5.9	6.2	6.7	6.6	6.9	6.6	7.2	7.4	7.2	7.6	8.0	7.5	5.7			
AVERAGE SPEED FOR THIS TABLE EQUALS 6.7																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 26																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE(DEG F/100FT) GREATER THAN -.8 BUT LESS THAN OR EQUAL TO -.3 REQUEST NUMBER 604-24R2
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPD(MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNN	NW	NNW			
CALM	6	5	4	3	4	8	6	2	4	4	3	4	2	3	7	3	68	.9	.30
CALM+ - 1.5	21	25	12	24	26	21	17	12	8	15	15	10	16	7	13	12	254	3.3	1.04
1.6 - 2.5	48	36	55	56	74	52	37	37	25	30	37	38	34	34	32	34	659	8.4	1.99
2.6 - 3.5	56	56	69	73	95	36	72	42	46	58	52	50	44	48	49	31	882	11.3	2.94
3.6 - 7.5	164	188	246	364	323	285	228	149	200	334	396	240	214	231	174	194	3930	50.3	5.06
7.6 - 12.5	47	51	87	156	103	107	64	37	84	147	213	114	95	144	122	85	1676	21.4	9.15
12.6 - 18.5	4	5	11	10	12	13	10	9	21	35	38	13	22	59	31	9	302	3.9	14.39
18.6+	0	0	0	0	0	0	0	0	1	1	2	8	12	13	3	3	43	.6	26.12
TOTAL	346	360	484	686	640	524	454	288	389	624	756	477	439	539	431	371	7814	100.0	3.75
PERCENT	4.4	4.7	6.2	8.8	8.2	6.7	5.8	3.7	5.0	8.0	9.7	6.1	5.6	6.9	5.5	4.7	100.0		
AV SPD	4.6	4.8	5.4	5.7	5.1	5.6	5.4	5.2	6.0	6.4	6.6	6.3	6.4	6.4	6.6	6.0			
AVERAGE SPEED FOR THIS TABLE EQUALS 5.9																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 79																			

HNP-2-FSAR-2

TABLE 2.3-14 (SHEET 3 OF 4)

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .8 REQUEST NUMBER 604-24R2
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED (MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPD (MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNN	NW	NNW			
CALM	5	9	3	8	4	6	3	4	3	5	4	3	2	8	4	3	74	1.0	.30
CALM+ - 1.5	32	32	45	33	40	32	25	34	14	21	23	29	21	24	36	30	471	6.1	.97
1.6 - 2.5	51	53	46	69	98	94	54	60	66	59	60	52	47	49	37	30	931	12.0	2.01
2.6 - 3.5	45	55	93	123	149	130	124	114	113	118	112	78	68	60	54	49	1453	19.2	2.97
3.6 - 7.5	95	96	175	205	207	283	324	262	349	509	484	276	259	226	194	141	4087	52.6	4.50
7.6 - 12.5	4	9	5	25	15	20	45	26	58	95	100	51	60	71	63	31	653	8.5	2.57
12.6 - 18.5	0	0	1	2	0	0	0	1	1	1	1	2	2	8	11	0	30	.4	13.82
18.5+	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	1	.0	18.84
TOTAL	232	254	372	467	513	555	544	501	606	808	784	491	459	447	399	284	7766	100.0	2.55
PERCENT	3.0	3.3	4.8	6.0	6.6	7.3	7.5	6.5	7.8	10.4	10.1	6.3	5.9	5.8	5.1	3.7	100.0		
AV SPD	3.2	3.3	3.6	3.7	3.5	3.9	4.3	4.1	4.7	4.9	5.1	4.7	4.8	5.1	5.0	4.4			
AVERAGE SPEED FOR THIS TABLE EQUALS 4.4																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 64																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 2.2 REQUEST NUMBER 604-24R2
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED (MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPD (MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNN	NW	NNW			
CALM	8	1	7	5	3	6	4	6	1	0	4	4	10	5	10	9	83	3.0	.30
CALM+ - 1.5	18	21	17	21	33	9	17	21	14	15	8	6	20	17	15	9	261	9.5	.95
1.6 - 2.5	31	31	23	27	59	43	34	28	27	27	24	22	32	26	30	30	434	18.0	1.57
2.6 - 3.5	24	24	33	35	54	80	52	49	43	39	47	43	48	50	36	23	626	24.7	2.58
3.6 - 7.5	28	28	41	46	51	58	82	65	118	154	167	106	95	65	47	26	1179	42.9	4.60
7.6 - 12.5	0	0	0	0	0	2	1	4	3	8	4	9	2	8	9	2	52	1.9	8.45
12.6 - 18.5	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	.0	13.33
18.5+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	.0	0.00
TOTAL	110	105	121	134	200	198	190	173	206	243	254	192	207	171	147	99	2750	0.0	2.13
PERCENT	4.0	3.8	4.4	4.9	7.3	7.2	6.9	6.3	7.5	8.8	9.2	7.0	7.5	6.2	5.3	3.6	100.0		
AV SPD	2.7	2.6	2.9	2.9	2.7	3.1	3.4	3.3	3.9	4.2	4.2	4.1	3.5	3.6	3.4	2.7			
AVERAGE SPEED FOR THIS TABLE EQUALS 3.4																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 27																			

HNP-2-FSAR-2

TABLE 2.3-14 (SHEET 4 OF 4)

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

REQUEST NUMBER 604-2482

SPEED (MPH)	WIND DIRECTION															TOTAL	PERCENT	GEO MEAN SPD (MPH)	
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW				NNW
CALM	5	2	10	4	5	2	4	1	7	6	3	5	3	6	8	7	78	3.2	3.0
CALM+ - 1.5	29	16	14	15	24	13	12	12	11	14	14	22	22	12	19	23	272	11.3	6.65
1.6 - 2.5	29	35	32	18	24	34	25	21	20	33	37	27	46	54	62	36	533	22.1	1.98
2.6 - 3.5	22	26	24	27	23	22	21	19	32	36	58	44	85	78	51	27	595	24.7	2.95
3.6 - 7.5	17	21	19	30	22	36	32	58	105	171	105	102	67	50	23	899	37.3	4.33	
7.6 - 12.5	0	0	2	1	0	0	0	1	2	4	3	1	2	5	7	2	30	1.2	6.61
12.6 - 18.5	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	1	0	14.53
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.00
TOTAL	102	100	101	95	98	107	98	86	130	199	266	204	260	222	157	123	2408	0.0	1.98
PERCENT	4.2	4.2	4.2	3.9	4.1	4.4	4.1	3.6	5.4	8.3	11.9	8.5	10.8	9.2	6.2	5.1	100.0		
AV SPD	2.2	2.6	2.5	3.0	2.5	2.9	3.0	3.1	3.4	3.9	3.9	3.6	3.4	3.2	2.9	2.5			
AVERAGE SPEED FOR THIS TABLE EQUALS 3.2																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 23																			

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 1 OF 48)

MONTH OF JANUARY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0

REQUEST NUMBER 60-43

SITE MATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	1	1	2	1	1	3	5	1	1	1	0	0	0	1	1	0	19	3.0	2.69
3.6 - 7.5	4	8	5	7	8	3	8	2	1	1	5	1	7	2	5	4	71	11.4	5.99
7.6 - 12.5	15	32	22	27	20	16	9	5	7	12	9	17	19	20	28	16	275	44.0	9.71
12.6 - 18.5	11	16	19	11	22	8	1	1	0	4	9	11	9	15	23	6	193	26.1	17.75
18.6 - 24.5	0	1	2	1	2	2	3	4	4	0	5	6	5	15	16	2	69	11.0	21.25
24.6 - 32.5	0	0	0	0	0	0	0	0	0	0	2	0	1	7	12	4	23	4.6	27.67
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	5.00
TOTAL	32	58	50	47	53	32	28	13	13	18	30	35	42	60	82	32	525	0.0	9.82
PERCENT	5.1	9.3	8.0	7.0	8.5	5.1	4.5	2.1	2.1	2.9	4.8	5.6	6.7	9.6	13.1	5.1	100.0		
AV SPD	10.8	12.5	11.3	10.3	11.8	10.5	9.8	13.4	13.0	10.3	14.2	13.4	12.3	15.8	16.0	13.3			
AVERAGE SPEED FOR THIS TABLE EQUALS 12.6																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 7																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -1.9

REQUEST NUMBER 60-43

SITE MATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	1	1	1	1	2	0	1	1	0	0	0	1	0	0	1	0	10	7.9	2.65
3.6 - 7.5	3	4	5	1	4	2	1	0	3	0	0	0	3	1	2	2	31	24.4	4.66
7.6 - 12.5	5	4	3	1	5	2	4	0	2	1	2	5	2	5	5	2	49	38.6	9.69
12.6 - 18.5	0	1	0	0	0	1	0	0	1	4	4	3	5	1	3	2	26	20.5	15.00
18.6 - 24.5	0	0	1	0	0	0	0	1	0	0	3	2	1	1	2	0	11	8.7	19.29
24.6 - 32.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	9	10	10	3	12	5	6	2	6	5	9	11	12	8	13	6	127	0.0	7.32
PERCENT	7.1	7.9	7.9	2.4	9.4	3.9	4.7	1.6	4.7	3.9	7.1	8.7	9.4	6.3	10.2	4.7	100.0		
AV SPD	6.9	7.7	7.3	5.8	7.1	8.9	7.5	12.3	8.5	14.8	16.8	12.8	12.5	10.8	11.2	10.8			
AVERAGE SPEED FOR THIS TABLE EQUALS 10.2																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 3																			

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 2 OF 48)

MONTH OF JANUARY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE(DEG F/100FT) GREATER THAN -.9 BUT LESS THAN OR EQUAL TO -.8 REQUEST NUMBER 604-43

SITE MATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	1	0	1	1	0	1	1	0	0	2	0	0	0	0	1	0	8	8.3	2.32
3.5 - 7.5	1	6	2	2	2	2	2	2	0	1	1	0	0	0	0	2	22	24.2	5.34
7.5 - 12.5	1	3	2	1	5	2	0	2	1	0	3	2	1	2	2	4	31	34.1	9.49
12.5 - 18.5	1	2	0	1	1	1	1	1	0	2	3	2	1	1	2	21	23.1	15.17	
18.5 - 24.5	0	0	1	0	0	0	0	0	0	1	2	0	0	1	0	0	5	5.5	23.29
24.5 - 32.5	0	0	0	0	0	0	0	0	0	0	1	0	0	1	0	0	3	3.3	26.58
32.5+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	1	1.1	33.84
TOTAL	4	11	6	5	8	6	2	5	1	6	10	4	2	6	7	8	91	100.0	7.22
PERCENT	4.4	12.1	6.6	5.5	8.8	6.6	2.2	5.5	1.1	6.6	11.0	4.4	2.2	6.6	7.7	8.8	100.0		
AV SPD	8.0	8.4	8.6	7.9	9.3	7.7	7.1	8.3	10.6	10.6	15.1	12.8	12.3	15.1	16.7	9.4			
AVERAGE SPEED FOR THIS TABLE EQUALS 10.8																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 4																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE(DEG F/100FT) GREATER THAN -.8 BUT LESS THAN OR EQUAL TO -.3 REQUEST NUMBER 604-43

SITE MATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	5	2	1	7	5	5	4	0	2	4	0	1	2	4	5	5	52	6.3	2.41
3.5 - 7.5	14	11	16	15	14	11	15	11	8	6	11	11	7	4	9	8	171	20.7	5.21
7.5 - 12.5	15	10	8	11	23	12	16	9	22	21	21	9	14	13	26	23	253	36.7	9.77
12.5 - 18.5	21	6	12	17	11	3	4	4	15	19	26	17	11	19	26	19	230	27.9	14.75
18.5 - 24.5	4	1	4	2	0	1	0	0	5	12	12	5	4	2	10	14	76	9.2	23.50
24.5 - 32.5	0	0	0	0	1	0	0	0	2	9	4	0	1	2	13	3	35	4.2	27.25
32.5+	0	0	0	0	0	0	0	0	0	1	2	0	0	3	2	0	4	1.0	34.54
TOTAL	59	30	41	52	54	32	39	24	54	72	76	43	39	47	91	72	825	100.0	8.16
PERCENT	7.2	3.6	5.0	6.3	6.5	3.9	4.7	2.9	6.5	8.7	9.2	5.2	4.7	5.7	11.0	8.7	100.0		
AV SPD	10.8	9.0	10.1	9.6	9.5	8.0	7.7	8.2	11.9	14.9	14.2	11.9	11.3	14.3	15.0	13.4			
AVERAGE SPEED FOR THIS TABLE EQUALS 11.9																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 9																			

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 3 OF 48)

MONTH OF JANUARY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE(DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .8

SITE MATCH
PERIOD OF RECORD FROM 7000101 TO 74003124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	DIR MEAN		
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	1	.1	1.51
CALM+ - 3.5	1	0	2	2	2	1	2	0	0	1	3	2	1	1	0	2	17	2.3	2.43		
3.5 - 7.5	2	3	5	3	5	8	6	2	4	1	5	5	5	2	5	6	67	9.1	5.59		
7.5 - 12.5	4	7	2	11	14	10	4	12	8	10	20	9	4	10	7	7	145	19.8	10.02		
12.5 - 18.5	3	6	5	10	12	15	12	11	23	33	35	18	20	22	13	20	256	35.6	15.46		
18.5 - 24.5	1	0	0	2	1	5	0	5	16	39	24	9	5	8	18	7	140	19.1	21.01		
24.5 - 32.5	0	0	0	0	0	0	0	0	8	19	34	4	3	11	2	34	11.4	27.11			
32.5+	0	0	0	0	0	0	0	0	8	19	34	4	3	11	2	34	11.4	27.11			
TOTAL	11	16	14	28	34	45	24	30	56	107	121	47	41	57	65	37	734	100.0	11.47		
PERCENT	1.5	2.2	1.9	3.8	4.6	6.1	3.3	4.1	7.6	14.6	16.5	6.4	5.5	7.8	9.0	5.0	100.0				
AV SPD	11.0	11.2	9.6	12.0	11.3	12.1	11.0	13.2	17.7	19.8	19.3	14.7	16.3	16.6	19.4	14.8					
AVERAGE SPEED FOR THIS TABLE EQUALS	13.2																				
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	5																				

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE(DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 2.2

SITE MATCH
PERIOD OF RECORD FROM 7000101 TO 74003124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	DIR MEAN
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CALM+ - 3.5	0	0	0	1	0	0	0	0	0	2	0	1	0	0	0	0	4	1.5	2.62
3.5 - 7.5	2	1	1	0	2	4	3	4	2	2	0	4	0	2	0	3	31	14.2	5.14
7.5 - 12.5	4	3	4	0	2	6	16	7	9	5	8	3	7	5	8	5	93	32.6	15.14
12.5 - 18.5	0	2	2	3	3	7	3	5	11	7	15	9	5	10	9	0	90	32.6	15.12
18.5 - 24.5	0	0	0	0	0	0	0	0	0	2	3	2	4	1	0	0	34	9.0	11.41
24.5 - 32.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2.2	28.00
32.5+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	5	6	7	13	10	17	22	16	24	26	25	23	14	29	23	5	253	0.0	10.29
PERCENT	2.2	2.2	2.6	4.9	3.7	5.3	3.2	5.0	9.0	10.4	9.3	8.6	6.7	9.3	8.5	1.9	100.0		
AV SPD	5.5	10.3	11.4	12.7	9.9	10.5	11.3	10.8	13.4	16.2	14.6	14.6	12.4	13.6	10.9	9.8			
AVERAGE SPEED FOR THIS TABLE EQUALS	13.6																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	5																		

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 4 OF 48)

MONTH OF JANUARY																			
JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2															REQUEST NUMBER 604-43				
SITE MATCH																			
PERIOD OF RECORD FROM 70066101 TO 74083124																			
SPEED AND DIRECTION FROM 150 LEVEL																			
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35																			
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT																			
WIND DIRECTION																			
SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	1	0	1	0	1	0	0	0	0	1	0	0	2	2	0	0	6	3.5	1.93
3.6 - 7.5	2	2	0	0	3	2	4	1	1	0	3	4	3	2	7	8	42	18.5	5.87
7.6 - 12.5	2	3	4	3	9	5	6	5	4	3	5	2	10	8	10	8	84	37.9	9.77
12.6 - 17.5	3	3	3	7	4	2	3	0	4	1	10	8	5	3	5	10	72	31.7	15.02
18.6 - 24.5	0	1	0	0	0	0	0	1	2	0	5	5	1	0	0	1	16	7.0	20.32
24.6 - 32.5	0	0	0	0	0	0	0	0	0	3	0	0	0	0	0	3	3	1.3	26.40
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	8	9	8	10	16	9	13	7	11	8	23	19	22	15	22	27	227	0.0	8.80
PERCENT	3.5	4.0	3.5	4.4	7.0	4.0	5.7	3.1	4.8	3.5	10.1	8.4	9.7	5.5	9.7	11.9	100.0		
AV SPD	10.3	11.8	10.1	13.5	10.1	10.0	11.2	11.2	13.8	15.5	14.4	14.4	10.7	9.2	9.9	10.7			
AVERAGE SPEED FOR THIS TABLE EQUALS	11.6																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	0																		

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 5 OF 48)

MONTH OF FEBRUARY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0

REQUEST NUMBER 604-43

SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+ - 3.5	0	2	2	1	0	0	1	1	0	0	0	0	0	3	1	2	13	1.8	2.35
3.6 - 7.5	8	8	11	9	7	8	3	0	1	2	3	5	3	5	6	4	33	11.6	5.26
7.6 - 12.5	17	11	17	34	35	19	6	3	2	3	9	6	14	17	15	19	227	31.6	9.90
12.6 - 18.5	14	3	10	6	12	2	5	7	2	3	9	27	23	29	40	24	215	30.1	15.10
18.6 - 24.5	3	1	2	2	0	0	1	5	2	6	8	9	10	21	38	24	132	18.4	20.98
24.6 - 32.5	0	0	0	1	0	0	0	0	0	2	0	6	7	4	15	3	38	5.3	27.00
32.6+	0	0	0	0	0	0	0	0	0	0	1	1	1	2	4	0	9	1.3	37.33
TOTAL	42	25	42	53	54	29	16	16	7	16	30	54	58	81	119	76	718	100.0	10.20
PERCENT	5.8	3.5	5.8	7.4	7.5	4.0	2.2	2.2	1.0	2.2	4.2	7.5	8.1	11.3	16.6	10.6	100.0		
AV SPD	11.7	8.3	10.1	10.2	10.3	8.8	10.9	14.9	14.0	16.1	15.1	16.7	16.5	16.2	18.5	15.6			
AVERAGE SPEED FOR THIS TABLE EQUALS	14.3																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	15																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -.9

REQUEST NUMBER 604-43

SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+ - 3.5	1	0	0	2	1	0	0	0	0	0	0	0	0	0	0	0	4	2.7	3.11
3.6 - 7.5	3	0	3	1	3	1	0	0	0	2	1	2	1	0	1	1	18	13.0	4.92
7.6 - 12.5	6	2	0	4	3	4	1	1	5	2	2	3	0	0	3	1	37	25.3	10.23
12.6 - 18.5	5	0	1	4	1	1	0	1	1	4	2	5	4	2	4	6	43	29.5	15.14
18.6 - 24.5	1	0	0	0	0	0	1	3	6	3	1	4	3	2	5	3	32	21.9	21.13
24.6 - 32.5	0	0	0	0	0	0	0	0	0	1	1	1	0	1	2	2	9	6.2	26.29
32.6+	0	0	0	0	0	0	0	0	0	0	0	1	0	0	1	0	2	1.4	35.15
TOTAL	15	2	4	11	9	6	2	5	13	12	7	16	8	5	16	15	146	100.0	10.82
PERCENT	11.0	1.4	2.7	7.5	5.5	4.1	1.4	3.4	8.9	8.2	4.8	11.0	5.5	3.4	11.0	10.3	100.0		
AV SPD	11.1	8.8	6.9	10.6	7.8	9.8	17.4	17.4	17.3	15.4	15.2	16.4	16.7	19.8	18.4	17.0			
AVERAGE SPEED FOR THIS TABLE EQUALS	14.7																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	6																		

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 6 OF 48)

MONTH OF FEBRUARY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -.9 BUT LESS THAN OR EQUAL TO -.8 REQUEST NUMBER 604-43

SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	1	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	2	2.5	3.11
3.6 - 7.5	0	2	2	0	0	0	0	0	0	0	0	0	0	1	0	0	5	6.3	5.23
7.6 - 12.5	0	1	1	2	2	1	0	1	1	3	2	1	1	2	2	0	20	25.0	10.39
12.6 - 19.5	1	0	1	2	0	1	0	3	1	1	2	4	0	2	3	5	26	32.5	19.62
19.6 - 24.5	0	0	0	1	0	0	0	1	3	1	0	0	1	4	2	1	14	17.5	23.71
24.6 - 32.5	0	0	0	0	0	0	0	0	1	2	1	1	2	0	1	1	9	11.2	26.23
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	3	0	1	0	4	5.0	39.24
TOTAL	2	3	4	5	2	2	0	5	6	7	6	6	7	9	9	7	80	100.0	12.70
PERCENT	2.5	3.7	5.0	6.3	2.5	2.5	0.0	6.3	7.5	8.7	7.5	7.5	8.7	11.2	11.2	8.7	100.0		
AV SPD	8.0	7.9	9.7	13.2	10.5	12.8	0.0	15.6	19.3	17.4	14.4	15.2	29.5	15.0	20.2	17.7			

AVERAGE SPEED FOR THIS TABLE EQUALS 15.8
 HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 1

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -.8 BUT LESS THAN OR EQUAL TO -.3 REQUEST NUMBER 604-43

SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	0	2	1	2	2	1	1	1	0	1	0	0	0	1	1	1	14	2.0	2.50
3.6 - 7.5	6	7	6	11	12	4	7	1	4	2	2	3	3	4	3	4	73	11.1	5.45
7.6 - 12.5	9	4	19	26	15	13	10	11	8	10	12	18	8	5	9	7	165	26.1	19.20
12.6 - 19.5	5	12	15	37	15	7	5	4	10	21	29	22	10	16	21	11	241	34.0	14.92
19.6 - 24.5	0	5	5	12	5	0	1	0	8	9	12	3	5	16	17	1	69	14.0	21.20
24.6 - 32.5	0	0	0	0	0	0	0	1	7	8	3	3	4	20	10	1	57	8.5	27.51
32.6+	0	0	0	0	0	0	0	0	0	1	0	0	9	10	5	0	34	4.8	38.70
TOTAL	20	30	46	88	51	25	24	18	37	52	58	58	39	72	66	25	709	100.0	11.47
PERCENT	2.8	4.2	6.5	12.4	7.2	3.5	3.4	2.5	5.2	7.3	8.2	8.2	5.5	10.2	9.3	3.5	100.0		
AV SPD	9.3	12.2	12.1	13.0	11.6	10.5	9.9	11.4	16.8	16.8	15.8	18.4	21.8	22.0	19.5	12.2			

AVERAGE SPEED FOR THIS TABLE EQUALS 15.6
 HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 7

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 7 OF 48)

MONTH OF FEBRUARY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION REQUEST NUMBER 604-43
 FOR TEMPERATURE DIFFERENCE(DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .8
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	1	.2	4.30
CALM+ - 3.5	0	1	1	0	0	0	1	0	0	2	0	1	1	0	0	0	7	1.2	2.32
3.5 - 7.5	2	2	3	5	4	3	3	2	3	1	3	2	0	1	0	3	37	6.5	5.43
7.5 - 12.5	5	5	4	6	13	13	8	9	2	4	8	5	3	4	5	7	101	18.0	10.11
12.5 - 18.5	8	11	14	8	11	17	8	14	11	17	25	18	14	19	30	5	239	41.4	15.37
18.5 - 24.5	1	2	4	2	1	2	6	11	13	7	24	9	9	15	11	5	122	21.8	21.04
24.5 - 32.5	0	0	0	0	0	0	1	2	8	4	2	5	5	9	6	0	42	7.5	27.55
32.5+	0	0	0	0	0	0	0	0	2	1	0	0	0	8	6	0	18	3.2	37.35
TOTAL	14	21	31	21	29	35	27	38	39	36	62	41	32	56	58	20	566	100.0	12.16
PERCENT	2.5	3.7	5.5	3.7	5.2	6.3	4.8	6.8	7.0	6.4	11.1	7.3	5.7	10.0	10.4	3.6	100.0		
AV SPD	12.8	13.0	13.3	12.2	11.5	12.6	14.6	16.0	19.9	16.9	17.2	17.8	18.3	22.1	19.6	12.7			
AVERAGE SPEED FOR THIS TABLE EQUALS 16.6																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 4																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION REQUEST NUMBER 604-43
 FOR TEMPERATURE DIFFERENCE(DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 2.2
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.35
CALM+ - 3.5	0	0	1	0	0	0	1	0	0	0	0	1	1	1	0	0	5	2.7	2.21
3.5 - 7.5	0	1	0	0	0	0	3	1	1	3	0	0	2	4	2	1	18	9.6	4.94
7.5 - 12.5	4	3	2	3	5	4	10	5	4	5	1	2	2	2	5	1	59	31.4	9.33
12.5 - 18.5	0	0	1	1	4	10	8	5	4	8	5	9	9	10	9	3	80	45.7	14.81
18.5 - 24.5	0	0	0	0	0	1	2	1	1	1	7	3	1	1	1	0	19	10.1	20.42
24.5 - 32.5	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	1	.5	24.77
32.5+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	4	4	4	4	9	15	24	12	10	18	13	15	15	18	18	5	185	0.0	10.99
PERCENT	2.1	2.1	2.1	2.1	4.8	8.0	12.8	6.4	5.3	9.6	5.9	8.0	8.0	9.6	9.5	2.7	100.0		
AV SPD	9.8	8.8	9.4	9.8	12.3	13.4	11.4	12.3	12.7	12.9	18.2	15.6	13.1	11.9	12.4	11.6			
AVERAGE SPEED FOR THIS TABLE EQUALS 12.8																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 0																			

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 8 OF 48)

MONTH OF FEBRUARY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2

REQUEST NUMBER 60-43

SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0	0	2	.9	.33
CALM+ - 3.5	1	0	0	0	0	0	0	1	1	1	0	1	0	2	0	1	8	3.5	2.65
3.6 - 7.5	3	2	2	0	2	4	0	3	4	1	1	2	2	6	4	4	40	17.6	5.65
7.6 - 12.5	14	2	0	7	3	4	0	0	0	2	0	4	3	4	11	13	77	33.9	9.92
12.6 - 18.5	0	0	0	0	7	5	2	7	2	1	5	12	14	12	7	4	79	34.8	15.07
18.6 - 24.5	0	0	0	0	0	0	0	1	1	1	9	5	2	0	1	0	25	8.8	21.44
24.6 - 32.5	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	1	.4	25.74
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.03
TOTAL	19	4	2	7	12	14	7	12	8	6	16	24	26	26	23	22	227	0.0	7.39
PERCENT	7.9	1.8	.9	3.1	5.3	6.2	3.1	5.3	3.5	2.6	7.0	10.6	11.5	11.5	10.1	9.7	100.0		
AV SPD	8.8	8.0	5.9	9.1	12.3	11.2	11.7	11.9	10.2	10.3	19.3	15.0	13.7	10.3	11.3	9.5			

AVERAGE SPEED FOR THIS TABLE EQUALS 11.9
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 0

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 9 OF 48)

MONTH OF MARCH

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.3

REQUEST NUMBER 604-43

SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)	
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	2	1	1	0	1	1	0	1	1	2	0	0	2	0	0	1	13	1.5	2.41	
3.5 - 7.5	5	8	3	11	11	7	3	8	2	1	3	6	4	7	13	8	101	11.5	5.46	
7.5 - 12.5	7	10	13	21	51	21	19	11	10	9	16	21	16	15	29	10	279	31.7	9.81	
12.5 - 18.5	6	2	2	12	33	18	10	10	17	19	12	23	40	16	23	11	254	28.9	15.02	
18.5 - 24.5	0	0	0	0	1	0	3	3	13	15	1	5	30	26	13	6	116	13.2	21.25	
24.5 - 32.5	0	0	0	0	0	0	0	1	6	9	0	2	17	36	9	2	82	9.3	27.24	
32.5+	0	0	0	0	0	0	0	0	0	0	0	1	12	21	1	0	35	4.0	35.46	
TOTAL	21	21	19	44	97	47	35	34	49	55	32	58	121	121	88	38	880	100.0	11.19	
PERCENT	2.4	2.4	2.2	5.0	11.0	5.3	4.0	3.9	5.6	6.3	3.6	6.6	13.7	13.7	10.0	4.3	100.0			
AV SPD	9.3	8.7	9.5	10.5	11.4	11.2	11.7	11.7	16.4	17.5	11.8	13.6	19.5	22.5	14.3	13.2				

AVERAGE SPEED FOR THIS TABLE EQUALS 15.1
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 27

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -1.9

REQUEST NUMBER 604-43

SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	0	1	0	0	0	0	0	0	0	0	0	0	0	0	1	0	2	1.3	2.43
3.5 - 7.5	1	3	2	3	5	4	1	1	0	2	1	0	3	1	3	2	33	25.8	5.01
7.5 - 12.5	4	2	5	13	7	5	5	1	2	1	1	4	7	0	0	0	57	35.8	10.08
12.5 - 18.5	0	1	1	2	3	2	2	2	2	1	4	3	9	4	2	4	42	26.4	15.29
18.5 - 24.5	0	0	1	0	1	0	0	2	2	1	0	2	1	2	3	4	19	11.9	20.64
24.5 - 32.5	0	0	0	0	0	0	0	0	2	0	0	0	0	1	0	0	3	1.9	25.53
32.5+	0	0	0	0	0	0	0	0	1	0	0	0	0	1	1	0	3	1.9	33.32
TOTAL	5	7	9	18	17	11	8	6	9	5	6	9	29	9	10	10	159	100.0	9.40
PERCENT	3.1	4.4	5.7	11.3	10.7	6.9	5.0	3.8	5.7	3.1	3.8	5.7	12.6	5.7	6.3	6.3	100.0		
AV SPD	9.2	7.5	10.4	9.8	10.0	9.4	10.7	14.8	19.5	11.1	12.9	14.5	12.8	18.4	14.4	16.0			

AVERAGE SPEED FOR THIS TABLE EQUALS 12.5
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 5

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 10 OF 48)

MONTH OF MARCH

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -0.9 BUT LESS THAN OR EQUAL TO -0.8 REQUEST NUMBER 604-43

SITE MATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GED MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+	3.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
3.0 - 7.5	3	4	1	1	2	0	2	1	0	2	0	2	2	1	0	0	0	21	15.7
7.5 - 12.5	1	3	0	2	4	3	6	5	3	4	4	2	1	0	0	2	40	29.9	
12.6 - 18.5	4	0	0	2	1	4	1	0	3	0	11	2	12	5	1	1	47	35.1	
18.6 - 24.5	1	0	0	0	1	0	1	0	2	2	3	2	2	0	3	1	18	13.4	
24.6 - 32.5	0	0	0	1	0	0	0	0	0	2	0	0	3	0	1	0	7	5.2	
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	1	.7	
TOTAL	9	7	1	6	8	7	10	6	8	10	18	8	20	7	5	4	134	100.0	
PERCENT	6.7	5.2	.7	4.5	6.0	5.2	7.5	4.5	6.0	7.5	13.4	6.0	14.9	5.2	3.7	3.0	100.0		
AV SPD	11.6	7.3	6.2	13.4	10.8	13.0	10.6	9.0	15.3	15.7	14.8	13.6	17.3	16.8	22.3	14.9			
AVERAGE SPEED FOR THIS TABLE EQUALS 14.0																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 2																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -0.8 BUT LESS THAN OR EQUAL TO -0.3 REQUEST NUMBER 604-43

SITE MATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GED MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+	3.5	1	2	0	0	3	2	2	1	0	1	1	2	2	2	0	0	19	2.8
3.0 - 7.5	6	6	3	8	5	12	5	7	7	8	4	4	5	2	6	4	96	14.0	
7.5 - 12.5	14	6	8	11	16	15	19	12	8	10	15	10	8	9	6	7	174	25.4	
12.6 - 18.5	15	7	8	10	6	5	12	14	15	19	19	21	21	10	14	11	207	30.3	
18.6 - 24.5	4	2	8	7	4	5	7	2	6	13	15	18	5	8	8	11	121	17.7	
24.6 - 32.5	0	0	1	0	0	4	0	0	2	2	6	2	7	10	3	2	39	5.7	
32.6+	0	0	0	0	0	1	0	0	2	4	0	1	3	16	1	0	28	4.1	
TOTAL	40	23	23	34	35	44	45	36	40	57	60	58	54	57	38	35	684	100.0	
PERCENT	5.8	3.4	4.1	5.0	5.1	6.4	6.6	5.3	5.8	8.3	8.8	8.5	7.9	8.3	5.6	5.1	100.0		
AV SPD	11.8	10.9	14.9	11.7	10.8	12.5	12.0	11.5	15.1	16.0	15.7	16.1	16.6	23.8	16.2	15.6			
AVERAGE SPEED FOR THIS TABLE EQUALS 14.9																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 15																			

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 11 OF 48)

MONTH OF MARCH

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .8

REQUEST NUMBER 604-43

SITE MATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)	
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	
CALM+ - 3.5	0	0	0	3	1	0	0	0	1	2	0	0	0	0	0	0	0	7	1.1	2.21
3.6 - 7.5	2	0	4	2	2	4	2	3	2	4	1	1	3	1	3	2	36	5.7	5.50	
7.6 - 12.5	1	2	2	5	7	11	7	8	10	4	13	7	4	4	7	5	97	15.5	10.26	
12.6 - 18.5	6	2	0	4	17	12	11	19	41	24	24	28	14	14	15	13	259	41.3	15.36	
18.6 - 24.5	1	0	1	0	0	0	3	10	13	24	28	14	15	19	13	15	161	25.7	20.92	
24.6 - 32.5	0	0	0	2	0	0	0	3	4	4	5	2	10	9	10	4	53	8.5	27.12	
32.6+	0	0	0	0	0	0	0	1	1	2	1	0	2	6	1	0	14	2.2	36.82	
TOTAL	12	4	7	16	27	32	23	44	72	64	72	52	51	53	49	39	827	100.0	13.62	
PERCENT	1.9	.6	1.1	2.6	4.3	5.1	3.7	7.0	11.5	10.2	11.5	8.3	9.7	8.5	7.8	6.2	100.0			
AV SPD	1.8	1.2	1.8	1.9	13.4	13.1	13.8	16.2	16.5	17.7	17.6	16.6	18.7	22.0	18.1	17.7				

AVERAGE SPEED FOR THIS TABLE EQUALS 17.0
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 3

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 2.2

REQUEST NUMBER 634-43

SITE MATCH

PERIOD OF RECORD FROM 70050101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	0	1	1	1	0	0	0	0	1	0	1	0	0	1	0	0	6	2.5	2.31
3.6 - 7.5	1	0	1	2	3	1	3	2	0	0	3	3	0	1	1	1	22	9.1	5.44
7.6 - 12.5	1	0	2	3	6	3	3	5	1	3	3	4	5	6	5	2	53	21.9	10.07
12.6 - 18.5	1	1	2	3	3	8	1	4	7	14	15	10	5	9	3	3	90	37.2	15.19
18.6 - 24.5	0	0	0	0	0	0	0	2	12	16	9	7	3	12	0	0	67	27.7	20.36
24.6 - 32.5	0	0	0	0	0	0	0	0	1	0	1	2	0	0	0	0	4	1.7	26.76
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	3	2	6	9	12	12	7	13	22	33	32	26	21	29	9	6	242	0.0	11.38
PERCENT	1.2	.8	2.5	3.7	5.0	5.0	2.9	5.4	9.1	13.6	13.2	10.7	8.7	12.0	3.7	2.5	100.0		
AV SPD	9.3	8.4	9.9	10.3	9.1	13.1	3.0	12.2	17.9	17.3	15.4	15.8	16.3	16.2	12.2	11.7			

AVERAGE SPEED FOR THIS TABLE EQUALS 14.7
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 3

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 12 OF 48)

MONTH OF MARCH

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION																	REQUEST NUMBER 604-43		
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2																			
SITE HATCH																			
PERIOD OF RECORD FROM 70060101 TO 74083124																			
SPEED AND DIRECTION FROM 150 LEVEL																			
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35																			
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT																			
WIND DIRECTION																			
SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	1	0	0	1	0	0	0	0	0	0	0	0	0	0	0	1	.4	.31
CALM+ - 3.5	0	0	1	0	0	1	1	2	1	1	1	0	0	0	2	0	10	4.4	2.58
3.6 - 7.5	2	0	1	0	4	1	6	4	3	3	5	3	5	1	3	0	42	18.6	6.44
7.6 - 12.5	2	2	1	4	3	5	6	4	1	1	2	6	1	7	3	9	71	31.4	9.95
12.6 - 18.5	0	0	0	2	3	2	1	3	8	4	10	6	9	14	3	5	70	31.0	15.00
18.6 - 24.5	0	0	0	0	1	1	0	1	1	5	11	2	5	4	0	0	31	13.7	23.29
24.6 - 32.5	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	1	.4	25.57
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	4	3	3	6	11	10	14	14	14	15	29	17	35	26	11	14	226	0.0	7.99
PERCENT	1.8	1.3	1.3	2.7	4.9	4.4	5.2	6.2	6.2	6.6	12.8	7.5	15.5	11.5	4.9	6.2	100.0		
AV SPD	8.1	8.4	8.7	10.5	10.4	10.0	7.9	9.5	11.9	14.7	15.1	12.0	12.4	15.0	9.0	11.5			
AVERAGE SPEED FOR THIS TABLE EQUALS 12.0																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 1																			

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 13 OF 48)

MONTH OF APRIL

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.9 BUT LESS THAN OR EQUAL TO -1.8 REQUEST NUMBER 604-43

SITE MATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	1	0	0	0	0	1	0	0	0	0	0	0	0	2	2.0	0.33
CALM+ - 3.5	0	1	0	2	0	0	0	1	1	0	0	0	0	0	0	0	5	5.1	2.15
3.6 - 7.5	0	2	0	3	1	0	0	1	1	1	1	1	1	1	1	2	14	14.1	4.27
7.6 - 12.5	1	1	0	4	5	3	0	1	0	3	1	1	2	3	2	3	27	27.3	9.75
12.6 - 15.5	0	0	0	0	0	0	2	1	3	2	5	6	9	1	0	0	30	30.3	15.13
15.6 - 24.5	1	0	0	0	1	1	0	0	0	0	4	5	3	1	2	0	17	17.2	21.12
24.6 - 32.5	0	0	0	0	0	0	0	0	0	1	1	1	1	0	0	0	4	4.0	22.00
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	1	4	0	10	7	5	3	3	6	7	12	13	15	6	5	2	99	100.0	5.64
PERCENT	1.0	4.0	0.0	10.1	7.1	5.1	3.0	3.0	6.1	7.1	12.1	13.1	15.2	6.1	5.1	2.0	100.0		
AV SPD	7.8	5.3	0.0	5.6	11.0	11.2	15.0	9.3	8.1	13.7	16.5	18.9	16.9	12.4	13.9	4.3			
AVERAGE SPEED FOR THIS TABLE EQUALS <u>13.0</u>																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = <u>1</u>																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.8 BUT LESS THAN OR EQUAL TO -1.3 REQUEST NUMBER 604-43

SITE MATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	1	0	0	0	0	0	0	0	0	1	0	0	0	2	2.4	0.33
CALM+ - 3.5	3	1	1	1	0	1	1	2	1	0	0	0	1	0	0	1	13	12.3	2.12
3.6 - 7.5	1	4	5	3	5	4	6	3	4	9	7	5	3	3	3	2	67	12.0	5.63
7.6 - 12.5	10	7	6	7	17	12	7	9	9	19	9	13	10	9	5	5	157	28.0	10.20
12.6 - 15.5	10	5	2	5	11	13	12	10	8	19	21	35	17	18	10	3	200	35.7	15.22
15.6 - 24.5	1	3	2	6	3	7	6	1	5	6	16	14	7	12	8	1	92	16.4	20.30
24.6 - 32.5	0	0	0	4	3	0	0	0	0	4	6	1	1	1	2	0	22	3.6	24.12
32.6+	0	0	0	1	0	0	0	0	1	0	3	1	1	0	0	0	7	1.2	25.30
TOTAL	25	20	16	31	39	40	26	25	26	57	62	69	41	43	28	12	560	100.0	9.50
PERCENT	4.5	3.6	2.9	5.5	7.0	7.1	4.6	4.5	4.6	10.2	11.1	12.3	7.3	7.7	5.0	2.1	100.0		
AV SPD	11.1	11.8	10.2	15.7	13.1	13.2	11.3	11.4	12.9	13.9	17.6	15.8	14.7	15.7	16.0	10.5			
AVERAGE SPEED FOR THIS TABLE EQUALS <u>14.2</u>																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = <u>7</u>																			

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 14 OF 48)

MONTH OF APRIL

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .8 REQUEST NUMBER 604-43
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	1	0	0	1	0	1	0	0	0	3	.5	.23
CALM+ - 3.5	0	0	1	1	0	0	1	1	0	1	0	0	1	1	2	0	9	1.7	1.70
3.6 - 7.5	2	0	3	0	3	4	4	1	1	0	1	1	2	1	0	3	26	4.9	5.58
7.6 - 12.5	3	3	3	9	14	2	7	12	8	6	7	7	9	6	3	6	105	19.3	12.37
12.6 - 18.5	5	1	5	14	12	13	20	17	19	20	38	21	19	9	9	8	230	43.3	15.14
18.6 - 24.5	0	0	0	2	0	0	6	2	1	14	35	25	10	9	4	1	122	23.0	22.85
24.6 - 32.5	0	0	0	0	0	0	1	0	2	5	12	6	5	0	0	1	33	6.2	25.42
32.6+	0	0	0	0	0	0	0	0	0	0	0	3	0	0	0	3	3	.6	35.66
TOTAL	10	4	12	26	23	19	39	34	44	46	94	63	43	26	18	19	531	100.0	10.13
PERCENT	1.9	.8	2.3	4.9	5.2	3.6	7.3	6.4	8.3	8.7	17.7	11.9	9.0	4.9	3.4	3.6	100.0		
AV SPD	12.0	11.6	10.6	12.6	12.0	12.3	13.9	12.8	16.7	17.4	18.5	19.1	16.3	15.3	14.6	13.2			
AVERAGE SPEED FOR THIS TABLE EQUALS	15.7																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	1																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 2.2 REQUEST NUMBER 604-43
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	3	1	0	1	0	0	0	0	0	0	0	0	0	0	5	2.3	.30
CALM+ - 3.5	0	0	0	0	0	0	1	0	1	1	1	1	1	0	0	0	6	2.8	1.90
3.6 - 7.5	0	0	0	2	2	0	1	0	4	1	1	4	0	0	1	1	17	7.9	5.57
7.6 - 12.5	3	1	1	4	5	4	8	11	6	4	3	4	3	4	2	2	66	30.5	13.63
12.6 - 18.5	2	2	1	3	3	3	7	7	2	7	11	7	8	11	2	1	77	35.6	15.83
18.6 - 24.5	1	0	1	1	0	0	0	3	0	8	5	3	9	4	0	0	41	19.5	20.75
24.6 - 32.5	0	0	0	0	0	0	0	0	0	0	1	2	0	1	0	4	1.9	26.32	
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	3.30
TOTAL	6	3	6	11	11	8	17	21	19	21	22	21	21	20	5	4	216	0.0	5.89
PERCENT	2.8	1.4	2.8	5.1	5.1	3.7	7.9	9.7	8.8	9.7	10.2	9.7	9.7	9.3	2.3	1.9	100.0		
AV SPD	13.4	14.6	7.5	10.8	11.2	11.8	11.6	13.1	12.8	15.8	15.6	13.3	16.4	15.1	10.4	9.2			
AVERAGE SPEED FOR THIS TABLE EQUALS	13.5																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	1																		

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 15 OF 48)

MONTH OF APRIL																			
JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION																	REQUEST NUMBER 634-43		
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2																			
SITE MATCH																			
PERIOD OF RECORD FROM 70060101 TO 74083124																			
SPEED AND DIRECTION FROM 150 LEVEL																			
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35																			
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT																			
WIND DIRECTION																			
SPEED (MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSH	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD (MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.90
CALM+ - 3.5	0	0	0	0	0	0	0	0	0	0	3	0	0	0	1	1	5	2.6	2.47
3.6 - 7.5	1	3	4	0	0	1	2	1	1	1	3	2	5	2	2	3	31	16.4	5.46
7.6 - 12.5	2	2	1	2	0	1	2	4	5	4	2	4	7	5	2	1	44	23.3	9.53
12.6 - 18.5	0	0	3	0	3	3	4	4	3	5	7	15	25	9	1	1	83	43.9	15.21
18.6 - 24.5	0	0	0	0	0	0	0	0	2	3	7	10	3	0	0	0	25	13.2	20.42
24.6 - 32.5	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	1	.5	2.77
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	3	5	8	2	3	5	8	9	11	13	22	32	40	16	6	6	189	9.0	9.92
PERCENT	1.6	2.6	4.2	1.1	1.6	2.6	4.2	4.8	5.8	6.9	11.6	16.9	21.2	8.5	3.2	3.2	100.0		
AV SPD	7.8	8.4	10.2	9.3	10.5	12.7	13.6	11.9	12.4	14.3	13.5	15.2	13.3	11.6	9.2	8.1			
AVERAGE SPEED FOR THIS TABLE EQUALS	12.9																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	0																		

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 16 OF 48)

MONTH OF MAY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0

REQUEST NUMBER 604-43

SITE HATCH
PERIOD OF RECORD FROM 70660101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT, ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	1	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	2	.2	0.33
CALM+ - 3.5	0	1	2	0	0	0	1	0	2	0	0	0	0	0	0	0	6	.7	2.59
3.5 - 7.5	10	8	7	5	11	3	3	8	3	3	9	7	11	19	18	13	138	15.0	5.75
7.5 - 12.5	20	16	19	12	15	17	10	13	13	10	20	26	31	41	54	21	338	36.6	9.22
12.5 - 18.5	8	8	3	3	5	11	12	15	20	31	29	36	33	47	39	9	310	33.6	14.22
18.5 - 24.5	0	0	3	0	3	3	4	8	7	17	10	19	14	7	9	4	108	11.7	20.59
24.5 - 32.5	0	0	0	0	0	0	0	0	2	10	2	0	3	2	1	0	20	2.2	26.57
32.5+	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	.1	38.93
TOTAL	39	33	35	20	35	34	30	44	47	71	70	88	83	116	121	47	923	100.0	9.81
PERCENT	4.2	3.6	3.8	2.2	3.1	3.7	3.3	4.8	5.1	7.7	7.6	9.5	10.1	12.6	13.1	5.1	100.0		
AV SPD	6.8	9.2	9.4	9.5	10.8	12.6	13.0	12.5	14.2	17.1	13.4	14.4	14.0	12.3	11.9	10.5			

AVERAGE SPEED FOR THIS TABLE EQUALS 12.7
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 31

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100 FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -1.9

REQUEST NUMBER 604-43

SITE HATCH
PERIOD OF RECORD FROM 70660101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT, ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	3	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.33
CALM+ - 3.5	1	0	0	0	0	2	2	1	1	0	1	0	0	0	0	0	8	5.6	2.32
3.5 - 7.5	5	3	0	0	1	2	3	2	2	1	4	3	2	3	5	1	37	25.7	5.32
7.5 - 12.5	2	2	1	1	2	1	2	5	6	4	7	2	7	2	4	2	53	34.7	10.01
12.5 - 18.5	1	0	3	0	1	1	2	3	4	5	9	3	1	0	2	1	36	25.0	14.71
18.5 - 24.5	0	0	0	0	1	0	0	1	1	0	0	5	2	0	1	0	11	7.6	20.22
24.5 - 32.5	0	0	0	0	0	0	0	0	0	0	0	2	0	0	0	0	2	1.4	31.23
32.5+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	9	5	4	1	5	6	9	12	14	10	21	15	12	5	12	4	144	0.0	7.89
PERCENT	6.3	3.5	2.8	.7	3.5	4.2	5.3	8.3	9.7	6.9	14.6	10.4	8.3	3.5	8.3	2.8	100.0		
AV SPD	7.0	7.4	12.4	11.8	12.8	6.5	7.6	11.3	10.8	12.7	11.5	16.4	11.4	6.6	9.4	9.4			

AVERAGE SPEED FOR THIS TABLE EQUALS 10.8
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 7

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 17 OF 48)

MONTH OF MAY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE(10EG F/100FT) GREATER THAN -.9 BUT LESS THAN OR EQUAL TO -.8

REQUEST NUMBER 604-43

SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOMEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+ - 3.5	1	0	0	1	0	0	0	1	1	0	1	0	0	0	0	0	2	7	6.6
3.6 - 7.5	1	0	0	0	1	2	0	1	0	2	4	2	1	1	2	2	19	17.9	5.44
7.6 - 12.5	2	0	4	1	5	2	3	0	3	2	3	2	0	4	6	4	41	34.7	9.33
12.6 - 18.5	2	1	1	1	3	1	1	0	0	5	4	4	2	2	0	0	27	25.5	14.43
18.6 - 24.5	0	0	1	0	0	0	0	2	0	1	1	0	0	0	0	1	6	5.7	23.39
24.6 - 32.5	0	0	0	0	0	0	0	0	0	1	0	3	0	0	1	0	5	4.7	27.03
32.6+	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	1	.9	32.57
TOTAL	6	1	6	3	9	5	4	4	4	11	14	11	3	7	9	9	106	100.0	8.44
PERCENT	5.7	.9	5.7	2.8	8.5	4.7	3.8	3.8	3.8	10.4	13.2	10.4	2.8	6.6	8.5	8.5	100.0		
AV SPD	8.3	14.8	12.8	8.8	12.3	8.9	11.8	12.7	8.0	14.3	11.6	15.9	11.2	10.6	10.9	8.4			
AVERAGE SPEED FOR THIS TABLE EQUALS	11.6																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	5																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE(10EG F/100FT) GREATER THAN -.8 BUT LESS THAN OR EQUAL TO -.3

REQUEST NUMBER 604-43

SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOMEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+ - 3.5	0	2	1	0	4	1	1	2	1	0	1	1	1	1	1	1	13	2.9	2.37
3.6 - 7.5	12	9	0	5	7	12	5	8	4	1	6	8	7	7	10	8	115	13.2	5.21
7.6 - 12.5	15	13	11	11	19	23	4	4	14	7	14	12	10	18	7	8	189	30.9	9.39
12.6 - 18.5	6	9	8	14	15	11	14	14	5	15	19	21	13	10	6	11	191	31.3	15.02
18.6 - 24.5	2	7	1	4	3	5	10	5	5	5	5	6	5	3	3	2	71	11.6	20.76
24.6 - 32.5	0	2	5	2	0	0	1	1	4	2	1	2	1	0	2	0	23	3.8	27.35
32.6+	0	0	1	0	0	0	0	0	0	1	2	0	0	0	0	0	4	.7	35.45
TOTAL	35	42	33	36	47	52	35	34	33	31	48	50	37	39	29	30	611	100.0	9.32
PERCENT	5.7	6.9	5.4	5.9	7.7	8.5	5.7	5.6	5.4	5.1	7.9	8.2	6.1	6.4	4.7	4.9	100.0		
AV SPD	9.3	12.6	14.0	14.1	11.3	10.9	14.5	12.8	13.9	16.1	14.0	13.5	12.3	11.3	11.4	10.8			
AVERAGE SPEED FOR THIS TABLE EQUALS	12.7																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	14																		

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 18 OF 48)

MONTH OF MAY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .8

REQUEST NUMBER 604-43

SITE HATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	.2	3.32
CALM+ - 3.5	0	0	0	0	0	1	0	1	1	1	0	0	1	1	0	0	7	1.1	2.66
3.6 - 7.5	4	1	5	2	5	9	2	2	4	0	2	7	0	8	1	6	53	9.7	5.23
7.6 - 12.5	9	3	7	4	9	13	11	17	12	9	18	6	12	12	6	13	166	27.2	9.96
12.6 - 13.5	9	10	0	5	6	22	13	19	36	40	30	16	15	5	13	9	243	40.6	15.11
13.6 - 24.5	1	3	0	1	1	5	12	16	26	5	15	8	3	4	7	4	111	18.2	20.73
24.6 - 32.5	0	2	0	0	0	0	1	1	3	4	1	0	1	0	1	0	14	2.3	27.34
32.6+	0	1	1	0	0	0	0	0	0	1	0	1	0	1	0	0	5	.8	34.31
TOTAL	23	20	13	12	22	50	39	56	82	60	66	39	32	31	29	38	611	100.0	10.87
PERCENT	3.8	3.3	2.1	2.0	3.6	8.2	6.4	9.2	13.4	9.8	10.8	6.2	5.2	5.1	4.7	6.2	100.0		
AV SPD	11.9	17.3	10.2	11.7	10.6	12.7	15.1	15.2	16.3	16.0	15.5	14.0	13.8	11.4	14.9	11.5			
AVERAGE SPEED FOR THIS TABLE EQUALS 14.2																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 5																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .9 BUT LESS THAN OR EQUAL TO 2.2

REQUEST NUMBER 604-43

SITE HATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	1	0	0	0	0	1	0	0	0	0	0	0	0	2	1.0	3.35
CALM+ - 3.5	2	0	0	0	1	1	0	0	2	1	1	0	1	0	0	0	9	4.6	2.22
3.6 - 7.5	3	1	4	0	1	0	4	1	0	4	3	3	2	2	3	1	32	16.2	5.85
7.6 - 12.5	4	1	1	0	2	4	5	4	8	5	4	4	1	4	5	7	62	31.5	9.90
12.6 - 18.5	5	3	4	2	3	1	6	4	6	7	8	6	5	4	5	70	35.5	14.70	
18.6 - 24.5	1	1	0	0	0	0	0	1	5	3	7	0	0	1	1	0	20	10.2	20.72
24.6 - 32.5	0	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	2	1.0	24.92
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	30.00
TOTAL	15	6	9	3	7	6	10	12	20	20	23	15	10	12	15	13	197	0.0	6.69
PERCENT	7.6	3.0	4.6	1.5	3.5	3.0	5.1	6.1	10.2	10.2	11.7	7.6	5.1	5.1	8.1	6.6	100.0		
AV SPD	10.0	13.8	9.9	12.3	5.5	9.9	9.2	12.3	12.4	12.6	15.3	11.6	11.9	12.3	10.8	11.7			
AVERAGE SPEED FOR THIS TABLE EQUALS 11.9																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 2																			

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 19 OF 48)

MONTH OF MAY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 7.2
SITE MATCH

REQUEST NUMBER 615-43

PERIOD OF RECORD FROM 70060101 TO 74093124
SPEED AND DIRECTION FROM 100 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	SEC MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	0	2	1.2	.33
CALM+ - 3.5	1	1	1	1	0	1	0	0	0	0	1	1	1	0	2	0	13	5.9	2.34
3.5 - 7.5	1	2	0	1	1	0	0	6	2	2	3	1	3	7	2	1	32	13.7	5.55
7.5 - 12.5	9	4	1	0	2	2	4	1	4	2	5	4	6	7	9	5	64	27.4	10.00
12.5 - 15.5	2	1	0	1	0	3	1	1	6	3	7	4	8	2	2	2	43	18.7	14.93
15.5 - 24.5	0	0	0	0	0	1	0	0	0	0	9	2	0	0	0	0	12	7.0	21.57
24.5 - 32.5	0	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	3	1.2	24.92
32.5+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	5	2.0	37.00
TOTAL	12	8	2	3	3	7	5	8	12	8	27	12	18	22	15	8	171	6.0	6.32
PERCENT	7.0	4.7	1.2	1.5	1.8	4.1	2.9	4.7	7.0	4.7	15.8	7.0	10.5	12.9	9.4	4.7	100.0		
AV SPD	9.4	4.8	6.1	7.2	8.5	13.0	10.7	7.5	12.0	12.5	14.7	12.4	11.2	11.0	8.7	10.0			
AVERAGE SPEED FOR THIS TABLE EQUALS	11.1																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	1																		

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 20 OF 48)

MONTH OF JUNE

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0

REQUEST NUMBER 604-43

SITE MATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	2	1	4	1	1	1	0	0	1	1	0	1	1	1	1	0	16	2.0	2.53
3.6 - 7.5	25	21	24	24	17	15	11	2	3	4	5	9	12	11	22	23	225	27.8	5.59
7.6 - 12.5	19	19	18	23	42	26	19	10	9	11	15	21	31	36	39	26	364	45.0	9.59
12.6 - 18.5	1	4	9	17	13	25	9	8	5	5	19	10	19	11	6	168	20.8	14.69	
18.6 - 24.5	0	0	1	0	3	5	3	1	1	0	3	4	4	2	1	0	28	3.5	23.37
24.6 - 32.5	0	0	0	0	0	3	0	0	0	0	0	1	3	3	1	5	8	1.0	27.57
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	47	45	55	65	52	72	43	21	18	17	29	54	61	72	75	52	809	0.0	8.28
PERCENT	5.8	5.6	6.9	8.0	10.1	9.9	5.3	2.6	2.2	2.1	3.6	6.7	7.5	8.9	9.3	6.4	100.0		
AV SPD	7.3	8.0	8.4	9.3	10.7	11.7	10.1	11.6	11.2	8.7	11.1	12.4	11.4	11.7	9.4	8.7			
AVERAGE SPEED FOR THIS TABLE EQUALS	10.1																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	17																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -.9

REQUEST NUMBER 604-43

SITE MATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	1	1	1	1	1	0	1	0	0	0	0	0	2	1	0	1	10	6.6	2.54
3.6 - 7.5	2	2	4	2	5	4	4	1	2	1	3	3	2	2	2	5	44	23.9	5.05
7.6 - 12.5	2	4	1	2	10	5	4	1	1	2	3	4	4	2	2	2	49	32.2	9.45
12.6 - 18.5	2	0	0	0	2	2	4	6	0	1	0	7	4	3	0	0	31	20.4	14.73
18.6 - 24.5	0	0	0	0	2	0	0	0	0	0	2	3	3	3	1	0	14	9.2	21.74
24.6 - 32.5	0	0	0	0	0	0	0	0	0	0	0	0	1	2	1	0	4	2.8	28.17
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	7	7	6	5	20	11	13	8	3	4	8	17	15	13	6	9	152	0.0	7.33
PERCENT	4.6	4.6	3.9	3.3	13.2	7.2	9.6	5.3	2.0	2.6	5.3	11.2	10.5	8.6	3.9	5.3	100.0		
AV SPD	9.5	7.0	5.2	6.6	9.7	9.1	9.7	13.2	6.6	8.8	11.4	12.9	13.3	15.1	12.6	6.3			
AVERAGE SPEED FOR THIS TABLE EQUALS	10.6																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	2																		

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 21 OF 48)

MONTH OF JUNE

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -.9 BUT LESS THAN OR EQUAL TO -.8

REQUEST NUMBER 60-43

SITE WATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+ - 3.5	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	5	4.7
3.6 - 7.5	2	1	3	1	2	4	3	0	0	1	3	3	0	2	3	5	33	31.1	5.23
7.6 - 12.5	1	1	1	5	2	1	3	0	4	3	3	3	4	1	2	1	35	33.0	9.70
12.6 - 18.5	0	0	0	0	0	0	3	2	2	2	3	1	1	1	1	0	17	16.0	14.02
18.6 - 24.5	0	0	0	0	1	1	1	1	0	0	1	2	0	0	1	0	8	7.5	19.93
24.6 - 32.5	0	0	0	0	0	0	0	0	0	0	0	0	0	2	4	0	7	6.6	28.79
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	1	.9	36.77
TOTAL	5	2	4	6	5	9	9	4	6	4	9	11	6	9	11	6	106	100.0	7.85
PERCENT	4.7	1.9	3.5	5.7	4.7	8.9	3.9	3.8	5.7	3.8	8.9	10.4	5.7	8.5	10.4	5.7	100.0		
AV SPD	5.2	2.8	4.3	6.9	10.5	11.2	10.6	20.7	10.4	9.6	10.5	11.9	10.9	15.5	16.7	6.2			

AVERAGE SPEED FOR THIS TABLE EQUALS 11.3
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 0

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -.8 BUT LESS THAN OR EQUAL TO -.3

REQUEST NUMBER 60-43

SITE WATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	1	0	0	0	1	0	0	0	0	0	0	0	0	1	0	0	3	.5	.33
CALM+ - 3.5	0	3	4	5	4	3	3	1	4	2	3	1	3	0	1	2	39	6.3	2.39
3.6 - 7.5	5	14	9	9	13	15	15	11	12	6	13	13	5	5	4	5	154	25.0	5.42
7.6 - 12.5	10	3	10	16	23	15	16	17	14	13	22	19	13	12	9	4	222	36.0	9.69
12.6 - 18.5	0	1	10	5	7	10	25	4	3	11	19	16	5	9	6	2	133	21.6	14.82
18.6 - 24.5	1	0	0	1	4	3	8	2	2	3	9	3	1	6	1	0	44	7.1	21.17
24.6 - 32.5	0	0	0	0	0	2	1	2	2	0	3	2	1	1	0	0	20	3.2	27.24
32.6+	0	0	0	0	0	1	0	0	0	0	0	0	0	0	1	0	2	.3	33.05
TOTAL	17	21	39	36	52	49	68	37	37	35	69	54	28	34	28	13	617	100.0	6.39
PERCENT	2.8	3.4	6.3	5.8	8.4	7.9	11.0	6.0	6.0	5.7	11.2	8.8	4.5	5.5	4.5	2.1	100.0		
AV SPD	8.6	6.3	9.2	8.9	9.7	11.2	12.2	10.3	9.6	11.3	12.2	11.9	10.2	12.9	10.1	8.6			

AVERAGE SPEED FOR THIS TABLE EQUALS 10.9
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 3

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 22 OF 48)

MONTH OF JUNE

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .8 REQUEST NUMBER 634-43
SITE MATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	1	1	1	0	1	0	1	0	1	0	0	6	.2	1.30
CALM+ - 3.5	1	0	0	1	1	0	2	0	0	0	1	0	0	1	0	0	5	1.5	2.49
3.5 - 7.5	3	1	5	7	9	6	9	7	5	5	3	3	5	6	3	8	85	11.7	5.57
7.5 - 12.5	1	6	7	13	24	18	24	21	17	18	13	9	4	6	6	7	144	20.6	9.91
12.5 - 18.5	4	2	8	15	25	23	41	19	27	23	22	22	15	16	9	8	279	33.3	15.00
18.5 - 24.5	1	0	0	3	3	5	13	5	6	13	12	10	4	3	5	37	12.0	20.74	
24.5 - 32.5	0	0	0	1	8	5	4	1	4	2	4	0	5	2	0	0	36	4.9	23.72
32.5+	0	0	0	0	3	0	1	4	1	0	0	4	8	2	0	0	30	4.1	36.63
TOTAL	10	9	20	40	79	58	95	58	58	56	36	47	43	46	23	30	723	100.0	8.67
PERCENT	1.4	1.2	2.7	5.5	10.9	8.0	13.0	8.0	8.0	7.7	4.9	6.5	5.9	6.3	3.2	4.1	100.0		
AV SPD	11.9	9.7	10.8	12.4	16.5	13.9	14.2	14.3	14.6	13.8	12.7	15.3	18.7	17.1	15.3	11.7			
AVERAGE SPEED FOR THIS TABLE EQUALS	14.7																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	2																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 2.2 REQUEST NUMBER 634-43
SITE MATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	1	0	0	1	1	1	0	0	0	1	0	5	2.1	1.30
CALM+ - 3.5	1	1	0	1	0	1	2	0	2	1	1	0	0	1	1	1	13	5.4	2.29
3.5 - 7.5	4	2	4	3	7	2	7	1	8	2	1	4	3	5	1	3	57	23.7	5.53
7.5 - 12.5	2	2	4	6	5	8	10	7	8	5	2	3	6	3	5	8	84	34.9	9.73
12.5 - 18.5	0	1	2	3	3	3	8	9	4	3	8	6	4	6	3	1	64	26.5	14.99
18.5 - 24.5	0	0	1	0	0	0	3	0	0	1	2	2	4	1	2	0	15	6.6	23.32
24.5 - 32.5	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	.4	24.93
32.5+	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	.4	43.54
TOTAL	8	6	11	13	15	15	30	17	23	13	15	15	18	16	13	13	241	100.0	5.15
PERCENT	3.3	2.5	4.0	5.4	6.2	6.2	12.4	7.1	9.5	5.4	6.2	6.2	7.5	6.6	5.4	5.4	100.0		
AV SPD	10.5	7.7	10.7	9.9	8.5	9.3	13.9	12.4	8.2	9.8	13.5	12.5	13.5	10.9	11.0	9.0			
AVERAGE SPEED FOR THIS TABLE EQUALS	10.7																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	2																		

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 23 OF 48)

MONTH OF JUNE

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2
SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

REQUEST NUMBER 604-43

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)	
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	2	1	0	0	2	1	1	1	0	0	1	0	0	0	0	0	0	5	3.5	2.42
3.5 - 7.5	5	2	4	2	1	1	2	2	1	2	1	0	2	3	4	3	35	33.3	5.17	5.17
7.5 - 12.5	1	0	0	1	3	1	1	0	3	1	5	4	5	4	4	0	35	33.3	9.73	9.73
12.5 - 17.5	0	0	0	0	1	1	1	0	2	5	1	2	1	5	3	1	23	21.9	13.92	13.92
17.5 - 24.5	0	0	0	0	0	0	0	0	0	0	1	0	1	0	0	1	3	2.9	23.07	23.07
24.5 - 32.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
32.5+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	8	3	4	3	7	4	5	4	6	8	9	6	16	12	11	5	105	0.0	6.62	6.62
PERCENT	7.5	2.9	3.8	2.9	6.7	3.8	4.8	3.8	5.7	7.6	8.6	5.7	9.5	11.4	10.5	4.8	100.0			
AV SPD	5.3	3.6	6.0	7.9	7.5	7.3	7.4	6.3	10.5	11.4	9.5	11.4	13.7	13.5	9.1	10.5				
AVERAGE SPEED FOR THIS TABLE EQUALS	9.0																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION *	1																			

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 24 OF 48)

MONTH OF JULY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0

REQUEST NUMBER 604-43

SITE MATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GED MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	5	3	2	3	3	2	0	1	0	0	1	2	4	4	3	0	3	4.0	2.33
3.6 - 7.5	32	7	16	25	23	10	9	5	3	13	21	25	15	18	25	36	265	25.8	5.47
7.6 - 12.5	7	9	29	47	35	21	11	10	4	30	33	39	34	46	37	16	413	43.2	9.62
12.6 - 18.5	5	1	3	7	20	12	6	5	2	16	24	21	22	22	16	5	137	15.5	14.64
18.6 - 24.5	1	0	0	0	4	1	0	0	0	3	2	5	3	2	1	24	2.5	21.15	
24.6 - 32.5	0	0	0	0	1	1	0	0	1	1	0	1	0	0	0	2	7	.7	28.33
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	3.03
TOTAL	50	23	52	82	57	47	26	21	10	63	51	93	82	92	87	63	956	0.0	7.59
PERCENT	5.2	2.1	5.4	8.6	9.1	4.9	2.7	2.2	1.0	6.6	8.5	9.7	8.8	9.6	9.1	6.5	100.0		
AV SPD	7.0	5.8	8.4	8.5	10.2	10.4	9.4	9.4	11.8	11.1	10.5	10.7	10.5	10.2	9.1	8.3			
AVERAGE SPEED FOR THIS TABLE EQUALS	9.6																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	7																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -0.9

REQUEST NUMBER 604-43

SITE MATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GED MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	0	0	0	0	0	1	0	1	0	0	0	0	1	0	0	2	5	3.9	2.33
3.6 - 7.5	3	4	2	1	1	3	3	2	1	4	2	4	1	5	5	3	45	35.2	5.13
7.6 - 12.5	1	2	3	6	3	2	4	3	3	6	3	4	5	1	2	3	51	39.8	9.71
12.6 - 18.5	0	1	1	1	0	3	3	1	1	1	5	0	1	4	0	0	22	17.2	14.21
18.6 - 24.5	0	0	0	0	0	0	0	1	0	2	1	0	0	0	0	0	4	3.1	20.27
24.6 - 32.5	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	1	.8	27.61
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	4	7	6	8	4	9	11	8	5	13	11	8	9	10	8	8	128	0.0	7.28
PERCENT	3.1	5.5	4.7	6.3	3.1	7.0	3.6	6.3	3.9	10.2	8.6	6.3	6.3	7.3	6.3	6.3	100.0		
AV SPD	6.3	7.4	9.0	10.1	8.7	8.9	11.6	10.8	9.2	10.4	12.4	7.8	8.7	9.9	6.3	5.5			
AVERAGE SPEED FOR THIS TABLE EQUALS	9.3																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	3																		

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 25 OF 48)

MONTH OF JULY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE(DES F/100FT) GREATER THAN -1.9 BUT LESS THAN OR EQUAL TO -1.3
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

REQUEST NUMBER 604-43

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM. MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+ - 3.5	2	0	0	0	0	1	0	1	0	1	0	0	0	0	0	0	1	7	3.2
3.5 - 7.5	0	2	0	2	0	1	1	0	2	1	4	1	5	1	1	1	22	23.8	5.25
7.5 - 12.5	0	2	0	0	3	2	0	3	3	2	4	2	5	2	4	1	33	43.4	9.32
12.5 - 18.5	0	0	1	0	1	0	0	2	0	2	2	2	0	0	0	1	11	14.5	14.57
18.5 - 24.5	0	0	0	1	0	0	0	0	0	0	1	1	0	0	0	0	3	3.5	18.78
24.5 - 32.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
32.5+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	2	4	1	3	4	4	2	5	6	5	11	6	11	3	5	4	76	0.0	6.60
PERCENT	2.6	5.3	1.3	3.9	5.3	5.3	2.6	6.6	7.9	6.6	14.5	7.9	14.5	3.9	6.6	5.3	100.0		
AV SPD	2.5	7.1	13.9	11.0	9.6	9.9	3.2	12.8	7.4	12.8	8.4	12.5	8.6	7.9	9.2	8.5			
AVERAGE SPEED FOR THIS TABLE EQUALS 9.1																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 0																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE(DES F/100FT) GREATER THAN -1.8 BUT LESS THAN OR EQUAL TO -1.3
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

REQUEST NUMBER 604-43

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM. MEAN SPD(MPH)
CALM	1	0	1	0	0	0	0	0	0	0	1	1	0	0	3	0	7	1.5	3.32
CALM+ - 3.5	0	2	1	0	2	1	4	5	2	1	0	1	1	1	1	1	23	4.9	2.53
3.5 - 7.5	5	5	18	9	7	4	7	4	5	10	9	8	11	13	11	6	132	23.3	5.41
7.5 - 12.5	1	6	8	6	7	13	12	14	9	24	27	15	15	10	6	2	175	37.5	9.56
12.5 - 18.5	1	2	1	2	4	5	3	7	5	28	19	18	3	2	0	1	101	21.6	14.61
18.5 - 24.5	0	0	2	0	0	1	3	2	3	3	2	2	0	2	1	0	21	4.5	23.22
24.5 - 32.5	1	0	0	0	1	0	0	2	0	0	0	0	0	1	0	0	5	1.1	23.58
32.5+	0	0	0	0	0	0	0	0	1	0	0	0	0	1	0	0	3	.6	35.25
TOTAL	9	15	31	17	21	24	29	34	25	66	58	45	30	30	23	10	467	100.0	5.62
PERCENT	1.9	3.2	6.6	3.6	4.5	5.1	5.2	7.3	5.4	14.1	12.4	9.6	6.4	6.4	4.9	2.1	100.0		
AV SPD	8.9	8.2	7.5	7.6	9.5	10.2	3.5	11.3	11.9	11.9	11.3	11.4	8.5	10.4	7.5	6.7			
AVERAGE SPEED FOR THIS TABLE EQUALS 10.1																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 1																			

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 26 OF 48)

MONTH OF JULY

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .8 REQUEST NUMBER 604-43
SITE HATCH

PERIOD OF RECORD FROM 70660101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	1	1	0	2	3	1	0	0	0	0	1	0	1	1	0	3	14	2.5	.30
CALM+ - 3.5	5	1	2	0	0	1	0	0	5	1	1	1	4	2	3	2	28	4.9	2.16
3.6 - 7.5	8	2	5	3	5	2	7	8	4	8	4	7	7	8	7	92	16.2	5.46	5.46
7.6 - 12.5	6	5	14	4	7	25	26	14	15	16	19	14	21	15	7	6	214	37.7	9.77
12.6 - 18.5	1	8	11	5	5	15	13	13	19	28	23	20	9	6	2	2	181	31.9	15.02
18.6 - 24.5	0	1	0	0	2	0	5	2	5	5	2	6	2	4	1	0	35	6.2	20.52
24.6 - 32.5	1	0	0	0	0	1	0	0	0	1	0	0	0	0	1	0	4	.7	28.33
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	22	19	33	14	23	45	51	37	50	55	54	45	44	35	22	20	568	0.0	5.06
PERCENT	3.9	3.2	5.8	2.3	4.0	7.9	9.0	6.5	8.8	9.7	9.5	7.9	7.7	5.2	3.9	3.5	100.0		
AV SPD	7.0	11.5	10.1	9.5	9.9	11.2	12.0	11.7	12.1	13.4	12.0	13.5	9.7	10.2	9.2	6.8			

AVERAGE SPEED FOR THIS TABLE EQUALS 11.1
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 3

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 2.2 REQUEST NUMBER 604-43
SITE HATCH

PERIOD OF RECORD FROM 70660101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	0	0	1	0	0	0	1	0	0	0	0	2	1.4	.35	
CALM+ - 3.5	0	2	1	0	0	0	1	0	0	0	1	1	0	2	1	0	9	6.3	2.06
3.6 - 7.5	0	1	3	3	1	5	2	1	4	2	1	0	0	3	1	27	18.7	5.49	5.49
7.6 - 12.5	0	0	0	1	2	3	4	7	7	6	2	5	9	1	1	0	48	33.3	9.67
12.6 - 18.5	0	0	1	3	3	2	4	1	6	2	5	10	9	3	0	0	49	34.0	14.67
18.6 - 24.5	0	0	0	0	0	0	1	1	2	1	2	1	0	0	1	0	9	6.3	21.89
24.6 - 32.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	0	3	5	7	5	10	13	10	19	11	12	17	18	6	6	1	144	0.0	5.84
PERCENT	0.0	2.1	3.5	4.9	4.2	6.9	9.0	6.9	13.2	7.6	8.3	11.8	12.5	4.2	4.2	.7	100.0		
AV SPD	0.0	3.6	6.7	10.0	12.3	8.9	9.9	11.2	12.1	10.8	12.2	13.0	12.5	3.5	8.5	7.4			

AVERAGE SPEED FOR THIS TABLE EQUALS 10.9
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 1

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 27 OF 48)

10TH OF JULY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2

REQUEST NUMBER 604-43

SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPD(MPH)	
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW				
CALM	0	1	0	0	0	0	0	0	1	0	0	1	0	0	0	0	0	3	5.0	3.35
CALM+ - 3.5	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	2	3.3	3.21
3.0 - 7.5	1	0	0	1	0	1	1	4	2	2	1	1	2	0	2	0	0	18	30.3	5.59
7.6 - 12.5	0	0	1	1	2	0	0	1	3	1	6	0	6	1	0	0	0	22	36.7	13.21
12.6 - 18.5	0	0	0	0	0	0	0	1	0	2	0	8	3	0	0	0	0	14	23.3	14.45
18.6 - 24.5	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0.0	1.7
24.6 - 32.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	1	1	1	2	2	1	1	6	7	6	7	11	11	1	2	0	60	100.0	3.46	
PERCENT	1.7	1.7	1.7	3.3	3.3	1.7	1.7	10.0	11.7	10.0	11.7	16.3	16.3	1.7	3.3	0.0	100.0			
AVERAGE SPEED	7.4	3	9.4	7.8	11.0	3.6	3.6	6.9	6.0	8.9	10.0	13.2	11.3	10.7	4.5	0.0				

AVERAGE SPEED FOR THIS TABLE EQUALS 9.3
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 1

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 28 OF 48)

10TH OF AUGUST

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0

REQUEST NUMBER 604-43

SITE MATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	3	0	3	2	2	2	0	0	0	0	0	1	0	0	0	0	14	3.4	2.74
3.5 - 7.5	5	8	8	11	12	5	4	1	1	7	7	3	17	9	10	115	28.2	5.42	
7.5 - 12.5	7	15	30	31	20	6	4	2	5	16	17	11	8	14	3	197	48.3	9.80	
12.5 - 18.5	3	2	5	2	10	5	3	1	0	6	5	10	12	9	1	0	74	18.1	14.43
18.5 - 24.5	0	0	0	0	1	0	0	0	1	1	2	1	1	0	0	0	8	2.0	19.42
24.5 - 32.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
32.5+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	21	25	46	46	45	18	11	4	7	30	29	30	24	35	23	14	408	0.0	7.76
PERCENT	5.1	6.1	11.3	11.3	11.3	4.4	2.7	1.0	1.7	7.4	7.1	7.4	5.9	8.6	5.6	3.4	100.0		
AV SPD	7.4	8.0	8.1	8.4	9.7	8.8	9.4	10.5	10.6	9.8	10.7	10.6	12.4	9.6	8.4	6.2			
AVERAGE SPEED FOR THIS TABLE EQUALS 9.4																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 5																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -.9

REQUEST NUMBER 604-43

SITE MATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	0	3	0	2	0	0	0	0	0	0	0	0	0	2	0	1	8	9.5	2.91
3.5 - 7.5	3	6	7	2	1	0	0	0	0	3	2	4	1	2	1	1	33	39.3	5.55
7.5 - 12.5	1	2	1	1	4	2	1	0	3	3	5	4	3	1	3	2	38	42.9	9.22
12.5 - 18.5	1	0	0	1	0	0	0	1	0	0	1	0	1	0	0	0	5	6.0	14.43
18.5 - 24.5	0	1	0	0	0	0	1	0	0	0	0	0	0	0	0	0	2	2.4	18.52
24.5 - 32.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
32.5+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	5	12	8	6	5	2	2	1	3	6	8	8	5	5	4	4	84	0.0	6.40
PERCENT	6.0	14.3	9.5	7.1	6.0	2.4	2.4	1.2	3.6	7.1	9.5	9.5	6.0	6.0	4.8	4.8	100.0		
AV SPD	7.9	8.8	6.3	7.2	9.4	8.2	10.0	10.8	8.7	7.8	8.6	7.3	10.4	5.4	9.2	6.8			
AVERAGE SPEED FOR THIS TABLE EQUALS 7.3																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 1																			

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 29 OF 48)

MONTH OF AUGUST

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE(DES F/100FT) GREATER THAN -.9 BUT LESS THAN OR EQUAL TO -.8

REQUEST NUMBER 604-43

SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)	
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00	
CALM+ - 3.5	1	0	1	1	0	0	0	0	1	0	0	0	0	0	0	0	1	7	10.9	2.11
3.6 - 7.5	3	0	2	1	2	2	0	0	0	3	3	2	3	2	1	2	26	40.6	5.35	
7.6 - 12.5	0	1	0	1	2	4	2	0	1	4	2	3	3	0	0	1	24	37.5	9.97	
12.6 - 18.5	0	0	0	0	0	0	1	0	0	0	1	0	2	0	0	0	4	6.3	14.15	
18.6 - 24.5	1	0	0	0	0	0	0	0	0	0	1	0	1	0	0	0	3	4.7	21.37	
24.6 - 32.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00	
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00	
TOTAL	5	1	3	3	4	6	3	0	2	7	7	5	9	4	1	4	64	0.0	5.55	
PERCENT	7.8	1.6	4.7	4.7	6.3	9.4	4.7	0.0	3.1	10.9	10.9	7.8	14.1	6.3	1.6	6.3	100.0			
AV SPD	7.3	7.5	3.6	6.3	7.3	8.5	11.3	0.0	5.9	8.7	11.5	8.1	11.3	4.2	4.7	5.2				
AVERAGE SPEED FOR THIS TABLE EQUALS 8.2																				
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 3																				

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE(DES F/100FT) GREATER THAN -.8 BUT LESS THAN OR EQUAL TO -.3

REQUEST NUMBER 604-43

SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	1	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	2	.4	.33
CALM+ - 3.5	2	4	3	2	3	2	5	3	2	2	3	0	0	1	1	1	34	6.9	2.52
3.6 - 7.5	4	11	14	11	12	11	16	8	16	12	19	8	9	4	6	6	170	34.7	5.54
7.6 - 12.5	8	9	10	10	13	7	10	8	24	23	24	7	5	2	5	5	178	36.3	9.75
12.6 - 18.5	0	0	0	0	7	5	3	3	4	21	21	5	3	1	3	85	17.3	14.25	
18.6 - 24.5	0	0	0	0	0	3	0	0	0	2	4	1	0	6	0	0	10	2.0	23.53
24.6 - 32.5	0	0	0	0	1	1	3	1	0	1	2	0	0	0	0	0	9	1.8	23.20
32.6+	0	0	0	0	0	2	0	0	0	0	0	0	0	0	0	0	2	.4	35.93
TOTAL	15	24	27	31	36	31	37	23	46	61	74	21	23	15	11	15	499	100.0	6.46
PERCENT	3.1	4.9	5.5	6.3	7.3	5.3	7.6	4.7	9.4	12.4	15.1	4.3	4.7	3.1	2.2	3.1	100.0		
AV SPD	6.7	7.0	6.7	7.7	9.2	12.0	9.1	9.2	8.2	11.3	11.0	10.4	10.0	7.7	8.5	8.9			
AVERAGE SPEED FOR THIS TABLE EQUALS 9.4																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 3																			

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 30 OF 48)

MONTH OF AUGUST

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE(DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .8

REQUEST NUMBER 60443

SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	1	0	1	1	0	1	0	1	1	1	1	1	0	0	0	9	2.2	4.33
CALM+ - 3.5	1	1	0	0	1	2	2	0	0	1	3	1	1	2	0	0	15	3.7	2.02
3.6 - 7.5	2	3	3	6	4	8	13	4	7	4	8	6	4	1	1	7	15.4	5.44	
7.6 - 12.5	5	1	9	6	14	16	15	11	23	23	7	6	5	0	3	4	149	37.1	9.53
12.6 - 19.5	0	0	6	6	5	10	8	15	28	17	18	13	5	0	0	0	131	32.6	14.96
19.6 - 24.5	0	0	0	0	5	1	0	1	2	5	1	4	0	0	0	0	19	4.7	20.72
24.6 - 32.5	0	0	0	0	0	1	2	2	0	0	0	0	0	0	0	0	5	1.2	27.02
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	8	6	18	19	30	38	41	33	61	50	36	33	17	1	5	5	402	0.0	5.25
PERCENT	2.0	1.5	4.5	4.7	7.5	9.5	11.2	8.2	15.2	12.4	9.0	8.2	4.2	.2	1.5	1.2	100.0		
AV SPD	7.5	4.9	10.1	9.7	11.7	10.8	9.6	12.8	12.0	12.4	11.4	11.5	9.5	3.4	6.2	8.9			
AVERAGE SPEED FOR THIS TABLE EQUALS 11.0																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 1																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE(DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 2.2

REQUEST NUMBER 60443

SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	2	0	0	0	0	0	0	0	0	2	1.9	3.3
CALM+ - 3.5	0	1	1	0	1	2	0	1	0	1	1	0	0	0	0	0	8	7.7	2.16
3.6 - 7.5	0	3	5	4	0	0	4	1	4	1	1	1	2	1	3	1	31	29.5	5.13
7.6 - 12.5	1	3	1	1	1	2	5	2	5	3	5	4	2	0	2	1	32	36.5	9.41
12.6 - 19.5	0	0	0	1	0	2	2	2	2	1	2	4	1	0	0	1	18	17.3	14.97
19.6 - 24.5	0	0	0	0	0	1	0	3	0	1	1	1	0	0	0	0	7	6.7	22.54
24.6 - 32.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	1	7	7	6	2	7	11	11	11	7	10	10	5	1	5	3	104	0.0	4.73
PERCENT	1.0	6.7	6.7	5.8	1.9	6.7	10.6	10.6	10.6	6.7	9.6	9.6	4.9	1.0	4.8	2.9	100.0		
AV SPD	9.4	6.3	5.3	8.1	5.9	11.6	9.1	10.6	9.1	10.5	10.9	12.2	8.8	6.2	6.6	9.9			
AVERAGE SPEED FOR THIS TABLE EQUALS 9.3																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 0																			

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 31 OF 48)

MONTH OF AUGUST

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74983124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

REQUEST NUMBER 614-43

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	SEC	MEAN	
0-2.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
2.5 - 3.5	0	0	0	1	0	0	0	0	1	0	0	0	0	0	0	0	0	2	12.5	2.50	
3.5 - 7.5	0	0	1	0	0	0	0	0	0	0	0	1	0	0	1	0	3	13.7	6.23		
7.5 - 12.5	0	0	0	0	1	1	1	0	1	0	2	0	0	0	0	0	2	8	50.0	10.56	
12.5 - 18.5	0	0	0	0	0	0	0	1	0	0	2	0	0	0	0	0	3	18.7	16.25		
18.5 - 24.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	
24.5 - 32.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	
32.5+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	
TOTAL	0	0	1	1	1	1	1	1	2	0	2	3	0	0	1	2	16	6.0	7.24		
PERCENT	0.0	0.0	6.3	6.3	6.3	6.3	6.3	6.3	12.5	0.0	12.5	18.7	0.0	0.0	6.3	12.5	100.0				
AV SPD	0.0	0.0	7.0	3.4	11.8	11.7	11.7	15.7	7.0	0.0	16.6	9.1	0.0	0.0	5.0	9.1					
AVERAGE SPEED FOR THIS TABLE EQUALS	9.9																				
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	0																				

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 32 OF 48)

MONTH OF SEPTEMBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0

REQUEST NUMBER 604-43

SITE MATCH

PERIOD OF RECORD FROM 70060101 TO 74043124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+ - 3.5	0	1	0	1	2	1	0	0	1	0	1	0	1	0	1	1	10	1.4	2.35
3.5 - 7.5	13	11	15	10	25	9	2	4	6	1	1	9	4	2	13	10	136	19.0	5.39
7.5 - 12.5	8	9	16	51	74	32	3	7	7	6	7	9	11	4	9	4	257	35.9	9.88
12.5 - 17.5	4	17	18	31	31	17	7	5	7	1	3	6	6	15	10	7	196	27.4	15.75
17.5 - 24.5	4	4	7	9	9	6	10	2	1	0	1	3	3	1	6	7	73	10.2	21.01
24.5 - 32.5	2	1	0	0	4	2	7	2	0	0	1	1	3	1	2	5	37	5.2	27.52
32.5+	2	1	0	0	0	0	1	0	0	0	0	0	0	0	2	0	6	.8	39.94
TOTAL	39	47	58	102	152	67	30	20	22	8	14	28	25	23	43	34	715	100.0	9.73
PERCENT	5.5	6.6	8.1	14.3	21.3	9.4	4.2	2.8	3.1	1.1	2.0	3.9	3.9	3.2	6.0	4.8	100.0		
AV SPD	14.0	14.1	11.9	12.1	11.5	11.8	20.6	13.2	10.6	8.9	12.2	11.6	14.0	14.6	14.3	14.3			
AVERAGE SPEED FOR THIS TABLE EQUALS	12.8																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	33																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -0.9

REQUEST NUMBER 604-43

SITE MATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+ - 3.5	1	0	0	0	0	0	1	0	0	0	0	0	0	0	1	0	3	2.6	2.79
3.5 - 7.5	1	1	4	1	0	1	2	0	0	0	0	0	0	0	1	0	11	9.4	5.77
7.5 - 12.5	3	3	4	4	3	6	1	2	0	3	0	1	2	1	5	4	42	35.9	9.58
12.5 - 17.5	2	2	3	9	9	2	4	0	1	0	2	1	2	1	3	1	41	35.0	15.57
17.5 - 24.5	0	0	0	1	3	1	2	0	0	0	0	0	0	0	0	0	7	6.0	20.33
24.5 - 32.5	1	2	0	0	1	0	3	1	3	0	0	1	0	0	0	0	12	10.3	26.49
32.5+	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	.9	48.84
TOTAL	9	8	11	14	15	10	13	3	4	3	2	3	4	2	10	5	117	100.0	10.53
PERCENT	7.7	5.8	9.4	12.0	13.7	9.5	11.1	2.6	3.4	2.6	1.7	2.6	3.4	1.7	8.5	4.3	100.0		
AV SPD	14.5	14.6	9.6	14.1	16.0	11.6	15.5	15.3	24.1	9.3	14.1	16.9	13.7	12.9	10.8	10.7			
AVERAGE SPEED FOR THIS TABLE EQUALS	13.9																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	1																		

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 33 OF 48)

MONTH OF SEPTEMBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -.9 BUT LESS THAN OR EQUAL TO -.8 REQUEST NUMBER 63-43
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	SEC MEAN SPD(MPH)	
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	1	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	2	2.5	2.42
3.5 - 7.5	1	1	1	1	0	2	2	2	1	1	2	0	2	1	1	1	19	23.7	5.33	5.33
7.5 - 12.5	2	1	5	4	7	2	0	0	0	1	3	1	2	2	3	0	33	41.2	9.36	9.36
12.5 - 18.5	2	1	1	3	1	4	1	1	0	0	1	0	2	1	0	0	18	22.5	15.35	15.35
18.5 - 24.5	0	0	1	3	6	1	0	0	0	0	0	1	0	0	0	0	6	7.5	20.22	20.22
24.5 - 32.5	0	0	0	0	1	0	0	0	0	0	0	0	1	0	0	0	2	2.5	28.81	28.81
32.5+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00	0.00
TOTAL	6	3	8	11	9	10	3	3	1	2	5	3	5	5	5	1	80	100.0	8.60	8.60
PERCENT	7.5	3.7	10.0	13.7	11.2	12.5	3.7	3.7	1.2	2.5	6.3	3.7	6.3	6.3	6.3	1.2	100.0			
AV SPD	10.1	10.0	11.0	14.0	12.4	11.6	8.8	9.4	5.3	6.7	7.2	15.0	12.5	11.1	10.5	3.9				
AVERAGE SPEED FOR THIS TABLE EQUALS 11.1																				
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 1																				

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -.8 BUT LESS THAN OR EQUAL TO -.3 REQUEST NUMBER 60-43
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	SEC MEAN SPD(MPH)	
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	0	0	2	1	1	1	2	4	2	0	0	0	0	2	1	1	17	3.3	2.49	2.49
3.5 - 7.5	3	8	12	14	15	5	7	5	4	2	4	2	5	4	5	5	134	20.1	5.62	5.62
7.5 - 12.5	8	9	21	42	30	13	13	4	6	4	8	7	10	7	8	3	193	37.3	9.73	9.73
12.5 - 18.5	4	7	13	23	21	17	5	3	4	11	11	2	5	6	4	2	138	26.6	14.71	14.71
18.5 - 24.5	1	1	2	5	8	4	1	4	2	0	0	0	2	0	1	2	35	6.8	21.38	21.38
24.5 - 32.5	0	0	1	0	1	4	0	8	5	0	3	3	0	1	0	0	26	5.0	28.41	28.41
32.5+	0	0	0	0	1	0	0	0	0	0	0	1	0	0	0	0	5	1.3	35.25	35.25
TOTAL	16	25	51	85	79	47	32	28	23	17	26	15	25	20	19	13	512	100.0	9.06	9.06
PERCENT	3.1	4.8	9.9	16.4	15.1	9.1	5.8	5.4	4.4	3.3	5.0	2.9	4.3	3.9	3.7	2.5	100.0			
AV SPD	11.3	10.7	10.6	10.7	12.3	13.9	10.3	15.5	14.4	12.6	14.4	15.7	14.2	10.4	10.2	10.3				
AVERAGE SPEED FOR THIS TABLE EQUALS 12.2																				
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 4																				

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 34 OF 48)

MONTH OF SEPTEMBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .8 REQUEST NUMBER 604-43

SITE MATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+ - 3.5	0	1	2	1	1	1	1	1	0	2	2	1	1	0	3	0	14	1.7	2.39
3.6 - 7.5	3	7	7	14	9	8	15	10	5	8	8	2	3	5	1	3	103	12.9	5.55
7.6 - 12.5	9	15	28	59	45	37	30	24	17	8	10	10	4	5	1	2	304	36.3	10.05
12.6 - 18.5	4	10	28	38	41	35	32	19	8	7	6	14	12	2	3	271	32.4	14.60	
18.6 - 24.5	2	1	3	3	5	15	6	6	3	5	4	1	4	8	0	73	3.7	26.50	
24.6 - 32.5	1	0	1	3	1	7	4	4	2	5	7	3	3	3	0	0	44	5.3	27.75
32.5+	0	0	0	0	0	0	2	2	4	2	3	5	0	0	0	0	23	2.7	35.90
TOTAL	19	34	59	118	103	103	90	66	39	37	40	36	32	33	10	8	837	100.0	10.67
PERCENT	2.3	4.1	6.2	14.1	12.3	12.3	10.8	7.9	4.7	4.4	4.8	4.3	3.8	3.9	1.2	1.0	100.0		
AV SPD	12.1	10.8	12.7	12.0	12.5	14.0	13.1	13.8	14.9	15.2	15.6	17.3	18.7	16.6	17.7	18.0			
AVERAGE SPEED FOR THIS TABLE EQUALS	13.7																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	5																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 2.2 REQUEST NUMBER 604-43

SITE MATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	1	.3	1.31
CALM+ - 3.5	0	0	0	1	1	0	1	1	1	2	0	0	0	0	1	0	8	2.6	2.44
3.6 - 7.5	2	1	3	6	5	4	6	3	2	0	0	3	2	1	3	2	43	14.2	5.53
7.6 - 12.5	4	5	11	14	12	10	17	4	5	3	5	9	5	4	0	3	106	35.1	9.75
12.6 - 18.5	2	4	3	8	5	10	6	2	10	4	3	6	5	2	2	5	78	25.8	14.63
18.6 - 24.5	3	1	2	2	1	5	5	1	0	2	1	4	3	1	1	0	32	10.6	21.63
24.6 - 32.5	1	0	0	0	1	6	2	3	2	1	0	0	1	3	1	0	21	7.0	27.53
32.5+	0	0	0	0	0	0	1	1	2	3	2	3	3	0	1	0	13	4.3	35.53
TOTAL	12	11	19	31	26	35	34	15	22	12	11	25	19	11	9	10	302	100.0	9.12
PERCENT	4.0	3.6	6.3	10.3	9.6	11.6	11.3	5.0	7.3	4.0	3.6	8.3	6.3	3.6	3.0	3.3	100.0		
AV SPD	15.2	12.1	11.1	11.2	11.2	15.6	13.1	15.1	15.7	13.8	17.4	15.5	17.8	15.3	14.2	11.1			
AVERAGE SPEED FOR THIS TABLE EQUALS	14.0																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	1																		

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 35 OF 48)

MONTH OF SEPTEMBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2

REQUEST NUMBER 634-43

SITE HATCH

PERIOD OF RECORD FROM 70660101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)	
CALM	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	1	1.1	1.3
CALM+ - 3.5	0	1	1	1	0	0	0	1	0	0	0	0	1	0	0	0	0	5	5.6	2.34
3.6 - 7.5	1	1	1	2	0	1	1	1	0	1	0	0	1	1	2	3	16	17.8	5.15	
7.6 - 12.5	1	0	2	2	1	0	0	3	3	1	0	4	1	1	3	9	22	24.4	9.89	
12.6 - 18.5	1	0	1	0	0	0	0	0	5	2	0	1	2	6	3	2	23	25.6	15.24	
18.6 - 24.5	1	0	0	0	0	0	0	0	0	1	0	2	4	2	1	0	11	12.2	21.35	
24.6 - 32.5	1	0	0	0	0	0	0	0	0	0	1	1	1	1	1	0	6	6.7	23.42	
32.6+	0	0	0	0	0	0	0	0	0	0	0	2	3	1	0	0	6	6.7	37.34	
TOTAL	5	2	5	5	1	1	1	6	8	5	1	10	13	12	10	5	93	100.0	6.82	
PERCENT	5.6	2.2	5.6	5.6	1.1	1.1	1.1	5.7	8.9	5.6	1.1	11.1	14.4	13.3	11.1	5.6	100.0			
AVERAGE SPEED FOR THIS TABLE EQUALS	14.6																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	3																			

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 36 OF 48)

MONTH OF OCTOBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0

REQUEST NUMBER 614-43

SITE HATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)	
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	1	3	0	0	1	1	0	0	0	0	0	0	0	0	1	3	13	1.3	3.24	
3.6 - 7.5	13	13	15	6	14	4	3	0	2	2	1	3	2	7	9	97	12.4	5.43		
7.6 - 12.5	13	13	15	27	46	25	12	2	4	3	4	8	10	6	11	203	25.3	9.78		
12.6 - 18.5	9	7	21	21	44	21	7	3	4	4	2	1	7	16	15	9	192	24.5	14.95	
18.6 - 24.5	5	3	11	7	15	9	12	0	0	3	2	3	4	8	14	2	93	12.6	20.64	
24.6 - 32.5	5	3	2	2	18	29	14	4	0	0	1	1	0	3	8	8	59	12.6	23.26	
32.6+	6	7	1	0	4	42	11	0	0	0	2	2	0	0	6	4	25	10.8	35.25	
TOTAL	53	49	66	63	143	131	59	9	10	12	12	14	21	39	58	45	785	100.0	11.93	
PERCENT	6.8	5.2	8.4	8.0	18.2	16.7	7.5	1.1	1.3	1.5	1.5	1.8	2.7	5.0	7.4	5.9	100.0			
AV SPD	15.9	14.8	13.2	13.1	15.6	25.3	22.4	20.5	10.7	13.9	18.3	16.4	13.6	15.5	18.9	15.2				
AVERAGE SPEED FOR THIS TABLE EQUALS	17.5																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	13																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -.9

REQUEST NUMBER 614-43

SITE HATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+ - 3.5	1	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	2	1.8	3.16
3.6 - 7.5	0	0	0	4	5	4	0	0	1	2	2	0	1	2	2	0	23	21.1	5.59
7.6 - 12.5	2	1	4	9	7	2	0	3	2	3	2	1	0	0	4	2	42	38.5	10.21
12.6 - 18.5	1	2	5	1	4	1	2	0	0	0	1	0	0	0	0	1	18	16.5	15.39
18.6 - 24.5	0	1	1	0	2	2	1	0	0	0	0	0	0	0	3	0	10	9.2	20.37
24.6 - 32.5	1	1	1	1	0	1	3	1	0	0	0	0	1	0	0	1	11	10.1	27.43
32.6+	0	0	0	1	1	1	0	0	0	0	0	0	0	0	0	0	3	2.8	42.87
TOTAL	5	5	12	15	19	11	6	4	3	5	5	1	2	2	9	4	135	100.0	9.83
PERCENT	4.6	4.6	11.0	14.7	17.4	10.1	5.5	3.7	2.8	4.6	4.6	.9	1.8	1.8	8.3	3.7	100.0		
AV SPD	12.4	19.9	14.7	13.0	12.7	16.7	23.6	13.6	8.8	7.5	9.1	8.9	16.4	4.9	12.9	15.4			
AVERAGE SPEED FOR THIS TABLE EQUALS	13.8																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	4																		

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 37 OF 48)

MONTH OF OCTOBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -0.9 BUT LESS THAN OR EQUAL TO -0.9

REQUEST NUMBER 604-43

SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
3.6 - 7.5	3	1	0	3	2	1	1	0	3	4	0	1	1	3	1	3	27	26.2	5.47
7.6 - 12.5	3	3	5	1	4	0	2	0	5	1	1	0	1	0	2	0	28	27.2	9.55
12.6 - 18.5	0	1	5	5	7	2	1	0	1	0	0	0	0	2	1	1	26	25.2	15.55
18.6 - 24.5	2	0	0	2	2	3	0	0	0	0	0	0	0	0	1	2	12	11.7	20.61
24.6 - 32.5	0	2	0	0	0	2	2	0	0	0	1	0	0	0	1	0	8	7.8	28.15
32.6+	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	2	1.9	37.73	
TOTAL	9	7	10	11	16	9	6	0	9	5	2	1	2	5	6	6	103	100.0	9.94
PERCENT	7.8	5.8	9.7	10.7	15.5	8.7	5.8	0.0	8.7	4.9	1.9	1.0	1.9	4.9	5.8	5.8			
AV SPD	10.4	12.4	13.0	13.4	15.1	21.1	16.7	0.0	9.1	7.1	20.1	6.5	7.8	10.2	14.6	12.3			
AVERAGE SPEED FOR THIS TABLE EQUALS	13.5																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	4																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -0.8 BUT LESS THAN OR EQUAL TO -0.3

REQUEST NUMBER 604-43

SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	3	4	1	5	3	1	1	0	2	1	1	1	2	0	4	3	32	4.6	2.55
3.6 - 7.5	14	12	8	10	5	14	4	2	3	1	2	6	9	9	7	6	113	16.1	5.73
7.6 - 12.5	7	16	25	46	29	17	9	2	4	2	3	2	6	6	6	6	186	26.5	9.93
12.6 - 18.5	3	9	42	41	37	15	3	3	1	5	2	5	3	7	5	5	186	26.5	15.09
18.6 - 24.5	2	0	12	24	15	12	8	3	1	2	4	0	1	9	5	6	106	15.1	21.13
24.6 - 32.5	8	1	2	1	3	10	6	3	0	2	3	2	3	1	3	7	61	8.7	27.60
32.6+	2	0	0	0	3	7	2	0	1	0	2	2	0	0	0	0	19	2.7	36.53
TOTAL	39	42	90	127	103	76	33	13	12	13	17	18	24	32	31	33	703	100.0	9.59
PERCENT	5.5	5.0	12.8	16.1	14.7	10.6	4.7	1.8	1.7	1.8	2.4	2.6	3.4	4.6	4.4	4.7			
AV SPD	14.3	9.3	13.9	13.3	15.9	17.0	17.5	17.3	11.4	15.8	19.7	14.7	10.7	13.7	12.7	14.8			
AVERAGE SPEED FOR THIS TABLE EQUALS	14.4																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	9																		

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 38 OF 48)

MONTH OF OCTOBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .8 REQUEST NUMBER 604-43
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEQ MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+ - 3.5	0	1	0	1	1	0	1	1	0	1	0	2	0	1	0	1	10	1.5	2.50
3.5 - 7.5	5	2	2	3	3	5	5	3	3	2	0	0	1	5	1	41	6.1	5.63	
7.5 - 12.5	11	8	8	17	22	1A	19	10	6	5	4	5	2	4	15	3	154	23.1	9.94
12.5 - 18.5	2	23	41	47	37	33	15	5	6	8	10	4	7	22	9	278	41.7	15.30	
18.5 - 24.5	4	1	16	8	11	14	2	3	7	5	4	3	9	4	4	3	103	15.4	21.07
24.5 - 32.5	1	1	4	3	9	13	7	5	1	4	1	2	0	1	2	3	57	8.5	27.90
32.5+	3	0	0	0	2	12	0	2	0	4	1	2	0	0	0	2	24	3.6	35.98
TOTAL	26	36	71	79	85	95	45	29	23	26	21	16	19	33	36	27	667	100.0	12.65
PERCENT	3.9	5.4	10.6	11.8	12.7	14.2	6.7	4.3	3.4	3.9	3.1	2.4	2.8	4.9	5.4	4.0	100.0		
AV SPD	14.9	13.6	16.9	14.9	16.3	19.2	14.1	16.2	14.9	16.7	19.0	14.7	17.0	15.7	12.7	19.0			
AVERAGE SPEED FOR THIS TABLE EQUALS	15.2																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	4																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO 2.2 REQUEST NUMBER 604-43
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEQ MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+ - 3.5	1	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	2	.8	1.77
3.5 - 7.5	2	0	0	2	2	1	1	1	2	1	0	1	1	1	3	0	18	7.2	5.77
7.5 - 12.5	2	4	12	10	8	4	12	4	7	4	6	2	3	1	6	3	88	35.2	10.25
12.5 - 18.5	1	12	13	13	12	8	6	4	6	4	5	6	7	3	3	2	105	42.0	14.91
18.5 - 24.5	0	0	0	0	1	2	0	1	1	2	4	1	2	2	0	2	18	7.2	21.64
24.5 - 32.5	1	1	0	0	1	0	2	0	1	0	0	1	1	5	0	1	14	5.6	27.36
32.5+	0	0	0	0	0	5	0	0	0	0	0	0	0	0	0	0	5	2.0	36.76
TOTAL	7	17	25	25	24	29	21	10	18	11	15	11	14	12	8	250	100.0		11.71
PERCENT	2.8	5.8	10.0	10.0	9.6	8.0	5.4	4.0	7.2	4.4	6.0	4.4	5.5	4.8	4.8	3.2	100.0		
AV SPD	11.3	14.2	12.4	12.7	13.5	19.5	13.1	12.9	12.4	14.2	15.3	15.0	16.5	20.9	9.6	17.3			
AVERAGE SPEED FOR THIS TABLE EQUALS	14.3																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	3																		

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 39 OF 48)

MONTH OF OCTOBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2
SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74043124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

REQUEST NUMBER 604-43

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	0	1	2	0	0	2	0	0	0	0	0	0	0	0	0	0	6	2.3	1.24
3.6 - 7.5	1	3	4	6	4	0	3	2	1	2	1	1	0	0	0	1	29	10.9	5.07
7.6 - 12.5	9	9	4	22	6	4	4	1	3	3	9	6	3	0	1	9	93	35.1	9.68
12.6 - 18.5	5	3	0	14	7	3	3	1	2	8	5	1	9	9	8	5	91	34.3	15.05
18.6 - 24.5	1	2	2	1	1	0	0	0	0	1	3	0	3	4	1	3	22	8.3	21.93
24.6 - 32.5	2	3	0	0	0	0	0	1	0	1	0	0	1	4	2	2	16	6.0	23.02
32.5+	1	0	0	0	0	0	1	1	0	0	0	1	2	0	0	2	8	3.0	33.70
TOTAL	19	21	20	43	18	7	13	6	6	15	18	9	19	17	12	22	265	100.0	10.39
PERCENT	7.2	7.9	7.5	16.2	6.8	2.6	4.9	2.3	2.3	5.7	6.8	3.4	7.2	6.4	4.5	8.3	100.0		
AV SPD	15.2	13.6	11.5	11.4	11.3	12.1	11.2	17.2	12.1	14.8	12.6	13.0	18.5	20.1	16.9	16.3			
AVERAGE SPEED FOR THIS TABLE EQUALS 14.1																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 3																			

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 40 OF 48)

MONTH OF NOVEMBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0

REQUEST NUMBER 604-43

SITE MATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+ - 3.5	4	6	0	2	0	1	0	0	1	0	0	0	0	0	0	0	0	0	3.05
3.5 - 7.5	7	5	8	3	5	1	1	0	2	1	4	2	4	2	4	5	21	4.5	2.57
7.5 - 12.5	4	4	7	12	9	13	4	6	6	8	10	5	11	15	12	6	132	29.2	9.75
12.5 - 17.5	0	2	10	9	11	8	5	4	3	11	12	5	11	15	12	14	140	31.0	15.02
17.5 - 24.5	7	1	3	2	3	0	0	0	0	3	6	1	5	9	9	6	57	12.6	20.84
24.5 - 32.5	0	0	0	0	0	1	0	0	1	4	1	1	5	6	3	7	29	6.4	27.53
32.5+	0	0	0	0	0	0	0	0	1	4	1	1	5	6	3	7	29	6.4	27.53
TOTAL	30	18	28	28	29	24	11	10	14	28	33	15	37	52	44	51	452	100.0	40.93
PERCENT	6.6	4.0	6.2	6.2	6.4	5.3	2.4	2.2	3.1	6.2	7.3	3.3	8.2	11.5	9.7	11.3	100.0		9.74
AV SPD	11.8	7.1	11.8	11.8	12.2	12.2	11.3	12.3	15.7	15.7	13.8	12.8	15.8	18.6	16.9	15.2			
AVERAGE SPEED FOR THIS TABLE EQUALS	14.2																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	10																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -.9

REQUEST NUMBER 604-43

SITE MATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+ - 3.5	1	0	1	0	1	0	2	0	0	0	0	0	0	0	0	0	0	0	0.0
3.5 - 7.5	1	3	3	1	2	3	1	0	0	0	2	0	0	1	4	5	2	12	9.2
7.5 - 12.5	2	0	3	4	8	3	1	3	0	2	2	0	0	2	1	0	26	19.8	5.41
12.5 - 17.5	1	0	4	4	3	1	3	2	1	1	0	4	2	4	1	1	31	23.7	9.65
17.5 - 24.5	0	0	1	1	2	2	1	0	0	1	1	0	4	1	1	1	32	24.4	15.15
24.5 - 32.5	2	0	2	2	0	0	0	0	1	1	0	0	0	4	1	0	14	10.7	21.39
32.5+	0	0	0	0	0	0	0	0	1	1	0	0	0	0	2	1	11	8.4	27.93
TOTAL	7	3	14	12	15	9	8	6	2	5	5	6	3	18	13	4	131	100.0	43.87
PERCENT	5.3	2.3	10.7	9.2	12.2	6.9	5.1	4.6	1.5	3.8	3.8	4.6	2.3	13.7	9.9	3.1	100.0		8.55
AV SPD	14.1	5.7	13.1	15.6	11.4	11.5	11.2	16.7	24.1	17.7	10.8	10.8	12.2	21.0	10.5	13.5			
AVERAGE SPEED FOR THIS TABLE EQUALS	13.9																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	7																		

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 41 OF 48)

MONTH OF NOVEMBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -.9 BUT LESS THAN OR EQUAL TO -.8

REQUEST NUMBER 604-43

SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEQ MEAN SPD(MPH)
CALM	0	0	0	0	3	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	2	0	1	1	1	0	0	0	0	1	0	0	1	1	0	2	10	9.1	2.10
3.6 - 7.5	1	0	1	2	4	0	0	0	1	0	2	1	2	1	3	20	18.2	5.51	
7.6 - 12.5	3	0	2	4	5	0	1	2	1	2	1	1	0	1	1	26	23.6	9.59	
12.6 - 18.5	1	5	2	3	1	0	1	0	1	0	0	3	1	0	3	2	23	21.9	15.23
18.6 - 24.5	0	3	1	0	0	0	0	0	2	0	0	0	0	3	0	1	13	9.1	22.70
24.6 - 32.5	0	1	1	2	2	2	0	0	0	0	1	0	0	0	2	2	13	11.8	27.53
32.6+	0	0	0	0	1	3	0	0	0	0	0	0	0	1	2	1	8	7.3	37.20
TOTAL	7	9	8	12	13	10	1	1	5	3	4	6	3	7	9	12	110	100.0	8.99
PERCENT	6.4	8.2	7.3	10.9	11.8	9.1	.9	.9	4.5	2.7	3.6	5.5	2.7	6.4	8.2	10.9	100.0		
AV SPD	8.5	19.1	13.0	12.8	13.7	23.9	15.4	11.5	16.0	6.5	11.7	10.7	8.6	17.6	21.7	14.9			
AVERAGE SPEED FOR THIS TABLE EQUALS 14.9																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 3																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -.8 BUT LESS THAN OR EQUAL TO -.3

REQUEST NUMBER 604-43

SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 150 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEQ MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	0	3	2	1	1	7	3	0	0	2	0	1	1	2	3	2	25	4.0	2.29
3.6 - 7.5	10	10	14	15	14	7	12	6	1	6	4	6	7	13	12	17	154	22.0	5.17
7.6 - 12.5	8	10	6	17	12	14	9	8	4	5	14	6	7	7	17	150	21.4	9.80	
12.6 - 18.5	11	9	4	3	15	15	11	3	1	4	6	19	11	13	13	15	193	21.8	15.22
18.6 - 24.5	2	3	0	3	12	5	3	2	1	5	13	5	9	5	17	15	96	13.7	21.15
24.6 - 32.5	4	0	0	2	7	4	1	1	1	2	1	4	3	7	19	7	59	8.4	28.14
32.6+	0	0	0	0	1	3	0	3	5	12	3	7	3	7	12	5	61	8.7	40.63
TOTAL	35	35	26	41	62	55	39	23	13	36	38	48	39	54	79	78	701	100.0	9.23
PERCENT	5.0	5.0	3.7	5.8	8.8	7.8	5.6	3.3	1.9	5.1	5.4	6.8	5.6	7.7	11.3	11.1	100.0		
AV SPD	12.7	10.1	7.7	10.0	14.3	14.2	10.8	14.3	25.8	22.6	16.0	18.0	17.3	17.7	21.1	15.4			
AVERAGE SPEED FOR THIS TABLE EQUALS 15.7																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 13																			

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 42 OF 48)

MONTH OF NOVEMBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .8

REQUEST NUMBER 604-43

SITE HATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)	
CALM	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	1	.2	1.30
CALM+ - 3.5	1	0	0	0	0	0	1	1	4	1	0	0	0	0	0	0	1	11	2.0	2.12
3.5 - 7.5	5	5	4	7	6	6	0	1	1	5	5	3	5	6	3	1	5	68	12.7	5.50
7.5 - 12.5	6	7	15	13	11	14	6	5	4	5	8	5	12	7	16	6	140	26.1	9.93	
12.5 - 18.5	0	0	4	17	10	13	12	8	13	10	14	5	27	14	4	13	176	32.3	14.93	
18.5 - 24.5	0	0	2	3	5	8	2	5	4	2	8	4	15	8	2	6	76	14.2	21.11	
24.5 - 32.5	0	0	4	2	8	5	0	2	3	1	0	1	0	1	6	3	37	6.9	27.64	
32.5+	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	1	2.0	38.59	
TOTAL	18	12	25	44	43	49	27	20	32	40	36	25	63	36	32	35	537	100.0	10.24	
PERCENT	3.4	2.2	4.7	8.2	8.0	9.1	5.0	3.7	6.0	7.4	6.7	4.7	11.7	6.7	6.0	6.5	100.0			
AV SPD	9.7	9.5	11.1	13.5	10.5	15.4	17.2	14.2	15.9	19.0	14.6	22.6	15.4	14.8	14.7	15.2				
AVERAGE SPEED FOR THIS TABLE EQUALS	15.3																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	1																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 2.2

REQUEST NUMBER 604-43

SITE HATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	1	1	1	1	0	0	0	0	0	0	0	1	1	0	0	6	2.0	1.30
CALM+ - 3.5	0	0	1	0	1	0	0	1	0	0	0	0	0	0	0	0	3	1.3	3.03
3.5 - 7.5	3	2	4	1	2	3	3	3	1	1	1	0	2	1	1	2	27	9.2	5.74
7.5 - 12.5	4	1	5	7	15	13	12	4	3	3	6	5	4	9	11	2	194	35.4	9.99
12.5 - 18.5	2	6	4	7	27	4	6	3	3	11	3	10	6	3	7	6	108	36.7	15.05
18.5 - 24.5	1	0	0	0	5	2	1	0	2	3	4	3	1	0	1	2	25	8.5	21.53
24.5 - 32.5	0	0	0	2	3	1	0	0	1	2	0	3	0	0	2	1	15	5.1	26.92
32.5+	0	0	0	0	0	0	0	0	2	0	1	1	0	0	1	0	6	2.0	38.59
TOTAL	10	10	11	21	54	22	11	12	20	15	22	14	14	23	13	294	100.0	6.51	
PERCENT	3.4	3.4	3.7	7.1	18.4	7.5	7.5	3.7	4.1	6.8	5.1	7.5	4.8	4.8	7.8	4.4	100.0		
AV SPD	11.5	10.9	10.8	12.6	15.0	12.1	11.5	8.6	18.7	16.3	15.2	17.9	12.2	9.8	15.3	14.7			
AVERAGE SPEED FOR THIS TABLE EQUALS	13.8																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	3																		

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 43 OF 48)

MONTH OF NOVEMBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2
SITE MATCH

REQUEST NUMBER 604-43

PERIOD OF RECORD FROM 7000101 TO 74033124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND #35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	2	2	0	1	0	0	0	0	1	0	2	0	8	1.7	.30
CALM+ - 3.5	1	1	0	1	2	1	0	0	2	1	1	0	0	3	0	0	13	2.7	2.43
3.6 - 7.5	7	6	10	6	9	5	5	4	3	2	8	6	10	3	4	3	90	19.0	5.67
7.6 - 12.5	14	12	8	17	13	13	16	9	10	7	9	10	11	18	9	8	186	39.3	9.53
12.6 - 18.5	2	2	7	2	11	3	3	9	5	6	10	26	27	18	10	4	145	31.7	14.49
18.6 - 24.5	0	0	2	1	1	1	0	0	1	4	0	10	3	0	0	1	24	5.1	23.79
24.6 - 32.5	0	0	0	0	0	0	0	0	1	0	0	2	0	0	0	1	4	.8	27.94
32.6+	0	0	0	0	0	0	0	0	2	0	0	0	0	0	0	1	3	.6	35.68
TOTAL	24	21	27	27	37	25	26	23	24	20	28	54	52	42	25	18	473	100.0	6.01
PERCENT	5.1	4.4	5.7	5.7	7.8	5.3	5.5	4.9	5.1	4.2	5.9	11.4	11.0	8.9	5.3	3.8	100.0		
AV SPD	8.4	3.8	10.9	9.3	9.5	8.5	9.8	10.5	13.1	12.9	10.5	14.6	11.3	11.0	10.6	12.9			
AVERAGE SPEED FOR THIS TABLE EQUALS	11.1																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	3																		

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 44 OF 48)

MONTH OF DECEMBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE(DEG F/100FT) GREATER THAN -.9 BUT LESS THAN OR EQUAL TO -.8 REQUEST NUMBER 604-43
SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN	
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	0	0	0	0	0	0	0	1	0	0	1	1	1	1	0	0	4	3.9	2.51	
3.6 - 7.5	0	1	0	1	0	0	0	3	2	0	0	1	1	1	1	0	12	11.7	5.60	
7.6 - 12.5	0	2	2	3	2	1	1	0	0	3	2	3	1	1	1	3	33	32.0	10.30	
12.6 - 19.5	4	3	2	0	3	1	0	2	0	0	2	3	3	3	3	2	30	29.1	15.55	
19.6 - 24.5	6	0	0	0	1	0	0	0	0	6	4	0	0	0	6	0	17	16.5	21.37	
24.6 - 32.5	0	0	0	0	2	0	0	0	0	1	2	0	0	0	2	0	7	6.8	27.09	
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00	
TOTAL	12	6	4	4	4	2	1	6	2	10	10	7	6	6	13	6	103	0.0	16.38	
PERCENT	11.7	5.8	3.9	3.9	7.8	1.9	1.0	5.8	1.9	9.7	9.7	6.8	5.8	5.8	12.6	5.8	100.0			
AV SPD	12.1	12.7	12.6	8.5	10.9	14.1	11.3	8.2	6.1	18.7	19.2	10.2	11.3	11.0	10.7	11.7				
AVERAGE SPEED FOR THIS TABLE EQUALS 14.1																				
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 2																				

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE(DEG F/100FT) GREATER THAN -.8 BUT LESS THAN OR EQUAL TO -.3 REQUEST NUMBER 604-43
SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN
CALM	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	.1	.33
CALM+ - 3.5	0	1	1	2	1	0	0	0	2	0	0	1	1	2	1	1	13	1.9	2.32
3.6 - 7.5	3	6	6	7	9	5	2	6	3	5	5	11	2	2	4	4	75	11.3	5.54
7.6 - 12.5	3	12	6	14	13	8	4	7	3	5	22	11	14	13	20	9	155	24.1	10.91
12.6 - 19.5	7	3	9	19	14	12	8	17	17	19	45	17	9	16	22	11	245	35.0	15.39
19.6 - 24.5	0	4	11	12	8	3	3	1	8	16	18	11	4	7	17	1	125	15.0	21.15
24.6 - 32.5	1	1	1	4	4	0	3	1	4	6	6	4	8	3	4	2	52	7.4	27.53
32.6+	0	1	0	0	1	1	1	0	0	1	1	1	2	0	6	0	15	2.1	37.06
TOTAL	15	28	30	58	54	29	21	32	37	52	97	56	40	43	74	28	700	100.0	10.84
PERCENT	2.1	4.0	5.1	8.3	7.7	4.1	3.0	4.6	5.3	7.4	13.9	8.0	5.7	5.1	10.6	4.0	100.0		
AV SPD	12.2	12.1	15.4	14.5	14.1	12.7	17.1	12.5	16.3	17.6	15.9	14.9	16.8	14.8	17.6	12.4			
AVERAGE SPEED FOR THIS TABLE EQUALS 15.2																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 2																			

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 45 OF 48)

MONTH OF DECEMBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0

REQUEST NUMBER 604-43

SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	1	.2	0.30
CALM+ - 3.5	2	1	5	5	3	2	4	0	0	0	1	0	3	2	1	0	29	5.1	2.30
3.6 - 7.5	7	9	6	2	11	9	6	1	5	7	12	9	5	9	6	6	111	19.4	5.26
7.6 - 12.5	6	4	6	6	13	14	13	0	4	6	6	16	20	35	15	8	175	30.6	10.04
12.6 - 18.5	4	4	6	4	1	1	5	2	7	8	13	5	10	29	21	23	143	25.0	14.79
18.6 - 24.5	2	0	0	0	1	1	1	0	1	7	4	5	5	13	15	21	78	13.7	20.39
24.6 - 32.5	0	0	0	0	0	0	0	0	0	1	5	1	2	5	9	10	33	5.3	27.41
32.6+	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	1	.2	33.59
TOTAL	21	14	26	17	29	27	29	3	17	29	42	36	47	93	69	68	571	100.0	8.27
PERCENT	3.7	3.2	4.6	3.0	5.1	4.7	5.1	.5	3.0	5.1	7.4	6.3	8.2	16.3	12.1	11.9	100.0		
AV SPD	9.7	7.8	8.0	8.3	8.1	8.8	9.5	11.4	11.6	13.6	13.8	11.5	12.7	13.7	15.8	17.5			
AVERAGE SPEED FOR THIS TABLE EQUALS 12.6																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 11																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -.9

REQUEST NUMBER 604-43

SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	0	1	0	0	1	0	0	0	1	0	1	1	1	1	2	2	11	7.3	2.90
3.6 - 7.5	2	1	1	3	2	1	0	4	1	3	1	3	1	2	0	2	27	18.0	4.91
7.6 - 12.5	4	3	0	1	6	12	3	3	2	4	5	4	4	3	2	1	57	38.0	9.78
12.6 - 18.5	1	1	2	1	2	1	0	0	2	2	1	2	3	4	1	23	15.3	15.19	
18.6 - 24.5	0	0	0	1	0	1	1	0	5	1	1	2	0	2	3	14	9.3	21.09	
24.6 - 32.5	0	0	0	0	3	2	0	1	0	0	1	1	1	4	0	1	14	9.3	26.73
32.6+	0	0	0	0	0	1	0	0	0	0	0	0	0	3	0	0	4	2.7	34.42
TOTAL	7	6	3	6	14	18	4	8	4	14	11	11	11	16	10	7	150	100.0	8.37
PERCENT	4.7	4.0	2.0	4.0	9.3	12.0	2.7	5.3	2.7	9.3	7.3	7.3	7.3	10.7	6.7	4.7	100.0		
AV SPD	9.3	8.1	12.8	9.7	13.7	13.8	12.9	9.4	6.6	13.7	12.1	10.9	13.8	13.0	13.9	8.9			
AVERAGE SPEED FOR THIS TABLE EQUALS 12.7																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 4																			

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 46 OF 48)

MONTH OF DECEMBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .6

REQUEST NUMBER 604-43

SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOMEAN SPD(MPH)
CALM	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	1	.2	0.33
CALM+ - 3.5	1	1	0	0	0	2	2	0	1	0	1	2	0	0	0	0	10	2.2	2.75
3.6 - 7.5	0	0	0	2	2	2	5	2	2	0	4	2	5	0	2	2	30	6.6	5.32
7.6 - 12.5	3	3	3	2	2	6	6	2	10	8	3	5	4	4	4	3	68	15.0	10.39
12.6 - 18.5	6	7	5	0	9	9	5	16	18	27	16	14	13	15	15	5	181	40.0	15.34
18.6 - 24.5	0	0	3	2	1	3	3	0	14	20	16	5	10	17	10	3	119	26.3	22.21
24.6 - 32.5	0	0	1	5	0	0	1	0	0	6	6	2	7	3	1	0	32	7.1	26.68
32.6+	0	0	0	0	0	0	0	1	2	0	2	1	0	2	3	0	11	2.4	38.06
TOTAL	10	11	15	11	14	22	21	27	47	61	48	31	45	41	35	13	452	100.0	11.85
PERCENT	2.2	2.4	3.3	2.4	3.1	4.9	4.6	5.0	10.4	13.5	10.6	6.9	10.0	9.1	7.7	2.9	100.0		
AV SPD	11.8	12.3	16.9	18.5	13.2	12.7	10.8	16.0	16.8	19.1	18.2	15.8	17.6	19.4	18.2	14.6			
AVERAGE SPEED FOR THIS TABLE EQUALS 15.6																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 1																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 2.2

REQUEST NUMBER 604-43

SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 150 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 150FT ADJUSTED TO 393 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOMEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 3.5	0	0	2	0	0	0	1	1	0	0	0	1	0	0	0	0	4	1.9	2.19
3.6 - 7.5	1	0	1	0	0	0	2	0	4	1	5	2	2	0	2	1	21	10.3	5.42
7.6 - 12.5	3	2	0	4	2	0	3	4	5	3	7	2	4	2	2	2	45	21.4	9.63
12.6 - 18.5	4	2	3	2	7	7	6	5	6	9	11	3	11	8	5	2	91	43.3	15.00
18.6 - 24.5	0	0	3	2	2	1	2	0	5	9	3	2	5	4	4	0	42	20.0	21.02
24.6 - 32.5	0	0	0	0	0	0	1	0	1	2	0	0	0	2	1	0	7	3.4	25.62
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	8	4	7	8	11	8	15	10	21	24	26	10	22	16	14	5	219	0.0	11.22
PERCENT	3.8	1.9	3.3	3.6	5.2	3.8	7.1	4.8	10.0	11.4	12.4	4.8	10.5	7.6	6.7	2.9	100.0		
AV SPD	11.4	10.8	15.8	13.7	15.0	15.3	13.0	11.7	14.0	17.5	12.7	13.0	14.7	17.4	16.0	10.0			
AVERAGE SPEED FOR THIS TABLE EQUALS 14.4																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 0																			

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 47 OF 48)

MONTH OF DECEMBER																					
JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2 SITE MATCH																		REQUEST NUMBER 604-43			
PERIOD OF RECORD FROM 70060101 TO 74083124 SPEED AND DIRECTION FROM 150 LEVEL TEMPERATURE DIFFERENCE BETWEEN 150 AND 35 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT																					
WIND DIRECTION																					
SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)		
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	.2	.33	
CALM+ - 3.5	1	0	0	0	1	0	0	0	0	0	1	1	0	2	2	0	8	8	2.0	2.13	
3.6 - 7.5	5	2	1	1	4	1	1	2	1	5	10	13	9	6	2	4	67	16.5	5.69	5.69	
7.6 - 12.5	7	3	5	5	7	10	9	1	4	14	15	15	20	10	10	10	145	35.6	9.33	9.33	
12.6 - 18.5	3	2	2	3	5	7	8	4	12	15	23	19	12	20	7	4	146	35.9	14.89	14.89	
18.6 - 24.5	1	2	0	3	0	1	1	0	2	4	2	3	2	3	3	1	28	6.9	21.69	21.69	
24.6 - 32.5	0	0	0	0	0	0	0	0	1	6	0	0	0	1	4	0	12	2.9	27.96	27.96	
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.3	0.00	0.00
TOTAL	17	9	8	12	17	19	19	7	20	44	51	51	43	42	28	20	407	0.0	9.00	9.00	
PERCENT	4.2	2.2	2.0	2.9	4.2	4.7	4.7	1.7	4.9	10.8	12.5	12.5	10.5	10.3	6.9	4.9	100.0				
AV SPD	9.6	12.5	10.4	13.7	10.1	12.1	12.4	12.3	14.9	14.8	11.9	11.4	11.0	12.8	13.8	10.3					
AVERAGE SPEED FOR THIS TABLE EQUALS	12.3																				
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION *	0																				

HNP-2-FSAR-2

TABLE 2.3-15 (SHEET 48 OF 48)

MONTH OF DECEMBER																				
JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2 SITE MATCH																		REQUEST NUMBER 604-43		
PERIOD OF RECORD FROM 70060101 TO 74083124 SPEED AND DIRECTION FROM 150 LEVEL TEMPERATURE DIFFERENCE BETWEEN 150 AND 35 SPEED MEASURED AT 150FT ADJUSTED TO 393 FT																				
WIND DIRECTION																				
SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)	
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	.2	.33
0.0 - 3.5	1	0	0	0	1	0	0	0	0	0	1	1	0	2	2	0	8	2.0	2.13	
3.6 - 7.5	5	2	1	1	4	1	1	2	1	5	10	13	9	6	2	4	67	16.5	5.69	
7.6 - 12.5	7	3	5	5	7	10	9	1	4	14	15	15	20	10	10	10	145	35.6	9.33	
12.6 - 18.5	3	2	2	3	5	7	8	4	12	15	23	19	12	20	7	4	146	35.9	14.89	
18.6 - 24.5	1	2	0	3	0	1	1	0	2	4	2	3	2	3	3	1	28	6.9	21.69	
24.6 - 32.5	0	0	0	0	0	0	0	0	1	6	0	0	0	1	4	0	12	2.9	27.96	
32.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.3	0.00
TOTAL	17	9	8	12	17	19	19	7	20	44	51	51	43	42	28	20	407	0.0	9.00	
PERCENT	4.2	2.2	2.0	2.9	4.2	4.7	4.7	1.7	4.9	10.8	12.5	12.5	10.5	10.3	6.9	4.9	100.0			
AV SPD	9.8	12.5	10.4	13.7	10.1	12.1	12.4	12.3	14.9	14.8	11.9	11.4	11.0	12.8	13.8	10.3				
AVERAGE SPEED FOR THIS TABLE EQUALS	12.3																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION *	0																			

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 1 OF 48)

MONTH OF JANUARY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0
SITE HATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70069101 TO 74091124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 75
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GRD MEAN SFD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	0	0	0	1	1	2	0	0	0	0	0	0	0	0	0	0	0	5.0	0.00
1.6 - 2.5	1	1	3	2	3	3	1	0	0	1	0	2	0	1	0	1	19	3.4	2.00
2.6 - 3.5	5	7	7	4	3	0	1	0	0	0	0	2	2	2	1	27	4.8	3.00	
3.6 - 7.5	39	26	38	18	21	8	10	2	6	14	18	16	26	23	25	19	317	56.0	6.44
7.6 - 12.5	18	17	15	22	8	3	1	1	4	8	9	13	10	23	8	15	143	24.3	6.19
12.6 - 18.5	0	1	0	0	0	0	0	0	0	0	1	0	8	13	13	7	76	6.4	14.51
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0	2	0.4	18.77
TOTAL	63	47	59	45	37	19	12	4	10	27	28	28	46	67	47	71	666	100.0	6.80
PERCENT	11.1	7.6	10.4	8.0	6.5	3.4	2.1	.7	1.8	4.8	4.9	4.9	8.1	11.8	8.3	5.6	100.0		
AV SPD	6.3	6.5	6.2	7.2	5.3	4.4	5.9	6.1	6.9	6.7	7.3	7.0	7.9	8.5	8.9	7.5			
AVERAGE SPEED FOR THIS TABLE EQUALS 7.0																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 4																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -0.9
SITE HATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70069101 TO 74091124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 75
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GRD MEAN SFD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	2	0	0	0	0	0	1	1	0	0	0	0	0	1	0	0	0	5.0	0.00
1.6 - 2.5	0	1	1	1	1	0	1	0	0	2	0	0	0	1	0	0	11	4.1	1.00
2.6 - 3.5	3	5	1	2	2	0	0	1	0	0	0	0	1	2	0	0	17	13.8	2.00
3.6 - 7.5	3	5	3	3	6	6	1	1	0	3	4	4	9	5	7	4	64	52.0	6.41
7.6 - 12.5	1	0	2	1	0	1	0	0	1	4	4	4	1	2	1	1	23	18.7	6.57
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	1	0	1	0	1	0	2	2.4	10.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	18.77
TOTAL	9	11	7	9	9	7	3	3	1	9	9	9	12	10	10	0	123	0.0	3.94
PERCENT	7.3	8.9	5.7	7.3	7.3	5.7	2.4	2.4	.8	7.3	7.3	7.3	9.8	8.3	8.1	4.1	100.0		
AV SPD	4.1	3.7	5.5	4.0	4.6	5.6	3.3	3.7	4.6	6.4	6.7	7.0	6.8	4.9	6.2	6.7			
AVERAGE SPEED FOR THIS TABLE EQUALS 5.6																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 1																			

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 2 OF 48)

MONTH OF JANUARY

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.9 BUT LESS THAN OR EQUAL TO -1.9
SITE HATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70060101 TO 74093124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	0	0	0	0	0	1	0	0	0	1	0	0	0	0	0	0	2	2.2	1.47
1.6 - 2.5	2	1	1	2	1	0	1	0	0	3	0	0	0	0	0	0	1	12	13.5
2.6 - 3.5	1	0	2	1	1	0	0	0	0	1	0	0	0	0	0	0	1	7	7.9
3.6 - 7.5	5	5	3	1	5	4	2	1	1	1	2	2	0	5	2	4	43	44.3	5.37
7.6 - 12.5	0	1	1	1	1	2	0	0	0	4	5	0	2	0	2	1	20	22.5	6.11
12.6 - 18.5	0	0	0	0	0	0	0	0	1	1	0	0	0	1	1	0	4	4.5	14.06
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	1	1.1	17.51
TOTAL	8	7	7	5	9	7	3	1	1	10	9	2	2	6	6	7	99	100.0	4.20
PERCENT	9.0	7.9	7.9	5.6	9.0	7.9	3.4	1.1	1.1	11.7	10.1	2.7	2.2	6.7	6.7	7.9	100.0		
AV SPD	4.4	4.2	5.2	4.0	5.2	5.6	3.8	5.9	5.5	6.4	5.6	5.1	9.4	6.7	10.5	4.3			
AVERAGE SPEED FOR THIS TABLE EQUALS	6.0																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	3																		

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.8 BUT LESS THAN OR EQUAL TO -1.3
SITE HATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70060101 TO 74093124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	1	2	3	2	0	0	1	0	1	1	0	0	1	1	2	1	16	2.0	1.75
CALM+ - 1.5	4	1	3	4	3	0	3	1	1	1	1	2	1	1	2	1	29	3.7	1.14
1.6 - 2.5	6	6	7	13	12	2	2	7	2	2	3	6	3	5	5	47	11.0	1.06	
2.6 - 3.5	5	6	9	4	10	2	7	7	6	4	4	4	5	4	5	4	91	11.5	2.33
3.6 - 7.5	26	16	15	29	35	17	27	14	24	40	40	37	21	27	30	76	436	51.5	5.07
7.6 - 12.5	14	2	5	8	5	2	2	0	7	14	12	6	3	4	14	19	171	15.3	9.23
12.6 - 18.5	1	0	0	0	1	0	0	0	1	8	0	0	0	3	11	5	38	4.8	14.32
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	1	1	1.1	15.69
TOTAL	60	29	42	60	66	23	35	29	42	70	68	41	37	48	69	71	789	100.0	3.14
PERCENT	7.6	3.7	5.7	7.6	8.4	2.9	4.4	3.7	5.3	8.9	8.6	5.2	4.7	6.1	8.7	8.9	100.0		
AV SPD	5.2	3.6	4.0	4.5	4.4	5.0	4.1	3.7	5.2	6.8	6.9	5.7	4.6	6.1	7.1	6.7			
AVERAGE SPEED FOR THIS TABLE EQUALS	5.5																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	10																		

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 3 OF 48)

MONTH OF JANUARY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DFG F/10CFT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .8
SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NW*	TOTAL	PERCENT	GEO MEAN SFD(MPH)
CALM	0	2	1	2	0	2	0	0	9	0	3	0	1	2	1	1	15	2.1	1.75
CALM+ - 1.5	1	2	4	1	1	1	1	2	0	1	3	5	0	3	1	6	36	5.1	1.98
1.6 - 2.5	5	2	2	4	9	6	2	4	6	4	5	2	5	4	5	0	65	9.2	1.93
2.6 - 3.5	3	0	2	8	6	11	7	6	6	4	11	6	4	7	2	97	13.8	2.92	
3.6 - 7.5	5	9	3	14	0	25	9	17	30	67	57	22	29	16	21	18	349	49.6	4.94
7.6 - 12.5	1	0	0	0	0	1	0	1	7	36	35	17	3	11	18	12	137	19.5	9.18
12.6 - 18.5	0	0	0	0	0	0	0	0	0	1	0	0	0	0	3	6	4	.6	13.64
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	15	15	12	31	24	49	21	30	49	116	115	47	42	43	56	79	703	0.0	2.95
PERCENT	2.1	2.1	1.7	4.4	3.4	6.8	3.0	4.3	7.0	16.5	16.4	6.7	6.0	6.1	8.0	5.5	100.0		
AV SPD	1.3	3.1	2.3	3.1	3.1	3.9	3.4	4.0	5.2	6.2	6.1	5.5	4.5	5.2	6.4	5.7			
AVERAGE SPEED FOR THIS TABLE	5.1																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	4																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DFG F/10CFT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 2.2
SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NW*	TOTAL	PERCENT	GEO MEAN SFD(MPH)
CALM	3	0	0	1	0	0	1	1	9	0	0	0	3	1	0	0	10	4.5	1.75
CALM+ - 1.5	0	1	1	2	0	1	1	3	0	0	1	0	2	2	1	1	16	7.1	1.02
1.6 - 2.5	1	2	3	2	4	0	4	4	4	3	4	1	3	2	3	1	41	18.3	2.54
2.6 - 3.5	1	0	0	2	9	7	9	4	3	5	5	3	7	2	6	3	68	30.4	2.97
3.6 - 7.5	0	0	4	4	0	3	0	11	20	13	6	7	6	0	0	0	95	37.9	4.48
7.6 - 12.5	0	0	0	0	0	0	0	0	2	0	2	0	0	0	0	0	4	1.8	8.43
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	5	3	8	11	13	11	17	20	19	30	23	12	22	13	10	5	274	0.0	2.21
PERCENT	2.2	2.7	3.6	4.9	5.8	4.9	7.6	8.9	8.3	13.4	10.3	5.4	9.8	5.8	4.5	2.2	100.0		
AV SPD	1.2	2.1	2.2	2.0	2.6	3.1	2.7	2.9	3.7	4.7	3.7	4.7	2.9	2.8	2.6	2.4			
AVERAGE SPEED FOR THIS TABLE	3.3																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	6																		

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 4 OF 48)

MONTH OF JANUARY

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2
GULF HATCH

PERIOD OF RECORD FROM 70061101 TO 74063124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

REQUEST NUMBER 604-46

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNE	TOTAL	PERCENT	GRD MEAN SPD(MPH)
CALM	0	0	1	0	0	0	0	0	0	0	0	2	0	0	0	1	4	2.3	0.10
CALM+ 1.5	0	2	1	2	1	0	1	2	1	1	1	2	0	0	1	7	18	10.4	1.05
1.6 - 2.5	2	1	4	1	1	5	3	1	4	2	0	4	3	2	5	5	43	24.9	1.95
2.6 - 3.5	3	2	4	1	1	2	2	2	5	3	1	3	4	7	3	2	49	28.7	2.17
3.6 - 7.5	1	0	1	3	3	1	1	2	5	7	15	6	2	3	4	7	57	32.9	4.15
7.6 - 12.5	0	0	0	0	0	0	0	0	0	2	0	0	0	0	0	0	2	1.2	7.49
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	6	5	11	7	6	8	7	7	15	15	17	17	13	12	13	14	173	9.0	2.10
PERCENT	3.5	2.9	6.4	4.0	3.5	4.6	4.0	4.0	8.7	8.7	9.8	9.8	7.5	6.9	7.5	8.1	100.0		
AV SPD	2.9	2.1	2.4	2.9	3.3	2.6	2.2	3.0	3.1	4.4	4.6	3.0	3.0	3.2	2.8	2.2			
AVERAGE SPEED FOR THIS TABLE EQUALS	3.1																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	0																		

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 5 OF 48)

MONTH OF FEBRUARY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0
SITE HATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	2	3	.4	1.11
CALM+ - 1.5	2	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	3	.4	1.11
1.6 - 2.5	0	0	1	5	0	0	1	0	1	0	1	0	0	1	2	2	20	2.9	2.15
2.6 - 3.5	5	2	5	2	2	2	1	0	1	0	0	0	3	4	1	4	32	4.6	2.68
3.6 - 7.5	20	14	31	44	33	13	4	2	2	8	14	13	16	31	22	15	242	40.8	5.62
7.6 - 12.5	3	7	7	9	5	2	13	2	3	10	20	40	21	56	58	72	288	41.7	6.89
12.6 - 18.5	0	0	5	2	0	0	0	1	1	4	4	14	6	14	5	2	57	8.2	14.13
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	1	2	3	1	6	.9	22.28
TOTAL	30	29	49	60	40	17	19	5	5	22	39	67	47	109	92	58	691	100.0	5.92
PERCENT	4.3	4.2	7.1	8.7	5.8	2.5	2.7	.7	1.2	3.2	5.6	9.7	6.8	15.8	13.3	8.4	100.0		
AV SPD	5.7	5.8	6.7	5.8	6.0	5.9	6.3	9.1	7.0	9.7	8.5	9.8	8.7	9.3	9.5	7.7			
AVERAGE SPEED FOR THIS TABLE EQUALS	4.0																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	20																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -1.9
SITE HATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
1.6 - 2.5	1	0	0	3	1	0	0	0	0	0	0	0	0	0	0	1	5	0.6	0.55
2.6 - 3.5	0	1	0	1	0	0	0	0	1	1	1	2	0	0	1	0	7	0.9	2.17
3.6 - 7.5	1	2	1	6	6	1	0	2	2	6	2	4	1	2	3	2	40	32.0	5.62
7.6 - 12.5	0	0	1	4	0	0	4	4	5	4	3	6	7	3	8	6	55	44.0	6.82
12.6 - 18.5	0	0	0	0	0	0	1	1	2	0	3	1	0	1	3	0	12	9.6	13.77
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	2	1.6	16.74
TOTAL	2	3	3	14	7	1	5	7	10	10	9	14	8	6	17	9	125	100.0	6.24
PERCENT	1.6	2.4	2.4	11.2	5.6	.8	4.0	5.6	8.0	8.0	7.2	11.2	6.4	4.8	13.6	7.2	100.0		
AV SPD	3.3	4.6	5.7	5.8	5.3	6.8	10.2	9.7	9.3	7.1	9.5	9.2	9.5	8.9	9.8	7.7			
AVERAGE SPEED FOR THIS TABLE EQUALS	8.2																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	8																		

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 6 OF 48)

MONTH OF FEBRUARY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.9 BUT LESS THAN OR EQUAL TO -1.1
 REQUEST NUMBER 604-44
 SITE MATCH
 PERIOD OF RECORD FROM 70060101 TO 74043124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNW	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GRD YEAR SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	(.0)
CALM+ - 1.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	(.0)
1.6 - 2.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	(.0)
2.6 - 3.5	0	1	1	1	0	0	0	0	0	0	0	0	1	0	0	0	2	2.6	2.62
3.6 - 7.5	0	0	2	4	1	0	1	2	2	2	4	1	2	1	3	1	24	31.6	5.73
7.6 - 12.5	0	0	1	0	3	1	3	2	4	1	2	2	6	5	4	3	36	47.4	6.64
12.6 - 18.5	0	0	0	0	0	0	1	0	2	1	1	0	2	0	0	1	7	9.2	13.55
18.6+	0	0	0	0	0	0	1	0	0	0	0	0	4	0	0	4	5.1	22.15	
TOTAL	0	1	4	6	4	1	3	7	8	4	7	1	7	11	8	6	76	100.0	7.13
PERCENT	0.0	1.3	5.3	7.9	5.3	1.3	3.9	9.2	10.5	5.3	9.2	3.9	9.2	14.5	10.5	7.9	100.0		
AV SPD	0.0	3.0	6.2	4.8	4.6	9.0	9.5	9.0	9.9	9.4	8.3	7.3	8.2	13.9	8.3	9.7			
AVERAGE SPEED FOR THIS TABLE EQUALS 9.2																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 3																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.8 BUT LESS THAN OR EQUAL TO -1.3
 REQUEST NUMBER 604-44
 SITE MATCH
 PERIOD OF RECORD FROM 70060101 TO 74043124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNW	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GRD YEAR SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	1	2	.3	(.0)
CALM+ - 1.5	0	1	2	0	0	1	1	0	1	3	0	0	0	1	0	1	10	1.6	1.12
1.6 - 2.5	2	2	6	7	3	4	3	0	0	0	1	2	1	2	2	0	31	4.6	2.04
2.6 - 3.5	2	7	5	7	7	0	5	1	2	2	3	2	0	0	3	4	42	6.2	2.95
3.6 - 7.5	9	12	29	48	27	22	13	13	21	29	40	14	15	18	19	12	340	50.0	5.70
7.6 - 12.5	0	0	0	16	17	7	1	4	13	16	28	11	13	22	24	0	127	21.4	6.32
12.6 - 18.5	0	0	0	0	2	0	1	1	6	2	1	5	4	18	3	0	42	6.2	14.54
18.6+	0	0	0	0	0	0	0	0	0	1	0	8	7	3	1	0	20	2.9	15.91
TOTAL	13	27	50	70	56	34	22	19	42	54	73	41	40	64	57	27	430	100.0	5.02
PERCENT	1.9	4.0	7.4	10.3	8.2	5.1	3.2	2.8	6.2	7.9	10.7	6.0	5.9	9.4	7.6	3.4	100.0		
AV SPD	4.5	5.0	5.4	6.2	6.1	5.5	4.4	6.6	7.6	7.1	6.8	10.1	10.1	10.4	8.4	5.2			
AVERAGE SPEED FOR THIS TABLE EQUALS 7.3																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 13																			

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 7 OF 48)

MONTH OF FEBRUARY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 1.0 BUT LESS THAN OR EQUAL TO 1.9

SITE MATCH
PERIOD OF RECORD FROM 70360101 TO 74093124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

REQUEST NUMBER 604-45

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	1	1	0	0	0	0	0	0	0	0	0	0	1	0	1	0	4	1.6	1.35
CALM+ - 1.5	3	1	1	1	1	1	1	1	0	2	0	2	2	0	2	0	19	3.4	1.55
1.6 - 2.5	1	1	2	4	3	3	2	0	2	3	0	1	2	1	1	1	29	5.5	2.05
2.6 - 3.5	2	4	8	7	9	7	4	7	4	1	5	6	4	3	1	4	67	12.8	2.83
3.6 - 7.5	11	10	18	14	12	18	25	21	18	29	37	25	28	27	23	8	324	61.7	4.56
7.6 - 12.5	0	0	0	0	0	1	1	4	15	6	9	6	5	12	13	0	74	14.1	6.19
12.6 - 18.5	0	0	0	0	0	0	0	0	1	1	0	1	0	3	3	0	9	1.7	12.84
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	18	17	29	22	25	25	35	33	40	42	54	40	41	47	44	17	522	0.0	3.88
PERCENT	3.4	3.2	5.6	4.2	4.8	4.8	6.7	6.3	7.6	8.0	10.3	7.6	7.8	9.0	8.4	3.3	100.0		
AV SPD	3.7	3.8	4.0	3.9	3.6	4.2	4.3	5.4	6.8	5.5	5.5	5.4	5.0	6.7	6.6	4.6			
AVERAGE SPEED FOR THIS TABLE EQUALS	5.3																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	3																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 1.0 BUT LESS THAN OR EQUAL TO 2.2

SITE MATCH
PERIOD OF RECORD FROM 70360101 TO 74093124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	1	0	1	1	7	1.8	1.35
CALM+ - 1.5	0	1	0	0	1	0	2	1	2	1	0	0	4	0	0	0	12	7.3	1.55
1.6 - 2.5	1	1	1	1	2	1	2	0	2	1	1	0	2	0	3	3	21	12.3	1.98
2.6 - 3.5	1	2	0	2	5	15	1	4	4	3	1	5	4	6	0	0	53	31.0	2.83
3.6 - 7.5	2	1	0	0	1	5	9	7	7	9	13	12	9	5	4	1	91	47.4	4.56
7.6 - 12.5	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	1	1.6	7.76
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	4	5	1	2	9	21	14	8	15	15	15	17	20	11	8	0	171	0.0	2.82
PERCENT	2.3	2.9	0.6	1.8	5.3	12.3	8.2	4.7	9.8	8.8	8.8	9.9	11.7	6.4	4.7	0.0	100.0		
AV SPD	1.4	2.0	1.8	2.5	2.7	3.4	3.7	3.4	3.2	4.5	4.6	4.5	3.0	3.6	2.8	2.1			
AVERAGE SPEED FOR THIS TABLE EQUALS	3.6																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	3																		

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 8 OF 48)

MONTH OF FEBRUARY

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (1000 F/100FT) GREATER THAN 2.2
SITE HATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70060101 TO 74003124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED (MPH)	N	NE	E	SE	S	SW	W	NW	TOTAL	PERCENT	GR. MEAN SPD (MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0.0
CALM+ - 1.5	4	1	0	0	0	0	0	0	5	17.7	1.2
1.6 - 2.5	3	5	4	1	2	1	2	1	22	72.0	1.51
2.6 - 3.5	4	0	1	3	6	1	4	5	24	79.0	2.55
3.6 - 7.5	1	0	0	1	2	4	2	3	13	41.0	4.58
7.6 - 12.5	0	0	0	0	0	0	0	0	0	0.0	0.00
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	12	6	5	6	10	6	10	5	64	200.0	2.05
PERCENT	5.6	2.9	2.3	2.8	4.7	2.8	4.7	2.3	100.0		
AV SPD	2.1	1.6	2.3	2.8	3.0	3.7	2.6	3.6			

AVERAGE SPEED FOR THIS TABLE EQUALS 2.2
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 1

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 9 OF 48)

MONTH OF MARCH

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0
SITE HATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70060101 TO 74093124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0.2	1.11
1.6 - 2.5	4	0	2	0	1	1	0	1	1	1	1	2	1	0	0	0	18	2.1	2.10
2.6 - 3.5	3	1	1	9	5	2	3	1	0	0	3	3	1	3	5	1	41	4.8	2.97
3.6 - 7.5	14	2	17	31	52	24	23	15	7	16	22	20	25	26	32	18	150	40.6	5.47
7.6 - 12.5	4	3	12	8	15	21	17	9	13	37	23	25	48	27	29	12	302	35.1	6.46
12.6 - 18.5	0	0	0	0	0	0	0	1	5	17	3	3	32	54	11	3	129	14.9	14.53
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	10	11	0	0	21	2.4	19.77
TOTAL	25	12	32	48	73	49	43	27	26	71	51	52	118	123	76	77	863	100.0	6.64
PERCENT	2.9	1.4	3.7	5.6	8.5	5.7	5.0	3.1	3.0	8.2	5.9	6.0	13.7	14.3	8.8	4.3	100.0		
AV SPD	4.9	6.0	6.7	5.4	6.1	7.1	7.3	7.1	9.1	10.1	7.8	8.0	11.0	12.0	8.2	7.1			
AVERAGE SPEED FOR THIS TABLE EQUALS	8.6																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	30																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -0.9
SITE HATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70060101 TO 74093124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	1	1	0	2	0	0	0	0	0	0	0	0	0	0	0	0	4	2.7	1.25
1.6 - 2.5	1	0	0	0	0	0	0	0	1	0	0	0	1	0	1	0	6	4.0	1.67
2.6 - 3.5	2	0	0	1	2	0	0	1	0	0	0	1	1	1	1	1	11	7.4	2.83
3.6 - 7.5	4	3	8	16	9	5	4	3	1	2	3	7	5	2	1	1	74	49.7	6.26
7.6 - 12.5	0	0	5	1	1	2	2	1	2	4	2	4	5	5	4	7	45	33.2	6.52
12.6 - 18.5	0	0	0	0	0	0	0	1	3	0	0	1	0	2	1	1	9	6.3	14.65
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	8	4	13	27	12	7	6	6	7	6	5	13	12	10	8	10	149	9.0	4.64
PERCENT	5.4	2.7	8.7	14.8	8.1	4.7	4.0	4.0	4.7	4.0	3.4	8.7	8.1	6.7	5.4	6.7	100.0		
AV SPD	3.8	3.0	7.4	4.6	4.9	7.2	6.6	6.9	9.9	9.0	7.8	7.3	6.5	10.0	8.4	9.1			
AVERAGE SPEED FOR THIS TABLE EQUALS	6.9																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	8																		

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 10 OF 48)

MONTH OF MARCH

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.9 BUT LESS THAN OR EQUAL TO -1.8
SITE HATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70060101 TO 74093124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+ - 1.5	0	1	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	2	1.6
1.6 - 2.5	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	1.6
2.6 - 3.5	0	1	0	1	1	0	1	0	1	0	1	0	0	0	0	0	0	4	3.1
3.6 - 7.5	2	2	2	2	5	5	4	4	1	4	3	4	6	3	0	3	58	45.0	5.44
7.6 - 12.5	0	0	1	1	3	3	0	0	4	4	7	4	4	1	3	3	44	34.1	9.13
12.6 - 18.5	0	0	1	0	0	0	0	0	1	1	2	0	3	0	1	2	13	10.1	14.43
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0	2	1.6	19.26	
TOTAL	6	4	4	4	9	8	6	5	6	16	12	14	18	5	4	8	129	100.0	6.05
PERCENT	4.7	3.1	3.1	3.1	7.0	6.2	4.7	3.9	4.7	12.4	9.3	10.9	14.0	3.9	3.1	6.2	100.0		
AV SPD	6.3	4.6	4.3	4.3	6.5	6.4	4.8	4.7	9.8	8.5	8.9	6.6	9.8	9.9	10.2	4.6			
AVERAGE SPEED FOR THIS TABLE EQUALS	7.7																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	4																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.8 BUT LESS THAN OR EQUAL TO -1.3
SITE HATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70060101 TO 74093124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	2	0	0	0	0	0	1	0	0	0	0	3	1.5	1.13
CALM+ - 1.5	0	0	0	0	3	2	1	0	0	2	0	0	1	0	3	1	16	2.5	1.11
1.6 - 2.5	2	1	2	2	3	4	1	2	2	5	1	0	3	1	3	0	32	4.9	1.86
2.6 - 3.5	6	2	4	7	6	5	3	2	3	2	3	3	2	2	1	2	49	7.5	2.92
3.6 - 7.5	23	11	14	10	24	24	20	13	14	14	33	11	27	13	19	15	113	44.1	5.18
7.6 - 12.5	2	2	12	5	6	9	1	12	20	32	10	13	13	14	16	17	27	27.2	6.76
12.6 - 18.5	0	0	0	0	1	4	0	0	4	5	9	2	8	16	3	1	53	8.1	14.49
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	3	5	0	0	8	1.2	21.45
TOTAL	33	17	24	27	43	50	34	14	39	72	78	27	57	50	43	75	651	100.0	4.62
PERCENT	5.1	2.6	4.2	4.1	6.6	7.7	5.2	2.4	6.0	11.1	12.0	4.1	8.8	7.7	6.6	5.4	100.0		
AV SPD	5.1	5.2	6.0	4.7	4.8	6.0	5.9	4.6	7.4	7.0	7.9	7.4	8.5	11.1	6.9	7.7			
AVERAGE SPEED FOR THIS TABLE EQUALS	7.0																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	14																		

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 11 OF 48)

MONTH OF MARCH

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .6 REQUEST NUMBER 604-44
SITE MATCH
PERIOD OF RECORD FROM 70060101 TO 74003124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPD(MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW			
CALM	0	0	0	0	0	0	0	0	1	0	0	0	0	1	0	0	2	.3	.30
CALM+ - 1.5	1	1	3	1	1	1	0	0	1	1	0	1	2	1	2	1	17	2.7	.92
1.6 - 2.5	2	0	1	2	3	3	3	6	1	2	2	1	2	1	1	1	31	5.0	1.69
2.6 - 3.5	1	4	1	6	7	5	3	5	7	3	14	4	4	2	3	7	72	11.6	3.92
3.6 - 7.5	12	0	2	7	12	20	22	31	39	55	56	35	37	17	31	28	404	65.2	5.02
7.6 - 12.5	1	0	1	2	0	0	2	4	8	12	10	6	11	13	10	8	58	14.2	8.91
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	2	3	2	0	5	.8
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	.2
TOTAL	17	5	8	18	23	29	32	44	57	72	82	48	57	40	47	41	620	100.0	3.93
PERCENT	2.7	.8	1.3	2.9	3.7	4.7	5.2	7.1	9.2	11.5	13.2	7.7	9.2	6.5	7.6	6.6	100.0		
AV SPD	4.9	2.7	2.9	4.0	3.7	4.2	4.9	4.5	5.2	5.8	5.2	5.3	5.9	7.3	5.9	5.0			

AVERAGE SPEED FOR THIS TABLE EQUALS 5.3
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 6

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .6 BUT LESS THAN OR EQUAL TO 2.2 REQUEST NUMBER 604-44
SITE MATCH
PERIOD OF RECORD FROM 70060101 TO 74003124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPD(MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW			
CALM	0	0	0	1	2	2	1	0	0	0	1	0	0	1	2	1	11	4.7	.35
CALM+ - 1.5	0	0	2	2	1	1	0	1	0	1	0	0	1	0	1	1	11	4.7	.97
1.6 - 2.5	0	0	1	0	3	3	1	0	1	0	1	2	4	1	0	1	17	7.3	1.66
2.6 - 3.5	0	2	2	7	6	6	2	2	1	2	5	5	6	1	4	1	48	20.9	2.66
3.6 - 7.5	0	2	1	4	2	1	3	5	29	24	30	15	20	6	1	2	145	62.0	4.95
7.6 - 12.5	0	0	0	0	0	0	0	0	0	0	1	1	0	0	0	0	2	.9	2.15
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	0	4	6	10	14	13	9	9	31	27	37	22	29	12	9	5	234	100.0	2.26
PERCENT	0.0	1.7	2.6	4.3	6.0	5.6	3.7	3.4	13.2	11.5	15.8	9.4	12.4	5.1	3.8	2.1	100.0		
AV SPD	0.0	3.4	2.3	2.6	2.2	2.3	3.1	4.0	5.1	4.9	4.8	4.4	4.5	3.7	2.2	2.7			

AVERAGE SPEED FOR THIS TABLE EQUALS 4.0
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 3

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 12 OF 48)

MONTH OF MARCH

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2
SITE WATCH

PCFUFST NUMBER 604-44

PERIOD OF RECORD FROM 70960101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	N*W	TOTAL	PERCENT	GFD	MEAN SFD(MPH)
CALM	0	0	1	0	1	0	1	0	0	1	1	0	0	0	0	0	5	2.4		0.0
CALM+ 1.5	3	2	2	3	4	1	2	0	1	0	1	2	2	0	1	0	24	11.5		0.02
1.6 - 2.5	1	2	3	1	0	1	2	1	2	3	5	0	8	5	1	4	39	18.7		2.02
2.6 - 3.5	1	1	1	1	1	3	2	2	4	5	11	7	4	7	5	2	57	27.3		2.01
3.6 - 7.5	2	0	0	1	1	6	4	4	22	13	17	10	2	0	0	0	84	40.2		4.62
7.6 - 12.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0		0.0
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0		0.0
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0		0.0
TOTAL	7	5	7	6	7	11	11	7	11	31	31	21	24	14	7	9	209	0.0		2.11
PERCENT	3.3	2.4	3.1	2.9	3.1	5.3	5.3	3.3	5.3	14.8	14.8	10.0	11.5	6.7	3.3	4.3	100.0			
AV SPD	2.3	1.7	1.7	1.8	1.5	3.4	3.0	3.9	3.4	4.3	3.4	3.7	3.5	3.1	2.6	2.9				

AVERAGE SPEED FOR THIS TABLE EQUALS 3.3
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 7

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 13 OF 48)

MONTH OF APRIL

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0
SITE HATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70061101 TO 74043124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPEED(MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSW	S	SSW	SW	WSW	W	WNW	NW				
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	
CALM+ - 1.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	
1.6 - 2.5	0	1	1	1	1	0	0	1	0	1	1	1	2	2	2	14	1.6	2.15	
2.6 - 3.5	4	1	1	2	5	1	0	1	1	3	1	4	2	2	2	15	3.0	3.29	
3.6 - 7.5	17	12	11	27	34	19	13	10	9	27	24	24	25	34	33	200	34.3	5.57	
7.6 - 12.5	4	4	4	5	19	34	34	16	13	12	24	40	42	69	54	17	41.4	9.51	
12.6 - 18.5	0	2	2	0	4	3	1	1	1	6	7	19	21	17	6	1	31	10.1	
18.6+	0	0	0	0	0	0	0	0	0	1	2	0	0	0	0	0	3	20.50	
TOTAL	25	20	19	31	63	57	52	27	24	64	70	84	93	124	97	45	900	6.76	
PERCENT	2.8	2.2	2.1	3.4	7.0	6.3	5.8	3.0	2.7	7.7	7.8	9.3	10.3	13.8	10.9	5.0	100.0		
AV SPD	5.5	6.5	6.5	6.2	7.2	8.5	8.8	8.1	7.6	8.3	8.5	9.6	9.7	9.1	8.4	6.0			
AVERAGE SPEED FOR THIS TABLE EQUALS 4.3																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 41																			

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -0.9
SITE HATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70061101 TO 74043124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPEED(MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSW	S	SSW	SW	WSW	W	WNW	NW				
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	
CALM+ - 1.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	
1.6 - 2.5	0	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	
2.6 - 3.5	1	0	0	1	1	0	0	0	0	1	1	0	1	0	0	6	4.5	2.77	
3.6 - 7.5	3	0	1	4	10	6	7	4	2	5	7	7	5	9	5	72	53.7	5.46	
7.6 - 12.5	1	0	1	0	1	2	5	2	1	5	6	4	3	7	1	1	43	20.9	
12.6 - 18.5	0	1	0	0	0	2	1	0	0	1	2	0	0	0	0	0	0	0.0	
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	
TOTAL	5	2	2	5	12	10	17	6	4	12	17	6	12	16	6	1	114	0.0	
PERCENT	3.7	1.5	2.2	3.7	9.0	7.5	12.7	4.5	3.0	9.0	12.7	4.5	9.0	11.9	4.5	0.7	100.0		
AV SPD	5.2	7.6	5.7	4.1	5.6	8.2	7.1	7.0	5.1	8.4	7.8	9.0	8.0	7.4	6.7	12.1			
AVERAGE SPEED FOR THIS TABLE EQUALS 7.2																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 2																			

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 14 OF 48)

MONTH OF APRIL

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .9 BUT LESS THAN OR EQUAL TO .9 REQUEST NUMBER 604-44
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNW	NW	ENE	E	ESE	SE	SSF	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)	
CALM	0	0	0	0	0	3	3	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	1	0	0	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2.9	1.45
1.6 - 2.5	0	0	0	1	0	0	1	0	1	0	1	0	0	0	0	0	2	6	5.5	1.66
2.6 - 3.5	1	1	0	2	1	0	0	0	0	0	0	0	1	0	0	0	0	6	5.5	2.07
3.6 - 7.5	1	2	0	5	6	4	2	1	4	7	2	3	2	5	2	1	47	43.1	5.55	
7.6 - 12.5	0	0	0	0	0	7	1	0	1	2	6	4	2	1	0	1	31	34.9	6.15	
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	3	3	2	0	1	0	9	6.3	14.57	
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.00	
TOTAL	3	2	0	10	9	11	4	1	6	9	12	14	13	7	4	7	109	100.0	6.31	
PERCENT	2.9	2.0	0.0	9.2	8.1	10.1	3.7	.9	5.5	8.3	11.0	12.8	11.9	6.4	3.7	2.9	100.0			
AV SPD	2.9	3.7	0.0	4.0	6.1	8.6	5.2	5.1	5.8	6.6	10.0	10.3	8.5	7.3	8.5	3.1				
AVERAGE SPEED FOR THIS TABLE EQUALS 7.1																				
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 2																				

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO .8 REQUEST NUMBER 604-44
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNW	NW	ENE	E	ESE	SE	SSF	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)	
CALM	0	0	0	0	0	1	3	0	0	0	0	0	0	0	0	0	0	1	.2	.10
CALM+ - 1.5	0	2	1	1	1	3	0	2	1	0	0	1	1	0	2	0	13	2.0	1.12	
1.6 - 2.5	2	0	0	1	1	1	0	3	1	3	3	3	0	1	3	0	22	3.7	1.55	
2.6 - 3.5	3	7	4	4	9	2	5	3	3	5	2	2	1	0	2	2	51	9.1	3.00	
3.6 - 7.5	15	10	9	14	24	24	18	11	22	14	29	26	26	24	7	13	112	52.4	6.23	
7.6 - 12.5	7	7	7	4	9	13	7	2	4	19	29	22	10	21	8	1	121	28.9	9.17	
12.6 - 18.5	0	0	0	0	4	0	0	0	0	6	7	1	1	0	0	0	23	3.4	14.65	
18.6+	0	0	0	0	0	0	0	0	0	0	1	0	1	0	0	0	2	1.3	19.16	
TOTAL	27	22	17	32	49	46	30	21	31	67	71	65	40	47	22	16	509	100.0	4.92	
PERCENT	4.6	3.7	2.9	5.4	8.1	7.8	5.1	3.5	5.2	11.3	12.0	9.3	6.5	7.9	3.7	2.7	100.0			
AV SPD	6.1	4.7	5.5	6.0	6.1	6.9	5.8	4.6	5.5	7.2	8.1	7.0	6.7	7.1	5.9	5.4				
AVERAGE SPEED FOR THIS TABLE EQUALS 6.5																				
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 5																				

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 15 OF 48)

MONTH OF APRIL

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .7 REQUEST NUMBER 604-44
SITE HATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN
CALM	1	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	2	.3	1.30
CALM+ - 1.5	2	0	1	1	1	2	1	2	0	2	0	1	2	0	0	0	15	2.6	1.50
1.6 - 2.5	1	1	2	6	9	2	3	1	3	3	2	2	2	2	0	2	42	7.3	2.02
2.6 - 3.5	1	2	4	10	14	6	11	9	7	7	9	9	3	1	2	2	131	17.6	2.99
3.6 - 7.5	6	0	7	16	14	24	31	25	27	53	60	36	21	25	13	2	366	43.8	4.98
7.6 - 12.5	0	0	0	0	0	0	3	2	3	5	19	12	3	0	0	1	48	6.4	6.71
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	11	3	19	34	38	34	49	39	40	79	90	60	31	28	15	12	574	100.0	3.79
PERCENT	1.9	.5	3.3	5.9	6.6	5.9	8.5	6.8	7.0	12.7	15.7	10.5	5.4	4.9	2.6	2.3	100.0		
AV SPD	2.8	2.5	3.5	3.4	3.3	4.2	4.5	4.3	4.9	5.2	6.1	5.6	5.0	4.7	5.0	4.5			
AVERAGE SPEED FOR THIS TABLE EQUALS	4.8																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	2																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .4 BUT LESS THAN OR EQUAL TO 2.2 REQUEST NUMBER 604-44
SITE HATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN
CALM	0	0	2	0	0	1	0	1	0	0	1	2	0	0	1	0	9	3.5	1.30
CALM+ - 1.5	0	2	2	2	1	1	1	2	1	0	0	1	2	1	0	0	18	7.8	1.59
1.6 - 2.5	2	2	0	2	5	2	5	1	3	0	2	3	2	2	2	2	37	16.0	2.05
2.6 - 3.5	0	1	1	2	5	8	7	4	3	2	5	4	3	3	1	2	51	22.1	3.03
3.6 - 7.5	3	2	4	2	2	4	5	6	9	19	23	6	19	3	5	3	114	49.4	4.76
7.6 - 12.5	0	0	0	0	0	0	0	1	0	0	0	1	1	0	0	0	3	1.3	6.21
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	5	7	9	10	13	16	19	15	15	21	31	17	26	10	10	8	231	100.0	3.79
PERCENT	2.2	3.0	3.9	4.3	5.6	6.9	7.8	6.5	6.5	9.1	13.4	7.4	11.3	4.3	4.3	3.5	100.0		
AV SPD	2.6	2.8	2.6	2.4	2.7	2.9	3.1	4.0	4.0	5.0	4.2	3.5	4.6	3.2	3.2	3.1			
AVERAGE SPEED FOR THIS TABLE EQUALS	3.7																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	1																		

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 16 OF 48)

MONTH OF APRIL

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74081124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 16
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

REQUEST NUMBER 604-44

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPD(MPH)	
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW				
CALM	2	0	1	0	0	0	0	0	1	0	0	1	0	0	0	0	0	5	2.4	0.70
CALM+ - 1.5	7	2	0	2	3	1	9	2	1	1	2	7	1	0	1	1	1	25	12.2	0.75
1.6 - 2.5	2	1	5	0	0	3	3	1	3	4	6	0	2	2	0	1	1	33	16.1	1.09
2.6 - 3.5	2	1	1	0	3	1	2	4	3	7	2	6	6	6	1	0	0	79	19.0	2.07
3.6 - 7.5	0	1	2	1	3	3	4	1	8	15	30	16	12	4	2	0	0	102	49.8	4.64
7.6 - 12.5	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	1	.5	0.55
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	13	5	9	3	5	7	9	8	16	23	40	25	21	12	4	1	0	305	6.6	2.02
PERCENT	6.3	2.4	4.4	1.5	4.4	3.4	4.4	3.9	7.4	11.2	19.5	12.2	10.2	5.9	2.0	.5	0	100.0		
AV SPD	1.3	2.0	2.6	1.9	2.8	2.8	3.0	2.3	3.3	4.3	4.2	3.9	4.0	3.2	3.2	1.5				
AVERAGE SPEED FOR THIS TABLE EQUALS																2.4				
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =																1.				

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 17 OF 48)

MONTH OF MAY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0
SITE HATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPD(MPH)		
	N	NNF	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW					
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	.1	1.20
1.6 - 2.5	0	0	3	1	1	1	0	0	1	1	1	0	0	0	0	0	0	0	7	1.2	2.10
2.6 - 3.5	7	4	4	2	0	2	4	1	1	1	2	1	0	0	0	0	0	0	27	4.3	7.80
3.6 - 7.5	30	22	24	21	29	11	11	19	23	24	30	43	41	5	10	5	57	5.9	301	4.5	14.00
7.6 - 12.5	11	2	7	1	7	19	14	18	14	18	32	37	41	51	29	6	72	14.0	220	3.3	11.00
12.6 - 18.5	0	0	0	0	0	2	3	0	2	16	6	1	4	6	3	1	41	4.3	140	2.0	6.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	48	28	35	25	37	34	29	38	47	86	71	83	90	135	126	47	360	0.0	6.34		
PERCENT	5.0	3.0	3.6	2.6	3.9	3.5	3.3	4.0	4.9	9.0	7.4	8.5	9.4	14.1	13.1	4.9	100.0				
AV SPD	5.9	5.3	5.2	5.4	6.3	7.6	7.2	7.7	7.2	9.0	8.1	7.6	7.8	7.3	6.4	5.7					
AVERAGE SPEED FOR THIS TABLE EQUALS 7.1																					
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 32																					

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -.9
SITE HATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPD(MPH)		
	N	NNF	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW					
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	1	.7	1.14
1.6 - 2.5	1	2	0	0	2	0	2	1	0	1	1	0	0	0	0	0	0	0	7	1.2	2.00
2.6 - 3.5	2	2	0	0	0	1	1	0	0	1	2	0	2	0	0	0	0	0	12	1.8	2.80
3.6 - 7.5	3	4	1	2	5	3	5	6	9	8	11	5	8	4	7	3	44	5.9	118	11.8	20.00
7.6 - 12.5	1	1	1	0	2	1	3	2	1	4	10	4	3	0	2	0	35	22.9	614	3.14	10.00
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	7	9	2	4	7	7	10	8	11	15	24	13	13	4	15	4	153	0.0	4.54		
PERCENT	4.6	5.0	1.3	2.6	4.6	4.6	6.5	5.2	7.2	9.8	15.7	8.5	8.5	2.6	9.8	2.6	100.0				
AV SPD	4.4	4.6	7.2	3.7	6.1	4.8	6.3	6.3	5.9	5.9	6.5	4.5	5.7	4.9	4.8	4.7					
AVERAGE SPEED FOR THIS TABLE EQUALS 5.9																					
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 6																					

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 18 OF 48)

MONTH OF MAY

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.9 BUT LESS THAN OR EQUAL TO -1.8

REQUEST NUMBER 604-44

SITE HATCH

PERIOD OF RECORD FROM 70069101 TO 74093124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED (MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NW	TOTAL	PERCENT	GEOM MEAN
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	3	2.8
1.6 - 2.5	0	1	0	0	1	1	3	1	0	0	0	0	0	0	0	0	1	8	7.4
2.6 - 3.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2.00
3.6 - 7.5	3	3	3	1	7	7	1	0	0	1	2	0	2	2	1	3	12	11.1	3.00
7.6 - 12.5	1	0	0	0	0	0	0	0	0	4	4	10	0	1	4	7	5	56	51.9
12.6 - 18.5	0	0	2	1	2	3	2	1	0	7	2	7	0	1	2	0	23	21.3	9.33
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	5	4.6	14.90
TOTAL	5	4	5	2	10	9	3	2	0	11	17	6	3	7	11	12	108	100.0	4.54
PERCENT	4.6	3.7	4.6	1.9	9.3	7.4	2.9	1.9	3.7	10.2	15.7	5.6	2.8	6.5	10.2	9.3	100.0		
AV SPD	5.3	4.4	6.1	6.3	5.4	5.7	6.6	6.5	4.9	8.0	6.3	11.7	4.5	5.3	6.1	3.9			
AVERAGE SPEED FOR THIS TABLE EQUALS 6.3																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 3																			

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.8 BUT LESS THAN OR EQUAL TO -1.3

REQUEST NUMBER 604-44

SITE HATCH

PERIOD OF RECORD FROM 70069101 TO 74093124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED (MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NW	TOTAL	PERCENT	GEOM MEAN
CALM	0	0	0	0	0	1	0	0	1	0	0	0	0	0	0	0	0	2	.3
CALM+ - 1.5	2	0	0	2	1	1	3	3	0	0	0	0	0	0	0	0	0	11	1.7
1.6 - 2.5	8	4	1	4	6	6	5	2	1	3	3	5	4	4	2	3	61	9.3	2.00
2.6 - 3.5	13	5	6	2	9	4	5	4	2	1	3	4	8	1	4	2	73	11.1	2.93
3.6 - 7.5	14	13	12	20	31	33	17	11	74	21	29	28	26	26	15	25	343	52.2	5.97
7.6 - 12.5	8	9	9	12	3	14	15	8	11	7	14	11	7	10	5	4	147	22.4	9.14
12.6 - 18.5	0	1	2	0	0	0	1	1	1	2	2	1	0	0	1	0	19	2.9	14.15
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	.2	20.67
TOTAL	45	30	35	42	50	59	47	29	40	74	54	49	45	41	27	74	657	100.0	4.15
PERCENT	6.8	4.6	5.3	6.4	7.6	9.0	6.5	4.4	6.1	5.2	8.2	7.5	6.8	6.2	4.1	5.2	100.0		
AV SPD	4.1	5.7	7.5	5.9	4.7	5.7	6.6	5.8	5.9	6.7	6.8	6.1	5.3	5.7	6.1	5.2			
AVERAGE SPEED FOR THIS TABLE EQUALS 5.8																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 5																			

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 19 OF 48)

MONTH OF MAY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .5 BUT LESS THAN OR EQUAL TO .8
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT
 REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NWN	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	1	0	0	1	0	1	0	0	0	0	0	0	0	0	3	.5	.10
CALM+ - 1.5	3	2	2	2	5	1	2	0	0	3	0	2	4	3	1	2	49	4.9	1.78
1.6 - 2.5	3	1	5	6	5	11	4	5	2	3	6	6	4	4	5	79	12.2	1.86	
2.6 - 3.5	6	2	2	4	9	10	11	7	11	6	11	9	6	4	7	12	122	18.8	2.88
3.6 - 7.5	12	9	5	10	13	25	23	35	55	43	55	17	14	15	19	13	373	57.6	4.88
7.6 - 12.5	0	4	0	0	0	3	5	3	6	6	3	1	1	2	2	1	38	5.9	6.60
12.6 - 18.5	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	1	.2	14.20
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	24	20	14	22	32	51	52	53	79	57	75	33	29	33	35	77	648	0.0	3.15
PERCENT	3.7	3.1	2.5	3.4	4.9	7.9	8.0	8.2	12.2	8.8	11.6	5.1	4.5	5.1	5.4	5.7	100.0		
AV SPD	3.3	5.2	3.3	3.1	3.1	3.1	4.6	4.5	5.0	4.9	4.7	3.9	3.5	3.7	4.0	3.7			
AVERAGE SPEED FOR THIS TABLE EQUALS 4.2																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 3																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 2.2
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT
 REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NWN	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	1	0	0	1	0	3	0	2	1	8	3.8	.10
CALM+ - 1.5	4	1	0	0	3	1	4	1	2	1	2	0	3	3	2	2	27	12.7	1.66
1.6 - 2.5	0	2	1	2	3	4	2	3	3	1	2	4	2	6	2	40	14.8	1.86	
2.6 - 3.5	2	0	0	2	1	5	7	5	3	5	3	7	4	9	3	0	56	25.3	3.10
3.6 - 7.5	4	2	2	3	2	1	3	11	12	5	8	3	5	6	6	82	38.5	4.81	
7.6 - 12.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	10	6	2	7	10	12	14	13	17	19	20	14	22	17	18	11	213	0.0	1.60
PERCENT	4.7	2.8	1.4	3.3	4.7	5.6	6.6	6.1	8.0	8.9	9.4	6.5	10.3	8.0	8.5	5.2	100.0		
AV SPD	2.8	2.0	3.4	2.9	2.4	2.8	2.5	2.6	4.2	4.1	4.0	3.4	2.7	2.8	2.6	3.0			
AVERAGE SPEED FOR THIS TABLE EQUALS 3.1																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 0																			

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 20 OF 48)

MONTH OF MAY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2
SITE WATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70069101 TO 74093124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CALM* - 1.5	3	0	0	0	1	0	1	0	1	1	1	1	2	1	2	1	12	6.7	1.30
1.6 - 2.5	0	1	0	0	1	2	6	1	1	2	5	7	7	6	8	7	45	25.3	2.61
2.6 - 3.5	1	2	1	1	1	2	1	3	2	5	6	5	7	7	7	2	51	29.7	2.62
3.6 - 4.5	0	0	0	0	0	2	2	2	3	8	16	2	9	4	6	3	57	32.0	4.43
4.6 - 5.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
5.6 - 6.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
6.6 - 7.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
7.6 - 8.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
8.6 - 9.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
9.6 - 10.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
10.6 - 11.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
11.6 - 12.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
12.6 - 13.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
13.6 - 14.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
14.6 - 15.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
15.6 - 16.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
16.6 - 17.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
17.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6 - 19.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
19.6 - 20.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
20.6 - 21.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
21.6 - 22.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
22.6 - 23.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
23.6 - 24.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
24.6 - 25.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
25.6 - 26.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
26.6 - 27.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
27.6 - 28.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
28.6 - 29.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
29.6 - 30.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
30.6 - 31.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
31.6 - 32.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
32.6 - 33.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
33.6 - 34.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
34.6 - 35.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	4	2	2	2	3	6	11	7	8	16	28	10	24	19	24	11	178	100.0	1.65
PERCENT	2.2	1.7	1.1	1.1	1.7	3.4	6.2	3.9	4.5	9.0	15.7	5.6	13.5	10.7	13.5	6.2	100.0		
AV SPD	1.6	2.7	1.4	1.7	1.9	2.8	2.3	2.9	2.7	4.0	3.9	2.8	2.9	2.7	2.6	2.4			
AVERAGE SPEED FOR THIS TABLE EQUALS	2.9																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	2																		

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 21 OF 48)

MONTH OF JUNE

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0

REQUEST NUMBER 604-44

SITE NAME
PERIOD OF RECORD FROM 70363101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM. MEAN SPEED(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+	0	0	0	0	1	2	0	1	0	0	0	0	1	0	0	0	5	4.6	1.98
1.6 - 2.5	1	5	3	2	2	5	2	0	2	3	3	0	0	2	1	1	32	3.9	2.56
2.6 - 3.5	12	17	15	5	4	9	1	2	0	1	1	7	5	7	5	9	90	11.0	2.56
3.6 - 7.5	28	30	36	49	49	43	19	11	16	15	19	25	38	29	66	42	513	62.9	5.20
7.6 - 12.5	0	7	11	9	21	15	15	7	4	6	9	16	26	9	12	4	143	20.0	5.00
12.6 - 18.5	0	0	0	0	0	1	0	0	0	0	2	3	5	1	0	0	12	1.5	17.57
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	41	50	65	65	77	75	37	17	22	25	34	45	75	49	84	74	815	0.0	4.82
PERCENT	5.0	6.1	8.0	8.0	9.4	9.2	4.5	2.1	2.7	3.1	4.2	5.6	9.2	5.9	10.3	6.6	100.0		
AV SPD	4.0	4.6	5.2	5.5	6.3	5.8	6.8	5.4	5.9	5.8	7.1	7.3	7.2	5.9	5.7	5.1			
AVERAGE SPEED FOR THIS TABLE EQUALS 5.0																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 25																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -.9

REQUEST NUMBER 604-44

SITE NAME
PERIOD OF RECORD FROM 70363101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM. MEAN SPEED(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1.3	1.27
1.6 - 2.5	3	1	1	0	2	1	1	1	1	0	0	0	0	0	2	1	16	10.3	1.57
2.6 - 3.5	3	0	3	3	4	1	0	1	1	1	0	1	0	1	1	0	20	12.8	2.56
3.6 - 7.5	8	4	2	4	7	9	1	4	0	5	6	12	6	4	3	4	79	50.6	5.00
7.6 - 12.5	1	0	0	1	1	2	5	4	1	0	1	6	7	2	1	0	32	20.5	5.40
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	3	0	2	2	0	0	7	4.5	17.44
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	15	5	6	8	15	13	7	10	3	6	10	19	15	9	7	4	156	0.0	4.32
PERCENT	9.5	3.2	5.1	5.1	9.6	8.3	4.5	6.4	1.9	3.8	6.4	12.7	9.6	5.8	4.5	3.8	100.0		
AV SPD	4.1	4.7	5.0	5.1	4.3	6.0	7.1	6.5	4.4	4.9	7.7	6.9	8.7	7.4	4.3	3.8			
AVERAGE SPEED FOR THIS TABLE EQUALS 5.8																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 1																			

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 22 OF 48)

MONTH OF JUNE

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -.9 BUT LESS THAN OR EQUAL TO -.8

REQUEST NUMBER 604-44

SITE HATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEQ MEAN SFD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	1	0.0	1.42
1.6 - 2.5	0	0	0	1	2	0	0	0	0	0	0	0	0	0	1	0	2	6.7	2.51
2.6 - 3.5	2	1	2	1	1	0	1	0	1	1	1	1	2	2	0	0	16	15.7	2.97
3.6 - 7.5	4	0	2	5	3	3	5	0	5	6	5	3	5	3	2	0	4	55	52.4
7.6 - 12.5	0	0	0	0	1	3	2	1	2	1	0	3	2	1	0	0	1	16	15.2
12.6 - 18.5	0	0	0	0	0	0	1	1	0	0	0	0	2	5	0	0	9	8.6	14.88
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	6	1	4	7	7	6	9	2	9	8	6	7	13	11	4	5	105	0.0	4.51
PERCENT	5.7	1.0	3.8	6.7	6.7	5.7	8.6	1.9	8.6	7.6	5.7	6.7	12.4	10.5	3.8	4.8	100.0		
AV SPD	4.1	2.8	3.0	4.4	5.0	7.2	7.1	11.3	5.6	6.2	5.6	7.2	6.6	9.4	3.6	3.2			
AVERAGE SPEED FOR THIS TABLE EQUALS	6.2																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	2																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -.8 BUT LESS THAN OR EQUAL TO -.3

REQUEST NUMBER 604-44

SITE HATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEQ MEAN SFD(MPH)
CALM	0	0	0	0	0	2	0	0	0	1	0	0	0	0	1	0	4	4.6	0.00
CALM+ - 1.5	2	5	0	4	2	3	1	2	0	2	2	1	0	1	1	0	2	24	4.4
1.6 - 2.5	6	4	4	4	6	11	9	5	3	4	6	4	3	2	3	2	40	12.6	2.02
2.6 - 3.5	4	6	5	8	12	2	3	0	5	6	5	12	7	6	3	1	39	15.5	2.84
3.6 - 7.5	12	10	14	27	17	25	21	27	13	19	49	31	18	19	7	7	116	49.6	4.81
7.6 - 12.5	2	1	1	0	9	11	14	5	3	7	17	11	4	15	2	1	103	16.2	6.15
12.6 - 18.5	0	1	0	0	0	2	3	0	0	1	1	0	1	1	0	0	7	1.1	17.72
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	26	27	24	41	46	56	54	47	24	40	40	59	32	44	17	12	637	0.0	2.21
PERCENT	4.1	4.2	4.4	6.4	7.2	8.8	8.5	7.4	3.8	6.3	12.6	9.3	5.2	6.9	2.7	2.0	100.0		
AV SPD	3.8	3.7	4.0	3.8	4.8	5.0	5.4	4.7	4.5	5.1	5.7	5.3	5.1	6.3	4.2	4.4			
AVERAGE SPEED FOR THIS TABLE EQUALS	4.9																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	3																		

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 23 OF 48)

MONTH OF JUNE

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 1.2 BUT LESS THAN OR EQUAL TO 1.5
SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NW	TOTAL	PERCENT	GRD MEAN SPD(MPH)
CALM	0	1	0	1	0	0	0	1	1	0	0	0	0	0	0	1	5	.7	.30
CALM+ - 1.5	2	2	4	4	4	5	2	2	4	1	4	2	3	1	5	2	47	6.6	1.85
1.6 - 2.5	1	3	5	4	6	6	7	3	10	4	3	4	2	5	4	6	73	10.1	2.05
2.6 - 3.5	4	3	4	13	21	11	20	15	12	16	2	3	3	3	8	5	143	19.9	2.97
3.6 - 7.5	4	3	12	21	30	21	57	23	25	41	49	34	19	14	19	7	379	52.5	4.76
7.6 - 12.5	0	0	0	11	9	3	10	4	4	4	6	7	11	4	1	1	71	9.8	9.17
12.6 - 18.5	0	0	0	2	0	0	0	0	0	0	0	0	0	1	0	0	3	.4	13.04
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	(.00)
TOTAL	11	11	25	56	70	48	95	48	55	55	64	46	38	28	37	22	722	100.0	2.96
PERCENT	1.5	1.5	3.5	7.8	9.7	6.6	13.3	6.6	7.4	7.4	8.9	6.4	5.3	3.9	5.1	3.0	100.0		
AV SPD	3.1	2.1	3.0	5.1	4.4	4.2	4.2	3.9	4.6	4.9	5.0	5.6	4.9	3.7	3.4				
AVERAGE SPEED FOR THIS TABLE EQUALS	4.4																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	4																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 1.8 BUT LESS THAN OR EQUAL TO 2.2
SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NW	TOTAL	PERCENT	GRD MEAN SPD(MPH)
CALM	2	1	1	1	1	0	0	0	0	0	0	0	0	0	0	1	5	2.1	.30
CALM+ - 1.5	2	2	2	2	2	2	2	2	3	2	0	0	0	0	2	0	17	10.2	.91
1.6 - 2.5	1	2	2	1	17	3	3	5	2	4	1	5	5	4	5	5	65	26.7	1.96
2.6 - 3.5	2	2	4	2	4	5	4	1	4	3	3	2	5	6	5	2	52	23.0	2.98
3.6 - 7.5	0	1	2	4	5	4	5	6	5	11	12	3	5	3	1	79	32.5	4.97	
7.6 - 12.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
12.6 - 18.5	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	.4	13.37
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	4	11	11	10	32	25	17	11	14	13	18	15	16	16	14	17	247	100.0	1.92
PERCENT	3.3	4.5	4.5	4.1	12.3	10.3	7.0	4.5	7.4	5.3	7.4	6.2	6.6	6.6	5.8	4.1	100.0		
AV SPD	3.0	2.0	2.6	2.7	2.3	3.0	3.5	3.1	3.0	3.0	4.2	4.4	2.5	3.0	2.6	2.1			
AVERAGE SPEED FOR THIS TABLE EQUALS	3.0																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	2																		

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 24 OF 48)

MONTH OF JUNE

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2
SITE NAME

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SFD(MPH)
CALM	1	0	3	1	0	0	0	1	0	0	0	0	0	0	2	1	9	4.6	.37
CALM+ - 1.5	1	1	1	1	1	0	2	1	0	0	0	0	5	3	3	2	21	20.0	.84
1.6 - 2.5	2	1	0	1	1	2	2	1	0	4	2	1	5	3	4	3	32	30.5	1.55
2.6 - 3.5	0	0	1	0	1	0	1	0	2	2	2	2	5	4	1	0	21	20.0	3.25
3.6 - 7.5	0	0	0	0	0	2	0	0	2	2	3	6	1	4	1	1	22	21.0	4.25
7.6 - 12.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	4	2	5	3	3	4	5	3	4	8	7	9	16	14	11	7	105	0.0	1.26
PERCENT	3.8	1.9	4.8	2.9	2.9	3.8	4.8	2.9	3.8	7.6	6.7	8.6	15.2	13.3	10.5	6.7	100.0		
AV SPD	1.5	1.7	1.9	1.2	2.1	3.5	1.7	1.1	3.3	2.9	3.4	4.0	2.2	2.8	1.6	1.6			
AVERAGE SPEED FOR THIS TABLE EQUALS	2.4																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	0																		

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 25 OF 48)

MONTH OF JULY

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0

REQUEST NUMBER 604-44

SITE HATCH
PERIOD OF RECORD FROM 70063101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	1	0	3	1	0	0	0	5	1	0	0	0	3	.3	.20
CALM+ - 1.5	1	2	1	2	1	0	0	0	0	1	1	1	0	0	1	1	12	1.3	1.16
1.6 - 2.5	9	6	8	9	4	2	4	2	0	0	3	2	0	7	3	64	6.7	2.12	
2.6 - 3.5	4	0	2	15	12	10	3	3	7	11	16	7	5	11	9	1	179	14.6	3.31
3.6 - 7.5	15	0	30	43	57	40	25	21	18	10	58	42	58	48	57	70	594	61.2	5.10
7.6 - 12.5	1	2	3	10	6	12	5	2	5	10	26	13	27	11	9	2	144	15.1	6.05
12.6 - 18.5	0	1	0	0	0	3	1	0	0	0	0	1	2	1	0	0	9	.9	14.38
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.70
TOTAL	37	29	44	79	85	67	38	29	30	52	102	67	95	71	83	47	955	100.0	4.19
PERCENT	3.9	3.0	4.6	8.3	8.9	7.0	4.0	3.0	3.1	5.4	10.7	7.0	9.9	7.4	8.7	4.9	100.0		
AV SPD	3.7	4.2	4.9	4.8	4.9	6.1	5.7	4.7	5.4	5.6	6.1	5.7	6.4	5.6	5.3	4.4			
AVERAGE SPEED FOR THIS TABLE EQUALS 5.4																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 15																			

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -.9

REQUEST NUMBER 604-44

SITE HATCH
PERIOD OF RECORD FROM 70063101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	1	2	1.5	1.25
1.6 - 2.5	2	1	1	0	0	2	0	0	0	1	1	0	1	1	3	1	14	10.4	2.17
2.6 - 3.5	1	1	3	1	0	3	0	1	4	0	2	5	2	0	4	1	28	21.7	3.04
3.6 - 7.5	0	3	4	4	6	5	7	5	4	3	11	7	7	6	2	3	77	57.0	5.17
7.6 - 12.5	0	0	1	1	0	0	1	1	0	3	2	2	0	0	1	0	12	8.9	9.11
12.6 - 18.5	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	2	1.5	14.37
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.70
TOTAL	3	5	9	6	6	10	9	8	4	7	17	14	10	7	10	6	135	100.0	4.32
PERCENT	2.2	3.7	6.7	4.4	4.4	7.4	6.7	5.9	5.9	5.7	12.6	10.4	7.4	5.2	7.4	4.4	100.0		
AV SPD	2.6	4.7	4.2	5.3	4.5	4.3	7.3	7.3	4.0	7.5	5.2	5.0	4.4	4.6	4.2	3.9			
AVERAGE SPEED FOR THIS TABLE EQUALS 5.0																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 2																			

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 26 OF 48)

MONTH OF JULY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .9 BUT LESS THAN OR EQUAL TO 1.1

REQUEST NUMBER 604-44

SITE MATCH

PERIOD OF RECORD FROM 70060101 TO 74043124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NW	TOTAL	PERCENT	GFD	MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+ - 1.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
1.6 - 2.5	1	1	0	0	0	0	1	0	2	2	1	0	0	1	0	1	9	11.5	2.03	1.90
2.6 - 3.5	1	0	0	1	1	1	0	0	1	1	1	3	2	1	1	1	15	19.2	2.47	2.00
3.6 - 7.5	1	1	2	1	2	3	1	2	3	3	2	4	6	3	5	0	43	55.1	5.16	3.00
7.6 - 12.5	0	1	0	1	0	0	0	1	1	1	2	1	1	0	1	0	10	12.8	9.18	3.00
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00	0.00
TOTAL	3	3	2	3	3	4	2	3	7	7	6	12	9	5	7	2	78	100.0	2.93	
PERCENT	3.8	3.8	2.6	3.8	3.8	5.1	2.6	3.8	9.0	9.0	7.7	15.4	11.5	6.4	9.0	2.6	100.0			
AV SPD	2.8	4.4	4.5	5.6	5.0	4.2	2.9	7.1	4.7	4.9	5.8	5.1	4.9	4.1	5.4	2.3				

AVERAGE SPEED FOR THIS TABLE EQUALS 4.9
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 0

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 1.3

REQUEST NUMBER 604-44

SITE MATCH

PERIOD OF RECORD FROM 70050101 TO 74043124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NW	TOTAL	PERCENT	GFD	MEAN SPD(MPH)
CALM	2	1	0	0	1	0	1	0	1	0	0	0	1	0	0	0	7	1.4	1.10	1.10
CALM+ - 1.5	2	1	2	4	4	2	4	0	1	1	2	1	2	2	0	0	31	5.2	1.50	1.50
1.6 - 2.5	4	7	0	6	7	2	5	7	2	3	6	5	3	1	3	3	65	13.1	1.63	1.63
2.6 - 3.5	1	3	10	9	5	3	3	4	5	9	4	8	6	6	3	4	38	17.1	2.46	2.46
3.6 - 7.5	2	6	9	4	10	14	20	10	17	42	57	29	14	16	5	4	259	52.1	4.72	4.72
7.6 - 12.5	0	3	1	0	1	1	2	3	7	9	5	4	2	4	1	0	43	9.7	6.72	6.72
12.6 - 18.5	0	0	0	0	0	0	0	2	0	0	0	0	0	1	0	2	5	1.0	14.41	14.41
18.6+	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	1	0.2	16.22	16.22
TOTAL	11	17	31	27	31	22	35	22	30	64	74	47	29	30	12	18	497	100.0	2.32	2.32
PERCENT	2.2	3.4	6.2	5.4	6.2	4.4	7.0	4.4	6.0	12.9	14.9	9.5	5.8	6.0	2.4	3.6	100.0			
AV SPD	2.1	4.1	3.3	2.9	3.4	4.1	3.9	5.7	5.7	5.1	4.9	4.8	4.0	5.1	3.7	4.2				

AVERAGE SPEED FOR THIS TABLE EQUALS 4.4
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 4

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 27 OF 48)

MONTH OF JULY

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .4
SITE MATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GRD MEAN SFD(MPH)
CALM	2	3	0	0	1	2	1	0	0	1	0	1	0	1	0	1	11	1.7	1.70
CALM+ - 1.5	6	8	6	3	4	2	3	3	0	3	4	6	2	2	8	6	54	9.7	1.65
1.6 - 2.5	11	12	7	6	7	14	5	13	13	9	10	11	7	8	4	1	131	19.8	2.00
2.6 - 3.5	4	2	10	13	8	12	20	13	8	12	21	14	15	6	4	4	127	21.2	2.67
3.6 - 7.5	7	8	15	4	8	17	24	11	34	49	35	23	11	10	2	4	263	39.2	4.51
7.6 - 12.5	1	0	0	0	1	0	2	1	1	2	1	0	0	0	1	0	10	1.5	4.66
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	31	29	34	26	29	47	55	41	53	96	71	55	35	27	19	16	653	0.0	2.28
PERCENT	4.7	4.2	5.1	3.9	4.4	7.1	8.3	6.2	8.0	14.5	10.7	8.3	5.3	4.1	2.9	2.4	100.0		
AV SPD	2.7	2.4	3.1	2.7	3.2	2.9	3.7	3.1	4.1	3.9	3.7	3.4	3.2	3.1	2.5	2.7			

AVERAGE SPEED FOR THIS TABLE EQUALS 3.3
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 1

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .4 BUT LESS THAN OR EQUAL TO .5
SITE MATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GRD MEAN SFD(MPH)
CALM	1	0	3	1	0	1	0	3	0	0	1	0	1	2	1	0	14	4.0	1.70
CALM+ - 1.5	0	2	0	2	4	1	2	1	3	1	2	1	1	2	1	1	25	14.4	1.67
1.6 - 2.5	2	2	2	0	5	3	5	4	1	7	1	0	1	1	1	2	37	21.3	2.00
2.6 - 3.5	0	0	0	1	2	4	4	6	9	5	8	4	4	2	0	0	49	28.2	2.66
3.6 - 7.5	0	2	2	1	1	1	7	1	4	6	13	4	2	3	0	0	47	27.0	4.50
7.6 - 12.5	0	0	0	0	0	0	0	1	3	0	0	0	0	1	0	0	2	1.1	7.86
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	3	7	7	5	12	10	13	16	17	19	25	9	9	11	3	2	174	0.0	1.97
PERCENT	1.7	4.0	4.0	2.9	6.9	5.7	10.3	9.2	9.4	10.9	14.4	5.2	5.2	6.7	1.7	1.7	100.0		
AV SPD	1.5	2.7	1.9	1.8	2.2	2.3	3.2	2.5	3.2	3.0	3.7	3.9	2.7	2.7	1.9	1.6			

AVERAGE SPEED FOR THIS TABLE EQUALS 2.8
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 0

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 28 OF 48)

MONTH OF JULY

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2
SITE WATCH

REQUEST NUMBER 604-66

PERIOD OF RECORD FROM 79069101 TO 74043124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	DIR. FREQ.
CALM	0	0	2	3	0	0	0	0	0	2	0	0	0	0	0	0	1	5	8.6
1.6 - 2.5	0	0	0	0	0	0	1	2	3	2	0	2	1	0	0	0	1	12	22.7
2.6 - 3.5	1	1	0	1	0	1	0	0	1	2	4	0	0	1	1	0	13	22.4	16.9
3.6 - 7.5	0	0	1	0	0	1	1	3	2	2	2	0	1	0	0	0	12	22.7	21.2
7.6 - 12.5	0	0	0	0	0	1	1	0	2	2	7	1	1	0	0	0	16	27.6	14.7
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0
TOTAL	2	1	3	1	0	2	3	5	4	10	13	3	3	1	1	2	54	100.0	1.75
PERCENT	3.4	1.7	5.2	1.7	0.0	3.4	5.2	8.6	13.4	17.2	22.4	5.2	5.2	1.7	1.7	3.4	100.0		
AV. SPD	2.6	1.9	1.5	1.6	0.0	2.7	2.2	2.3	2.7	2.1	3.4	2.4	3.3	2.1	1.9	2.8			
AVERAGE SPEED FOR THIS TABLE EQUALS 2.5																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 2																			

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 29 OF 48)

MONTH OF AUGUST

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0

REQUEST NUMBER 604-44

SITE HATCH

PERIOD OF RECORD FROM 70360101 TO 74093124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNF	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	1	0	1	0	1	0	0	1	0	2	1	0	0	0	0	0	7	1.1	1.21
1.6 - 2.5	4	7	4	6	6	3	0	3	1	3	4	2	1	1	0	2	43	6.9	2.09
2.6 - 3.5	8	11	12	11	11	6	2	2	1	3	7	3	1	11	7	8	124	16.4	2.97
3.6 - 7.5	11	19	30	46	36	23	14	6	10	14	37	32	26	29	35	23	430	62.9	5.04
7.6 - 12.5	0	5	4	1	6	8	0	3	0	7	7	9	13	12	6	0	41	12.7	4.75
12.6 - 18.5	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	1	.2	14.49
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	24	38	50	64	60	40	17	15	12	29	56	46	41	53	48	33	636	0.0	4.24
PERCENT	3.8	6.0	9.4	10.1	9.4	6.3	2.7	2.4	1.9	4.6	8.9	7.2	6.4	8.3	7.5	5.2	100.0		
AV SPD	3.6	4.7	5.0	4.5	4.9	5.5	5.4	4.8	5.4	5.1	5.4	5.6	6.5	5.4	5.2	4.7			
AVERAGE SPEED FOR THIS TABLE EQUALS 5.1																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 13																			

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -0.9

REQUEST NUMBER 604-44

SITE HATCH

PERIOD OF RECORD FROM 70360101 TO 74093124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNF	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOM MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
1.6 - 2.5	1	2	0	2	0	0	0	0	0	0	0	1	1	2	0	1	10	10.5	2.02
2.6 - 3.5	3	5	5	2	1	0	0	0	0	0	1	2	1	1	1	0	22	23.2	3.09
3.6 - 7.5	1	7	7	2	0	4	1	1	3	5	9	4	5	5	4	0	57	60.1	4.89
7.6 - 12.5	0	1	0	0	1	1	0	1	0	0	0	0	0	1	0	1	6	6.3	6.54
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	5	12	16	4	4	5	1	2	3	5	10	7	7	9	5	2	95	0.0	3.95
PERCENT	5.3	12.6	16.7	4.2	4.2	5.1	1.1	2.1	3.2	5.7	10.5	7.4	7.4	9.5	5.3	2.1	100.0		
AV SPD	2.8	4.4	3.4	3.6	4.6	6.2	6.5	7.9	5.8	5.3	4.9	4.5	3.9	5.1	5.1	4.7			
AVERAGE SPEED FOR THIS TABLE EQUALS 4.5																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 2																			

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 30 OF 48)

MONTH OF AUGUST

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.9 BUT LESS THAN OR EQUAL TO -1.9 REQUEST NUMBER 604-44
SITE HATCH

PERIOD OF RECORD FROM 70063101 TO 74043124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GFC MEAN SPD(MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW			
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+ - 1.5	0	1	1	0	0	1	0	0	0	0	0	0	0	0	0	0	0	3	3.7
1.6 - 2.5	1	0	0	0	0	1	0	0	0	0	1	1	0	3	0	0	0	7	8.5
2.6 - 3.5	1	4	1	3	1	0	2	0	0	1	3	1	1	1	2	0	21	25.6	
3.6 - 7.5	1	1	1	2	3	4	4	0	1	3	4	4	5	2	2	3	44	53.7	
7.6 - 12.5	0	0	0	0	1	0	0	0	0	1	0	0	1	0	0	1	6	7.3	
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
TOTAL	3	6	3	5	5	6	6	0	1	5	13	6	9	0	0	0	102	100.0	
PERCENT	3.7	7.2	3.7	6.1	6.1	7.3	7.3	0.0	1.2	6.1	15.9	7.3	11.0	7.3	4.9	4.0	100.0		
AV SPD	3.1	3.4	2.5	3.3	5.7	4.5	4.8	3.0	5.7	5.8	5.5	5.0	7.1	2.9	3.7	5.9			
AVERAGE SPEED FOR THIS TABLE EQUALS 4.9																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 2																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.9 BUT LESS THAN OR EQUAL TO -1.9 REQUEST NUMBER 604-44
SITE HATCH

PERIOD OF RECORD FROM 70063101 TO 74043124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GFC MEAN SPD(MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW			
CALM	1	1	0	0	0	0	0	0	0	1	1	0	0	0	0	0	4	4.7	
CALM+ - 1.5	0	4	2	0	3	5	4	2	3	2	6	7	1	1	0	0	32	4.5	
1.6 - 2.5	5	0	0	9	6	9	2	5	9	0	8	4	4	1	4	0	57	16.7	
2.6 - 3.5	6	0	0	12	12	4	14	7	4	16	14	4	6	5	6	0	107	21.9	
3.6 - 7.5	9	11	10	17	21	24	11	15	15	47	51	18	10	5	7	17	300	48.4	
7.6 - 12.5	0	1	0	0	1	1	1	0	1	2	15	6	4	0	0	0	27	5.7	
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
TOTAL	21	22	27	34	44	47	37	29	33	73	95	37	24	19	15	17	541	100.0	
PERCENT	3.6	4.2	4.4	6.5	7.6	8.1	5.5	5.1	5.7	12.6	16.4	6.4	4.1	3.3	2.9	3.1	100.0		
AV SPD	3.4	3.7	3.2	3.3	7.4	3.9	3.5	3.7	3.4	4.7	5.0	4.9	4.7	3.3	3.4	4.8			
AVERAGE SPEED FOR THIS TABLE EQUALS 4.0																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 6																			

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 31 OF 48)

MONTH OF AUGUST

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .8

REQUEST NUMBER 604-44

SITE MATCH

PERIOD OF RECORD FROM 70061101 TO 74063124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	1	1	0	1	0	1	0	0	1	1	0	0	0	2	0	0	9	1.2	1.70
CALM+ - 1.5	3	6	10	5	7	6	6	6	3	6	3	5	4	4	7	5	89	12.9	1.99
1.6 - 2.5	9	6	5	11	18	16	9	12	19	18	19	12	10	6	4	3	177	25.7	2.10
2.6 - 3.5	3	5	11	13	14	13	9	24	14	27	17	12	6	14	9	5	191	27.8	2.57
3.6 - 7.5	3	0	4	6	11	8	17	14	27	55	36	18	11	4	2	2	218	31.7	4.55
7.6 - 12.5	0	0	0	0	1	0	1	1	0	1	0	1	0	0	0	0	5	.7	5.11
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	19	17	30	36	52	45	42	59	64	104	75	48	31	30	21	15	698	0.0	2.17
PERCENT	2.8	2.5	4.4	5.2	7.6	6.5	6.1	8.6	9.3	15.1	10.9	7.0	4.5	4.4	3.1	2.2	100.0		
AV SPD	2.2	1.7	2.5	2.5	2.8	2.5	3.4	3.0	3.3	3.7	3.7	3.5	3.1	2.6	2.2	2.2			
AVERAGE SPEED FOR THIS TABLE TOTALS																			3.1
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =																			13

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 2.2

REQUEST NUMBER 604-44

SITE MATCH

PERIOD OF RECORD FROM 70062101 TO 74063124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	2	0	0	0	0	0	2	0	1	0	0	1	0	0	1	0	7	4.0	1.30
CALM+ - 1.5	4	1	2	4	3	0	2	3	7	1	0	0	1	2	2	4	31	17.7	1.57
1.6 - 2.5	3	0	0	2	3	4	2	2	4	4	3	7	5	2	0	7	52	29.7	1.95
2.6 - 3.5	0	1	0	0	0	2	4	8	5	1	4	3	4	4	3	2	41	23.4	2.56
3.6 - 7.5	1	0	0	0	0	3	5	4	7	5	11	6	1	0	0	0	43	24.5	4.55
7.6 - 12.5	0	0	0	0	0	1	3	0	0	0	0	0	0	0	0	0	1	.6	7.55
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	10	10	2	6	6	10	15	17	19	11	18	17	11	8	6	9	175	0.0	1.65
PERCENT	5.7	5.7	1.1	3.4	3.4	5.7	8.6	9.7	10.9	6.7	10.3	9.7	6.3	4.6	3.4	5.1	100.0		
AV SPD	1.4	2.0	1.9	1.2	1.3	3.4	2.9	3.0	3.1	3.1	4.0	3.1	2.6	2.2	2.0	1.7			
AVERAGE SPEED FOR THIS TABLE TOTALS																			2.7
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =																			3

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 32 OF 48)

MONTH OF AUGUST

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (IN FC/100FT) GREATER THAN 2.2
SITE HATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70960101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 15
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED (MPH)	WIND DIRECTION																TOTAL	PERCENT	GFD	MEAN SPD (MPH)			
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW							
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	1	5.3	0.20
CALM* - 1.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
1.5 - 2.5	0	0	1	0	0	0	0	1	0	1	0	0	1	1	0	0	1	0	0	6	21.6	1.05	
2.6 - 3.5	0	0	0	0	0	0	1	0	0	0	0	1	0	0	0	0	0	0	0	2	10.5	2.1*	
3.6 - 7.5	0	0	0	0	1	2	0	1	1	0	4	0	1	0	0	0	0	0	0	10	52.6	4.14	
7.6 - 12.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00	
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00	
18.6*	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00	
TOTAL	0	0	1	0	1	3	1	1	2	0	6	1	1	0	2	0	0	0	0	19	100.0	1.96	
PERCENT	0.0	0.0	5.3	0.0	5.3	15.4	5.3	5.3	10.5	0.0	31.6	5.3	5.3	0.0	10.5	0.0	0.0	0.0	0.0	100.0			
AV SPD	0.0	0.0	1.5	0.0	3.7	3.6	2.4	4.7	2.7	0.0	3.7	2.5	4.4	0.0	0.9	0.0	0.0	0.0	0.0				
AVERAGE SPEED FOR THIS TABLE EQUALS																	3.1						
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =																	1						

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 33 OF 48)

MONTH OF SEPTEMBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0
SITE MATCH
PERIOD OF RECORD FROM 70360101 TO 74043124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GRD MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	1	4	1.5
1.6 - 2.5	0	0	2	4	4	1	1	1	0	0	0	1	1	0	2	2	23	3.3	2.06
2.6 - 3.5	0	0	5	8	9	5	2	2	2	1	3	1	3	2	4	4	61	8.9	2.67
3.6 - 7.5	13	12	23	69	57	37	11	8	7	5	14	13	19	12	21	9	330	48.0	5.33
7.6 - 12.5	4	10	26	27	30	19	15	11	4	4	4	7	5	11	11	6	194	28.2	6.25
12.6 - 18.5	3	5	7	10	4	6	5	6	8	4	1	1	0	3	4	2	69	10.0	14.43
18.6+	0	0	0	0	0	0	0	0	2	1	0	0	0	0	0	0	7	1.0	20.64
TOTAL	23	35	65	119	105	68	34	28	23	15	22	23	29	25	42	24	688	100.0	5.57
PERCENT	4.1	5.1	9.4	17.3	15.3	9.9	4.9	4.1	3.3	2.7	3.2	3.3	4.2	4.1	6.1	3.5	100.0		
AV SPD	6.1	8.4	8.2	6.9	6.6	7.3	8.4	8.8	10.4	9.5	6.0	7.1	5.8	7.9	7.1	6.2			
AVERAGE SPEED FOR THIS TABLE EQUALS	7.4																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	38																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -0.9
SITE MATCH
PERIOD OF RECORD FROM 70360101 TO 74043124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GRD MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1.9
1.6 - 2.5	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0	4	3.4	2.34
2.6 - 3.5	0	1	3	0	2	0	1	0	0	0	1	0	0	0	0	0	8	6.8	2.73
3.6 - 7.5	2	0	8	5	9	3	0	3	1	3	1	0	3	2	4	4	48	41.0	5.72
7.6 - 12.5	0	5	7	7	3	7	4	0	2	0	2	1	0	1	0	3	42	35.9	6.01
12.6 - 18.5	0	0	0	1	1	1	1	1	3	1	3	0	0	1	0	0	13	11.1	15.01
18.6+	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1.9	24.31
TOTAL	2	6	19	13	15	11	6	4	6	4	7	1	3	5	5	8	117	100.0	5.77
PERCENT	1.7	6.8	16.2	11.1	12.8	9.4	5.1	3.4	5.1	3.4	6.0	1.9	2.6	4.3	4.3	6.8	100.0		
AV SPD	7.2	6.5	7.3	6.3	6.1	6.9	9.2	7.8	11.9	7.9	11.1	8.5	6.3	6.8	5.7	6.2			
AVERAGE SPEED FOR THIS TABLE EQUALS	7.7																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	2																		

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 34 OF 48)

MONTH OF SEPTEMBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.9 BUT LESS THAN OR EQUAL TO -1.3

REQUEST NUMBER 604-44

SITE MATCH

PERIOD OF RECORD FROM 70963101 TO 74093124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED (MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPD (MPH)				
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW							
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1.2	1.47
1.6 - 2.5	0	0	0	0	0	2	1	0	0	0	1	0	0	1	0	0	0	0	0	0	4	6	7.5
2.6 - 3.5	0	0	1	0	0	1	1	0	0	1	0	1	0	1	1	0	0	0	0	0	7	8.7	2.80
3.6 - 7.5	2	7	6	5	8	5	2	0	0	7	5	1	4	2	1	0	0	0	0	0	46	57.6	4.81
7.6 - 12.5	1	2	5	1	0	2	2	1	0	0	0	0	0	2	0	0	0	0	0	0	18	22.5	4.23
12.6 - 18.5	0	0	0	0	0	0	1	0	0	0	0	0	0	0	1	0	0	0	0	0	2	2.5	16.22
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	4	9	12	6	8	10	7	2	1	7	6	2	4	6	3	1	0	0	0	0	100	0.0	4.61
PERCENT	5.0	6.3	15.0	7.5	10.0	12.5	8.7	2.5	1.2	3.7	7.5	2.5	5.0	7.5	3.7	1.2	0.0	0.0	0.0	0.0			
AV SPD	5.5	7.0	7.2	6.9	5.2	5.3	6.9	5.4	5.1	4.2	4.1	3.6	4.2	6.1	8.9	2.4							
AVERAGE SPEED FOR THIS TABLE EQUALS																		5.9					
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =																			1				

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.8 BUT LESS THAN OR EQUAL TO -1.3

REQUEST NUMBER 604-44

SITE MATCH

PERIOD OF RECORD FROM 70963101 TO 74093124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED (MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO MEAN SPD (MPH)				
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW							
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	3	1	1	4	1	3	2	1	1	1	2	0	2	0	1	0	0	0	0	0	7	4.6	1.11
1.6 - 2.5	1	7	5	6	12	2	1	3	1	0	1	1	1	4	1	4	4	7	7.3	14.5	14.5	14.5	1.69
2.6 - 3.5	2	8	8	9	9	5	9	1	1	1	5	3	3	7	2	2	7	14.5	14.5	14.5	73	14.5	7.06
3.6 - 7.5	13	17	24	49	17	25	14	9	17	16	7	13	7	17	9	0	277	55.1	4.81	4.81	55.1	4.81	6.16
7.6 - 12.5	1	4	6	5	3	9	6	1	3	4	7	1	2	1	2	2	52	12.3	6.16	6.16	12.3	6.16	17.44
12.6 - 18.5	0	0	0	0	1	1	4	0	1	4	3	0	0	3	3	0	20	4.2	17.44	17.44	4.2	17.44	19.73
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	20	30	46	73	62	45	37	15	26	70	25	14	15	27	19	17	503	100.0			3.75		
PERCENT	4.0	6.0	8.7	14.5	12.3	8.9	7.4	3.0	5.2	6.0	5.0	3.6	3.0	5.4	3.8	3.4	100.0						
AV SPD	4.5	4.8	4.9	4.6	4.4	5.6	6.1	4.4	5.6	7.3	6.6	4.3	4.4	5.2	7.4	4.7							
AVERAGE SPEED FOR THIS TABLE EQUALS																		5.2					
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =																			3				

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 35 OF 48)

MONTH OF SEPTEMBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .4
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNF	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SFD(MPH)
CALM	0	1	1	1	1	0	0	0	0	1	0	1	0	0	0	0	6	4.4	0.30
CALM+ - 1.5	5	4	7	6	8	7	6	7	7	1	3	7	1	7	2	4	66	5.7	1.09
1.6 - 2.5	7	10	10	14	13	15	14	7	7	4	5	6	4	1	4	142	17.9	2.01	
2.6 - 3.5	10	16	23	23	26	29	15	11	12	5	6	8	6	0	1	4	225	25.8	2.54
3.6 - 7.5	11	16	25	29	43	44	26	13	4	18	22	18	16	10	8	342	43.0	4.42	
7.6 - 12.5	1	0	0	1	1	0	3	1	3	4	7	1	2	3	7	0	34	4.3	6.44
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	1	0.1	12.77
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	34	55	66	90	83	90	85	52	34	27	38	40	33	26	22	70	736	0.0	2.58
PERCENT	4.3	6.9	8.7	11.7	10.4	11.3	10.4	6.5	4.1	3.4	4.8	5.0	4.1	3.3	2.9	2.5	100.0		
AV SPD	3.1	2.9	3.1	3.2	3.1	3.7	3.4	3.5	3.9	3.9	4.8	3.9	4.1	4.4	6.2	3.1			
AVERAGE SPEED FOR THIS TABLE EQUALS 3.6																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 6																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .4 BUT LESS THAN OR EQUAL TO 2.0
 SITE HATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNF	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEO MEAN SFD(MPH)
CALM	0	0	0	1	0	1	0	0	0	0	0	1	1	1	2	2	9	3.1	0.70
CALM+ - 1.5	4	7	7	5	6	1	1	2	1	3	2	0	2	1	2	0	34	13.0	1.09
1.6 - 2.5	5	6	6	5	9	5	2	0	7	2	3	3	3	2	4	3	57	19.4	1.07
2.6 - 3.5	3	4	6	6	7	7	4	3	6	5	4	0	3	2	4	68	27.2	2.00	
3.6 - 7.5	9	7	8	8	9	10	7	6	10	8	5	7	4	6	5	6	105	25.8	4.27
7.6 - 12.5	0	0	0	0	0	0	0	0	1	7	2	0	0	4	4	1	15	5.1	8.42
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	21	17	18	25	31	24	15	13	14	22	16	11	10	17	19	16	293	0.0	1.58
PERCENT	7.2	5.8	6.1	8.5	10.6	8.2	5.1	4.4	6.1	7.5	5.5	3.8	7.4	5.3	6.5	5.4	100.0		
AV SPD	3.1	2.7	2.9	2.7	2.7	3.1	3.7	3.1	4.1	4.0	4.1	2.8	2.9	4.7	3.9	3.2			
AVERAGE SPEED FOR THIS TABLE EQUALS 3.3																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 5																			

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 36 OF 48)

MONTH OF SEPTEMBER

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 1.0
 SITE MATCH
 PERIOD OF RECORD FROM 70063101 TO 74093124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 15
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

REQUEST NUMBER 574-44

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	UNK	TOTAL	PERCENT	GEOM MEAN SFD(MPH)
CALM	0	0	0	1	0	2	0	0	0	0	0	0	0	1	0	0	4	4.4	0.0
CALM+ - 1.5	1	0	0	0	0	0	1	0	0	0	0	1	0	0	4	0	10	11.1	1.00
1.6 - 2.5	0	2	2	2	3	3	0	1	1	0	0	0	0	3	1	0	16	17.8	2.00
2.6 - 3.5	3	0	2	2	0	1	0	0	3	1	1	0	2	7	2	0	22	24.4	2.67
3.6 - 7.5	3	0	2	0	0	0	0	0	2	4	1	1	6	5	2	1	28	32.2	4.00
7.6 - 12.5	0	0	0	1	0	3	0	0	0	0	0	0	1	2	3	2	9	10.0	4.25
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	7	2	6	6	3	3	1	3	6	6	2	2	9	14	12	8	90	0.0	1.56
PERCENT	7.8	2.2	6.7	6.7	3.3	3.3	1.1	3.3	6.7	6.7	2.2	2.2	10.0	15.6	13.3	8.9	100.0		
AV SPD	2.9	2.0	3.2	3.1	2.0	1.2	1.9	3.7	3.4	4.2	3.8	4.5	4.2	4.9	4.2	3.7			
AVERAGE SPEED FOR THIS TABLE EQUALS 1.7																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 1																			

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 37 OF 48)

MONTH OF OCTOBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0

REQUEST NUMBER 604-44

SITE HATCH
PERIOD OF RECORD FROM 70960101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEQ MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	1	0	0	0	0	1	0	0	0	0	0	0	1	0	0	0	3	1.4	1.04
1.6 - 2.5	7	2	4	0	0	0	0	0	0	0	0	1	0	0	1	5	20	2.6	2.07
2.6 - 3.5	4	2	3	1	3	3	3	0	2	0	1	0	0	2	3	7	24	5.6	3.04
3.6 - 7.5	12	19	22	47	56	14	11	8	13	8	6	6	13	16	19	12	286	36.5	6.77
7.6 - 12.5	8	17	11	34	37	17	26	8	8	6	4	7	10	25	11	8	254	32.4	6.45
12.6 - 18.5	6	7	9	11	2	8	26	24	9	3	1	0	4	2	4	1	117	14.9	11.70
18.6+	3	1	1	1	1	1	21	17	3	0	0	0	1	1	0	0	60	7.7	21.51
TOTAL	41	55	80	108	101	44	84	57	37	17	12	13	26	46	33	73	794	100.0	6.67
PERCENT	5.2	7.0	10.2	13.8	12.9	5.6	10.7	7.3	4.1	2.2	1.5	1.3	3.3	5.9	4.8	4.2	100.0		
AV SPD	7.9	7.7	8.1	8.6	7.6	9.2	14.2	16.0	11.0	9.6	8.1	6.3	9.5	8.6	7.3	5.5			
AVERAGE SPEED FOR THIS TABLE EQUALS	0.4																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	34																		

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -0.9

REQUEST NUMBER 604-44

SITE HATCH
PERIOD OF RECORD FROM 70960101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEQ MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
1.6 - 2.5	1	0	1	0	1	0	0	0	0	0	1	0	0	0	0	0	5	4.5	2.31
2.6 - 3.5	0	0	0	2	3	1	0	0	1	0	0	0	0	0	1	0	9	9.3	2.96
3.6 - 7.5	2	2	5	10	9	4	1	3	2	3	3	1	2	0	5	4	58	53.2	5.12
7.6 - 12.5	0	2	5	7	4	3	1	1	0	1	1	0	0	1	1	1	23	21.1	9.73
12.6 - 18.5	1	0	0	0	3	2	2	0	1	0	1	0	0	0	1	0	11	10.1	14.66
18.6+	0	0	0	0	0	1	0	1	1	0	0	0	0	0	0	0	3	2.9	23.11
TOTAL	4	2	12	14	20	11	4	5	5	4	7	1	2	2	8	5	129	100.0	5.49
PERCENT	3.7	4.8	11.0	12.9	18.3	10.1	3.7	4.6	4.6	3.7	6.4	.9	1.8	1.8	7.3	4.8	100.0		
AV SPD	6.3	7.4	7.2	5.7	7.3	9.6	11.0	11.6	9.9	7.3	6.7	5.5	7.9	5.9	6.2	5.6			
AVERAGE SPEED FOR THIS TABLE EQUALS	7.4																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	4																		

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 38 OF 48)

MONTH OF OCTOBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.9 BUT LESS THAN OR EQUAL TO -1.4
 SITE MATCH
 PERIOD OF RECORD FROM 70060101 TO 74083124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT
 REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0.0
CALM+ - 1.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
1.6 - 2.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
2.6 - 3.5	2	1	1	1	0	0	0	0	0	0	0	0	1	0	0	1	4	3.9	1.84
3.6 - 7.5	1	1	5	6	3	2	2	2	6	2	4	0	1	0	1	3	14	13.6	2.91
7.6 - 12.5	1	2	5	5	7	2	6	0	0	0	0	0	1	1	2	1	33	32.0	9.51
12.6 - 18.5	0	0	1	0	2	1	1	1	1	0	0	0	0	0	0	0	7	6.8	14.55
18.6+	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1	1.0	21.75
TOTAL	4	10	17	17	12	6	9	5	8	3	4	0	4	2	6	6	103	100.0	5.20
PERCENT	3.9	9.7	11.7	11.7	11.7	5.8	8.7	4.9	7.6	2.9	3.9	0.0	3.9	1.9	5.8	5.8	100.0		
AV SPD	5.9	5.3	7.4	7.2	9.2	11.5	9.3	5.9	6.7	4.0	5.5	0.0	5.3	5.9	5.9	3.8			
AVERAGE SPEED FOR THIS TABLE EQUALS 7.0																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 2																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.8 BUT LESS THAN OR EQUAL TO -1.3
 SITE MATCH
 PERIOD OF RECORD FROM 70163101 TO 74083124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT
 REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NW	TOTAL	PERCENT	GEO MEAN SPD(MPH)
CALM	1	0	1	0	2	0	2	0	1	1	2	1	0	1	4	1	17	2.4	3.33
CALM+ - 1.5	3	4	0	0	4	1	0	0	0	0	0	0	4	0	0	0	2	18	2.6
1.6 - 2.5	4	2	4	2	6	1	1	2	1	0	0	4	5	3	6	7	48	6.8	1.03
2.6 - 3.5	7	2	0	8	5	4	2	0	4	1	3	1	2	5	6	1	61	1.7	2.05
3.6 - 7.5	9	44	71	57	43	22	25	7	6	6	6	0	11	9	13	145	49.1	5.16	
7.6 - 12.5	3	0	10	47	24	18	27	5	6	5	1	3	6	7	7	6	193	26.0	6.72
12.6 - 18.5	0	0	4	5	2	3	3	3	1	1	0	0	1	3	1	0	30	4.3	14.51
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.1	20.36
TOTAL	27	50	108	110	95	49	56	17	21	14	13	15	27	31	33	29	703	100.0	7.16
PERCENT	3.8	7.1	15.4	15.6	13.6	7.0	8.0	2.4	3.0	2.0	1.8	2.1	3.8	4.4	4.7	4.1	100.0		
AV SPD	3.9	4.0	6.1	6.9	6.1	6.9	7.5	7.9	7.0	7.1	5.0	5.1	5.0	6.9	4.5	4.5			
AVERAGE SPEED FOR THIS TABLE EQUALS 6.1																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 4																			

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 39 OF 48)

MONTH OF OCTOBER

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .13 BUT LESS THAN OR EQUAL TO .14
 SITE MATCH
 PERIOD OF RECORD FROM 700601101 TO 74083124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT
 REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOMEAN SPEED(MPH)
CALM	0	0	0	1	1	0	1	1	1	0	0	0	0	1	0	0	7	1.0	1.00
CALM+ - 1.5	1	2	2	3	0	3	0	1	2	0	1	0	2	0	1	2	22	3.0	1.17
1.6 - 2.5	6	2	3	5	5	4	5	4	2	1	0	1	6	4	7	5	55	8.2	1.89
2.6 - 3.5	2	0	1A	15	19	12	13	6	5	7	5	2	9	9	6	13A	20.1	3.00	2.00
3.6 - 7.5	12	30	47	48	42	47	27	1A	19	17	16	0	15	22	17	10	356	59.4	4.29
7.6 - 12.5	0	4	7	4	1	7	9	5	2	6	0	1	2	2	1	2	53	7.9	5.71
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	21	48	77	76	6A	73	54	36	31	30	22	17	20	42	34	88	667	100.0	3.85
PERCENT	3.1	7.2	11.5	11.4	10.7	10.9	8.1	5.4	4.5	4.5	3.3	1.9	7.0	6.3	5.1	13.3	100.0		
AV SPD	3.8	4.5	4.6	4.3	4.2	4.9	4.9	4.6	4.7	5.3	4.7	4.5	4.6	3.9	3.5	4.0			
AVERAGE SPEED FOR THIS TABLE EQUALS	4.5																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	9																		

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .18 BUT LESS THAN OR EQUAL TO .22
 SITE MATCH
 PERIOD OF RECORD FROM 700601101 TO 74083124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT
 REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GEOMEAN SPEED(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	.4	1.00
CALM+ - 1.5	2	1	1	1	2	0	1	0	1	0	0	1	1	3	1	1	14	5.6	1.70
1.6 - 2.5	8	2	1	4	6	2	1	4	4	7	0	1	2	1	1	7	47	17.2	2.00
2.6 - 3.5	11	2	10	4	7	9	5	3	2	2	2	3	5	6	2	2	75	30.0	2.00
3.6 - 7.5	6	12	11	6	6	5	3	9	5	10	9	8	3	4	6	1	112	44.6	4.29
7.6 - 12.5	0	0	0	0	0	1	0	2	0	0	0	1	0	1	0	0	5	2.0	5.71
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	27	16	23	15	21	17	15	15	12	15	11	14	11	16	10	14	250	100.0	3.85
PERCENT	10.8	6.4	9.2	6.0	8.4	6.8	6.0	7.2	4.9	6.0	4.4	5.6	4.4	6.0	4.0	4.0	100.0		
AV SPD	3.0	4.0	4.6	3.3	2.9	3.7	3.5	4.2	3.5	3.9	4.8	4.0	2.8	3.1	4.4	3.7			
AVERAGE SPEED FOR THIS TABLE EQUALS	3.6																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	1																		

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 40 OF 48)

MONTH OF OCTOBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN
 SITE MATCH
 PERIOD OF RECORD FROM 70960101 TO 74083124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNE	TOTAL	PERCENT	GEOMEAN SPD(MPH)
CALM	1	1	0	1	0	0	0	0	0	0	0	0	0	0	0	1	4	1.6
CALM+	1.5	3	1	4	1	2	2	3	1	2	2	1	1	0	1	4	26	10.3
1.6 - 2.5	5	8	4	3	2	5	0	2	1	1	4	2	0	4	6	3	50	19.4
2.6 - 3.5	3	11	7	4	3	2	0	2	1	3	1	0	10	6	9	4	65	25.7
3.6 - 7.5	5	15	9	7	3	3	2	1	4	9	7	1	9	7	6	9	97	38.3
7.6 - 12.5	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	10	4.0
12.6 - 18.5	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	1	0.4
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0
TOTAL	17	35	26	16	10	12	2	6	4	16	14	4	20	20	26	71	253	6.0
PERCENT	6.7	13.8	10.3	6.3	4.0	4.7	.8	2.4	3.2	6.3	5.5	1.6	7.9	7.9	10.3	8.7	100.0	2.34
AV SPD	2.7	3.2	3.6	3.5	3.0	2.5	4.7	2.4	4.7	4.4	3.2	2.6	3.8	4.2	3.9	3.0		
AVERAGE SPEED FOR THIS TABLE EQUALS 3.5																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 2																		

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 41 OF 48)

MONTH OF NOVEMBER

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0

REQUEST NUMBER 604-44

SITE MATCH

PERIOD OF RECORD FROM 70061191 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GRD MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	1	1	1	0	2	0	0	0	1	2	0	1	0	0	0	0	1	9	1.9
1.6 - 2.5	1	0	1	0	1	0	1	2	0	1	0	0	0	1	3	2	23	4.9	1.93
2.6 - 3.5	4	5	1	3	0	2	1	2	2	1	0	0	0	1	3	4	33	7.0	2.98
3.6 - 7.5	12	8	17	29	17	7	5	5	19	9	5	8	15	24	24	10	196	41.4	6.98
7.6 - 12.5	3	4	9	19	9	5	3	5	13	14	4	19	26	19	17	151	34.4	9.28	
12.6 - 18.5	1	0	1	2	0	0	1	2	2	2	3	0	4	11	5	1	39	8.2	10.63
18.6+	0	0	0	0	0	0	0	1	0	1	0	1	4	4	0	0	11	2.3	19.74
TOTAL	26	26	30	35	29	14	11	17	18	29	23	14	46	67	54	75	474	100.0	5.48
PERCENT	5.5	5.5	6.3	7.4	6.1	3.0	2.3	3.6	3.8	6.1	4.9	3.0	9.7	14.1	11.4	7.4	100.0		
AV SPD	6.2	4.4	7.5	6.8	5.9	6.1	7.6	7.6	6.6	8.1	9.0	7.6	10.2	9.6	7.7	7.3			
AVERAGE SPEED FOR THIS TABLE EQUALS	7.6																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	21																		

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -0.9

REQUEST NUMBER 604-44

SITE MATCH

PERIOD OF RECORD FROM 70061191 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GRD MEAN SPD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
1.6 - 2.5	2	2	1	0	1	0	1	0	0	0	1	0	2	0	3	2	15	11.1	2.56
2.6 - 3.5	0	1	0	0	2	1	0	0	0	0	0	0	2	1	3	0	11	7.4	2.58
3.6 - 7.5	3	2	10	19	7	3	2	1	2	1	6	0	2	5	2	0	57	42.2	5.38
7.6 - 12.5	0	2	5	4	5	0	3	1	0	1	0	1	6	5	1	4	39	28.8	8.97
12.6 - 18.5	0	0	1	0	0	0	1	1	1	1	1	0	2	3	1	0	12	8.9	15.20
18.6+	0	0	1	1	0	0	0	0	0	0	0	0	0	0	0	0	2	1.5	19.44
TOTAL	5	5	17	15	15	4	7	3	3	4	8	1	14	14	10	6	139	100.0	5.38
PERCENT	3.7	5.0	12.6	11.0	11.1	3.0	5.2	2.2	2.2	3.0	5.9	.7	10.4	10.4	7.4	4.4	100.0		
AV SPD	4.3	5.1	7.5	6.3	6.2	5.0	7.6	10.8	9.3	8.7	6.7	10.3	7.4	8.8	5.0	6.7			
AVERAGE SPEED FOR THIS TABLE EQUALS	7.1																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	7																		

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 42 OF 48)

MONTH OF NOVEMBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .9 BUT LESS THAN OR EQUAL TO .9
SITE HATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NW	TOTAL	PERCENT	GEO MEAN SPD(MPH)	
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	.9	.30
CALM+ - 1.5	0	0	1	0	0	0	0	0	0	0	0	1	0	0	0	0	0	1	.9	1.25
1.6 - 2.5	1	2	1	0	2	0	0	0	1	0	0	0	0	0	0	0	0	4	3.4	2.06
2.6 - 3.5	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	7	6.0	3.06
3.6 - 7.5	7	7	4	2	6	6	0	0	3	1	2	0	0	0	2	0	10	8.6	5.77	
7.6 - 12.5	3	2	7	1	1	0	1	2	0	0	0	1	0	5	4	3	38	32.1	9.26	
12.6 - 18.5	0	0	0	1	0	0	0	0	0	1	0	0	3	4	2	2	5	6	5.2	15.73
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	15.47
TOTAL	12	7	14	14	10	6	1	4	4	2	1	0	0	0	0	0	1	.9	15.47	
PERCENT	19.3	6.0	12.1	12.1	8.6	5.2	.9	3.4	3.4	1.7	3.4	6.0	3.4	8.6	9.5	5.2	100.0		4.33	
AV SPD	6.4	5.9	6.6	8.3	5.5	5.3	12.3	7.1	4.3	11.5	7.5	5.7	12.6	8.8	5.1	7.2				
AVERAGE SPEED FOR THIS TABLE EQUALS	7.1																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	2																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO .8
SITE HATCH

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

REQUEST NUMBER 604-44

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NW	TOTAL	PERCENT	GEO MEAN SPD(MPH)	
CALM	0	1	0	1	1	2	2	1	0	0	0	0	0	1	0	0	0	9	1.2	.30
CALM+ - 1.5	5	4	0	1	2	1	2	0	0	2	0	1	2	1	2	2	25	3.5	1.17	
1.6 - 2.5	6	4	4	4	5	7	3	2	1	0	4	1	1	1	0	0	51	7.1	1.89	
2.6 - 3.5	3	5	4	3	4	4	7	0	2	4	1	4	2	7	4	5	53	8.7	2.91	
3.6 - 7.5	21	15	18	30	32	24	16	2	8	14	25	17	21	26	27	25	140	47.1	5.15	
7.6 - 12.5	1	1	0	16	1	1	2	1	0	11	18	17	24	23	21	22	197	26.6	9.24	
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	14.10	
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	15.73	
TOTAL	37	32	34	66	52	47	34	15	20	33	49	30	54	70	66	74	722	100.0	3.48	
PERCENT	5.1	4.4	4.7	9.1	7.2	6.5	4.7	2.1	2.9	4.6	6.8	5.4	7.5	9.7	9.1	10.2	100.0			
AV SPD	4.5	3.7	5.8	6.5	5.2	5.2	4.7	9.0	6.8	6.7	6.6	7.3	7.5	8.1	7.3	6.0				
AVERAGE SPEED FOR THIS TABLE EQUALS	6.4																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	7																			

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 43 OF 48)

MONTH OF NOVEMBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .8
SITE MATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70060101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNF	NF	ENF	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NW	TOTAL	PERCENT	GEO MEAN SFD(MPH)
CALM	0	1	0	0	0	0	0	0	0	0	1	0	0	0	0	0	2	4.4	1.10
CALM*	1	3	5	7	7	1	2	2	2	1	3	0	2	4	2	2	35	6.2	1.97
1.6 - 2.5	3	4	5	7	10	11	0	1	2	5	5	1	0	7	1	52	10.9	2.01	
2.6 - 3.5	2	4	4	7	10	11	4	3	4	6	7	3	5	7	2	76	14.4	2.77	
3.6 - 7.5	0	7	28	22	17	15	21	12	29	24	27	15	28	23	24	322	56.6	4.56	
7.6 - 12.5	0	0	0	0	1	4	5	2	6	4	1	4	13	19	0	70	12.3	9.22	
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	2	4	12.33	
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.00	
TOTAL	14	19	42	33	41	45	31	19	46	47	43	26	47	49	47	74	569	0.0	3.29
PERCENT	2.5	3.2	7.4	5.4	7.2	7.9	5.4	3.3	8.1	7.6	7.6	4.6	8.3	8.6	8.3	4.2	100.0		
AV SPD	3.6	3.1	3.8	3.7	3.6	4.1	5.6	4.6	4.4	4.6	4.3	5.3	5.9	6.8	5.3	5.4			
AVERAGE SPEED FOR THIS TABLE EQUALS 4.4																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 3																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 2.2
SITE MATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70163101 TO 74083124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNF	NF	ENF	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NW	TOTAL	PERCENT	GEO MEAN SFD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1.3
CALM*	0	1	2	1	3	0	1	2	1	1	0	1	1	0	1	0	14	4.7	1.88
1.6 - 2.5	4	4	4	5	4	4	3	3	0	1	1	0	3	2	2	1	23	13.4	1.99
2.6 - 3.5	3	2	9	15	6	9	4	3	1	7	2	1	1	5	5	4	63	27.8	2.14
3.6 - 7.5	2	1	0	12	13	11	17	4	13	19	15	16	10	14	12	0	140	53.7	4.62
7.6 - 12.5	0	0	0	0	0	0	1	0	1	0	1	4	1	1	4	1	14	4.7	2.42
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.00	
TOTAL	9	8	27	27	26	24	25	12	16	15	19	27	13	23	24	10	294	0.0	3.03
PERCENT	3.0	2.7	7.7	9.1	8.7	8.1	8.7	4.0	5.4	5.0	6.4	7.7	4.4	7.7	8.1	3.4	100.0		
AV SPD	2.6	2.4	3.0	3.4	3.2	3.7	4.5	3.2	4.5	3.9	4.6	5.3	6.4	4.5	5.0	3.2			
AVERAGE SPEED FOR THIS TABLE EQUALS 4.0																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 0																			

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 44 OF 48)

MONTH OF NOVEMBER

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DAILY AVERAGE) GREATER THAN 2.2
SITE NAME

REQUEST NUMBER 624-44

PERIOD OF RECORD FROM 20141110 TO 20141124
SPEED AND DIRECTION FROM 25 FT LVL
TEMPERATURE DIFFERENCE BETWEEN 100 AND 35
SPEED MEASURED AT 75 FT ADJUSTED TO 33 FT

SPEED (MPH)	WIND DIRECTION																TOTAL	PERCENT	GR. MEAN SPEED (MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW			
CALM	0	0	1	1	0	0	0	0	0	0	1	0	1	1	1	0	8	1.7	1.0
CALM+	6	4	7	7	5	3	7	0	0	1	2	1	3	4	3	0	46	9.6	1.0
1.6 - 2.5	10	10	6	5	7	5	5	6	1	0	3	3	7	13	14	3	103	21.6	1.0
2.6 - 3.5	4	4	5	7	6	4	5	2	2	5	9	5	17	15	9	10	112	23.4	1.0
3.6 - 7.5	2	1	3	12	2	9	17	8	9	10	28	36	28	19	13	6	203	42.5	1.0
7.6 - 12.5	0	0	0	0	0	0	0	1	0	0	2	1	1	5	0	0	6	1.2	1.0
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	1.0
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	1.0
TOTAL	22	27	18	28	20	21	30	17	15	16	45	46	57	52	39	29	478	100	2.31
PERCENT	4.6	4.8	3.8	5.9	4.2	4.4	6.3	3.6	3.1	3.3	9.4	9.6	11.9	10.9	8.2	6.1	100.0		
AV. SPD	2.2	2.3	2.3	3.1	2.4	3.6	3.9	3.9	4.4	4.4	4.0	4.6	3.8	3.1	2.9	2.6			
AVERAGE SPEED FOR THIS TABLE EQUALS 3.4																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 1																			

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 45 OF 48)

MONTH OF DECEMBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) LESS THAN OR EQUAL TO -1.0

REQUEST NUMBER 604-44

SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74093124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 175
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GRD MEAN SFD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	0	1	1	0	1	0	0	1	0	0	2	0	0	0	0	0	5	1.1	0.57
1.6 - 2.5	6	2	7	6	1	3	2	0	1	1	3	2	0	2	2	0	39	7.0	2.01
2.6 - 3.5	3	2	2	3	3	1	2	2	1	2	3	1	5	2	3	2	41	7.3	2.35
3.6 - 7.5	12	6	11	20	16	21	3	7	6	15	19	17	20	51	27	3	253	44.0	5.24
7.6 - 12.5	3	2	0	5	3	8	2	0	7	11	14	17	16	23	44	12	167	20.1	5.40
12.6 - 18.5	0	0	0	0	0	1	0	0	1	4	9	1	2	4	17	4	43	7.7	14.22
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	24	16	21	24	24	34	3	9	17	33	44	37	53	82	93	77	581	0.0	5.27
PERCENT	4.3	2.9	3.7	4.1	4.3	6.1	1.5	1.6	3.0	5.9	8.6	6.6	9.4	14.5	16.6	4.4	100.0		
AV SPD	4.5	4.9	4.2	5.2	5.1	6.4	4.3	5.0	6.6	7.3	8.1	6.2	7.1	7.1	9.2	8.8			
AVERAGE SPEED FOR THIS TABLE EQUALS 6.9																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 7																			

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.0 BUT LESS THAN OR EQUAL TO -1.0

REQUEST NUMBER 604-44

SITE HATCH
PERIOD OF RECORD FROM 70060101 TO 74093124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 175
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	PERCENT	GRD MEAN SFD(MPH)
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
1.6 - 2.5	4	2	0	0	0	0	0	0	0	0	0	0	0	0	1	0	7	1.7	1.78
2.6 - 3.5	1	1	0	2	3	0	1	0	2	1	0	1	1	0	1	0	14	3.0	2.52
3.6 - 7.5	6	2	2	5	9	8	4	2	4	5	3	4	4	1	4	2	66	18.3	5.20
7.6 - 12.5	0	0	2	6	4	3	1	0	1	2	3	2	2	6	2	1	35	24.2	8.54
12.6 - 18.5	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	0	6	4.7	14.17
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	11	5	2	13	16	11	5	2	5	10	11	8	10	8	11	3	141	0.0	4.40
PERCENT	7.8	3.6	1.4	9.2	11.3	7.8	4.3	1.6	5.7	7.1	7.8	5.7	7.1	5.7	7.8	2.1	100.0		
AV SPD	4.0	3.8	3.2	6.0	5.8	7.4	5.2	3.3	4.2	6.4	5.9	7.5	5.9	9.3	5.7	6.9			
AVERAGE SPEED FOR THIS TABLE EQUALS 5.0																			
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 7																			

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 46 OF 48)

MONTH OF DECEMBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.9 BUT LESS THAN OR EQUAL TO -1.9
 SITE MATCH
 PERIOD OF RECORD FROM 70060101 TO 74091124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO WIND (FPM)				
	N	NNE	NE	ENE	E	ESE	SE	SSF	S	SSW	SW	WSW	W	WNW	NW								
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
CALM+ - 1.5	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	2	1.0
1.6 - 2.5	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	0	2	5	4.7
2.6 - 3.5	1	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	1	4	4.7
3.6 - 7.5	11	1	1	7	4	0	2	1	0	4	2	4	1	1	3	4	4	43.0	43.0	43.0	5.44		
7.6 - 12.5	2	2	2	2	0	3	1	0	2	4	6	3	2	3	4	2	42	39.3	42.0	4.50			
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.00			
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.00			
TOTAL	14	3	3	9	5	3	5	1	4	11	11	11	3	5	17	6	107	100.0	5.44				
PERCENT	13.1	2.7	2.8	8.4	4.7	2.8	4.7	.9	3.7	10.3	10.3	10.3	2.8	4.7	12.1	5.6	100.0		5.44				
AV SPD	6.2	7.5	7.5	6.6	5.0	9.9	4.5	7.1	6.3	9.0	9.7	7.3	6.9	9.1	8.5	6.9			5.44				
AVERAGE SPEED FOR THIS TABLE EQUALS 7.5																							
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 2																							

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
 FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN -1.9 BUT LESS THAN OR EQUAL TO -1.9
 SITE MATCH
 PERIOD OF RECORD FROM 70060101 TO 74091124
 SPEED AND DIRECTION FROM 75 LEVEL
 TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
 SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	GEO WIND (FPM)				
	N	NNE	NE	ENE	E	ESE	SE	SSF	S	SSW	SW	WSW	W	WNW	NW								
CALM	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1.4	1.77
CALM+ - 1.5	0	2	1	1	2	2	0	0	0	1	0	1	0	1	2	0	0	0	17	1.0			
1.6 - 2.5	2	1	0	2	7	3	3	3	2	1	1	2	4	4	3	0	0	0	38	4.7			
2.6 - 3.5	1	2	3	4	7	3	4	5	5	7	5	3	2	5	6	7	54	43.0	43.0	5.44			
3.6 - 7.5	11	31	21	42	22	27	32	17	20	32	30	24	26	34	23	17	400	31.0	40.0	5.44			
7.6 - 12.5	9	10	15	39	17	9	3	0	9	29	35	14	7	20	24	7	201	31.3	31.3	4.50			
12.6 - 18.5	2	0	0	1	1	2	0	0	5	3	5	0	4	5	1	0	30	4.0	30.0	4.50			
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.00			
TOTAL	26	46	40	82	56	46	42	27	41	72	76	49	39	64	55	27	403	100.0	4.90				
PERCENT	3.2	5.1	5.0	11.1	7.0	5.7	5.2	3.4	5.1	9.1	9.5	6.1	4.9	8.0	6.9	7.0	100.0		4.90				
AV SPD	6.2	6.4	6.8	7.5	5.9	5.0	5.4	4.2	6.9	7.2	7.8	6.5	6.4	7.0	7.0	6.0			4.90				
AVERAGE SPEED FOR THIS TABLE EQUALS 6.7																							
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 5																							

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 47 OF 48)

MONTH OF DECEMBER

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .3 BUT LESS THAN OR EQUAL TO .8
SITE HATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70060101 TO 74003124
SPEED AND DIRECTION FROM 75 LFVFL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NWW	TOTAL	PERCENT	GEO MEAN
CALM	0	1	0	1	1	0	1	1	0	2	0	1	0	1	0	0	9	1.5	1.70
CALM+ - 1.5	4	1	0	2	4	3	2	4	0	1	0	3	1	2	0	2	29	4.9	1.86
1.6 - 2.5	2	3	2	0	5	3	1	4	4	3	3	5	2	2	3	45	7.6	2.00	
2.6 - 3.6	7	4	2	3	6	6	6	8	17	6	5	3	12	6	3	0	94	15.9	2.99
3.6 - 7.5	4	6	10	9	11	17	21	29	33	64	38	20	28	37	13	14	354	59.9	4.99
7.6 - 12.5	0	1	0	1	1	1	0	0	3	9	9	4	9	5	2	3	55	9.7	4.91
12.6 - 18.5	0	0	0	0	0	0	0	1	0	0	1	0	1	2	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	17	16	14	23	28	30	31	47	57	85	55	35	55	54	22	72	591	0.0	3.13
PERCENT	2.9	2.7	2.4	3.9	4.7	5.1	5.2	8.0	9.6	14.4	9.3	5.9	9.3	9.1	3.7	100.0			
AV SPD	2.8	3.5	4.4	5.5	3.2	3.7	3.9	4.3	4.6	5.2	5.7	4.8	5.0	5.4	5.8	4.8			
AVERAGE SPEED FOR THIS TABLE EQUALS	4.7																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	10																		

JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN .8 BUT LESS THAN OR EQUAL TO 2.2
SITE HATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70060101 TO 74003124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN 150 AND 35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

WIND DIRECTION

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NWW	TOTAL	PERCENT	GEO MEAN
CALM	0	1	2	0	0	1	3	0	0	9	0	0	1	0	0	1	6	2.5	1.80
CALM+ - 1.5	2	1	1	0	1	1	0	3	0	3	1	2	0	2	1	0	14	7.4	1.91
1.6 - 2.5	4	1	3	1	3	6	4	2	0	2	4	2	3	2	3	2	42	17.2	1.99
2.6 - 3.5	1	4	2	1	2	2	2	6	2	3	4	2	5	3	5	3	47	19.3	3.04
3.6 - 7.5	1	2	3	3	9	5	8	11	7	26	12	15	9	10	6	1	126	51.6	4.77
7.6 - 12.5	0	0	0	0	0	0	0	0	1	2	0	0	0	1	1	0	5	2.0	7.93
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00
TOTAL	8	9	10	5	15	15	14	22	10	46	21	21	18	18	16	7	244	0.0	2.28
PERCENT	3.3	3.7	4.1	2.0	6.1	6.1	5.7	9.0	4.1	14.8	8.6	8.6	7.4	7.4	6.6	2.9	100.0		
AV SPD	2.3	2.6	2.4	4.3	3.6	2.9	3.7	3.5	4.9	4.3	4.0	3.9	3.5	4.6	4.1	2.6			
AVERAGE SPEED FOR THIS TABLE EQUALS	3.7																		
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION =	3																		

HNP-2-FSAR-2

TABLE 2.3-16 (SHEET 48 OF 48)

MONTH OF DECEMBER

JOINT FREQUENCY TABLES OF WIND SPEED AND DIRECTION
FOR TEMPERATURE DIFFERENCE (DEG F/100FT) GREATER THAN 2.2
SITE MATCH

REQUEST NUMBER 604-44

PERIOD OF RECORD FROM 70060101 TO 74003124
SPEED AND DIRECTION FROM 75 LEVEL
TEMPERATURE DIFFERENCE BETWEEN .150 AND .35
SPEED MEASURED AT 75FT ADJUSTED TO 33 FT

SPEED(MPH)	WIND DIRECTION																TOTAL	PERCENT	CFO	MEAN SPD(MPH)
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW				
CALM	1	1	0	0	4	0	0	0	2	1	0	0	0	3	1	1	14	3.3	.35	
1.6 - 2.5	3	2	3	3	7	6	1	2	7	4	5	10	4	3	2	3	60	14.1	1.94	
2.6 - 3.5	0	2	1	0	1	6	1	1	7	7	10	11	15	11	7	7	101	21.7	2.99	
3.6 - 7.5	3	4	1	5	7	3	3	8	16	11	24	12	12	12	13	2	143	33.6	4.50	
7.6 - 12.5	0	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	2	.5	0.35	
12.6 - 18.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00	
18.6+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.00	
TOTAL	8	17	4	17	26	24	9	17	32	45	51	45	40	36	37	17	426	0.0	1.89	
PERCENT	1.9	3.1	1.0	4.0	6.1	5.6	1.9	4.0	7.5	10.6	12.0	10.6	9.4	8.4	8.7	4.0	100.0			
AV SPD	2.5	2.5	1.9	3.3	2.2	2.7	3.0	2.9	3.5	3.4	3.6	2.8	3.0	2.8	2.9	2.4				

AVERAGE SPEED FOR THIS TABLE EQUALS 3.0
HOURS IN ABOVE TABLE WITH VARIABLE DIRECTION = 5

TABLE 2.3-17
LIST OF COMPUTER RUNS

<u>Run Number</u>	<u>Vent Identification</u>	<u>Data Used</u>	<u>Type of Run</u>	<u>Hourly or Joint Frequency Data Used</u>	<u>Grazing Season or Annual Data</u>	To Be Used for Evaluating Releases from the Following <u>Vent^(a)</u>	<u>Location of Results in the Report</u>
HX-1	Stack	4 years Hatch	Elevated release	Joint frequency	Annual	Stack	Tables 2.3-21 and 2.3-23
HX-2	Reactor building vent	4 years Hatch	Ground release in building wake	Joint frequency	Annual	Vent	Tables 2.3-22 and 2.3-24

a. See table 2.3-18.

TABLE 2.3-18

GASEOUS DISCHARGE POINTS (HNP-1 AND HNP-2)

<u>System</u>	<u>Vent</u>	<u>Mode ID Number</u>	<u>Months Operating</u>
Reactor building exhaust	Reactor building	1	All
Refueling floor exhaust	Reactor building	1	All
Turbine building exhaust	Reactor building	1	All
Radwaste building exhaust	Reactor building	1	All
Control building exhaust	Reactor building	1	All
Waste gas treatment	Stack	1	All
Off-gas	Stack	1	All
Gland-seal	Stack	1	All
Mechanical vacuum pump	Stack	1 (startup only)	All

TABLE 2.3-19

VENT DESIGN INFORMATION (HNP-1 AND HNP-2)

<u>Vent</u>	<u>Location</u>	<u>Discharge Elevation Above Grade (m)</u>	<u>Height of Discharge Above Maximum Building Elevation (m)</u>	<u>Effective Vent Diameter (m)</u>	<u>Velocity at Point of Discharge (m/s)</u>	<u>Operating Mode Identification Number</u>
Reactor bldg vent, Unit 1	Reactor bldg roof	49.7	3.1	4.6	5.9 ^(a)	1
Reactor bldg vent, Unit 2	Reactor bldg	49.7	3.1	4.6	4.0 ^(a)	1
Main stack	550-ft east of reactor bldg	120	73	0.81	4.1	1

a. Top-hat on vent prevents vertical discharge.

TABLE 2.3-20

TABULATION OF INPUT ASSUMPTIONS FOR CALCULATIONS

<u>Parameter</u>	<u>Assumed Value or Characteristic</u>
Height of meteorological instruments for stack runs	150-ft speed and direction, ΔT 150-35, speed adjusted to represent 393 ft
Height of meteorological instruments for ground-level releases	75-ft speed and direction, ΔT 150-35, 75-ft speed adjusted to 33 ft
Height of meteorological instruments for hourly wake-split runs	Not applicable to HNP
Height of meteorological instruments for wake-split runs using joint frequency tables	Not applicable to HNP
Method for determining stability and diffusion coefficients	Temperature difference using Regulatory Guide 1.23 and Pasquill curves
Calms treatment	Assumed 0.3 mph. Assumed to have same direction as measured
Upper limit for $\sigma(m)$	1000
Height of tallest structure for computation of $\Sigma_{eff}(m)$	46.6
Vent exit conditions	From table 2.3-19
Delta-temperature correction factor	0.56 prior to 9/72
Terrain height	See figure 2.3-12
Terrain correction factors	Figure 2 of Regulatory Guide 1.111

HNP-2-FSAR-2

TABLE 2.3-21

ATMOSPHERIC DISPERSION FACTOR FOR HNP

IN DIRECTION SECTION	RUN TYPE- I/O SEC/M ³				VENT STACK DISTANCE (METERS)		SEASONAL-ANNUAL-REG-MX-1 JFT			
	1250	2413	4022	5631	7240	12047	24135	40225	56315	72405
N	4.44E-09	3.30E-09	3.77E-08	3.42E-09	2.47E-09	1.35E-09	4.74E-09	2.70E-09	1.83E-09	1.36E-09
NNE	4.40E-09	4.65E-08	4.87E-09	3.44E-09	2.74E-09	1.34E-09	4.72E-09	2.62E-09	1.77E-09	1.30E-09
NE	5.85E-09	5.06E-08	3.85E-09	3.05E-09	3.08E-09	1.45E-09	5.12E-09	2.89E-09	1.97E-09	1.46E-09
NNE	4.79E-09	4.40E-09	2.02E-09	2.19E-09	2.18E-09	1.11E-09	4.00E-09	2.79E-09	1.57E-09	1.17E-09
E	7.31E-09	4.34E-09	2.80E-09	2.09E-09	1.88E-09	8.72E-09	3.32E-09	1.93E-09	1.33E-09	9.98E-10
ESE	6.67E-09	4.53E-08	4.72E-09	2.94E-09	2.74E-09	1.13E-09	4.06E-09	2.36E-09	1.63E-09	1.23E-09
SE	1.00E-07	7.91E-09	4.84E-09	3.63E-09	2.55E-09	1.18E-09	4.15E-09	2.40E-09	1.65E-09	1.24E-09
SE	7.80E-09	4.37E-09	4.24E-09	2.93E-09	2.34E-09	1.04E-09	3.62E-09	2.04E-09	1.39E-09	1.03E-09
S	7.93E-09	4.47E-09	4.04E-09	2.88E-09	1.99E-09	8.95E-09	3.02E-09	1.89E-09	1.15E-09	8.49E-10
SSW	5.73E-09	5.27E-09	3.41E-08	2.68E-09	1.90E-09	8.89E-09	3.04E-09	1.73E-09	1.14E-09	8.79E-10
SW	8.41E-09	8.04E-09	4.82E-08	3.67E-09	2.58E-09	1.23E-09	4.30E-09	2.42E-09	1.64E-09	1.22E-09
WSW	8.48E-09	9.34E-09	7.88E-09	4.42E-09	3.44E-09	1.43E-09	5.53E-09	3.04E-09	2.04E-09	1.50E-09
W	1.11E-07	9.84E-09	7.88E-09	5.09E-09	3.75E-09	1.49E-09	5.78E-09	3.21E-09	2.17E-09	1.50E-09
WNW	7.94E-09	4.85E-09	3.27E-09	2.68E-09	2.08E-09	1.36E-09	4.78E-09	2.67E-09	1.81E-09	1.34E-09
NW	4.24E-09	3.71E-09	2.78E-09	2.77E-09	2.74E-09	1.47E-09	5.20E-09	2.91E-09	1.97E-09	1.45E-09
NNW	3.43E-09	3.57E-08	3.05E-09	2.84E-09	2.45E-09	1.15E-09	4.04E-09	2.30E-09	1.57E-09	1.16E-09

IN DIRECTION SECTION	RUN TYPE- DEPLETED I/O SEC/M ³				DISTANCE (METERS)		SEASONAL-ANNUAL-REG-MX-1 JFT			
	1250	2413	4022	5631	7240	12047	24135	40225	56315	72405
N	4.71E-09	3.25E-09	3.54E-09	3.41E-09	2.70E-09	1.26E-09	4.42E-09	2.47E-09	1.66E-09	1.22E-09
NNE	4.70E-09	4.44E-09	4.42E-09	3.42E-09	2.58E-09	1.24E-09	4.27E-09	2.34E-09	1.55E-09	1.13E-09
NE	4.59E-09	4.86E-09	3.47E-09	3.71E-09	2.87E-09	1.33E-09	4.58E-09	2.54E-09	1.78E-09	1.25E-09
NNE	4.52E-09	4.21E-09	2.78E-09	2.06E-09	2.02E-09	1.01E-09	3.53E-09	1.97E-09	1.33E-09	9.76E-10
E	7.02E-09	4.17E-09	2.85E-09	1.04E-09	1.54E-09	7.99E-09	2.93E-09	1.65E-09	1.11E-09	8.17E-10
ESE	8.29E-09	4.19E-09	4.04E-09	2.73E-09	2.04E-09	1.02E-09	3.54E-09	2.02E-09	1.37E-09	1.01E-09
SE	1.07E-07	7.59E-09	4.52E-09	3.14E-09	2.32E-09	1.05E-09	3.54E-09	1.99E-09	1.34E-09	9.85E-10
SE	7.45E-09	6.04E-09	4.00E-09	2.72E-09	2.15E-09	9.59E-09	3.18E-09	1.75E-09	1.17E-09	8.48E-10
S	7.80E-09	8.33E-09	3.79E-09	2.67E-09	1.79E-09	7.40E-09	2.54E-09	1.37E-09	8.99E-10	6.42E-10
SSW	4.44E-09	5.03E-09	3.29E-09	2.28E-09	1.73E-09	7.91E-09	2.63E-09	1.45E-09	9.64E-10	7.05E-10
SW	9.18E-09	7.87E-09	4.52E-09	3.21E-09	2.34E-09	1.10E-09	3.76E-09	2.04E-09	1.37E-09	9.94E-10
WSW	9.20E-09	8.95E-09	6.44E-09	4.27E-09	3.17E-09	1.47E-09	4.84E-09	2.60E-09	1.71E-09	1.23E-09
W	1.04E-07	8.37E-09	7.44E-09	4.72E-09	3.45E-09	1.53E-09	5.04E-09	2.73E-09	1.80E-09	1.30E-09
WNW	7.44E-09	4.65E-09	3.11E-09	2.78E-09	1.87E-09	1.25E-09	4.24E-09	2.33E-09	1.55E-09	1.12E-09
NW	4.05E-09	3.57E-09	2.45E-09	2.42E-09	2.50E-09	1.37E-09	4.75E-09	2.62E-09	1.75E-09	1.28E-09
NNW	3.49E-09	3.47E-09	3.77E-09	2.69E-09	2.30E-09	1.07E-09	3.72E-09	2.09E-09	1.41E-09	1.04E-09

IN DIRECTION SECTION	RUN TYPE- DEPOSITION I/O M-2				DISTANCE (METERS)		SEASONAL-ANNUAL-REG-MX-1 JFT			
	1250	2413	4022	5631	7240	12047	24135	40225	56315	72405
N	4.84E-09	1.84E-09	6.81E-10	3.78E-10	2.07E-10	7.12E-11	1.63E-11	7.04E-12	4.84E-12	2.63E-12
NNE	7.08E-09	2.98E-09	1.85E-09	5.84E-10	3.10E-10	1.07E-10	2.64E-11	1.07E-11	6.10E-12	3.95E-12
NE	8.53E-09	3.43E-09	1.22E-09	5.13E-10	3.77E-10	1.32E-10	3.03E-11	1.31E-11	7.49E-12	4.94E-12
NNE	9.51E-09	3.57E-09	1.22E-09	5.09E-10	3.64E-10	1.24E-10	2.90E-11	1.32E-11	7.64E-12	4.96E-12
E	1.09E-09	3.44E-09	1.29E-09	4.20E-10	3.77E-10	1.33E-10	3.16E-11	1.43E-11	8.47E-12	5.59E-12
ESE	1.34E-09	4.49E-09	1.58E-09	7.12E-10	4.34E-10	1.51E-10	3.57E-11	1.61E-11	9.37E-12	6.10E-12
SE	1.47E-09	4.88E-09	1.55E-09	7.31E-10	4.44E-10	1.45E-10	3.64E-11	1.64E-11	9.55E-12	6.20E-12
SE	4.00E-09	3.22E-09	1.83E-09	4.84E-10	2.89E-10	1.03E-10	2.41E-11	1.09E-11	6.24E-12	4.05E-12
S	7.17E-09	2.45E-09	8.44E-10	4.11E-10	2.51E-10	8.77E-11	2.04E-11	9.18E-12	5.31E-12	3.45E-12
SSW	4.37E-09	2.30E-09	7.08E-10	3.70E-10	2.32E-10	8.04E-11	1.88E-11	8.29E-12	4.71E-12	3.09E-12
SW	8.93E-09	3.22E-09	1.84E-09	4.28E-10	3.05E-10	1.06E-10	2.45E-11	1.08E-11	6.19E-12	4.09E-12
WSW	1.00E-09	3.47E-09	1.34E-09	4.35E-10	3.90E-10	1.34E-10	3.10E-11	1.35E-11	7.75E-12	5.01E-12
W	1.39E-09	5.11E-09	1.87E-09	7.83E-10	4.78E-10	1.64E-10	3.89E-11	1.73E-11	9.98E-12	6.47E-12
WNW	9.77E-09	3.48E-09	1.18E-09	4.81E-10	3.45E-10	1.24E-10	2.89E-11	1.28E-11	7.41E-12	4.80E-12
NW	4.13E-09	2.39E-09	8.31E-10	4.14E-10	2.54E-10	8.89E-11	2.05E-11	8.94E-12	5.13E-12	3.33E-12
NNW	3.99E-09	1.84E-09	6.04E-10	2.91E-10	1.80E-10	6.18E-11	1.41E-11	6.17E-12	3.51E-12	2.28E-12

HNP-2-FSAR-2

TABLE 2.3-22

ATMOSPHERIC DISPERSION FACTORS FOR HNP

IN DIRECTION	RUM TYPE- 1/0 SEC/M3				VENT-REACTOR BLDG (GROUND) SEASON-ANNUAL				REQ-HX-2 4 YRS JFT	
	1250	2413	4022	5631	7240	12067	24135	40225	56315	72405
N	6.87E-04	2.14E-04	1.07E-07	3.44E-07	2.19E-07	4.44E-04	2.59E-08	1.30E-08	8.53E-09	6.21E-09
NNE	8.71E-04	2.73E-04	8.80E-07	4.59E-07	2.98E-07	1.11E-07	3.23E-08	1.62E-08	1.05E-09	7.72E-09
NE	9.38E-04	2.93E-04	9.50E-07	4.94E-07	3.23E-07	1.21E-07	3.53E-08	1.78E-08	1.16E-09	8.49E-09
NNE	7.42E-04	2.32E-04	7.45E-07	3.98E-07	2.60E-07	9.16E-08	2.89E-08	1.46E-08	9.58E-09	7.01E-09
E	4.14E-04	2.49E-04	8.90E-07	4.50E-07	2.95E-07	1.12E-07	3.37E-08	1.69E-08	1.12E-09	8.23E-09
ESE	7.77E-04	2.44E-04	8.11E-07	4.23E-07	2.77E-07	1.05E-07	3.11E-08	1.59E-08	1.04E-09	7.64E-09
SE	7.88E-04	2.48E-04	8.25E-07	4.27E-07	2.81E-07	1.07E-07	3.20E-08	1.61E-08	1.07E-09	7.89E-09
SE	4.13E-04	1.93E-04	4.60E-07	3.34E-07	2.19E-07	8.27E-08	2.44E-08	1.25E-08	8.24E-09	6.05E-09
S	4.42E-04	2.01E-04	4.61E-07	3.34E-07	2.25E-07	8.47E-08	2.49E-08	1.26E-08	8.27E-09	6.06E-09
SSW	4.80E-04	1.80E-04	4.84E-07	3.03E-07	1.97E-07	7.31E-08	2.13E-08	1.07E-08	7.00E-09	5.09E-09
SW	7.15E-04	2.24E-04	7.33E-07	3.80E-07	2.48E-07	9.24E-08	2.72E-08	1.37E-08	9.01E-09	6.58E-09
WSW	7.58E-04	2.34E-04	7.58E-07	3.90E-07	2.53E-07	9.29E-08	2.84E-08	1.38E-08	9.13E-09	6.33E-09
W	4.79E-04	2.75E-04	8.62E-07	4.59E-07	2.99E-07	1.10E-07	3.19E-08	1.60E-08	1.05E-09	7.61E-09
WNW	7.84E-04	2.48E-04	7.90E-07	4.10E-07	2.68E-07	9.79E-08	2.91E-08	1.41E-08	9.16E-09	6.64E-09
NW	7.16E-04	2.25E-04	7.28E-07	3.74E-07	2.47E-07	8.97E-08	2.58E-08	1.29E-08	8.43E-09	6.12E-09
NNW	4.19E-04	1.97E-04	4.69E-07	3.29E-07	2.14E-07	7.89E-08	2.27E-08	1.14E-08	7.42E-09	5.39E-09

IN DIRECTION	RUM TYPE- DEPLETED 1/0 SEC/M3				DISTANCE (METERS)					
	1250	2413	4022	5631	7240	12067	24135	40225	56315	72405
N	4.43E-04	1.64E-04	4.81E-07	2.64E-07	1.53E-07	4.16E-04	1.24E-08	5.29E-09	3.02E-09	1.97E-09
NNE	7.14E-04	2.07E-04	6.20E-07	3.04E-07	1.91E-07	6.45E-04	1.54E-08	6.54E-09	3.76E-09	2.45E-09
NE	7.49E-04	2.22E-04	6.78E-07	3.31E-07	2.07E-07	7.01E-04	1.71E-08	7.22E-09	4.12E-09	2.69E-09
NNE	4.80E-04	1.76E-04	5.42E-07	2.85E-07	1.85E-07	4.64E-04	1.39E-08	5.99E-09	3.39E-09	2.22E-09
E	4.68E-04	1.96E-04	6.88E-07	3.80E-07	1.89E-07	6.50E-04	1.61E-08	6.87E-09	3.96E-09	2.61E-09
ESE	4.38E-04	1.86E-04	5.74E-07	2.82E-07	1.77E-07	6.09E-04	1.50E-08	6.41E-09	3.69E-09	2.42E-09
SE	4.47E-04	1.88E-04	5.84E-07	2.84E-07	1.81E-07	6.23E-04	1.55E-08	6.60E-09	3.80E-09	2.51E-09
SE	4.03E-04	1.66E-04	4.53E-07	2.23E-07	1.40E-07	4.81E-04	1.19E-08	5.07E-09	2.92E-09	1.92E-09
S	4.24E-04	1.53E-04	4.44E-07	2.30E-07	1.44E-07	4.90E-04	1.20E-08	5.11E-09	2.93E-09	1.92E-09
SSW	4.75E-04	1.37E-04	4.15E-07	2.02E-07	1.24E-07	4.25E-04	1.03E-08	4.35E-09	2.48E-09	1.62E-09
SW	4.87E-04	1.70E-04	5.10E-07	2.53E-07	1.59E-07	5.39E-04	1.32E-08	4.57E-09	3.19E-09	2.09E-09
WSW	4.21E-04	1.79E-04	5.37E-07	2.68E-07	1.62E-07	5.41E-04	1.29E-08	4.44E-09	3.09E-09	2.01E-09
W	7.21E-04	2.00E-04	6.31E-07	3.04E-07	1.91E-07	6.42E-04	1.44E-08	6.51E-09	3.71E-09	2.41E-09
WNW	4.87E-04	1.88E-04	5.45E-07	2.74E-07	1.70E-07	5.69E-04	1.36E-08	5.71E-09	3.24E-09	2.11E-09
NW	4.87E-04	1.71E-04	5.14E-07	2.69E-07	1.54E-07	5.22E-04	1.25E-08	5.25E-09	2.99E-09	1.94E-09
NNW	4.04E-04	1.50E-04	4.33E-07	2.20E-07	1.37E-07	4.59E-04	1.10E-08	4.62E-09	2.63E-09	1.71E-09

IN DIRECTION	RUM TYPE- DEPOSITION D/D M-2				DISTANCE (METERS)					
	1250	2413	4022	5631	7240	12067	24135	40225	56315	72405
N	7.14E-04	7.73E-09	2.08E-09	9.27E-10	5.34E-10	1.69E-10	3.44E-11	1.29E-11	6.48E-12	4.02E-12
NNE	4.59E-04	1.13E-04	2.98E-09	1.36E-04	7.83E-10	2.48E-10	5.09E-11	1.87E-11	9.49E-12	5.89E-12
NE	5.23E-04	1.29E-04	3.30E-09	1.54E-04	8.90E-10	2.82E-10	5.79E-11	2.13E-11	1.08E-11	6.70E-12
NNE	7.83E-04	9.45E-09	2.40E-09	1.13E-04	6.53E-10	2.07E-10	4.25E-11	1.54E-11	7.92E-12	4.92E-12
E	4.23E-04	1.04E-04	2.75E-09	1.25E-04	7.21E-10	2.24E-10	4.69E-11	1.77E-11	8.74E-12	5.43E-12
ESE	4.54E-04	1.12E-04	2.94E-09	1.35E-04	7.77E-10	2.44E-10	5.04E-11	1.88E-11	9.43E-12	5.85E-12
SE	4.88E-04	1.01E-04	2.68E-09	1.21E-04	6.95E-10	2.20E-10	4.52E-11	1.64E-11	8.43E-12	5.23E-12
SE	2.88E-04	4.41E-04	1.74E-09	7.92E-10	4.57E-10	1.45E-10	2.97E-11	1.09E-11	5.44E-12	3.44E-12
S	2.44E-04	6.02E-09	1.69E-09	7.22E-10	4.14E-10	1.32E-10	2.71E-11	9.94E-12	5.05E-12	3.13E-12
SSW	2.43E-04	5.99E-09	1.68E-09	7.19E-10	4.14E-10	1.31E-10	2.69E-11	9.90E-12	5.02E-12	3.12E-12
SW	7.30E-04	4.14E-09	2.14E-09	9.76E-10	5.83E-10	1.78E-10	3.64E-11	1.35E-11	6.82E-12	4.24E-12
WSW	4.19E-04	1.03E-04	2.72E-09	1.24E-04	7.13E-10	2.24E-10	4.64E-11	1.71E-11	8.05E-12	5.37E-12
W	4.38E-04	1.08E-04	2.84E-09	1.29E-04	7.45E-10	2.34E-10	4.85E-11	1.78E-11	9.04E-12	5.61E-12
WNW	7.79E-04	9.37E-09	2.44E-09	1.12E-04	6.45E-10	2.04E-10	4.20E-11	1.54E-11	7.82E-12	4.86E-12
NW	7.36E-04	8.28E-09	2.18E-09	9.92E-10	5.72E-10	1.81E-10	3.72E-11	1.37E-11	6.94E-12	4.31E-12
NNW	2.57E-04	4.74E-09	1.47E-09	7.40E-10	4.38E-10	1.39E-10	2.85E-11	1.05E-11	5.31E-12	3.30E-12

HNP-2-FSAR-2

TABLE 2.3-23 (SHEET 1 OF 2)

DIFFUSION AND DEPOSITION ESTIMATES FOR ALL RECEPTOR LOCATIONS

Release Point: Stack				Season: Annual				Computer Run ID: HX-1				
Direction	Distance to Nearest Milk Cow	X/Q	Depleted X/Q	D/Q	Distance to Nearest Meat Animal	X/Q	Depleted X/Q	D/Q	Distance to Nearest Milk Goat	X/Q	Depleted X/Q	D/Q
	(m)	(s/m ³)	(s/m ³)	(m ⁻²)	(m)	(s/m ³)	(s/m ³)	(m ⁻²)	(m ³)	(s/m ³)	(s/m ³)	(m ⁻²)
N	-(^a)	2.5E-08	N/A(^b)	1.7E-10	2574-4020	3.7E-08	N/A	1.6E-09	-	2.5E-09	N/A	1.7E-10
NNE	4827	4.2E-08		6.9E-10	4660	4.4E-08		7.3E-10	-	2.4E-08		2.5E-10
NE	-	2.7E-08		3.1E-10	5310	4.0E-08		6.8E-10	-	2.7E-08		3.1E-10
ENE	-	2.0E-08		3.0E-10	6760	2.2E-08		4.2E-10	-	2.0E-08		3.0E-10
E	-	1.5E-08		3.1E-10	-	1.5E-08		3.1E-10	-	1.5E-08		3.1E-10
ESE	-	2.0E-08		3.6E-10	5960	2.8E-08		6.4E-10	-	2.0E-08		3.6E-10
SE	6918	2.6E-08		4.7E-10	3700-4180	5.0E-08		1.8E-09	-	2.2E-08		3.6E-10
SSE	7080	2.4E-08		3.1E-10	3380	5.3E-08		1.5E-09	-	2.1E-08		2.4E-10
S	7400	1.8E-08		2.3E-10	2570-4340	6.3E-09		2.3E-09	-	1.7E-08		2.1E-10
SSW	-	1.6E-08		1.9E-10	3050	4.4E-08		1.4E-09	-	1.6E-08		1.9E-10
SW	6918	2.6E-08		3.2E-10	2090-4670	8.6E-08		4.2E-09	-	2.3E-08		2.5E-10
WSW	6275	4.1E-08		5.2E-10	1930	9.4E-08		5.8E-09	-	3.0E-08		3.2E-10
W	-	3.2E-08		3.9E-10	2730-4500	1.1E-07		4.0E-09	-	3.2E-08		3.9E-10
WNW	-	1.8E-08		2.9E-10	-	1.8E-08		3.0E-10	-	1.8E-08		2.9E-10
NW	-	2.4E-08		2.1E-10	7080	2.8E-08		2.6E-10	-	2.4E-08		2.1E-10
NNW	8000	2.1E-08		1.4E-10	4340-4670	3.7E-08		5.0E-10	-	2.1E-08		1.4E-10

a. (-) indicates receptor distance is greater than 8000 m; diffusion values given are for 8000 m.

b. N/A indicates that diffusion information for this run was not used in dose calculation for receptors in this column.

HNP-2-FSAR-2

TABLE 2.3-23 (SHEET 2 OF 2)

Direction	Distance to Residences (m)	X/Q (s/m ³)	Depleted X/Q (s/m ³)	D/Q (m ⁻²)	Distance to Vegetable Garden (m)	X/Q (s/m ³)	Depleted X/Q (s/m ³)	D/Q (m ⁻²)	Nearest Site Boundary (m ³)	X/Q (s/m ³)	Depleted X/Q (s/m ³)	D/Q (m ⁻²)
N	2574-4800	4.0E-08	3.7E-08	1.7E-09	2574-4800	4.0E-08	N/A	1.7E-09	1638	4.0E-08	3.8E-08	3.5E-09
NNE	4827	4.1E-08	4.0E-08	6.9E-10	4700-4820	4.1E-08		7.6E-10	1950	4.4E-08	4.1E-08	3.9E-09
NE	4505	3.9E-08	3.7E-08	9.1E-10	5470	4.0E-08		6.6E-10	1882	5.5E-08	5.3E-08	5.1E-09
ENE	7884	2.0E-08	1.8E-08	3.1E-10	8000	2.0E-08		3.1E-10	1547	5.8E-08	5.6E-08	7.4E-09
E	8000	1.5E-08	1.4E-08	3.1E-10	8000	1.5E-08		3.1E-10	1402	6.7E-08	6.4E-08	9.4E-09
ESE	4660	3.7E-08	3.4E-08	1.1E-09	4660	3.7E-08		1.1E-09	1753	7.9E-08	7.4E-08	8.5E-09
SE	3200-4800	5.7E-08	5.4E-08	2.5E-09	2090-4800	8.8E-08		7.0E-09	1814	9.5E-08	9.0E-08	8.5E-09
SSE	2090 ³ -4800	6.5E-08	6.2E-08	4.5E-09	2413-4800	6.3E-08		3.2E-09	1530	7.2E-08	6.9E-08	7.1E-09
S	1760-4800	7.2E-08	6.8E-08	4.9E-09	1760-4800	7.2E-08		4.9E-09	1554	7.3E-08	7.0E-08	5.6E-09
SSW	3050-4800	4.4E-08	4.2E-08	1.5E-09	3540-4800	3.7E-08		1.4E-09	1585	6.2E-08	5.9E-08	5.6E-09
SW	1600-4800	9.7E-08	9.2E-08	6.7E-09	1930-4800	9.1E-08		4.6E-09	1410	9.8E-08	9.4E-08	7.9E-09
WSW	1760-4800	9.4E-08	9.0E-08	6.5E-09	1760-4800	9.4E-08		6.5E-09	1516	9.3E-08	8.9E-08	8.3E-09
W	2090-4800	1.0E-07	9.1E-08	6.5E-09	2090-4800	1.0E-07		6.5E-09	1501	1.0E-07	9.8E-08	1.1E-08
WNW	7884	1.8E-08	1.7E-08	2.9E-10	7884	1.8E-08		2.9E-10	1524	6.8E-08	6.5E-08	7.5E-09
NW	6275	3.0E-08	2.8E-08	3.3E-10	6275	3.0E-08		3.3E-10	1570	4.3E-08	4.3E-08	4.8E-09
NNW	3050-4800	4.1E-08	3.8E-09	1.1E-09	3378-4800	4.1E-08		8.5E-10	1646	3.1E-08	3.0E-08	2.9E-09

HNP-2-FSAR-2

TABLE 2.3-24 (SHEET 1 OF 2)

DIFFUSION AND DEPOSITION ESTIMATES FOR ALL RECEPTOR LOCATIONS

Release Point: Assumed ground in building wake

Season: Annual

Computer Run ID: HX-1
604-29

Direction	Distance to Nearest Milk Cow (m)	X/Q (s/m ³)	Depleted X/Q (s/m ³)	D/Q (m ⁻²)	Distance to Nearest Meat Animal (m)	X/Q (s/m ³)	Depleted X/Q (s/m ³)	D/Q (m ⁻²)	Distance to Nearest Milk Goat (m ³)	X/Q (s/m ³)	Depleted X/Q (s/m ³)	D/Q (m ⁻²)
N	-(a)	2.0E-07	N/A ^(b)	4.3E-10	2574	1.9E-06	N/A	6.5E-09	-	2.0E-07	N/A	4.3E-10
NNE	4827	6.1E-07		1.9E-09	4660	6.4E-07		2.0E-09	-	2.5E-07		6.3E-10
NE	-	2.7E-07		7.2E-10	5310	5.4E-07		1.7E-09	-	2.7E-07		7.2E-10
ENE	-	2.2E-07		5.3E-10	6760	2.9E-07		7.6E-10	-	2.2E-07		5.3E-10
E	-	2.5E-07		5.8E-10	-	2.5E-07		5.8E-10	-	2.5E-07		5.8E-10
ESE	-	2.3E-07		6.3E-10	5960	3.9E-07		1.2E-09	-	2.3E-07		6.3E-10
SE	6918	3.0E-07		7.4E-10	3700	9.6E-07		3.2E-09	-	2.4E-07		5.6E-10
SSE	7080	2.3E-07		4.9E-10	3380	8.9E-07		2.6E-09	-	1.8E-07		3.7E-10
S	7400	2.1E-07		3.9E-10	2570	1.7E-06		5.2E-09	-	1.9E-07		3.4E-10
SSW	-	1.6E-07		3.4E-10	3050	1.0E-06		3.1E-09	-	1.6E-07		3.4E-10
SW	6918	2.6E-07		6.0E-10	2090	3.0E-06		1.1E-08	-	2.1E-07		4.6E-10
WSW	6275	3.21E-07		1.0E-09	1930	3.6E-06		1.7E-08	-	2.1E-07		5.8E-10
W	-	2.5E-07		6.0E-10	2730	2.1E-06		7.6E-09	-	2.5E-07		6.0E-10
WNW	-	2.2E-07		5.2E-10	-	2.2E-07		5.2E-10	-	1.2E-07		5.2E-10
NW	-	2.0E-07		4.6E-10	7080	2.5E-07		6.0E-10	-	2.0E-07		4.6E-10
NNW	8000	1.8E-07		3.6E-10	4340	5.6E-07		1.4E-09	-	1.8E-07		3.6E-10

a. (-) indicates receptor distance is greater than 8000 m; diffusion values given are for 8000 m.

b. N/A indicates that diffusion information for this run was not used in dose calculation for receptors in this column.

HNP-2-FSAR-2

TABLE 2.3-24 (SHEET 2 OF 2)

Direction	Distance to Nearest Milk Cow	Depleted			Distance to Vegetable Garden	Depleted			Nearest Site Boundary	Depleted		
	(m)	X/Q (s/m ³)	X/Q (s/m ³)	D/Q (m ⁻²)	(m)	X/Q (s/m ³)	X/Q (s/m ³)	D/Q (m ⁻²)	(m ³)	X/Q (s/m ³)	X/Q (s/m ³)	D/Q (m ⁻²)
N	2574	1.8E-06	1.4E-06	5.7E-09	2574	1.9E-06	N/A	5.7E-09	1638	4.7E-06	3.7E-06	2.0E-06
NNE	4827	6.1E-07	4.2E-07	1.9E-09	4700	6.4E-07		2.0E-09	1950	4.2E-06	3.2E-06	1.9E-08
NE	4505	7.5E-07	5.2E-07	2.7E-09	5470	5.3E-07		1.6E-09	1882	4.8E-06	3.7E-06	2.3E-08
ENE	7884	2.2E-07	1.4E-07	5.6E-10	8000	2.2E-07		5.3E-10	1547	5.4E-06	4.3E-06	2.7E-08
E	8000	2.5E-07	1.5E-07	5.8E-10	8000	2.5E-07		5.8E-10	1402	6.9E-06	5.6E-06	3.5E-08
ESE	4660	6.0E-07	4.2E-07	2.1E-09	4660	6.1E-07		2.1E-09	1753	4.6E-06	3.7E-06	2.5E-08
SE	3200	1.3E-06	9.4E-07	4.5E-09	2090	3.3E-06		1.4E-09	1814	4.4E-06	3.5E-06	2.0E-08
SSE	2090	2.8E-06	2.0E-06	9.3E-09	2413	1.9E-06		6.7E-09	1530	4.6E-06	3.7E-06	1.9E-08
S	1760	3.8E-06	3.0E-06	1.3E-08	1760	3.8E-06		1.3E-06	1554	4.7E-06	3.8E-06	1.7E-08
SSW	3050	1.0E-06	7.7E-07	3.0E-09	3540	1.1E-06		2.1E-09	1585	4.0E-06	3.2E-06	1.6E-08
SW	1600	5.0E-06	4.0E-06	2.25E-08	1930	3.6E-06		1.4E-08	1410	6.0E-06	4.9E-06	2.7E-08
WSW	1760	4.4E-06	3.5E-06	2.2E-08	1760	4.5E-06		2.2E-06	1516	5.8E-06	4.7E-06	3.1E-08
W	2090	3.7E-06	2.9E-06	1.4E-08	2090	3.7E-06		1.4E-08	1501	6.8E-06	5.4E-06	3.2E-08
WNW	7884	2.3E-07	1.5E-07	5.2E-10	7884	2.3E-07		5.2E-10	1524	6.0E-06	4.8E-06	2.7E-08
NW	6275	3.2E-07	2.1E-07	7.8E-10	6275	3.2E-07		7.8E-10	1570	5.1E-06	4.1E-06	2.3E-08
NNW	3050	1.2E-06	8.4E-07	3.4E-09	3378	9.5E-07		2.5E-09	1646	4.2E-06	3.3E-06	1.6E-08

HNP-2-FSAR-2


TABLE 2.3-25

X/Q VALUES AT MCR AIR INTAKE AND TSC INTAKE^(a) (s/m³)

<u>Averaging Time</u>	<u>Reactor Building</u>	<u>Turbine Building</u>	<u>Main Stack</u>
0 - 2 h	1.26E-03	1.26E-03	4.85E-06
2 - 8 h	3.87E-04	3.87E-04	1.17E-06
8 - 24 h	4.17E-04 ^(b)	4.17E-04 ^(b)	9.69E-07
1 - 4 days	3.56E-04	3.56E-04	8.27E-07
4 - 30 days	2.37E-04	2.37E-04	5.49E-07

a. Values for MCR air intake bound those for the TSC air intake.

b. As documented in NUREG/CR-6331, the 8-24 h X/Q values were greater than the X/Q values for 2-8 h. Ordinarily X/Q values decrease with increasing duration of the averaging period. However, it is possible to have the 95th percentile X/Q value increase as the averaging time increases. This phenomenon is caused by a change in the model's calculation procedure which uses a centerline model for the 1 and 2-h X/Q calculations and a sector-average model for the X/Q calculations in the period exceeding 2 h.



GLENNVILLE-24 MILES EAST OF SITE


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

MONTHLY MAX., AVG., AND MIN.
TEMPERATURE FOR GLENNVILLE, GA.

FIGURE 2.3-1




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 1 AND UNIT 2

MONTHLY AVG. AND 24-h
 PRECIPITATION FOR GLENNVILLE, GA.

FIGURE 2.3-2




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 1 AND UNIT 2

TOTAL NUMBER OF HAIL REPORTS $\frac{3}{4}$ in. AND GREATER,
 1955-1967, BY 1 DEGREE SQUARES (BASED ON SELS LOG)

FIGURE 2.3-3




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

TOTAL NUMBER OF HAIL REPORTS $\frac{3}{4}$ in. AND GREATER,
1955-1967, BY 2 DEGREE SQUARES (BASED ON SELS LOGS)

FIGURE 2.3-4




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 1 AND UNIT 2

TOTAL TORNADOES, 1955-1967, BY 1 DEGREE SQUARES
 (BASED ON SELS LOG)

FIGURE 2.3-5




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

TOTAL TORNADOES, 1955-1967, BY 2 DEGREE SQUARES
(BASED ON SELS LOG)

FIGURE 2.3-6




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 1 AND UNIT 2

PERCENT OF PROBABILITY OF EXCEEDING
 ORDINATE VALUE OF THE WINDSPEED

FIGURE 2.3-7




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 1 AND UNIT 2

CALCULATED TORNADOES WINDSPEED BY 5 DEGREE
 SQUARES FOR 10^{-7} PROBABILITY PER YEAR

FIGURE 2.3-8




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 1 AND UNIT 2

TOTAL WINDSTORMS, 50 KNOTS AND GREATER, 1055-1967, BY
 1 DEGREE SQUARES (BASED ON SELS LOG)

FIGURE 2.3-9



- 200 +
- ▬ 100 - 200
- ▩ 50 - 100
- ▨ 25 - 50
- ▧ 5 - 25


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 1 AND UNIT 2

TOTAL WINDSTORMS, 50 KNOTS AND GREATER, 1955-1967, BY
 2 DEGREE SQUARES (BASED ON SELS LOG)

FIGURE 2.3-10




REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 1 AND UNIT 2

REGIONAL TOPOGRAPHY

FIGURE 2.3-11



SCALE: 1" = 4000' HORIZ
 1" = 200' VERT




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 1 AND UNIT 2


TOPOGRAPHICAL PROFILE

FIGURE 2.3-12 (SHEET 1 OF 8)



PROFILE "B-B"

SCALE: 1" = 4000' HORIZ
 1" = 200' VERT




REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 1 AND UNIT 2

TOPOGRAPHICAL PROFILE

FIGURE 2.3-12 (SHEET 2 OF 8)



SCALE: 1" = 4000' HORIZ
 1" = 200' VERT




REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 1 AND UNIT 2

TOPOGRAPHICAL PROFILE

FIGURE 2.3-12 (SHEET 3 OF 8)



SCALE: 1"=4000' HORIZ
1"=200' VERT




REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

TOPOGRAPHICAL PROFILE

FIGURE 2.3-12 (SHEET 4 OF 8)



SCALE: 1" = 4000 HORIZ
 1" = 200 VERT




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 1 AND UNIT 2


TOPOGRAPHICAL PROFILE

FIGURE 2.3-12 (SHEET 5 OF 8)



PROFILE "F-F"

SCALE: 1" = 4000 HORIZ
1" = 200 VERT




REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

TOPOGRAPHICAL PROFILE

FIGURE 2.3-12 (SHEET 6 OF 8)



SCALE: 1" = 4000' HORIZ
 1" = 200' VERT




REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 1 AND UNIT 2

TOPOGRAPHICAL PROFILE

FIGURE 2.3-12 (SHEET 7 OF 8)



SCALE: 1"=4000 HORIZ
1"=200 VERT




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

TOPOGRAPHICAL PROFILE

FIGURE 2.3-12 (SHEET 8 OF 8)



ACAD


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

SITE TOPOGRAPHIC MAP

FIGURE 2.3-13



- △ = WINDSPEEDS LESS THAN OR EQUAL TO 3 MPH
- + = WINDSPEEDS LESS THAN OR EQUAL TO 7 MPH
- X = WINDSPEEDS LESS THAN OR EQUAL TO 12 MPH
- = ALL WINDSPEEDS


REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

HATCH SITE 150-ft ANNUAL WIND ROSE
BASED ON 4 YEARS OF DATA


FIGURE 2.3-14




WINTER
0.10-PERCENT CALMS



SPRING
0.27-PERCENT CALMS



SUMMER
0.72-PERCENT CALMS



FALL
0.20-PERCENT CALMS

- △ = WINDSPEEDS LESS THAN OR EQUAL TO 3 MPH
- + = WINDSPEEDS LESS THAN OR EQUAL TO 7 MPH
- X = WINDSPEEDS LESS THAN OR EQUAL TO 12 MPH
- = ALL WINDSPEEDS

ACAD


REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

HATCH SITE 150-ft MONTHLY AND SEASONAL
WIND ROSES BASED ON 4 YEARS OF SITE
DATA


FIGURE 2.3-15 (SHEET 1 OF 4)




JANUARY
0.03-PERCENT CALMS



FEBRUARY
0.11-PERCENT CALMS



MARCH
0.03-PERCENT CALMS



APRIL
0.57-PERCENT CALMS

ACAD


REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

HATCH SITE 150-ft MONTHLY AND SEASONAL
WIND ROSES BASED ON 4 YEARS OF SITE
DATA


FIGURE 2.3-15 (SHEET 2 OF 4)




MAY
0.25-PERCENT CALMS



JUNE
0.52-PERCENT CALMS



JULY
0.93-PERCENT CALMS



AUGUST
0.75-PERCENT CALMS


REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

HATCH SITE 150-ft MONTHLY ANAD SEASONAL
WIND ROSES BASED ON 4 YEARS OF SITE
DATA


FIGURE 2.3-15 (SHEET 3 OF 4)




OCTOBER
0.00-PERCENT CALMS



SEPTEMBER
0.07-PERCENT CALMS



DECEMBER
0.15-PERCENT CALMS



NOVEMBER
0.56-PERCENT CALMS

ACAD


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

HATCH SITE 150-ft MONTHLY AND SEASONAL
WIND ROSES BASED ON 4 YEARS OF SITE
DATA

FIGURE 2.3-15 (SHEET 4 OF 4)



ACAD

REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

COMPARISON OF MEASURED WINDSPEED VS.
HEIGHT

FIGURE 2.3-16

2.4 HYDROLOGIC ENGINEERING

2.4.1 HYDROLOGIC DESCRIPTION (HNP-1 AND HNP-2)

2.4.1.1 Site and Facilities

The site of the Edwin I. Hatch Nuclear Plant (HNP), which is owned by Georgia Power Company (GPC), consists of about 2244 acres. Figures 2.4-1 and 2.4-2 characterize the site environs and show the approximate site boundaries. The site is located on the south side of the Altamaha River southeast of the intersection of the river with U.S. Highway No. 1 as shown on figures 2.4-1 and 2.4-2. It is in the northwestern sector of Appling County just across the river from Toombs County, ~ 98 miles southeast of Macon and 73 miles northwest of Brunswick. Figure 2.4-3 shows a topographic map of the site area and figure 2.4-4 is a plot plan of the plant area which shows the finished grade. As shown in figure 2.4-3, the natural site grade varies from ~ 175 ft to < 75 ft at the river. The natural grade in the plant area varies from about 150 ft to < 75 ft at the river. The major safety-related structures are listed in table 2.4-1. Grade elevation at the intake structure is 110 ft; the grade elevation at the control building, reactor building, and diesel building is 129.5 ft.

2.4.1.2 Hydrosphere

The dominant surface hydrological feature of the site region is the Altamaha River and its contributory streams, the Oconee and Ocmulgee, which join to form the Altamaha ~ 20 river miles upstream and west of the site. The location of these rivers and their drainage basins with respect to the site is shown on figures 2.4-5 and 2.4-6. The regional topography is shown in figure 2.3-11.

The area of the drainage basin affecting the Altamaha at the site is about 11,700 mi². The average flow in the river at the site is ~ 13,000 ft³/s. The maximum historical flow, based on 58 years (1913 to 1970) of stage record taken by the U.S. Weather Bureau's Charlotte gage, ~ 19.0 river miles upstream from the site, was about 170,000 ft³/s during the flood of January 1925. Estimates of the maximum flood of record range from 170,000 ft³/s to 200,000 ft³/s. This discrepancy is apparently due to differences in converting stage measurements at the Charlotte gage and high-water marks observed near the Baxley gage (by the Georgia Department of Transportation) to discharges in ft³/s. A discharge of 200,000 ft³/s at the plant site corresponds to an elevation of 91.3 ft mean sea level (msl). The finished plant grade is at el 129 ft msl.

During 34 years of measurement at the Doctortown gage⁽¹⁾ ~ 57.5 river miles downstream from the plant site, the minimum daily flow, which occurred in November 1954, was ~ 1430 ft³/s corresponding to an elevation at the plant site estimated at 62.8 ft msl. The monthly average, maximum, and minimum river temperatures for a 17-year period, 1962 to 1978, from Doctortown are shown in table 2.4-2.

The waters of the Altamaha downstream from the site are not used for municipal or industrial water supplies, probably because wells provide a better source. There are no known uses of river water for human consumption or irrigation downstream of the site. There is sport fishing on the river with catches

including pickerel, large-mouth bass, channel catfish, red-breasted sunfish, and bluegill. American shad and striped bass migrate upstream as far as the dams that form Jackson Lake and Lake Sinclair. These dams are shown on figure 2.4-6. There is commercial fishing near the mouth of the river, about 115 river miles downstream from the plant site. Catches consist principally of oysters, crabs, shrimp, shad, king whiting, flounder, and fresh water catfish.

Should an accidental spillage of radioactive liquid on the surface of the ground at the plant occur, the liquid would either run off into the river because of the topographical configuration of the site (figure 2.4-7) or would enter the ground and then slowly move to the river. Since the soils at the site are relatively impermeable, it is expected that such movement would be very slow. The possibility of affecting offsite wells by spills into the ground water at the site is very remote.

There are three major dams in the Altamaha River basin above the site. The Sinclair Dam on the Oconee River is the largest with a reservoir storage capacity of 330,000 acre-ft at el 340 ft. The drainage area is 2910 mi². It is 169 river miles upstream from the plant site. The Wallace Dam, which is at a site at the upper end of Sinclair Reservoir, reduces its probable maximum flood (PMF) spillway outflow. Lloyd Shoals Dam is located on the Ocmulgee River 268 river miles above the HNP-2 site and has a drainage area of 1400 mi². The reservoir volume is 107,000 acre-ft at el 530 ft. Table 2.4-3 provides pertinent information about the upstream dams and reservoirs.

2.4.2 FLOODS (HNP-1 AND HNP-2)

2.4.2.1 Flood History

Maximum annual flows for the Charlotte gaging station are based on the stage discharge relation from 1913 through 1980. The rating curve is shown in figure 2.4-8. These flows are given in table 2.4-4. In 1970, the United States Geologic Survey (USGS) established a stream-gaging station near Baxley. The maximum annual flows from the Baxley gaging station are also shown on table 2.4-4, for the years 1971 through 1979.

The maximum historical flood at the plant site based on 68 years (table 2.4-4) of record was estimated by USGS to be 200,000 ft³/s, and occurred January 22, 1925. This flow corresponds to a stage at the site of el 91.3 ft msl (200,000 ft³/s). This was determined by USGS from a high-water mark furnished by the Georgia Department of Transportation. From the flood frequency analysis, this has been estimated as a 250-year flood.

The flood discharge studies are summarized in table 2.4-5.

2.4.2.2 Flood Design Considerations

In order to evaluate the ability of safety-related structures and equipment to withstand floods and flood waves, an investigation was made to determine the maximum water levels due to hypothetical floods. This study included the effects of winds concurrent with the probable maximum discharge which

produced the maximum water level at the HNP site (of the wave crest) of 108.3 ft. This is below the grade of the diesel generator, reactor building, and control buildings (129.5 ft). Dam failures were also considered but resulting water levels were below that caused by the PMF concurrent with waves due to winds.

2.4.2.3 Effects of Local Intense Precipitation

As has been stated in paragraph 2.4.2.2, the plant grade is at ~ el 129.5 ft msl which is high enough to be unaffected by the flood stage from the river. In addition, the effects of severe local precipitation have been investigated. To evaluate the effects of local intense precipitation, the probable maximum precipitation (PMP) used was selected from the World Record Point Precipitation Curve shown on Figure 9-44 in reference 2. The equation of the curve is:

$$R = 15.3 D^{0.486}$$

where:

$$R = \text{rainfall (in.)}$$

$$D = \text{duration of precipitation (h)}$$

The topography of the plant is such that the runoff of rainfall is directed away from the power block area as shown in figure 2.4-7, both by natural drainage and by a combined system of culverts along with open ditches to the natural drainage channels which subsequently go to the river. Therefore, the drainage system for the site precludes flooding safety-related structures. The plant drainage system is designed for a maximum precipitation of 6 in./h, which is estimated to occur about once in 100 years. The plant site was checked to ensure that flooding of safety-related equipment would not occur as a result of the PMP (15.3 in. in 1 h). In the calculations, an assumption was made that the underground storm drainage system was blocked and the PMP runoff was carried off on the surface. The runoff from local PMP across the plant area was checked using the rational method,

$$Q = C i A$$

where:

$$Q = \text{peak rate of runoff in ft}^3/\text{s at the check location}$$

$$C = \text{weighted runoff coefficient expressing the ratio of rate of runoff to rate of rainfall}$$

$$i = \text{average intensity of rainfall in in./h for PMP during the time of concentration}$$

$$A = \text{area in acres that drains to the check location}$$

In checking the plant area the i used above was taken from the World Record Envelope Curve given in reference 2 for the time of concentration determined for each area checked. The C to be used is

HNP-2-FSAR-2

discussed in reference 3 where it stated: "Higher intensity storms will require the use of higher coefficients because infiltration and other losses have a proportionally smaller effect on runoff." A discussion on estimating storm runoff from small areas is given in reference 4. Since the runoff areas around the safety-related structures are largely planted in grass, $C = 0.6$ was used for each area, including those that are roof areas. This is conservative since the roof drainage system on structures with outside parapet walls includes outside scupper holes. This system permits rainfall pondage on these roofs and gradual release of the pondage through the downspouts after the rainfall ends.

The depth of water at check locations was determined by using the Manning equation:

$$AR^{2/3} = Qn / 1.486 S^{1/2}$$

where:

A = cross-sectional area of the flowing water in square ft taken at right angles to the direction of flow.

R = hydraulic radius.

Q = discharge as determined from rational method.

n = Manning coefficient of channel roughness.

S = slope of water surface in ft/ft.

In ascertaining the surface water depth in the plant area, an n of 0.05 was used. This was obtained by assuming conservatively that grassed areas were adjacent to the doorways and openings.

The roofs of all safety-related structures are designed to pass the local PMP corresponding to time of concentration of flow. The design includes measures to guard against wind-induced seepage through roof penetrations, windows, and doors where safety-related equipment could be damaged.

Icing normally does not occur. The combination of icing followed by heavy local precipitation is not considered for determining the effects of local intense precipitation for site drainage.

2.4.3 PROBABLE MAXIMUM FLOOD (HNP-1 AND HNP-2)

The probable maximum discharge and stage of the Altamaha River at the Hatch site in the general vicinity of the crossing of U.S. Highway No. 1 (~ 20.0 river miles downstream from the confluence of the Oconee and Ocmulgee Rivers) have been determined from a detailed study. The primary consideration in determining the flood potential is the maximum possible depth of precipitation which can occur over the contributing drainage basin above the plant site aggregating ~ 11,700 mi². The resulting peak discharge would produce the probable maximum stage at the plant location with the river channel and flood plain in the present condition. The following paragraphs outline the study, describe the procedures and techniques employed from storm transposition, rotation, and maximization, and present the findings.

2.4.3.1 Probable Maximum Precipitation

2.4.3.1.1 Selection of Storm

A detailed study of the storm of March 11 through 16, 1929, with primary center near Elba, Alabama was made because it has been found, through many studies for spillway design floods for hydro projects in Alabama and Georgia, to produce the maximum design flood. After examination of the area-depth duration curves and storm rainfall pattern for a number of other southeastern storms, the hurricane storm of July 5 through 10, 1916, with the center of greatest depth near Bonifay, Florida was also selected for detailed study. The results of these studies are discussed later. The 1916 storm was found to give the greater volume of precipitation in the Altamaha River basin above the plant site and was used as a basis of design. Subsequent paragraphs describe the details of the study.

2.4.3.1.2 Transposition of Storm

The selected storm was positioned within meteorological limits over the basin above the plant site so as to produce the maximum volume of precipitation. The maximum position is determined by positioning the storm at several locations and finding the position for the maximum volume of precipitation by trial and error. For the 1916 storm the maximum position was with the primary storm center located ~ 8-miles N 27°W from Lumber City, Georgia with the storm axis rotated 20 degrees clockwise from its original bearing.

2.4.3.1.3 Maximization of Storm Precipitation

The PMP in the selected storm in its transposed position over the Altamaha River basin is determined by ensuring that the amount of precipitable water is proportional to moisture charge^(a) and the storm efficiency.^(b) Maximum possible moisture charge at any location and time is related to the temperature contrast^(c) for that location and time. Inasmuch as maximum possible dewpoint and temperature contrast vary by months, it was necessary to determine the month in which the resulting moisture charge is maximum. However, due to use of the 1916 storm which resulted from a hurricane, the months considered were limited to June, July, August, September, and October. The PMP is computed for each reporting station within the basin in the transposed position, with appropriate adjustments made in the moisture charge to account for the elevation of the inflow barrier. The computational procedures used to relate, by stations, the PMP resulting from the storm in its transposed position to the actual rainfall depths are shown on table 2.4-6. The computed probable maximum depth at each station was used to prepare an isohyetal map^(d) of the storm in the transposed position described in the preceding paragraph. The resulting map of the maximum probable storm precipitation is shown on figure 2.4-9.

2.4.3.1.4 Rainfall Volume

The total storm volume over the drainage basin above the plant site is computed from the maximized isohyetal map. The portion of the total volume within each Thiessen polygon^(e) is distributed by

6-h periods in the same proportion as the rainfall depths at the respective precipitation station. The average total depth of storm rainfall for 11,700 mi² area above the plant site amounts to 16.93 in. and is shown by 6-h increments on figure 2.4-10.

2.4.3.2 Precipitation Losses

The ground was assumed to be saturated at the start of the storm as the result of antecedent rainfall and, accordingly, no initial retention loss has been taken. A study of several historical storms and related floods indicated that an average infiltration rate equal to 0.05 in./h is reasonable. For each polygon the 6-h increments of rainfall excess are obtained by deducting from the respective 6-h volumes of rainfall the portions thereof required to satisfy infiltration. The volume of rainfall excess over the basin above the plant site for each 6-h period equals the sum of the volumes within each Thiessen polygon or portion thereof, for respective periods, and is presented on figure 2.4-10. The average depth of rainfall excess over the drainage basin amounts to 14.19 in.

2.4.3.3 Runoff Model

The nearest location to the plant site on the Altamaha River, at which discharge hydrographs^(f) for historical floods can be developed, is at the Georgia-Florida Railway crossing about 1 mile below the confluence of the Oconee and Ocmulgee Rivers and about 19 miles upstream of the site. At that station, which the weather bureau identifies as Altamaha River at Charlotte, river stages have been measured daily since 1913. Of five flood events selected for study, the unit hydrographs developed from the floods of November and December 1948 and February and March 1961, which were found to have the shorter times of concentration and higher peak discharges, were adopted for making further study at the plant site. Data for the 1948 flood at Charlotte, Georgia is shown on figure 2.4-11. Shown are the observed storm hydrograph, the unit hydrograph, the observed storm hydrograph with the base flow removed, and the reconstituted hydrograph using the unit hydrographs. Similar data for the 1961 flood are shown on figure 2.4-12. The unit hydrographs at the plant site were patterned after the unit hydrographs at the Charlotte station for the respective floods with the volumes thereof increased in direct proportion to the drainage areas at the two locations and the peak discharges related to the square root of the drainage areas. The contributing drainage areas above the Charlotte station and the plant site are estimated to be 11,550 and 11,700 mi², respectively. The 6-h unit hydrograph developed from the 1948 flood has a more

-
- a. Moisture charge is the precipitable water in a saturated atmosphere with pseudoadiabatic lapse rate in the column of air above sea level at the representative 1000-mb dewpoint.
 - b. Storm efficiency in computing the maximum probable precipitation is the optimum combination of moisture charge and convergence of the wind.
 - c. Temperature contrast is defined as the difference in temperature between cold and warm air masses which can be expected to interact at any location resulting in the energy needed to produce precipitation.
 - d. Isohyetal map is a map showing lines of equal depths of precipitation.
 - e. Thiessen polygon is the figure bound by the perpendicular bisectors of the lines joining adjacent precipitation stations, and the whole area is used to determine the weighted rainfall amounts for the basin.
 - f. Discharge hydrographs are graphs showing rate of flow of water with respect to time.

critical distribution than that resulting from the 1961 flood and, accordingly, was used to obtain the probable maximum stage at the plant site. The adopted 6-h unit hydrograph is shown on figure 2.4-13.

2.4.3.4 PMF Flow

The 6-h increments of rainfall excess were applied to the adopted 6-h unit hydrograph to obtain the hydrograph without base flow. It was assumed that the base flow would correspond to the fifth-day flow following the peak of a preceding storm runoff. The floods of record were analyzed and a base flow of 75,000 ft³/s adopted. Adding the base flow to the hydrograph results in a peak discharge of 612,000 ft³/s as presented on figure 2.4-10.

2.4.3.5 Water-Level Determination

To determine the probable maximum stage which corresponds to the probable maximum discharge, a stage discharge curve for the site was developed by computational means from known data.

Flood stage data for this portion of the Altamaha River is very limited. The best available data was for the 1948 flood with a discharge of 79,900 ft³/s. The stage at Charlotte was el 96 ft and at Baxley el 83.1 ft. A straight-line hydraulic gradient was assumed between the gages at Baxley and Charlotte and projected downstream. Six valley cross-sections were surveyed in the 28-mile stretch of the river downstream of the U.S. Highway No. 1 bridge near the site. The location of these cross-sections are shown on figure 2.4-14. The values of Mannings n to match the projected gradient are tabulated in the following table under natural n value. To obtain a conservative n value for the section below Baxley, the stage at Baxley was assumed 2 ft higher and the gradient projected downstream. The values of Mannings n required to match this assumed gradient at each section computed as shown were in the following table under adopted n values except at section 2, where the plant is to be built and the river channel improved. These n values were used in computing water surface profiles for various flows up to the probable maximum. The computed stage relationship at U.S. Highway No. 1 is shown on figure 2.4-8. This relationship indicates that the peak discharge of 612,000 ft³/s corresponds to a stage of el 105 ft. Using figure 2.4-8, the stage hydrograph shown on figure 2.4-10 was developed.

<u>Section</u>	<u>Computed natural n value</u>	<u>Adopted n value</u>
2	0.032	0.031
A	0.110	0.145
3	0.061	0.093
B	0.043	0.074
C	0.097	0.159
4	0.069	0.130

As indicated in paragraph 2.4.3.1.1, after transposition and maximization, the 1916 storm was found to produce the greatest volume of precipitation in the Altamaha River basin above the plant site. Similar results of the study of the 1929 storm are shown in figures 2.4-15 through 2.4-17.

Figure 2.4-17 shows a peak discharge of 540,000 ft³/s based on the 1929 storm compared to 612,000 ft³/s based on the 1916 storm. Similarly, the peak flood stage based on the 1929 storm is el 103.1 ft compared to el 105 ft based on the 1916 storm.

2.4.3.5.1 Flood Frequency-Discharge-Stage Relationships

The probable average recurrence intervals at which normal to moderately large flood discharges and stages of the Altamaha River at the plant site are equaled or exceeded were useful in the planning and design of the plant as well as of the work required for river control during construction. The techniques employed in the development of the frequency relationships are hereinafter discussed.

2.4.3.5.2 Selection of Method

It is considered likely that recurrence intervals extending up to 1000 years may be needed, whereas continuous records of stage of the Altamaha River and tributaries at locations within the same physiographic region as the plant site cover periods < 100 years in length. In view thereof, Hazen's logarithmic probability factors,⁽¹⁾ which should best utilize the available basic data to produce the desired results, have been selected for development of the probable flood frequency relationships.

2.4.3.5.3 Mean Flood and Coefficients of Variation and Skew

Weighted basin coefficients of variation and skew have been determined by using the records at five stations situated along the Altamaha River and the lower reaches of the Oconee and Ocmulgee Rivers. These basin coefficients of variations and skew are 0.59 and 1.19, respectively. Station coefficients of variation and skew have been computed for the periods of record at two stations on the Altamaha River, one operated by the weather bureau near Charlotte from which 53 years of data were used, and the second operated for 41 years by the geological survey at Doctortown, ~ 57.5 river miles downstream from the plant site. Respectively, the coefficients of variation are 0.58 and 0.60, and coefficients of skew are 1.45 and 1.48. The close agreement of the coefficients at the two stations indicates that these coefficients are better suited than the weighted basin coefficients for application to the plant site. The mean annual peak discharge at the site has been obtained by applying the drainage area above the site (11,700 mi²) to a log-log relationship of mean annual peak discharge to drainage area as defined by the 2 stations on the Altamaha River above and below the plant site. The mean annual peak discharge at the plant site approximates 58,000 ft³/s.

2.4.3.5.4 Frequency-Discharge-Stage Relationships - Results

Using a coefficient of variation of 0.59, a coefficient of skew of 1.45, and an annual mean peak discharge of 58,000 ft³/s, a frequency-discharge relationship has been developed at the plant site with present channel conditions. Applying to this relationship the stage-discharge relationship previously described, a frequency-stage curve at the plant site has been developed and is shown on figure 2.4-18.

The findings from studies outlined herein relating to flood discharges and stages of the Altamaha River at the plant site are summarized in table 2.4-5.

2.4.3.6 Coincident Wind/Wave Activity

The possible maximum wave height would result from a 45-mph wind concurrent with the probable maximum discharge. The wave-height study was based on the procedure described in reference 5. The maximum fetch was directly up the river for a distance of 18 miles starting at the State Highway No. 121 bridge. The maximum sustained wind velocity with a duration of more than an hour was taken as 45 mph. The significant wave height that could be developed at the site was computed to be 6.5 ft (crest to trough). The wave crest at maximum discharge would be el 108.3 ft. This is safely below the plant grade of el 129 ft.

The pump intake is the one structure that could be affected by wave runup. This structure is of reinforced concrete with walls designed for an impact load of 4000 lb at 50 mph on an area of 25 ft². The floor in the pump room is at el 111 ft with the pump motors mounted above this. The floor is drained into the pump well beneath. Two doors are the only wall openings into the building, and these are placed in labyrinth offsets and are weather-stripped. The roadfill to the building is at el 110 ft. The wave crest, at maximum discharge, is at 108.3 ft and the waves could splash water onto the roadway. This could potentially lead to water draining into the valve pit. Two submersible pumps located in the valve pit sump are available to pump the water out, should this occur. Thus, the intake structure is protected against waves.

If wind-generated waves caused the water level inside the intake structure to rise temporarily to the wave crest of the design basis flood, there would be no flooding in the pump room or in the valve pit. Water rising in the intake structure well to el 108.3 ft would not reach the bottom of the pump room floor (drawing no. H-12192). The only concern would be leakage from the well into the valve pit through the residual heat removal service water (RHRSW) pump discharge line sleeves which penetrate the wall between the pump well and the valve pit (drawing no. H-21102). Each sleeve is sealed to the RHRSW pump discharge line specifically to prevent such leakage. Also, if any water did seep into the valve pit, it would be handled by two redundant, submersible sump pumps located in a small sump inside the valve pit.

2.4.4 POTENTIAL DAM FAILURES

2.4.4.1 Reservoir Description

There are three major dams in the Altamaha River Basin above the site. Sinclair Dam on the Oconee River is the largest with a reservoir storage capacity of 330,000 acre-ft at el 340 ft. The drainage area is 2910 mi². It is 169 river miles upstream of the Hatch site. This project has 1596 ft of earth dike and 1392 ft of concrete structure consisting of nonoverflow walls, powerhouse, intake, and spillway as shown in figures 2.4-19 and 2.4-20. The spillway has 24 gates on a crest at el 319 ft. Flood flows are controlled by gates to hold the reservoir at el 340 ft until all gates are fully open. The Elba storm of

1929 transposed, rotated, and optimized produces the PMF for this dam. The PMF results in a maximum reservoir level of el 346 ft and a peak discharge of 389,000 ft³/s, as shown on figure 2.4-21. This dam passes the PMF with 9 ft of freeboard, thereby providing adequate capacity to pass the flood without overtopping. The freeboard provides additional capacity for contingencies. The structures are capable of withstanding higher heads. Wallace Dam, at the upper end of Sinclair Reservoir, reduces the PMF spillway outflow. The Sinclair Reservoir normal elevation is 340 ft msl with normal daily drawdown at 1.8 ft. The surface area of the reservoir is 15,000 acres at normal elevation.

Wallace Dam, completed in 1980, is located on the Oconee River at river mile 172.7, which is 1.5 miles north of Georgia Highway 16 between Eaton and Sparta, Georgia, at the headwaters of Lake Sinclair and 22 miles above Sinclair Dam. It has a drainage area of 1830 mi².

The project consists of a reservoir; earth and concrete gravity dam, a 5-gate spillway, and appurtenant facilities; a semi-outdoor-type power-house integral with the dam, housing two conventional units at 56.25 MW each, and four reversible units at 52.2 MW each, for a total installed capacity of 321.3 MW; an excavated tailrace into Sinclair Reservoir for pumped storage operation of the project; a 230-kV substation; and recreation facilities.

The reservoir area is 19,050 acres at full-pond el 435 ft and extends ~ 40 miles upstream into the counties of Putnam, Hancock, Greene, and Morgan. The shoreline length of the reservoir is 374 miles. The existing 15,000-acre Sinclair Reservoir serves as the tailpond and is the source of water during pumping operations.

The powerhouse is a semi-outdoor-type reinforced concrete structure integral with the dam and is ~ 530 ft long.

Components of the dam are earth dam embankment sections ~ 1070 ft long, concrete nonoverflow sections with a total length of ~ 526 ft, and a concrete gravity spillway 266 ft in length containing 5 radial gates 43 ft wide x 48 ft high. Spillway piers are shifted downstream on the crest to increase the effective spillway length. The concrete dam sections, excepting the intake and spillway piers which are reinforced, are essentially unreinforced concrete gravity sections. All concrete dam sections are founded on sound rock and are designed for maximum reservoir flood level of el 440, with earthquake loadings applied at normal reservoir level of el 435.

Spillway discharge capacity has been model tested and rated at ~ 30,000 ft³/s at flood pool level of 400. Each gate can release ~ 35,000 ft³/s, when fully open, with normal full reservoir of 435. For this reason, the gates are operated in sequence and opened only one hoist increment (~ 1 ft) at a time. Sequence of operation is automatic. Rating tables are provided for various gate openings. The dam is 117 ft high and consists of 2700 ft of earth dikes and 1323 ft of concrete structures as shown on figures 2.4-28, 2.4-29, and 2.4-30. At normal full-pond elevation of 435 ft msl, the full reservoir storage capacity is 37,000 acre-feet with a surface area of 19,050 acres. The normal daily drawdown is about 1.5 ft. The shoreline length is ~ 374 miles. Area capacity curve is given in figure 2.4-31. The tailpond (Sinclair Reservoir) normal elevation is 340 ft msl with normal daily drawdown of 1.8 ft. The surface area of the Sinclair Reservoir is 15,000 acres.

Lloyd Shoals Dam is located on the Ocmulgee River 268 river miles above the HNP site and has a drainage area of 1400 mi². It has 1070.0 ft of concrete structure, 530 ft of earth dam, and 500 ft of auxiliary spillway as shown on figures 2.4-22 and 2.4-23. Flashboards are provided on the concrete spillway to maintain the reservoir at el 530 ft. When flood flows occur, the flashboards are overtopped and collapse to provide more discharge over the spillway. The spillway crest is at el 525 and el 527 ft. The auxiliary spillway flashboards are designed to collapse at pool el 526 ft. The reservoir volume is 107,000 acre-ft at el 530 ft. The normal head on the project is 102.2 ft, while the head at the time of the SPF would be 73 ft and at the time of the PMF would be 68.4 ft. At Lloyd Shoals, the 500-ft-long auxiliary spillway was added in 1971 to increase spillway design flood capacity. The Elba storm of 1929 when transposed, rotated, and optimized produces the PMF for this basin. This storm would result in the overtopping of Lloyd Shoals Dam at a peak outflow of 290,000 ft³/s and a maximum pool elevation of 543.3 ft, as shown on figure 2.4-24. The resulting elevation at HNP is el 101.8 ft based on the Elba storm on the Altamaha Basin positioned for PMF at Lloyd Shoals, and without considering the failure of Lloyd Shoals.

2.4.4.2 Dam Failure Permutations

The design flood for HNP is based on the most severe precipitation event (PMP) in combination with upstream dam failures. There are two upstream dams which can affect the river's flood stage at HNP site:

- Sinclair Dam, located 189 river miles upstream of the site on the Oconee River.
- Lloyd Shoals Dam, located 288 river miles upstream of the site on the Ocmulgee River.

There are two approaches which can be used to analyze the effects of an upstream dam failure. The first is the conventional routing method and the second is the numerical solution of unsteady flow equations.

The numerical solution of the unsteady flow equations uses the finite difference approach. Use of this method required a prohibitively large number of river cross-sections in order to obtain credible results. A reduction in the number of river cross-sections would have reduced the number of computations required, but would also reduce the accuracy and hence the credibility of such computations. It was therefore concluded that the conventional routing (or graphic) method would give the best results for the effort required. The method adopted for use is fully discussed in reference 6. The values of lag time (L) and the storage coefficient (K) are based on actual experimental releases of water from both dams. By use of these two parameters in combination with a stage discharge curve at the HNP site (figure 2.4-8), the flood stage at the HNP site corresponding to any flood discharge can be determined.

Under SPF events, a failure of Sinclair Dam would result in a higher stage at the site than would Lloyd Shoals Dam because of its greater volume, dam length, and closer proximity to the Hatch site. Assuming instantaneous removal of the earth dike sections at Sinclair Dam during the peak of a SPF, a 27-ft-high wave would be created just below the dam with a discharge of about 3,000,000 ft³/s. It should be noted that this disregards a concrete core wall section above normal pool level in the earth dike section which is unlikely to go out suddenly. Routing was done by graphic method as shown in technical memorandum WBTM HYDRO-4, "Elements of River Forecasting," dated October 1967. This instantaneous flow was

routed from Sinclair Dam to the site with a lag L of 72 h and a storage factor K of 39 h. The lag $L^{(6)}$ used in the routing was determined from Sinclair releases. Investigations were made during 1970 to determine the effect of releases from Lloyd Shoals and Sinclair hydro plants on the stages at and below HNP. Bihourly gage readings were taken at the HNP site. Below Sinclair Dam, continuous recording gages were available at Milledgeville (3.75 miles below Sinclair Dam), at Dublin, below HNP at Doctortown, Georgia, and below Lloyd Shoals Dam at Lumber City. The results of the tests from Sinclair are shown on figures 2.4-25 through 2.4-27. The time lag as shown was ~ 72 h (3 days). The dam failure could cause an additional flow of $100,000 \text{ ft}^3/\text{s}$ at the Hatch site. Adding this additional flow of $100,000 \text{ ft}^3/\text{s}$ to an assumed simultaneous SPF at the Hatch site would result in about a 4-ft increase in stage to el 100 ft. This is well below el 105 ft obtained from the PMF. This increase in stage has been verified by a wave decay curve which indicated that the wave, after traveling 169 river miles, would be $\sim 15\%$ of the starting wave or also ~ 4 ft.

In a similar analysis for Lloyd Shoals Dam, it was assumed that the entire concrete spillway would fail. This created a 24-ft-high wave with a discharge of $\sim 800,000 \text{ ft}^3/\text{s}$. The study of the Sinclair releases described in the paragraph above was used to determine the lag value. The gage at Lumber City did not indicate any distinct wave after releases from Lloyd Shoals plant of $3000 \text{ ft}^3/\text{s}$. Since the Ocmulgee and Oconee Rivers have similar channels, the lag for Lloyd Shoals was determined as being proportional to the river miles above HNP using the lag obtained from Sinclair releases. This gave L of 130 h as a reasonable value for routing Lloyd Shoals failure wave. A storage factor K of 72 h was used. A wave of ~ 1 ft could be expected at the Hatch site after traveling 268 river miles. This failure could cause the water surface at the site to be at el 97 ft during the peak of the SPF at the site. When all the turbines are opened, a 2.5-ft-high wave is created in the tailrace with a $3000 \text{ ft}^3/\text{s}$ surge. This surge cannot be detected at the Lumber City gage 237 river miles below the dam. It should be noted that these wave analysis approximations have been deliberately handled to produce wave heights of conservatively high values.

As Lloyd Shoals Dam would be overtopped at the time of its PMF, the effect of this failure at the site was considered. This would involve considering the concrete spillway vanishing at the peak of the PMF. The result of this failure considered simultaneously with the PMF and HNP is shown on figure 2.4-24 as a dashed line with cross marks above the PMF hydrograph for the HNP. The outflow hydrograph assumed at failure is conservatively high in total volume released, although the peak could be different depending on extent and mode of failure. The Lloyd Shoals Dam failure results in an artificial flood wave at HNP of $20,000 \text{ ft}^3/\text{s}$. This increases the stage 0.3 ft to el 105.3 ft. Consideration was given to whether there was a combination of storm and storm location which would fail Lloyd Shoals Dam and result in a more adverse effect at HNP than the site PMF. By definition, the highest flood stage at the site comes from the PMF. If we combine a Lloyd Shoals failure due to its PMF with the site PMF stage, we would have the upper limit of possible effect at the site as shown on figure 2.4-24. Thus, the upper limit of stage at HNP considering the failure of Lloyd Shoals Dam results in a stage of el 105.3 ft.

At Wallace Dam flood flows are controlled by gates at reservoir el 435 ft until all gates are open; then free overflow occurs over the spillway, based on the rating curve as shown on figure 2.4-32. Assuming instantaneous loss of all earth dikes coincident with the SPF for this dam, an artificial flood wave of 29 ft at the dam would result. This wave would be attenuated to 23 ft at Sinclair Dam and would overtop the dam by 8 ft. Assuming conservatively that this overtopping of the earth dikes resulted in their instantaneous failure, an artificial flood wave of 33 ft would be increased. This wave height would decay

to 5 ft at the Hatch site. The maximum stage at the Hatch site would be el 101 ft, assuming the stage at the Hatch site as that corresponding to the SPF. The Elba storm of 1929 transposed, rotated, and optimized produces the PMF for Wallace Dam. The PMF results in a maximum reservoir level of el 441.1 ft and a peak discharge of 316,800 ft³/s, as shown on figure 2.4-33. This dam is designed to pass the PMF with 3.9 ft of freeboard, thereby having adequate capacity to pass the flood without overtopping. The dam structures are being designed to withstand the floodhead.

2.4.4.3 Unsteady Flow Analysis of Potential Dam Failure

See paragraph 2.4.4.2.

2.4.4.4 Water Level at Plant Site

See paragraph 2.4.4.2.

2.4.5 PROBABLE MAXIMUM SURGE AND SEICHES FLOODING

Not applicable.

2.4.6 PROBABLE MAXIMUM TSUNAMIS FLOODING

Not applicable.

2.4.7 ICE FLOODING

There is no record, in modern times, of the Altamaha River freezing over. Based on the river temperature data at Doctortown, Georgia, the minimum temperature of record is 37.4°F (3°C, table 2.4-2) and is safely above the freezing temperature. Therefore, the formation of fragile ice is unlikely and the ice blockage of the intake structure is not considered possible.

2.4.8 COOLING-WATER CANALS AND RESERVOIRS

Not applicable.

2.4.9 CHANNEL DIVERSIONS

The plant site is located ~ 1/2 mile below U.S. Highway No. 1. The river channel is relatively straight for a distance of 1.5 miles below U.S. No. 1. Thus, there are no meanders at the plant site which could be cut across to divert the flow. The U.S. No. 1 bridge and highway fill serve to control the channel

alignment to its present location. Thus, the channel alignment from the bridge to the plant site is relatively stable. The Altamaha River was surveyed by the U.S. Army Corps of Engineers in about 1900. It is reported that no major changes in channel alignment have occurred in subsequent years. Corps of Engineers personnel estimate that an oxbow meander is cut off about once every 100 years. Observation of river patterns shows that meanders develop very slowly. Thus, any possible effect on water supply to the river intake from channel changes should come from extremely slow changes which can be remedied as they occur.

2.4.10 FLOODING PROTECTION REQUIREMENTS

The topography of the HNP is such that none of the safety-related facilities are exposed to river flooding by the most severe flood at the site. The probable maximum discharge concurrent with a severe wind of 45 mph would develop a wave height of 6.5 ft (crest to trough). The elevation of the wave crest due to a sustained wind of 45 mph and at a PMF would be at el 108.3 ft msl. This is well below the plant grade of el 129 ft msl and, therefore, flooding is improbable from this source.

The intake is a safety-related structure. The pumps and motors are housed above the most severe flood stage. The floor elevation of the two outside access doors is at el 111.0 ft msl (table 2.4-1). There are no safety-related systems or components located below the design maximum flood elevation that are not protected against flooding. The foundation slabs and exterior walls of safety-related structures are designed to resist upward and lateral pressures caused by the maximum flood level.

The reinforced concrete intake pump structure walls which may be affected by the wave runup are designed for an impact load of 4000 lb at a windspeed of 50 mph over an area of 25 ft² (section 3.4).

The plant is located on high ground adjacent to the river. Minor surface area drainage into the plant is carried by the yard drainage. The nearest adjacent tributary drains the area south and east of the plant and has an area of 21 mi². The flowline of this drainage at the point nearest the plant is at el 75 ft. The crest of the ridge between the plant and flowline is el 125 ft. The flow area is adequate to remove the probable maximum rainfall on the drainage area without flooding the plant.

Another possible source of flooding is severe local precipitation. The power block area is not in the path of any watershed drainage; moreover, the location of the plant is such that the runoff from local precipitation is directed away from the power block both by natural drainage and by a combined system of culverts to the natural drainage channel (paragraph 2.4.2.3).

The plant drainage system is designed for a maximum precipitation of 6 in./h and has been checked to ensure that flooding of safety-related equipment does not occur as a result of local intense precipitation equal to the PMP. The roofs of all safety-related structures are designed to pass the local PMP corresponding to the time of concentration.

2.4.11 LOW-FLOW CONSIDERATION

2.4.11.1 Low Flow in the Altamaha River

Minimum stream flows and related stages may influence water supply to the intake pumps and the plan of operation of the plant. For these reasons, a very low-flow river stage-discharge relationship (discharge rating curve) was developed for the Hatch intake structure location as outlined below.

The Hatch intake structure is located on the Altamaha River at approximately river mile 116.4. The nearest USGS gage is: 02-2250, Altamaha River Near Baxley, Georgia. The Baxley gage is located on the south bank of the river (same side as the intake structure) ~ 400 ft downstream from the bridge on U.S. Highway No. 1, and 2750 ft upstream from the Hatch intake structure. The discharge rating curve at the intake structure was developed by making appropriate adjustments to the low-flow discharge rating curve at the Baxley gage. The USGS performs bathymetric surveys of the river cross-section at the Baxley gage and measures a river-stage relationship on the average every 6 weeks. From time to time, as needed, the USGS revises the rating table at the Baxley gage when adequate additional data are collected, and the new data show the river bottom has stabilized. Rating Table No. 11 was developed in October 1994. The discharge rating curve shown in figure 2.4-34 was developed using the USGS measurement data taken since Rating Table No. 11 was published. The drop in water surface level from the Baxley gage to the Hatch intake depends on the quantity of discharge in the river. A higher discharge would result in a steeper hydraulic gradient and, therefore, in a greater drop between the two sites, and vice versa. A drop of 0.1 ft was determined by level survey, from the Baxley gage to the Hatch intake, when the river elevation at the Baxley gage was 62.0 ft msl. The discharge rating curve at the Hatch intake structure was developed by adjusting to the Baxley discharge rating curve, as shown in figure 2.4-34. At the Hatch intake structure, the river level would be 61.4 ft msl for 1200 ft³/s, which is the low flow of record at Charlotte gage and 60.9 ft msl for the hypothetical minimum flow of 950 ft³/s at the intake structure.

In accordance with plant procedure, the river stage-discharge rating curve at the Hatch intake structure is determined at least twice per 12 months, including a low-flow extension to el 60.0 ft msl. The rating curve is verified to ensure that adequate water supply to the intake pumps is available for at least 30 days (required for a safe plant shutdown operation) when the river level falls to el 60.8 ft msl, which corresponds to 60.7 ft msl in the pump well of the intake structure.

In accordance with plant procedures, the USGS discharge-stage measurements taken since the last verification are analyzed, and the Hatch rating curve is adjusted every 6 months (at the middle and end of the year). The rating curve is evaluated to determine whether there is any adverse effect on water supply to the intake pumps. The rating curve is then used to estimate the number of days for which water supply would be available between river el 60.8 and 60.0 ft msl. Therefore, for up-to-date information on the Plant Hatch rating curve for low flows, refer to the most recent calculation, "Plant Hatch River Stage-Discharge Curve Verification."

2.4.11.2 Low Water Resulting from Surges, Seiches, or Tsunamis

Not applicable.

2.4.11.3 Historical Low Water

Stream flow data near the site are available from several gages as shown below:

<u>Gage</u>	<u>Agency</u>	<u>River Mile</u>	<u>Drainage Area (mi²)</u>	<u>Period of Record Available</u>	<u>Type of Record</u>	<u>Lowest Flow of Record</u>
Charlotte	USWB ^(a)	135.7	11,550	1925-	Daily gage	1200 ft ³ /s (1925)
Baxley	USGS	116.9	11,600	1949-1951 1970 -	Daily gage Recording	1620 ft ³ /s (1986)
Doctortown	USGS	59.4	13,600	1931-	Recording	1430 ft ³ /s (1954)
	USWB			1925-1931	Daily gage	

Analysis of the records for these stations showed that 1925, 1954, 1986, and 1988 were periods of drought. The only reservoir in existence in 1925 was Lloyd Shoals.

In this 1925 period, the Charlotte gage had 23 consecutive days of low flow. In 1954 both Lloyd Shoals and Sinclair Reservoirs were operative. In that year, the Charlotte gage had 31 consecutive days of flow between 1300 and 1400 ft³/s, while at Doctortown there were 23 days of low flow. In 1954 the low-flow period occurred in the latter part of October. During that month, there was no generation at Lloyd Shoals Dam except for 1700 kWh on October 22. The Lloyd Shoals reservoir level was constant at el 507.4 ft from October 22 to October 29, indicating inflow was equal to evaporation and leakage. At Sinclair Dam, the reservoir was drawn down 0.8 ft during the period from October 15 to October 31. This decrease in storage is equivalent to an average of 300 ft³/s from the reservoir. Estimated evaporation losses from the 2 reservoirs, Lloyd Shoals and Sinclair, were 75 to 100 ft³/s. Thus, the net addition to river flows due to Lloyd Shoals and Sinclair Dams was ~ 200 ft³/s. Data from Lloyd Shoals operation for a similar analysis of 1925 flows are not available, but based on the similar period in 1954 were probably minimal.

During the past 48 years of measurement (1931 to 1979) at the Doctortown gage 57.5 river miles downstream from the plant site, the minimum daily flow occurred in November 1954 and was 1430 ft³/s, corresponding to an elevation at the plant site estimated at 62.8 ft msl.

a. USWB - United States Weather Bureau.

2.4.11.4 Future Control

For large rivers such as the Altamaha, there is some minimum base flow that can be sustained from ground water and aquifer flows. This is apparent by the number of days of essentially steady flow in the low-flow periods. An analysis of annual minimum flows at Charlotte indicate that this extrapolated hypothetical minimum natural (without reservoir supplementation) low flow is 950 ft³/s and that the low flows are approaching this limit asymptotically. This is considered a very conservative low-flow estimate.

2.4.11.5 Plant Requirements

The minimum low flow is important because of its effect on the operation of plant service water (PSW) and RHRSW pumps. The RHRSW pumps at rated flow conditions require for net positive suction head (NPSH) a river stage of only 59.0 ft which corresponds to a flow of less than 100 ft³/s. Thus, no further consideration is required on river stage with regard to submergence of these pumps.

The PSW pumps at rated conditions of about 8500 gal/min-pump require a stage in the pump well of 61.2 ft. Normal operation requires about 7840 gal/min for each of three pumps. Shutdown or emergency conditions require only 1 pump with a discharge of 4428 gal/min. Therefore, the applicant provides means for local measurement of level in the intake pump well. If the level in the well should reach the low level of 61.2 ft (~ 1200 ft³/s river flow) the applicant throttles discharge flow from PSW (unless previously accomplished) such that maximum flow does not exceed 7000 gal/min. Means are provided for measurement of service water flow. The ability to achieve the pump flow rate for minimum required NPSH of 35.5 ft was demonstrated during the preoperational testing of the HNP-1 service water pumps, which are the same as those of HNP-2. The rating curve (figure 2.4-34) is based on records obtained from the USGS Altamaha River Gage No. 02-2250 just downstream of the U.S. No. 1 bridge near Baxley, Georgia. No additional work has been done at this station or at the U.S. Highway No. 1 bridge except the erection of a temporary weir across the river downstream of the intake structure during a period of low flow. This measure was taken to increase the effective water level at the intake structure but was later removed. The rating curve is verified at regular intervals. If any shift occurs in a manner which would adversely affect the water supply to the pumps, appropriate action is taken to maintain the water-supply capability under low-flow conditions.

2.4.11.6 Heat Sink Dependability

Technical Specification requirements relative to the ultimate heat sink assure that Plant Hatch is protected against essentially incredibly low flows. In these analyses, credit is not taken for Sinclair Dam discharge, since the HNP site was not given credit for Sinclair Dam's minimum instantaneous flow requirements imposed by the Federal Energy Regulatory Commission license.

Also, close surveillance is given to maintaining the depth of the approach channel in the river during periods of low river flows to ensure that water is available to the pumps. In this respect, the Altamaha River on the centerline of the intake structure was first sounded on July 18, 1974. GPC continues to monitor the bottom conditions on a yearly basis in late spring or early summer and take appropriate

action to maintain water supply under all conditions. Figure 2.4-43 shows river bottom profiles for the years as indicated. It shows that some siltation has taken place but is not considered excessive or necessarily a trend.

2.4.12 ENVIRONMENTAL ACCEPTANCE OF EFFLUENTS

The liquid radioactive releases occurring during the full range of operating conditions, the dilution factors used in evaluating these releases, and the doses resulting from these releases are discussed in subsections 11.2.6, 11.2.8, and 11.2.9, respectively.

See paragraphs 2.4.1.2 and 2.4.13.2 for locations and users of surface and ground waters, respectively.

The ultimate heat sink design parameters are covered in subsection 9.2.5.

There are no known safety-related effects of normal or accidental releases of radionuclides and heated water on surface and ground waters. Should an accidental spillage of radioactive liquid on the surface of the ground at the plant occur, the liquid would enter the ground and then slowly move to the river. The soils at the site are relatively impermeable and it is expected that such movement would be very slow (permeabilities are given in table 2.4-9). The possibility of affecting offsite wells by spills into the ground water at the site is very remote.

Liquid plant wastes suitable for release to the environment are discharged into the Altamaha River. The discharge structure is located ~ 1300 ft downstream of the intake structure to prevent any recirculation of liquid waste. Even in the case of low river flows, the flow is sufficient to carry the waste downstream and prevent recirculation to the plant's intake structure.

2.4.13 GROUND WATER

This section presents the results and conclusions of the ground water investigations for HNP. The investigations were performed by Law Engineering Testing Company, GPC, and Bechtel Corporation.

2.4.13.1 Description and Onsite Use

The site is within the coastal plain province of Georgia which extends from the fall line on the north to Florida on the south and from the Savannah River on the east to the Chattahoochee River on the west (figure 2.5-1). Sediments underlying the coastal plain consist of alternating beds of sand, gravel, clay, limestone, and marl that dip southeastward slightly more than the regional ground surface. These strata outcrop in belts nearly parallel to the present Atlantic coastline. Water enters the permeable sand, gravel, and limestone aquifers principally by direct infiltration of precipitation in their outcrop areas, and migrates downdip. The permeable strata lie between relatively impermeable layers of clay, marl, and silty or clayey sand. This configuration results in artesian conditions downdip from the aquifer recharge areas.⁽⁷⁾

Most of the large ground water supplies withdrawn from the coastal plain sediments are provided by the artesian or confined aquifers described in the previous paragraph. Ground water supplies may also be obtained from shallow, unconfined aquifers under water-table conditions. The unconfined aquifers consist of surficial sand and gravel deposits that underlie terraces in upland areas and floodplains adjacent to larger streams. Perched water zones, which are discontinuous lenses or layers of permeable material overlying relatively impermeable strata, locally provide minor and unreliable supplies of ground water. Recharge to the perched water zones and unconfined aquifers occurs locally where the water-bearing units are exposed to infiltration of precipitation.⁽⁷⁾

A small amount of ground water is used for plant operations (paragraph 2.4.13.1.3). This water is withdrawn from two high-capacity wells that are open to very permeable limestone. The characteristics of the regional and local aquifers and a description of plant and local water usage are provided in the following paragraphs.

2.4.13.1.1 Regional Aquifers

The major aquifer underlying the region in which the site is located is referred to as the principal artesian (or limestone) aquifer. In the southeast Georgia area, the aquifer ranges from 450- to 1500-ft thick.⁽⁸⁾ It consists chiefly of limestone, with occasional layers of dolomite, sand, silt, clay, and marl.⁽⁹⁾ Geologic units comprising the aquifer range in age from Middle Eocene to Miocene and include, in ascending order, limestones of the Claiborne group, the Ocala limestone, the Suwanee formation, and the Tampa formation.⁽⁸⁾ In some areas, sandy limestones in the lower part of the Hawthorn formation (Miocene) are considered part of the principal artesian aquifer. These limestones act as a hydrologic unit and provide over 70% of the ground water used in Georgia.⁽⁸⁾ Above and below the aquifer are low-permeability beds that confine the water in the limestones. The upper confining bed consists of clay of the Hawthorn formation of Miocene age. Middle Eocene age clay and limestone of the McBean formation in eastern Georgia, and the lower Lisbon and Tallahatta formations elsewhere in Georgia provide the lower confining beds. The aquifer and confining beds dip gently to the southeast, with resultant artesian conditions occurring a short distance downdip from the recharge areas.⁽⁸⁾

The outcrop areas serve as the source of recharge for the principal artesian aquifer.⁽⁷⁾ The main recharge area, over 60 miles northwest of the site, contains nearly 8500 mi² in a northeast-southwest trending belt that extends from south of Augusta, Georgia, to the vicinity of Dothan, Alabama. Other areas of recharge include about 1000 mi² in and to the south of the Okefenokee Swamp, and ~ 500 mi² in the area of Valdosta, Georgia. Precipitation, which provides most of the recharge, averages 44 to 55 in. annually in the outcrop areas.⁽⁷⁾ Recharge occurs downward through the exposed rock and from sinkholes in the limestone. Adjacent to the main outcrop belt, where the aquifer is underlain and overlain by sands, recharge takes place upward and downward from these sand units. These units include portions of the Hawthorn formation overlying the aquifer, and sands of Cretaceous and Paleocene ages underlying the aquifer.⁽⁹⁾

The characteristics of the principal artesian aquifer vary widely in southeast Georgia. The southeastward slope of the potentiometric surface ranges from 1.5 to 15 ft/mi for a distance of ~ 25 miles downdip from the recharge area (figure 2.4-35). About 10 miles northwest of the site, the slope of the potentiometric surface changes to < 2 ft/mi and continues at that gradient almost to the coast. These

lower gradients appear to be due to an increase in the thickness and permeability of the aquifer downdip, enabling the limestone to transmit under much lower gradients the water supplied to it from the northwest.⁽¹⁰⁾ Values for transmissivity are between 72,000 and 90,000 gal/day/ft where the gradients are steep, while from Appling County southeastward, transmissivity values range from 130,000 to 2,000,000 gal/day/ft.⁽⁹⁾ The average transmissivity of the aquifer in this area is 220,000 gal/day/ft. Specific capacities of 47 wells penetrating the aquifer in different parts of the Georgia coastal plain range from 1.1 to 240 gal/min/ft of drawdown. Most of the wells penetrated over 100 ft of aquifer and had specific capacities > 50 gal/min/ft of drawdown. In general, the specific capacity of wells within the aquifer increases with increased exposure to the more permeable zones in the aquifer.⁽⁸⁾

Water-table conditions occur in the sediments overlying the principal artesian aquifer. The amount of water within these unconfined aquifers is largely dependent on their water-bearing characteristics, although large supplies are generally not available. Within the site region, the unconfined aquifers range in age from Late Miocene to Holocene and include sandy portions of the Hawthorn formation, the Pleistocene terrace deposits, and alluvium of Holocene age adjacent to the major rivers.⁽⁷⁾

The Hawthorn formation consists of clay, silt, sand, limestone, and dolomite. Some of the sandy limestone and dolomite beds are minor aquifers and furnish water for local rural supplies. Individually, the waterbearing lithologies are thin, discontinuous, and comprise only a small percentage of the total volume of the formation. Yields in the most permeable sections are generally < 200 gal/min. In some areas, water in the lower Hawthorn formation may exhibit artesian conditions. The most important function of the Hawthorn formation is to confine water in the underlying principal artesian aquifer.⁽⁹⁾ The Pleistocene terrace deposits are similar to material in the Hawthorn formation and consist of varying amounts of sand, gravel, silt, and clay. They generally occupy upland areas between the major river valleys. Owing to rapid horizontal and vertical facies changes within the terrace deposits, they are unreliable as sources of ground water except for small rural supplies. Sand and gravel layers at the base of the deposits may provide over 10 gal/min per well, while perched lenses usually yield a smaller quantity of ground water.⁽⁸⁾ The alluvium adjacent to the larger streams consists of sand, clay, and gravel and could potentially provide large supplies where deposits are hydraulically connected to streams. The Holocene alluvium is not generally used to supply ground water.⁽⁸⁾

2.4.13.1.2 Local Aquifers

Ground water in the vicinity of the site is obtained from five water-bearing strata. These are, in ascending order, the principal artesian aquifer, the middle and upper parts of the Hawthorn formation, the Brandywine formation, and the Altamaha River alluvium. The characteristics of these strata have been obtained from published reports and from data obtained during testing and operation of wells drilled into the water-bearing units.

The principal artesian aquifer beneath the site consists of the Lisbon formation of Middle Eocene age, the Ocala formation of Late Eocene age, the Suwanee formation of Oligocene age, and the Tampa and extreme lower Hawthorn formations of Miocene age. The Ocala and Suwanee formations are chiefly limestones, while the Lisbon, Tampa, and extreme lower Hawthorn formations are sandy limestone and calcareous clayey sand. These formations are overlain and confined by fine sand and sandy clay in the lower part of the Hawthorn formation. The lower confining bed consists of sandy clay of the Tallahatta

formation. The principal artesian aquifer is ~ 1000-ft thick beneath the site, with the top at approximate el -105 ft msl (figure 2.4-35). Recharge to the aquifer occurs at the outcrop area ~ 60 miles northwest of the site.

Eleven wells within 2 miles of the site extend into but do not completely penetrate the principal artesian aquifer (table 2.4-7). The bottoms of these wells range from el -117 ft msl to el -570 ft msl, with the intervals exposed to the aquifer known for seven of the wells. For the two wells on which tests were made (site wells 1 and 2), the specific capacity of the aquifer ranged from 100 to 125 gal/min/ft of drawdown. Transmissivity in the site vicinity is ~ 130,000 gal/day/ft. The effective permeability is between 0.1 and 0.2 ft/min, based on published transmissivity and thickness data.⁽⁸⁾⁽⁹⁾ Properly designed individual wells drilled into the aquifer can safely yield over 1100 gal/min.

The water levels in wells drilled into the principal artesian aquifer are discussed in paragraph 2.4.13.2.2. The potentiometric surface of the aquifer in the vicinity of the site is generally between el 49 ft msl and el 60 ft msl, sloping gently to the southeast.

The upper part of lithologic unit 1 and all of unit 2 of the Hawthorn formation, as defined in paragraph 2.5.1.2.2, form an aquiclude between the principal artesian aquifer and an overlying confined aquifer within the Hawthorn formation. The aquiclude consists of fine sandy clay and is between 100- and 110-ft thick. The top of this zone is near sea level (el 0 ft msl). Published permeability values for the aquiclude are $< 1 \times 10^{-7}$ ft/min.⁽⁸⁾⁽⁹⁾

The middle portion of the Hawthorn formation, between approximate el 65 ft msl and sea level, contains a minor confined aquifer. The vertical limits of the aquifer are within lithologic units 3 and 4 of the Hawthorn formation (paragraph 2.5.1.2.2). The aquifer consists of fine to coarse sand and clayey sand. It is confined between sandy clay and clay in the upper Hawthorn formation (upper confining bed) and sandy clay in the lower Hawthorn formation, described above. The thickness of the aquifer under the site is ~ 65 ft. Recharge occurs locally to the southwest of the site, where this part of the Hawthorn formation is exposed. Natural discharge occurs where material in the aquifer is in contact with the alluvium underlying the Altamaha River floodplain, generally below el 60 ft msl.

Field tests conducted at the site indicate that the permeability of the minor confined aquifer ranges from 2.5×10^{-4} to 4.1×10^{-4} ft/min. The permeability generally increases with increasing depth in the aquifer and decreasing silt content of the water-bearing sand. Water levels of the aquifer, discussed in detail in paragraph 2.4.13.2.2, range between el 67 ft msl and el 85 ft msl. The potentiometric surface of the aquifer has a gradient of ~ 23 ft/mi to the north, toward the Altamaha River. Although no data on maximum safe yield are available for the site area, the low permeability values indicate that individual wells yield < 10 gal/min.

The confining bed overlying the minor confined aquifer corresponds with lithologic unit 5 and the upper part of lithologic unit 4 of the Hawthorn formation (paragraph 2.5.1.2.2). It consists chiefly of sandy clay and clay, with locally cemented sand layers. The confining bed is ~ 40- to 50-ft thick, with the irregular top generally at el 100 ft msl to el 120 ft msl. Permeabilities determined from field tests in sandy zones of the confining bed were $< 2.0 \times 10^{-6}$ ft/min.

HNP-2-FSAR-2

Unconfined ground water exists within the upper part (lithologic unit 6) of the Hawthorn formation. This is the surface unit over most of the site south of the Altamaha River. The base of this aquifer corresponds with the irregular top of the confining bed described above. The base is at approximate el 120 ft msl, although in the southeastern part of the site and near the Altamaha River, it is at approximate el 100 ft msl or less. The aquifer consists of clayey sand, about 45- to 50-ft thick, that becomes less clayey with depth. The high clay content near the top of the aquifer and at the ground surface locally forms discontinuous, relatively impermeable zones. Recharge to the aquifer occurs by infiltration of precipitation through and around the leaky clay zones.

The permeability of the unconfined aquifer, as determined by field tests on a site borehole extending to el 132 ft msl, was $\sim 1.5 \times 10^{-3}$ ft/min. Tests in two pits exposing the aquifer between el 132 ft msl and el 128 ft msl yielded permeabilities of 1.1×10^{-3} ft/min and 1.7×10^{-3} ft/min. No data on the maximum yield from this aquifer in the site area are available. However, 33 wells within 2 miles of the site utilize ground water from the unconfined aquifer for domestic purposes throughout the year (see paragraph 2.4.13.2.1). The low permeability values indicate that a yield of less than 10 gal/min per well may be expected.

Water levels in the unconfined aquifer are discussed in detail in paragraph 2.4.13.2.2. In summary, they range from el 148 ft msl west of the site to $< el 100$ ft msl east of the plant area. The water table reflects the topography of the site area, with high water levels underlying hills and low water levels near valleys. The flow direction is north and east toward the Altamaha River floodplain, along gradients ranging from 14 to 80 ft/mi.

The relatively impermeable clay zones at the top of the Hawthorn formation cause perched water conditions in the overlying Brandywine formation. The Brandywine is Pliocene(?) to Pleistocene in age and caps the hills at and around the site above approximate el 165 ft msl to el 170 ft msl. Maximum known thickness in this area is ~ 20 ft. The perched aquifer consists of poorly sorted sand and gravel and is recharged by precipitation in the site area. Perched ground water is found only locally in the deposits, although ten wells near the site (table 2.4-7) dug or drilled into the aquifer contain water throughout the year. A few springs occur at the base of the Brandywine about 1.5 miles southwest of the plant. During drier seasons, these springs are dry, owing to lack of recharge. No values for permeability or maximum safe yield have been recorded for the Brandywine formation in the site area. A discussion of the perched water levels is included in paragraph 2.4.13.2.2.

Pleistocene(?) to Holocene age alluvium underlying the Altamaha River floodplain contains ground water under water-table conditions. The alluvium consists of up to 55 ft of poorly sorted sand, gravel, and clay. The top of these deposits is generally below el 75 ft msl. Recharge to the alluvial aquifer is provided mainly by infiltration of local precipitation. Recharge is also provided by discharge from the Altamaha River during high stages and by the minor confined aquifer in the Hawthorn formation, to which the alluvium is hydraulically connected. The alluvium is a potential source of large quantities of water,⁽⁸⁾ although only two shallow dug wells near the site are open to the aquifer (table 2.4-7).

2.4.13.1.3 Plant Wells and Ground Water Requirements

Two onsite water wells provide ground water for plant usage. The locations of the wells are shown on figures 2.4-36 and 2.4-37. The wells draw water from the Ocala limestone and the Suwanee formation which are part of the principal artesian (limestone) aquifer. Well No. 1 has a surface elevation of 109.5 ft msl and is 680-ft deep. The top 455 ft are cased and sealed with cement grout to prevent seepage of water into the well bore from higher water-bearing strata. The interval from a depth of 455 ft to 680 ft (el 345 ft msl to el 570 ft msl) is open to the limestone aquifer. The static water level from this interval was at a depth of 59 ft (el 50 ft msl) on November 21, 1969. Well No. 2 has a surface elevation of 151.9 ft msl and is 711-ft deep. The well bore is cased and sealed above a depth of 490 ft with cement grout. Between 490 ft and the bottom (el 339 ft to el 559 ft msl) the well is open to limestone. On the test date, September 3, 1969, the static water level was at a depth of 103 ft (el 48.9 ft msl). As-built drawings at the two site wells are included as figure 2.4-38.

Each well is equipped with a 100-hp electric suction pump. Well No. 1 was pumped for 9 h at 752 gal/min. Drawdown was 5 ft, indicating a specific capacity of 125 gal/min/ft of drawdown. Well No 2 was pumped for 9 h at 797 gal/min. Drawdown stabilized at 8 ft, indicating a specific capacity of nearly 100 gal/min/ft of drawdown. The maximum rate of withdrawal in well No. 1 was 1120 gal/min, with 10 ft of drawdown. No attempt was made to determine the maximum rate of withdrawal for well No. 2.

The initial use of ground water from these wells is to fill the following storage tanks:

	<u>Total Capacity (gal)</u>
Fire protection tanks (2)	600,000
Demineralized water storage tank	100,000
Sanitary water storage tank	20,000
Filtered water storage tank	100,000

After the tanks are filled, normal plant operation requires 374,880 gal/day of ground water. Of this amount, 364,800 gal/day is supplied as makeup to the demineralizer at a rate of 320 gal/min for 19 h/day. The remaining 10,080 gal/day is routed through the sanitary water storage tank to the sanitary water system at a rate of 7 gal/min for 24 h/day. Ground water is not used for emergency cooling. However, ground water is used as makeup for the fire protection system as described in the HNP Fire Hazards Analysis and Fire Protection Program.

2.4.13.2 Sources

2.4.13.2.1 *Present and Projected Ground Water Use*

To determine the use of ground water in the site region, a survey of water users within ~ 2 miles of the plant was conducted. The results of the survey are presented on table 2.4-7, with the well locations shown on figure 2.4-36. Of the 61 wells located, 5 are abandoned, 9 are open to the principal artesian aquifer, two are screened in the minor confined aquifer, 33 draw water from the unconfined aquifer, 10 draw from the perched (Brandywine) deposits, and 2 are open to the Altamaha River alluvium. The two site wells which obtain water from the principal artesian aquifer are also listed in table 2.4-7. The primary use of water from the local wells is for domestic needs, with a limited amount for livestock. Well water is not used for irrigation. Most wells are equipped with pumps, although a few dug wells use bucket lifts. There are no large tanks near the site for storage of ground water; however, there are several storage ponds southwest of the site which utilize surface runoff for stock and crop watering. Requirements and usage of the two site wells are presented in paragraph 2.4.13.1.3.

At present, there is no industrial demand for ground water within the site area. The nearest appreciable amount of ground water withdrawal is 10 miles south of the site, where the town of Baxley has three wells which withdraw a total of 250,000 to 300,000 gal/day from the principal artesian aquifer. The wells are slightly down-gradient from the site. Water storage for the town is provided by two 60,000-gal tanks.

An estimated 115 people live within 2 miles of the plant (figure 2.1-4). The suggested normal per capita use for this area is ~ 65 gal/day.⁽⁷⁾ Based on these figures, the total present usage from all aquifers is estimated to be 7475 gal/day, or ~ 5.2 gal/min. The population within the same area is expected to increase to about 125 by the year 2012 (figure 2.1-4). By conservatively assuming that per capita use will increase to 100 gal/day, the total projected ground water usage by the year 2012 is estimated to be 12,500 gal/day, or ~ 8.7 gal/min.

2.4.13.2.2 *Piezometer Installations and Piezometric Levels*

Fifty-six piezometers have been installed at and near the site to allow monitoring of water levels in the unconfined and minor confined aquifers in the Hawthorn formation. Five additional piezometers are open to the sandy clay separating these two aquifers to detect the presence and levels of water in the aquiclude. The locations of the piezometers are shown on figure 2.4-37, with data concerning the piezometers presented on table 2.4-8. Forty-four of these piezometers were destroyed during construction activities. There are currently 17 active piezometers. No piezometers are used to monitor water levels in the principal artesian aquifer or the Brandywine (perched) aquifer. Water levels in the principal artesian aquifer were noted during tests on the two site water wells (paragraph 2.4.13.1.3) and during the local well survey. The potentiometric surface in the site vicinity was at approximate el 70 ft msl in 1944.⁽¹⁰⁾

As of 1968, the potentiometric surface had declined to elevations ranging from 49 ft msl to 60 ft msl. The decline in the site area accompanied a general decline of the potentiometric surface in the entire

southeast Georgia area. This decline has been attributed to excessive pumping from the aquifer along the Atlantic coast.⁽⁹⁾ The range in the water levels in the site vicinity represents withdrawal from different portions of the principal artesian aquifer. Wells completed in the upper part of the aquifer generally have higher water levels than those drawing from deeper parts of the aquifer. The potentiometric surface of the aquifer may fluctuate as much as 10 ft seasonally or following heavy rain in the recharge areas.⁽⁸⁾

Water levels in the perched (Brandywine) aquifer were measured during the local well survey. The levels ranged from el 161 ft msl to el 174 ft msl. Local residents stated that springs discharging from the base of the perched aquifer went dry during periods of extended drought, although no dug wells drawing from the aquifer had gone dry.

Contours of the natural water level in the unconfined aquifer, shown on figure 2.4-39, illustrate the correlation of the water surface with the configuration of the terrain. The highest water levels occur beneath the crest of the hill, west of the plant site, and along the spurs radiating from the hill. Flow direction is downslope toward the river and small tributary drainage channels. Gradients range from 0.0026 to 0.015. The underlying aquiclude precludes significant downward percolation, so ground water in the aquifer moves laterally to the stream channels. The top of the aquiclude is irregular, ranging in elevation from ~ 100 ft msl to 120 ft msl. Where the tributary channels have cut below the top of the aquiclude, the unconfined water is discharged at the ground surface through springs.

The natural potentiometric surface of the confined water within the minor confined aquifer underlying the aquiclude is shown on figure 2.4-40. The contours indicate that the configuration of the potentiometric surface is not related to surface topography. The predominant direction of ground water movement within the aquifer is north, toward the Altamaha River. The gradient is about 0.0043. The river channel has cut below the base of the aquiclude under the flood plain, providing hydraulic contact between the river alluvium and the minor confined aquifer.

Since periodic monitoring of site piezometers began in late 1969, the levels in the unconfined and minor confined aquifers have shown little fluctuation (figure 2.4-41). Other than one weekly series of isolated measurements (which are believed in error) and the effects of the dewatering operation, water levels of both aquifers have fluctuated less than 10 ft. Future ground water levels should remain essentially where they are.

Fluctuations in the potentiometric surface of the minor confined aquifer respond closely to fluctuations of the river level (figures 2.4-41 and 2.4-42). Potentiometric levels prior to April 24, 1970, were controlled primarily by the dewatering operations for the construction excavation. After recovery of the levels following deactivation of the dewatering system, the hydrographs (figures 2.4-41 and 2.4-42) demonstrate that levels in the minor confined aquifer are higher than the river level most of the time. During high flood flows, a temporary flattening of the hydraulic gradient may occur. Reversals in the normal gradient due to pumping are discussed in paragraph 2.4.13.2.4.

2.4.13.2.3 Permeability and Porosity Values

Values of permeability and porosity for the relevant geologic formations beneath the site are shown on table 2.4-9. Field permeability tests were conducted utilizing piezometer walls as inflow wells. The field tests were falling-head type in sealed piezometers and constant-head permeameter type. These tests were conducted in accordance with the NAVDOCKS and Bureau of Reclamation (E-18) procedures.⁽¹¹⁾⁽¹²⁾ Permeability values for formations not tested at the site were obtained from publications.⁽⁷⁾⁽⁸⁾⁽⁹⁾⁽¹⁰⁾ Porosity values were determined from laboratory test data.

2.4.13.2.4 Reversibility Potential and Withdrawal Effects

No reversal of the gradients of the unconfined and minor confined aquifers at the site should occur as a result of present or future offsite or onsite pumping. The closest area of concentrated ground water withdrawal is at Baxley, Georgia, 10 miles south of the site. The present rate of withdrawal from the three city wells at Baxley is relatively small (up to 300,000 gal/day). Water is extracted exclusively from the principal artesian aquifer, which is hydraulically isolated from the unconfined and minor confined Hawthorn formation aquifers. The city wells are slightly down-gradient from the site. Pumpage for the Baxley municipal water system, therefore, has no effect on water levels in the Hawthorn formation aquifers underlying the site.

A water usage survey conducted in August and September 1967 revealed that there were 61 wells within 2 miles of the site, of which 5 were abandoned (table 2.4-7). Thirty-three of the remaining wells (59% of the total wells in use) obtained water from the unconfined aquifer, serving an estimated 68 people (59% of the total population within 2 miles of the plant). At the per capita rate of 65 gal/day⁽⁷⁾ ~ 4420 gal/day is withdrawn from the unconfined aquifer. This represents an average rate of withdrawal of less than 0.1 gal/min per well. There is no apparent influence from the existing wells on the present unconfined water surface (figure 2.4-39). Therefore, continued usage causes no reversal of the gradient of the unconfined aquifer.

The population within 2 miles of the plant is expected to increase to 125 by the year 2012 (figure 2.1-4), representing an increase of 10 people. If all 10 people use well water obtained from the unconfined aquifer, and the per capita usage by the year 2012 increases to 100 gal/day, then a total of 7800 gal/day will be withdrawn from the aquifer. Assuming the present ratio of people per well remains at ~ 2 to 1, a total of 39 wells will be pumping from the aquifer. The rate of withdrawal will be ~ 0.14 gal/min per well, or an increase of < 0.05 gal/min per well over the present withdrawal rate. This low increase of usage indicates that the possibility of a reversal of the present ground water flow in the unconfined aquifer due to offsite overdraft is extremely remote.

Two wells, serving an estimated four people, draw water from the minor confined aquifer within 2 miles of the site. They withdraw an estimated total of 260 gal/day, or < 0.1 gal/min per well. If the present 4 people and the 10 people expected to enter the area by 2012 use well water obtained from the minor confined aquifer at a per capita rate of 100 gal/day, the total withdrawal from the aquifer will be about 1400 gal/day. Assuming the present ratio of people per well remains at 2 to 1, a total of seven wells will be pumping from the aquifer. The rate of withdrawal will be ~ 0.14 gal/min per well, or an increase of

0.05 gal/min over the present withdrawal rate. This low increase of usage is not expected to alter the existing ground water flow in the minor confined aquifer.

There are no onsite wells drawing water from the two Hawthorn formation aquifers. Water for plant usage is supplied by two wells open to the principal artesian aquifer at a normal rate of 374,880 gal/day (paragraph 2.4.13.1.3 and figures 2.4-36 through 2.4-38). The wells are ~ 1780 ft apart. For 19 h/day, the rate of withdrawal is 327 gal/min; with only one well in operation, the corresponding maximum drawdown at the pumping well is < 4 ft. During the remaining 5 h, withdrawal is 7 gal/min, resulting in considerably less drawdown at the well. Because of the distance between wells and the low drawdown, there is no interference between the two wells. Normal plant operation does not significantly affect the natural southeastward slope of the potentiometric surface of the principal artesian aquifer.

If required, each site well is capable of producing 750 gal/min of ground water, resulting in a temporary maximum drawdown of 7.5 ft per well. There is no interference between wells at this rate of withdrawal and drawdown. Since the duration of any such pumping is short, there is no significant effect on the potentiometric surface of the principal artesian aquifer. Ground water is not used for emergency cooling.

2.4.13.2.5 Recharge Areas Within Plant Influence

There are no significant areas of recharge within the influence of the plant. Since the northern boundary of the plant site extends beyond the Altamaha River, the alluvium in the river valley at the site is not used as a source of ground water for local residents. All other local recharge areas are up-gradient from the plant and supply water to aquifers not used by the plant.

2.4.13.3 Accident Effects

Normal operation of the plant has no adverse effect on the ground water systems in the site vicinity. All ground water for plant usage is derived from wells in the deeper principal artesian aquifer.

In the unlikely event of an accidental release of radioactive contaminants into water-bearing strata at the plant, movement of the contaminants into the nearest potential potable water supply (the Altamaha River) would be affected by several factors. First, ion exchange and absorption properties of the soil would retard the migration of contaminants to some extent, and the concentration of the ions moving with the ground water would be reduced. Secondly, downward movement of the contaminants would be contained within the minor confined aquifer in the Hawthorn formation, the top of which is ~ 8 ft below the radwaste building foundation. This limitation of downward movement is due to the confining beds beneath the minor confined aquifer and to upward artesian pressures associated with the deeper principal artesian aquifer. Construction of the plant wells (completed in the principal artesian aquifer) includes a cement grout seal from the ground surface through the top of the aquifer to prevent seepage downward along the well bore.

For an analysis of the rate of movement of contaminated ground water, the most probable leak or spill location is the HNP-2 radwaste building. The most conservative (shortest) path for ground water

HNP-2-FSAR-2

movement from the HNP-2 radwaste building to the nearest potable water supply was determined on the basis of the following assumptions:

- A. The nearest potential potable water supply is the Altamaha River.
- B. Ground water moves down-gradient from the leak or spill location to the river along a straight path.
- C. The shortest (and fastest) route of travel is within the minor confined aquifer, the top of which is ~ 8 ft below the HNP-2 radwaste building foundation.
- D. The thin layer of aquiclude material between the radwaste building foundation and the minor confined aquifer does not prevent rapid downward infiltration of contaminants into the aquifer.
- E. The upward hydraulic pressure within the minor confined aquifer does not prevent the leaked or spilled contaminants from entering the aquifer and traveling to the river.
- F. Once the ground water reaches the river bank, it encounters Altamaha River water, independent of the river bed conditions.

Based on these assumptions, the most conservative path to the Altamaha River from the HNP-2 radwaste building is to the north through the minor confined aquifer, a minimum distance of 1300 ft.

The travel time of ground water is dependent on the velocity of the water and the distance traveled. The velocity of the ground water is calculated using the Darcy equation:

$$\bar{V} = KI/n$$

where:

K = coefficient of permeability of the aquifer.

I = gradient of the potentiometric surface.

n = effective porosity of the aquifer.

The permeability coefficient K of the minor confined aquifer was determined in the field using both falling-head and constant-head permeability tests. In general, the permeability increased from 3.1×10^{-5} ft/min (16.3 ft/year) in the upper portions of the aquifer to 2.5×10^{-4} ft/min (131.4 ft/year) in the lower portions of the aquifer over 40 ft below the plant foundations. However, a conservative value of $K = 2.5 \times 10^{-4}$ ft/min was used to determine \bar{V} .

Along the most conservative path (a distance of 1300 ft), the maximum gradient of the potentiometric surface in the minor confined aquifer is 23 ft/mi toward the Altamaha River, based on preconstruction piezometer readings (figure 2.4-40). This conservative value of $I = 0.0043$ was used to determine \bar{V} .

The velocity of ground water within the aquifer is inversely proportional to the effective porosity n . A conservative value of total porosity N , which includes effective porosity n and specific retention, was calculated from laboratory test data on unit weights of samples of aquifer material. The calculated value for N from 72 samples was 0.50 (50%). A conservative value of effective porosity n , estimated to be 0.10 (10%) was used to calculate \bar{V} .⁽¹³⁾

From the above values, the velocity of ground water from the Unit 2 radwaste building to the Altamaha River through the minor confined aquifer is 5.65 ft/year.

The travel time is calculated from:

$$T = L/\bar{V}$$

where:

T = travel time.

L = distance traveled.

\bar{V} = velocity of ground water.

Using the minimum value of $L = 1300$ ft and $\bar{V} = 5.65$ ft/year, the travel time of ground water from the Unit 2 radwaste building to the Altamaha River through the minor confined aquifer is 230 years.

The general direction of ground water flow in the immediate plant area in the unconfined and minor confined aquifers is northward, toward the Altamaha River. There are no potential ground water recharge areas within the influence of the plant (paragraph 2.4.13.2.5), and domestic wells within the plant boundaries have been abandoned. Therefore, the possibility of contaminating existing or future ground water withdrawal systems following an accidental release of contaminants at the plant site is extremely remote.

Because the subsurface materials at the Edwin I. Hatch site are primarily sands and clays, with only partial cementation of a few sand horizons, it was necessary to use drilling mud to hold the exploratory holes open. The heavy drilling mud retained in the holes provide an effective barrier to ground water migration through the area of the hole, as the permeability of the mud is considerably lower than that of the surrounding sands and clays.

2.4.13.4 Monitoring or Safeguard Requirements

As discussed in paragraph 2.4.13.2.4, ground water users in the vicinity of the plant are not affected by the withdrawal of ground water for plant use. The plant uses a relatively small amount of water obtained from the principal artesian aquifer, which is hydraulically isolated from the aquifers supplying most of the offsite ground water users. The quantity of ground water required for plant use is much less than the maximum safe yield of the aquifer (paragraph 2.4.13.1.2). Plant usage does not adversely affect offsite wells open to the aquifer.

During extremely high river stages, a temporary flattening of the gradient of the minor confined aquifer may occur. The area affected by the PMF (el 91 ft msl) would be immediately adjacent to the Altamaha River and would not extend to the plant, owing to the low permeability of the minor confined aquifer and the short duration of the flood. Wells in the vicinity of the plant would not be affected by such a gradient change because of their distance from the river (figure 2.4-36). Site piezometers are monitored throughout the life of the plant.

In the event of an accidental spill of contaminants, the piezometers and observation wells, shown on figure 2.4-37, can be monitored periodically to detect the flow path and dispersion of contaminants.

Potable water from both surface and subsurface sources is available in the area surrounding the site. Analyses of water samples are shown on table 2.4-10. These analyses provide background data against which future quality tests may be compared.

2.4.13.5 Design Bases for Subsurface Hydrostatic Loading

Paragraph 2.4.13.1.2 describes the system of wells and piezometers that are used to define the ground water conditions in the areas of the HNP-1 and HNP-2 structures. Those studies, which are the basis of the design parameters, define two independent ground water zones or aquifers. An unconfined aquifer occurs within unit 6 (upper stratum) of the Hawthorn formation. The water table within the aquifer trends parallel to the natural ground surface at depths of 10 to 15 ft below the ground surface. A confined aquifer occurs within the sandy (middle) portions of the Hawthorn formation. The confined aquifer corresponds to unit 3 and the lower part of unit 4 of the Hawthorn formation, below approximate el 65 ft msl. The piezometric level of water within the confined aquifer is at or below approximate el 80 ft msl. A cemented sandstone and sandy clay zone, corresponding to unit 5 and the upper part of unit 4 of the Hawthorn formation, comprises an aquiclude separating the two aquifers.

The post-construction behavior of the ground water level in the unconfined aquifer was anticipated to be consistent with the ground water level prior to construction; the ground water level reflected the ground surface contours. During construction, the ground surface elevation in the yard area was lowered from approximate el 143 ft msl to approximate el 129 ft msl. A corresponding reduction in the elevation of the unconfined ground water level resulted. To provide a conservative basis for basement wall design, a design ground water level 7 ft below the general yard level, or el 122 ft msl, was selected.

REFERENCES

1. Hazen, Allen, Flood Flows, John Wiley and Sons, Inc., N.Y., 1930.
2. Ven Te Chow, Handbook of Applied Hydrology, Ed., McGraw-Hill, N.Y., 1964.
3. Design and Construction of Sanitary and Storm Sewers, Manuals and Reports of Engineering Practice No. 37, American Society of Civil Engineers, p 51, 1969.
4. Design of Roadside Drainage Channels, Bureau of Public Roads, Chapter II, 1965.
5. Saville, McClendon, and Cochran, "Freeboard Allowances for Waves in Inland Reservoirs," Journal of Water Ways Division, ASCE, May 1962.
6. Elements of River Forecasting; Technical Memorandum WBTM Hydro-4, U.S. Department of Commerce, October 1967.
7. Thomson, M. T., Herrick, S. M., Brown, E., et al, The Availability and Use of Water in Georgia, Georgia Geological Survey, Bulletin 65, p 329, 1956.
8. Stringfield, V. T., Artesian Water in Tertiary Limestone in the Southeastern States, U. S. Geological Survey, Professional Paper 517, p 226, 1966.
9. Callahan, J. T., The Yield of Sedimentary Aquifers of the Coastal Plain Southeast River Basins, U.S. Geological Survey Water Supply Paper 1669-W, p 56, 1966.
10. Warren, M. A., Artesian Water in Southeastern Georgia, Georgia Geological Survey, Bulletin 49, p 140, 1944.
11. Design Manual, Soil Mechanics, Foundations, and Earth Structures, NAVDOCKS, DM-7, 1962.
12. Earth Manual, U. S. Bureau of Reclamation, pp 541-543, 1963.
13. Todd, D.K., Ground Water Hydrology, John Wiley and Sons, Inc., N.Y., 1959.

TABLE 2.4-1

ACCESS TO SAFETY-RELATED STRUCTURES

<u>Structures</u>	<u>Access</u>	<u>No. of Access</u>	<u>Floor El (ft)</u>
<i>Intake</i>	<i>Outside doors</i>	<i>2</i>	<i>111</i>
<i>Control building</i>	<i>Outside door</i>	<i>1</i>	<i>130</i>
	<i>Elevator door</i>	<i>1</i>	<i>130</i>
<i>Reactor building</i>	<i>Outside door (Airlocked)</i>	<i>1</i>	<i>130</i>
<i>Diesel building</i>	<i>Outside doors</i>	<i>6</i>	<i>130</i>
	<i>Air intakes</i>	<i>2</i>	<i>130</i>
<i>Main stack</i>	<i>Outside doors</i>	<i>2</i>	<i>120</i>
	<i>Freight door</i>	<i>1</i>	<i>120</i>
	<i>Outside door</i>	<i>1</i>	<i>145</i>

TABLE 2.4-2 (SHEET 1 OF 6)

**AVERAGE, MAXIMUM, MINIMUM TEMPERATURE OF ALTAMAHA RIVER WATER
TEMPERATURE (°C)**

<i>Month</i>	<i>1962</i>			<i>1963</i>			<i>1964</i>			<i>1965</i>		
	<i>Avg</i>	<i>Max</i>	<i>Min</i>	<i>Avg</i>	<i>Max</i>	<i>Min</i>	<i>Avg</i>	<i>Max</i>	<i>Min</i>	<i>Avg</i>	<i>Max</i>	<i>Min</i>
<i>Oct</i>	22.0	25.0	16.0	22.0	24.0	19.0	19.0	27.0	17.0	21.0	24.0	16.0
<i>Nov</i>	14.0	16.0	12.0	15.0	18.0	12.0	17.0	18.0	15.0	16.0	18.0	13.0
<i>Dec</i>	9.0	13.0	8.0	8.0	12.0	6.0	12.0	15.0	11.0	11.0	13.0	10.0
<i>Jan</i>	8.0	11.0	6.0	9.0	11.0	7.0	7.0	10.0	5.0	11.0	14.0	6.0
<i>Feb</i>	14.0	18.0	11.0	9.0	11.0	7.0	9.0	11.0	9.0	11.0	14.0	8.0
<i>Mar</i>	14.0	19.0	10.0	15.0	20.0	10.0	15.0	17.0	10.0	14.0	19.0	11.0
<i>Apr</i>	18.0	20.0	16.0	20.0	24.0	18.0	18.0	21.0	14.0	20.0	23.0	17.0
<i>May</i>	25.0	29.0	21.0	23.0	26.0	20.0	22.0	26.0	19.0	25.0	29.0	22.0
<i>Jun</i>	22.0	29.0	27.0	26.0	29.0	24.0	28.0	31.0	25.0	25.0	28.0	24.0
<i>Jul</i>	30.0	31.0	28.0	27.0	28.0	25.0	27.0	29.0	25.0	28.0	29.0	26.0
<i>Aug</i>	30.0	31.0	27.0	29.0	31.0	27.0	26.0	28.0	26.0	29.0	31.0	28.0
<i>Sep</i>	27.0	30.0	23.0	26.0	30.0	21.0	25.0	27.0	23.0	27.0	29.0	23.0
<i>Annual Average</i>	30.0			19.0			19.0			20.0		

HNP-2-FSAR-2

TABLE 2.4-2 (SHEET 2 OF 6)

<i>Month</i>	<u>1966</u>			<u>1967</u>			<u>1968</u>			<u>1969</u>		
	<u>Avg</u>	<u>Max</u>	<u>Min</u>	<u>Avg</u>	<u>Max</u>	<u>Min</u>	<u>Avg</u>	<u>Max</u>	<u>Min</u>	<u>Avg</u>	<u>Max</u>	<u>Min</u>
<i>Oct</i>	21.0	25.0	18.0							23.0	27.0	17.0
<i>Nov</i>	15.0	18.0	18.0	<i>Data not</i>			13.0	18.0	11.0	16.0	18.0	14.0
<i>Dec</i>	11.0	14.0	9.0	<i>available</i>			12.0	14.0	11.0	14.5	16.0	13.0
<i>Jan</i>	10.0	14.0	3.0				8.0	11.0	6.0	12.0	16.0	10.0
<i>Feb</i>	9.0	14.0	4.0				9.0	10.0	8.0	10.0	12.0	8.0
<i>Mar</i>	13.0	17.0	11.0				14.5	18.0	9.0	11.0	14.0	9.0
<i>Apr</i>	23.0	24.0	16.0				21.0	23.0	18.0	18.0	19.0	14.0
<i>May</i>	24.0	25.0	21.0				24.0	26.0	22.0	21.5	24.0	18.0
<i>Jun</i>	24.0	26.0	22.0				27.0	30.0	23.0	27.0	31.0	24.0
<i>Jul</i>	28.0	30.0	25.0				29.0	31.0	28.0	30.5	32.0	29.0
<i>Aug</i>	27.0	29.0	26.0				21.0	33.0	26.0	26.0	29.0	24.0
<i>Sep</i>	26.0	29.0	24.0				27.0	29.0	26.0	25.0	26.0	23.0
<i>Annual Average</i>	19.0						18.0			19.5		

HNP-2-FSAR-2

TABLE 2.4-2 (SHEET 3 OF 6)

<i>Month</i>	<i>1970</i>			<i>1971</i>			<i>1972</i>			<i>1973</i>		
	<i>Avg</i>	<i>Max</i>	<i>Min</i>	<i>Avg</i>	<i>Max</i>	<i>Min</i>	<i>Avg</i>	<i>Max</i>	<i>Min</i>	<i>Avg</i>	<i>Max</i>	<i>Min</i>
<i>Oct</i>	22.1	24.0	19.0	23.7	26.0	21.5	24.2	27.5	22.5	22.8	27.0	21.0
<i>Nov</i>	15.7	19.0	14.0	17.1	21.5	13.5	18.7	23.0	14.0	18.9	22.5	14.5
<i>Dec</i>	10.8	14.5	9.0	13.8	15.0	12.0	14.4	16.5	13.0	14.5	17.5	13.0
<i>Jan</i>	8.3	11.0	5.5	11.3	12.5	9.5	13.5	14.5	12.5	12.0	14.0	10.0
<i>Feb</i>	10.42	11.0	9.5	10.9	14.0	9.5	11.5	13.0	10.0	9.9	11.5	9.0
<i>Mar</i>	14.6	16.0	11.0	14.4	16.0	13.5	15.8	17.5	13.0	14.1	17.0	9.0
<i>Apr</i>	18.9	23.5	15.5	18.2	21.5	14.5	19.4	22.0	17.0	16.2	19.0	12.5
<i>May</i>	24.5	26.5	22.0	21.8	23.5	20.0	22.5	23.5	21.5	21.3	23.5	19.0
<i>Jun</i>	27.1	30.5	24.5	26.5	29.0	23.5	24.6	26.0	22.5	24.1	24.5	23.5
<i>Jul</i>	29.7	30.0	29.0	28.51	29.5	28.0	27.0	29.0	24.5	26.6	27.0	24.5
<i>Aug</i>	28.6	30.5	26.5	27.6	28.5	26.0	29.0	29.5	28.5	26.5	28.0	24.5
<i>Sep</i>	28.1	28.5	26.0	27.4	28.0	27.0	28.2	29.0	27.0	27.8	28.0	25.0
<i>Annual Average</i>	19.9			20.1			20.7			19.8		

HNP-2-FSAR-2

TABLE 2.4-2 (SHEET 4 OF 6)

<i>Month</i>	<i>1974</i>			<i>1975</i>			<i>1976</i>			<i>1977</i>		
	<i>Avg</i>	<i>Max</i>	<i>Min</i>	<i>Avg</i>	<i>Max</i>	<i>Min</i>	<i>Avg</i>	<i>Max</i>	<i>Min</i>	<i>Avg</i>	<i>Max</i>	<i>Min</i>
<i>Oct</i>	23.75	26.5	21.0	23.25	25.5	21.0	20.0	23.5	16.5	19.25	25.0	13.5
<i>Nov</i>	19.5	21.0	18.0	19.5	22.0	17.0	15.75	22.0	9.5	12.25	14.5	10.0
<i>Dec</i>	15.5	18.5	12.5	15.75	17.0	14.5				9.5	11.5	7.5
<i>Jan</i>	15.25	17.0	13.5	14.5	15.5	13.5				6.0	9.0	3.0
<i>Feb</i>	15.75	17.5	14.0	15.0	15.5	14.5	13.25	17.5	9.0	9.75	14.5	5.0
<i>Mar</i>	15.75	17.5	14.0	15.75	16.5	15.0	16.5	19.0	14.0	16.5	20.0	13.0
<i>Apr</i>	18.5	20.0	17.0	18.0	19.5	16.5	21.25	25.0	17.5	20.75	23.0	18.5
<i>May</i>	22.5	25.0	20.0	21.75	24.0	19.5	22.25	24.0	20.5	25.0	28.0	22.0
<i>Jun</i>	26.0	27.0	25.0	25.25	26.5	24.0	25.0	28.0	22.0	29.5	32.0	27.0
<i>Jul</i>	27.5	28.5	26.5	26.5	27.0	26.0	27.5	30.5	24.5	30.25	32.5	28.0
<i>Aug</i>	28.5	29.0	28.0	27.75	29.0	26.5	27.5	30.5	24.5	29.0	30.5	27.5
<i>Sep</i>	27.5	29.0	26.0	25.0	29.0	21.0	24.75	28.0	21.5	27.75	29.5	26.0
<i>Annual Average</i>	21.34			20.67			21.38			19.63		

HNP-2-FSAR-2

TABLE 2.4-2 (SHEET 5 OF 6)

<u>Month</u>	<u>1978</u>		
	<u>Avg</u>	<u>Max</u>	<u>Min</u>
<i>Oct</i>	22.25	27.5	17.0
<i>Nov</i>	18.0	22.0	14.0
<i>Dec</i>	12.25	16.5	8.0
<i>Jan</i>	8.0	10.5	5.5
<i>Feb</i>	7.25	9.5	5.0
<i>Mar</i>	14.25	20.0	9.0
<i>Apr</i>	21.0	24.0	18.0
<i>May</i>	23.75	28.0	19.5
<i>Jun</i>	29.25	32.5	26.0
<i>Jul</i>	30.0	32.0	28.0
<i>Aug</i>	29.0	30.5	27.5
<i>Sep</i>	27.0	30.5	23.5
<i>Annual Average</i>	20.19		

HNP-2-FSAR-2

TABLE 2.4-2 (SHEET 6 OF 6)

<u>Year^(a)</u>	<u>Maximum Temperature (°C)</u>
1979	31.0 (B)
1980	32.0 (J)(G)
1981	31.0 (J)(G)
1982	29.5 (B)
1983	30.0 (B)(J)
1984	30.0 (B)(J)
1985	31.0 (G)
1986	31.5 (G)
1987	31.0 (G)
1988	30.0 (B)
1989	29.5 (G)
1990	32.0 (J)
1991	29.0 (J)(G)
1992	31.0 (J)(G)
1993	31.0 (J)(G)

Note: 1962-1978 maximum temperature values recorded were taken at the Doctortown, Georgia, gaging station.

a. 1979-1993 maximum temperature values recorded were taken at the Baxley, Georgia, gaging station (B); the Jesup, Georgia, gaging station (J); or the Gardi, Georgia, gaging station (G) as noted. No monthly maximum, average, or minimum values are available.

TABLE 2.4-3
SUMMARY OF DATA ON DAMS

<u>Name of Dam and Reservoir</u>	<u>Sinclair</u>	<u>Lloyd Shoals</u>	<u>Wallace</u>
Owner	GPC	GPC	GPC
River miles from site	189	189	211
Drainage area (mi)	2910	1400	1830
Construction completed (year)	1952	1910	1980
Stream bed elevation	258	435	325
Top-of-dam elevation	355	540	445
Normal pool elevation	340	530	435
Usable (conservation) storage (acre-feet)	214,600	78,000	32,000
Floor-control allocation (acre-feet)	None	None	None
Type of spillway	24T - 30x21	FB: 308.5x2 420x5	5T - 42x45
Crest elevation	319.0	528.0 525.0	391
Earth or rockfill dike	1596	530	2700
Conc power house N ₂ O wall	1392	1570	1000
Conc spillway			
Seismic design	--	--	0.05 hor - 0.0333 vert on concrete structure

a. All elevations approximately msl.

b. All dimensions in feet.

c. T - tainter gates.

d. FB - flash boards.

TABLE 2.4-4

**GAUGING STATION RECORDS - ALTAMAHA RIVER BASIN
ALTAMAHA AT CHARLOTTE AND BAXLEY, GEORGIA
ANNUAL FLOOD PEAKS**

<u>Charlotte Gauge</u>				<u>Baxley Gauge</u>	
<u>Water (year)</u>	<u>Discharge (ft³/s)</u>	<u>Water (year)</u>	<u>Discharge (ft³/s)</u>	<u>Water (year)</u>	<u>Discharge (ft³/s)</u>
1913	98,000	1949	44,000	1971	97,500
1914	29,000	1950	21,400	1972	67,800
1915	37,500	1951	20,900	1973	53,800
1916	52,900	1952	66,800	1974	46,500
1917	45,100	1953	66,000	1975	91,300
1918	32,300	1954	31,800	1976	53,400
1919	90,800	1955	20,600	1977	45,000
1920	46,400	1956	30,500	1978	73,000
1921	38,500	1957	30,500	1979	76,000
1922	82,000	1958	49,000		
1923	68,500	1959	37,000		
1924	33,600	1960	79,100		
1925	170,000	1961	81,000		
1926	29,800	1962	49,000		
1927	20,400	1963	50,900		
1928	108,000	1964	79,100		
1929	130,000	1965	60,200		
1930	39,000	1966	93,800		
1031	32,300	1967	40,500		
1932	34,100	1968	24,500		
1933	40,000	1969	34,000		
1934	39,500	1970	73,000		
1935	21,400	1971	100,000		
1936	145,000	1972	66,200		
1937	45,100	1973	54,100		
1938	66,000	1974	45,100		
1939	86,000	1975	89,000		
1940	31,000	1976	55,000		
1941	33,600	1977	47,300		
1942	93,000	1978	79,250		
1943	76,200	1979	77,000		
1944	108,000	1980	84,000		
1945	36,500				
1946	61,900				
1947	64,300				
1948	123,000				

TABLE 2.4-5
SUMMARY OF FLOOD DISCHARGE STUDIES
(HNP-1 AND HNP-2)

<u>Condition</u>	<u>Discharge (ft³/s)</u>	<u>Stage Equaled or Exceeded (ft msl) With Present Channel</u>
<i>Bankfull</i>	20,000	74.0
<i>Recurrence interval (years)</i>		
2	52,000	79.8
5	80,000	83.5
10	102,000	85.3
20	122,000	86.9
50	150,000	88.6
100	172,000	89.7
250	200,000	91.3
1000	243,000	93.0
PMF	612,000	105.0

TABLE 2.4-6

**PROBABLE MAXIMUM PRECIPITATION ADJUSTMENT FACTOR
ALTAMAHA RIVER ABOVE NUCLEAR PLANT SITE
STORM OF 5-10 JULY 1916 (GM 1-19) TRANSPOSED FOR MONTH OF OCTOBER
(HNP-1 AND HNP-2)**

<u>Thiessen Polygon</u>	<u>Barrier Elevation (ft)</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>Explanatory Notes</u>
Greensboro	1000	73.6	2.70	0.24	2.46	7.3	1.06	Storm's 12-h 1000-MB dewpoint
Uniontown	900	73.8	2.73	0.22	2.51	7.4	1.07	Actual throughout (Dp) _s = 76.0°F
Selma	750	73.9	2.75	0.19	2.56	7.6	1.10	Maximum at selected location and time
Benton	750	74.0	2.76	0.18	2.58	7.6	1.10	(Dp) _M ' per station ___ column 1
Thomasville	850	74.0	2.76	0.21	2.55	7.5	1.09	Storm's moisture charge adjusted for elevation of inflow barrier
Fort Deposit	550	74.2	2.79	0.16	2.63	7.8	1.13	
Highland Homes	500	74.5	2.83	0.12	2.71	8.0	1.16	Actual total at (Dp) _s dewpoint ___ (Wp) _s = 3.04 in.
Greenville	600	74.3	2.81	0.15	2.66	7.8	1.13	Actual inflow barrier reduction at (Dp) _s ___ (Wp) _s = 0.04 in.
Evergreen	650	74.9	2.89	0.17	2.72	8.0	1.16	Net actual above inflow barrier (Wp) _s - (\bar{Wp}) _s = 3.00 in.
Bermuda	750	74.7	2.86	0.19	2.67	7.7	1.12	
Troy	450	74.8	2.88	0.12	2.76	8.1	1.17	Maximum corresponding to (Dp) _M
Molino	450	75.3	2.94	0.12	2.82	8.3	1.20	(Wp) _M ' per station ___ column 2
Carniers	450	75.9	3.03	0.12	2.91	8.6	1.25	Maximum inflow barrier reduction at (Dp) _M
Defuniak Springs	450	75.6	2.98	0.12	2.86	8.4	1.22	(Wp) _M ' per station ___ column
Bonifay	400	75.8	3.01	0.11	2.90	8.6	1.25	Maximum above inflow barrier
Ozark	450	75.2	2.93	0.12	2.81	8.3	1.20	(Wp) _M ' - (\bar{Wp}) _M ' per station ___ column 4
Marianna	350	76.0	3.04	0.09	2.95	8.7	1.26	Temperature contrast
Wausau	350	76.0	3.04	0.09	2.95	8.7	1.26	Actual storm center (Tc) _s = 5.3
Alaga	400	75.8	3.01	0.11	2.90	8.6	1.25	Storm center transposed in location and time (Tc) _T = 8.7
Pushmataha	950	73.8	2.73	0.24	2.49	7.3	1.07	Moisture charge adjusted for inflow barrier and storm efficiency
Demopolis	950	73.5	2.69	0.22	2.47	7.3	1.06	Actual storm location (Tc) _s ^{1/2} [(Wp) _s - (\bar{Wp}) _s] = 6.9
Millry	900	74.2	2.79	0.22	2.57	7.6	1.10	
Clanton	750	73.7	2.72	0.18	2.54	7.5	1.09	Maximum at selection location and time
Pratville	650	74.0	2.76	0.16	2.60	7.7	1.12	(Tc) _T ^{1/2} [(Wp) _M ' - (\bar{Wp}) _M '] per station = 8.7 ^{1/2} x column 4 = column 5
Montgomery	650	74.1	2.77	0.16	2.61	7.7	1.12	Maximum probable precipitation factor Ratio of maximum at station in transposed location to actual for respective station in original location =

$$\frac{(Tc)_T^{1/2} [(Wp)_M' - (\bar{Wp})_M']}{(Tc)_S^{1/2} [(Wp)_S - (\bar{Wp})_S]} = \frac{\text{column 5}}{6.9} = \text{column 6}$$

TABLE 2.4-7 (SHEET 1 OF 2)
RESULTS OF LOCAL WELL SURVEY

<u>Well Number</u>	<u>Owner</u>	<u>Surface Elevation (ft)</u>	<u>Type of Well</u>	<u>Elevation of Bottom of Well (ft)</u>	<u>Elevation of Water Surface (ft)</u>	<u>Aquifer</u>	<u>Remarks</u>
1	Buck Dunn, Baxley	11	Drilled	98	108	Unconfined	
2	Lambert Miles, Baxley	117	Dug	98	102	Unconfined	Water rushed into well from aquifer
3	Rube Beacher, Lyons	123	Drilled	(-)234	60	Principal artesian	160-ft casing (4 in.) sulphur water
4	Willis	136	Dug	-	124	Unconfined	
5	Branch	124	Drilled	56	67	Minor confined	32-ft casing
5A		125	Dug	108	113	Unconfined	
6	Deen	74	Dug	45	54	Alluvium	
7	Emmanuel	144	Dug	130	132	Unconfined	Abandoned
8	Hutcheson	145	Dug	127	138	Unconfined	Water spurted in when dug
8A		162	Dug	-	148	Unconfined	
9	King	142	Dug	130	132	Unconfined	Water spurts from bottom
10	Leona Hutcheson	158	Dug	131	135	Unconfined	30 years old, water comes from sides
11	Henry Hutcheson	152	Dug	131	136	Unconfined	7 years old
12	J. C. Mosley	131	Drilled	44	81	Minor confined	57-ft casing
12A		124	Dug	109	110	Unconfined	Abandoned
13	E. E. Mosley	99	Dug	85	87	Unconfined	
14	Beecher	115	Dug	100	108	Unconfined	Water spurted in when dug
15	Tom Lawrence	131	Drilled	(-)196	-	Principal artesian	Casing 265 ft; well 10 ft into aquifer; sulphur water
16	Crosby	114	Drilled	(-)300	-	Principal artesian	Sulphur water, 260-ft casing
16A	Crosby	100	Dug	84	92	Unconfined	
17	Robertson	142	Drilled	(-)213	52	Principal artesian	Slight sulphur, 355-ft casing
18	J. O. Beasley	174	Dug	155	161	Perched	
19	Melr	169	Dug	125	128	Unconfined	Was at 41 ft and went dry, deepened to 44 ft and water rushed in
20	Coleman	143	Drilled	(-)212	52	Principal artesian	Possibly same as well No. 17
21	V. Cannon	80	Dug	55	-	Alluvium	Sealed
22		148	Dug	123	138	Unconfined	
23	Braswell	159	Dug	141	147	Unconfined	
24	Calloway	157	Dug	142	146	Unconfined	
25	Covington	172	Drilled	(-)328	-	Principal artesian	207-ft casing
26	Ansley	150	Dug	130	136	Unconfined	
28	Sellers	156	Dug	139	-	Unconfined	

HNP-2-FSAR-2

TABLE 2.4-7 (SHEET 2 OF 2)

<u>Well Number</u>	<u>Owner</u>	<u>Surface Elevation (ft)</u>	<u>Type of Well</u>	<u>Elevation of Bottom of Well (ft)</u>	<u>Elevation of Water Surface (ft)</u>	<u>Aquifer</u>	<u>Remarks</u>
29	Collins	167	Dug	148	-	Unconfined	Covered over, abandoned
30	Sellers	151	Dug	129	138	Unconfined	
31	Sellers	134	Drilled	105	128	Unconfined	Well drilled 9/12/67
32	J. W. Adams	146	Drilled	135	140	Unconfined	
33	Moody	176	Dug	161	170	Perched	
34	Williams	184	Drilled	151	166	Perched	
35	Thigpen	188	Dug	156	173	Perched	Muddy water
35A		188	Drilled	139	164	Unconfined	
36	Sellers	164	Dug	134	152	Unconfined	
37		166	Dug	155	159	Unconfined	
38	Dewnann	165	Dug	151	157	Unconfined	
39		160	Dug	144	148	Unconfined	Abandoned
40	Hucheson	180	Dug	157	171	Perched	
41	Branch	187	Dug	147	157	Unconfined	
42	Deen	203	Drilled	157	174	Perched	
43	Branch	195	Dug	155	170	Perched	
44	Hardee	190	Drilled	155	168	Perched	
44A	Hardee	190	Dug	165	168	Perched	
45	Hutcheson	158	Dug	120	138	Unconfined	
46	Hutcheson and Setters	146	Drilled	(-)256	-	Principal artesian	Unable to measure, sealed
47	Baker	134	Drilled	(-)251	-	Principal artesian	
48		160	Drilled	(-)117	80(1940) 72(1956)	Principal artesian	
49	Baker	150	Dug	110	-	Unconfined	Abandoned, sealed
51	Williamson	156	Dug	136	148	Unconfined	
52	Williamson	143	Dug	123	135	Unconfined	
53		149	Dug	134	138	Unconfined	
54	Britt	130	Dug	116	121	Unconfined	
55		181	Dug	158	166	Perched	
56	Lawrence	162	Dug	151	153	Unconfined	
57		153	Dug	137	147	Unconfined	
Site Well 1		109.5	Drilled	(-)570.5	50.5	Principal artesian	As-built drawing, figure 2.4-38
Site Well 2		151.9	Drilled	(-)559.1	48.9	Principal artesian	As-built drawing, figure 2.4-38

HNP-2-FSAR-2

TABLE 2.4-8 (SHEET 1 OF 4)

PIEZOMETER DATA

<u>OBS Pt Number</u>	<u>Year Constructed</u>	<u>Surface Elevation</u>	<u>Location Coordinates</u>		<u>Piezometer Range or Bottom Elevation</u>	<u>Remarks</u>
			<u>North</u>	<u>East</u>		
P-1	1969	128	703+935	444+640	50	Destroyed 1971
P-2	1969	128.4	703+640	444+625	50	Destroyed 1971
P-3	1969	128.4	703+350	444+720	50	Destroyed 1971
P-6	1969	129.1	703+930	444+100	50	Destroyed 1971
P-7	1969	130.4	703+590	445+100	50	Destroyed 1971
P-8	1969	128.8	703+590	445+100	50	Destroyed 1971
P-9	1969	119.7	703+930	445+420	50	Destroyed 1973
P-10	1969	120.8	703+280	445+439	50	Destroyed 1974
P-11	Sept 71	130.0	702+989	445+418	50	Destroyed 1974
P-12	Oct 71	132.6	703+038	444+844	50	
P-13	Oct 71	131.2	703+038	444+584	50	
P-14	Oct 71	130.1	704+081	444+469	50	
P101A	1967	138.0	700+270	441+240	53.0	Destroyed 1969
P101B	1967	138.0	700+270	441+240	118.0	Destroyed 1969
P102A	1967	141.3	703+950	441+470	114.3	
P102B	1967	142.1	703+950	441+470	56.3	
P103A	1967	156.4	703+030	442+750	51.4	Destroyed 1968
P103B	1967	156.4	703+030	442+750	136.4	Destroyed 1968
P104A	1967	142.6	700+090	443+800	124.0	
P104B	1967	142.6	700+090	443+800	66.6	
P105A	1967	135.5	701+240	444+140	116.5	
P105B	1967	135.5	701+240	444+140	53.5	
P106A	1967	128.9	704+230	443+380	53.0	Destroyed 1969
P106B	1967	128.9	704+230	443+380	98.9	Destroyed 1969
P107A	1967	131.0	700+260	445+590	51.0	Destroyed 1974
P107B	1967	131.0	700+260	445+590	101.0	Destroyed 1974
P108A	1967	103.9	700+590	447+550	88.9	
P108B	1967	103.9	700+590	447+550	69.9	
P109A	1967	96.3	698+960	448+010	84.7	
P109B	1967	96.3	698+960	448+010	59.7	
P110A	1967	103.9	697+920	445+530	43.9	Destroyed 1969
P110B	1967	103.9	697+920	445+530	83.9	Destroyed 1969
P111A	1967	159.0	700+590	451+140	137.0	

HNP-2-FSAR-2

TABLE 2.4-8 (SHEET 2 OF 4)

<u>OBS Pt Number</u>	<u>Year Constructed</u>	<u>Surface Elevation</u>	<u>Location Coordinates</u>		<u>Piezometer Range or Bottom Elevation</u>	<u>Remarks</u>
			<u>North</u>	<u>East</u>		
P111B	1967	159.0	700+590	451+140	128.4	
P112A	1967	76.6	707+372	441+869	31.3	
P112B	1967	76.6	707+372	441+869	66.3	
B-402-1	1967	120.3	703+550	445+650	78-83	Destroyed 1968
B-402-2	1967	120.3	703+550	445+650	52-58	Destroyed 1968
B-402-3	1967	120.3	703+550	445+650	28-40	Destroyed 1968
B-402-4	1967	120.3	703+550	445+650	13-22	Destroyed 1968
B-402- surficial	1967	120.3	703+550	445+650	100-120	Destroyed 1968
B-404-1	1967	117.5	702+950	445+940	77-84	Destroyed 1968
B-404-2	1967	117.5	702+950	445+940	61-66	Destroyed 1968
B-404-3	1967	117.5	702+950	445+940	45-55	Destroyed 1968
B-404-4	1967	117.5	702+950	445+940	23-30	Destroyed 1968
B-404-5	1967	117.5	702+950	445+940	7-17	Destroyed 1968
B-404- surficial	1967	117.5	702+950	445+940	98-115.5	Destroyed 1968
B-407-1	1967	110.3	702+820	447+060	73-82	
B-407-2	1967	110.3	702+820	447+060	63-68	
B-407-3	1967	110.3	702+820	447+060	45-55	
B-407-4	1967	110.3	702+820	447+060	27-35	
B-407-5	1967	110.3	702+820	447+060	5-15	
B-407- surficial	1967	110.3	702+820	447+060	90-110	Destroyed 1968
B-411-1	1967	114.0	703+750	444+950	70-76	Destroyed 1969
B-411-2	1967	114.0	703+750	444+950	52-58	Destroyed 1969
B-411-3	1967	114.0	703+750	444+950	20-50	Destroyed 1969
B-411-4	1967	114.0	703+750	444+950	20-30	Destroyed 1969
B-411-5	1967	114.0	703+750	444+950	6-15	Destroyed 1969
B-411- surficial	1967	114.0	703+750	444+950	118-114	Destroyed 1969
B-434-1	1967	120.0			80	Destroyed 1968 ^(a)
B-434-2	1967	120.0	704+065	444+000	50	Destroyed 1968 ^(a)
B-434-3	1967	120.0	704+065	444+000	28-33	Destroyed 1968 ^(a)
B-434-4	1967	120.0	704+065	444+000	8-13	Destroyed 1968 ^(a)
P-1009A	Sept 72	139.0	702+635	444+360	44.0	
P-119B	Sept 72	139.0	702+635	444+360	105.0	

HNP-2-FSAR-2

TABLE 2.4-8 (SHEET 3 OF 4)

<u>Piezometer</u>	<u>Year Constructed</u>	<u>Reference Point Elevation (ft msl)</u>	<u>Plant Grid Location Coordinates</u>		<u>Depth Below Surface (ft)</u>	<u>Bottom Elevation (ft msl)</u>
			<u>North</u>	<u>East</u>		
N1A	1977	131.7	52+79	42+34	83.6	45.7
N1B	1976	131.0	52+80	42+33	26.5	102.9
N2A	1976	132.0	52+60	44+98	81.1	47.8
N2B	1976	131.1	52+40	44+98	26.9	102.0
N3A	1976	131.0	49+49	46+71	84.3	44.4
N3B	1976	130.6	49+49	46+51	27.0	101.7
N4A	1976	135.8	45+91	46+94	83.5	50.1
N4B	1976	135.7	45+71	46+92	27.0	106.8
N5B	1977	131.3	48+35	51+63	25.0	103.3
N7A ^(b)	1976	131.1	53+14	51+74	82.6	46.4
N8A	1976	131.9	56+12	52+78	79.6	49.9
N8B	1976	131.3	55+28	51+19	25.9	103.5
N9B	1977	131.6	55+26	49+44	17.0	112.4
N10B	1977	132.0	54+57	51+18	20.0	109.5
N11B	1977	131.7	52+72	51+25	20.0	109.6
N12B	1977	131.8	52+53	51+15	15.0	114.7
N13B	1977	129.5	52+65	37+64	25.0	103.0
N14B	1977	133.2	39+96	53+41	25.0	106.6
N15B	1977	120.1	46+91	62+12	25.0	94.2
P13A	1976	130.5	47+38	46+84	69.8	59.2
P13B	1977	129.9	47+40	46+80	23.2	105.8
P15A	1976	130.6	53+80	47+61	75.0	53.9
P15B	1976	131.3	53+90	47+61	19.3	109.7
P16	1976	131.4	53+14	51+87	14.6	115.2
P17A	1976	131.7	56+36	48+99	77.7	52.1
P17B	1976	131.7	56+46	48+99	14.8	115.3

TABLE 2.4-8 (SHEET 4 OF 4)

<u>OBS Pt Number</u>	<u>Year Constructed</u>	<u>Reference Point Elevation (ft msl)</u>	<u>Plant Grid Location Coordinates</u>		<u>Depth Below Surface (ft)</u>	<u>Bottom Elevation (ft msl)</u>
			<u>North</u>	<u>East</u>		
NW2A	2006	131.2	50+40	53+30	25.0	106.2
NW2B	2006	130.8	49+40	54+50	25.0	105.8
NW3A	2006	131.2	47+90	53+00	25.0	106.2
NW3B	2006	130.7	47+80	54+40	25.0	105.7
NW4A	2006	130.5	48+00	47+60	25.0	105.5
NW5A	2006	130.4	49+50	45+80	25.0	105.4
NW5B	2006	130.2	50+20	42+80	25.0	105.2
NW6	2006	131.3	56+50	46+90	25.0	106.3
NW7A	2006	130.5	56+10	43+50	25.0	105.5
NW8	2006	131.2	58+40	48+40	25.0	106.2
NW9	2006	131.8	57+00	52+70	25.0	106.8
NW10	2006	131.2	50+60	51+40	25.0	106.2
R1	2008	130.5	48+00	47+50	80.0	50.5
R2	2008	131.2	58+42	48+45	78.5	52.7
R3	2008	131.1	53+05	51+56	91.0	40.1
R4	2008	82.9	60+50	62+00	38.5	44.4
R5	2008	130.8	53+75	53+70	32.0	98.8
R6	2008	130.6	54+05	54+20	36.1	94.5

- a. *Destroyed shortly after installation.*
 b. *Abandoned in 2008.*

TABLE 2.4-9

PERMEABILITY AND POROSITY DATA

<u>Formation</u>	<u>Elevation of Tested Strata (ft msl)</u>	<u>Permeability (ft/min)</u>		<u>Porosity</u>		
		<u>Min</u>	<u>Max</u>	<u>Samples</u>	<u>Average n</u>	<u>Effective n (estimated)</u>
Hawthorn unit 6 (unconfined aquifer)	128-132	1.1×10^{-3}	1.7×10^{-3}	(1)	.19	.12
Hawthorn units 5 and 4 (aquiclude)	70-117	1.0×10^{-6}	4.4×10^{-6}	(7)	.31	.10
Hawthorn units 4 and 3 (confined aquifer)	20-72	3.1×10^{-5}	2.5×10^{-4}	(72)	.50	.15

TABLE 2.4-10

WATER QUALITY ANALYSES


	<i>Sample No. 1</i>	<i>Sample No. 2</i>	<i>Sample No. 3</i>	<i>Sample No. 4</i>
<i>Date of collection</i>	--	--	7/19/67	11/15/67
<i>Silica (SiO₂) (ppm)</i>	46	45	10	8.1
<i>Iron (Fe) (ppm)</i>	--	0.11	3.1	0.11
<i>Manganese (Mn) (ppm)</i>	--	--	0.4	0.0
<i>Calcium (Ca) (ppm)</i>	28	36	10	24
<i>Magnesium (Mg) (ppm)</i>	9.2	10	2	0.0
<i>Sodium (Na) (ppm)</i>	21.0	15	8	33.4
<i>Potassium (k) (ppm)</i>	0.9	2.7	--	3.5
<i>Bicarbonate (HCO₃) (ppm)</i>	172	161	--	113.5
<i>Carbonate (CO₃) (ppm)</i>	0	0	--	0
<i>Sulfate (SO₄) (ppm)</i>	2.4	20	7	0
<i>Chloride (Cl) (ppm)</i>	9.0	10	7	3.0
<i>Fluoride (F) (ppm)</i>	0.6	0.7		7.2
<i>Nitrate (NO₃) (ppm)</i>	0	0.2	1	0
<i>Dissolved solids</i>				
<i>Calculated (ppm)</i>	202	219	--	164.4
<i>Residue on evaporation at 180 °C</i>	--	--	--	258.0
<i>Hardness as CaCO₃ (ppm)</i>	180	131	--	60.0
<i>Noncarbonate hardness as CaCO (ppm)</i>	0	0	--	0
<i>Alkalinity as CaCO₃ (ppm)</i>	--	--	36	93
<i>Specific conductance</i>				
<i>(micro-mhos at 25 °C)</i>	280	311	100	270
<i>pH</i>	7.9	7.6	6.6	7.4
<i>Color</i>	0	5	15	--

Sample No. 1 - Hutcheson's well, north of Baxley, drilled 277 ft; analysis furnished by Geological Survey Water Resources Division, Atlanta, Georgia.

Sample No. 2 - City of Baxley, drilled 849 ft, cased 564; analysis furnished by Geological Survey Water Resources Division, March 12, 1963.

Sample No. 3 - GPC sample - raw water from the Altamaha River near site; analysis furnished by GPC, July 19, 1967.

Sample No. 4 - Piezometer water, boring 411-5, el 6 ft to 15 ft; analysis, November 20, 1967.



HISTORICAL
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

EDWIN I. HATCH NUCLEAR PLANT SITE

FIGURE 2.4-1




HISTORICAL
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

LOCAL SITE ENVIRONS

FIGURE 2.4-2



ACAD


HISTORICAL
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

SITE TOPOGRAPHIC MAP

FIGURE 2.4-3



HISTORICAL
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

HATCH STRUCTURES GENERAL ARRANGEMENT PLAN


FIGURE 2.4-4

STATE OF GEORGIA

LOCATION OF
HATCH NUCLEAR PLANT


LEGEND

● POPULATION CENTERS OVER 20,000 WITHIN
100 MILES OF THE SITE AND OTHER MAJOR
POPULATION CENTERS IN GEORGIA



ADAPTED FROM: COUNTY AND CITY DATA BOOK — 1962
US DEPT OF COMMERCE
BUREAU OF THE CENSUS

UPDATED FROM: CENSUS OF THE POPULATION — 1970



ACAD

HISTORICAL
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

LOCATION OF HATCH NUCLEAR PLANT

FIGURE 2.4-5

ALTAMAHA DRAINAGE BASIN



ACAD


HISTORICAL
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

ALTAMAHA DRAINAGE BASIN

FIGURE 2.4-6




HISTORICAL
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

OVERALL SITE DRAINAGE PLAN

FIGURE 2.4-7



ACAD


HISTORICAL
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

ALTAMAHA RIVER AT HNP STAGE DISCHARGE RELATION HIGH
FLOWS

FIGURE 2.4-8



NOTE:
 THE STORM OF 5-10 JULY, 1916 WITH THE PRIMARY CENTER NEAR BONFAY, FLORIDA WAS TRANSPOSED TO THE ALTAMAHA RIVER BASIN AND THE STORM AXIS WAS ROTATED 20° CLOCKWISE.

LEGEND
 — 5 — ISOHYET
 ——— THIESSEN POLYGON
 ——— BASIN BOUNDARIES




HISTORICAL
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 1 AND UNIT 2

ISOHYETAL MAP FOR PROBABLE MAXIMUM PRECIPITATION –
 ALTAMAHA RIVER ABOVE PLANT SITE

FIGURE 2.4-9



NOTE:
 RAINFALL BASED ON STORM OF JULY 5-10, 1961, (GMI-19)
 WITH PRIMARY CENTER NEAR BONIFAY, FLORIDA


HISTORICAL
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
 EDWIN I. HATCH NUCLEAR PLANT
 UNIT 1 AND UNIT 2

PROBABLE MAXIMUM FLOOD ALTAMAHA RIVER

FIGURE 2.4-10




HISTORICAL
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

HYDROGRAPH - 1948 FLOOD

FIGURE 2.4-11




HISTORICAL
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

HYDROGRAPH - 1961 FLOOD

FIGURE 2.4-12



ACAD


HISTORICAL
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

ADOPTED 6-h UNIT HYDROGRAPH ALTAMAHA
RIVER AT NUCLEAR POWER PLANT SITE

FIGURE 2.4-13



ACAD


HISTORICAL
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT
UNIT 1 AND UNIT 2

LOCATIONS OF SECTIONS RUN IN 1967 FOR
BACKWATER GRADIENT STUDY


FIGURE 2.4-14



NOTE:
 THE STORM OF MARCH 11-16, 1929 WITH
 PRIMARY CENTER NEAR ELBA, ALABAMA
 WAS TRANSPOSED TO ALTAMAHA RIVER
 BASIN. THE RAINFALL WAS MAXIMIZED
 AND THE STORM AXIS ROTATED 20°
 COUNTER CLOCKWISE.

LEGEND
 — 5 — ISOHYET
 - - - - - THIESSEN POLYGON
 ~~~~~ BASIN BOUNDARIES

**ISOHYETAL MAP**  
 MAXIMUM PRECIPITATION ON ALTAMAHA RIVER  
 BASIN ABOVE EDWIN I. HATCH NUCLEAR PLANT  
 USING STORM OF MARCH 11-16, 1929.



HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

ISOHYETAL MAP

FIGURE 2.4-15

**PROBABLE MAXIMUM PRECIPITATION ADJUSTMENT FACTOR  
ALTAMAHA RIVER BASIN ABOVE EDWIN I. HATCH NUCLEAR PLANT**

STORM OF MARCH 11-16, 1929, (LMV 2-20) TRANPOSED FOR MONTH OF MAY

| THIESSEN POLYGON | BARRIER ELEVATION (FEET) | 1    | 2    | 3    | 4    | 5   | 6    | EXPLANATORY NOTES                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
|------------------|--------------------------|------|------|------|------|-----|------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| WETUMPKA         | 1000                     | 74.4 | 2.82 | 0.24 | 2.58 | 7.8 | 1.10 | <p>STORM'S 12-HOUR 1000-MB DEWPOINT<br/>ACTUAL THROUGHOUT (Dp)<sub>s</sub> = 67°<br/>MAXIMUM AT SELECTED LOCATION AND TIME<br/>(Dp)<sub>m</sub> PER STATION - - - - COLUMN 1</p> <p>STORM'S MOISTURE CHARGE ADJUSTED FOR ELEVATION<br/>OF INFLOW BARRIER<br/>ACTUAL TOTAL AT (Dp)<sub>s</sub> DEWPOINT - (Wp)<sub>s</sub> = 1.96"<br/>ACTUAL INFLOW BARRIER REDUCTION (Wp)<sub>s</sub> = 0.04"<br/>AT (Dp)<sub>s</sub><br/>NET ACTUAL ABOVE INFLOW BARRIER (Wp)<sub>s</sub> - (Wp)<sub>s</sub> = 1.92"</p> <p>MAXIMUM CORRESPONDING TO (Dp)<sub>m</sub><br/>(Wp)<sub>m</sub> PER STATION - - - - COLUMN 2</p> <p>MAXIMUM INFLOW BARRIER REDUCTION AT (Dp)<sub>m</sub><br/>(Wp)<sub>m</sub> PER STATION - - - - COLUMN 3</p> <p>MAXIMUM ABOVE INFLOW BARRIER<br/>(Wp)<sub>m</sub> - (Wp)<sub>m</sub> PER STATION - - - - COLUMN 4</p> <p>TEMPERATURE CONTRAST<br/>ACTUAL STORM CENTER - - - - (Tc)<sub>s</sub> = 13.7<br/>STORM CENTER TRANPOSED IN LOCATION<br/>AND TIME - - - - (Tc)<sub>t</sub> = 9.2</p> <p>MOISTURE CHARGE ADJUSTED FOR INFLOW BARRIER AND<br/>STORM EFFICIENCY<br/>ACTUAL STORM LOCATION (Tc)<sub>s</sub><sup>1/2</sup> X [(Wp)<sub>s</sub> - (Wp)<sub>s</sub>] = 7.1<br/>MAXIMUM AT SELECTED LOCATION AND TIME<br/>(Tc)<sub>s</sub><sup>1/2</sup> X [(Wp)<sub>m</sub> - (Wp)<sub>m</sub>] PER STATION =<br/>9.2<sup>1/2</sup> X COLUMN 4 = COLUMN 5</p> <p>MAXIMUM PROBABLE PRECIPITATION FACTOR<br/>RATIO OF MAXIMUM AT STATION IN TRANPOSED<br/>LOCATION TO ACTUAL FOR RESPECTIVE STATION<br/>IN ORIGINAL LOCATION =<br/><math display="block">\frac{(Tc)_t^{1/2} \times [(Wp)_m - (Wp)_m]}{(Tc)_s^{1/2} \times [(Wp)_s - (Wp)_s]} = \frac{\text{COLUMN 5}}{7.1} = \text{COLUMN 6}</math></p> |
| MILSTEAD         | 750                      | 74.5 | 2.83 | 0.20 | 2.63 | 8.0 | 1.12 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| PRATTVILLE       | 900                      | 74.4 | 2.82 | 0.23 | 2.59 | 7.9 | 1.11 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| SELMA            | 950                      | 74.4 | 2.82 | 0.24 | 2.58 | 7.8 | 1.10 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| BENTON           | 900                      | 74.6 | 2.84 | 0.23 | 2.61 | 7.9 | 1.11 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| MONTGOMERY       | 750                      | 74.5 | 2.83 | 0.19 | 2.64 | 8.0 | 1.13 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| PRIMROSE FARM    | 750                      | 74.5 | 2.83 | 0.19 | 2.64 | 8.0 | 1.13 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| TROY             | 650                      | 74.8 | 2.87 | 0.17 | 2.70 | 8.2 | 1.15 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| HIGHLAND HOME    | 700                      | 74.7 | 2.86 | 0.18 | 2.68 | 8.1 | 1.14 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| GREENVILLE       | 750                      | 74.8 | 2.87 | 0.19 | 2.68 | 8.1 | 1.14 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| EVERGREEN        | 700                      | 75.2 | 2.92 | 0.18 | 2.74 | 8.3 | 1.17 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| MCKENZIE         | 700                      | 75.1 | 2.91 | 0.18 | 2.73 | 8.3 | 1.16 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| RIVER FALLS      | 600                      | 75.2 | 2.92 | 0.15 | 2.77 | 8.4 | 1.18 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| ELBA             | 600                      | 75.1 | 2.91 | 0.15 | 2.76 | 8.4 | 1.18 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| COFFEE SPRINGS   | 450                      | 75.2 | 2.92 | 0.11 | 2.81 | 8.5 | 1.20 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| GENEVA           | 450                      | 75.2 | 2.92 | 0.11 | 2.81 | 8.5 | 1.20 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| BREWTON          | 450                      | 75.5 | 2.97 | 0.12 | 2.85 | 8.6 | 1.22 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| BLUFF SPRINGS    | 450                      | 75.5 | 2.97 | 0.12 | 2.85 | 8.6 | 1.22 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| COTTAGE HILLS    | 450                      | 75.7 | 3.00 | 0.12 | 2.88 | 8.7 | 1.23 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| METTS            | 450                      | 75.7 | 3.00 | 0.12 | 2.88 | 8.7 | 1.23 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| GARNIERS         | 400                      | 75.9 | 3.03 | 0.11 | 2.92 | 8.9 | 1.25 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| NICEVILLE        | 450                      | 75.7 | 3.00 | 0.12 | 2.88 | 8.7 | 1.23 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| PANAMA CITY      | 350                      | 76.0 | 3.04 | 0.10 | 2.94 | 8.9 | 1.25 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| DEFUNIAC SPRINGS | 450                      | 75.5 | 2.97 | 0.11 | 2.86 | 8.7 | 1.22 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| VERNON           | 400                      | 75.7 | 3.00 | 0.11 | 2.89 | 8.8 | 1.23 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

PROBABLE MAXIMUM PRECIPITATION ADJUSTMENT FACTOR

FIGURE 2.4-16



STORM OF MARCH 11-16, 1929, TRANSPOSED AND  
 MAXIMIZED TO OBTAIN MAXIMUM PRECIPITATION  
 IN ALTAMAHA BASIN ABOVE EDWIN I. HATCH  
 NUCLEAR PLANT


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

STORM HYDROGRAPH

FIGURE 2.4-17



ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

DISCHARGE STAGE FREQUENCY CURVES – ALTAMAHA RIVER  
AT U.S. HIGHWAY 1 CROSSING GEORGIA


FIGURE 2.4-18




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SINCLAIR DAM PLAN AND ELEVATION


FIGURE 2.4-19




SECTION THRU POWERHOUSE & INTAKE



SECTION THRU SPILLWAY



SECTION THRU NON-OVERFLOW



SECTION THRU EARTH DAM

ACAD

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SINCLAIR DAM SECTIONS

FIGURE 2.4-20





NOTE:  
 RAINFALL BASED ON STORM OF MARCH 11-16, 1929, (LMV 2-20)

STORM MAXIMIZED AND TRANPOSED TO SINCLAIR BASIN; STORM AXIS ROTATED 20° COUNTER-CLOCKWISE AND POSITIONED FOR MAXIMUM RAINFALL VOLUME ON THE BASIN


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

SINCLAIR DAM HYDROGRAPH DURING SPILLWAY DESIGN  
 FLOOD

FIGURE 2.4-21




HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

LLOYD SHOALS DAM PLAN, ELEVATION, AND SECTIONS

FIGURE 2.4-22




HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

LLOYD SHOALS PROJECT GENERAL PLAN AND SECTIONS

FIGURE 2.4-23




HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

LLOYD SHOALS DAM FAILURE STUDY

FIGURE 2.4-24




HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SINCLAIR DAM GENERATION TEST STAGE CURVES

FIGURE 2.4-25




HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SINCLAIR DAM GENERATION TEST DISCHARGE CURVES

FIGURE 2.4-26




HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

HYDROGRAPH AT BAXLEY, GEORGIA FROM  
SINCLAIR TURBINE RELEASE (UNITS 1 AND 2)

FIGURE 2.4-27



ACAD

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

WALLACE DAM GENERAL PLAN OF DEVELOPMENT

FIGURE 2.4-28







EXHIBIT L  
SHEET 2 OF 9



SCALE IN FEET  
0 20 40 60 80

THIS DRAWING IS A PART OF THE APPLICATION FOR LICENSE MADE BY THE UNDERSIGNED THE 10TH DAY OF APRIL, 1966, AS REVISED THIS 8TH DAY OF FEBRUARY, 1972

GEORGIA POWER COMPANY  
BY: *Blanchard*  
VICE PRESIDENT

NOTES:  
1 THIS DRAWING SUPERSEDES EXHIBIT L, SHEET 2 DATED APRIL 10, 1966.  
2 PLANT ELEVATIONS ARE PLANT DATUM  
EL. 4350 PLANT DATUM = EL. 4354 WFL DATUM  
DUE TO AN MOVEMENT IN A U.S.C.B.S. BENCH MARK


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

WALLACE DAM PLAN AND DOWNSTREAM ELEVATION

FIGURE 2.4-29



ACAD




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

HISTORICAL  
REV 19 7/01

WALLACE DAM TYPICAL SECTIONS

FIGURE 2.4-30



ACAD


*HISTORICAL*  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

WALLACE DAM RESERVOIR CAPACITY CURVE

FIGURE 2.4-31



ACAD


*HISTORICAL*  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

WALLACE DAM SPILLWAY RATING CURVE USED IN 1972

FIGURE 2.4-32



NOTE:  
 MARCH 11-16, 1929 ELBA STORM  
 (LMV 2-20) MAXIMIZED AND TRANSPPOSED  
 TO WALLACE BASIN, STORM AXIS  
 ROTATED 20° CLOCKWISE AND  
 POSITIONED FOR MAXIMUM RAINFALL  
 VOLUME ON THE BASIN WITH CENTER  
 AT LAT. 33° 54.9', LONG. 83° 23.8'

NOTE: SINCLAIR DATUM + .6 = MSL

ACAD

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

WALLACE DAM SPILLWAY DESIGN FLOOD

FIGURE 2.4-33

ACAD 2020434

WATER ELEVATION FT. MSL

ACAD


HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

ALTAMAHA RIVER AT HNP STAGE DISCHARGE  
RELATION LOW FLOWS

FIGURE 2.4-34





ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

PROFILE OF PRINCIPAL ARTESIAN AQUIFER, NW-SE

FIGURE 2.4-35



ACAD

*HISTORICAL*  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

WELL LOCATIONS IN PLANT VICINITY

FIGURE 2.4-36





**LEGEND**

- P-106 GROUND WATER OBSERVATION POINTS. NUMBER WITH LETTER PREFIX IS IDENTIFICATION (SEE TABLE 2.4-2)
- B-407
- SITE WATER WELLS
- GEORGIA GRID SYSTEM PLANT GRID SYSTEM
- TOPOGRAPHIC CONTOUR (25 FEET INTERVAL)

ACAD

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SIZE PIEZOMETER AND WELL LOCATIONS

FIGURE 2.4-37

SITE WELL 1

SITE WELL 2



NOT TO SCALE


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

DETAIL OF SITE WELLS

FIGURE 2.4-38



**NOTES:**  
 PIEZOMETER DATA PRESENTED ON TABLE 2.4-8 .  
 SITE WELL DETAILS PRESENTED ON FIGURE 2.4-38

**LEGEND**

- P-105 SITE PIEZOMETER - UNCONFINED AQUIFER (CONSTRUCTED 1967)
- N2B NEW PIEZOMETER - UNCONFINED AQUIFER (CONSTRUCTED 1976-77)
- ⊙ 2 SITE WATER WELL
- 120 — UNCONFINED WATER LEVEL CONTOUR, FEET, MSL (JUNE, 1977)
- N702,000 GEORGIA GRID SYSTEM  
 37400 PLANT GRID SYSTEM
- 100 — TOPOGRAPHIC CONTOUR, FEET, MSL



ACAD


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

CONTOURS OF UNCONFINED WATER SURFACE

FIGURE 2.4-39



ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

CONTOURS OF POTENTIOMETRIC SURFACE, MINOR  
CONFINED AQUIFER

FIGURE 2.4-40



◊ SAME READINGS FOR MORE THAN ONE PIEZOMETER

1969  
PLANT PIEZOMETERS

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

PIEZOMETER LEVELS

FIGURE 2.4-41 (SHEET 1 OF 6)



⊙ SAME READINGS FOR MORE THAN ONE PIEZOMETER

1970

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

PIEZOMETER LEVELS

FIGURE 2.4-41 (SHEET 2 OF 6)



◉ SAME READINGS FOR MORE THAN ONE PIEZOMETER

ACAD

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

PIEZOMETER LEVELS

FIGURE 2.4-41 (SHEET 3 OF 6)





• SAME READINGS FOR MORE THAN ONE PIEZOMETER

1972

ACAD

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

PIEZOMETER LEVELS

FIGURE 2.4-41 (SHEET 4 OF 6)





◊ SAME READINGS FOR MORE THAN ONE PIEZOMETER

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

PIEZOMETER LEVELS

FIGURE 2.4-41 (SHEET 5 OF 6)



© SAME READINGS FOR MORE THAN ONE PIEZOMETER

1974

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

PIEZOMETER LEVELS

FIGURE 2.4-41 (SHEET 6 OF 6)



⊙ SAME READINGS FOR MORE THAN ONE PIEZOMETER

1968

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SITE PIEZOMETER LEVELS

FIGURE 2.4-42 (SHEET 1 OF 9)



⊙ SAME READINGS FOR MORE THAN ONE PIEZOMETER

1968

ACAD

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SITE PIEZOMETER LEVELS

FIGURE 2.4-42 (SHEET 2 OF 9)





ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SITE PIEZOMETER LEVELS

FIGURE 2.4-42 (SHEET 3 OF 9)



1973

© SAME READINGS FOR MORE THAN ONE PIEZOMETER

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SITE PIEZOMETER LEVELS

FIGURE 2.4-42 (SHEET 4 OF 9)



ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SITE PIEZOMETER LEVELS

FIGURE 2.4-42 (SHEET 5 OF 9)



ACAD

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SITE PIEZOMETER LEVELS

FIGURE 2.4-42 (SHEET 6 OF 9)





ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SITE PIEZOMETER LEVELS

FIGURE 2.4-42 (SHEET 7 OF 9)



ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SITE PIEZOMETER LEVELS

FIGURE 2.4-42 (SHEET 8 OF 9)



© SAME READINGS FOR MORE THAN ONE PIEZOMETER

1974

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SITE PIEZOMETER LEVELS

FIGURE 2.4-42 (SHEET 9 OF 9)



- LEGEND:
- PROFILE TAKEN 7/12/75
  - PROFILE TAKEN 7/18/74
  - PROFILE TAKEN 7/79
  - ▲—▲— PROFILE TAKEN 7/28/80
  - PROFILE TAKEN 9/8/77

NOTE:  
 PROFILE TAKEN ALONG THE CENTERLINE OF THE  
 INTAKE STRUCTURE AT E49+63.STA.0+00 IS LOCATED AT  
 N64+79.58 WITH STATIONS PROGRESSING ACROSS THE RIVER.

ACAD

HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

ALTAMAHA RIVER PROFILE AT INTAKE

FIGURE 2.4-43

## 2.5 **GEOLOGY AND SEISMOLOGY (HNP-1 AND HNP-2)**

*In compliance with the criteria provided in appendix A, Seismic and Geologic Siting Criteria for Nuclear Power Plants, of 10 CFR 100, this section provides information regarding the geologic and seismic characteristics of the site and the region surrounding the site.*

*The Edwin I. Hatch Nuclear Plant (HNP) is located on the south bank of the Altamaha River in Appling County, southeastern Georgia. This area is in the Coastal Terraces subprovince of the Atlantic Coastal Plain physiographic province. The site is underlain by ~ 4000 ft of relatively unconsolidated Mesozoic and Cenozoic sands, gravels, clays, marls, claystones, sandstones, and limestones. These strata, overlying basaltic basement rock of pre-Cretaceous age, dip and thicken seaward. No structural features affect the material underlying the site. No major or minor fault zones are near the site, nor were any local faults discovered during field mapping, exploratory drilling, and construction.*

*The site is within a region of infrequent seismic activity. No earthquakes within 200 miles of the site, including those in the Charleston area ~ 150 miles from the site, produced Modified Mercalli intensities at the site greater than VI. Historically, reported earthquakes occurring in other areas have not produced intensities greater than VI at the site. The design basis earthquake (DBE) is conservatively selected as Modified Mercalli Intensity VII.*

*The Hawthorn Formation of Miocene to Pliocene(?) age is the foundation-bearing stratum for the major plant structures. It consists primarily of sand, clay, and cemented sand and clay layers. There are no zones of deformation, alteration, or weakness within the Hawthorn Formation.*

*The site is underlain by both confined and unconfined aquifers. Local and regional ground water conditions have not been altered by construction and operation of the plant.*

*The scope of site investigations included the geologic, geohydrologic, and seismologic conditions of the area and evaluation of these conditions regarding their effects on the design, construction, and operation of a nuclear plant at the site. The purpose of the investigations was to determine the following:*

- *The characteristics of the foundation materials, especially in regard to their suitability for supporting plant structures.*
- *The extent of geologic structures affecting the site.*
- *The seismicity of the area.*
- *The depth and configuration of the ground water table.*
- *The characteristics of soil and rock with respect to their effects on the migration of radioactive solutions, should such solutions come in contact with them.*

*The purpose was accomplished by conducting programs of geological and geophysical field exploration, foundation analysis and evaluation, installation of a ground water monitoring system, and review of pertinent literature.*

## 2.5.1 BASIC GEOLOGIC AND SEISMIC INFORMATION

*The following sections and subsections contain the results and conclusions of the regional and site geologic and seismic investigations. Information on regional and local ground water conditions is included in subsection 2.4.13, Ground Water, and is only summarized in the following geology subsections. The characteristics of soils with respect to the support of major plant structures are discussed in detail in supplement 2A and cross-referenced in this section.*

*The information presented in the following sections was obtained from the latest published sources and reflects presently accepted geologic interpretations. The Georgia Geological Survey prepared a new state geologic map, published in June 1975, which designates new terminology for some formations found at the Hatch site. These changes in nomenclature do not affect lithologic or structural relationships in the site area, nor do they have any significance in the selection of the DBE or in the description of site ground water conditions.*

### 2.5.1.1 Regional Geology

#### 2.5.1.1.1 Regional Physiography (HNP-1 and HNP-2)

*The Edwin I. Hatch Nuclear Plant is on the south bank of the Altamaha River ~ 10 miles north of Baxley, Georgia, and ~ 73 miles northwest of Brunswick, Georgia. The site is within the Atlantic Coastal Plain physiographic province.<sup>(1)</sup> Within 200 miles of the site are parts of three other major physiographic provinces: the Blue Ridge, Piedmont, and East Gulf Coastal Plain. The first two provinces are associated with the Appalachian Mountain System. They are separated from the Coastal Plain province by the Fall Line, a break in slope represented by rapids in the major streams about 80 miles northwest of the site.<sup>(2)</sup> The regional physiography is shown in figure 2.5-1.*

*The Blue Ridge province trends northeastward across the northwest corner of Georgia. Elevations in the province range from a high of over 6000 ft in North Carolina to less than 2000 ft in Alabama where the Blue Ridge rocks dip below Coastal Plain sediments at the Fall Line. In Georgia, local relief approaches 200 ft, with rounded summits nearly 4000 ft above sea level. The summits and valleys in the province are distinctly nonlinear, reflecting both the lack of structural control and the erosive effects of the well-developed drainage system that flows generally transverse to the northeastern trend of the Appalachians.<sup>(3)</sup> The boundary with the Piedmont province to the southeast is the Brevard Fault Zone and is marked by a somewhat obscured, northeast-trending topographic lineation in Georgia.<sup>(4)</sup> The nearest approach of the Blue Ridge province to the site is ~ 185 miles.*

*The Piedmont is a rolling, southeast-sloping plain between the Blue Ridge on the northwest and the Coastal Plain provinces on the south and southeast. The plain's surface is broken by numerous hills and ridges that rise as monadnocks up to 1000 ft high, although local relief is generally < 200 ft. The seaward edge of the Piedmont province is marked by the Fall Line, where Piedmont rocks dip below the mostly unconsolidated material of the Coastal Plain provinces.<sup>(3)</sup> The Piedmont is ~ 80 miles northwest of the site.*

*The Atlantic and East Gulf Coastal Plain provinces extend from the Fall Line to the Atlantic Ocean and Gulf of Mexico, respectively. The Atlantic Coastal Plain is characterized by nearly flat-lying terrace*

surfaces, underlain by limestone or unconsolidated sand and clay, that occur as narrow belts parallel to the coast. By contrast, the wider subprovince belts of the East Gulf Coastal Plain consist of numerous ridges or cuestas separated by low valleys or inner lowlands. Rocks underlying the East Gulf subprovinces vary in their resistance to erosion and range from sandstone, shale, and limestone to softer clay, sand, and marl. The transition zone between the two major provinces is in central Georgia, about 60 miles west of the site, between the eastward flowing Ocmulgee River and the southward flowing Flint River.<sup>(2)</sup>

The Fall Line Hills, Red Hills, Dougherty Plain, Tifton Upland, and Coastal Terraces subprovinces are common to both Coastal Plain provinces. The Fall Line Hills extend from the Tennessee River on the west to the central Carolinas on the east where they are known as the Sand Hills. The maturely dissected topography, with relief approaching 350 ft, is developed on predominantly sand-bearing formations of Cretaceous age. The Red Hills, with a similar topography, lie immediately seaward of the Fall Line Hills in Georgia, and are developed on Eocene rocks. In Alabama, the Red Hills become the Southern Red Hills, underlain by both Eocene and Oligocene rocks weathered bright red. The Dougherty Plain extends from southeastern Alabama and the Florida panhandle into central Georgia. This wide, largely flat plain contains shallow solution depressions developed in Eocene limestone. Low scarps separate the Dougherty Plain from the higher, landward Red Hills subprovince and the higher, seaward Tifton Upland. The Tifton Upland is a region of gently rolling hills with broad rounded summits underlain by Miocene-age sand. Relief is generally < 50 ft, but may approach several hundred feet near the wide, flat-bottomed river valleys. The Red Hills, Dougherty Plain, and Tifton Upland merge with the Upper Coastal Plain subprovince of South Carolina. The Coastal Terraces subprovince is seaward from and lower in elevation than the adjacent Tifton Upland. This subprovince, with maximum relief of ~ 100 ft near major stream valleys, can be subdivided into at least seven terraces, whose nearly flat surfaces constitute late Miocene to late Pleistocene sea floors. The landward limit of each terrace is marked by a low, often obscure scarp. The older, higher terraces merge with the Middle Coastal Plain of South Carolina, while the younger, lower terraces merge with the Lower Coastal Plain of South Carolina and the late Pleistocene terraces of Florida.<sup>(2)</sup>

The physiography of that part of Florida within 200 miles of the site has been determined by Pleistocene terracing, solution of underlying rocks, and stream erosion. The subprovinces affected by these factors are the late Pleistocene Terraces, East Florida Flatwoods, Lake Region, Lime-Sink Region, and Flatwoods and Hammock Lands.<sup>(2)</sup>

The late Pleistocene terraces, with highest surfaces of el 40 to 45 ft, 65 to 70 ft, and 95 to 100 ft, extend from the South Carolina Lower Coastal Plain into Florida without change of character. The surfaces are nearly flat, with a slight seaward dip, and are often swampy. This terrace belt merges with the East Florida Flatwoods Terraces near Jacksonville, Florida. The Lake Region to the west is higher in elevation (~ 100 ft above sea level) and is characterized by large, shallow lake basins enclosed primarily by sand. By contrast, the Lime-Sink Region further west has numerous small-solution depressions and lakes and as much as 50 ft of relief. The Flatwoods and Hammock Lands extend along the entire west coast of Florida to Mobile Bay. Between Tampa Bay and the Apalachicola River, low relief is typical, with old sinkholes discontinuously covered by more recent thin sand deposits.<sup>(2)</sup>

The site is adjacent to the valley of the Altamaha River, near the boundary between the Brandywine and Coharie Terraces of the Coastal Terrace subprovince.<sup>(2)</sup> From the Altamaha River flood plain to the ground surface at the site, relief is ~ 100 ft.

#### **2.5.1.1.2 Regional Geologic Maps (HNP-1 and HNP-2)**

*The surficial geology of the region is characterized by Precambrian and early Paleozoic rocks inland from the Fall Line, and Cretaceous to Holocene sediments from the Fall Line to the Atlantic and Gulf coasts. The rocks within the Appalachian provinces are largely folded, faulted, and metamorphosed.<sup>(4)</sup> Those in the Coastal Plain provinces dip seaward at low angles and have undergone comparatively minor structural deformation.<sup>(1)</sup>*

*Regional maps depicting the surface geology and tectonic features are presented in figures 2.5-2 and 2.5-3, respectively.*

#### **2.5.1.1.3 Regional Geologic Setting (HNP-1 and HNP-2)**

*Since the physiography of a province is determined largely by the character of its underlying rocks, the names and boundaries of the geologic and physiographic provinces within 200 miles of the site are considered the same.<sup>(1)</sup>*

*The geology of the region within 200 miles of the site may be divided into two categories:*

- *Areas in which Precambrian and Paleozoic rocks are exposed.*
- *Areas containing exposures of upper Mesozoic and Cenozoic sediments, underlain by Precambrian, Paleozoic, and lower Mesozoic rocks.*

*The Blue Ridge and Piedmont provinces contain surface exposures of Precambrian and Paleozoic rocks. Mesozoic and Cenozoic sediments constitute the surface formations in the Atlantic and Gulf Coastal Plains.*

*The Blue Ridge province, included in the western Piedmont by some authors,<sup>(5)</sup> extends from the Cartersville Fault to the Brevard Fault Zone.<sup>(4)</sup> It has been interpreted as:*

- *A synclinorium modified by doming and faulting subsequent to deposition and metamorphism of Middle Devonian to Early Mississippian sediments.<sup>(6)</sup>*
- *An anticlinorium consisting of middle Precambrian basement rocks flanked by younger rocks that were folded in the mid-Paleozoic and then broken and transported westward by later Paleozoic thrusting.*

*Regardless of interpretation, the rocks are unmetamorphosed to highly metamorphosed and deformed by flexure, slip, flow folding, and thrusting.<sup>(4)</sup> The metamorphic grade generally increases southeastward. Granitic plutons and ultrabasic intrusives of Paleozoic age are common in the southeastern part of the province.<sup>(3)</sup> Two belts of low-grade metasediments, the Talladega and Murphy Belts, are found in the northwest part of the province in Georgia. (See figure 2.5-2.)*

*East and south of the Brevard Fault Zone is the Piedmont province. Rocks in the province range in age from middle Precambrian to early mid-Paleozoic and consist of granite and metamorphics of various*



grades. On the northwestern edge, Chauga Belt low-grade metamorphics of late-Precambrian to Early-Cambrian age form a synclinorium separating the Blue Ridge from the Inner Piedmont. Rocks in the Inner Piedmont are mostly granitized, high-grade metamorphics.<sup>(4)</sup> They have been overturned and overthrust to the northwest,<sup>(1)</sup> forming a large anticlinal mass of northwest-directed nappes rooted to the southeastern side of the Inner Piedmont. The Kings Mountain Belt in Alabama and Georgia is an anticlinal belt of late Precambrian to Cambrian rocks that range from weak to low-grade metamorphics, similar to the Chauga Belt. The Charlotte Belt, southeast of the Kings Mountain Belt, consists of an isoclinally folded anticlinorium. The anticlinorium is cored by middle-Precambrian basement rocks and overlain by late-Precambrian high-grade metasediments and metavolcanics. A few early mid-Paleozoic plutons intrude the metamorphics. A low-rank assemblage of late-Precambrian to middle-Paleozoic metasediments and metavolcanics is found in the Carolina Slate Belt. The belt is interpreted as a synclinorium, with northeast trending folds that are either open or are tightly compressed and overturned.<sup>(4)</sup>

Rocks underlying the upper Mesozoic and Cenozoic coastal plain deposits vary in age and lithology. The basement rocks in Georgia consist of Precambrian and Paleozoic high-grade metamorphics, granite, diorite, and some volcanic rhyolites in southeast Georgia. In the tri-state area of southeastern Alabama, southwestern Georgia, and northern Florida, the coastal plain sediments are underlain by tightly consolidated, clastic sedimentary rocks. The rocks contain many fossils which range in age from Cambrian to Silurian. A well drilled in Appling County, Georgia, less than 5 miles from the site, ended in basalt of probable Triassic age at a depth of 4108 ft.<sup>(7)</sup>

The top of basement rock beneath the East Gulf and Atlantic Coastal Plains represents a portion of the erosional surface developed on deformed Appalachian Belt rocks prior to or during the Jurassic. The surface is exposed inland from the Fall Line where the overlapping wedge of younger coastal plain material terminates. Geophysical data suggest the presence of general north-to-northeasterly trends in the basement underlying the Atlantic Coastal Plain. These trends may be due to lithologic or structural variations in the basement rocks, or to topographic relief developed on a pre-Cretaceous erosion surface. Seismic surveys and well borings reveal an irregular surface with a general seaward slope for the top of basement rocks underlying the Coastal Plain provinces.<sup>(1)</sup>

Overlying the Paleozoic basement rocks, the Atlantic and East Gulf Coastal Plain sediments range in age from Triassic to Holocene. A regional geologic column showing these strata is shown in figure 2.5-4. These sediments generally consist of alternating layers of relatively unconsolidated sand, sandstone, shale, clay, and limestone. Triassic deposits in the form of red beds occur in isolated grabens underlying the Atlantic Coastal Plain. No Jurassic strata are known to exist in the Atlantic Coastal Plain, and pre-Cretaceous rocks are not exposed in either Coastal Plain province.<sup>(1)</sup>

Cretaceous through Holocene sediments are found at the surface in both coastal plain areas. The outcrop pattern, with bands of older strata lying landward of younger strata, reflects the gentle seaward dip of the deposits.<sup>(3)</sup> In Georgia, this dip is between 5 and 50 ft/mile.<sup>(8)</sup> Regionally, the dip increases with depth as a result of seaward thickening of the coastal plain deposits.<sup>(3)</sup> The sediments consist of gravels, sands, silts, clays, marls, and their consolidated equivalents, such as sandstone and limestone. Numerous transgressions and regressions of the sea have resulted in the interfingering of marine and nonmarine deposits.<sup>(9)</sup> The total thickness of these units ranges from a feather edge along the Fall Line to more than 7500 ft in southwestern Georgia.<sup>(8)</sup>

*Geologic structure in the Coastal Plain provinces within 200 miles of the site is relatively simple. There are no known features affecting material younger than Miocene. The structural features of the region are discussed in paragraph 2.5.1.1.6, Regional Tectonic Structures.*

#### **2.5.1.1.4 Regional Geologic History (HNP-1 and HNP-2)**

*The geologic history of the region is characterized by mountain building and erosion in the Appalachian areas and by deposition of marine and nonmarine sediments in the Coastal Plain provinces.<sup>(1)</sup>*

*During the Precambrian and early Paleozoic, a large sedimentary basin, the Appalachian geosyncline, extended along the eastern portion of the United States.<sup>(3)</sup> Subsidence within the geosyncline allowed great thicknesses of sediments to collect. In the middle and late Paleozoic, this basin sustained mountain-building forces that metamorphosed portions of the early Paleozoic and older sediments, injected plutonic masses into them, and raised them by folding and faulting. The metamorphosed area includes the Piedmont and Blue Ridge provinces.<sup>(1)</sup>*

*In the Triassic, the eastern Appalachian provinces were again faulted and injected with northwest trending diabase dikes. Terrigenous deposition occurred in northeast trending, graben-like basins.<sup>(3)</sup> Erosion of the Appalachian areas marginal to the present coastlines continued until the Cretaceous.<sup>(1)</sup>*

*Deposition of marine and nonmarine sediments in the coastal plain areas began in the Cretaceous.<sup>(1)</sup> The sediments were deposited in seas that originally invaded the margin of the continent up to the Fall Line.<sup>(9)</sup> During the Cretaceous, several rivers draining the Appalachian Highlands contributed vast amounts of material to the slowly subsiding continental margin.<sup>(1)</sup> After the Late Cretaceous, the seas began a persistent, although irregular, retreat with progressively younger marine and marginal marine sediments being deposited on older strata in belts generally parallel to the present coastline. As a result, a seaward-thickening wedge of coastal plain sediments was built up.<sup>(9)</sup> Cenozoic deposition of uniform thicknesses of material was probably modified by submarine erosion and intermittent, slow growth of fold structures in southern Georgia and Florida.<sup>(1)</sup> Material in the coastal areas younger than Miocene appears to be unaffected by geologic structures.*

#### **2.5.1.1.5 Regional Geologic Conditions (HNP-1 and HNP-2)**

*The geologic conditions of the coastal plain within 200 miles of the site are related to the rate of subsidence of the buried Paleozoic fold belts during deposition of the coastal plain sediments and the source and lithology of the coastal plain deposits. The coastal plain begin to form after tilting and subsidence of the Appalachian Fold System. The truncated surface of this ancient system dips southward and southeastward beneath the coastal plain. Material eroded from the Paleozoic rocks was laid down in or on the margins of seas that overlapped inland from the Atlantic Ocean and Gulf of Mexico. Mesozoic and Cenozoic deposits that cover the Paleozoic surface dip and thicken toward the coast.<sup>(1)</sup> The regional subsurface conditions are shown in figures 2.5-5 and 2.5-6, Regional Geologic Profiles.*

##### Mesozoic Conditions

*The first coastal plain deposition within 200 miles of the site occurred in the Early Cretaceous when strata of the Comanche series were deposited. These materials have been identified in deep wells drilled*

*in seaward areas of Alabama and Georgia. They typically consist of red beds in updip areas and interbedded evaporites, shale, and carbonates downdip. No Lower Cretaceous deposits are exposed within the study area.<sup>(1)</sup>*

*Upper Cretaceous Gulf Series deposits overlying the Comanche Series include, in ascending order, the Tuscaloosa group, and the Eutaw, Blufftown, Cusseta, Ripley, and Providence Formations. These units underlie the coastal plain within 200 miles of the site and are exposed in southwestern Georgia and Alabama in belts seaward from the Fall Line. In addition, the Tuscaloosa group is exposed in central and eastern Georgia and South Carolina. The Tuscaloosa generally has a lower, terrigenous sand and gravel unit, a middle silt and clay sequence (mostly marine), and an upper terrigenous sand-to-gravel unit. The overlying formations are lithologically similar to the Tuscaloosa, but interfinger downdip with predominantly calcareous beds. Gulfian deposits rest in updip areas with angular unconformity on Comanchean and older strata, while in seaward areas the contact appears transitional.<sup>(1)</sup>*

*The preceding Mesozoic deposits were laid down during a time of transgression and submergence.<sup>(9)</sup> Numerous landward unconformities indicate that submergence was interrupted by sporadic emergence. Deposition of Cretaceous strata was centered in areas of subsidence (depocenters) adjacent to the Appalachian Fold Belt. Subsidence contemporaneous with deposition was necessary to contain the great thickness of sediments. One such basin, the Apalachicola embayment, is in southwestern Georgia and northern Florida and contains thin, near-surface Quaternary and Tertiary rocks overlying thick deposits of Cretaceous and older Mesozoic strata. This basin was subsiding and receiving coarse deposits from the adjacent uplifted highlands during the Early Cretaceous. As the Cretaceous sea spread inland over the eroded fold belts, Gulfian (Late Cretaceous) marine sediments were deposited in the embayment, while the coarser sediments were deposited inland. The thin layers of overlying Cenozoic material indicate that subsidence had ceased before their deposition. The pattern of deposition was further modified by positive features, such as the Peninsular Arch. This subsurface arch extends from southcentral Georgia into eastcentral Florida. Lower Cretaceous strata are absent on the apex of the arch and pinch out against the flanks, indicating that the feature was positive and possibly forming during the Jurassic and Early Cretaceous. Erosion of the Paleozoic core supplied coarse material to the basin on the western flank of the arch during the Early Cretaceous. Development of the arch apparently had ceased by the Late Cretaceous, since Gulfian marine deposits are found undeformed on the arch.<sup>(1)</sup>*

#### Cenozoic Conditions

*The Paleocene is represented by the Clayton formation of the Midway group. The Clayton is predominantly limestone and sandy marl in eastern Alabama and western Georgia. In Florida, Midway strata are characterized by limestones, oolitic beds, and evaporites of the Cedar Keys Formation.<sup>(1)</sup> In South Carolina, Paleocene strata are represented by undifferentiated Midwayan clay and sand beds.<sup>(10)</sup> Midway beds in the area of study lie unconformably on Cretaceous strata. The Midwayan strata were probably deposited in near-shore and shallow-marine environments. Locally, Paleocene strata lack considerable thickness or are absent, owing to erosion or nondeposition or both.<sup>(1)</sup>*

*Eocene strata, exposed in belts seaward of Cretaceous formations, lie disconformably on Paleocene and older deposits in both the Atlantic and Gulf Coast areas. (See figure 2.5-2.) The Eocene is represented by, in ascending order, the Wilcox, Claiborne, and Jackson groups.*

*Undifferentiated lower Eocene Wilcox deposits contain sandy material in updip areas and become finer-grained, more calcareous, and generally more marine seaward in the subsurface. Deposition probably occurred in deltaic, marginal marine, and shallow marine areas.<sup>(1)</sup>*

*Middle Eocene Claiborne Group deposits rest disconformably on the Wilcox Group. The Claiborne Group is represented by the Tallahatta and Lisbon Formations in southeastern Alabama and Georgia.<sup>(1)</sup> Equivalent strata are the Congaree and McBean Formations in South Carolina,<sup>(10)</sup> and the Lake City and Avon Park limestones in northern Florida. The Tallahatta generally contains unconsolidated sand and lignitic, calcareous, and micaceous silty clay and limestone. The overlying Lisbon Formation consists of fossiliferous clay, marl, and calcareous sand. Claiborne sediments were deposited in warm, shallow seas.<sup>(1)</sup>*

*The upper Eocene is represented by the Ocala Formation (and equivalents) of the Jackson Group. In downdip areas and in the subsurface, the Ocala is a highly fossiliferous, calcareous clay and limestone. Updip exposures are typically a deeply weathered sandy clay. Jackson Group deposits represent an extensive marine invasion of the continental margin in the late Eocene.<sup>(1)</sup>*

*Undifferentiated Oligocene deposits are mainly limestone and marl, with some calcareous clay and dolomite.<sup>(1)</sup> The discontinuous outcrop pattern of Oligocene material, especially in western Georgia, is the result of solution of the calcareous strata.<sup>(11)</sup> The Oligocene Formations were deposited in a warm, shallow marine environment.<sup>(1)</sup>*

*Miocene deposits in the coastal plain include shallow marine and nonmarine rocks of the Tampa, Alum Bluff, and Choctawhatchee stages. The basal stage (Tampa) in Georgia and northern Florida is a series of dolomitic limestones interbedded with clays and sands in updip areas.<sup>(12)</sup> This stage is represented at the site by the Tampa Formation. The middle and upper stages (Alum Bluff and Choctawhatchee) are predominantly clastics, consisting of sandy micaceous clays and arkosic sands,<sup>(8)</sup> and include the Hawthorn Formation at the site.*

*Sand and gravel deposits generally recognized as Pliocene occur near the Apalachicola River in northern Florida. Material identified as Miocene in Georgia and South Carolina, including the Hawthorn Formation, may be of Pliocene age. (This material is referred to as "Neogene Undifferentiated" by the Georgia Geological Survey). Other possible Pliocene material includes marl in downdip areas, and river terrace deposits along stream valleys.<sup>(1)</sup>*

*Pleistocene deposits along the coast consist of nonmarine, marginal, and marine sands and clays underlying seaward coastal terraces of terrace surfaces. They merge inland along the major river valleys with fluvial deposits.<sup>(1)</sup>*

*Cyclic advances and retreats of the sea determined depositional patterns in the Tertiary following a period of erosion at the end of the Cretaceous. During the Paleocene, Midway sediments were deposited to within 50 miles of the Fall Line over the eroded Cretaceous deposits. Erosion then resulted from a general lowering of sea level. This pattern of transgression and deposition, followed by regression and erosion, was repeated throughout the Tertiary. Each succeeding stage encroached inland to a lesser extent over the eroded remains of the previous stage.<sup>(9)</sup>*

*Various structural features modified Tertiary depositional patterns. From the Eocene into the Miocene, materials were thinly deposited and slightly folded in the area of the rising Ocala uplift. Accumulation of*

great thicknesses of Miocene and earlier materials took place in negative areas, such as the Apalachicola embayment. The present outcrop pattern reflects the minor influence of these structural features on Tertiary deposition.<sup>(1)</sup>

#### 2.5.1.1.6 Regional Tectonic Structures (HNP-1 and HNP-2)

Rocks in the Blue Ridge and Piedmont tectonic provinces within 200 miles of the site have been faulted and folded to varying degrees. Major deformation of these rocks occurred prior to the Mesozoic, although there is evidence for Triassic displacement of Piedmont rocks. By contrast, the Cenozoic coastal plain sediments within 200 miles of the site are not displaced by major faults.

The major structures within the Blue Ridge and Piedmont provinces are the Brevard, Towaliga, and Goat Rock Fault Zones. (See figure 2.5-3.) These fault zones extend from the Fall Line in Alabama northeast and eastward into Georgia. The Brevard Zone, more than 180 miles northwest of the site, follows a relatively straight trace through Georgia, South Carolina, and into North Carolina.<sup>(38)</sup> This fault marks the boundary between the Blue Ridge province to the northwest and the Piedmont province to the southeast. Fault planes within the zone dip steeply to the southeast. It has been variously interpreted as a right-lateral strike-slip fault with at least 135 miles of displacement,<sup>(39)</sup> a major fold complicated by trough faulting,<sup>(40)</sup> a zone of simultaneous thrusting and left-lateral strike-slip movement with less than 10 miles of displacement,<sup>(38)</sup> and the sole of a great overthrust.<sup>(5)</sup> The Towaliga and Goat Rock Fault Zones form the northwest and southeast sides, respectively, of the Kings Mountain Belt in Alabama and western Georgia. The northern portion of the Towaliga Zone also forms the northwest boundary of the Charlotte Belt in eastern Georgia. Movement along the Towaliga Fault Zone, which is more than 125 miles northwest of the site, has been variously interpreted as strike-slip with a minor dip-slip component;<sup>(41)</sup> high-angle thrusting toward the southeast;<sup>(4)</sup> and northwestward relative displacement along the sole of an overthrust.<sup>(5)</sup> Fault planes within the zone dip steeply to the northwest.

The Goat Rock Fault Zone is exposed in the Piedmont province more than 100 miles north of the site. The fault zone has been mapped northwestward from the Coastal Plain - Piedmont border near Salem, Alabama, into western Jones County, central Georgia. In western Georgia, the fault zone is the intensely sheared portion of the Uchee Block<sup>(55)</sup> and forms the southern boundary of the Pine Mountain series.<sup>(63)</sup> The main fault zone is ultramylonite, mylonite, and blastomylonite bordered on each side by mylonite gneisses.<sup>(43)(54)</sup> Based on the presence of discontinuous shear zones and regional magnetic characteristics and lineaments, various workers have proposed to extend the fault zone beyond central Georgia as far as the vicinity of Columbia, South Carolina. (See references 4, 42, 44, 46, 50, 53, 54, 57, 60, 61, 62, 68, 70, and 72.) Total length of the mapped and proposed portions of the fault zone is ~ 250 miles. The Geologic Map of Georgia acknowledges the presence of northeast-trending shear zones up to 10 miles long in east-central Georgia, but does not indicate a continuous fault trace northeastward beyond central Georgia.<sup>(82)</sup> Two of the shear zones are coincident with proposed splays off an extended Goat Rock Fault Zone in east-central Georgia termed the Flat Rock and Morton Fault Zones.<sup>(45)</sup> A zone of cataclastic rock forming the boundary between the Kiokee and Carolina Slate Belts northeast of Columbia, South Carolina, has been attributed to another proposed extension of the Goat Rock Fault Zone terminating near Laurinburg, North Carolina.<sup>(56)</sup> The sense and magnitude of displacement of these shear zones has not been reported. Recent speculation based on magnetic data extends the Goat Rock Fault into Virginia.<sup>(74)</sup>

The width of the fault zone is nearly 10 miles in Alabama and adjacent parts of Georgia.<sup>(5)</sup> The proposed extension in South Carolina is believed to be 2 miles wide (oral communication, D. E. Howell). Some workers contend that the Goat Rock Fault Zone is the southern boundary of a folded thrust sheet which is bounded on the northern edge by the Brevard Fault. (See references 5, 48, 52, and 77.) The amount of displacement is not known. Dip of the fault in west-central Georgia is 10° to 50° southeast.<sup>(43)(44)(55)</sup> The reported type of displacement includes thrusting,<sup>(5)(48)(54)</sup> and right lateral strike-slip.<sup>(43)</sup> A mapped high-angle fault, trending southwestward from Columbia, South Carolina, into Georgia,<sup>(42)</sup> has been associated with the Goat Rock Fault Zone. However, the dip of that fault plane (northwestward) and sense of displacement (normal) is opposite to the dip and displacement of mapped portions of the Goat Rock Fault in eastern Alabama and western Georgia. (See references 5, 43, 44, 48, 54, and 55.)

Apparently, the Goat Rock Fault Zone is one of many structures created during the collision of southeastern North America and Africa between Late Devonian and Permian time.<sup>(4)</sup> Potassium/argon dates for rock from the Goat Rock Fault Zone give an approximate 300-million year (Early Mississippian) age for the time of major fault movement.<sup>(69)</sup> An upper time limit for surface displacement on the Goat Rock Fault Zone can be established as pre-Cretaceous. Near Salem, Alabama, and Columbia, South Carolina, undeformed Cretaceous sediments of the Coastal Plain cover the fault zone.<sup>(54)(68)</sup> Several diabase dikes are mapped across the trace of the Goat Rock Fault Zone and show no offset.<sup>(47)(59)</sup> The diabase dikes are part of a large dike system which extends from Alabama to Massachusetts.<sup>(58)</sup> The dikes are Late Triassic<sup>(58)</sup> or Jurassic,<sup>(49)</sup> the age of the dikes being determined by stratigraphic and paleomagnetic methods, respectively, by these workers.

Historic epicenter location maps for eastern Alabama and most of Georgia show no geographical distribution of events which suggests the Goat Rock Fault Zone is active in these areas.<sup>(36)(37)(51)</sup> The Goat Rock Fault obliquely crosses the "South Carolina-Georgia Seismic Zone" in which two-thirds of all historic activity in the southeastern United States has occurred.<sup>(37)(67)</sup>

The number of reported seismic events in South Carolina has increased significantly in recent years. This is due to increased instrumentation in this region, and the increase of detection capability this implies. Consequently, the increase in the number of recorded events is due to the detection of small events that previously went undetected, and not to an overall increase in seismicity. This contention is supported by cumulative strain release and cumulative frequency of occurrence for events of Modified Mercalli IV or greater over the time intervals 1776-1973 and 1872-1974, respectively, in the southeastern United States.

If the Charleston event of 1886 is assigned a maximum Modified Mercalli intensity of X, then ~ 5000 times more energy was released during this event than all other known events in the southeastern United States during the 1776 to 1973 period. Approximately 85% of all remaining strain released during this period occurred during the years 1905 through 1916. Therefore, the strain release pattern is dominated by a few large events which occurred more than 60 years ago. No increase in the rate of occurrence of these events is evident. The frequency of occurrence of events from the above data set between 1957 and 1974 is comparable to a period between 1911 and 1930. Between these two time periods, there is a definite lull in recorded activity. A similar lull in the frequency of events occurred between 1911 and the swarm of events associated with the 1886 Charleston events. Therefore, historic data does not suggest that the southeastern United States is in or is entering a period of unusual seismic activity in either a qualitative or quantitative sense.

Several recent studies have linked recent and historical seismicity to the eastern extension of the Goat Rock Fault in South Carolina. (See references 63, 65, 66, and 68.) In the absence of corroborative

evidence such as focal mechanism solutions, any seismic implications of this fault's activity must depend on some observed alignment of epicenters. This type of evidence is the sole basis for proposing current activity along the Goat Rock Fault. In particular, the 8 epicenters listed in table 2.5-3 and shown in figure 2.5-15 are proposed by Talwani<sup>(66)</sup> to occur along the Goat Rock Fault. An indication of the method of epicentral determination is also included in table 2.5-3. An S indicates that the epicenter is derived from an isoseismal map, while an F implies that felt data is the only source of an epicentral location. An I implies that some instrumental location was computed.

There are several reasons to doubt a simple interpretation of the apparent alignment as given by Talwani.<sup>(66)</sup> The uncertainty in locating individual, small epicenters makes their extremely close alignment probably fortuitous. In figure 2.5-15, a coordinate system is superposed on the epicentral locations of the 8 events as given by Talwani.<sup>(66)</sup> The orientation and scale of this coordinate system are such that the data may be treated as univariant and Gaussian with a zero mean and a standard deviation of  $\pm 8$  km. That is, it was assumed that the fault trace is the true location for all the events of table 2.5-3; however, due to univariant Gaussian measurement noise, the events do not appear to fall on this line. The assigned standard deviation of  $\pm 8$  km is believed to be a conservatively small average value for these epicenter locations. Under these conditions, the error criterion defined to be the sum of the squares of the residuals may be shown to be a chi-square variable with 6 degrees of freedom.<sup>(75)</sup> The best fit for the data using the least squares method is also shown in figure 2.5-15. The sum of the squares of the residuals of each individual epicenter from the least square regression line is 0.218 compared to an expected error criterion value of 6.<sup>(71)</sup> The probability of the error criterion value, 0.218, occurring under the above assumptions is  $< 2$  in 10,000. It is concluded that either the average standard deviation given above is too large or that the striking coincidence of these eight epicenters with the trace of the Goat Rock Fault is fortuitous.

There are also questions as to the pertinence of assigning several of the epicenters to a NE to SW trending structure. Two of the events, January 4, 1974, and December 8, 1974, of table 2.5-3 and figure 2.5-15, are so small (magnitude  $\leq 1$ ) that it is unnecessary to associate them with any structure. Furthermore, both NW to SE and NE to SW structural trends occur in the area of the January 4, 1974, epicenter<sup>(73)</sup> so that it is not clear with which trend, if any, this event is best associated. In the case of the 1879 event, there is disagreement about its actual location. All sources found<sup>(76)(78)(79)</sup> place this event 25 to 50 km north of the position shown in figure 2.5-15 as derived from Talwani. (See figure 2.5-16.)

Figure 2.5-16 and table 2.5-4 show that the historical seismicity of South Carolina has been rather diffuse with the exception of the Charleston area events which are listed in table 2.5-5. This conclusion is not altered by recent detailed work of the United States Geological Survey (USGS)-USC seismic network.<sup>(80)</sup> Lineations anywhere in the state are at best poorly supported by epicenter location data. In view of all these difficulties, it is not reasonable to consider the Goat Rock Fault seismically active in any but a speculative sense.

Sediments of the Atlantic and East Gulf provinces are only slightly modified by post-Paleozoic structural movements. The significant tectonic structures underlying the coastal plain region within 200 miles of the site include the Peninsular arch, Ocala uplift, Apalachicola embayment, and Southeast Georgia embayment. Several structures of questionable existence or having only minor effects may also underlie coastal plain deposits. Development of all the above listed structural features ceased before the Pleistocene, and none is considered significant to the site.<sup>(1)</sup>

*The relationship of these structures to the geologic history of the area is discussed in paragraph 2.5.1.1.5, Regional Geologic Conditions. A regional tectonic map is presented in figure 2.5-3. The possibility of uplift, subsidence, or collapse related to tectonic structures is discussed in paragraph 2.5.1.1.6.2, Areas of Potential Instability.*

*Since issuance of the construction permit in December, 1972, investigations of the geology, seismology, and tectonics within 200 miles of the site have focused on 3 main areas:*

- *Charleston, South Carolina.*
- *The Upper and Middle Coastal Plains in South Carolina and eastern Georgia.*
- *The Piedmont of South Carolina, Georgia, and Alabama.*

*The primary methods of investigations have been remote sensing, geophysical and earthquake monitoring, supplemented by surface reconnaissance and borings. The investigations have suggested preliminary correlation between seismic events and known geologic structures, and have inferred the existence of previously unrecognized structures in the Coastal Plain and Piedmont provinces. Data from the investigations have also been synthesized into regional studies of seismology and tectonics.*

*A. Charleston, South Carolina*

*Recent studies in the Charleston area have attempted to define the local crustal structure and basement configuration. Seismic refraction was used by Ackerman<sup>(83)</sup> to detect three subsurface marker horizons. Two horizons, at depths of 100 m and 850 m, are depressed in the area of maximum destruction from the 1886 earthquake. A velocity range of 4.5 to 5.6 km/s in the shallow basement Cretaceous volcanics below the 850 m horizon is interpreted to indicate a zone of extensive fracturing or a major lithology change. A third horizon, marking the base of the Cretaceous volcanics, dips steeply to the southeast at 70 m/km. The shallow basement layer is thus interpreted to be wedge-shaped, thickening southeastward.<sup>(83)</sup>*

*Depth analyses of aeromagnetic profiles in the Charleston area also suggest the presence of at least two magnetic basement surfaces.<sup>(84)</sup> The uppermost surface, at a depth of about 3000 ft (900 m), may correspond with Cretaceous basalt found in a core hole northwest of Charleston by Gohn, *et al.*,<sup>(85)</sup> at a depth of 750 m, and with the shallow basement of Ackerman<sup>(83)</sup> at 850 m. At depths > 3000 ft (900 m), the aeromagnetic profiles indicate that a second magnetic horizon, possibly corresponding to crystalline basement, may be broken by east-trending faults. The magnitude of vertical displacement is thought to be on the order of 1000 ft (300 m). A third magnetic source at depths greater than 10,000 ft (3050 m) may correspond with deep-seated intrusives.<sup>(84)</sup> Circular aeromagnetic and gravity anomalies in the same area have also been attributed to deep mafic intrusives.<sup>(86)</sup>*

*Resistivity and magnetotelluric (AMT) soundings conducted by Campbell<sup>(87)</sup> in the Charleston region failed to detect the Cretaceous basalt found by Gohn, *et al.*,<sup>(85)</sup> at 750 m. The basalt is consequently estimated to be < 75 m thick. Electric basement in the vicinity of the core hole, which bottomed at 792 m,<sup>(85)</sup> is ~ 1200 m below ground surface. The*



AMT data outline a northeast-trending, 11-km wide, higher resistivity zone roughly corresponding to the region on highest damage from the 1886 earthquake. The zone is believed to be bordered on the northwest by a gravity lineament possibly representing a steeply dipping fault, with the southeast side downthrown.<sup>(87)</sup> However, resistivity soundings within the zone indicate shallower electric basement (900 m depth) than in areas outside the zone (1200 m depth). According to Campbell,<sup>(87)</sup> "If this basement represents a thicker interval of the same Cretaceous basalt encountered in the core hole, some 150 m of post-Cretaceous vertical displacement would be indicated along this (postulated) fault."

There appears to be a lack of agreement regarding details of subsurface structure determined from the above-described geophysical studies. Ackerman<sup>(83)</sup> suggests extensive fracturing within the Cretaceous volcanics, while Phillips<sup>(84)</sup> proposes displacement of the deeper crystalline basement. In the zone of maximum damage from the 1886 earthquake, Campbell<sup>(87)</sup> indicates that the Cretaceous basalt layer has been displaced upward. The same layer in the same area has been found to be depressed by Ackerman.<sup>(83)</sup> The geophysical data confirm the crustal complexity in the Charleston region, but do not provide adequate information to describe the subsurface structure. The following recent studies have also contributed significant information regarding the geology of the Charleston area:

1. Popenoe<sup>(86)</sup> and Popenoe, *et al.*,<sup>(88)</sup> describe preliminary information and conclusions obtained from gravity and aeromagnetic data, ERTS imagery, and borings. (See figures 2.5-17 and 2.5-18.) At least four major structural grains exist near Charleston, one of which (circular magnetic and gravity highs) is coincident with the epicenter of a 1974 earthquake (November 22,  $M_b = 4.7$ ). Two other grains are similar to Piedmont northwest and northeast structural trends. The dominant grain is east to west, reflected by gravity and aeromagnetic anomalies.<sup>(86)</sup> A preliminary contour map of the basement surface has been constructed based on these data.<sup>(88)</sup>
2. Higgins, *et al.*,<sup>(89)</sup> further define the Beaufort high southwest of Charleston, and speculate on the structural control of the Orangeburg scarp west of Charleston. Based on biostratigraphic interpretations, the Beaufort high is ~ 96 km long and 48 km wide, trending parallel to the coast to within 24 km of Charleston. Vertical closure is ~ 84 m on the Eocene-Oligocene contact. Faults have been proposed on the north and southeast sides,<sup>(89)</sup> although no age or sense of displacement is reported. Structural control of the Orangeburg scarp is suggested on the basis of magnetic anomalies, facies changes, ERTS lineaments, and drainage irregularities.<sup>(89)</sup>
3. Bollinger<sup>(90)</sup> confirms an intensity X (MM) for the epicentral region and IX for Charleston resulting from the 1886 earthquake. He estimates the body-wave magnitude from the event as 6.8, based on central United States data, and 7.1 based on western United States data.<sup>(90)</sup> An epicentral intensity X (MM) was assumed for the Hatch site in determining the safe shutdown earthquake. (See paragraph 2.5.2.9.)
4. Tarr and Carver<sup>(80)</sup> report that current seismic activity near Charleston is centered near Middleton Gardens, about 22 km northwest of Charleston. The

November 22, 1974, earthquake ( $M_b = 4.7$ ) had its epicenter near Middleton Gardens at a computed depth of 12 km. They report: "The focal mechanism of the November 22 earthquake is consistent with either reverse faulting on a plane dipping  $78^\circ$  SW or thrust faulting on a plane dipping  $12^\circ$  NE; both planes strike  $N 42^\circ W$ ."

5. Long<sup>(91)</sup> has proposed a model for earthquake generation in the Charleston-Summerville area. His model requires that two crustal blocks are in contact, that the boundary between the blocks is irregular, and that one of the blocks is characterized by a linear crustal velocity structure which contains rocks having a higher rigidity than surrounding crustal rocks. He contends that his configuration could amplify regional stresses to the extent that earthquakes could occur. Gravity and seismic data indicate that such a linear structure exists in the Charleston area and intersects a zone of gravity anomalies.<sup>(91)</sup> The intersection is interpreted as a boundary between crustal blocks. The zone of gravity anomalies has been attributed to deep mafic intrusions possibly comprising a body of higher rigidity. Long's model remains speculative, however, since the existence of the required features and configuration is still unproven.

#### B. Upper and Middle Coastal Plains

The following recent investigations have been conducted in the Upper and Middle Coastal Plain areas of eastern Georgia and South Carolina.

1. Early Tertiary to Pleistocene or later movement has been proposed along the Belair Fault Zone near Augusta, Georgia.<sup>(62)(92)(93)</sup> Weathered phyllites of Precambrian(?) age have been thrust over sediments of possible early Tertiary age. The fault zone consists of a 12-mile long series of echelon breaks which individually trend  $\sim N 25^\circ E$ . The control points indicate vertical separation of 100 ft at the northern end of the zone. About 15 ft of separation at the southern end has occurred along fault planes dipping  $\sim 50^\circ SE$ . Deformed carbon-bearing material within the fault zone yields a radiometric age of  $< 2500$  years before present. However, the lack of an adequate sample size and other factors may have biased the age determination.<sup>(92)</sup> The rate and characteristics of movement along the faults remain uncertain. Movement may have been by creep and not necessarily accompanied by earthquake activity.<sup>(92)</sup> No historical seismic activity has occurred along the fault zone. There is no surface indication of the fault trace visible on aerial photographs.<sup>(a)</sup> The known southern extent of the fault zone is more than 100 miles north of the site.
2. Several deformation features in the central part of the Upper Coastal Plain of South Carolina have been attributed to tectonic activity.<sup>(94)</sup>

Deformation in sediments of the upper Coastal Plain of South Carolina was examined by USGS personnel. The deformation features were reported by Owens, Prowell, and Higgins of the USGS at a Geological Society of America (GSA) meeting held in Reston, Virginia, in 1976. No written report has been prepared, so only the abstract for that GSA presentation is currently available.

*The Upper Coastal Plain of South Carolina, as used in the abstract cited, refers to the area of the South Carolina Coastal Plain between McBean, Georgia, and Sumter, South Carolina. The deformations occur in sediments of the Cretaceous Middendorf Formation and in sediments of the Eocene McBean Formation and were seen where these formations are at the ground surface near the Fall Line. The features are briefly described in the abstract for the GSA presentation as follows: "Four categories of deformation were recognized: (1) intricately contorted and faulted interbedded clays and sands; (2) open folds in sandy clays; (3) disconnected slabs of clayey sand, underlain and separated by cleaner sands that have disrupted bedding; (4) domes and detached teardrop-shaped bodies of opal claystone that have sediments draped over and around them." (Owens, *et al.*). These workers hypothesize that at least some of the features were earthquake caused and may represent quake sheet deformation at a time when the sediments were still soft.*

*Some of the structures examined by Owens, *et al.*, were seen to be overlain by undisturbed flat-lying sedimentary deposits of similar sedimentary character to the deformed strata (Prowell, personal communication). This condition implies that the time of deformation is contemporaneous with deposition, that is, Eocene time or 35 million years before the present. Dr. Prowell also pointed out that the relationship of undeformed sediments overlying the deformation features was not found at all locations.*

*The tectonic mechanisms proposed are folding or faulting, and earthquake-induced liquefaction, slumping, and diapirism. The location of possibly causative faults has not been reported. The features are within sediments of Upper Cretaceous through Eocene ages. No age of deformation has been assigned to the features. Although liquefaction is a postulated mechanism, laboratory determinations of grain size distribution were not conducted on the sands thought to be susceptible to liquefaction (B. B. Higgins, personal communication). Deformation in several Upper Coastal Plain localities had been previously attributed to slumping associated with solution of underlying material.<sup>(94)</sup> The geologic evidence could support either a tectonic or nontectonic mechanism for generation of the features.*

3. *Marine<sup>(95)</sup> has further defined the buried Dunbarton Triassic basin. The basin is ~ 20 miles southeast of the Fall Line on the South Carolina-Georgia border, buried beneath 1150 ft of Coastal Plain sediments. Although seismic reflection, gravity, and magnetic surveys have indicated fault displacement on both the top and bottom of the basin, drilling evidence indicates no such displacement at the top of the Triassic sediments. No fault movement has occurred since development of the erosion surface on the top of the Triassic, about 100 million years ago.<sup>(95)</sup>*

#### C. Piedmont

*Geophysical surveys have recently been conducted in the Piedmont province of Alabama, Georgia, and South Carolina. Aeromagnetic and aeroradioactivity maps of Alabama*

---

a. O'Conner, oral presentation, March 1976.

delineate the known major lithologies and fault zones. (See references 70, 96, 97, and 98.) The geophysical maps have supplemented extensive surface mapping of the Alabama Piedmont.<sup>(99)</sup> The Goat Rock, Bartletts Ferry, Towaliga, and Brevard Fault Zones are marked by strong contrasts in magnetic lineaments. A major subsurface fault zone based on strong, N 75°E-to-N 80°E-trending lineaments has been proposed to exist beneath Coastal Plain sediments south of the Goat Rock and Towaliga faults.<sup>(46)</sup> Age, sense, and magnitude of possible displacement have not been reported for this proposed fault zone.

Aeromagnetic maps of the Georgia Piedmont show at least five postulated fault zones.<sup>(45)</sup> The proposed Indian Springs Fault Zone is a northeast trending splay off the Towaliga Fault Zone coincident with a thick zone of cataclastic rocks near Indian Springs, Georgia. A similar cataclastic zone marks the Flat Rock Fault Zone, a splay off the Goat Rock Fault Zone. Two other geophysically-inferred fault zones, the Macon and Key Creek, may be continuous with known fault zones in South Carolina. The Morton Fault Zone is proposed as a splay off the Goat Rock Zone between the Macon and Flat Rock Zones. Structural discontinuities or cataclastic rocks coincident with these zones have been verified by field investigations.<sup>(45)</sup> The characteristics of postulated fault movement have not been reported. New fault zones and extensions of existing zones in the Georgia Piedmont are also indicated by aeroradioactivity mapping,<sup>(100)</sup> although fault characteristics are unreported.

Aeromagnetic and gravity surveys indicate possible extensions of the Towaliga and Goat Rock Fault Zones into South Carolina which is further than previously suspected. The Towaliga Fault Zone is coincident with a zone of cataclastic rocks marking the contact between the Kings Mountain and Charlotte belts. Historic and recent seismic activity has been attributed to this zone.<sup>(68)</sup> The Towaliga is proposed to extend into North Carolina near Gastonia.<sup>(100)</sup> The Goat Rock Fault Zone, previously discussed, is proposed to extend northwestward through South Carolina to the vicinity of Laurinburg, North Carolina. The fault zone is marked by a zone of cataclastic rock between the Kiokee and Carolina Slate belts.<sup>(56)</sup> Earthquake activity was cited to propose an extension of the Goat Rock Zone under Coastal Plain sediments north of Columbia, South Carolina.<sup>(65)(68)</sup> Extension of the Goat Rock Fault Zone is generally preliminary and speculative, and in some cases contradicts known features of the mapped portion of the fault zone in Alabama and Georgia. Paragraph 2.5.1.1.6 provides a detailed discussion of the Great Rock Fault Zone.

Aftershock monitoring near the Clark Hill Reservoir north of Augusta, Georgia, indicates seismic activity is confined to the upper 5 km of the crust.<sup>(101)</sup> The majority of the fault plane solutions suggest left lateral strike-slip motion along a strike of N 40° E and a dip of 82° SE; remaining data indicate overthrusting, with the fault plane striking N 34° E and dipping 70° SE. The earthquakes have occurred in the immediate vicinity of Clark Hill Reservoir, and have been attributed by Talwani to fluctuations in the reservoir water level.<sup>(65)(66)</sup>

#### D. Regional Studies

Bollinger<sup>(102)</sup> has further investigated the spatial and temporal distribution of earthquakes in the southeastern United States. The data suggest that "strain development induced by

*crustal uplifting but concentrated by old Appalachian structures may be the proximate cause of the recent seismicity in the southeastern United States."*<sup>(102)</sup>

*Aeromagnetic surveys in the Coastal Plains of North Carolina, South Carolina, Georgia, and Alabama, show the contrast between magnetic basement beneath the Coastal Plain and the exposed crystalline Piedmont. Gravity and magnetic highs of the Coastal Plain basement have been attributed to gabbroic-basaltic terrain containing mafic plutons or volcanic centers; gravity highs and magnetic lows of the Piedmont are coincident with metavolcanic terrains. Major crustal differences between Piedmont and Coastal Plains basements are further shown by nonmatching magnetic trends.<sup>(103)</sup> The Triassic basins underlying the Coastal Plain have been extended to form a continuous series based on geophysical data,<sup>(68)</sup> the continuous basins have not been delineated by drilling.*

#### **2.5.1.1.6.1 Description of Coastal Plain Structures (HNP-1 and HNP-2)**

##### **A. Peninsular Arch**

*The Peninsular arch is a buried arch-like fold trending northwesterly from east-central Florida into south-central Georgia. Early Paleozoic strata make up the core of the arch. They are flanked by Lower Cretaceous and possibly Jurassic deposits. Lower Cretaceous strata are absent on the apex of the arch, indicating that the feature was positive and possibly forming during the Jurassic and Early Cretaceous. The arch was apparently inactive and covered by seas during and after the Late Cretaceous, since Gulfian and younger deposits are found over the arch.<sup>(1)</sup> The northern end of the buried Peninsular arch is ~ 85 miles southwest of the site. Material at the site is not affected by the arch.*

##### **B. Ocala Uplift**

*The Ocala uplift is a broad, northwest-trending anticline with its axis west of the older Peninsular arch. The two folds are apparently unrelated, since they affect material of different ages. The uplift is reflected at the surface by a broad outcrop of Ocala limestone.<sup>(1)</sup>*

*Undeformed late Miocene beds overlie upwarped beds of earlier Miocene and Eocene ages in the southern part of the uplift, indicating that development of the uplift may have begun in Eocene time and ceased before the end of the Miocene.<sup>(13)</sup> The Ocala uplift is over 150 miles southwest of the site. The uplift does not affect site material.*

##### **C. Apalachicola Embayment**

*The Apalachicola embayment is located in southwestern Georgia and northern Florida.<sup>(11)</sup> It is a relatively shallow basin or syncline representing a change in strike of coastal plain strata from predominantly east-west in eastern Alabama to ~ north-south in southwestern Georgia and northern Florida. The embayment narrows in the northeast; its axis is generally aligned northeast-southwest.<sup>(1)</sup>*

*Magnitude of the basin increases with depth, thereby indicating a long and continued development. Near-surface late Tertiary rocks are scarcely downwarped while Cretaceous and earlier Mesozoic strata are downwarped to a progressively greater extent. Correspondingly, the older strata are generally thicker.<sup>(1)</sup>*

*The basin area contains early Paleozoic flat-lying unmetamorphosed sediments that apparently were not involved in the severe folding of the Appalachian orogenic belt. These sediments are overlain by early and middle Mesozoic red beds, which are in turn covered by later Cretaceous marine deposits. The presence of shallow marine sediments throughout the Tertiary and the lack of faulting in the basin indicate that the area is relatively stable at present.<sup>(1)</sup> The northeastern edge of the basin is 125 miles southwest of the site. Material at the site is not affected by the basin.*

D. *Southeast Georgia Embayment*

*The Southeast Georgia embayment is a depositional basin recessed into the Atlantic Coast between Savannah, Georgia and Jacksonville, Florida. It is primarily a tectonically passive feature between the uplifted Cape Fear arch to the north and the Peninsular arch to the south.<sup>(14)</sup> The basin received relatively thick sequences of Cretaceous through Miocene material from the adjacent positive areas.<sup>(1)</sup> Post-Miocene material is undeformed in the embayment and has a uniform thickness with areas to the south and north. The base of Miocene material in northwest-southeast cross-section through the site (figure 2.5-5) is nearly flat,<sup>(14)</sup> indicating that relative subsidence of the basin (or uplift of the adjacent arches) had ceased by Miocene time. The uniform elevations of Pleistocene marine terrace features in the area of the embayment also indicate a long, continued tectonic stability.<sup>(15)</sup> The site is about 11 miles west of the landward edge of the Southeast Georgia embayment.*

*Other major and minor structural features have been proposed or identified on the coastal plain area within 200 miles of the site and are shown in figure 2.5-3. These features are the Chattahoochee anticline, Gordon anticline, Andersonville fault, Gulf trough, Ochlockonee fault, and Barwick arch. None of these features is of any significance to the site.*

*According to Patterson and Herrick (1971),<sup>(11)</sup> the Chattahoochee anticline was first postulated by Veatch in 1911. It reportedly extends from the Fall Line to the Florida state line and straddles the Chattahoochee River. Veatch's proposition was based on the north-south alignment of the Chattahoochee River along the axial part of the postulated anticline, and the entrenchment of that river.<sup>(11)</sup> Other authors (Stephenson, 1928, and Toulmin, 1955)<sup>(9)(16)</sup> show a similar position for the anticline. Sever (1964)<sup>(17)</sup> shows the anticline trending northeast for about 225 miles from Panama City, Florida, into central Georgia. This position was based on mapped outcrops of Eocene rock flanked on the northwest and southeast by Oligocene rock in the Georgia coastal plain.*

*An evaluation of the evidence supporting the existence of the Chattahoochee anticline (Patterson and Herrick, 1971)<sup>(11)</sup> indicates that the existence of the anticline is little more than speculation. The evaluation found that:*

*...most published reports in which structural features are proposed in the area of concern fail to spell out supporting evidence in a convincing manner. Many articles simply*

illustrate the axis of an anticline on a small-scale map and mention the feature by formal name in the text. Most of the questionable evidence in support of the Chattahoochee anticline was outlined by Veatch (1911) in his original proposal, and by Sever (1964) in his redefinition. The results of several investigations, both published and unpublished, are in opposition to the ideas advanced by Veatch and Sever....His (Veatch's) ideas regarding this anticline are suspect for the following reasons: 1. The course of the Chattahoochee River is nowhere diverted as it should be, if it were influenced by an uplift, and the proposed axial position of this river is an unlikely one; 2. The entrenchment of the river is not sound evidence for an anticline along it, because similar entrenchment has been noted further west in Alabama where it is attributed to regional uplift in Pliocene time.....(Patterson and Herrick, 1971, p. 3-5).<sup>(11)</sup>

Sever's proposition was disrupted because there is no evidence for the reversal of regional dip necessary for an anticline to occur and because the outcrop pattern (Eocene material surrounded by Oligocene material) is the result of topographic differences, with Oligocene material exposed at higher elevations than Eocene material.<sup>(11)</sup> Furthermore, regional geologic profiles (Maher, 1965, Plate 7; Maher and Applin, 1968, Plate 5)<sup>(14)(18)</sup> show no reversal of regional dip in the vicinity of the Chattahoochee River. Accordingly, interpretations of the Chattahoochee anticline, without sufficient evidence, should be considered as no more than hypothetical.<sup>(11)</sup>

The Gordon anticline was initially defined by Hager in 1918 to be near Gordon, in southeast Alabama.<sup>(19)</sup> He described it as having a closure of 40 ft and an area of 10 sq mi about an east-west axis. Adams (1929) noted some irregularities of dip in outcrops along the Chattahoochee River near Gordon, but no well-defined structure.<sup>(20)</sup> Toulmin and La Moreaux (1963, Figure 4)<sup>(21)</sup> show a reversal of dip in the vicinity of Gordon on their geologic section. It appears that the Gordon anticline actually exists, but its influence is minor, and it does not affect the uppermost (Upper Eocene) beds. The anticline is over 165 miles southwest of the site and shows no influence on strata underlying the site.

An east-trending fault having a maximum vertical displacement of 100 ft and a length of ~ 5 miles was named the Andersonville fault by Zapp (1965).<sup>(22)</sup> The fault is located near Andersonville, Georgia, ~ 95 miles west of the site, and displaces middle Eocene Claiborne deposits but not the overlying upper Eocene Jackson deposits. It is not known whether the fault is normal or reverse, as the fault plane was not observed. Other minor structural irregularities in the same area have been attributed to underground solution of limestone in the near-surface Paleocene Midway Group and consequent irregular slumping of the overlying sediments. Although the fault passes westward into a monocline that dies out further west, the Andersonville fault may also be a solution feature.<sup>(22)</sup>

The name Gulf Trough of Georgia was proposed by Herrick and Vorhis (1963)<sup>(8)</sup> for a major linear structural feature of the subsurface in southwest Georgia. As first recognized by Applin and Applin in 1944,<sup>(23)</sup> this feature extends northeastward from the Gulf of Mexico, through the Tallahassee, Florida, area and into south-central Georgia. It has subsequently been recognized as a sediment-filled depression and termed Gulf Trough.<sup>(13)</sup> Various authors have described the Gulf trough as a graben, downfaulted embayment, syncline, faulted syncline, structural basin or depression, trough or channel, submarine valley or strait, and a solution valley.<sup>(11)</sup>

Arguments favoring faulting or graben faulting as the origin for the trough do not present convincing evidence of the existence of faulting and a downthrown central block.<sup>(11)</sup> Sever's (1966)<sup>(24)</sup> proposed Ochlockonee fault would be on the southeast side of such a central block. After reexamination of Sever's

data, however, Patterson and Herrick (1971)<sup>(11)</sup> conclude that there is no evidence to suggest that movement along a fracture had occurred. A thick elongate belt of Miocene sediments fills the trough, indicating the feature is a depression of major dimensions. It apparently merges with the Apalachicola embayment to the southwest and may have been an extension of the embayment during part of its history. The shape of the trough is indicative of a sediment-filled strait or marine valley formed by erosion.<sup>(11)</sup> The nearest approach of the postulated feature is 85 miles west of the site.

A related feature, the Barwick arch, was proposed by Sever (1966)<sup>(24)</sup> to lie ~ 9 miles southeast of his proposed Ochlockonee fault. The arch was based on contours drawn on the top of the subsurface Suwanee limestone of Oligocene age that show ~ 100 ft of closure. No oil or water wells in the vicinity of the arch penetrate through Oligocene rock, so little information is available to prove or disprove the existence of such a feature.

Sever's (1966) assertion, based on well data, that the Suwanee has a uniform thickness in the region, is therefore invalid.<sup>(11)</sup> One possibility is that the apparent reversal of regional dip from the arch northwestward into the adjacent Gulf trough is an initial dip resulting from deposition on the southeast side of a strait or marine valley. Structure contour maps of the top of the Oligocene in areas south of the arch show a buried karst topography having high areas of the same magnitude as Sever's Barwick arch. This indicates that carbonate solution also may have significantly modified the apparent dips in the vicinity of the arch. The Barwick arch can be explained as an erosional or solution feature rather than a tectonic structure.<sup>(11)</sup>

**2.5.1.1.6.2 Areas of Potential Instability (HNP-1 and HNP-2).** The East Gulf and Atlantic Coastal Plains within 200 miles of the site appear to be relatively stable. As seen on the crustal movement map (figure 2.5-7), the greatest uplift within the coastal plains is less than 5 mm/year. The map is based on measurements made over the past 100 years by the National Geodetic Survey. Much of it is based on interpolation between widely spaced lines of elevation that have been measured by geodetic field parties. The elevations are relative to each other and are referred to the 1929 Sea Level Datum. The site is located just inside the southern Appalachian uplift area. The uplift is regional in character and not associated with a specific tectonic feature.<sup>(25)</sup>

The major tectonic depressions within 200 miles of the site are the Apalachicola embayment. Both of these structures are discussed in paragraph 2.5.1.1.6.1, Description of Tectonic Features. No differential movement is shown in the area of these structures on the crustal movement map (figure 2.5-7) except for slight uplift in the northern part of the Southeast Georgia embayment. In the Apalachicola embayment, near-surface late Tertiary deposits are scarcely downwarped.<sup>(1)</sup> Material in the Southeast Georgia embayment shows no evidence of deformation since the Miocene.<sup>(14)</sup> The Apalachicola embayment and Southeast Georgia embayment are, therefore, considered stable at present.

Buried and surficial karst terrains exist in the areas of regional consideration. A buried karst surface has been developed on the Suwanee limestone of Oligocene age in south-central Georgia, southwest of the site.<sup>(24)</sup> Underlying the site, deeply buried Oligocene limestone is recalcitized, and does not contain cavities. The top of the limestone conforms with the regional dip of coastal plain strata without irregularities due to solution.<sup>(26)</sup> The Dougherty Plain northwest of the site displays a karst terrain. However, the Tifton Upland, adjacent to the site, shows no evidence of solution of underlying materials.<sup>(2)</sup> Solution of limestone and development of karst features are not significant to the safety of the site.



No petroleum producing areas are located within 200 miles of the site in South Carolina and Georgia.<sup>(27)</sup> Production of petroleum in Alabama is limited to areas in the central and western parts of the state underlain by Jurassic and Lower Cretaceous producing formations.<sup>(28)</sup> Production in Florida is similarly limited. These formations do not exist within 200 miles of the site. No other mineral extraction or subsurface mining occurs or has occurred in the site area.<sup>(29)</sup> Withdrawal of ground water from the area, discussed in paragraphs 2.4.13.2 and 2.4.13.2.5, will not cause subsidence. Future subsidence does not appear to be of concern at the site.

#### **2.5.1.1.7 Regional Ground Water Conditions (HNP-1 and HNP-2)**

The regional ground water conditions are discussed in detail in paragraph 2.4.13.1.1. In general, the major source of ground water in southeastern Georgia is known as the principal artesian aquifer. The formations composing this aquifer are the Ocala limestone of Eocene age, the Suwanee limestone of Oligocene age, and the Tampa limestone of Miocene age. These three limestones and their stratigraphic equivalents generally act as a single hydrologic unit. They are confined between low permeability beds of the overlying Hawthorn Formation of Miocene age and the underlying Claiborne Group strata of middle Eocene age. The principal artesian aquifer provides adequate amounts of potable water to individual rural users as well as municipal systems. No significant cones of depression exist in the region.

#### **2.5.1.2 Site Geology**

##### **2.5.1.2.1 Site Physiography (HNP-1 and HNP-2)**

The site is within the Coastal Terraces subprovince of the Atlantic Coastal Plain physiographic province. The Coastal Terraces subprovince consists of at least seven terraces arranged in belts parallel to the Atlantic coast and extending from the Fall Line to the ocean. The nearly flat terrace surfaces slope gently seaward, although over 100 ft of relief may be developed near major stream valleys traversing the terraces. The terrace surfaces near the site are the Brandywine and Coharie Terraces, which are underlain by sandy clay and clayey sand of Pliocene(?) to early Pleistocene ages. Over most of the site, the terrace surfaces have been destroyed by fluvial processes of the Altamaha River and its local tributaries. As a result, the southern part of the site occupies a gentle, dissected slope between the terraces to the south and the Altamaha river valley to the north, while the northern and eastern parts of the site are within the nearly flat Altamaha River flood plain.

##### **2.5.1.2.2 Site Geologic Conditions (HNP-1 and HNP-2)**

During the initial geologic reconnaissance prior to preparation of the HNP-2 Preliminary Safety Analysis Report (PSAR), two areas of possible faulting were postulated to exist within 3 miles of the plant site. These areas, shown in figure 2.5-19, are located ~ 2 miles south of the site near Bay Creek in Appling County and ~ 2.5 miles northeast of the site in southern Toombs County. Subsequent investigations have concluded that no faulting exists in these areas. Observations cited as evidence for this faulting are more representative of deltaic and fluvial processes than of tectonic or structural origin.

*The initial reconnaissance consisted of mapping the outcropping sediments at road cuts along all primary and many secondary roads within 20 miles of the site. Exposures of the contact between the Brandywine and Hawthorn Formations were most prevalent. The contact between lithologic units 6 and 5 of the Hawthorn Formation is exposed in the deeper road cuts and near stream valleys. The lithologies of these three sedimentary units are similar, thereby making picks of the contacts somewhat subjective at the widely spaced outcrops.*

*No displacement of the contacts was found at any of the individual outcrops. However, the contact between lithologic units 6 and 5 of the Hawthorn Formation north of Bay Creek was estimated to be 6 ft higher than the same contact in an exposure south of Bay Creek. Distance between the exposures is ~ 1300 ft. An aerial photograph of the site vicinity shows a possible short lineament along the trace of Bay Creek near the two above-mentioned outcrops. On the basis of these two observations, a fault was proposed to displace the surface material parallel to the trend of Bay Creek.*

*To verify the existence of this proposed fault, two boreholes were drilled north and south of Bay Creek. These boreholes, labeled D and F are shown in figure 2.5-20, and the drill logs are shown in figure 2.5-21. They are ~ 1700 ft apart and on opposite sides of the postulated fault trace. The boreholes penetrated through the fluivial and deltaic facies of the Hawthorn Formation into the Tampa Formation. The erosional surface on top of the shallow marine silty clay of the Tampa Formation provided a well defined local marker bed along which any displacement could be detected and measured. Additional correlation was sought by gamma, resistivity, and self-potential logging of the boreholes. Both the lithologic and geophysical logs revealed that the top of the Tampa Formation was at el -130 msl in boreholes D and -129 ft msl in borehole F. This difference in elevation is negligible and compares favorably with the 15 ft of erosional relief found on the same surface in foundation borings in the plant area. Thus, based on subsurface information along the trace of the proposed fault, no offset of stratigraphic units is indicated.*

*Surface evidence of faulting along Bay Creek is likewise lacking. The 6 ft of relief on the unit 6 - unit 5 contact between exposures north and south of Bay Creek, mentioned above as evidence for faulting along Bay Creek, represents a southeastward dip of ~ 24 ft/mile. The regional dip of coastal plain strata in Georgia ranges between 5 and 60 ft/mile.<sup>(8)</sup> The relief at Bay Creek is therefore not anomalous when placed in the context of the regional coastal plain dip. Fluvial erosion of lithologic unit 5 prior to or contemporaneous with deposition of unit 6 explains some relief along the exposed contact. It is concluded that no surface or subsurface evidence exists to support faulting along Bay Creek.*

*Differences in the elevation of the Brandywine-Hawthorn contact between widely spaced exposures in southeastern Toombs County were suggested to be caused by faulting. Exposures of the contact are located along County Road 107 (figure 2.5-19) and discontinuously extend up to 6 miles northeast of the site. The examined exposures are more prevalent near numerous stream valleys, although a few road cuts not covered by vegetation also exist. Distances between the contact exposures investigated during the initial reconnaissance ranged from 0.2 to 1.4 miles. The maximum relief of the contact was found to be 17 ft between exposures ~ 0.45 miles apart. No displacements of the contact were found in the individual exposures. However, it was postulated that faulting between the exposures could have caused at least some of the relief on the contact.*

*A subsequent field investigation was performed to determine the location of the fault or faults thought responsible for the relief. The Brandywine-Hawthorn contact was traced continuously along the slopes of the divides separating the streams crossed by County Road 107. This traverse provided an unbroken*

profile across the area for which faulting has been postulated. No displacements of the Brandywine-Hawthorn contact were found during the investigation. It is concluded that there is no evidence to support faulting in the area and that fluvial erosion was responsible for any local relief encountered along the Brandywine-Hawthorn contact.

The geologic conditions at the site are typical of the geology of the Atlantic Coastal Plain province. Deep borings 5 miles west of the site in Appling County and 10 miles north of the site in Toombs County indicate that pre-Cretaceous basement rock underlying the site consists of arkosic sandstone, and basalt or diabase. These lithologies are similar to Triassic age rocks found elsewhere along the Atlantic seaboard.<sup>(7)</sup> Overlying the basement rocks are relatively unconsolidated sedimentary units ranging in age from Early Cretaceous to Holocene. These units dip southward and southeastward at 5 to 50 ft/mile and thicken downdip. Sea level fluctuations resulted in erosion of some of the units after their deposition. Moderate relief was developed during low sea level stands and before deposition of the next stratigraphic sequence. The only structural feature near the site is the Southeast Georgia embayment, the inland edge of which is 11 miles east of the site. (See paragraph 2.5.1.1.6.1.) The embayment has had little or no influence on geologic formations underlying the site.

Materials from the following geologic units, listed from oldest to youngest, were found in geologic and foundation borings drilled at the site: Tampa and Hawthorn Formations of Miocene to Pliocene(?) ages; Brandywine terrace deposits of Pliocene(?) to Pleistocene ages; and alluvium of late Pleistocene and Holocene ages. The closest oil test well to the site (Appling County, Georgia Geological Survey 148), drilled about 5 miles west of the site, penetrated below the Tampa Formation into the following units, listed from oldest to youngest:<sup>(26)</sup>

- Undifferentiated deposits of Early Cretaceous age.
- Tuscaloosa Formation and post-Tuscaloosa undifferentiated deposits of Late Cretaceous age.
- Clayton Formation of Paleocene age.
- Early Eocene (Wilcox) deposits.
- Tallahatta and Lisbon Formations of middle Eocene (Claiborne) age.
- Ocala Formation of late Eocene (Jackson) age.
- Undifferentiated carbonates (probably Suwanee Formation) of Oligocene age.

The oil test well is along the strike of the coastal plain strata from the site.

The Cretaceous Formations represent a transgressive sequence, characterized by continental and deltaic deposition of the Lower Cretaceous undifferentiated and the Tuscaloosa Formation and by lagoonal to marginal marine deposition of the post-Tuscaloosa deposits. The Lower Cretaceous strata, which are probably correlative with the Comanche series found westward in the Coastal Plain province,<sup>(8)</sup> consist of sandy, micaceous clays interbedded with arkosic sands. They rest unconformably on basement rock of possible Triassic age<sup>(7)</sup> and are ~ 115 ft thick. The top of the Lower Cretaceous strata in the site vicinity

is at el -3731 ft msl. (Elevations below the Tampa Formation refer to Well Georgia Geological Survey 148.) The overlying Tuscaloosa Formation consists of ~ 910 ft of fine-grained to arkosic, carbonaceous, fossiliferous, and micaceous sand and clay. The top of the unit is at el -2821 ft msl. Post-Tuscaloosa deposits are ~ 995 ft thick<sup>(26)</sup> and are equivalent to Eutaw and Selma group deposits found in Alabama.<sup>(8)</sup> They consist of coquinoid and phosphatic sand and carbonaceous, fossiliferous, glauconitic marl. The top of these strata is at el -1866 ft msl.<sup>(26)</sup> Contacts between the preceding formations are generally conformable and somewhat indistinct, owing to the similar fossils (where present) and lithologies.<sup>(8)</sup>

The widespread, post-Cretaceous sea level regression noted elsewhere in the Gulf and Atlantic Coastal Plains<sup>(9)</sup> is represented at the site by an erosion surface developed on top of the post-Tuscaloosa deposits. The Tertiary Formations underlying the site are typical of shallow marine deposition during high sea levels and deltaic to marginal marine deposition during lower sea levels.

The basal Tertiary Formation in the site area is the Clayton Formation of Paleocene age.<sup>(8)</sup> It consists of massive crystalline limestone and carbonaceous, marly sand. Throughout the Coastal Plain provinces, the Clayton rests unconformably on the underlying Cretaceous age deposits. The unit is ~ 315 ft thick, with the top at el -1551 ft msl.<sup>(26)</sup>

Undifferentiated Wilcox Group deposits of early Eocene age represent deposition in a shallow marine environment. The Wilcox deposits underlying the site consist of ~ 90 ft of carbonaceous, micaceous, silty fossiliferous marl. The top of the unit is at el -1461 ft msl.<sup>(26)</sup> This material is correlative with the upper part of the Hatchetigbee Formation found westward in the Coastal Plain province.<sup>(8)</sup> In the site area, the early Eocene sea was restricted in extent, as indicated by the absence of extensive lower Eocene strata that are found elsewhere in the southeast.<sup>(1)</sup>

The Tallahatta and Lisbon Formations comprise the middle Eocene Claiborne Group underlying the site. The Tallahatta is ~ 160 ft thick and consists of glauconitic sand and thin stringers of fossiliferous marl. The top of the formation is at el -1301 ft msl. The Lisbon Formation consists of 610 ft of dolomitic to sandy, phosphatic limestone, with abundant glauconite and fossils. The top of the Lisbon is at el -691 ft msl.<sup>(26)</sup> Both of these formations were deposited in a shallow marine environment that was typical of the middle Eocene in the Coastal Plain provinces.<sup>(1)</sup>

The late Eocene is represented by the Ocala Formation of the Jackson Group. The Ocala is below el -411 ft msl and is 280 ft thick. It consists of crystalline, massive, extremely fossiliferous limestone that was deposited in a shallow marine environment.<sup>(26)</sup>

Material of Oligocene age underlying the site is equivalent to the upper part of the Vicksburg Group found in the Gulf Coastal Plain and to the Suwannee limestone found in Florida.<sup>(8)</sup> The Oligocene undifferentiated in Appling County consists of massive, calcitized, fossiliferous limestone deposited in a shallow sea. The unit is 120 ft thick, and the top is at el -291 ft msl.<sup>(26)</sup>

Miocene to Pliocene(?) age material at the site, penetrated by site borings, represents a regressive sequence, characterized by shallow marine limestone of the Tampa Formation overlain by marginal marine to fluvial deposits of the Hawthorn Formation. The Tampa Formation of Miocene age is ~ 160 ft thick, with a top at approximate el -130 ft msl. It consists of sandy to clayey, phosphatic, fossiliferous, and somewhat dolomitized limestone. The Hawthorn Formation of Miocene to Pliocene(?) age consists of six distinct lithologic units. The basal unit is probably lagoonal in origin, ~ 115 ft thick, and contains phosphatic, carbonaceous, well-sorted fine sand and sandy clay. The second unit is about 20 ft thick and

consists of phosphatic, fine to coarse sand, and silty clay that is calcareous in the bottom 10 ft, with abundant shell fragments. The overlying third unit, ~ 25 to 35 ft thick, contains phosphatic, clayey, fine to medium sand with some pyrite. The fourth unit is similar, but contains less phosphate and no pyrite. It is ~ 40 to 50 ft thick. The fifth unit is 20 to 40 ft thick and consists of micaceous and feldspathic fine to coarse sand and sandy clay that is locally cemented. These last three units were deposited in progressively shallower environments, ranging from estuarine to deltaic. The top unit of the Hawthorn Formation is fluvial in origin. It consists of over 50 ft of arkosic clayey sand, sandy clay, and gravel, with abundant cross-bedding. Total thickness of the Hawthorn Formation is over 300 ft.<sup>(26)</sup> The Hawthorn Formation has recently been reclassified as Neogene Undifferentiated by the Georgia Geological Survey; the interval includes Miocene to Pliocene ages.

In the southwestern part of the site, the Brandywine Formation of Pliocene(?) to Pleistocene age is locally exposed above approximate el 165 ft msl. The Brandywine is a fluvial to deltaic deposit consisting of poorly sorted, feldspathic, cross-bedded sand and gravel with abundant hematite concretions. The northern and eastern parts of the site are covered with alluvium associated with the Altamaha River. The flood plain deposits may be Pleistocene age depth, but the surface material is Holocene in age.<sup>(30)</sup> The alluvium consists of poorly sorted sand and gravel and carbonaceous silty clay.

A site geologic column showing the relationship between formations underlying the site is presented in figure 2.5-8. The regional geologic column is shown in figure 2.5-4. Logs of all site borings are presented in supplement 2B.

#### **2.5.1.2.3 Site Structural Geology (HNP-1 and HNP-2)**

The Southeast Georgia embayment is the only known structural feature in the vicinity of the site. The inner edge of the embayment is ~ 11 miles east of the site. Material underlying the site was not affected by subsidence of the basin. Details of the Southeast Georgia embayment are included in paragraph 2.5.1.1.6.1, Description of Tectonic Structures.

A site structural geology map showing contours on top of unit 5 of the Hawthorn Formation is presented in figure 2.5-9. This unit is the foundation for the plant reactor. The bedrock contours indicate that although erosion of the unit occurred before deposition of the overlying strata, there has been no structural deformation of the bearing stratum.

#### **2.5.1.2.4 Site Geologic Map (HNP-1 and HNP-2)**

A geologic map of the site is presented in figure 2.5-10. This map shows the locations of Category I structures and the known and inferred contacts between materials exposed at the site. An areal geologic map is shown in figure 2.5-11.

#### **2.5.1.2.5 Site Geologic History (HNP-1 and HNP-2)**

The geologic history of the site is closely allied with the geologic history of the Atlantic Coastal Plain province. Underlying the site are rocks of Triassic to Holocene ages (except Jurassic) that extend to or

have equivalents in other areas of the Atlantic and Gulf Coastal Plains. Structural features found elsewhere in the Coastal Plain provinces have not influenced the geology of the site.

Following erosion of the Appalachian belt Paleozoic rocks, Triassic continental deposits and igneous rocks were laid down in inland basins or graben-faulted areas. During the Jurassic, the Triassic rocks were eroded. Deposition of Jurassic strata did not occur in the area of the site.<sup>(1)</sup>

Initial deposition of marine and fluvial coastal plain sediments in the vicinity of the site occurred in the Cretaceous. Undifferentiated Lower Cretaceous strata, probably equivalent to the Comanche series, were deposited on the eroded Triassic deposits. As the Late Cretaceous sea transgressed inland, a sequence of fluvial to shallow marine material, represented by the Tuscaloosa Formation and post-Tuscaloosa undifferentiated, was deposited. A period of erosion marked the end of the Cretaceous.<sup>(1)</sup>

Tertiary depositional patterns were determined by cyclic advances and retreats of the sea and relative subsidence of areas marginal to the present coast. As the sea spread inland, near short to moderately deep marine deposits (predominantly carbonates) were laid down on the eroded surface of older units. The greatest thickness of material was deposited in slowly subsiding basins, such as the Southeast Georgia embayment. As the sea retreated, newly deposited material was eroded. This pattern of transgression and deposition followed by regression and erosion was repeated throughout the Tertiary and continued into the Quaternary. During the Pleistocene, the sea encroached progressively less on the Coastal Plain province, with earlier deposited material, such as the Brandywine Terrace deposits, extending further inland and higher than younger material. In the vicinity of the site, the terrace deposits were partially eroded by the Altamaha River and its local tributaries. The Altamaha River flood plain has been developed during the late Pleistocene and Holocene.

The characteristics of each formation found at the site are included in paragraph 2.5.1.2.2, Site Geologic Conditions. A site geologic column is shown in figure 2.5-8.

#### **2.5.1.2.6 Plot Plan (HNP-1 and HNP-2)**

Information concerning the locations of major structures of the plant, including all Category I structures, and borings made at the site are presented in figures 2A-1 and 2A-2. The graphic logs of the borings are shown in figures 2B-1 through 2B-112. These figures, along with a discussion of findings, are presented in supplements 2A and 2B.

#### **2.5.1.2.7 Geologic Profiles and Plant Foundations (HNP-1 and HNP-2)**

The relationship of the major foundations to subsurface materials is presented in the form of generalized subsurface profiles shown in figure 2A-3. The ground water conditions are discussed in subsection 2.4.13. The significant engineering characteristics of the subsurface materials are discussed in supplement 2A. All Category I buildings are founded on cemented sand or silty sand of the Hawthorn Formation.

**2.5.1.2.8 Excavations and Backfill**

The methods of excavation and compaction of fills are discussed in section 2A-8 of supplement 2A. The plant area excavation plan and sections are shown in figure 2A-37. The compaction criterion is 95% (minimum) of the maximum dry density as determined by American Society of Testing Materials D 1557 (Modified Proctor).

**2.5.1.2.9 Evaluation of Local Engineering Geology (HNP-1 and HNP-2)**

**2.5.1.2.9.1 Prior Earthquake Effects.** There is no evidence to suggest that surficial or subsurface materials at the site have been affected by prior earthquake activity. No fault planes were penetrated by the numerous site borings or exposed in any of the excavations. The tops of formations and beds within formations have not been offset by faulting or slumping. The steep slopes between the plant area and the Altamaha River flood plain are not marked by slumps. Streams courses are not offset along any lineations associated with structural features. No topographic features can be attributed to seismic activity. Earthquake activity apparently has had no effect on the materials at the site.

**2.5.1.2.9.2 Deformational Zones.** Inspection of outcrops, excavations, and subsurface samples of the Hawthorn Formation, which is the foundation material for the major plant structures, has revealed that there are no deformational zones within Hawthorn material. There are no reversals of dip of the Hawthorn Formation in the vicinity of the site. Exposures of the Hawthorn do not contain joints or fractures. Core samples of Hawthorn material at the site do not exhibit shear zones or fractures.

**2.5.1.2.9.3 Zones of Alteration or Weakness.** The foundation material (Hawthorn Formation) has not been altered by chemical weathering. By contrast, local cementation of the upper part of the Hawthorn has occurred. The top of the Hawthorn was eroded prior to deposition of the Brandywine terrace deposits, effectively stripping any weathering profile that had developed. Calcareous material underlying the Hawthorn is well crystallized and shows no evidence of solution. There are no surface sinkholes indicating solution of underlying material. There are no zones of structural weakness composed of crushed or disturbed materials underlying the site.

**2.5.1.2.9.4 Bedrock Stress.** Over 4000 ft of relatively unconsolidated coastal plain deposits overlie bedrock of possible Triassic age beneath the site. Therefore, bedrock stresses are not applicable in considering the design and operation of the plant.

**2.5.1.2.9.5 Potentially Unstable Soils.** Numerous field and laboratory tests indicate that there are no potentially unstable soils at the site under any of the plant structures. The characteristics of the soils underlying the site are discussed in detail in supplement 2A.

There are no soils or rocks under any plant structures that have potentially undesirable characteristics which would cause them to respond adversely to expected seismic events. Sandy overburned soils were

analyzed for liquefaction potential and found not susceptible to liquefaction. (See subsection 2A.5.2 of supplement 2A.)

**2.5.1.2.9.6 Effects of Man's Activities.** *The effects of man's activities on geologic conditions at the site are discussed in paragraph 2.5.1.1.6.2, Areas of Potential Instability. There are no mining or mineral extraction activities occurring near the site, and ground water extraction is nominal in this area of low population. Therefore, there are no human activities that will affect site geologic conditions.*

**2.5.1.2.10 Site Ground Water Conditions (HNP-1 and HNP-2)**

*Site ground water conditions are described in detail in paragraphs 2.4.13.1.2 and 2.4.13.2.2. In general, the site is underlain by a shallow unconfined aquifer and a deeper lying, minor confined aquifer. These aquifers are separated by a layer of silty cemented sand ~ 40 to 50 ft thick that forms an effective aquiclude, preventing migration of water from one aquifer to the other. The unconfined aquifer lies above el 100 to 120 ft msl in the plant area, with the unconfined water table generally reflecting the site topography. The minor confined aquifer consists of silty sands of the Hawthorn Formation between approximate el 65 and 0 ft msl. Piezometric levels generally are below el 80 ft msl, and the potentiometric surface slopes northeastward toward the Altamaha River. The river is hydraulically connected to the two aquifers.*

*Present and projected usage of ground water in the vicinity of the site, discussed in paragraphs 2.4.13.2.1 and 2.4.13.2.5 will not affect the present ground water conditions. Ground water for plant usage is withdrawn from a deep, confined aquifer (at a maximum rate of 327 gal/min) that is not hydraulically connected with aquifers utilized by most offsite domestic wells.*

**2.5.1.2.11 Geophysical Survey Results (HNP-1 and HNP-2)**

*Results of geophysical surveys conducted at the site are shown in figures 2A-5 and 2A-6. A discussion of the geophysical exploration and the results are included in subsection 2A.1.4.*

**2.5.1.2.12 Static and Dynamic Properties (HNP-1 and HNP-2)**

*The static and dynamic properties of the site materials are discussed in section 2A.3 (Laboratory Testing) of supplement 2A. The results of the laboratory testing are presented in tables 2A-1 and 2A-5.*

*Laboratory testing, procedures, and classification procedures are discussed in section 2A.3. Grain-size classification is presented in table 2A-1 and figure 2A-8 and discussed in subsection 2A.3.1 of supplement 2A.*

*Consolidation characteristics are presented in figures 2A-9 and 2A-10 and table 2A-4 and discussed in subsection 2A.3.3 of supplement 2A.*



*In situ* moisture content is shown in table 2A-2. Atterberg limits are shown in table 2A-1. Triaxial shear test data are presented in table 2A-5 and the test results are presented in figure 2A-11. Cyclic triaxial testing is discussed in subsection 2A.3.5 with the results of testing presented in figures 2A-12 and 2A-13.

The geophysical explorations performed are discussed in subsection 2A.1.4 of supplement 2A.

#### **2.5.1.2.13 Safety Criteria and Analysis Techniques**

The foundation conditions provide the safe support of all structures. The safety criteria and methods of analysis are discussed in detail in supplement 2A, section 2A.5.

### **2.5.2 VIBRATORY GROUND MOTION**

#### **2.5.2.1 Site Geologic Conditions**

The lithologic, stratigraphic, and structural geologic conditions at the site, including the geologic history, are discussed in paragraph 2.5.1.1.5, Regional Geologic Conditions; paragraph 2.5.1.2.2, Site Geologic Conditions; paragraph 2.5.1.2.3, Site Structural Geology; and paragraph 2.5.1.2.5, Site Geologic History.

Over 4000 ft of coastal plain sediments, ranging in age from Cretaceous to Holocene, underlie the site. These sediments consist of sand, clay, marl, sandstone, shale, and limestone. No structural features affect materials underlying the site.

The Hawthorn Formation of Miocene to Pliocene(?) age is the bearing stratum for the plant Category I structures. It consists of cemented sand, silty clay, and silty sand with clay layers. Engineering properties of the Hawthorn Formation are discussed in supplement 2A.

#### **2.5.2.2 Underlying Tectonic Structures**

Tectonic structures underlying the region surrounding the site are discussed in paragraph 2.5.1.1.6.1, Description of Tectonic Structures, and are shown in figure 2.5-3. There are no known or suspected structural features within 11 miles of the site. Structures in the coastal plain within 200 miles of the site have not been active since the end of Miocene time. Therefore, no structural features are of significance to the site.

#### **2.5.2.3 Behavior During Prior Earthquakes**

The effects of prior earthquakes on materials at the site are discussed in paragraph 2.5.1.2.9.1, Prior Earthquake Effects. Earthquake activity has apparently had no effect on site materials.

#### 2.5.2.4 Engineering Properties of Site Materials

The properties of the materials underlying the site are discussed in detail in supplement 2A. The locations of the seismic traverse lines are shown in figure 2A-4. The compressional, shear, and Rayleigh waves are shown in figure 2A-5 and 2A-6. Geophysical exploration results are discussed in subsection 2A.1.4. Boring logs are presented in supplement 2B.

In situ moisture content is shown in table 2A-2. Triaxial shear test data are presented in table 2A-5 and the test results are presented in figure 2A-11. Cyclic loading is discussed in subsection 2A.3.5, with the result of testing presented in figures 2A-12 and 2A-13.

#### 2.5.2.5 Earthquake History

The site is within a broad region of infrequent seismic activity encompassing southern Alabama, southern Georgia, and northern Florida. Figure 2.5-12, Seismic Risk Map of the United States, shows that the site is in zone 1, an inactive seismic region characterized by a few low-magnitude and low-intensity shocks. The nearest zone 2 area is about 55 miles away, and the nearest zone 3 is about 90 miles distant. Zone 1 is described as follows: "Minor damage; distant earthquakes may cause damage to structures with fundamental periods greater than 1.0 seconds; corresponds to intensities V and VI of the MM Scale" (Modified Mercalli Intensity Scale of 1931, table 2.5-1).

Table 2.5-2 is a list of historically reported earthquakes having epicenters within 200 miles of the site and epicentral intensities of IV (MM) or greater. The locations of these events are shown in figure 2.5-13, Tectonic and Epicenter Map. Of the 76 earthquakes listed, 53 had epicenters within the Coastal Plain province, including one in the Atlantic Ocean. Thirty of the coastal plain events were confined to the vicinity of Charleston, South Carolina. No earthquakes occurring in the coastal plain outside of the Charleston area had an epicentral intensity greater than VI (MM). (See references 31, 32, 33, and 34.)

A review of the literature indicates that none of the 76 events had damaging effects within the plant vicinity or in Baxley, Georgia, ~ 10 miles to the south. Iseismal and felt area reports indicate that the site area sustained its largest intensity during the 1886 Charleston event that had an epicentral intensity of X. The site intensity during that event was probably VI (MM).<sup>(35)(36)</sup> Estimates of ground acceleration and duration of shaking for the site during the earthquake are included in paragraph 2.5.2.9, Maximum Earthquake.

#### **2.5.2.6 Correlation of Epicenters with Geologic Structures**

*Although a few epicenters are near major faults shown in figure 2.5-13, the many thrust and normal faults that have been mapped in the Appalachian provinces do not have a record of surface breakage during historic times.<sup>(36)</sup> Ten events have occurred on the coastal margin of the Southeast Georgia embayment in the Coastal Plain province. Regional cross sections through the embayment show no evidence of faulting.<sup>(14)</sup> Since the epicenters listed in table 2.5-2 cannot be reasonably associated with geologic structures, they are assigned to tectonic provinces. Boundaries of the tectonic provinces are discussed in paragraph 2.5.1.1, Regional Geology. It should be noted that the high seismicity in the vicinity of Charleston, South Carolina, is not typical of the generally quiescent Coastal Plain province. (See table 2.5-2 and figure 2.5-13.)*

#### **2.5.2.7 Identification of Active Faults**

*No faults in the Coastal Plain province within 200 miles of the site are considered active. A discussion of coastal plain faults is included in paragraph 2.5.1.1.6.1, Description of Tectonic Structures.*

*Faults within the Appalachian Mountain System are over 90 miles from the site and are in a separate tectonic province. These faults (figure 2.5-13) do not exhibit evidence of surface displacement during historic time.<sup>(36)</sup> If movement along these faults at depth has caused earthquakes in historic times, none has had an epicentral intensity greater than VII-VIII (MM) (table 2.5-2); and the intensity at the site would be much lower. They are therefore not significant in establishing the SSE.*

#### **2.5.2.8 Description of Active Faults**

*No active faults exist within 200 miles of the site. (See paragraph 2.5.2.7, Identification of Active Faults).*

#### **2.5.2.9 Maximum Earthquake**

*The highest intensity sustained in the vicinity of the site during historic times resulted from the August 31, 1886, Charleston, South Carolina event. The earthquake was centered about 160 miles northeast of the site and had an epicentral intensity of X (MM). The shock lasted 35 to 40 s in the epicentral area.<sup>(31)</sup> The intensity in the area of the site, as shown in Dutton's report, was VII (Rossi-Forel scale).<sup>(35)</sup> This corresponds to middle VI on the Modified Mercalli scale.<sup>(37)</sup> The reports upon which Dutton based his isoseismal map, shown in figure 2.5-14, indicate that the middle intensity VI (MM) in the vicinity of the site is a maximum value. The nearest reported damage from the 1886 event occurred in the Savannah, Georgia, area about 70 miles east of the site, where the intensity was VI to VII (MM).<sup>(35)</sup> Savannah is about 90 miles from the epicenter, or about 70 miles closer than the site. The site intensity of middle VI (MM) corresponds to a horizontal surface acceleration of 0.064 g on Neumann's (1954) curve and 0.047 g on Hershberger's (1956) curve.*

#### **2.5.2.10 Design Basis Earthquake**

*For the DBE an intensity of VII (MM) is selected. This intensity corresponds with the highest damage sustained at Savannah, Georgia, during the 1886 Charleston event. Outside of the anomolous Charleston seismic area, no events within 200 miles of the site in the coastal plain have had epicentral intensities higher than VI (MM). It is unlikely that an intensity VII (MM) event has ever been felt at the site. An intensity of VII (MM) is equivalent to 0.12 g on both the Neumann (1954) and Hershberger (1956) curves. However, a horizontal surface acceleration of 0.15 g is conservatively selected for the DBE. The selected maximum vertical acceleration is two-thirds the maximum horizontal acceleration.*

*A detailed discussion of response spectra, damping factors, and time history accelerogram is presented in section 3.7.*

#### **2.5.2.11 Operating Basis Earthquake (OBE)**

*The highest intensity felt at the site was VI (MM). This corresponds to an OBE with a horizontal surface acceleration of 0.064 g on Neumann's (1954) curve and 0.047 g on Hershberger's (1956) curve.*

*For conservatism, a value of 0.08 g is selected for the OBE. The selected maximum vertical surface acceleration is two-thirds the maximum horizontal acceleration. Section 3.7 provides a discussion of the response spectra for the OBE.*

### **2.5.3 SURFACE FAULTING**

*There are no active faults within 200 miles of the site. (See paragraph 2.5.1.1.6.1.) The nearest occurrence of known surface faulting is the Andersonville fault, 95 miles west of the site, which has been inactive since middle Eocene time.<sup>(22)</sup> There is no surface faulting in the vicinity of the site; therefore, it is not necessary to design the plant for surface faulting.*

#### **2.5.3.1 Geologic Conditions of the Site**

*The lithologic, stratigraphic, and structural geologic conditions of the site and vicinity, including geologic history, are discussed in paragraph 2.5.1.1.5, Regional Geologic Conditions; paragraph 2.5.1.2.2, Site Geologic Conditions; paragraph 2.5.1.2.3, Site Structural Geology; and paragraph 2.5.1.2.5, Site Geologic History.*

#### **2.5.3.2 Evidence of Fault Offset**

*Pertinent publications, geologic investigations in the site vicinity, and investigations of construction excavations indicate that there is no fault offset at or near the ground surface in the vicinity of the site.*

**2.5.3.3 Identification of Active Faults**

*No faults in the Coastal Plain provinces within 200 miles of the site are considered active. A discussion of coastal plain faults is included in paragraph 2.5.1.1.6.1, Description of Tectonic Structures.*

**2.5.3.4 Earthquakes Associated With Active Faults**

*None of the earthquakes that have had epicenters within 200 miles of the site can be reasonably associated with active faults. Earthquakes in this area are listed in table 2.5-2, and none is associated with faults within 5 miles of the site.*

**2.5.3.5 Correlation of Epicenters With Active Faults**

*No epicenters of historically reported earthquakes can be correlated with active faults within 5 miles of the site. There are no active faults in the site vicinity.*

**2.5.3.6 Description of Active Faults**

*There are no active faults within 5 miles of the site. A discussion of coastal plain faults is included in paragraph 2.5.1.1.6.1, Description of Tectonic Structures.*

**2.5.3.7 Faulting Investigation Zone**

*Published reports of the site area and geologic investigations at and near the site indicate that the area contains no faults. The coastal plain strata dip southeastward, with no reversals of dip or offset in the beds. A detailed faulting investigation was not required.*

**2.5.3.8 Justification for Nonexistence of Surface Faulting**

*Data presented in paragraph 2.5.1.1.6.1, Description of Tectonic Structures; paragraph 2.5.1.2.3, Site Structural Geology; and in figure 2.5-11, Areal Geologic Map, indicate that no faulting exists in the vicinity of the site. No surface offsets were found in geologic investigations at the site or in the area surrounding the site. Coastal plain strata in southeastern Georgia dip southeastward at 5 to 50 ft/mile, with the dip increasing with depth. No fault planes were penetrated by site geologic or foundation borings, nor were structural offsets indicated in the area between borings. Published reports on the geology of the area do not present any information on surface faults. It is concluded that surface faulting is not present in the site area and does not require further consideration.*

## **2.5.4 STABILITY OF SUBSURFACE MATERIALS**

*Information presented in this section concerns the stability of soils and rock beneath the plant foundations during the vibratory ground motion associated with the DBE. In general, this information is included in section 2.5 and supplement 2A and is cross-referenced to appropriate subsections.*

### **2.5.4.1 Geologic Features**

#### **2.5.4.1.1 Areas of Potential Instability**

*A discussion of areas of actual or potential surface or subsurface subsidence, uplift, or collapse is included in paragraph 2.5.1.1.6.2, Areas of Potential Instability. The plant foundations will not be affected by movement in the areas discussed. No areas of potential surface or subsurface subsidence exist at the plant site.*

#### **2.5.4.1.2 Deformational Zones**

*The site foundation material does not contain deformational zones of any kind. A discussion of the foundation material with respect to zones of deformation is included in paragraph 2.5.1.2.9.2, Deformational Zones.*

#### **2.5.4.1.3 Zones of Alteration or Weakness**

*Paragraph 2.5.1.2.9.3, Zones of Alteration or Weakness, contains a discussion of these aspects of materials underlying the site. There are no altered or weak zones in the site foundation materials.*

#### **2.5.4.1.4 Bedrock Stress**

*Over 4000 ft of coastal plain deposits overlie bedrock of possible Triassic age beneath the site.<sup>(7)</sup> The Triassic rock was eroded before deposition of the Cretaceous and Cenozoic sedimentary deposits. It is unlikely that unrelieved residual stresses exist in the bedrock. Major deformation has not occurred since Triassic time.<sup>(1)</sup>*

#### **2.5.4.1.5 Potentially Unstable Soils**

*The characteristics of soils underlying the site are discussed in supplement 2A. There are no soils or rocks under any plant structures that have potentially undesirable responses to seismic events.*

#### 2.5.4.2 Properties of Underlying Materials

(HNP-2) subsurface conditions were investigated by the following borings:

- Reactor and radwaste buildings by 8 borings numbered 587 through 594 and one numbered 401 drilled during initial investigations.
- The turbine building by 6 borings numbered 596 through 600.

The conditions were verified by borings RFI-1 through RFI-10 (figures 2B-113 through 2B-122) which were performed as part of the foundation inspection of HNP-2.

The borings were made with a rotary wash boring process which utilized a heavy viscous drilling fluid to stabilize the sides and bottom of the drill holes. Standard penetration tests were made in accordance with ASTM Specification D1586-67 at 5-ft intervals throughout the borings. The standard penetration test samples were inspected, classified, and used as the basis for selecting depths to obtain 3-in.-diameter undisturbed Shelby-Tube-type samples.

The area of the powerblock initially varied in elevation from about el 135 to 145 ft. General site grading lowered this area to ~ el 130 ft. Excavation for HNP-1 extended to ~ el 75 ft and extended southward to ~ the centerline of the HNP-2 reactor. The area excavated was covered with a reinforced concrete working slab which varied in thickness from 8 in. to 1 ft. Borings for HNP-2 were made from both the level of the excavation for the HNP-1 powerblock and the general elevation of the yard area.

The soil conditions determined by the borings in the HNP-2 powerhouse area are generally consistent with the soil conditions determined by the borings in the HNP-1 powerblock area.

The borings made from the general yard level initially encountered firm to dense, multi-colored, clayey, fine to medium sands and very stiff to hard, fine, sandy clays extending downward to ~ el 120 ft.

These sands and clays are underlain by very dense, gray, clayey, fine to medium sand which in most locations, is partially cemented. Within this generally cemented sand zone are scattered layers and inclusions of very hard clay and very dense uncemented sands. These sands extend to ~ el 75 ft.

The cemented sands are underlain by firm to very dense, gray-green fine sands and clayey fine sands which extend to ~ el 30 ft. Within this zone, thin layers of lenses of gray-green plastic clay, which vary in thickness from 3 to 6 ft, were encountered from el 60 to 70 ft. Below el 30 ft, dense to very dense, gray, slightly clayey, fine sands with thin, hard, clay layers were encountered. The dense sands extend to ~ el 0 ft. Below el 0 ft, very hard, gray-green, silty clays were encountered.

The properties of the underlying materials are discussed in detail in supplement 2A. Subsurface profiles in the HNP-2 powerblock are shown in figure 2A-3.

Laboratory testing procedures and classification procedures are discussed in section 2A.3. Grain size classification is presented in table 2A-1 and figure 2A-8 and discussed in subsection 2A.3.1 of supplement 2A. Atterberg limits test results are shown in table 2A-1.

Consolidation characteristics are presented in figures 2A-9 and 2A-10 and table 2A-4 and discussed in subsection 2A.3.3 of supplement 2A.

In situ moisture contents are shown in table 2A-2. Triaxial shear test data are presented in table 2A-5, and the test results are presented in figure 2A-11. Triaxial testing is discussed in subsection 2A.3.5, with the results of testing presented in figures 2A-12 and 2A-13.

The geophysical exploration performed is discussed in subsection 2A.1.4 of supplement 2A.

#### **2.5.4.3 Plot Plan**

Information concerning the locations of major structures of the plant, including all Category I structures, and borings made at the site are presented in figures 2A-1 and 2A-2. These figures, along with discussion of findings, are presented in detail in section 2A.2 of supplement 2A. The logs of the borings are included in supplement 2B.

The locations of seismic traverse lines are shown in figure 2A-4; the subsurface profiles in the powerblock area are shown in figure 2A-3; and a surface distribution of geologic formations is shown in figure 2A-7 of supplement 2A. Regional geologic profiles are shown in figures 2.5-5 and 2.5-6. A plot of the piezometer locations is presented in figure 2.4-37.

#### **2.5.4.4 Soil and Rock Characteristics**

The site subsurface conditions and the soil characteristics are discussed in detail in supplement 2A. The locations of the seismic traverse lines are shown in figures 2A-4. The compressional, shear, and Rayleigh wave velocities are shown in figures 2A-5 and 2A-6. Geophysical exploration results are discussed in subsection 2A.1.4. Boring logs are presented in supplement 2B.

#### **2.5.4.5 Excavations and Backfill**

The plant area excavation plan and sections are presented in figure 2A-37. A discussion of excavation and backfill is presented in section 2A.8.

#### **2.5.4.6 Ground Water Conditions**

Hydrology and ground water conditions are described and discussed in detail in section 2.4. Where plant excavation occurs below the water table, dry and stable foundation conditions were maintained during construction by conventional dewatering methods.

Permanently sealed piezometers have been installed around the exterior of the HNP-1 powerblock area. After the installation of these piezometers, continuous dewatering of the foundation soils was accomplished by eductor well points. The piezometer locations are shown in figure 2.4-37. This dewatering has resulted in water levels within the permanent piezometers which vary from ~ el 50 to 80 ft. During 1974, the water levels within the different permanent piezometers ranged from el 70 to



78 ft. It is anticipated that the stabilized ground water level in the (HNP-1) and (HNP-2) powerblock areas will coincide with approximate el 70 to 75 ft.

#### **2.5.4.7 Dynamic Loading Response**

Cyclic triaxial test results and the dynamic response of site soils are discussed in subsection 2A.3.5 of supplement 2A. The responses of specimens of representative site soils indicate that there should be no adverse effects on the site soils under dynamic loading. The result of the cyclic triaxial tests are presented in figures 2A-12 and 2A-13.

#### **2.5.4.8 Liquefaction Potential**

Within the area of the principal structures, there are no soils susceptible to liquefaction when subjected to the stress condition imposed by the DBE. For verification, laboratory dynamic triaxial tests were performed on samples from the plant area. The results of these tests were used to determine safety factors against liquefaction for several piezometric levels at various locations in the powerblock area. (See subsection 2A.5.2 of supplement 2A.) The shear stresses produced by the DBE were found to be far less than the dynamic strength of the soil indicated by the dynamic triaxial tests.

In addition, the penetration resistances of the sand zones considered are much higher (the soil is much denser) than sands that have been liquefied in other parts of the world where this phenomenon has been observed. (Penetration resistance histograms are presented in figures 2A-14 and 2A-15.) Generally, 15 to 25% of the sands at the site pass through the No. 200 sieve. This shows that the soils are not truly cohesionless and are not susceptible to liquefaction. Also, the foundation soils are at least 13 million years old (Miocene) and are highly preconsolidated; whereas, where liquefaction has occurred, the soils have been recent alluvium, glacial outwash, or loose manmade fills.

#### **2.5.4.9 Earthquake Design Basis**

Basis of earthquake design is the DBE with a maximum horizontal acceleration of 15% of the acceleration of gravity. Background for selection of the DBE is provided in subsection 2.5.2.10, Design Basis Earthquake.

#### **2.5.4.10 Static Analyses**

Foundation investigations and evaluations for HNP-2 principal structures (the reactor, radwaste, and turbine buildings) and auxiliary structures have been carried out as part of investigations encompassing a large portion of the site. The extensive information and knowledge of the site subsurface conditions that has been accumulated for HNP-1 is used to augment and verify the evaluation of HNP-2 foundation conditions.

The stability of the soil foundations for static as well as dynamic loads and for adverse ground water level conditions was evaluated by performing bearing capacity, settlement, liquefaction, and slope

stability analyses. The results of these analyses show that the foundations are capable of safely supporting the plant structures. These analyses are discussed in sections 2A.5 and 2A.6.

#### **2.5.4.11 Criteria and Design Methods**

Mat foundations were considered flexible or rigid, depending on the stiffness of the structure relative to the foundation material. A minimum safety factor of three against a static bearing capacity or shear failure was used in the design. Settlement analyses were based on the theory of consolidation in the case of saturated primarily cohesive soil and on the theory of elasticity in the case of unsaturated or noncohesive soils.

Liquefaction analyses were made using laboratory cyclic triaxial test results of relatively undisturbed soil samples and the results of standard penetrations tests. These are discussed in subsection 2A.5.2.

Slope stability during static and dynamic loading was evaluated by means of the circular arc and slices method of analysis (section 2A.6). The minimum acceptable factors of safety against sliding or shear failure for all slopes were established as follows:

- A. Normal conditions: For normal operating conditions with the most adverse water level, the minimum factor of safety is 1.5.
- B. Earthquake conditions: For the addition of the effect of the DBE to the normal operating conditions, the minimum factor of safety is 1.1.
- C. Construction conditions: For temporary construction conditions, the minimum factor of safety is 1.3.

All slopes at the site are designed to meet or exceed the above criteria. The results of the stability analyses are discussed in section 2A.6.

#### **2.5.4.12 Techniques to Improve Subsurface Conditions**

The site and foundation materials are stable and capable of safely supporting the plant loads under static as well as dynamic conditions. Therefore, the improvement of subsurface conditions was not needed.

### **2.5.5 SLOPE STABILITY**

Slope stability analyses indicate that the permanent and construction slopes in the plant area are stable. Analyses also indicate that the natural bank between the river and upper plant level is quite stable for both static and dynamic conditions. The minimum calculated safety factors are presented in section 2A.6.

**2.5.5.1 Slope Characteristics**

*The following slope sections were analyzed for stability under static and earthquake conditions:*

- *Section through intake structure.*
- *Section of the riverbank upstream of intake structure.*

*The slope cross section, soil properties, and design conditions for the riverbank upstream of the intake structure are shown in figure 2A-27.*

**2.5.5.2 Design Criteria and Analyses**

*Refer to paragraph 2.5.4.11.*

**2.5.5.3 Logs of Core Borings**

*Graphic logs of test borings made for the design of the principal structures of HNP-1 and HNP-2 are presented in supplement 2B. A discussion of the methods used and results obtained is included in sections 2A.1 and 2A.2. The boring locations are shown in figures 2A-1 and 2A-2.*

**2.5.5.4 Compaction Specifications**

*Onsite and locally available offsite sandy clays, clayey sands, and silty fine sands were used as backfill around Seismic Category I structures and in conduit trenches. Backfill was placed on inspected subgrade in thin layers and compacted by vibratory compactors to an average of 95% of the maximum dry density as determined by ASTM D-1557 (Modified Proctor). Representative compaction tests are shown in figure 2A-38.*

REFERENCES

1. Murray, G. E., Geology of the Atlantic and Gulf Coastal Province of North America, Harper & Brothers, New York, 1961.
2. Fenneman, N. M., Physiography of Eastern United States, McGraw-Hill Book Co., New York, 1938.
3. Eardley, A. J., Structural Geology of North America, 2nd Edition, Harper & Row, New York, 1962.
4. Hatcher, R. D., Jr., "Developmental Model for the Southern Appalachians," Geological Society of America Bulletin, Vol. 83, pp 2735-2760, 1972.
5. Bentley, R. D. and Neathery, T. L., Geology of the Brevard Fault Zone and Related Rocks of the Inner Piedmont of Alabama, Alabama Geological Society, Guidebook for the Eighth Annual Field Trip, 1970.
6. Neathery, T. L., and Reynolds, T. W., "Stratigraphy and Metamorphism of the Wedowee Group: A Reconnaissance" Preliminary draft for publication in the American Journal of Science, 1973.
7. Milton, C., and Hurst, V. J., Subsurface "Basement" Rocks of Georgia, Georgia Geological Survey, Bulletin 76, 1965.
8. Herrick, S. M., and Vorhis, R. C., Subsurface Geology of the Georgia Coastal Plain, Geological Survey of Georgia, Inf. Circ. 25, 1963.
9. Stephenson, L. W., "Marine Transgressions and Regressions of the Gulf Coastal Plain," American Journal of Science, 5th Ser., Vol. 16, No. 94, pp 281-298, 1928.
10. Siple, G. E., Guidebook for the South Carolina Coastal Plain Field Trip of the Carolina Geological Society 1957, South Carolina State Division of Geology, Bulletin 24, 1959.
11. Patterson, S. H., and Herrick, S. M., Chattahoochee Anticline, Apalachicola Embayment, Gulf Trough and Related Structural Features, Southwestern Georgia, Fact or Fiction: Geological Survey of Georgia, Inf. Circ. 41, 1971.
12. Olson, N. K., ed., Geology of the Miocene and Pliocene Series in the North Florida-South Georgia Area: Atlantic Coastal Plain Geological Association and Southeastern Geological Society, Guidebook for 1966 Annual Field Conference, 1966.
13. Sever, C. W., Cathcard, J. B., and Patterson, S. H., Phosphate Deposits of South-Central Georgia and North-Central Peninsular Florida: Geological Survey of Georgia, South Georgia Minerals Program, Project Report No. 7, 1967.

14. *Maher, J. C., Correlations of Subsurface Mesozoic and Cenozoic Rocks Along the Atlantic Coast, American Association Pet. Geol., Tulsa, Okla., 1965.*
15. *King, P. B., "Tectonics of Quaternary Time in Middle North America," in Wright, M. E., Jr., and Frey, D. G., The Quaternary of the United States, Princeton University Press, Princeton, N. J., pp 831-870, 1965.*
16. *Toulmin, L. D., "Cenozoic Geology of Southeastern Alabama, Florida, and Georgia," AAPG Bulletin, Vol 39, No. 2, pp 207-236, 1955.*
17. *Sever, C. W., "The Chattahoochee Anticline in Georgia," Georgia Mineral Newsletter, Vol 17, pp 39-43.*
18. *Maher, J. C., and Applin, E. R., Correlation of Subsurface Mesozoic and Cenozoic Rocks Along the Eastern Gulf Coast, American Association Pet. Geol., Cross Sect. Publ. 6, 1968.*
19. *Hager, D., "Possible Oil and Gas Fields In the Cretaceous Beds of Alabama," Amer. Inst. of Mining Engineers, Transactions, Vol 59, 1918.*
20. *Adams, G. I., "The Streams of the Coastal Plain of Alabama and the Lafayette Problem," Journal of Geology, Vol 37, 1929.*
21. *Toulmin, L. D. and LaMoreaux, P. E., Stratigraphy Along Chattahoochee River, Connecting Link Between Atlantic and the Gulf Coastal Plain, Geological Survey of Alabama, Reprint Series 4, pp 385-404, 1963.*
22. *Zapp, A. D., Bauxite Deposits of the Andersonville District, Georgia: United States Geological Survey (USGS) Bulletin 1199 - G, 1965.*
23. *Applin, P. L., and Applin, E. R., "Regional Subsurface Stratigraphy and Structure of Florida and Southern Georgia," AAPG Bulletin, Vol 28, No. 13, pp 1673-1753, 1944.*
24. *Sever, C. W., Miocene Structural Movements in Thomas County, Georgia, USGS, Prof. Paper 550-C, pp C12-C16, 1966.*
25. *U.S. Department of Commerce NEWS, Release NOAA 72-122, September 22, 1972.*
26. *Herrick, S. M., Well Logs of the Coastal Plain of Georgia, Georgia Geological Survey Bulletin 70, 1961.*
27. *Marsalis, W. E., Petroleum Exploration in Georgia, Geological Survey of Georgia, Inf. Circ. 38, 1970.*
28. *Moore, D. B., and Joiner, T. J., A Subsurface Study of Southeast Alabama, Geological Survey of Alabama, Bulletin 88, 1969.*

29. Mineral Resources Map, 1969, State of Georgia, Department of Mines, Mining, and Geology, Scale 1:500,000.
30. Cooke, C. W., Geology of Coastal Plain of Georgia: USGS Bulletin 941, 1943.
31. Eppley, R. A., Earthquake History of the United States, Part I: U.S. Department of Commerce, Coast and Geodetic Survey, 1965.
32. "Seismic History of the Southeast Region of the United States": Computer Printout from Oak Ridge National Laboratory, Oak Ridge, Tennessee; includes area bounded by 27.0° N latitude, 35.4° N latitude, 80.0° W longitude, 90.0° W longitude.
33. "Hypocenter Data File": Computer Printout from Earthquake Information Center, Boulder, Colorado; includes area bounded by 27.0° to 35.4° N latitude, 80.0° to 90.0° W longitude, 1961 to 1974.
34. United States Earthquakes (1963): U.S. Department of Commerce, U.S. Government Printing Office, Washington, D.C.
35. Dutton, C. E., "The Charleston Earthquake of August 31, 1886": Annual Report, USGS 1887 to 1888, pp 203-528, 1889.
36. Bollinger, G. A., "Seismicity of the Southeastern United States," Bulletin Seism. Soc. Amer. Vol 63, No. 5, pp 1785-1808, 1973.
37. Bollinger, G. A., "Historical and Recent Seismic Activity in South Carolina:" Bulletin Seism. Soc. Amer., Vol 62, No. 3, p. 851-864, 1972.
38. Reed, J. C., Jr., Bryant, B., and Mayers, W. B., "The Brevard Zone: A Reinterpretation", in Fisher, G. W., et al., Studies of Appalachian Geology: Central and Southern, John Wiley and Sons, New York, N. Y., pp 261-269, 1970.
39. Reed, J. C., Jr., and Bryant, B., "Evidence for Strike-Slip Faulting along the Brevard Zone in North Carolina". Geol. Soc. of America Bulletin, Vol 75, pp 1177-1196, 1964.
40. Hurst, V. J., "The Piedmont in Georgia," in Fisher, G. W., et al., Studies of Appalachian Geology: Central and Southern, John Wiley and Sons, New York, N. Y., pp 383-396, 1970.
41. Grant, W. H., "Movements in the Towaliga Fault Zone, Pike and Lamar Counties, Georgia," Geological Society of America, Abstracts for 1968, Spec. Paper 121, pp 440-441, 1969.
42. Overstreet, W. C., and Bell, H. B., III, The Crystalline Rocks of South Carolina, USGS, Bulletin 1183, 1965.

43. Bentley, R. D., "Strike Slip Faults in Lee County, Alabama," Geological Society of America Abstracts, Columbia, South Carolina, p 5, 1969.
44. Bentley, R. D., "Geology of Harris County, Georgia," Georgia Geological Survey, Open File Report, pp 1-41, 1973.
45. Bentley, R. D., *et al.*, 1974a, "Preliminary Interpretation of an Aeromagnetic Map of Most of the Central and Southern Georgia Piedmont," Geological Society of America Abstracts, Atlanta, Georgia, p 333.
46. Bentley, R. D., *et al.*, 1974b, "Preliminary Interpretation of Aeromagnetic and Aeroradioactivity Maps of the Crystalline Rocks of Alabama: Part IV, Geophysical Evidence for Major Fault Zones and Associated Meganappes in Alabama Piedmont," Geological Society of America Abstracts, Atlanta, Georgia, pp 334-335.
47. Black, W. E. and Nelson, J. S., "Geophysical Report: Ground Magnetic Survey, Columbus, Georgia," Harding-Lawson Associates, San Rafael, Ca. (Unpublished), 1973.
48. Clarke, J. W., "Geology and Mineral Resources of the Thomaston Quadrangle, Georgia," Georgia Geological Survey, Bulletin 59, pp 73-80, 1952.
49. De Boer, J., "Paleomagnetic - Tectonic Study of Mesozoic Dike Swarms in the Appalachians," Journal of Geophysical Research, Vol 72, No. 8, pp 2237-2247, 1967.
50. Griffin, V. S., "Position of the Kings Mountain Belt in Abbeville County, South Carolina," Southeastern Geology, Vol 12, 1970.
51. Hadley, J. B. and Devine, J. F., Seismotectonic Map of the Eastern United States, U.S. Geological Survey, Misc. Field Investigations, MF-620, 8 pp and 3 maps, 1975.
52. Hatcher, R. D., "Recent Trends in Thought and Research on Southern Appalachian Tectonics," Southeastern Geology, Vol 14, No. 3, pp 131-151, 1972.
53. Hewett, D. F. and Crickmay, G. W., The Warm Springs of Georgia-Their Geologic Relations and Origin, U.S. Geological Survey, Water Supply Paper 819, 1937.
54. Higgins, M. W., "Cataclastic Rocks," USGS Professional Paper 687 pp 46-50, 1971.
55. Holland, W. A. and Schamel, S., "Structural Relations between the Uchee Block and the Goat Rock - Bartletts Ferry Mylonite Zone, Alabama - Georgia Piedmont," Geological Society of America Abstracts, Knoxville, Tennessee, p 405, 1973.
56. Howell, D. E., "Major Structural Features of South Carolina," Geological Society of America Abstracts, Arlington, Virginia, pp 200-201, 1976.

57. Humphrey, R. C., *The Geology of the Crystalline Rocks of Greene and Hancock Counties, Georgia, University of Georgia, M.S. Thesis, pp 9-14, 1970.*
58. King, P. B., "Systematic Pattern of Triassic Dikes in the Appalachian Region," U.S. Geological Survey, *Short Papers in the Geologic and Hydrologic Sciences, Article 41, pp B-93 - B-95, 1961.*
59. Lester, J. G. and Allen, A. T., "Diabase of the Georgia Piedmont," *Geological Society of America Bulletin, Vol 61, pp 1217-1224, 1950.*
60. Libby, S. C., *Petrology of Igneous Rocks of Putnam County Georgia, University of Georgia, M.S. Thesis, pp 4-13, 1971.*
61. Morgan, B. A., *Metamorphic Map of Appalachians, U.S. Geological Survey, Miscellaneous Geologic Investigation, Map I - 724, 1972.*
62. O'Connor, B. J., *et al.*, "Recently Discovered Faults in the Central Savannah River Area," *Georgia Academy of Science, Vol 32, p 15, 1974.*
63. Sandrock, G. S. and Penley, H. M., "Geologic Map of the Pine Mountain Series and Adjacent Areas in the Southwest Georgia Piedmont," *Geological Society of America Abstracts, Atlanta, Georgia, p 395, 1974.*
64. Scheffler, P. and Talwani, P., "Recent Earthquakes in the South Carolina Piedmont," *Geological Society of America Abstracts, Memphis, Tennessee, pp 530-531, 1975.*
65. Talwani, P., 1975a, *Crustal Structure of South Carolina, Semi-Annual Technical Report, University of South Carolina, USGS Contract 14-08-0001-14553.*
66. Talwani, P., 1975b, *Crustal Structure of South Carolina, Second Technical Report, University of South Carolina, USGS Contract 14-08-0001-14553.*
67. Talwani, P., *et al.*, "Preliminary Crustal Studies in South Carolina," *Seismological Society of America Abstracts, Los Angeles, California, p 425, 1975.*
68. Talwani, P. and Howell, D. E., "Crustal Structure of South Carolina - Some Speculations," *Geological Society of America Abstracts, Arlington, Virginia, p 284, 1976.*
69. Wampler, J. M., *et al.*, "Age Relations in the Alabama Piedmont," *Alabama Geological Society 8th Annual Field Trip Guidebook, pp 81-90, 1970.*
70. Zietz, I., *et al.*, "Preliminary Interpretation of Aeromagnetic and Aeroradioactivity Maps of the Crystalline Rocks of Alabama, Part II, The Aeromagnetic and Aeroradioactivity Data," *Geological Society of America Abstracts, Atlanta, Georgia, p 416, 1974.*
71. Cramer, H., *The Elements of Probability Theory and Some of its Applications, John Wiley and Sons, Inc., 1955.*



72. Daniels, D. L., Geologic Interpretation of Geophysical Maps, Central Savannah River Area, South Carolina and Georgia, USGS Geophysical Investigations, Map GP-893, 1974.
73. Denman, H. E., Implications of Seismic Activity at the Clark Hill Reservoir, Unpublished M.S. Thesis, Georgia Institute of Technology, 1974.
74. Hatcher, R. D., The Goat Rock Fault: Extent, Timing, and Sense of Movement, Unpublished report to Bechtel Corp., March 22, 1976.
75. Jackson, David D., "Most Squares Inversion," Journal of Geophysical Research, Vol 81, No. 5, pp 1027-1030, 1976.
76. McClain, W. C. and O. H. Myers, Seismic History and Seismicity of the Southeastern Region of the United States, ORNL-4582, 1970.
77. Rankin, D. W., "The Continental Margin of Eastern North America in the Southern Appalachians: The Opening and Closing of the Proto-Atlantic Ocean." American Journal of Science, Vol 274-A, pp 298-336, 1975.
78. Reid, H. F., Reid Earthquake Catalog, Unpublished Collection of Earthquake and Volcano Data, U.S. Department of Commerce, NOAA, Boulder, Colorado.
79. Rockwood, C. G., "Notices of Recent American Earthquakes," American Journal of Science and Arts, 3rd Series, Vol 19, p 299, 1880.
80. Tarr, A. C., et al., "Recent Seismicity in the Source Area of the 1886 Charleston, South Carolina Earthquake," Geological Survey of America Abstract and Oral Presentation, Arlington, Virginia, 1976.
81. Tewhey, J., "The Transition Between Metamorphic Belts in the Southeastern Edge of the Carolina Slate Belt, South Carolina," Geological Survey of America Abstracts, Knoxville, Tennessee, p 443, 1973.
82. Geologic Map of Georgia, 1:500,000, Georgia Geologic Survey, 1975.
83. Ackerman, H. D., "Exploring the Charleston, South Carolina Earthquake Area by Seismic Refraction," Geological Society of America Abstracts, Vol 8, No. 2, pp 121-122, 1976.
84. Phillips, J. D., "Magnetic Basement Near Charleston, South Carolina," Geological Society of America Abstracts, Vol 8, No. 2, p 245, 1976.
85. Gohn, G. S., et al., "Lithostratigraphy of the Clubhouse Crossroads Core; Charleston Project, South Carolina," Geological Society of America Abstracts, Vol 8, pp 181-183, 1976.

86. Popenoe, P., "The Charleston Earthquake - the Search for a Geologic Cause - New Magnetic and Gravity Data," Geological Society of America Abstracts, Vol 7, p 254, 1975.
87. Campbell, D., "Electric and Electromagnetic Soundings Near Charleston, South Carolina," Geological Society of America Abstracts, Vol 8, No. 2, p 146, 1976.
88. Popenoe, P., Phillips, J. D., Higgins, B. B., "Lithology and Structure of the Basement in the Charleston, South Carolina Area from Interpretation of Gravity and Magnetic Data," Geological Society of America Abstracts, Vol 8, No. 2, p 248, 1976.
89. Higgins, B. B., et al., "Structures in the Coastal Plain of South Carolina," Geological Society of America Abstracts, Vol 8, No. 2, pp 195-196, 1976.
90. Bollinger, G. A., "Reinterpretation of the Intensity Effects of the 1886 Charleston, South Carolina, Earthquake," Geological Society of America Abstracts, Vol 8, No. 2, pp 139-140, 1976.
91. Long, L. T., "A Model for the Earthquake Tectonics of the Bowman and Summerville, South Carolina, Epicentral Zones," Geological Society of America Abstracts, Southeastern Section, p 511, 1975.
92. Prowell, D. C., O'Connor, B. J., and Rubin, M., "Preliminary Evidence for Holocene Movement along the Belair Fault Zone near Augusta, Georgia," USGS Open File Report 75-680, 1976.
93. O'Connor, B. J. and Prowell, D. C., "Post-Cretaceous Faulting along the Belair Fault Zone near Augusta, Georgia," Geological Society of America Abstracts, Vol 8, No. 2, pp 236-237, 1976.
94. Owens, J. P., Prowell, D. C. and Higgins, B. B., "Tectonic Origin of Deformed Strata in the Upper Coastal Plain of South Carolina," Geological Society of America Abstracts, Vol 8, No. 2, p 240, 1976.
95. Marine, I. W., "Structural Model of the Buried Dunbarton Triassic Basin in South Carolina and Georgia," Geological Society of America Abstracts, Vol 8, No. 2, p 255, 1976.
96. Neathery, T. L., Higging, M. W., Zietz, I., and Bentley, R. D., "Aeromagnetic and Aeroradioactivity Maps of the Crystalline Rocks of Alabama," Geological Society of America Abstracts, Vol 5, No. 7, p 873, 1973.
97. Higgins, M. W. et al., "Preliminary Interpretation of Aeromagnetic and Aeroradioactivity Maps of the Crystalline Rocks of Alabama: Part III, Value of the Geophysical Maps for Geologic Mapping and Interpretation," Geological Society of America Abstracts, Vol 6, No. 4, p 365, 1974.
98. Cook, R. B. and Neathery, T. L., "Surface Investigation of Aeroradiometric Anomalies in the Alabama Piedmont," Geological Society of America Abstracts, Vol 8, No. 3, p 154, 1976.

HNP-2-FSAR-2

99. Neathery, T. L., *et al.*, "Preliminary Interpretation of Aeromagnetic and Aeroradioactivity Maps of the Crystalline Rocks of Alabama; Part I, Geologic Outline," Geological Society of America Abstracts, Vol 6, No. 4, p 383, 1976.
100. Lawton, D. E., *et al.*, "Correspondence Between Geology and Contoured Aeroradioactivity in the Georgia Piedmont," Geological Society of America Abstracts, Vol 8, No. 2, pp 214-215, 1976.
101. Bridges, S. Rutt and Long, L. T., "Recent Seismic Activity in the Clark Hill Reservoir Area on the Georgia - South Carolina Border," Geological Society of America Abstracts, Southeastern Section, p 473, 1976.
102. Bollinger, G. A., "Seismicity and Crustal Uplift in the Southeastern United States," American Journal of Science, Cooper Vol 273-A, pp 396-408, 1973.
103. Zietz, I., Popenoe, P., and Higgins, B. B., "Regional Structure of the Southeastern United States as Interpreted from New Aeromagnetic Maps of Part of the Coastal Plain of North Carolina, South Carolina, Georgia, and Alabama," Geological Society of America Abstracts, Vol 8, No. 3, p 307, 1976.

**TABLE 2.5-1 (SHEET 1 OF 8)**

**MODIFIED MERCALLI INTENSITY SCALE, 1931<sup>(a)</sup>**

- I. *Not felt except rarely under especially favorable circumstances. Under certain conditions, at and outside the boundary of the area in which a great shock is felt:*
- *Sometimes birds, animals reported uneasy or disturbed.*
  - *Sometimes dizziness or nausea experienced.*
  - *Sometimes trees, structures, liquids, bodies of water may sway; doors may swing, very slowly.*
- II. *Felt indoors by few, especially on upper floors, or by sensitive or nervous persons. Also, as in grade I, but often more noticeably:*
- *Sometimes hanging objects may swing, especially when delicately suspended.*
  - *Sometimes trees, structures, liquids, bodies of water may sway; doors may swing, very slowly.*
  - *Sometimes birds, animals reported uneasy or disturbed.*
  - *Sometimes dizziness or nausea experienced.*
- III. *Felt indoors by several; motion usually rapid vibration:*
- *Sometimes not recognized to be an earthquake at first.*
  - *Duration estimated in some cases.*
  - *Vibration like that due to passing of light, or lightly loaded trucks, or heavy trucks some distance away.*
  - *Hanging objects may swing slightly.*
  - *Movements may be appreciable on upper levels of tall structures.*
  - *Rocked standing motor cars slightly.*

a. *Adapted from Sieberg's (1923) Mercalli-Cancani scale, modified and condensed. Quoted from Wood and Neumann (1931).*

**TABLE 2.5-1 (SHEET 2 OF 8)**

IV. *Felt indoors by many; outdoors by few:*

- *Awakened few, especially light sleepers.*
- *Frightened no one, unless apprehensive from previous experience.*
- *Vibration like that due to passing of heavy, or heavily loaded trucks.*
- *Sensation like heavy body striking building, or falling of heavy objects inside.*
- *Rattling of dishes, windows, doors; glassware and crockery clink and clash.*
- *Creaking of walls, frame, especially in the upper range of this grade.*
- *Hanging objects swung, in numerous instances.*
- *Disturbed liquids in open vessels slightly.*
- *Rocked standing motor cars noticeably.*

V. *Felt indoors by practically all; outdoors by many or most; outdoors direction estimated:*

- *Awakened many, or most.*
- *Frightened few; slight excitement; a few ran outdoors.*
- *Buildings trembled throughout.*
- *Broke dishes, glassware, to some extent.*
- *Cracked windows in some cases, but not generally.*
- *Overtured vases, small or unstable objects, in many instances, with occasional fall.*
- *Hanging objects, doors, swung generally or considerably.*
- *Knocked pictures against walls, or swung them out of place.*
- *Opened, or closed, doors, shutters, abruptly.*
- *Pendulum clocks stopped, started, or ran fast or slow.*
- *Moved small objects, furnishings, the latter to slight extent.*

**TABLE 2.5-1 (SHEET 3 OF 8)**

- *Spilled liquids in small amounts from well-filled open containers.*
- *Trees, bushes, shaken slightly.*

VI. *Felt by all, indoors and outdoors:*

- *Frightened many; excitement general; some alarm, many ran outdoors.*
- *Awakened all.*
- *Persons made to move unsteadily.*
- *Trees and bushes shaken slightly to moderately.*
- *Liquid set in strong motion.*
- *Small bells rang (church, chapel, school, etc.).*
- *Damage slight in poorly built buildings.*
- *Fall of plaster in small amount.*
- *Cracked plaster somewhat, especially fine cracks, chimneys in some instances.*
- *Broke dishes, glassware, in considerable quantity, also some windows.*
- *Fall of knick-knacks, books, pictures.*
- *Overtured furniture in many instances.*
- *Moved furnishings of moderately heavy kind.*

VII. *Frightened all; general alarm; all ran outdoors:*

- *Some, or many, found it difficult to stand.*
- *Noticed by persons driving motor cars.*
- *Trees and bushes shaken moderately to strongly.*
- *Waves on ponds, lakes, and running water.*

**TABLE 2.5-1 (SHEET 4 OF 8)**

- *Water turbid from mud stirred up.*
- *Incaving to some extent of sand or gravel stream banks.*
- *Rang large church bells, etc.*
- *Suspended objects made to quiver.*
- *Damage negligible in buildings of good design and construction, slight to moderate in well-built ordinary buildings, considerable in poorly built or badly designed buildings, adobe houses, old walls (especially where laid-up without mortar), spires, etc.*
- *Cracked chimneys to considerable extent, walls to some extent.*
- *Fall of plaster in considerable to large amount, also some stucco.*
- *Broke numerous windows, furniture to some extent.*
- *Shook down loosened brickwork and tiles.*
- *Broke weak chimneys at the roofline (sometimes damaging roofs).*
- *Fall of cornices from towers and high buildings.*
- *Dislodged bricks and stones.*
- *Overtured heavy furniture, with damage from breaking.*
- *Damage considerable to concrete irrigation ditches.*

*VIII. Fright general; alarm approaches panic:*

- *Disturbed persons driving motor cars.*
- *Trees shaken strongly, branches, trunks, broken off, especially palm trees.*
- *Ejected sand and mud in small amounts.*
- *Changes: temporary, permanent; in-flow of springs and wells; dry wells renewed flow; in temperature of spring and well waters.*
- *Damage slight in structures (brick) built especially to withstand earthquakes.*

**TABLE 2.5-1 (SHEET 5 OF 8)**

- *Considerable damage in ordinary substantial buildings, partial collapse; racked, tumbled down, wooden houses in some cases; threw out panel walls in frame structures, broke off decayed piling.*
  - *Fall of walls.*
  - *Cracked, broke, solid stone walls seriously.*
  - *Wet ground to some extent, also ground on steep slopes.*
  - *Twisting, fall, of chimneys, columns, monuments, also factory stacks, towers.*
  - *Moved conspicuously; overturned very heavy furniture.*
- IX. *Panic general:*
- *Cracked ground conspicuously.*
  - *Damage considerable in (masonry) structures built especially to withstand earthquakes:*
    - *Threw out of plumb some wood frame houses built especially to withstand earthquakes.*
    - *Great in substantial (masonry) buildings, some collapse in large part; or wholly shifted frame buildings off foundations, racked frames.*
    - *Serious to reservoirs; underground pipes sometimes broken.*
- X. *Cracked ground, especially when loose and wet, up to widths of several inches; fissures up to a yard in width ran parallel to canal and stream banks:*
- *Landslides considerable from riverbanks and steep coasts.*
  - *Shifted sand and mud horizontally on beaches and flat land.*
  - *Changed level of water in wells.*
  - *Threw water on banks of canals, lakes, rivers, etc.*
  - *Damage serious to dams, dikes, embankments.*
  - *Damage severe to well-built wooden structures and bridges; some destroyed.*
  - *Developed dangerous cracks in excellent brick walls.*



**TABLE 2.5-1 (SHEET 6 OF 8)**

- *Destroyed most masonry and frame structures, also their foundations.*
- *Bent railroad rails slightly.*
- *Tore apart, or crushed endwise, pipe lines buried in earth.*
- *Open cracks and broad wave folds in cement pavements and asphalt road surfaces.*

*XI. Disturbances in ground many and widespread, varying with ground material:*

- *Broad fissures, earth slumps, and land slips in soft, wet ground.*
- *Ejected water in large amount charged with sand and mud.*
- *Caused sea waves (tidal waves) of significant magnitude.*
- *Damage severe to wood frame structures, especially near shock centers.*
- *Great to dams, dikes, embankments, often for long distances.*
- *Few, if any (masonry), structures remained standing.*
- *Destroyed large well-built bridges by the wrecking of supporting piers or pillars.*
- *Affected yielding wooden bridges less.*
- *Bent railroad rails greatly, and thrust them endwise.*
- *Put pipe lines buried in earth completely out of service.*

*XII. Damage total; practically all works of construction damaged greatly or destroyed:*

- *Disturbances in ground great and varied, numerous shearing cracks.*
- *Landslides, falls of rock of significant character, slumping of riverbanks, etc., numerous and extensive.*
- *Wrenched loose, tore off, large rock masses.*
- *Fault slips in firm rock, with notable horizontal and vertical offset displacements.*
- *Water channels, surface and underground, disturbed and modified greatly.*

**TABLE 2.5-1 (SHEET 7 OF 8)**

- *Dammed lakes, produced waterfalls, deflected rivers, etc.*
- *Waves seen on ground surfaces (actually seen, probably in some cases).*
- *Distorted lines of sight and level.*
- *Threw objects upward into the air.*

**MODIFIED MERCALLI INTENSITY SCALE OF 1931 (Abridged)**

- I. *Not felt except by a very few under especially favorable circumstances.*
- II. *Felt only by a few persons at rest, especially on upper floors of buildings. Delicately suspended objects may swing.*
- III. *Felt quite noticeably indoors, especially on upper floors of buildings, but many people do not recognize it as an earthquake. Standing motor cars may rock slightly. Vibration like passing of truck. Duration estimated.*
- IV. *During the day, felt indoors by many, outdoors by few. At night some awakened. Dishes, windows, doors disturbed; walls made cracking sound. Sensation like heavy truck striking building. Standing motor cars rocked noticeably.*
- V. *Felt by nearly everyone; many awakened. Some dishes, windows, etc., broken; a few instances of cracked plaster; unstable objects overturned. Disturbance of trees, poles and other tall objects sometimes noticed. Pendulum clocks may stop.*
- VI. *Felt by all; many frightened and run outdoors. Some heavy furniture moved; a few instances of fallen plaster or damaged chimneys. Damage slight.*
- VII. *Everybody runs outdoors. Damage negligible in buildings of good design and construction; slight to moderate in well-built ordinary structures; considerable in poorly built or badly designed structures; some chimneys broken. Noticed by persons driving motor cars.*
- VIII. *Damage slight in specially designed structures; considerable in ordinary substantial buildings with partial collapse; great in poorly built structures. Panel walls thrown out of frame structures. Fall of chimneys, factory stacks, columns, monuments, walls. Heavy furniture overturned. Sand and mud ejected in small amounts. Changes in well water. Disturbed persons driving motor cars.*
- IX. *Damage considerable in specially designed structures; well-designed frame structures thrown out of plumb; great in substantial buildings, with partial collapse. Buildings shifted off foundations. Ground cracked conspicuously. Underground pipes broken.*

**TABLE 2.5-1 (SHEET 8 OF 8)**

- X. *Some well-built wooden structures destroyed; most masonry and frame structures destroyed with foundations; ground badly cracked. Rails bent. Landslides considerable from riverbanks and steep slopes. Shifted sand and mud. Water splashed (slopped) over banks.*
- XI. *Few, if any (masonry), structures remain standing. Bridges destroyed. Broad fissures in ground. Underground pipe lines completely out of service. Earth slumps and land slips in soft ground. Rails bent greatly.*
- XII. *Damage total. Waves seen on ground surfaces. Lines of sight and level distorted. Objects thrown upward into the air.*

TABLE 2.5-2 (SHEET 1 OF 3)

**CHRONOLOGICAL LISTING OF EARTHQUAKES WITHIN 200 MILES  
OF THE EDWIN I. HATCH NUCLEAR PLANT**

| <u>Date</u> | <u>Latitude<br/>N</u> | <u>Longitude<br/>W</u> | <u>Locality</u>             | <u>Epicentral<br/>Intensity<br/>(MM)</u> | <u>Magnitude</u> | <u>Felt<br/>Area<br/>(mi<sup>2</sup>)</u> | <u>Seismic<br/>Area</u> | <u>Distance<br/>From<br/>Site (mi)</u> | <u>Reference</u> |
|-------------|-----------------------|------------------------|-----------------------------|------------------------------------------|------------------|-------------------------------------------|-------------------------|----------------------------------------|------------------|
| 1872, 6-17  | (22.1                 | 83.3) <sup>(a)</sup>   | Milledgeville, Ga.          | V                                        |                  |                                           | Appalachian             | 100                                    | Eppley           |
| 1875, 11-01 | (33.8                 | 82.5)                  | Northern Georgia            | VI                                       |                  | 25,000                                    | Appalachian             | 135                                    | Eppley           |
| 1879, 1-12  | (29.5                 | 82.0)                  | Northern Florida-2 events   | VI                                       |                  | 25,000                                    | Coastal Plain           | 170                                    | Eppley           |
| 1885, 10-17 | (33.0                 | 82.8)                  | Sandersville, Ga.           | IV                                       |                  |                                           | Coastal Plain           | 85                                     | Oak Ridge        |
| 1886, 8-27  | (33.1                 | 80.2)                  | Near Charleston, S.C.       | V                                        |                  |                                           | Charleston              | 152                                    | Oak Ridge        |
| 1886, 8-31  | (32.9                 | 80.0)                  | Charleston, S.C.-2 events   | X                                        |                  | 2,000,000                                 | Charleston              | 155                                    | Eppley           |
| 1886, 9-03  | (32.9                 | 80.0)                  | Charleston, S.C.            | VI                                       |                  |                                           | Charleston              | 155                                    | Oak Ridge        |
| 1886, 9-05  | (32.9                 | 80.0)                  | Charleston, S.C.            | VI                                       |                  |                                           | Charleston              | 155                                    | Oak Ridge        |
| 1886, 9-21  | (32.9                 | 80.0)                  | Charleston, S.C.            | V-VI                                     |                  |                                           | Charleston              | 155                                    | Oak Ridge        |
| 1886, 9-27  | (32.9                 | 80.0)                  | Charleston, S.C.            | VI                                       |                  |                                           | Charleston              | 155                                    | Oak Ridge        |
| 1886, 10-22 | (32.9                 | 80.0)                  | Charleston, S.C.            | VI                                       |                  | 30,000                                    | Charleston              | 155                                    | Eppley           |
| 1886, 10-22 | (32.9                 | 80.0)                  | Charleston, S.C.            | VII                                      |                  | 30,000                                    | Charleston              | 155                                    | Eppley           |
| 1886, 11-05 | (32.9                 | 80.0)                  | Charleston, S.C.            | VI                                       |                  | 30,000                                    | Charleston              | 155                                    | Eppley           |
| 1887, 1-04  | (32.9                 | 80.0)                  | Charleston, S.C.            | VI                                       |                  |                                           | Charleston              | 155                                    | Eppley           |
| 1887, 6-03  | (32.9                 | 80.0)                  | Charleston, S.C.            | IV                                       |                  |                                           | Charleston              | 155                                    | Oak Ridge        |
| 1888, 1-12  | (32.9                 | 80.0)                  | Charleston, S.C.            | VII                                      |                  |                                           | Charleston              | 155                                    | Oak Ridge        |
| 1893, 6-21  | (30.4                 | 81.7)                  | Jacksonville, Fla.          | IV                                       |                  |                                           | Coastal Plain           | 112                                    | Oak Ridge        |
| 1900, 10-12 | (30.4                 | 81.7)                  | Jacksonville, Fla.-8 events | V                                        |                  | Local                                     | Coastal Plain           | 112                                    | Oak Ridge        |
| 1901, 12-01 | (32.9                 | 80.0)                  | Charleston, S.C.            | IV-V                                     |                  |                                           | Charleston              | 158                                    | Oak Ridge        |
| 1903, 1-23  | (32.8                 | 80.0)                  | Charleston, S.C.            | IV                                       |                  |                                           | Charleston              | 152                                    | Oak Ridge        |

TABLE 2.5-2 (SHEET 2 OF 3)

| <u>Date</u> | <u>Latitude<br/>N</u> | <u>Longitude<br/>W</u> | <u>Locality</u>              | <u>Epicentral<br/>Intensity<br/>(MM)</u> | <u>Magnitude</u> | <u>Felt<br/>Area<br/>(mi<sup>2</sup>)</u> | <u>Seismic<br/>Area</u> | <u>Distance<br/>From<br/>Site (mi)</u> | <u>Reference</u> |
|-------------|-----------------------|------------------------|------------------------------|------------------------------------------|------------------|-------------------------------------------|-------------------------|----------------------------------------|------------------|
| 1903, 1-23  | (32.1                 | 81.1)                  | Savannah, Ga.                | VI                                       |                  | 10,000                                    | Coastal Plain           | 76                                     | Oak Ridge        |
| 1907, 4-19  | (32.9                 | 80.0)                  | Charleston, S.C.             | V                                        |                  | 10,000                                    | Charleston              | 155                                    | Eppley           |
| 1908, 1-15  | (33.0                 | 80.2)                  | Summerville, S.C.            | III-IV                                   |                  |                                           | Charleston              | 148                                    | Oak Ridge        |
| 1908, 3-03  | (33.1                 | 80.2)                  | Summerville, S.C.            | III-IV                                   |                  |                                           | Charleston              | 152                                    | Oak Ridge        |
| 1908, 3-07  | (33.1                 | 80.2)                  | Summerville, S.C.            | III-IV                                   |                  |                                           | Charleston              | 152                                    | Oak Ridge        |
| 1908, 10-28 | (33.1                 | 80.2)                  | Summerville, S.C.            | III-IV                                   |                  |                                           | Charleston              | 152                                    | Oak Ridge        |
| 1912, 6-12  | (32.9                 | 80.0)                  | Summerville, S.C.            | VII                                      |                  | 35,000                                    | Charleston              | 155                                    | Eppley           |
| 1912, 6-20  | (32.0                 | 81.0)                  | Savannah, Ga.                | V                                        |                  |                                           | Coastal Plain           | 83                                     | Oak Ridge        |
| 1912, 10-22 | (32.7                 | 83.5)                  | Macon, Ga.                   | IV                                       |                  | 1,500                                     | Coastal Plain           | 88                                     | Oak Ridge        |
| 1912, 12-07 | (34.7                 | 81.7)                  | Union County, S.C.           | III-IV                                   |                  |                                           | Appalachian             | 196                                    | Oak Ridge        |
| 1913, 1-01  | (34.7                 | 81.7)                  | Union County, S.C.           | VII-VIII                                 |                  | 43,000                                    | Appalachian             | 196                                    | Oak Ridge        |
| 1914, 3-05  | (33.5                 | 83.5)                  | Morgan County, S.C.          | VI                                       |                  | 50,000                                    | Appalachian             | 130                                    | Eppley           |
| 1914, 9-22  | (33.0                 | 80.3)                  | Near Summerville, S.C.       | V                                        |                  | 30,000                                    | Charleston              | 140                                    | Oak Ridge        |
| 1916, 3-02  | (34.5                 | 82.7)                  | Anderson, S.C.-6 events      | IV-V                                     |                  |                                           | Appalachian             | 182                                    | Oak Ridge        |
| 1923, 12-31 | (34.8                 | 82.5)                  | Greenville, S.C.             | IV                                       |                  |                                           | Appalachian             | 199                                    | Oak Ridge        |
| 1933, 12-19 | (33.0                 | 80.2)                  | Summerville, S.C.            | IV-V                                     |                  | Local                                     | Charleston              | 148                                    | Oak Ridge        |
| 1934, 12-09 | (33.0                 | 80.2)                  | Summerville, S.C.            | IV                                       |                  |                                           | Charleston              | 148                                    | Oak Ridge        |
| 1935, 11-13 | (29.9                 | 81.3)                  | St. Augustine, Fla.-2 events | IV                                       |                  |                                           | Coastal Plain           | 151                                    | Oak Ridge        |
| 1943, 12-28 | (33.0                 | 80.2)                  | Summerville, S.C.            | IV                                       |                  |                                           | Charleston              | 148                                    | Oak Ridge        |
| 1945, 7-26  | 34.3                  | 81.4                   | North of Lake Murray, S.C.   | VI                                       |                  | 25,000                                    | Appalachian             | 175                                    | Eppley           |
| 1952, 11-18 | (30.6                 | 84.6)                  | Quincy, Fla.                 | IV                                       |                  |                                           | Coastal Plain           | 160                                    | Oak Ridge        |
| 1952, 11-19 | (32.8                 | 80.0)                  | Charleston, S.C.             | V                                        |                  |                                           | Charleston              | 150                                    | Eppley           |

TABLE 2.5-2 (SHEET 3 OF 3)

| <u>Date</u> | <u>Latitude</u><br><u>N</u> | <u>Longitude</u><br><u>W</u> | <u>Locality</u> | <u>Epicentral</u><br><u>Intensity</u><br><u>(MM)</u> | <u>Magnitude</u> | <u>Felt</u><br><u>Area</u><br><u>(mi<sup>2</sup>)</u> | <u>Seismic</u><br><u>Area</u> | <u>Distance</u><br><u>From</u><br><u>Site (mi)</u> | <u>Reference</u> |           |
|-------------|-----------------------------|------------------------------|-----------------|------------------------------------------------------|------------------|-------------------------------------------------------|-------------------------------|----------------------------------------------------|------------------|-----------|
| 1956,       | 1-05                        | (34.3                        | 82.4)           | Due West, S.C.-2 events                              | IV               |                                                       | Appalachian                   | 168                                                | Oak Ridge        |           |
| 1956,       | 5-19                        | (34.3                        | 82.4)           | Due West, S.C.                                       | IV               |                                                       | Appalachian                   | 168                                                | Oak Ridge        |           |
| 1956,       | 5-27                        | (34.3                        | 82.4)           | Due West, S.C.                                       | IV               |                                                       | Appalachian                   | 168                                                | Oak Ridge        |           |
| 1958,       | 10-20                       | (34.5                        | 82.8)           | Anderson, S.C.                                       | V                |                                                       | Appalachian                   | 183                                                | Oak Ridge        |           |
| 1959,       | 8-03                        | (33.0                        | 79.5)           | East of Charleston, S.C.                             | VI               | 25,000                                                | Coastal Plain                 | 186                                                | Eppley           |           |
| 1960,       | 7-23                        | (33.0                        | 80.0)           | Charleston, S.C.                                     | V                | Local                                                 | Charleston                    | 155                                                | Eppley           |           |
| 1963,       | 4-11                        | (34.8                        | 82.4)           | Greenville, S.C.                                     | IV               |                                                       | Appalachian                   | 199                                                | Oak Ridge        |           |
| 1963,       | 5-04                        | (32.2                        | 79.7)           | Southeast of Charleston, S.C.                        | IV               |                                                       | Coastal Plain                 | 158                                                | USC & GS         |           |
| 1964,       | 3-12                        | (33.2                        | 83.4)           | Macon, Ga.                                           | (V)              | 4.4                                                   | 400                           | Appalachian                                        | 110              | NOAA      |
| 1964,       | 4-20                        | (34.0                        | 81.0)           | Near Columbia, S.C.                                  | V                |                                                       | Coastal Plain                 | 165                                                | Oak Ridge        |           |
| 1967,       | 10-23                       | 33.4                         | 80.7            | Southeast of Orangeburg, S.C.                        | (V)              | 3.8                                                   |                               | Coastal Plain                                      | 143              | NOAA      |
| 1968,       | 9-22                        | 34.0                         | 81.5            | South of Lake Murray, S.C.                           | (IV)             | 3.7                                                   | 400                           | Appalachian                                        | 155              | Oak Ridge |
| 1971,       | 5-19                        | (33.4                        | 80.6)           | East of Orangeburg, S.C.                             | IV               | 3.4                                                   |                               | Coastal Plain                                      | 148              | NOAA      |
| 1971,       | 7-13                        | (34.7                        | 82.9)           | Seneca, S.C.                                         | IV               |                                                       | Appalachian                   | 195                                                | Oak Ridge        |           |
| 1972,       | 2-03                        | 33.5                         | 80.4            | Lake Marion, S.C.                                    | V                | 4.5                                                   |                               | Coastal Plain                                      | 158              | NOAA      |
| 1974,       | 8-02                        | 33.9                         | 82.5            | Lincoln County, Ga.                                  | V                | 4.5-4.9                                               |                               | Appalachian                                        | 140              | NOAA      |
| 1974,       | 11-22                       | 32.9                         | 80.0            | Charleston, S.C.                                     | V-VI             | 4.5                                                   |                               | Charleston                                         | 155              | NOAA      |
| 1976,       | 12-27                       | 32.2                         | 82.5            | Reidsville, Ga.                                      | IV-V             | 3.7                                                   |                               | Coastal Plain                                      | 15               | NOAA      |

a. Parentheses around coordinates indicate an approximate epicentral location.

**TABLE 2.5-3**

**DATA FOR EPICENTERS SHOWN IN FIGURE 2.5-15**

| <u>Date</u>                   | <u>Latitude (N)</u> | <u>Longitude (W)</u> | <u>Magnitude</u> |
|-------------------------------|---------------------|----------------------|------------------|
| <i>October 26, 1879 (F)</i>   | 34.5                | 81.1                 | -                |
| <i>September 22, 1968 (I)</i> | 34.0                | 81.5                 | 3.7              |
| <i>January 4, 1974 (I)</i>    | 33.66               | 82.40                | <1               |
| <i>February 14, 1974 (I)</i>  | 33.62               | 82.48                | 2.7              |
| <i>October 28, 1974 (S)</i>   | 33.79               | 81.92                | 3.0              |
| <i>November 5, 1974 (F)</i>   | 33.73               | 82.22                | 3.7              |
| <i>December 8, 1974 (I)</i>   | 34.17               | 80.81                | 1.0              |
| <i>November 16, 1975 (I)</i>  | 34.28               | 80.55                | 3.0              |

TABLE 2.5-4 (SHEET 1 OF 3)

**CHRONOLOGICAL LISTING OF EARTHQUAKES (INTENSITY III AND GREATER) SHOWN IN FIGURE 2.5-16  
(EXCLUSIVE OF CHARLESTON-SUMMERVILLE AREA)**

| <u>Date</u>    | <u>Locality</u>               | <u>°N</u> | <u>°W</u> | <u>Felt Area<br/>(mi<sup>2</sup>)</u> | <u>Epicentral Intensity/<br/>Magnitude</u> |
|----------------|-------------------------------|-----------|-----------|---------------------------------------|--------------------------------------------|
| 1799, April 11 | Camden, S.C.                  | -         | -         | -                                     | IV <sup>(a)</sup>                          |
| 1826, Oct. 15  | Savannah, Ga.                 | 32.0      | 81.0      | -                                     | _(b)                                       |
| 1872, June 17  | Milledgeville, Ga.            | 33.1      | 83.3      | -                                     | V                                          |
| 1875, July 28  | Milledgeville, Ga.            | 33.1      | 83.3      | -                                     | _(b)                                       |
| 1875, Nov. 1   | N. Georgia                    | 33.8      | 82.5      | 25,000                                | VI                                         |
| 1879, Oct. 26  | Winnsboro, S.C.               | 34.5      | 81.1      | -                                     | III                                        |
| 1884, Mar. 31  | Milledgeville, Ga.            | 33.1      | 83.3      | -                                     | III                                        |
| 1885, Oct. 17  | Sandersville, Ga.             | 33.0      | 82.8      | -                                     | IV                                         |
| 1903, Jan. 23  | Ga.-S.C. region               | 32.1      | 81.1      | 10,000                                | VI                                         |
| 1911, Apr. 20  | N.C.-S.C. area                | 35.2      | 82.7      | 600                                   | V                                          |
| 1912, June 20  | Savannah, Ga.                 | 32.0      | 81.0      | -                                     | V                                          |
| 1912, Oct. 23  | Dublin, Macon, and Perry, Ga. | 32.7      | 83.5      | 1,500                                 | IV                                         |
| 1912, Dec. 7   | Union County, S.C.            | 34.7      | 81.7      | -                                     | III-IV                                     |
| 1913, Jan. 1   | Union County, S.C.            | 34.7      | 81.7      | 43,000                                | VI-VII                                     |
| 1914, Mar. 5   | Near Atlanta, Ga.             | 33.5      | 83.5      | 50,000                                | VI                                         |
| 1914, Mar. 7   | Darlington and Florence, S.C. | 34.3      | 79.8      | -                                     | III-IV                                     |
| 1916, Mar. 2   | Anderson, S.C.                | 34.5      | 82.7      | -                                     | IV-V                                       |
| 1924, Jan. 1   | Greenville, S.C.              | 34.8      | 82.5      | -                                     | IV                                         |
| 1924, Oct. 20  | Pickens County, S.C.          | 35.0      | 82.6      | 56,000                                | V                                          |



HNP-2-FSAR-2

**TABLE 2.5-4 (SHEET 2 OF 3)**

| <u>Date</u>    | <u>Locality</u>                     | <u>°N</u> | <u>°W</u> | <u>Felt Area<br/>(mi<sup>2</sup>)</u> | <u>Epicentral Intensity/<br/>Magnitude</u> |
|----------------|-------------------------------------|-----------|-----------|---------------------------------------|--------------------------------------------|
| 1929, Jan. 3   | Sumter, S.C.                        | 33.9      | 80.3      | -                                     | IV <sup>(a)</sup>                          |
| 1929, Oct. 27  | Due West, S.C.                      | 34.3      | 82.4      | -                                     | IV <sup>(a)</sup>                          |
| 1930, Dec. 9   | Due West, S.C.                      | 34.3      | 82.4      | -                                     | III <sup>(a)</sup>                         |
| 1930, Dec. 25  | Chesterfield County, S.C.           | 34.5      | 80.3      | -                                     | III <sup>(a)</sup>                         |
| 1931, May 6    | Due West, S.C.                      | 34.3      | 82.4      | -                                     | IV <sup>(a)</sup>                          |
| 1933, June 29  | Eatonton, Ga.                       | -         | -         | -                                     | IV-V <sup>(a)</sup>                        |
| 1935, Jan. 1   | N.C.-Ga. border                     | 35.1      | 83.6      | 7,000                                 | V                                          |
| 1945, July 26  | Murray Lake, S.C.                   | 34.3      | 81.4      | 25,000                                | IV-V                                       |
| 1956, Jan. 5   | Due West, S.C.                      | 34.3      | 82.4      | -                                     | IV                                         |
| 1956, May 19   | Due West, S.C.                      | 34.3      | 82.4      | -                                     | IV                                         |
| 1956, May 27   | Due West, S.C.                      | 34.3      | 82.4      | -                                     | IV                                         |
| 1957, Nov. 24  | N.C.-Tenn. border                   | 35.0      | 83.5      | 4,100                                 | VI                                         |
| 1958, Oct. 20  | Anderson, S.C.                      | 34-1/2    | 82-3/4    | -                                     | V                                          |
| 1959, Oct. 26  | Northeast S. Carolina               | 34-1/2    | 80-1/4    | 4,800                                 | VI                                         |
| 1960, Mar. 12  | -                                   | 33.0      | 79.0      | 3,500                                 | V                                          |
| 1963, April 11 | Greenville, S.C.                    | 34.8      | 83.4      | -                                     | IV                                         |
| 1963, May 4    | -                                   | 32.2      | 79.7      | -                                     | IV                                         |
| 1964, Mar. 12  | Central Georgia                     | 33.2      | 83.4      | 400                                   | V                                          |
| 1964, Apr. 20  | Columbia, S.C.                      | 34.0      | 81.0      | -                                     | V                                          |
| 1967, Oct. 23  | -                                   | 33.4      | 80.7      | -                                     | V                                          |
| 1968, Sept. 22 | Richland and Lexington County, S.C. | 34.0      | 81.5      | 400                                   | IV/3.7                                     |

HNP-2-FSAR-2

**TABLE 2.5-4 (SHEET 3 OF 3)**

| <u>Date</u>   | <u>Locality</u>       | <u>°N</u> | <u>°W</u> | <u>Felt Area<br/>(mi<sup>2</sup>)</u> | <u>Epicentral Intensity/<br/>Magnitude</u> |
|---------------|-----------------------|-----------|-----------|---------------------------------------|--------------------------------------------|
| 1971, May 19  | Near Orangeburg, S.C. | 33.34     | 80.56     | -                                     | V                                          |
| 1971, July 13 | Near Newry, S.C.      | -         | -         | 2,000                                 | VI                                         |
| 1971, July 31 | Near Orangeburg, S.C. | 33.4      | 80.7      | -                                     | III                                        |
| 1972, Feb. 3  | -                     | 33.5      | 80.4      | 26,000                                | V/4.5                                      |
| 1972, Feb. 6  | St. George, S.C.      | -         | -         | -                                     | III-IV <sup>(a)</sup>                      |
| 1972, Aug. 14 | Southern, S.C.        | -         | -         | 2,500                                 | 3.0                                        |
| 1974, Aug. 2  | -                     | 33.95     | 82.50     | -                                     | VI/4.3                                     |
| 1974, Oct. 28 | -                     | 33.79     | 81.92     | -                                     | 3.0                                        |
| 1974, Nov. 5  | -                     | 33.73     | 82.22     | -                                     | 3.7                                        |
| 1974, Dec. 3  | -                     | 33.95     | 82.50     | -                                     | 3.6                                        |
| 1975, Mar. 7  | -                     | 34.92     | 81.33     | -                                     | 3.4                                        |
| 1975, Mar. 7  | -                     | 34.92     | 81.33     | -                                     | 3.8                                        |
| 1975, Nov. 4  | Hartsville, S.C.      | -         | -         | -                                     | 3                                          |
| 1975, Nov. 16 | -                     | 34.28     | 80.55     | -                                     | 3.0                                        |
| 1975, Nov. 25 | -                     | 34.95     | 82.91     | -                                     | 3.5                                        |

a. Bechtel estimate of maximum intensity.

b. Inadequate data to assign an intensity.

c. It seems possible that this date should be May 5, corresponding to that of a shock centered in Alabama.

TABLE 2.5-5 (SHEET 1 OF 3)

**CHRONOLOGICAL LISTING OF EARTHQUAKES CENTERED  
IN CHARLESTON-SUMMERVILLE AREA (INTENSITY III AND GREATER)**

| <u>Date</u>    | <u>Locality</u>              | <u>°N</u> | <u>°W</u> | <u>Felt Area<br/>(mi<sup>2</sup>)</u> | <u>Epicentral Intensity/<br/>Magnitude</u> |
|----------------|------------------------------|-----------|-----------|---------------------------------------|--------------------------------------------|
| 1857, Dec. 19  | Charleston, S.C.             | 32.9      | 80.0      | -                                     | IV-V <sup>(a)</sup>                        |
| 1886, Aug. 31  | Charleston, S.C.             | 32.9      | 80.0      | 2,000,000                             | IX-X                                       |
| 1886, Oct. 22  | Charleston, S.C.             | 32.9      | 80.0      | 30,000                                | VI                                         |
| 1886, Oct. 22  | Charleston, S.C.             | 32.9      | 80.0      | 30,000                                | VII                                        |
| 1886, Nov. 5   | Charleston, S.C.             | 32.9      | 80.0      | 30,000                                | VI                                         |
| 1903, Jan. 24  | Charleston, S.C.             | 32.8      | 80.0      | -                                     | IV                                         |
| 1907, Apr. 19  | Charleston, S.C.             | 32.9      | 80.0      | 10,000                                | V                                          |
| 1908, Jan. 15  | Summerville, S.C.            | 33.0      | 80.2      | -                                     | III-IV                                     |
| 1908, Mar. 3   | Summerville, S.C.            | 33.1      | 80.2      | -                                     | III-IV                                     |
| 1908, Mar. 7   | Summerville, S.C.            | 33.1      | 80.2      | -                                     | III-IV                                     |
| 1908, Oct. 26  | Summerville, S.C.            | 33.1      | 80.2      | -                                     | III                                        |
| 1908, Oct. 28  | Summerville, S.C. aftershock | 33.1      | 80.2      | -                                     | III-IV                                     |
| 1912, June 12  | Summerville, S.C.            | 33.0      | 80.2      | 35,000                                | VII                                        |
| 1914, June 1   | Waterboro, S.C.              | 33.0      | 80.3      | -                                     | III                                        |
| 1914, July 14  | Summerville, S.C.            | 33.1      | 80.2      | -                                     | III                                        |
| 1914, Sept. 22 | Near Summerville, S.C.       | 33.0      | 80.2      | 30,000                                | V                                          |
| 1915, Dec. 20  | Charleston, S.C.             | 32.8      | 79.9      | -                                     | III-IV                                     |
| 1916, June 25  | Summerville, S.C.            | 33.1      | 80.2      | -                                     | III                                        |
| 1920, Aug. 1   | Summerville, S.C.            | 33.1      | 80.2      | -                                     | IV-VII                                     |

HNP-2-FSAR-2


**TABLE 2.5-5 (SHEET 2 OF 3)**

| <u>Date</u>   | <u>Locality</u>                       | <u>°N</u> | <u>°W</u> | <u>Felt Area<br/>(mi<sup>2</sup>)</u> | <u>Epicentral Intensity/<br/>Magnitude</u> |
|---------------|---------------------------------------|-----------|-----------|---------------------------------------|--------------------------------------------|
| 1921, Apr. 19 | Summerville, S.C.                     | 33.1      | 80.2      | -                                     | III                                        |
| 1921, Apr. 23 | Summerville, S.C.                     | 33.1      | 80.2      | -                                     | III                                        |
| 1923, Mar. 23 | Charleston and Summerville, S.C.      | 32.9      | 80.0      | -                                     | III                                        |
| 1923, May 4   | West of Charleston                    | 33.1      | 80.2      | -                                     | III                                        |
| 1924, Feb. 14 | Summerville, S.C.                     | 33.1      | 80.2      | -                                     | III                                        |
| 1924, June 3  | Summerville, S.C.                     | 33.1      | 80.2      | -                                     | III                                        |
| 1933, July 25 | Summerville, S.C.                     | 33.1      | 80.2      | -                                     | III                                        |
| 1933, Dec. 19 | Summerville, S.C.                     | 33.0      | 80.2      | -                                     | IV-V                                       |
| 1933, Dec. 23 | Summerville, S.C.                     | 33.0      | 80.2      | -                                     | IV <sup>(a)</sup>                          |
| 1934, Dec. 9  | Summerville, S.C.                     | 33.0      | 80.2      | -                                     | IV                                         |
| 1935, Feb. 6  | Summerville, S.C.                     | 33.0      | 80.2      | -                                     | IV <sup>(a)</sup>                          |
| 1935, Oct. 20 | Summerville, S.C.                     | 33.0      | 80.2      | -                                     | IV <sup>(a)</sup>                          |
| 1940, Jan. 5  | Summerville, S.C.                     | 33.0      | 80.2      | -                                     | IV                                         |
| 1943, Dec. 28 | Summerville, S.C.                     | 33.0      | 80.2      | -                                     | IV                                         |
| 1944, Jan. 28 | Summerville, S.C.                     | 33.0      | 80.2      | -                                     | IV <sup>(a)</sup>                          |
| 1945, Jan. 30 | Summerville, S.C.                     | 33.0      | 80.2      | -                                     | IV <sup>(a)</sup>                          |
| 1945, May 18  | 3 miles southwest of Charleston, S.C. | -         | -         | -                                     | III <sup>(a)</sup>                         |
| 1945, June 5  | Near Charleston                       | 32.8      | 80.0      | -                                     | III <sup>(a)</sup>                         |
| 1946, Feb. 8  | Summerville, S.C.                     | 33.0      | 80.2      | -                                     | III <sup>(a)</sup>                         |
| 1947, Nov. 1  | Summerville, S.C.                     | 33.0      | 80.2      | -                                     | IV <sup>(a)</sup>                          |
| 1949, Feb. 2  | Summerville, S.C.                     | 33.0      | 80.2      | -                                     | IV <sup>(a)</sup>                          |

TABLE 2.5-5 (SHEET 3 OF 3)

| <u>Date</u>   | <u>Locality</u>              | <u>°N</u> | <u>°W</u> | <u>Felt Area<br/>(mi<sup>2</sup>)</u> | <u>Epicentral Intensity/<br/>Magnitude</u> |
|---------------|------------------------------|-----------|-----------|---------------------------------------|--------------------------------------------|
| 1949, June 27 | Summerville, S.C.            | 33.0      | 80.2      | -                                     | III <sup>(a)</sup>                         |
| 1951, March 3 | Summerville, S.C.            | 33.0      | 80.2      | -                                     | IV <sup>(a)</sup>                          |
| 1951, Dec. 30 | Summerville, S.C.            | 33.0      | 80.2      | -                                     | IV <sup>(a)</sup>                          |
| 1952, Nov. 19 | Charleston, S.C.             | 32.9      | 80.0      | -                                     | V                                          |
| 1959, Aug. 3  | Near Charleston, S.C.        | 33.0      | 79.5      | 25,000                                | VI                                         |
| 1960, July 23 | Charleston, S.C.             | 33.0      | 80.0      | -                                     | V                                          |
| 1961, May 20  | Summerville, S.C.            | 33.0      | 80.2      | -                                     | III                                        |
| 1961, Oct. 17 | Summerville, S.C.            | 33.0      | 80.2      | -                                     | III                                        |
| 1968, July 9  | Near Charleston, S.C.        | -         | -         | -                                     | VI                                         |
| 1974, Nov. 22 | Charleston-Summerville, S.C. | 32.9      | 80.1      | -                                     | VI/4.7                                     |

a. Bechtel estimate of maximum intensity.



ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

REGIONAL PHYSIOGRAPHIC MAP

FIGURE 2.5-1




HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

REGIONAL GEOLOGIC MAP

FIGURE 2.5-2



HISTORICAL  
REV 19 7/01

ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

REGIONAL TECTONIC MAP

FIGURE 2.5-3



| ERA          | PERIOD     | EPOCH                  | GEOLOGIC UNIT              | APPROX. MAX. THICKNESS (FT)                                                     | LITHOLOGIC DESCRIPTION                                                                                                                     |                                                                                                                                                                              |
|--------------|------------|------------------------|----------------------------|---------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| CENOZOIC     | QUATERNARY | HOLOCENE               | ALLUVIAL & MARINE DEPOSITS |                                                                                 | SAND, GRAVEL, AND CLAY IN FLOODPLAINS; CALCAREOUS SILT AND CLAY NEAR COAST.                                                                |                                                                                                                                                                              |
|              |            | PLEISTOCENE            | TERRACE DEPOSITS           | 100+                                                                            | NON-MARINE SAND, GRAVEL, AND CLAY ADJACENT TO RIVERS; MARINE, SOMEWHAT CALCAREOUS SAND AND MARL IN COASTAL TERRACES PARALLEL TO SHORELINE. |                                                                                                                                                                              |
|              | TERTIARY   | PLIOCENE               | TERRACE DEPOSITS           | 20                                                                              | SAND AND GRAVEL; MARL IN DOWNDIP AREAS NEAR COAST.                                                                                         |                                                                                                                                                                              |
|              |            | PLIOCENE (?)           | HAWTHORN FM                | 634                                                                             | SANDY, MICACEOUS CLAY, AND ARKOSIC SAND.                                                                                                   |                                                                                                                                                                              |
|              |            |                        | TAMPA FM                   |                                                                                 | DOLOMITIC LIMESTONE; INTERBEDDED CLAY AND CALCAREOUS SAND UPDIP.                                                                           |                                                                                                                                                                              |
|              |            | OLIGOCENE              | VICKSBURG GP               | 287+                                                                            | LIMESTONE AND MARL, WITH OCCASIONAL CALCAREOUS CLAY AND DOLOMITE.                                                                          |                                                                                                                                                                              |
|              |            | EOCENE                 | OCALA FM (JACKSON GP)      | 725                                                                             | FOSSILIFEROUS, CALCAREOUS CLAY AND LIMESTONE; WEATHERED SANDY CLAY UPDIP.                                                                  |                                                                                                                                                                              |
|              |            |                        | CLAIBORNE GP               | LISBON FM                                                                       | 1190+                                                                                                                                      | FOSSILIFEROUS CLAY, LIMESTONE, AND MARL; CALCAREOUS SAND.                                                                                                                    |
|              |            |                        |                            | TALLAHATTA FM                                                                   |                                                                                                                                            | SILTY SAND; CALCAREOUS, MICACEOUS, SILTY CLAY AND LIMESTONE WITH SOME LIGNITE.                                                                                               |
|              |            |                        | WILCOX GP                  | 400+                                                                            | CALCAREOUS, SILTY FINE SAND AND MARL.                                                                                                      |                                                                                                                                                                              |
|              | PALEOCENE  | CLAYTON FM (MIDWAY GP) | 615+                       | LIMESTONE AND SANDY MARL; OOLITIC BEDS AND GYPSUM DOWNDIP; CLAY AND SAND UPDIP. |                                                                                                                                            |                                                                                                                                                                              |
|              | MESOZOIC   | CRETACEOUS             | GULFIAN                    | PROVIDENCE RIPLEY CUSSETA BLUFFTOWN EUTAW                                       | 1755                                                                                                                                       | SAND, FOSSILIFEROUS AND PHOSPHATIC; INTERBEDDED FOSSILIFEROUS, MICACEOUS, PYRITIFEROUS, SILTY MARL; LOWER UNITS GENERALLY MORE CALCAREOUS, WITH OCCASIONAL COQUINA HORIZONS. |
|              |            |                        |                            | TUSCALOOSA FM                                                                   | 910                                                                                                                                        | TERRIGENOUS SAND, GRAVEL, AND KAOLINITIC CLAY; MARINE SILT AND CLAY, WITH SOME CARBONATES DOWNDIP.                                                                           |
| COMANCHEAN   |            |                        | UNDIFFERENTIATED           | 2630                                                                            | ARKOSIC SAND AND MICACEOUS CLAY; RED BEDS UPDIP; GYPSUM, SHALE, AND CARBONATES DOWNDIP.                                                    |                                                                                                                                                                              |
| TRIASSIC (?) |            |                        | UNDIFFERENTIATED           |                                                                                 | MICACEOUS CLAY, ARKOSIC SAND, AND SANDSTONE; INTERBEDDED DIABASE AND BASALT.                                                               |                                                                                                                                                                              |
| PALEOZOIC    |            |                        | UNDIFFERENTIATED           |                                                                                 | GRANITE, CRYSTALLINE SCHIST, BIOTITE GNEISS; SHALE.                                                                                        |                                                                                                                                                                              |


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

REGIONAL GEOLOGIC COLUMN

FIGURE 2.5-4



ACAD





**SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2**

**HISTORICAL  
REV 19 7/01**

**REGIONAL GEOLOGIC PROFILE NW-SE**

**FIGURE 2.5-5**



**NOTES**

- 1 MARINE EQUIVALENT OF TUSCALOOSA FORMATION REFERRED TO AS AUSTIN FORMATION IN EXTREME SOUTH GEORGIA.
- 2 TAMPON FORMATION INCLUDED IN MIOCENE FORMATION INTERPRETED BY GEORGIA GEOLOGICAL SURVEY (GGS), 1978.

**REFERENCES**

- APPLIN, E.M. and APPLIN, E.M., 1947, REGIONAL SUBSURFACE STRATIGRAPHY, STRUCTURE, AND CORRELATION OF MIDDLE AND EARLY CRETACEOUS ROCKS IN FLORIDA, GEORGIA, AND NORTH FLORIDA, U.S.G.S. AND THE INVESTIGATION PRELIMINARY REPORT IN COOPERATION WITH THE U.S. GEOLOGICAL SURVEY.
- COOPER, C.W., 1943, GEOLOGY OF THE COASTAL PLAIN OF GEORGIA, U.S.G.S. BULLETIN 741, 127.
- HEMPEL, E.W., 1946, WELL LOGS OF THE COASTAL PLAIN OF GEORGIA, GEORGIA GEOLOGICAL SURVEY BULLETIN 70, 457.
- MAHER, J.C., 1940, CORRELATION OF SUBSURFACE MIOCENE AND EOCENE ROCKS ALONG THE ATLANTIC COAST AT APO, TALLAHASSEE, AND PALM BEACH, U.S.G.S. BULLETIN 704, 1-14.
- MAHER, J.C. and APPLIN, E.M., 1948, CORRELATION OF SUBSURFACE MIOCENE AND EOCENE ROCKS ALONG THE EASTERN GULF COAST, U.S.G.S. CROSS SECTION PUBLICATION 3, PAGES 6 PLATES.
- MARSHALL, W.L., 1970, PETROLOGY EXPLOSION IN GEORGIA, GEORGIA GEOLOGICAL SURVEY INFORMATION CIRCULAR 10, 129.
- WILSON, C. and HOBBS, V.J., 1987, SUBSURFACE "BASEMENT" ROCKS OF GEORGIA, GEORGIA GEOLOGICAL SURVEY BULLETIN 78, 249.

ACAD


HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

REGIONAL GEOLOGIC PROFILE NE-SW

FIGURE 2.5-6



**MILLIMETERS PER YEAR**



\*ONE MILLIMETER = 0.04 INCHES  
 25.4 MILLIMETERS = ONE INCH  
 304.8 MILLIMETERS = ONE FOOT

**PROBABLE VERTICAL MOVEMENTS OF THE EARTH'S SURFACE**  
 AUGUST 18, 1972

**REFERENCE**

U.S. DEPARTMENT OF COMMERCE NEWS,  
 NOAA 72-122: SEPTEMBER 22, 1972.

ACAD

*HISTORICAL*  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

CRUSTAL MOVEMENT MAP

FIGURE 2.5-7

| ERA           | PERIOD     | EPOCH        | GEOLOGIC UNIT         | APPROX. THICKNESS (FT)                                                                            | LITHOLOGIC DESCRIPTION                                                                                             |                                                                                               |
|---------------|------------|--------------|-----------------------|---------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------|
| CENOZOIC      | QUATERNARY | HOLOCENE     | ALLUVIUM              | 55+                                                                                               | SAND AND GRAVEL; CARBONACEOUS SILTY CLAY.                                                                          |                                                                                               |
|               |            | PLEISTOCENE  | BRANDYWINE FM         | 10+                                                                                               | CROSS-BEDDED SAND AND GRAVEL WITH HEMATITE CONCRETIONS.                                                            |                                                                                               |
|               | TERTIARY   | PLIOCENE (?) | HAWTHORN FM           | 300+                                                                                              | PHOSPHATIC, FINE TO COARSE SAND; SANDY, CALCAREOUS CLAY; ARKOSIC, CROSS BEDDED SAND AND GRAVEL; OCCASIONAL PYRITE. |                                                                                               |
|               |            | MIOCENE      | TAMPA FM              | 160                                                                                               | SANDY TO CLAYEY, PHOSPHATIC, FOSSILIFEROUS LIMESTONE; PARTLY DOLOMITIZED.                                          |                                                                                               |
|               |            |              | OLIGOCENE             | UNDIFFERENTIATED                                                                                  | 120                                                                                                                | MASSIVE, CALCITIZED, FOSSILIFEROUS LIMESTONE.                                                 |
|               |            | EOCENE       | OCALA FM (JACKSON GP) | 280                                                                                               | MASSIVE, CRYSTALLINE, FOSSILIFEROUS LIMESTONE.                                                                     |                                                                                               |
|               |            |              | CLAIBORNE GP          | LISBON FM                                                                                         | 610                                                                                                                | SANDY, PHOSPHATIC, DOLOMITIC LIMESTONE; ABUNDANT GLAUCONITE AND FOSSILS.                      |
|               |            |              |                       | TALLAHATTA FM                                                                                     | 160                                                                                                                | GLAUCONITIC, CALCAREOUS SAND AND THIN, FOSSILIFEROUS MARL LAYERS.                             |
|               |            |              |                       | WILCOX GP                                                                                         | 90                                                                                                                 | CARBONACEOUS, MICACEOUS, SILTY, FOSSILIFEROUS MARL; OCCASIONAL GLAUCONITIC SAND LAYERS.       |
|               | PALEOCENE  | CLAYTON FM   | 315                   | MASSIVE, CRYSTALLINE LIMESTONE; INTERBEDDED WITH CARBONACEOUS, MICACEOUS, GLAUCONITIC MARLY SAND. |                                                                                                                    |                                                                                               |
|               | MESOZOIC   | CRETACEOUS   | GULFIAN               | POST-TUSCALOOSA DEPOSITS                                                                          | 955                                                                                                                | COQUINOID, PHOSPHATIC SAND; CARBONACEOUS, FOSSILIFEROUS, GLAUCONITIC MARL; OCCASIONAL PYRITE. |
| TUSCALOOSA FM |            |              |                       | 910                                                                                               | FINE-GRAINED TO ARKOSIC, CARBONACEOUS, FOSSILIFEROUS, MICACEOUS SAND AND CLAY.                                     |                                                                                               |
| COMANCHEAN    |            |              | UNDIFFERENTIATED      | 115                                                                                               | SANDY, MICACEOUS CLAY; ARKOSIC SAND.                                                                               |                                                                                               |
| TRIASSIC (?)  |            |              | UNDIFFERENTIATED      |                                                                                                   | ARKOSIC SANDSTONE; BASALT OR DIABASE.                                                                              |                                                                                               |


*HISTORICAL*  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SITE GEOLOGIC COLUMN

FIGURE 2.5-8




HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

CONTOURS ON TOP OF UNIT 5 HAWTHORN FORMATION

FIGURE 2.5-9




HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SITE GEOLOGIC MAP

FIGURE 2.5-10



ACAD

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

AREA GEOLOGIC MAP

FIGURE 2.5-11





**LEGEND**

| DAMAGE |          |
|--------|----------|
| 0      | NONE     |
| 1      | MINOR    |
| 2      | MODERATE |
| 3      | MAJOR    |

Seismic risk map for conterminous U.S., developed by ESSA/Coast and Geodetic Survey and issued in January 1969. Subject to revision as continuing research warrants, it is an updated edition of the map first published in 1948 and revised in 1951. The map divides the U.S. into four zones: Zone 0, areas with no reasonable expectancy of earthquake damage; Zone 1, expected minor damage; Zone 2, expected moderate damage; Zone 3, where major destructive earthquakes may occur.

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SEISMIC RISK MAP

FIGURE 2.5-12



**REFERENCES**

- GEOLOGIC MAP OF GEORGIA, 1:500,000: GA. GEOL. SURVEY, 1975, (IN PRESS).
- BASEMENT ROCK MAP OF THE UNITED STATES, 1:2,500,000, U.S.G.S. AND THE UNIV. OF TEXAS, 1968.
- HERRICK, S.M., 1981, WELL LOGS OF THE COASTAL PLAIN OF GEORGIA: GA. GEOL. SURVEY, BULL. 70, 470p.
- MURRAY, R.E., 1981, GEOLOGY OF THE ATLANTIC AND GULF COASTAL PROVINCE OF NORTH AMERICA: HARPER & BROTHERS, NEW YORK, 692p.
- OLSON, N.K., et al., 1966, GEOLOGY OF THE MIOCENE AND PLEISTOCENE SERIES IN THE NORTH FLORIDA-SOUTH GEORGIA AREA: ATLANTIC COASTAL PLAIN GEOL. ASSOC. AND SOUTHEASTERN GEOL. SOC., 1966 ANNUAL FIELD CONF., 94p.
- PATTERSON, S.H. AND HERRICK, S.M., 1971, CHATTAHOOCHEE ANTICLINE, APALACHICOLA EMBAYMENT, GULF TROUGH AND RELATED STRUCTURAL FEATURES, SOUTHWESTERN GEORGIA - FACT OR FICTION: GEOL. SURVEY OF GA., INF. CIRC. 41, 16p.
- SEVER, C.W., 1966, MIOCENE STRUCTURAL MOVEMENTS IN THOMAS CO., GA.: U.S.G.S. PROF. PAPER 550-C.
- TECTONIC MAP OF GULF COAST REGION, U.S.A., 1:1,000,000: GULF COAST ASSOC. PET. GEOL. AND AAPG, 1972.
- TECTONIC MAP OF THE UNITED STATES, 1:2,500,000: U.S.G.S. AND AAPG, 1962.
- ZAPP, A.D., 1965, BAUXITE DEPOSITS OF THE ANDERSONVILLE DISTRICT, GEORGIA: U.S.G.S. BULL. 1199-0, 37p.

**EARTHQUAKE DATA:**

- HYPOCENTER DATA FILE, 1961 - JUNE 1972: NATIONAL GEOPHYSICAL AND SOLAR-TERRRESTRIAL DATA CENTER, NOAA, BOULDER, COLORADO.
- SEISMIC HISTORY OF THE SOUTHEAST REGION OF THE UNITED STATES 1699 - 1971: OAK RIDGE LABORATORY, OAK RIDGE, TENNESSEE.

**LEGEND**


- ▲▲▲▲▲ THRUST FAULT
- ▲▲▲▲— NORMAL FAULT
- ARTICLINAL AXIS
- SYNCLINAL AXIS
- 5— STRUCTURE CONTOURS ON PRE-MESOZOIC SURFACE (IN THOUSANDS OF FEET)

**LEGEND**

- ..... INTENSITY
- ..... VIII
- ①..... VII
- ②..... VI
- ③..... V
- ④..... IV
- 1952..... YEAR OF EARTHQUAKE OCCURRENCE
- (2)..... NUMBER OF EARTHQUAKES IN SAME LOCATION WITH SAME INTENSITY.

**NOTE**

WHERE MORE THAN ONE EARTHQUAKE OCCURS AT A LOCATION, ONLY THE EARTHQUAKE WITH THE HIGHEST INTENSITY IS GIVEN.



ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

TECTONIC AND EPICENTER MAP

FIGURE 2.5-13



ACAD


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

ISOSEISMAL MAP OF 1886 CHARLESTON, S.C., EARTHQUAKE

FIGURE 2.5-14




**EXPLANATION**

The dashed line is the least squares best fit of these eight epicenters relative to the coordinate system represented by the solid lines. The orientation and scale of this coordinate system are such that the distances between the epicenters and the x axis may be treated as uncorrelated Gaussian noise with a standard deviation of +8 km.

Epicenter locations are from Taiwan (Ref. 65) as indicated in text.

○ Earthquake as plotted by Taiwan (Ref. 66).

△ Earthquake as listed in Refs. 76, 78 and as it appears in Fig. 2.



ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

EPICENTRAL LOCATIONS NEAR THE GOAT ROCK FAULT


FIGURE 2.5-15



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SOUTH CAROLINA EARTHQUAKE EPICENTERS 1799 TO 1975

FIGURE 2.5-16



**NOTE:**  
 CONTOUR INTERVAL  
 10 MILLIGALS  
 REDUCTION DENSITY  
 2.67 G PER CM<sup>3</sup>

SOURCE: BOUGUER GRAVITY ANOMALY MAP  
 OF THE UNITED STATES,  
 SCALE 1:2,500,000, U.S.G.S., 1964



ACAD


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

BOUGUER GRAVITY ANOMALY MAP  
 SOUTHEASTERN UNITED STATES

FIGURE 2.5-17



**REFERENCES**

- ① ALABAMA GEOLOGIC SURVEY, Preliminary Aeromagnetic Map of East-Central Alabama, 1:250,000, 1973.
- ② GEORGIA GEOLOGIC SURVEY, Open File, Aeromagnetic Map of parts of the Atlanta and Rome Quadrangles, 1:250,000, 1975.
- ③ U.S.G.S. Open File, 1970, Aeromagnetic Map of the Camden-Karshaw Area, North-Central South Carolina, 1:24,000, 4 Sheets.
- ④ PETTY, A.J., PETRAFESO, F.A., and MOORE, F.C., Jr., 1965, Aeromagnetic Map of the Savannah River Plant Area, South Carolina and Georgia: U.S.G.S. Geophys. Inv. Map GP489, 1:250,000.
- ⑤ U.S.G.S. Open File 75-590, 1975, Aeromagnetic Map of Charleston and Vicinity, South Carolina; part (A) 1 Sheet, 1:250,000; publ. in coop. with U.S.N.R.C.
- ⑥ DANIELS, D.L., 1974, Aeromagnetic Map of the Piedmont Part of the Savannah River Plant Area, South Carolina and Georgia: U.S.G.S. Geophys. Inv. Map GP893 (1975), 1:250,000.
- ⑦ U.S.G.S. Open File 75-51m, 1975, Aeromagnetic Map of the Enoree Quadrangle, South Carolina, 1:62,500.
- ⑧ PHILBIN, P.W., PETRAFESO, F.A., and LONG, C.L., 1964, Aeromagnetic Map of the Georgia Nuclear Lab. Area, Georgia: U.S.G.S. Geophys. Inv. Map GP488, 1:250,000.
- ⑨ U.S.G.S. Open File, 1973, Composite Aeromagnetic Map North Central Georgia: Lockwood, Kessler, and Bartlett Inc., 1:250,000, 1973.
- ⑩ U.S.G.S. Open File 76-155m, 1976, Aeromagnetic Map of parts of the Brunswick and Savannah 1° x 2° Quadrangles, Georgia and South Carolina, 1:250,000.
- ⑪ U.S.G.S. Open File 76-181, 1976, Aeromagnetic Map of parts of Georgia, South Carolina, and North Carolina: C.P.R.C. and U.S.G.S., 1:250,000, 13 Sheets.

**NOTE**  
COVERAGE BOUNDARIES  
ARE APPROXIMATE.

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

INDEX OF AEROMAGNETIC COVERAGE ALABAMA, GEORGIA,  
AND SOUTH CAROLINA

FIGURE 2.5-18



HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

POSTULATED FAULTS IN SITE VICINITY

FIGURE 2.5-19





*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 1 AND UNIT 2**

**BOREHOLES AT BAY CREEK**

**FIGURE 2.5-20**

| GEOLOGIC LOG |      | BORING NO.<br>D                                                                                                                                                                                 | LOCATION<br>NORTH SIDE<br>BAY CREEK |
|--------------|------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|
| DEPTH        | ELEV | DESCRIPTION                                                                                                                                                                                     | GEOLOGIC UNIT                       |
| 0            | 135  |                                                                                                                                                                                                 |                                     |
| 10           |      | CLAYEY SAND AND SAND, MEDIUM TO VERY COARSE, POORLY SORTED, PEBBLES COMMON.                                                                                                                     | HAWTHORN VI                         |
| 20           | 121  | SANDY CLAY AND SAND, FINE TO COARSE, POORLY TO FAIR SORTED; CLAY CONTENT INCREASES WITH DEPTH; LOCALLY CEMENTED.                                                                                | HAWTHORN V                          |
| 30           |      |                                                                                                                                                                                                 |                                     |
| 40           |      |                                                                                                                                                                                                 |                                     |
| 50           |      |                                                                                                                                                                                                 |                                     |
| 60           | 73   | SAND AND CLAYEY SAND, FINE TO COARSE, POORLY TO FAIR SORTED; LOCALLY CEMENTED; CLAY STRINGERS COMMON NEAR BASE; TAN PHOSPHATE SPARSE TO ABUNDANT.                                               | HAWTHORN IV                         |
| 70           |      |                                                                                                                                                                                                 |                                     |
| 80           |      |                                                                                                                                                                                                 |                                     |
| 90           |      |                                                                                                                                                                                                 |                                     |
| 100          |      |                                                                                                                                                                                                 |                                     |
| 110          |      |                                                                                                                                                                                                 |                                     |
| 120          | 19   | INTERBEDDED CLAYEY SAND AND SAND, MEDIUM TO COARSE, WELL SORTED; BROWN AND BLACK PHOSPHATE COMMON.                                                                                              | HAWTHORN III                        |
| 130          |      |                                                                                                                                                                                                 |                                     |
| 140          | -3   | SAND AND SANDSTONE, MEDIUM TO VERY COARSE, POORLY SORTED; BLACK AND BROWN PHOSPHATE ABUNDANT.                                                                                                   | HAWTHORN II                         |
| 150          |      |                                                                                                                                                                                                 |                                     |
| 160          |      |                                                                                                                                                                                                 |                                     |
| 170          | -37  | SANDSTONE AND CLAYEY SAND, VERY FINE TO COARSE, POORLY TO WELL SORTED; BROWN AND BLACK PHOSPHATE COMMON TO ABUNDANT. CLAY CONTENT INCREASES WITH DEPTH; PHOSPHATE CONTENT DECREASES WITH DEPTH. | HAWTHORN I                          |
| 180          |      |                                                                                                                                                                                                 |                                     |
| 190          |      |                                                                                                                                                                                                 |                                     |
| 200          |      |                                                                                                                                                                                                 |                                     |
| 210          |      |                                                                                                                                                                                                 |                                     |
| 220          |      |                                                                                                                                                                                                 |                                     |
| 230          |      |                                                                                                                                                                                                 |                                     |
| 240          |      |                                                                                                                                                                                                 |                                     |
| 250          |      |                                                                                                                                                                                                 |                                     |
| 260          |      |                                                                                                                                                                                                 |                                     |
| 270          | -130 | CLAYEY SAND AND SANDY MARL, FINE TO COARSE, FAIR TO WELL SORTED; CALCAREOUS, FOSSILIFEROUS; PHOSPHATE SPARSE TO ABUNDANT.                                                                       | TAMPA FORMATION                     |
| 280          |      |                                                                                                                                                                                                 |                                     |
| 290          |      |                                                                                                                                                                                                 |                                     |
| 300          |      |                                                                                                                                                                                                 |                                     |
| 310          |      |                                                                                                                                                                                                 |                                     |
| 320          |      |                                                                                                                                                                                                 |                                     |
| 330          |      |                                                                                                                                                                                                 |                                     |
| 340          |      |                                                                                                                                                                                                 |                                     |
| 350          |      | BORING TERMINATED AT 347 FEET                                                                                                                                                                   |                                     |

| GEOLOGIC LOG |      | BORING NO.<br>F                                                                                                                                                               | LOCATION<br>SOUTH SIDE<br>BAY CREEK |
|--------------|------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|
| DEPTH        | ELEV | DESCRIPTION                                                                                                                                                                   | GEOLOGIC UNIT                       |
| 0            | 130  |                                                                                                                                                                               |                                     |
| 10           |      | SANDY CLAY AND CLAYEY SAND, FINE TO VERY COARSE, POORLY SORTED, GRAVEL NEAR BASE                                                                                              | HAWTHORN VI                         |
| 20           | 115  | SANDY CLAY AND CLAYEY SAND, FINE TO VERY COARSE, FAIR SORTED; CLAY CONTENT INCREASES WITH DEPTH; LOCALLY CEMENTED                                                             | HAWTHORN V                          |
| 30           |      |                                                                                                                                                                               |                                     |
| 40           |      |                                                                                                                                                                               |                                     |
| 50           |      |                                                                                                                                                                               |                                     |
| 60           | 67   | SAND AND CLAYEY SAND, FINE TO COARSE, FAIR TO WELL SORTED; CLAY STRINGERS COMMON NEAR BASE; TAN PHOSPHATE RARE TO ABUNDANT, INCREASING WITH DEPTH.                            | HAWTHORN IV                         |
| 70           |      |                                                                                                                                                                               |                                     |
| 80           |      |                                                                                                                                                                               |                                     |
| 90           |      |                                                                                                                                                                               |                                     |
| 100          |      |                                                                                                                                                                               |                                     |
| 110          | 24   | SAND, MEDIUM TO COARSE, WELL SORTED; TAN PHOSPHATE ABUNDANT; CLAY STRINGERS COMMON TO ABUNDANT.                                                                               | HAWTHORN III                        |
| 120          |      |                                                                                                                                                                               |                                     |
| 130          |      |                                                                                                                                                                               |                                     |
| 140          |      |                                                                                                                                                                               |                                     |
| 150          | -17  | CLAYEY SAND AND SANDSTONE, VERY FINE TO VERY COARSE, POORLY TO WELL SORTED; BROWN AND BLACK PHOSPHATE COMMON TO ABUNDANT; OCCASIONAL CLAY LAYER. CALCAREOUS CEMENT NEAR BASE. | HAWTHORN II                         |
| 160          |      |                                                                                                                                                                               |                                     |
| 170          |      |                                                                                                                                                                               |                                     |
| 180          | -48  | CLAYEY SAND AND CLAY, VERY FINE TO COARSE, FAIR TO WELL SORTED; PHOSPHATE SPARSE TO ABUNDANT; CLAY CONTENT INCREASES WITH DEPTH, WITH CLAY LAYER 235 FT. TO 258 FT.           | HAWTHORN I                          |
| 190          |      |                                                                                                                                                                               |                                     |
| 200          |      |                                                                                                                                                                               |                                     |
| 210          |      |                                                                                                                                                                               |                                     |
| 220          |      |                                                                                                                                                                               |                                     |
| 230          |      |                                                                                                                                                                               |                                     |
| 240          |      | OCCASIONAL SLICKENSIDES *                                                                                                                                                     |                                     |
| 250          |      |                                                                                                                                                                               |                                     |
| 260          | -128 | CLAYEY SAND AND SANDY MARL, FINE TO VERY COARSE, POORLY TO WELL SORTED; CALCAREOUS, OCCASIONAL LIMESTONE; PHOSPHATE COMMON TO ABUNDANT FOSSILIFEROUS.                         | TAMPA FORMATION                     |
| 270          |      |                                                                                                                                                                               |                                     |
| 280          |      |                                                                                                                                                                               |                                     |
| 290          |      |                                                                                                                                                                               |                                     |
| 300          |      |                                                                                                                                                                               |                                     |
| 310          |      |                                                                                                                                                                               |                                     |
| 320          |      |                                                                                                                                                                               |                                     |
| 330          |      |                                                                                                                                                                               |                                     |
| 340          |      |                                                                                                                                                                               |                                     |
| 350          |      | BORING TERMINATED AT 345                                                                                                                                                      |                                     |

\* IN THIS CASE, THE SLICKENSIDES ARE SLIPPAGE PLANES CONSIDERED CONTEMPORANEOUS WITH CONSOLIDATION OF THE CLAY LAYER, CAUSED BY STRESSES INITIATED BY WEIGHT OF OVERLYING SEDIMENTS

HISTORICAL  
REV 19 7/01

ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

TEST BORING RECORD  
BORING NUMBERS D AND F

FIGURE 2.5-21

**SUPPLEMENT 2A**

**SUBSURFACE INVESTIGATION  
AND FOUNDATIONS**

**INTRODUCTION**

*This supplement presents the findings and conclusions of the subsurface soil investigation and foundation analyses for the Edwin I. Hatch Nuclear Plant (HNP) in Appling County, Georgia, performed by Law Engineering Testing Company.*

*The HNP-2 site is situated within the Coastal Plain Geologic Province which is underlain entirely by sedimentary deposits. The sediments at the site include Holocene alluvium near the river and Miocene to Pliocene(?) deltaic and marine deposits elsewhere. Beneath the Miocene deposits are older, soft rock-like deposits ranging in age from Oligocene to Cretaceous with an estimated thickness of over 4000 ft.*

*The HNP-2 site was evaluated and selected after detailed and extensive geologic field mapping, geophysical explorations, air photo reconnaissance and interpretation, aerial inspection, piezometer observations, subsurface exploration and sampling, and materials identification, classification, and testing. Site geology and seismology are discussed in section 2.5.*

**2A.1 FIELD EXPLORATION**

*Foundation investigations and evaluations were performed on a continuing basis as required. These investigations included test borings made for the design of principal structures of HNP-1 and HNP-2. Borings 587 through 600 have verified that previous soils data are applicable to HNP-2. The borings locations and the locations of Category 1 structures are shown on figures 2A-1 and 2A-2.*

*In addition to the above, sampling and testing of soils for backfill design were accomplished. This included the location of borrow areas for backfill material sources. Soils evaluations for location and design of the condenser cooling water intake structure and offgas stack have been accomplished. Details of sampling, testing, and evaluations are recorded in the following subsections.*

**2A.1.1 PLANT LOCATION**

*The plant site is in Appling County, Georgia, on the south bank of the Altamaha River about 3500 ft downstream from the river's intersection with U.S. Highway No. 1, 10 miles north of Baxley, Georgia, and 17 miles southwest of Reidsville, Georgia.*

### **2A.1.2 RECONNAISSANCE**

*During field exploration, intensive studies of available geologic literature pertinent to the area were made. An extensive air photo study was made covering an area 90 miles east-west by 70 miles north-south (6300 square miles). From these photos, detailed studies of stream patterns, densities, and anomalies were made. These features, as well as topographic features reflecting geologic structure, were studied.*

### **2A.1.3 BORING, SAMPLING, AND GROUNDWATER INVESTIGATION**

*Site investigations included soil test borings made at ~ 136 locations. Of the total, 64 borings were completed for the principal purpose of soil classification, analysis, and testing to establish foundation design criteria for the principal structures. Twenty-eight soil test borings were located within or in areas immediately adjacent to the reactor, radwaste, and turbine building foundations. These are presented in figures 2A-1 and 2A-2. Borings 562 through 575 and RFI-1 through RFI-10 were performed during construction as part of the foundation inspection of HNP-1 and HNP-2, respectively.*

*The subsurface investigation in the stack area consisted of 5 soil test borings, B-477 through B-481, which were made on 50-ft centers along the tentative east-west centerline of the stack. Two additional borings, B-584 and B-585, were made at the selected location of the stack along the north-south centerline.*

*Borings B-576 through B-578 were made in the Altamaha River, drilling from a barge, at the location of the temporary cellular cofferdams. Borings B-579, B-580, B-586, and B-603 were made within or immediately adjacent to the intake structure. Boring B-581 was made near the top of the bluff, south of the intake structure.*

*Soil sampling and penetration testing were performed in accordance with American Society of Testing Materials (ASTM) Specification D 1586-67.<sup>(1)</sup> Representative portions of the soil samples thus obtained were placed in glass jars and transported to the soils laboratory. In the laboratory, the samples were examined to verify the driller's field classifications. Test boring records are included in supplement 2B; they graphically show soil descriptions and penetration resistances. Based on the site borings, subsurface profiles for HNP-2 are shown as figure 2A-3.*

*Split tube samples were used for visual examination and classification tests. Undisturbed samples were obtained by forcing sections of 3-in. OD tubing into the soil at the desired sampling levels. This sampling procedure is described by ASTM Specification D 1587. Each tube, together with the encased soil, was carefully removed from the ground, made airtight, and then transported to the laboratory. Locations and depths of undisturbed samples are shown on the test boring records (supplement 2B).*

*In order to study the ground water levels at this site, piezometers were installed both in the plant area and to distances of 1 mile outside the plant area. Cased open-hole piezometers were installed to measure surficial groundwater levels. Deep piezometers, sealed in the less pervious strata above, were installed at various elevations to measure piezometric levels of deeper pervious strata. The locations and levels of piezometers are presented in subsection 2.4.13.*

## HNP-2-FSAR-2

Field variable head permeability tests were performed in selected piezometers in accordance with the procedures outlined by the Department of the Navy, Bureau of Yards and Docks Design manual.<sup>(2)</sup> Field well permeameter tests were performed near the surface in accordance with the procedures outlined by the Bureau of Reclamation.<sup>(3)</sup>

### 2A.1.4 GEOPHYSICAL EXPLORATION

Seismic traverses were conducted to determine compressional and shear wave velocities through the overburden soils above el 0 ft. Two traverse lines ~ 600 ft long were run at approximate right angles to each other (figure 2A-4). One traverse was run approximately along the proposed centerline of the HNP-1 turbine building and the other was run through the HNP-1 reactor and turbine buildings. Seismic velocities were determined by refraction methods using a Dresser RS-4 12-channel seismograph. Dynamite blasts placed in hand augered holes ~ 3 ft below the surface were used as the energy source. Geophone spacings of 25 and 50 ft were utilized.

The data obtained from the refraction surveys are shown on figures 2A-5 and 2A-6. The average velocities within the materials to a maximum depth of 100 ft below the ground surface are:

- Compressional wave velocity =  $6600 \pm 300$  ft/s.
- Shear wave velocity =  $2450 \pm 200$  ft/s.

These data are refraction measurements and, therefore, horizontal velocities. The velocity of vertically propagated waves is ~ 80 to 85% of these values. These velocities represent a single refracting layer which extends to an undetermined depth. They are representative average velocities to a depth of at least 50 ft. No significant velocity increase appears to exist to a depth of 100 ft below the ground surface.

In addition to measurement of compressional and shear velocities, Rayleigh wave arrivals were observed on the seismograph records. The Rayleigh wave velocity observed is about  $2200 \pm 200$  ft/s. This is in good agreement with the measured shear wave velocities.

### 2A.2 SITE CONDITIONS

#### 2A.2.1 TOPOGRAPHY AND DRAINAGE

The topography of the site is a gently rolling surface sloping toward the river. The elevation of the site along the river is ~ 75 ft,<sup>(a)</sup> and it rises to ~ el 172 ft in the southern portion of the site. Thus, there is about 100 ft of relief.

In the northwestern corner of the site, the south bank of the Altamaha River is bordered by a narrow floodplain. However, in the area of the site, the floodplain broadens rapidly at an approximate

---

a. All elevations refer to USC and GS mean sea level (msl) in feet.

## HNP-2-FSAR-2

35-degree angle with the course of the river. This floodplain enlargement is the result of an old stream channel, as shown by the meander scar on figure 2A-7.

The drainage of the site is mainly accomplished by a wet weather branch or a drainage swale that nearly bisects the site in a northeast-southwest direction. This drainage feature branches where it intercepts the floodplain. One of the branches flows northwest into the river while the other branch generally flows east paralleling the river for about a mile before intercepting it. Both follow the old channel.

### 2A.2.2 SOIL CONDITIONS

The site is heavily wooded and in the floodplain area is covered with dense underbrush. In the majority of locations where test borings were made, the site is covered with a surface veneer of topsoil and organic debris. In some locations, borings were placed along existing roads where this organic layer is thin or absent.

The general soil conditions near the site can be characterized in four different areas. The different soil characteristics peculiar in each area occur in the upper soils above ~ el 50 ft. The deeper indurated soils, below el 50 ft, underlying the entire area are quite similar in character and composition. The conditions are portrayed in the cross sections of the plant site which show the significant stratifications and the soil penetration resistances (figure 2A-3). Detailed soil descriptions and penetration resistance data are shown on the boring logs in supplement 2B.

#### 2A.2.2.1 Central Area

Borings B-401, B-411, B-425, and B-426 were made in the central portion of the proposed plant location area. These borings were made well south of the rocky bluff along the river. The ground surface generally varies between el 125 to 130 ft, with boring B-411 on a small ridge with the ground surface elevation of 144 ft.

The uppermost soil stratum in this area consists of firm to dense multicolored silty sands and clayey sands containing scattered clay lenses. The lower boundary of this stratum is between el 100 to 110 ft.

Underlying these surficial sands is a zone of very dense sand to ~ el 80 ft. This dense zone is cemented to varying degrees, creating lens-like to massive rock strata within the zone. The penetration resistances in this zone are generally greater than 100 blows per ft. Within this zone are scattered, very hard, partially cemented clay lenses. The bottom of the zone is indistinct, but approximately at el 80 ft.

Underlying this dense, partially cemented zone and extending approximately to el 0 ft are irregular strata of fine sands and silty sands. These fine sands are generally dense to very dense with penetration resistances from 30 to 50 blows per ft. However, there are erratic zones that are somewhat looser. These zones generally occur between el 80 and 40 ft. Within this same elevation range, the fine sands are somewhat clayey or silty. Below el 40 ft, the fine sands are generally clean; however, silty zones are scattered throughout this zone. Also within this fine sand zone are irregular lenses and nodules of hard clays, which, in many instances, are partially cemented.

## HNP-2-FSAR-2

*Below el 0 ft are generally very dense, gray green fine sands with clay seams. Occurring within this zone are lenses or layers of cream-colored calcareous fine to medium sand, some of which are partially cemented.*

### **2A.2.2.2 Eastern Area**

*The second area of relatively consistent soil conditions is defined by borings B-402, B-404, B-405, B-406, B-407, B-408, B-410, B-416, B-418, B-427, B-430, B-431, and B-432. In this area there is a surface zone of firm-to-dense, multicolored clayey and silty sands with erratic clay lenses between el 100 to 120 ft, similar to that in the central zone.*

*Underlying these multicolored sands are stiff, light gray, fine sandy clays and firm, clayey fine sands. The base of this unit is between el 80 to 90 ft.*

*These sands and clays are underlain by a widespread, thick zone of firm to stiff, light gray green and tan plastic clay which extends as deep as els 60 to 70 ft. These clays display the potential to undergo volume change (swell) with moisture fluctuation or stress relief, as verified by X-ray diffraction identification and swell tests. The base of this plastic clay is sometimes marked by a very hard, partially cemented clay or partially cemented sand layer of limited thickness (2 to 5 ft).*

*Underlying these clays are firm to very dense fine sands with clay seams. These are similar to the fine sands encountered below el 80 ft in the central portion of the site. These fine sands, in turn, are underlain by the same very dense gray green fine sands with clay seams previously described in the central area.*

### **2A.2.2.3 Intermediate Area**

*Between these two areas of relatively different soil conditions is a transition zone marked by borings B-412, B-413, B-417, B-423, B-424, B-428, B-429, and B-435. Again, these borings encountered a zone of firm-to-dense, multicolored clayey and silty sands with clay zones that extend to between els 100 and 110 ft.*

*Underlying these surficial sands is a hard layer which extends to ~ el 75 ft. This hard layer displays partial cementation and is similar to the cemented layer encountered between el 110 and 80 ft by the five borings in the central portion of the site, initially discussed in this section. The hard layer encountered by these transition borings is poorly defined. However, throughout this hard layer there are marked higher penetration resistances.*

*The partially cemented or hard zone is underlain by interlayered firm sands and plastic clays. The base of this zone is quite irregular and lies between el 45 to 60 ft. Except at B-423 and B-424, these interlayered sands are looser and the clays are softer than their equivalents that underlie the cemented sands and clays in the central portion of the site. The clay seams are similar in plasticity and mineralogy to the plastic clays encountered in the remainder of the site.*

*Underlying these interlayered sands and clays are dense to very dense fine sands with clay lenses and seams. These sands are similar to the dense sands generally encountered below el 50 ft over the entire site.*

#### **2A.2.2.4 Floodplain**

*The fourth area of generally consistent soil conditions is along the floodplain of the river where the upper zones of sands and clays, described in the previous paragraphs, have been eroded by the river and replaced by Altamaha River alluvium. Borings B-403, B-409, B-419, B-420, B-421, and B-422 were made in the floodplain area of the river. All of these borings encountered Holocene alluvial soil underlying the organic topsoil. In B-403 and B-409, the alluvium extends to depths of 12 and 13 ft and consists of firm multicolored clayey sands. In borings B-419 through B-422, the alluvial soils initially are stiff to firm mottled fine sandy clays. These soils become coarser with depth and grade to loose and firm sands at depths varying from 4 to 13 ft. These alluvial soils extend to depths varying from 18 to 24 ft. Corresponding elevations are from 58 to 48 ft.*

*Underlying the alluvium are firm and dense silty fine sands which contain some hard and partially cemented clay seams or layers. These sands and clays are similar to the dense sands encountered throughout the site below els 45 to 80 ft. At borings B-420 and B-421, interlayered fine sand and plastic clay, similar to that described in the intermediate area borings, was found above el 33 to 34 ft, respectively.*

*Borings B-576 through B-578 were made in the Altamaha River, drilling from a barge, at the location of the temporary cellular cofferdams. Borings B-579, B-580, B-586, and B-603 were made within or immediately adjacent to the intake structure. Boring B-581 was made near the top of the bluff, south of the intake structure. Boring B-581 encountered the intact geologic sequence as described previously.*

*Moving northward from boring B-581, the upper portions of the geologic sequence have been removed by past activity of the Altamaha River. In some areas, erosion has been followed by deposition of recent river alluvium at the ground surface. Borings B-576 through B-580 and B-586 encountered alluvium at the ground surface. In these borings, the thickness of the alluvial blanket varied from 4 ft in B-577 to 19.5 ft in B-579. Minimum elevations of the base of the alluvium ranged from 49 ft in boring B-457 to 68 ft in boring B-580.*

#### **2A.2.2.5 Plant Location Soil Conditions**

*The soil conditions determined by borings in the power block area are generally consistent with the soil conditions described in subsection 2A.2.2.1. Geologic sections are shown on figure 2A-3. The locations of the borings representing the power block are shown on figure 2A-2.*

*Detailed soil descriptions and penetration resistances are shown on the boring logs in supplement 2B. The uppermost soils in the plant area consist of firm to very dense purple, brown, and gray clayey fine to medium sand with some clay layers. These soils were encountered from the surface to depths of 18 to 29 ft or to between el 110 and 120 ft.*

*The next unit encountered beneath the firm to very dense clayey sand zone is a stratum of very dense gray clayey fine to medium sand which extends to ~ el 75 ft. These dense sands are generally described as partially cemented sands. Within this zone are scattered layers and inclusions of very hard cemented clay and dense sands.*



## HNP-2-FSAR-2

The cemented sands are underlain by firm to very dense gray green sand and clayey sands to ~ el 0 ft. Thin layers of lenses, between 3 and 6 ft thick, of very stiff to hard plastic clay were found between el 60 and 70 ft by borings B-411, B-440, B-445, R-449, T-463, and T-464. These clays are harder than their equivalents found at other areas of the site. Thicker layers of firm gray green slightly clayey fine sands, between 5 and 15 ft in thickness, were found between el 50 and 65 ft by borings B-440 through B-443, R-444, T-445, B-446, B-448, B-449, and R-466. Penetration resistances within these zones generally ranged between 9 and 18 blows per ft.

Very hard gray green silty clays were encountered below ~ el 0 ft.

### **2A.3 LABORATORY TESTING (HNP-1 AND HNP-2)**

Each undisturbed sample and split-spoon sample obtained during the field operations was carefully inspected by a soils engineer and representative samples were selected for detailed testing. Each selected sample, still in its steel tube, was cut into sections with a high-speed abrasive saw. Portions of each sample were removed for moisture and specific gravity determinations. From these data, the sample's void ratio, unit weight, and saturation were calculated.

#### **2A.3.1 ROUTINE CLASSIFICATION**

Detailed classification tests were made of selected samples. These tests included Atterberg Limits on the clayey samples and grain size determinations on the sandier samples. The liquid limit is the moisture content at which the soil will flow as a heavy viscous fluid and is determined in accordance with ASTM D 423-66. The plastic limit is the moisture content at which the soil begins to lose its plasticity and is determined in accordance with ASTM D 424-59. The soil's plasticity characteristic is represented by its plasticity index (PI) which is the difference between the liquid limit (LL) and the plastic limit (PL). The results of Atterberg Limits testing are included in table 2A-1. Also, in situ moisture contents are shown on table 2A-2.

The grain size tests were performed on the sandier samples. The grain size distribution of particles coarser than the No. 200 sieve was determined by passing the samples through a standard set of nested sieves. In most samples, the materials were sufficiently fine that it was necessary to wash the fraction finer than the No. 200 sieve through the sieve. In those samples where the material passing the No. 200 sieve was a major fraction of the total sample, the fine materials were suspended in water and the grain size distribution measured by their rate of settlement. These tests were conducted in accordance with ASTM Specifications D 421-58 and D 422-63. The results of all grain size tests are given in table 2A-1. The grain size curves for borings from the power block area, HNP-1 and HNP-2, and the intake structure are shown on figure 2A-8.

#### **2A.3.2 X-RAY DIFFRACTION TESTS**

The minerals comprising the sediments were identified by X-ray diffraction and petrographic techniques. The clay fraction was separated from the sand fraction and made into a slurry of known clay concentration. The clay slurry was placed on petrographic slides and air dried. One of the sedimentation slides, thus prepared on each sample, was further treated with ethylene glycol at 60°C for

## HNP-2-FSAR-2

1 h. Both the air-dried sedimentation slide and glycol-treated slides were then irradiated on a Phillips X-ray diffraction unit and the X-ray diffractogram analyzed for characteristic clay minerals. The results are presented as the tabulation of X-ray diffraction tests, in table 2A-3.

### 2A.3.3 CONSOLIDATION AND SWELL TESTS

Consolidation and swell tests were performed on representative samples obtained from each soil type or stratum encountered by the borings. Standard testing procedures in accordance with ASTM D 2435-65T were utilized in performing the tests. In all tests, unidimensional consolidometers were used. All consolidation samples were carefully trimmed to discs 2 in. in diameter and 1-in. thick. These discs were sandwiched between porous stones and placed in a stainless steel ring. Samples were loaded to their *in situ* effective overburden pressure in three increments of load. The samples were then unloaded to simulate the condition of general excavation during construction. The minimum unloaded pressure utilized was 300 lb/ft<sup>2</sup>. At the unloaded condition, the samples were given free access to water and allowed to swell or consolidate fully. After all deformation on the micrometer dial had terminated at this inundated-unloaded condition, the samples were loaded in increments to axial pressures of 16,000 lb/ft<sup>2</sup>.

The results of consolidation tests are given in table 2A-4. The void ratio vs pressure curves for borings from the power block area are shown on figure 2A-9. Consolidation test results for HNP-1 and HNP-2 are compared in figure 2A-10.

### 2A.3.4 TRIAXIAL SHEAR TESTS

Quick triaxial compression tests were performed on selected undisturbed samples. These samples were extruded from their sampling tubes and trimmed into cylinders 1.4 in. in diameter. Sample lengths were between 2 and 2.5 times their diameter. Some samples contained numerous inclusions of hard clay which made sample trimming difficult. In these cases, sample diameters of 2.8 in. were utilized. The trimmed samples were encased in rubber membranes and placed in a compression chamber. Each test consisted of a series of three samples and each sample was confined at different air pressures. Axial load was applied to each sample until it failed in shear. The results of all triaxial shear tests are given in table 2A-5. The Mohr envelopes and stress-strain curves for borings from the power block area are shown on figure 2A-11.

### 2A.3.5 CYCLIC TRIAXIAL COMPRESSION TESTS

Dynamic triaxial shear tests were performed on undisturbed samples to evaluate the potential for liquefaction due to repetitive loading. The samples tested were selected from the most sandy portions of the proposed foundation materials between approximate el 50 and 80 ft, where penetration resistances below 20 blows per ft were encountered. Samples representing only the loosest conditions were tested.

Samples of 1.4-in. diameter were utilized for these tests. These samples were encased in rubber membranes and placed within the triaxial compression chamber. Saturation of the samples was obtained by inducing a back pressure within the sample. The samples were allowed to remain under this back pressure for periods of between 12 and 48 h. After saturation was essentially complete, the back pressure and chamber pressure were simultaneously increased. The samples were then allowed to remain under

## HNP-2-FSAR-2

*this back pressure condition until equilibrium was reached, but not < 1 h. In all cases, the equilibrium time was under 1 h.*

*Confining pressures of from 4000 to 6000 lb/ft<sup>2</sup> were utilized for the testing. These are comparable to the average effective confining stresses at the site after construction grading has been completed. A wide range of axial deviator stresses was employed, from ± 1500 lb/ft<sup>2</sup> to ± 3100 lb/ft<sup>2</sup>. The largest deviator stresses were greater than the shear stresses generated by potential earthquakes. The range was designed to establish the relation between cyclical shear stress and the number of cycles required for liquefaction of the loosest sandy soils at the site.*

*Initial liquefaction was defined as the point where the pore water pressure equals the confining pressure. The corresponding strains were generally between 1 and 5%, although a few were as much as 10%. The condition, therefore, is not the complete liquefaction defined by continuing large strains. Instead, the definition used herein lies between the initial and partial liquefaction described by Seed and Lee<sup>(4)</sup> and is referred to as momentary liquefaction. Large strains, denoting complete liquefaction, generally required many additional cycles. However, the condition is more difficult to define accurately from the test data.*

*The results are summarized in figure 2A-12 in which the deviator stress is plotted as a function of the number of cycles required to produce liquefaction as herein defined. The results have been normalized by expressing the deviator stress as a fraction of the confining stress. A second curve, figure 2A-13, shows the deviator stress required to produce complete liquefaction.*

### **2A.4 STRUCTURAL DATA**

*HNP-2 structures are of similar size and produce similar loadings as the structures for HNP-1; also, the elevations of these structures coincide with the elevations of the structures of HNP-1. The following information applies to HNP-2.*

#### **2A.4.1 SITE GRADING**

*The original site level varied from el 75 ft near the river to ~ el 145 ft at the power block area, el 125 ft at the switchyard, and el 118 ft at the cooling towers. Excavations ranging between el 107 and 75 ft were made for the reactor building, turbine building, and radwaste building.*

#### **2A.4.2 REACTOR BUILDING**

*The reactor building is 149 ft by 149 ft in plan area. The static foundation pressures range between 6.2 and 10.1 ksf with a 14.77 ksf maximum edge pressure under maximum transient load conditions. The level for the bottom of the foundation mat is at el 75 ft.*

#### **2A.4.3 TURBINE AND CONTROL BUILDING**

*The combined turbine and control building is 355 ft by 160 ft in plan area. Within the turbine building, the turbine pedestal is 175 ft by 40 ft. The average static foundation pressures for the building and*

pedestal is 6 ksf. The bottom of the mat foundation is at el 105 ft. Intake and discharge water passages extend beneath the turbine pedestal to about el 87 ft.

#### **2A.4.4 RADWASTE BUILDING**

The radwaste building is an L-shaped structure in plan with dimensions 142 ft 3 in. x 93 ft 9 in. in the north-south sides and 121 ft 0 in. x 86 ft 6 in. in the east-west sides. The maximum static foundation pressure is 8.48 ksf. The bottom of the mat is at el 96 ft.

#### **2A.4.5 INTAKE STRUCTURE**

In plan view, the major portion of the structure is rectangular with dimensions ~ 66 ft by 53 ft. A smaller portion of the structure, projecting north, is ~ 45 ft by 27 ft. The gross weight of the structure is 19,400 kips, producing a contact pressure of 4100 lb/ft<sup>2</sup> at el 52 ft over the total foundation area.

Surrounding the intake structure is a system of cellular cofferdams which have top elevations ranging from 85 to 105 ft. The fill surface is graded to slope from el 110 ft at the intake structure to the cofferdams.

The intake structure foundation was inspected by means of soil test borings, laboratory grain size distribution tests, and visual inspection, and conditions were found to be commensurate with those determined by the predesign investigations and studies.

Six soil test borings (figures 2B-133 through 2B-138) were drilled within the intake excavation. The soils' consistency was determined by standard penetration tests performed in accordance with ASTM D 1586. Grain size tests were performed to determine the particle size and distribution of six samples from boring IFI-1. The grain size distribution for soils coarser than a No. 200 sieve was determined by passing the samples through a standard set of nested sieves. Materials passing the No. 200 sieve were suspended in water, and the grain size distribution of the finer fraction was measured by the rate of settlement for 3 of the 6 samples tested. These tests are similar to those described by ASTM D 421-65 and D 422-23. The results are presented on figure 2A-8 (sheets 24-29).

The foundation subgrade was carefully inspected and found to be firm, dry, undisturbed soils typical of those encountered in the preconstruction investigation. The average penetration resistance measured within the fine sands, which constitute the foundations materials for the intake structure, was slightly lower than the average penetration resistance previously measured during the initial investigation for the intake. However, the lowest penetration resistances measured during the inspection are greater than the lowest values measured during the predesign investigation. To evaluate the distribution of standard penetration resistance values within the sands between el 15 and 55 ft, histograms were plotted for both the inspection and the predesign borings. The resulting histogram (figure 2A-14) shows that 80% of the soils had penetration resistances of 25 blows or greater at the time of the original foundation investigation.

The inspection borings, which were made from near the base slab level, indicate that 80% of the soils have penetration resistances of 20 blows or greater. Foundation soils have been unloaded ~ 2000 lb/ft<sup>2</sup> because of excavation to the base slab level. The slight decrease in penetration resistance representing

## HNP-2-FSAR-2

*the lowest quintile of standard penetration resistances is attributed to the decrease in confining stresses within the sand caused by unloading.*

*In addition to studying the penetration resistances representing the fine sand portion of the bearing stratum, the penetration resistances representing equal elevations were studied. From this analysis a penetration resistance was obtained which represents the bearing stratum both before construction and after excavation. A summary of these data is presented below.*

| <u>Before Construction</u> |            |               | <u>After Excavation</u> |            |               |
|----------------------------|------------|---------------|-------------------------|------------|---------------|
| <u>el (ft)</u>             | <u>SPT</u> | <u>rd (%)</u> | <u>el (ft)</u>          | <u>SPT</u> | <u>rd (%)</u> |
| 45                         | 27         | 87            | 45                      | 25         | 90            |
| 35                         | 30         | 85            | 35                      | 20         | 25            |
| 25                         | 27         | 77            | 25                      | 20         | 75            |

*The relative densities tabulated were obtained from the relationship of Standard Penetration Test (SPT) and effective overburden pressure published by Gibbs and Holtz. As can be seen from this tabulation, although the SPT has decreased, the relative density of this stratum is essentially unchanged.*

*Dewatering was accomplished within the intake excavation by a deep-ejector-well point system. At the time of final excavation of the intake, water levels within the excavation appeared to vary between el 46 and 39 ft. Data obtained from 5 piezometers located within the excavation indicated that the water level varied between approximate el 44 and 39 ft. Water levels encountered within the six soil test borings drilled near the foundation level indicated that water levels varied between el 46 and 42 ft. This data substantiates that ground water levels were maintained at least 5 ft below the lowest portion of the intake excavation.*

*The intake excavation was graded to ~ el 52 ft on September 10, 1971. A final 1 ft of excavation was performed on September 13, 1971. A bulldozer and a front-end loader were used to perform the excavation. Upon completion of excavation, the exposed surface was methodically probed and any loose or disturbed areas were undercut.*

*The mud slab was placed on September 13, 1971, the same day that final excavation was performed. The mud slab was ~ 1- to 1 1/2-ft thick with its bottom between el 50.5 and 51 ft.*

### **2A.4.6 MAIN STACK**

*The height of the reinforced concrete stack is 120 m (394 ft) above yard grade (el 119.5 ft). The foundation details and loads are as follows:*

- *Plan dimensions - octagon with 36 ft inscribed radius, top of cap el 108 ft 6 in.*
- *Bottom of cap el 97 ft 6 in.*
- *Pile cut off el 98 ft 3 in.*

## HNP-2-FSAR-2

- 164-14BP73 100-ton piles at 4- to 6-ft spacing in 5 rings with radii of 6 ft, 16 ft, 20 ft, 30 ft, and 34 ft, piles driven to el 20 ft.
- Loads on pile foundation of 114,000 kip-ft moment, 21-500-kips vertical load at pile cap.

A shear of 800 kips is supported by the piles and pile cap.

Subsequent to the preproduction pile load tests, it was decided to modify the field installation methods as follows for production driving:<sup>(16)</sup>

- A. Substitute a Vulcan OR hammer with a rated energy of 30,225 ft-lb for the smaller McKiernan-Terry S68 hammer with a rated energy of 26,000 ft-lb.
- B. Predrill to el 62 using a 20-in.-diameter auger, and then predrill to el 45 using a 14-in.-diameter auger.
- C. Remove the soil from the 20-in.-diameter hole.
- D. Drive the piles and then place concrete to fill the 20-in.-diameter predrill hole.

These procedures were used to install the production piles. Pile tips ranged from el 25 to el 10, and final resistances of the piles almost always exceeded 50 blows for the last foot of penetration.

A typical production pile, R4-30, was selected for load testing. This pile was driven to 48 blows for the last foot, with the pipe tip at el 12. The load test was carried to 240 tons with no indication of failure.

The significant results of the load test are as follows:

| <u>Load</u><br>(tons) | <u>Deflection</u><br><u>Gross</u> | (in.)<br><u>Net</u> |
|-----------------------|-----------------------------------|---------------------|
| 100                   | 0.19                              | Not available       |
| 200                   | 0.49                              | 0.05                |
| 240                   | 0.58                              | 0.07                |

This load test of a typical production pile confirmed that the piles in the stack foundation are capable of supporting more than 200 tons.

The stack was completed in 1973, and surveys of the stack since that time indicate that the maximum settlement recorded is 0.3 in., which is considerably less than the estimated 2 in. Most of the settlement is elastic shortening of the pile.

#### **2A.4.7 DIESEL GENERATOR BUILDING**

*Plan dimensions of the building are ~ 196 ft by 103.5 ft; static foundation pressure is < 3 ksf; bottom of mat foundation is at el 125 ft.*

#### **2A.4.8 SERVICE WATER PIPING AND ELECTRICAL DUCTS**

*The service water piping and electrical duct banks follow the routes indicated on figure 2A-1, sheet 2. The subsurface profile of these routes is shown in figure 2A-3, sheet 7. The soils underlying these buried structures are stable and capable of carrying the small net additional loads imposed on them by the pipes and ducts. The granular soils between el 50 and 80 ft underlying the routes are similar in character and consistency to the materials in the power block area and have factors of safety against liquefaction comparable to the values given for the yard area shown on figure 2A-24.*

*In addition, the following provisions were employed to ensure that allowable piping stresses are not exceeded due to differential settlement between the various foundation and fill materials along the service water piping alignment:*

- A. The site subsurface investigation by drilling and sampling establishes the types of foundation materials beneath the pipelines. Thus, the pipeline routing is selected to provide a satisfactory support for normal operation and extreme conditions such as earthquakes.*
- B. Buried pipelines are installed in ditches dug into natural ground and fill and backfilled with either compacted soil or controlled-density fill (see section 2A.9). The net additional loading on the foundation soils is generally very small since the pipe and the volume of water in it replace the volume of soil. Thus, generally, bearing capacity and settlement are not a problem unless the pipes are laid in or above very soft soils. As can be seen from figure 2A-3, sheet 7, the pipeline is founded on soils competent to support the pipeline loads.*
- C. Soils under the pipelines were evaluated for their liquefaction potential, which precludes any large displacements due to seismic settlement of the sands.*
- D. Between the intake structure and the plant area (figures 2A-1, sheet 2, and 2A-3, sheet 7) the pipe alignment passes through either compacted soil fill or controlled-density fill (see section 2A.9). The compacted soil fill was placed 9 months prior to installation of the pipe, and, therefore, any significant settlement of the fill or the underlying materials generally occurred prior to placement of the pipe. However, a portion of the pipe alignment compacted soil fill was determined to be improperly compacted and subsequently replaced with controlled-density fill as described in section 2A.9.*
- E. The pipes are placed on sand bedding or controlled-density fill (see section 2A.9) to provide a base that will accommodate adjustments of the pipe length over varying local conditions of foundation soil stiffness.*

## HNP-2-FSAR-2

F. After construction, the pipes were hydraulically tested before they were placed in service.

### **2A.5 FOUNDATION EVALUATION**

*The soil conditions delineated by the soil test borings in the HNP-2 power block area compare very favorably with the soil conditions delineated by the subsurface investigations in the HNP-1 area. The soils which constitute the foundation materials for the HNP-2 structures have similar characteristics to the soils which support the HNP-1 structures.*

*It is noted that the penetration resistances within the fine sands which constitute the foundation materials for the HNP-2 reactor building are somewhat lower than the penetration resistances measured during the initial investigation of the HNP-1 structures. The decrease in penetration resistance at the HNP-2 area is attributed to the unloading which has been accomplished by grading and excavation for HNP-1.*

*The original borings in the HNP-1 area were drilled from elevations varying from 135 to 146 ft. The frequency distribution of all penetration resistances made in these borings within the fine sands below el 75 ft was plotted. The resulting histogram showed that 80% of the soils had a penetration resistance of 31 blows or greater. Subsequently, additional borings were made as a part of the foundation inspection in the HNP-1 area. These borings were made from the base slab elevation of ~ el 75 ft. The frequency distribution of the penetration resistances of these borings was also plotted and indicates that 80% of the penetration resistances were in excess of 13 blows per ft. The difference in the penetration resistance representing 80% of the soils is attributed to unloading effects and is a generally recognized occurrence in sand. Figure 2A-15 is the histogram for HNP-1 before and after excavation.*

*Borings for the HNP-2 investigation were made from both the elevation of the excavation for HNP-1 and the general yard level at el 130 ft. As was done for the HNP-1 data, the frequency distribution of all borings within the fine sands below el 75 ft was plotted. A penetration resistance of 24 blows per ft or greater was determined to represent 80% of the soils in the HNP-2 area. Six of the borings studied were made at elevations below el 105 ft, whereas the remaining nine borings were made at elevations near el 130 ft. Ten additional borings were made as a part of the foundation inspection in the HNP-2 area. These borings were made from the base slab elevation of ~ el 75 ft. The frequency distribution of the penetration resistances of these borings was also plotted and indicates that 80% of the soils have penetration resistances of 15 blows or greater. As with HNP-1, the decrease in penetration resistance is attributed to the decrease in confining stress within the sand caused by unloading. Figure 2A-16 is the histogram for HNP-2 before and after excavation. From a comparison of this data with HNP-1 (figure 2A-15), it is concluded that the consistency of the soils as measured by penetration tests for HNP-2 closely agrees with the consistency of the soils previously determined in the HNP-1 area.*

*In addition to the above comparison, the grain size distribution for the foundation soils of HNP-1 and HNP-2 compares very favorably. Figure 2A-8, sheet 30, compares the results of grain size tests with depth. Figure 2A-8, sheet 31 through sheet 34, compares the shapes of curves at specific elevations. Also, the settlement properties of soils under the two units (as compared in figure 2A-10) are similar. The results of these laboratory tests further support the similarity of the soil conditions of HNP-1 and HNP-2.*

*The soil at this site is quite satisfactory for the nuclear power plant with its imposed static and transient loads. The site excavation to el 130 ft and the pit excavation for the reactor building amount to an*



## HNP-2-FSAR-2

*unloading equal to ~ 50% of the imposed static load. In the turbine building and radwaste building areas the excavation unloading is approximately equal to the imposed static load.*

*The strength characteristics of the dense foundation soils complemented by the weight of the soil removed by site grading and pit excavation provide an excellent foundation for the plant structures. The allowable static-bearing capacity is in excess of 15,000 lb/ft<sup>2</sup>.*

*Settlement predictions have been made for the HNP-2 reactor building, turbine building, turbine-generator pedestal, and radwaste building. These predictions utilized stresses calculated in accordance with the Westergaard theory<sup>(5)</sup> and considered stress overlap from all nearby foundations. For stress calculation purposes, the loads imparted to the foundations were considered to be the structural dead loads plus live loads. The soils compressibility characteristics were determined by one-dimensional laboratory consolidation tests.*

*The total settlement of the HNP-1 reactor building was calculated to be 3 in. The total settlement of the HNP-1 turbine building, including the turbine pedestal, and the radwaste building was calculated to be 1.5 in. The majority of the total settlements occurred during construction. For HNP-2, the total settlement for the reactor building is estimated to be 4.5 in. The estimated post-construction settlement is predicted to be 0.5 in. for the reactor building and < 0.5 in. for the turbine and radwaste buildings. The maximum post-construction differential settlement of the structures should be < 0.5 in. A summary of settlement estimates for both units is shown on table 2A-6.*

*To confirm the predicted settlements and check piping stress due to differential settlement, a program of monitoring the base slab settlements of the major plant structures was established.*

*It should be noted that the observed settlement beneath the HNP-2 reactor building reported in figure 2A-17, sheet 2, is not a complete record of the settlement that the soil has experienced. These data reflect only the settlement that has taken place since construction of the mat was begun. It does not include the settlement which occurred during the construction of HNP-1. The HNP-1 reactor building was completed at approximately the same time the HNP-2 mat was started.*

*The record in figure 2A-16, sheet 2, provides information on the consolidation after construction. Comparison of these data with figure 2A-18, sheet 1, indicates that the 2 reactor buildings have experienced most of the settlement which can be expected, and the settlement now occurring is the expected consolidation after construction. (Refer to table 2A-6.)*

*The settlement of HNP-2 due to the construction of HNP-1 can be estimated by examining the HNP-1 record (figure 2A-18, sheet 1) for the effect of the construction of HNP-2 and then extrapolating that settlement to HNP-2. This increases the total settlement to ~ 2 in. (slightly less than the observed values for HNP-1 total settlement).*

*Although this adjusted value is still less than the predicted settlement (table 2A-6), it is reasonable. In soils engineering practice, a settlement estimate is considered good if the observed settlement is within  $\pm 50\%$  of the predicted value. In this case, the settlement predicted for the HNP-2 reactor building after construction is 4 in. (an additional 0.5 in. is predicted for long-term consolidation after construction; see table 2A-6). The 2 in. of settlement which appears to have taken place is within 50% of the predicted value.*

## HNP-2-FSAR-2

*The settlement records for the HNP-1 radwaste building are shown in figure 2A-18, sheet 2. A settlement-monitoring program for the HNP-2 radwaste building has been started. Figure 2A-17, sheet 5, provides the settlement record for the HNP-2 radwaste building.*

*Static undrained triaxial sheet tests were performed utilizing both consolidated and unconsolidated conditions. Elastic moduli were calculated using the elastic portion of the stress strain curves from these tests. The graph of average elastic moduli (figure 2A-19) represents weighted averages at confining pressures commensurate with in situ overburden stresses. Individual moduli ranges per geologic formation are also shown on figures 2A-20 through 2A-23.*

*The HNP-2 foundation subgrade was inspected to confirm that the subsurface conditions encountered during construction were similar to those previously determined by the predesign investigations and studies. This was done by means of soil test borings, hand auger borings with cone penetrometer tests, laboratory grain size distribution, triaxial and consolidation tests, and visual inspection.*

*The inspections confirmed that subsurface conditions closely coincide with the conditions predicted by the predesign soil investigations which are reported in section 2.5 and supplement 2A.*

*Borings RFI-1 through RFI-10 were performed as part of this inspection. The logs of these borings are shown in supplement 2B, figures 2B-113 through 2B-122, and the locations are indicated in figure 2A-2.*

*Fifteen hand auger borings with cone penetrometer tests were performed within the HNP-2 reactor area. These borings were advanced by manually twisting a sharpened steel auger into the ground. The soils encountered were identified from the cuttings brought to the surface.*

*At regular intervals, the auger was removed and the soil consistency measured with a cone penetrometer. The conical point was first seated to penetrate any loose cuttings and then driven an additional 1 3/4 in. with blows from a 15-lb hammer falling 20 in. The number of hammer blows to achieve this penetration was recorded and is an index to the soil strength and density.*

*Cone penetrometer data were used to detect soft surface areas and to confirm suitable surface conditions. Boring records showing soil stratigraphy and consistency determined by the hand auger and cone penetrometer methods are given in table 2A-7.*

*Grain size tests were performed to determine the particle size and distribution of the samples tested. The grain size distribution of soil particles coarser than a No. 200 sieve was determined by passing the samples through a standard set of nested sieves. Materials passing the No. 200 sieve were suspended in water and the grain size distribution measured by the rate of settlement in water. These tests are similar to those described by ASTM D 421-58 and D 422-54T. The results are presented on table 2A-1 and figure 2A-8.*

*Consolidated-undrained triaxial shear tests were performed to determine the shear strength of two representative samples of foundation soils. The test results are presented in table 2A-5. The stress-strain curves and Mohr diagrams are shown on figure 2A-11.*

*Two undisturbed samples were selected for consolidation testing to determine the settlement characteristics of the foundation soils. These test results are presented in table 2A-4 and figure 2A-9.*

## HNP-2-FSAR-2

*The average penetration resistance measured within the fine sands, which constitute the foundation materials for the HNP-2 reactor building, was slightly lower than the penetration resistances measured during the initial investigation for this structure. This was also observed during the HNP-1 inspection.*

*The relative density of the loosest sand sample was also determined from the relationship of standard penetration resistance and effective overburden pressure published by Gibbs and Holtz. This analysis indicates that the loosest sand zone encountered during the HNP-2 foundation inspection has a relative density of 50% and that generally the relative density is much higher. This relative density of 50% for the loosest sands below foundation level is the same relative density value determined during predesign liquefaction studies for the loosest sand zones. Therefore, the safety factors against liquefaction, as presented in the predesign foundation evaluation, are valid.*

*Data from triaxial shear tests performed on firm clayey sand samples obtained from immediately below HNP-2 area confirm that the soil strengths, which have previously been reported and used in bearing capacity analyses of the powerhouse structures, are conservative.*

*Consolidation tests performed on representative samples of the loosest sands and softest clay below HNP-2 indicate that the settlement characteristics are similar to soils previously reported in the predesign and settlement analyses. Therefore, the settlement estimates needed no revision.*

*The predicted and actual observed settlement of the major Category I structures are discussed in subsection 2A.5.3. The settlement records are given for each monument on figures 2A-17 and 2A-18, sheets 1 through 4.*

### **2A.5.1 PLANT FOUNDATIONS**

*In the plant area, very dense partially cemented sands with clay seams are present down to ~ el 80 ft. This partially cemented layer is generally underlain by sands containing hard clay seams or lenses which extend to ~ el 0 ft. In this area of the site, the soft to firm plastic clay was not encountered.*

#### **2A.5.1.1 Reactor Building**

*The HNP-2 reactor building, with its foundation at el 75 ft, bears on firm-to-dense sands and clayey sands with layers of plastic clay. Using soil strength parameters based on triaxial test data, the computed safety factor against bearing capacity failure for this foundation is in excess of three.*

*The sands which support the reactor building are, in general, dense and incompressible. Settlement occurring from these sands is calculated to be on the order of 4.5 in. This settlement is relatively uniform and will occur primarily during construction. Maximum post-construction settlement beyond a period of 6 months is in the range of 0.5 in. The foundation soils will not be adversely affected by earthquake shock or vibratory loading.*

**2A.5.1.2 Turbine and Control Buildings**

*The HNP-2 turbine and control buildings with the bottom of the foundation slabs at el 105 ft, bear on a relatively thick zone of cemented sands underlain by firm-to-dense clayey sands with lenses or layers of plastic clays. These soils are capable of safely supporting the design loads with a bearing capacity safety factor in excess of 3.*

*The total settlement of the foundation soils is calculated to be 2 in. The zone of cemented sands beneath the turbine slab is incompressible. However, stress increases within the underlying zone of firm sands due to the weight of the building account for the expected settlement. Most of this settlement occurred during construction. The long-term post-construction settlement will be negligible. The foundation soils will not be adversely affected by shock or vibratory loading.*

**2A.5.1.3 Radwaste Building**

*The radwaste building, with its base slab at el 100 ft, bears on soils comparable to those described for the reactor building. These soils are capable of safely supporting the design loads for the radwaste building. The total calculated settlement for this structure is 3.5 in. The settlement occurred largely during construction with negligible post-construction settlement.*

**2A.5.1.4 Intake Structure**

*Support of the intake structure is on a mat foundation at el 52 ft. Based on 4100 lb/ft<sup>2</sup> bearing pressure, the safety factor against bearing capacity failure is in excess of 5. Both the intake structure alone and the influence of the adjacent cofferdam were considered in this evaluation.*

*The settlement of the structure prior to the placement of the backfill was expected to be ~ 1.5 in. The additional settlement due to the zone of backfill around the structure is in the order of 0.5 in. As of April 1976, the total measured settlement of the intake structure was 1 1/4 in.*

**2A.5.1.5 Main Stack**

*The stack is supported on pile foundations. The 11-ft-thick base pad is octagonal with a 72-ft-diameter inscribed circle. The foundation system consists of 165 100-ton piles in 5 concentric rings. The bearing strata for piles are the dense sands below el 50 ft. Static analyses indicate that the 14-in.-H sections develop 100-ton capacity when driven to ~ el 20 ft. In order to obtain the required embedment, predrilling to ~ el 45 ft was required to penetrate the dense and hard soils above that elevation.*

*Predrilling was limited to 14-in. or 20-in.-diameter holes. In order to ensure lateral support throughout the pile length, the 20-in.-diameter holes were backfilled with concrete after driving the piles. Analysis based on the previously given loading data and laboratory consolidation tests indicate that settlement of the pile group is in the order of 2 in.*

**2A.5.1.6 Diesel Generator Building**

*The diesel generator building, with its spread mat foundation at el 125 ft, bears on very dense clayey fine to medium sand with some clay layers extending to ~ el 120 ft.*

*Between el 120 and 70 ft are very dense medium to fine clayey sands with scattered layers and inclusions of very hard cemented clay and dense sands. The foundation pressure is < 3 ksf.*

**2A.5.2 SOIL LIQUEFACTION POTENTIAL**

*Irregular localized seams of sandy soils having penetration resistances < 20 blows per ft were found between el 50 and 80 ft. These soils were considered possibly susceptible to liquefaction. Cyclical shear tests were run on samples of the loosest sandy materials encountered, as described in subsection 2A.3.5.*

*The results of these tests were analyzed assuming that the site may undergo an earthquake where maximum horizontal acceleration at the ground surface is 0.15 g corresponding to the design basis earthquake for this site. The approach advanced by Seed and Idriss<sup>(6)</sup> was utilized to evaluate safety factors with respect to liquefaction.*

*If the soil between the ground surface and a depth h below the ground surface responded as a rigid body to the motions induced by the earthquake, the maximum shear stress in the soil at depth h would be equal to 0.15 γh, when γ is the unit weight of the soil. Since the soil is, in fact, a deformable material, the actual maximum shear stress will be somewhat < 0.15 γh, the reduction depending on the distance h and the characteristics of the soil profile. Studies by H. B. Seed show that the maximum shear stress at a depth of 70 ft (or el 58 ft) would be ~ 70% of the value corresponding to a rigid body behavior, giving a maximum shear stress at this depth of ~ 0.105 γh.*

*For any given earthquake, the maximum acceleration (and the corresponding maximum shear stress) occurs only once. A typical strong motion earthquake, such as the El Centro, may include about 10 large cycles of motion as well as many smaller ones. The average amplitude of shear stress or acceleration for these cycles is substantially less than the maximum. A conservative value for the average is ~ 75% of the maximum. On this basis, it was concluded that at el 58 ft, the effective average shear stress developed for 10 cycles during the maximum hypothetical earthquake would be ~ 0.75 x 0.105 γh = 0.08 γh.*

*The safety factor against liquefaction is defined as the shear stress required to cause liquefaction of soil samples in 10 cycles divided by the average shear stress induced by the 10 largest shocks of the earthquake. Safety factors have been calculated for both momentary and complete liquefaction at various points beneath the proposed structures and outside the proposed structures.*

*The cyclical shear stress required to produce liquefaction at 10 cycles is a function of the soil's relative density as well as the confining pressure.*

$$\tau_{L10} = \frac{\sigma' \times R_D}{\text{constant}}$$

## HNP-2-FSAR-2

where:

$\tau_{L10}$  = shear stress to cause liquefaction in 10 cycles.

$\sigma'$  = effective overburden pressure.

$R_D$  = relative density.

The constant of proportionality determined by Seed and Idriss<sup>(6)</sup> for Sacramento river sand is 200. Assuming that this relationship applies to the soil at the HNP site, the data for momentary liquefaction indicates a constant of 172. This indicates that the sands tested are ~ 15% stronger under cyclical loading conditions than the sands tested by Seed and Lee.<sup>(4)</sup> This additional strength is attributed to the following factors:

- A. The samples tested are undisturbed samples which have been subjected to preconsolidation pressures and the development of some permanent microstructure.
- B. The samples tested contain up to 14% clay. Therefore, they are not truly cohesionless materials.

Applying the same equation of proportionality to the point defined as complete or continuing liquefaction, it was determined that constant of proportionality is 151.

The cyclical triaxial shear test requires that samples be isotropically consolidated for testing. The *in situ* state of stress, however, varies from this isotropic condition by the value of  $K_o$ . It has been found that the cyclical triaxial shear test results are somewhat more optimistic than those of the simple shear but that they are proportional. According to Professor Seed,<sup>(7)</sup> the triaxial test results realistically simulate the soil behavior during actual earthquakes if the dynamic strengths are multiplied by 0.55. The dynamic strengths discussed herein have been reduced in this fashion.

In making the analyses, two possible relative density conditions were evaluated. The average relative density of the soils tested was 50%. (The use of the relative density concept in silty clayey sands is questionable, but the determination was made as a guide.)

The relative density corresponding to the poorest 20% of the sandy soils in question is 60%, contrasting with the average of 50% of the samples tested. Therefore, one set of safety factors was computed utilizing the test strengths corrected for a relative density of 60%. A second set was computed directly from the test results.

The safety factors were also computed for four different water levels - el 77, 85, 93, and 105 ft. These levels represent the highest observed level in the plant area, a 10-year flood peak, a 1000-year flood peak, and a maximum theoretical flood, respectively.

The safety factor against liquefaction is defined as the shear stress required to cause liquefaction of soil samples in 10 cycles divided by the average shear stress induced by the 10 largest shocks of the earthquake. Safety factors have been calculated for both momentary and complete liquefaction at various points beneath and outside the proposed structures as shown on figure 2A-24. The lowest computed safety factor was 1.4.

## HNP-2-FSAR-2

*In view of severe stresses selected for laboratory testing, even the loosest sands (those encountered between el 80 and 50 ft at this site) is not adversely affected by shock or vibratory loadings of the magnitudes and durations that occur due to earthquake forces.*

*Other characteristics which also support the fact that there is no liquefaction hazard at the site are:*

- A. The penetration resistances of the sands beneath the bearing stratum have been compared with penetration resistance data of sands which have and have not experienced liquefaction during a 1964 earthquake in Niigata, Japan.<sup>(8)(9)</sup> Those sands that experienced liquefaction display a preponderance of penetration resistances between 5 and 15 blows per ft. Most sands at the site have penetration resistance values between 25 and 55 blows per ft. The sands from the site are denser than the sands that did not experience liquefaction at Niigata, and are far denser than the sands that experienced partial liquefaction.*
- B. The grain size distributions of the sands at the site have also been compared with the Niigata data. Although some of the sands fall partially within the range of the sands at Niigata, in most cases the site materials contain more fines (15 to 25% of the material passes the No. 200 sieve) than potentially liquefiable materials are considered to have.*
- C. In areas where liquefaction has occurred, the soils have been alluvium, Quaternary glacial outwash, or loose uncompacted fill. The soils at this site are at least 13 million years old (Miocene) and have been heavily preconsolidated.*

*It is concluded that the soils at this site display a very large margin of safety against liquefaction failure if subjected to earthquake shocks of the magnitude postulated for this site.*

### **2A.5.3 BUILDING SETTLEMENT MONITORING**

A comprehensive building settlement monitoring program was begun for selected buildings in HNP Units 1 and 2 in 1980. The plan tracked total building settlement and differential settlement across structures from 1980 to 2006. In January 2007, it was determined that time deflection/settlement curves for virtually all points of possible settlement were essentially flat and had been for 25 years. Southern Company issued correspondence (Log # NL-07-0175) providing justifications for terminating the building settlement monitoring program. This section of the FSAR is included for historic reference only.

*Building settlement is monitored for the following buildings:*

- HNP-2 reactor building.*
- HNP-2 turbine building.*
- HNP-2 radwaste building.*
- Diesel generator building.*

## HNP-2-FSAR-2

- *Intake structure.*
- *Main stack.*
- *Control building.*
- *HNP-1 reactor building.*
- *HNP-2 turbine building.*

*The HNP-1 buildings are monitored due to their proximity to the HNP-2 buildings.*

*Building settlement monitoring is divided into the following major categories:*

### *A. Total Settlement*

*The total settlement of each structure is measured and compared with the predicted settlement to assess the accuracy of the settlement predictions and to obtain an indication of settlement trends.*

### *B. Differential Settlement Across Structures*

*The differential settlement across each building is measured to assess the tilt of the building and to compare this value with the allowable tilt which is based on preventing building structural and equipment damage.*

### *C. Penetration Differential Settlement*

*Two types of differential settlement are considered under this category. The differential movement at a penetration can be caused by differential settlement between adjacent buildings or between building and soil. The allowable displacements at the penetrations are calculated using pipe stress analysis methods and are compared with settlements measured at nearby benchmarks.*

### **2A.5.3.1 Total Settlement**

#### **2A.5.3.1.1 Measurement**

*Settlement values are determined by measurements which are compared with known elevations at established reference benchmarks. The locations of the reference benchmarks are shown on drawing no. H-12523. Elevations of the benchmarks were originally established from a United States Geological Survey (USGS) benchmark in Toombs County. The benchmarks are situated in the yard in such a way as to avoid accidental displacement and facilitate the settlement surveys of the Category I buildings. They are far enough away to avoid settling with the buildings and are placed in areas isolated from traffic which might disturb the marker. Precautions were also taken to provide proper soil and anchorage*



## HNP-2-FSAR-2

conditions to ensure the stability of the benchmarks. There is no procedure for periodically checking the elevations of the reference benchmarks.

A plant operating procedure established a detailed method for monitoring settlement of Category I structures for HNP-1 and HNP-2. A series of special drawings were also drawn to clearly locate the benchmarks and establish a fixed survey route. These drawings are referenced in and supplement the procedure. The procedure establishes the order in which specific survey routes are followed and requires closure of each survey route for a specific building or structure before continuing. Acceptance criterion for closure error is 0.005 ft. The procedure establishes a specific format for recording the final elevation data. This procedure establishes as much consistency as possible from one survey to the next in order to make any change or abnormality immediately apparent.

The benchmarks established inside all buildings except the reactor building are 1/2- to 3/4-in. self-drilling "red head" expansion anchor bolts set in the floor or walls of the structure. Benchmarks on the exterior walls of structures are similar. Benchmarks in the reactor building are 3/4 in. x 3/4 in. x 6 in. to 12 in. brass embedded in the concrete floor. This leaves ~ 1/4 in. of the bar exposed above the floor resulting in a 3/4 in. to 3/4 in. x 1/4 in. exposed benchmark. Outside benchmarks are poured in place concrete posts ~ 1 ft x 1 ft square by 2 ft 6 in. long with a maximum of 1 ft exposed above ground level. This leaves a minimum of 1 ft 6 in. embedded below ground. A 3/4-in. galvanized bolt is embedded in the center of the top of the post, and the top is sloped away from the center for drainage.

Measurements of structure movements were obtained by periodically reading the elevations of benchmarks established generally at the beginning of construction. Settlement versus time curves for each structure, except the intake structure, were developed. (See figures 2A-17 and 2A-18.) Only one benchmark was originally set on the intake structure; four new benchmarks were set in July 1978. The total measured settlement of each structure was obtained by averaging the settlements at each benchmark. These average measured settlements in most cases represent the total settlements since the beginning of construction, although the settlement records are not always clear on precisely at which stage of foundation construction the monitoring started.

### **2A.5.3.1.2 Comparison of Predicted Versus Measured**

The ratios are highest at the control and intake structures; these were constructed earlier than the HNP-2 buildings and have had longer to settle. No significant settlement of either of these structures has occurred since October 1978. It can be observed that the settlement curves have flattened out. As predicted, the large majority of settlement appears to have taken place during construction due to the mainly granular nature of the foundation soils. The ratios of the measured settlements to the predicted settlements are shown in table 2A-8.

### **2A.5.3.1.3 Allowable Total Settlements**

The total allowable settlements are 4.5 in. for the reactor building and 2.5 in. each for the control building, diesel generator building, main stack, and intake structure.

### **2A.5.3.2 Differential Settlement Across Structures**

#### **2A.5.3.2.1 Allowable Differential Settlements**

*To establish allowable differential settlements across the Category I buildings, the foundations are assumed to be completely rigid. As the building settles, the entire structure moves vertically and/or rotates as a plane rigid body. The allowable differential settlement values place a limit on the amount or rotation of each building as settlement occurs. Two criteria were developed to cover the buildings under consideration; the choice of criterion is based primarily on distance to adjacent buildings. The criteria are summarized in table 2A-9.*

*The first criterion covers structures which are not in close proximity to other buildings, i.e., the main stack, the intake structure, and the diesel generator building. The criterion developed limits the tilt of the building to ensure the appearance and proper functioning of all operating systems and equipment. In order to satisfy this criterion, a limiting settlement profile slope of 0.002 radians was used to calculate allowable differential settlements between the established benchmarks in the corners of each building. The 0.002 slope value is for structures with rigid foundations and is tabulated in the Navy Design Manual.<sup>(10)</sup>*

*The second criterion applied to structures concentrated in the powerblock and separated by a gap of 3 in. from surrounding structures. Included in this group are the control building, turbine building HNP-1 and HNP-2, reactor building HNP-1 and HNP-2, and the radwaste building HNP-2. The criterion developed for these structures limits the tilt of each building to ensure that two adjacent buildings do not touch during a possible operating basis earthquake (OBE). A summary of the allowable slope calculation procedure is shown in figure 2A-26.*

*Based on the allowable slopes derived for the buildings, the allowable differential settlement values were calculated between the established benchmarks in each of the Category I buildings. The allowable settlements represent the worst case. In order to touch during the earthquake, the buildings must lean towards each other and both must reach or exceed the allowable tilt simultaneously. The fact that a building has reached the maximum allowable tilt value does not necessarily mean that touching would occur during the OBE.*

#### **2A.5.3.2.2 Measured Differential Settlements**

*To determine the actual differential settlements, reference elevations have been established for the benchmarks in each building. A reference elevation is defined here as an elevation which can be compared with current survey elevation readings to indicate the existing degree of differential settlement. These reference elevations are based on the survey readings taken at the approximate structure completion date of each building. This date corresponds to the time when the structure is assumed to be properly aligned, both with respect to itself and to any adjacent building. Existing differential settlement will be measured from this reference date and compared with the allowables.*

*For those cases where a benchmark location has been altered in the field since the completion date of the building, an adjustment must be made to the reference elevation. This adjustment ensures that the*

reference elevation can be compared directly with the current readings to establish differential settlement.

Using the reference elevations and the latest survey values, the settlement of each benchmark from the reference date to the present can be determined. A comparison of settlement values of any two benchmarks within a building provides the differential settlement between the benchmarks. The reference dates and elevations are summarized in table 2A-10.

**2A.5.3.2.3 Comparison of Allowable and Measured Settlements**

Comparison of the existing and allowable differential settlements of the Category I structures of HNP-2 indicates that there has been little differential settlement to date, and that the existing settlement is well below the allowable differential settlement values for each of the buildings examined. The comparisons are provided in table 2A-11.

**2A.5.3.3 Penetration Differential Settlement**

**2A.5.3.3.1 Allowable Differential Settlements**

The amount of differential movement each penetration can withstand before the pipe or pipe anchor (or support) becomes overstressed was computed for penetrations entering the building directly from the soil and for penetrations passing between adjacent buildings. Either the pipe or the pipe anchor can become overstressed due to penetration settlement.

For pipes, the allowable stress criterion is:

$$\frac{iM_D}{Z} \leq 3.0 S_C \text{ (reference 11)}$$

where:

- $i$  = stress intensification factor.
- $Z$  = pipe section modulus.
- $M_D$  = moment due to building settlement.
- $S_C$  = allowable stress in cold condition.

For anchors, the allowable stress criterion is:

$$M_D \leq M_{\text{anchor design}}$$

or

## HNP-2-FSAR-2

$$\sigma \leq \sigma_{\text{allowable}}$$

where:

$M_{\text{anchor design}}$  = moment from pipe stress analysis (seismic, thermal).

$\sigma_{\text{allowable}}$  = particular allowable stress in anchor parts (bearing, bending, bolt shear, etc.)

*For penetrations leading from the structure into the soil, the moments in the pipes and anchors produced by building settlement were computed by one of three methods. The first method is more conservative by assuming the pipe anchor to be rigid; with this assumption, small settlements tend to produce large stresses in the pipe and anchor. The second method assumes a degree of flexibility in the anchor; moments are obtained from a computer calculation using a pipe stress program. The third method assumes changes to have been made in the pipe anchors to allow more flexibility, and also requires computer solution.*

*For penetrations passing between adjacent structures, the moments in the pipes and anchors produced by the differential movements of the structures were computed by one of the two methods outlined in table 2A-12. Again, the first method is more conservative by assuming rigid anchors and double-acting hangers. The second method assumes a degree of flexibility in the anchors and considers single-acting hangers, where applicable.*

*In all of the penetrations analyzed except at the intake structure, methods 1 or 2 indicated allowable settlements large enough to present no major measurement problems in the future life of the plant. At the intake structure, allowable settlements calculated by methods 1 or 2 were unacceptably low. The intake structure penetrations were reanalyzed by assuming that anchors and supports were modified to allow more flexibility in the pipe; fixity was assumed to be ~ 10-pipe diameters outside the walls (method 3). This analysis, assuming the modifications, produced acceptably high allowable penetration settlements.*

*The conservative assumptions used in determining the allowable settlements involve mainly soil behavior. No account is taken of the fact that some movement of the soil adjacent to the building takes place as building movement occurs. Movement of the soil with the building reduces the amount of differential settlement between building and soil. In addition, time and relaxation effects are not taken into account. Settlement of the building is slow enough to ensure that stresses built up in the soil due to penetration movement is redistributed with time, reducing the level of stress in the pipes and anchors.*

### **2A.5.3.3.2 Measured Differential Settlements**

*Differential settlements of the penetrations since installation were measured by assuming the settlement of the penetration to be the same as the settlement of the nearest benchmark. For each penetration leading from the structure into the soil, reference was made to the appropriate settlement curve to obtain the maximum settlement which had occurred since the date of penetration completion. It should be noted that the maximum settlement is not necessarily the settlement between the penetration completion date and the present. The settlement pattern of most of the benchmarks is presently nearly level, with dips and peaks; maximum settlement frequently occurs in one of the dips established prior to the present.*

## HNP-2-FSAR-2

For penetrations passing between adjacent structures, the settlement of the benchmarks closest to the penetration on both structures must be considered. The settlement curves of the two benchmarks from date of penetration installation to present are compared. Review of the curves indicates that maximum differential settlement does not necessarily occur on the most recent date.

### 2A.5.3.3.3 Comparison of Allowable and Measured Settlements

The ratios of the maximum measured settlement to the allowable settlement for the penetration pipes and anchors have been calculated and are indicated in tables 2A-13 through 2A-20. It is evident that, at present, the measured settlements exceed ~ 30% of the allowable in only isolated cases, and the majority are < 20% of the allowable. These low ratios reflect two related factors: first, the majority of the penetrations have been installed since late 1976; and second, settlement values since late 1976 have been very small. In general, the small ratios are more a function of small measured settlements than large allowable settlements.

### 2A.6 SLOPE STABILITY

Slope stability analyses indicate that the permanent slopes in the plant area as designed are stable and conservative. The stability of the intake structure and the river bluff immediately adjacent thereto have been analyzed. The calculated minimum safety factors for various conditions are as follows:

| <u>Failure Mode</u>                                                                                              | <u>Minimum Safety Factor</u> |
|------------------------------------------------------------------------------------------------------------------|------------------------------|
| A. Circular arc-river banks ~ 100 ft upstream of the intake structure, pseudostatic, <sup>(a)</sup> $a = 0.15 g$ | 1.7                          |
| B. Circular arc through intake structure-static                                                                  | 3.4                          |
| C. Circular arc through intake structure, pseudostatic, <sup>(a)</sup> $a = 0.15 g$                              | 2.3                          |
| D. Sliding through intake structure-static                                                                       | 2.8                          |
| E. Sliding through intake structure, pseudostatic, <sup>(a)</sup> $a = 0.15 g$                                   | 2.1                          |

The section analyzed for condition A above is shown on figure 2A-27.

Sloped excavations to the base slab levels of the power block structures were maintained. The firm to dense clayey sands which extend from the surface to ~ el 120 ft, were excavated no steeper than 45 degrees with the horizontal. The very dense sands which underlie the dense clayey sands to ~ el 75 ft are stable for excavation slopes flatter than one-half horizontal to 1 vertical. These requirements necessitated the use of a composite slope for the power block excavation (figure 2A-27). The factor of safety against massive failure was 1.3. No significant breakouts occurred within the power block excavation.

## HNP-2-FSAR-2

*The seismic stability of the riverbank in the site vicinity was later reevaluated. The following information is presented to demonstrate the stability of the riverbank and the margin of safety against its failure during or after the design basis earthquake*

*Three additional standard penetration test borings, B-2001, B-2002, and B-2003 were performed in the vicinity of the river bluff upstream of the intake structure. These borings were used to define better the extent of the low-blow-count zone encountered in boring B-458. The locations of these borings are shown in figure 2A-1, and the logs are presented in supplement 2B. A fourth boring, B-2001A, was drilled next to boring B-2001 to obtain undisturbed samples for laboratory testing.*

*Index properties tests, i.e., grain size, water content, unit weight, and Atterberg limits, were performed on all samples from boring B-2001A. Consolidated, undrained, static triaxial shear tests were performed on undisturbed samples. Stress-controlled cyclic triaxial tests were performed on undisturbed samples of the low-blow-count sands. Results of the index-properties tests are given in table 2A-1 and figure 2A-8. The static triaxial test results are shown in table 2A-5 and figure 2A-11. A summary of the cyclic strength results are presented in table 2A-21 and figure 2A-28.*

*The profile developed for analysis of the river bluff is shown in figure 2A-30. A pocket of loose sands was encountered in borings B-2001, B-2002, B-2003, and B-458. No such loose material was found in boring B-459.*

*The individual cyclic triaxial test data plots are presented in figure 2A-29, sheets 1 through 13. Note that the plots present peak-to-peak ranges of measured quantities.*

### **2A.6.1 LIQUEFACTION POTENTIAL OF LOOSE ZONE**

*As a first step in analyzing the stability of the bluff, the liquefaction potential of the pocket of loose sands has been evaluated by using the method developed by Seed and Idriss.<sup>(10)</sup> The cyclic strength data shown in figure 2A-28 are used for this evaluation. The factor of safety against liquefaction is defined as:*

---

a. Earthquake forces considered to be equivalent static forces.

## HNP-2-FSAR-2

$$\text{Factor of safety} = \frac{\tau_f}{\tau_d}$$

where:

$\tau_f$  = the cyclic shear stress required to cause 10% double-amplitude strain in five uniform stress cycles.

$\tau_d$  = the equivalent average uniform shear stress induced by the design earthquake.

Five uniform cycles are recommended by Seed *et al.*<sup>(11)</sup> as an adequately conservative representation of earthquakes, such as the design basis earthquake (DBE), with magnitudes ranging from 5 to 6.3. The equivalent average uniform shear stress,  $\tau_d$ , is taken as:

$$\tau_d = 0.65 r_d \tau_{max}$$

in which  $\tau_{max}$  is the peak seismically induced shear stress.  $\tau_{max}$  can be determined by conservatively assuming that the soil column responds to the earthquake as a rigid beam. For the HNP DBE with a maximum acceleration of 0.15g, the peak shear stress at any point in the profile is:

$$\tau_{max} = 0.15 \times (\text{total weight of soil above the point being considered}).$$

This approach is conservative because soil is flexible. The maximum shear stress is therefore somewhat less than the rigid beam value. The factor  $r_d$  is a stress-reduction coefficient with a value  $< 1$  ( $r_d = 1$  for a rigid shear beam). Seed and Idriss<sup>(10)</sup> have developed and published a range of  $r_d$  values for soils for depths up to 100 ft. The complete range of these values, as well as the rigid-beam assumption, has been used in the liquefaction evaluation presented herein.

The cyclic shear stress required to cause 10% double-amplitude strain in five cycles is defined as:

$$\tau_f = C_r (\text{SR}) \bar{\sigma}_v$$

$C_r$  is a correction factor to relate laboratory to insitu conditions.

The value  $C_r$  ranges from 0.57 to 0.9, De Alba *et al.*<sup>(12)</sup> A value of  $C_r = 0.57$  issued for this study. (SR) is the stress ratio for five cycles of uniform stress from figure 2A-28.  $\bar{\sigma}_v$  is the effective normal pressure on the assumed horizontal failure plane.

The results of the analysis are presented in figure 2A-31 for a column of soil corresponding to that in boring 2001. In addition to the material in the loose pocket (els 38 to 73), the top 10 ft of the silty sand below el 32 has been checked. It may be seen that the factors of safety against a shear strain of  $\pm 5\%$  and, therefore, against the development of high-pore water pressures are on the order of 2 to 3, indicating that the actual pore pressure developed by the induced stresses are very low. In fact, following the procedure described by Seed *et al.*<sup>(13)</sup> for conditions where the factor of safety against cyclic liquefaction is 2, the ratio of the number of cycles developed to the number of cycles required to cause liquefaction for the induced cyclic shear stress is on the order of  $10^{-4}$ , and the corresponding value of the

*excess pore pressure ratio developed is negligibly small. Clearly, such pore pressures would have negligible effects on the stability of the slope; furthermore, this method of estimating pore pressures is conservative since conditions underlying a sloping surface are likely to lead to even lower pore pressures than those under a level ground surface, as was assumed in the above analysis.*

#### **2A.6.2 SLOPE STABILITY ANALYSIS**

*Since the pore pressures developed in the loosest sand zone by the earthquake shaking are not likely to be significant, the possibility of sliding in the slope because of the maximum inertia forces generated by the earthquake can be computed by using a conventional slope stability analysis, including a lateral force equal to the DBE multiplied by the mass of the potential sliding mass. The results of this type of computation are shown in figure 2A-27.*

*The slope was analyzed by using the simplified Bishop method of circular arc stability analysis (McDonnell Douglas Corporation, 1974<sup>(14)</sup>) including a horizontal inertia force represented by a seismic coefficient of 0.15. The computed factor of safety for the most critical surface under these conditions was found to be 1.7. The critical circle is shown in figure 2A-27. The shear-strength parameters are based on the data obtained from the triaxial tests on samples from boring 2001A.*

*Since the cyclic strength characteristics shown in figure 2A-28 appear to be unduly high with regard to the standard penetration-resistance values of these soils, a result which may be due to some degree of sample disturbance, it was considered appropriate to check further the seismic stability of the slope by using an analysis based on the assumption that the earthquake shaking might possibly induce liquefaction of the loose zone of sand (soil 4, figure 2A-27) toward the end of the earthquake shaking and that, following the earthquake, the soil in this zone would make no contribution to the continued stability of the slope. This is believed to be a conservative approach since the liquefaction analysis shows that no such liquefaction could occur and, also, if it should occur for a magnitude 6 earthquake, it would have to be near the end of the period of strong shaking which would last only a few seconds; thereafter, the stability of the slope would be determined by the static stress conditions with no inertia forces included but with zero shear strength assigned to the loose zone of soil.*

*The results of this conservative analysis are shown in figure 2A-32. It may be seen that, even assuming zero strength for soil 4, the computed minimum factor of safety is 1.6.*

*Accordingly, it is concluded that in spite of the presence of a loose zone of soil in parts of the riverbank profile, the section nevertheless provides an ample margin of safety against sliding during or following the DBE event.*

*In addition the following analysis, observations, and conclusions regarding the stability of the river bank slope were made. An analysis of the river bank slope was made with the loose zone extending to the outer river bank. The simplified Bishop method of circular arc stability analysis (McDonnell Douglas Corporation, 1974<sup>(14)</sup>) including a horizontal inertia force represented by a seismic coefficient of 0.15, was used. The computed factor of safety for the most critical surface under this condition was 1.6. The original and extended zones of soil 4, along with the critical circle, are shown in figure 2A-33. The shear-strength parameters are based on the data obtained from the triaxial tests on samples from boring 2001A.*



## HNP-2-FSAR-2

*Although the slope is safe for the assumed condition of an extended loose zone, such an assumption is unreasonable when the descriptions of the low-blow-count zones in borings 459 and 2002 are considered. The material in boring 459 is brown and gray slightly clayey fine sand. It is an alluvial deposit. The material in boring 2002 is a light gray green clayey silty fine sand. The loose zones in borings 459 and 2002 are 2 different soil deposits.*

*The landward extension of the loose zone postulated from borings 485, 486, 487, 488, 494, 511, 516, 521, and 522 does not have any impact on the service water piping and safety-related structures. Borings 413, 423, 435, 456, 495, 512, 519, and 522 have  $N$  values greater than or equal to 10. The existence of these  $N$  values precludes the possibility of such an extension. The subsurface profiles, figure 2A-3, sheets 1 through 7, also demonstrate this. The granular soils underlying the service water piping (figure 2A-3, sheet 7) are similar in character and consistency to the materials in the power block area and have factors of safety against liquefaction comparable to the values given for the yard area shown in figure 2A-24.*

*No uncemented layers were encountered in the cemented clayey silty sand zone during the river bank test borings. The shear strength of this zone (soil 2), represented by sampled UD-3 and UD-4 from boring 2001A (figure 2A-11, sheet 5), has been reevaluated, using triaxial test results from samples taken from the same soil layer elsewhere on the site (B-446, UD at 53 to 56 ft and B-456, UD at 23 to 25 ft, figure 2A-11, sheets 2 and 3). The shear strength from these tests was evaluated at a strain level of 2%.*

*A pseudostatic analysis of the slope was then made for a seismic coefficient of 0.15, assuming this reduced strength for the cemented zone (soil 2) and the extension of the loose zone (soil 4) to the outer bank. The computed factor of safety for the most critical surface under this condition was 1.4. The critical circle is shown in figure 2A-34.*

*Consolidated drained triaxial strength tests have not been performed on site soil specimens. The specimens in the completed consolidated undrained triaxial tests performed on samples from boring B-2001A were not saturated by the back-pressure method before shearing.*

*The unconfined water surface in the upper stratum of the Hawthorn formation has very little effect on the stability of the river bank slope. The water is confined to the upper layer by the clayey silty coarse-to-fine cemented sand zone (soil 2) and is not connected to the lower strata. The presence of the unconfined water surface will slightly reduce the resistance to sliding contributed by the friction angle of the upper soil zone (soil 1), but this is insignificant because the soil has a relatively high value of cohesion, 1000 lb/ft<sup>2</sup>.*

*A pseudostatic analysis of the slope was then made for a seismic coefficient of 0.15 and a water surface at el 122 in the slope; this assumes that the water is not confined to the upper layer by the cemented sand zone, (soil 2). The computed factor of safety for the most critical surface under this condition was 1.2. The original and higher water levels, and the critical circle are shown in figure 2A-35.*

### **2A.7 LATERAL EARTH PRESSURES**

*The earth pressure developed as a result of backfilling. The structural excavations depend on the type of material utilized and the elevation of groundwater. Normally, the at-rest condition is developed when relatively unyielding walls are backfilled after construction. However, the operation of heavy compaction*

## HNP-2-FSAR-2

equipment adjacent to the walls may result in the development of lateral earth pressures in excess of those calculated on the basis of the at-rest condition. Therefore, temporary bracing of the walls was provided in order to prevent excessive deflection of the walls during backfilling operations. The at-rest earth pressures were calculated using a coefficient ( $K_0$ ) of 0.5. The onsite low plasticity sandy clays or clayey sands and silty fine sands were utilized as backfill.

Exterior walls for the turbine building are designed about 3-ft thick at el 130 ft, increasing uniformly with depth to 6-ft thick at el 100 ft. Reactor building walls are 3 1/2-ft thick. These walls thicknesses, together with stiffness afforded by the internal floor wall and wall system are considered to present essentially a rigid, nonyielding wall. Therefore, lateral pressures were based on the at-rest earth pressure condition.

Figure 2A-36 is an earth pressure diagram for a wall height of 54 ft between el 129 and 75 ft for the reactor building. Pressure diagrams for any shorter wall were obtained by using that portion of the diagram between the appropriate elevations. This pressure diagram is based on backfill comprised of the aforementioned sands and clayey sands available onsite. Maximum ground water was assumed at el 122 ft based on the surficial water level perched above the lower impervious layer.

For design purposes, the earth pressures developed during an earthquake were assumed to be equivalent to 1.3 times the static earth pressure.

### **2A.8 EXCAVATION AND BACKFILL**

The plant area excavation plan and sections are shown on figure 2A-37. The firm to dense clayey sands extending from the surface to between el 120 to 110 ft, were excavated no steeper than 1 (H): 1 (V) slopes.

The very dense sands or cemented sands underlying the firm to dense clayey sands to ~ el 70 to 80 ft were excavated no steeper than 1/2 (H): 1 (V). The safety of the slope geometry was verified by stability analysis (section 2A.6).

A concrete working mat was employed to prevent disturbance to the exposed soils. The working mat thickness was dependent of the presence of sand seams within the cemented zone, the firm clayey sands and plastic clays between el 50 and 60 ft, and the thickness of the cemented zone remaining in place below the foundation level.

The purpose of the working mat was to prevent damage to the foundation soils from heavy equipment moving over the surface and to prevent moisture changes of underlying plastic clay seams. The working mat thickness was 6 in. for the turbine and radwaste buildings and 12 in. for the reactor structure.

Proper and efficient dewatering was used to maintain a dry excavation and prevent damage to foundation soils from hydrostatic uplift. The contractor was required to maintain the water table at least 5 ft below the excavation level and provide a dry excavation.

Dewatering was accomplished within the reactor building excavation by a deep ejector well-point system. The ejector header lines were installed on a narrow berm at el 87 ft on the east, south, and west sides of the reactor building excavation. On the north side of the HNP-2 reactor excavation, the ejector header lines were supported at el 87 ft by brackets tied to the existing HNP-1 reactor building wall. The well

## HNP-2-FSAR-2

points on the east, south, and west sides of the excavation were operational starting September 13, 1971. Installation of the northern line of well points was delayed until completion of a retaining wall at the southeast corner of the existing HNP-1 reactor building. Pumping from the northern well-point line was started on October 20, 1971.

Groundwater levels were monitored by ten piezometers located within the HNP-2 excavation and by observations of several of the drill holes. Piezometers within the HNP-2 excavation were sealed and had tip elevations varying from el 45 to 62 ft. Water levels surrounding the powerhouse area were also measured by the system of permanent piezometers which was installed to monitor ground water between el 50 and 60 ft.

The data from the piezometers and measurements of water levels within open holes indicated that two water levels exist. A perched water table exists above the clay and sand with clay seams stratum immediately below the foundation level. Dewatering lowered the general water table within the sandy portions of the foundation material to levels much below foundation elevation. Water levels in the permanent piezometers surrounding the HNP-2 excavation indicated that the well-point system lowered the ground water table within the deeper sand zone to below el 65 ft over a broad area surrounding HNP-2. Within the excavation, piezometers installed within the deeper sand strata indicated water levels as deep as el 45 to 50 ft. Piezometers installed above ~ el 60 ft and water levels in shallow drill holes indicated that ground water occurred as high as ~ el 71 ft. This water formed in sand zones above the strata of clays and sands, with thin clay layers located at, and immediately below, the foundation level.

The foundation subgrade was carefully inspected and found to be firm, dry, undisturbed soils typical of those encountered in the preconstruction investigation. At no time was any upward flow of water noted. The relatively high perched water table in some portions of the excavation in no way adversely affected the foundation soil. The exposed foundation surface was methodically probed and all loose or disturbed areas were undercut.

Hydraulic communication between the minor confined aquifer and the unconfined groundwater did not occur. The excavations at the site did not expose this lower aquifer. As shown on figure 2A-3, sections A-A through F-F, and figure 2A-37, HNP-2 excavation plan, the deepest excavations were for the HNP-1 and HNP-2 reactor buildings. Material in these areas was excavated to el 73.2 ft msl. In addition, two small sumps were excavated to el 66.6 ft for the HNP-2 reactor building. The subsurface profiles (figure 2A-3) also show materials comprising the base of the confining layer. The basal portion of the confining layer in the plant area consists of sandy plastic clay with fine sand layers (stratum G) and clayey fine and very fine sand with plastic clay layers (stratum H). In some areas stratum G is not present but is replaced by a thick layer of stratum H. The irregular base of the confining layer is generally below el 65 ft msl, and in many areas, below el 60 ft msl. The highest occurrence of the base of the confining layer below the HNP-2 reactor building was in B-592 (section E-E, figure 2A-3), where the base was encountered at el 67.5 ft msl. At this location, a 5.7-ft section of the basal portion of the confining layer separates the excavation from the lower aquifer.

Further assurance that the HNP-2 reactor building excavation had not exposed the lower aquifer was provided by the ten inspection borings (RFI-1 through RFI-10). The RFI-series borings were drilled as part of a comprehensive foundation inspection program. The logs of these borings are shown in supplement 2B figures 2B-113 through 2B-122, and their locations are shown on figure 2A-2. These borings encountered 2.5 to 10 ft of stratum G material and 5 to 11.5 ft of stratum H material. The minimum thickness of the basal portion of the confining layer encountered in these borings was 11.8 ft in

## HNP-2-FSAR-2

*RFI-1. A similar inspection program was conducted for HNP-1 structures. Borings B-562 through B-575, shown on figures 2B-89 through 2B-91, encountered 0 to 5.5 ft of stratum G material, and 6 to 20 ft of stratum H material. The minimum thickness of the basal portion of the confining layer encountered in these borings was 8 ft in B-571.*

*Two borings near the sumps for the HNP-2 reactor building encountered a minimum of 12.6 ft of the confining layer below the excavation for the reactor building. Boring RFI-2 was located 10 ft south of the south sump (figure 2A-37). Stratum G was encountered between el 68.7 ft and 65.7 ft msl. Stratum H was encountered between el 72.1 and 68.7 ft msl, and again between el 65.7 and 59.5 ft msl. Since the base of the south sump was at el 66.6 ft msl, ~ 7.1 ft of the basal portion of the confining layer exists below the base of the sump. Boring B-455 was drilled prior to excavation ~ 24 ft north of the north sump. Stratum G was not encountered. Stratum H was penetrated between el 73.4 and 60.4 ft msl. Since the base of the north sump was at el 66.6 ft msl, ~ 5.2 ft of the basal portion of the confining layer exists below the base of the sump. The presence of at least 5 ft of intact material comprising the confining layer below the deepest plant excavations precludes hydraulic communication between the upper and lower aquifer.*

*Onsite and locally available offsite sandy clays, clayey sands, and silty fine sands were used as backfill around Seismic Category I structures and in conduit trenches. The offsite soils were brought to the site from a borrow pit in Toombs County, 5 miles north of the plant site on U.S. Highway 1. Backfill was placed on inspected subgrade in thin layers and compacted to an average of 95% of the maximum dry density as determined by ASTM D 1557 (Modified Proctor). Representative moisture-density relationships for the backfill materials are shown in figure 2A-38.*

### **2A.9 EXCAVATION AND REPLACEMENT OF BACKFILL FOR THE INTAKE STRUCTURE BURIED PIPING AND CONCRETE DUCTS**

#### **2A.9.1 INTRODUCTION**

*During routine maintenance operations at the intake structure in the summer of 1979, a localized failure of the asphalt pavement occurred. The 20-in.<sup>2</sup> outrigger pad of a 90-ton truck crane rested on the asphalt pavement with a heavy load being lifted by the crane. The location of the failure is shown on figure 2A-39.*

*As a result of the incident, a preliminary investigation (phase I investigation) was undertaken by Georgia Power Company. The investigation consisted of the following:*

- *A visual inspection of the area surrounding the intake structure.*
- *A test pit with density tests.*
- *Soil test borings.*
- *Installation of piezometers.*

## **2A.9.2 ASSESSMENT OF IN SITU BACKFILL**

### **2A.9.2.1 Phase I Findings**

*The results of the initial investigation around the south side of the intake structure indicated the following:*

- *Medium dense soil near the surface and loose soil around the service water pipes immediately adjacent to the intake structure.*
- *A void beneath and around the western-most 30-in.-diameter service water pipe.*
- *Relatively weak soil backfill just south of the intake structure and around the pipe for a distance of ~ 50 ft.*
- *A 6-in.-diameter pipe column used for temporary support of the pipes during construction at the south end of the test pit, ~ 20-ft south of the intake.*

*The temporary support was cut and removed. Dial gauges were used to determine deflections of the pipe after removing the support. Measured deflections were ~ 0.09 in.*

### **2A.9.2.2 Phase II Findings**

*In order to supplement the phase I investigation program and to better define the nature and extent of the loose soils, a phase II investigation was performed by Law Engineering Testing Company (LETCO). All field and laboratory testing was made in accordance with the appropriate ASTM specifications. The investigation consisted of the following:*

- *15 SPT soil borings, including 35 thin-walled tube samples for density and strength tests.*
- *10 Dutch Cone Penetrometer soundings.*
- *Four ground water observation wells.*
- *Four test pits, including five horizontal plate load tests, sand cone in-place density tests, moisture-density relationship tests, and drive tube samples for in-place soil densities.*

*Existing conditions determined as a result of the phase I and II field investigations are summarized on figure 2A-40. Detailed subsurface profiles are given in figure 2A-41.*

### **2A.9.2.3 Chronology of Intake Structure Construction**

*Preconstruction subsurface conditions are shown on figure 2A-42. The original construction sequence of the intake structure backfill and adjacent pipelines is shown on figure 2A-43.*

## HNP-2-FSAR-2

Difficulty may have been experienced in placing the backfill soils on the south side of the intake structure due to:

- Overhanging portion of intake.
- Pipelines installed prior to backfilling.

This construction sequence may have resulted in inadequate backfill compaction in this area.

### **2A.9.2.4 Evaluations**

The results of the phase II soil borings, Dutch Core Penetrometer tests, and various field tests were evaluated to provide a detailed assessment of subsurface conditions.

The SPT results for the backfill on the east and west sides of the intake structure are summarized on figures 2A-44 and 2A-45, respectively. The south side results are summarized on figure 2A-46. It should be noted that the SPT results (figure 2A-46) indicate a distinct change in the density of the backfill at ~ el 80 ft. Figures 2A-45 and 2A-46 also indicate a loose layer at ~ el 65 ft, which is near the existing ground water level.

The ground water table in the backfill adjacent to the intake structure corresponds closely to the river water level. At the time of the field investigations, the river water level ranged between el 65 ft and el 68 ft.

Undisturbed thin-walled tube samples obtained from borings were measured for density in the field. Table 2A-22 summarizes dry density and water content of these samples.

Visual inspections of the test pits were documented by LETCO using field mapping techniques and photographs.<sup>(15)</sup> Test pits excavated near the intake structure (T-1 and TP-2 on figure 2A-41) revealed voids under the exposed pipes ranging from ~ 1/2 in. seen in TP-2 to ~ 3 in. seen in T-1. The results of the density tests made as the test trench (T-1) was excavated indicated an upper layer of strong, well-compacted fill material. The fill material became weaker with depth. These results are summarized in table 2A-23.

The results of the horizontal plate load tests performed on the pipe backfill sand to determine modules of subgrade reaction (K) are summarized on figures 2A-47 through 2A-51. For plate sizes ranging from 12.0-in. square to 30-in. round, K ranges from 300 to 800 lb/in<sup>3</sup>.

### **2A.9.2.5 Conclusions**

Based on the evaluation of conditions, the following conclusions were reached:

- A. The existing soil backfill around the service water pipes and other utilities located immediately south, east, and west of the intake structure was loose and needed to be removed to natural soil levels.

## HNP-2-FSAR-2

- B. *The soil backfill in the original pipe trench excavation was loose and needed to be removed to natural soil levels for a distance of ~ 120-ft south of the intake structure. Test pits, borings, and Dutch Cones substantiated this lateral extent.*
- C. *It was possible that other pipe supports existed under the service water pipes and they needed to be removed. The same procedure used for removal of the first support, including measurements of deflections, was recommended.*
- D. *Replacement of the loose backfill soil with well compacted structural backfill in the congested south side of the intake structure would be difficult and time consuming.*

### **2A.9.2.6 Structural Properties of K-Krete**

*It was recommended that, after securing the existing pipes and ducts, the soil backfill within the affected area should be removed down to natural soils and replaced with a controlled-density fill that did not require compaction. It was further recommended that the controlled-density fill be K-Krete.*

*A testing program for K-Krete was conducted by LETCO.<sup>(15)</sup> Laboratory tests on K-Krete indicated the following:*

- *Unit weight of ~ 128 lb/ft<sup>3</sup>.*
- *7-day unconfined compressive strength of about 3-4 kip/ft<sup>2</sup>.*
- *7-day triaxial shear strength parameters of  $\phi = 34$  degrees,  $C=1$  kip/ft<sup>2</sup>. The results of the unconfined compression and triaxial shear tests are shown in tables 2A-24 and 2A-25.*

*Field tests on K-Krete indicated:*

- *Unit weight of ~ 132 lb/ft<sup>3</sup>.*
- *7-day modules of subgrade reaction of about 1800 lb/in.<sup>3</sup> for both 18-in. and 30-in.-diameter plates, as summarized on figures 2A-52 and 2A-53, respectively.*
- *A coated and wrapped 10-in.-diameter pipe as having 30 lb/in.<sup>2</sup> of adhesion with K-Krete.*
- *Negligible shrinkage movements.*

### **2A.9.3 DESIGN, CONSTRUCTION, AND BACKFILLING**

#### **2A.9.3.1 Excavation and Backfilling Construction**

*The buried utilities in the shallow excavation portion south of coordinate N63 + 10 were first uncovered, and temporary structural supports were provided at intervals of design spans specified on the construction drawings. Prior to backfilling with K-Krete, all pipes were coated and wrapped with*

## HNP-2-FSAR-2

*Tapacoat TC Cold Prime and Tapacoat CT Tape Coat, respectively. Backfilling was performed at all times in such a manner as to avoid abrasion or other damage to tape protection on pipes.*

*The support system for the deep excavation portion at the east, west, and south ends of the intake structure consisted of soldier piles and timber lagging secured in place by means of bracing members. The bracing members, consisting of wales and struts, were preloaded to minimize ground displacements. The construction methods followed for erecting the excavation support system ensured speed and safety of erection and provided the required horizontal and vertical stability of the ground behind the wall and in front of the wall at the bottom of the excavation. The component members of the support system were designed to safely support the foundation loads, earth pressures, surcharge loads, utility loads, and dead loads of the structural systems. The surcharge loading for the vertical excavation support system was based on a maximum construction loading of 600 lb/ft<sup>2</sup>. Dead weight, internal pressure, and seismic computer piping stress analyses performed for the piping systems, spans, and existing conditions at various stages of the construction showed that the uncovered Seismic Class 1 piping satisfied the operability criteria (i.e., pressure + weight + DBE seismic stresses were less than the pipe yield stress) as well as equations 8 and 9 of NC 3600 of the American Society of Mechanical Engineers (ASME) Code. The results of the analyses were submitted to Nuclear Regulatory Commission (NRC) Region II with the January and February 1981 progress reports.*

*Corrugated Metal Pipe (CMP) sleeves extending for distances of 6 1/2 to 24 ft and butting against the south end wall of the intake structure were installed around all Seismic Class 1 pipes. This was done in order to provide flexibility for 1/2 in. differential settlement between the intake structure and the adjoining K-Krete backfill.*

*The extent of the excavation down to the natural subgrades is shown in figure 2A-54. All loose soil was removed before the excavations were backfilled with K-Krete.*

### **2A.9.3.2 Dewatering System**

*A dewatering system was required for excavating around the intake structure. Dewatering was accomplished within the deep excavation portion by a deepwell system. At the time of the final excavation to subgrade el between 52.5 to 57 ft, ground water levels below the excavation were around el 50 ft according to the data obtained from four piezometers located around the intake structure. Wellpoint Dewatering Corporation drawing D-81-15 shows details of the dewatering system. Continuous operation and complete effectiveness of the dewatering system installation was maintained until sufficient K-Krete backfill was poured to offset the hydrostatic uplift pressures.*

### **2A.9.3.3 Limits of Excavation in the South End**

*An engineering inspection of the bedding condition of the service water pipes was performed to determine the southern limit of the excavation. A test pit was excavated manually at coordinates east 4980 and north 6209 downward ~ 6 to 8 in. below the invert (el 102.54) of the 18-in.-diameter residual heat removal (RHR) line (2E-11-RHR). A second test pit was excavated immediately west of the western-most 30-in. diameter service water line (P-41) at coordinates east 4938 and north 6206. The excavation was extended manually downward ~ 6 in. below the invert (el 102.31) of the pipe. The pipes were determined to be bedded directly on the backfill sand.*



## HNP-2-FSAR-2

*Based on the design requirements for bedding and support of the service water lines at HNP and the observations made at the site, it was concluded that the bedding for the service water lines is continuous at the southern limit of the backfill modifications of the piping backfill at the HNP intake structure. The pipes are continuously supported on the bottom as well as the sides and tops by well-compacted sand or clayey sand. The conditions which were observed in the field met the intent of the design and no further K-Kreteing was necessary south of coordinate north 6200.*

### **2A.9.3.4 Final Grade Preparation**

*The excavated portions were backfilled with K-Krete up to ~ el 110. The last 2 ft to the original site grade (~ el 112) were achieved by gravel and soil backfill and then asphalt paving as shown in figure 2A-55. The site grounds, fencing, and security systems were restored to their original configurations.*

## HNP-2-FSAR-2

### REFERENCES

1. *American Society for Testing and Materials (ASTM), 1966 Annual Book Of ASTM Standards, Philadelphia, Pa., 1966.*
2. *Department of the Navy, Bureau of Yards and Docks Design Manual, Navdocks DM-7, Washington, D.C., 1971.*
3. *Bureau of Reclamation, Earth Manual, First Edition, Denver, Colorado, 1963.*
4. *Seed, H. B., and Lee, Kenneth L., "Liquefaction of Saturated Sands During Cyclic Loading," Journal of the Soil Mechanics and Foundations Division, ASCE, Vol. 92, No. SM6, November 1966.*
5. *Westergaard, H. M., "A Problem of Elasticity Suggested by a Problem in Soil Mechanics: Soft Material Reinforced by Numerous Strong Horizontal Sheets," Contributions to the Mechanics of Solids, Stephen Timoshenko, 60th Anniversary Volume, Macmillan Company, New York, 1938.*
6. *Seed, H. B., and Idriss, I. M., "Analysis of Soil Liquefaction: Niigata Earthquake," Journal of the Soil Mechanics and Founda Division, ASCE, Vol. 93, No. SM3, May 1967.*
7. *Seed, H. B., Personal Communication, January 1969.*
8. *Ohsaki, Y., "Niigata Earthquakes - 1964 - Building Damage and Soil Conditions," Soil and Foundation, Vol. VI, No. 2, Tokyo, 1966.*
9. *Whitman, R. V., "Foundation Dynamics for the Proposed Nuclear Power Plant at Surry, Va.," MIT, 1967.*
10. *H. B. Seed and I. M. Idriss, "Simplified Procedure for Evaluating Soil Liquefaction Potential," Report No. FERC 70-9, Earthquake Engineering Research Center, University of California, Berkeley, November 1970.*
11. *H. B. Seed, I. M. Idriss, F. Makdisi, and N. Banerjee, "Representation of Irregular Stress Time Histories by Equivalent Uniform Stress Series in Liquefaction Analyses," Report No. FERC 75-29, Earthquake Engineering Research Center, University of California, Berkeley, October 1975.*
12. *P. DeAlba, C. K. Chan, and H. B. Seed, "Determination of Soil Liquefaction Characteristics by Large-Scale Laboratory Tests," Report No. EERC 75-14, Earthquake Engineering Research Center, University of California, Berkeley, May 1975.*
13. *H. B. Seed, P. P. Martin, and J. Lysmer, "Pore Water Pressure Changes During Soil Liquefaction," Journal of the Geotechnical Engineering Division, ASCE, Vol. 102, No. GT.4, April 1976.*
14. *McDonnell Douglas Corporation, ICES Slope User's Manual, St. Louis, 1974.*

HNP-2-FSAR-2

15. *Law Engineering Testing Company, Plant Hatch Intake Backfill Investigation Subsurface Data Submittal, Georgia Power Company, Baxley, Georgia.*
16. *Edwin I. Hatch Nuclear Plant Stack Foundation Pile Load Tests, Law Engineering Testing Company, April 7, 1971.*

HNP-2-FSAR-2

TABLE 2A-1 (SHEET 1 OF 6)

CLASSIFICATION DATA

| <u>Boring No.</u> | <u>Sample No.</u> | <u>Depth (ft)</u> | <u>Elevation</u> | <u>Liquid Limit (%)</u> | <u>Plastic Limit (%)</u> | <u>Plastic Index (%)</u> | <u>Particle Distribution (%)</u> |                                |                          |
|-------------------|-------------------|-------------------|------------------|-------------------------|--------------------------|--------------------------|----------------------------------|--------------------------------|--------------------------|
|                   |                   |                   |                  |                         |                          |                          | <u>+4.76 mm (gravel)</u>         | <u>4.76 to 0.074 mm (sand)</u> | <u>-0.074 mm (fines)</u> |
| B-401             | UD-5              | 60.25             | 75               |                         |                          |                          | 0                                | 66                             | 34                       |
| B-401             | UD-7              | 100.25            | 35               |                         |                          |                          | 0                                | 76                             | 24                       |
| B-402             | 2                 | 10                | 110              | 63                      | 18                       | 45                       |                                  |                                |                          |
| B-402             | UD                | 15.5              | 103              | 25                      | 12                       | 13                       | 0                                | 71                             | 29                       |
|                   |                   | 17.5              |                  |                         |                          |                          |                                  |                                |                          |
| B-402             | UD                | 29                | 90               | 38                      | 13                       | 25                       | 0                                | 29                             | 71                       |
|                   |                   | 31                |                  |                         |                          |                          |                                  |                                |                          |
| B-402             | UD                | 45                | 74               | 137                     | 28                       | 109                      | 0                                | 14                             | 86                       |
|                   |                   | 47                |                  |                         |                          |                          |                                  |                                |                          |
| B-402             | 13                | 47.5              | 72.5             | 123                     | 24                       | 99                       |                                  |                                |                          |
| B-402             | UD                | 54                | 65               | 188                     | 39                       | 149                      | 0                                | 20                             | 80                       |
|                   |                   | 56                |                  |                         |                          |                          |                                  |                                |                          |
| B-402             | UD                | 64-66             | 55               |                         |                          |                          | 0                                | 81                             | 19                       |
| B-402             | UD                | 74                | 45               |                         |                          |                          | 0                                | 86                             | 14                       |
|                   |                   | 76                |                  |                         |                          |                          |                                  |                                |                          |
| B-402             | S-31              | 120               | 0                | 122                     | 73                       | 49                       | 0                                | 21                             | 79                       |
| B-402             | S-33              | 130               | -10              |                         |                          |                          | 0                                | 17                             | 83                       |
| B-403             | UD-1              | 7                 | 92               |                         |                          |                          | 0                                | 57                             | 43                       |
|                   |                   | 9                 |                  |                         |                          |                          |                                  |                                |                          |
| B-403             |                   | 26                | 74               | 87                      | 21                       | 66                       |                                  |                                |                          |
| B-403             | UD                | 53                | 47               |                         |                          |                          | 0                                | 89                             | 11                       |
| B-404             |                   | 12                | 104              | 80                      | 22                       | 58                       | 0                                | 25                             | 85                       |
|                   |                   | 14                |                  |                         |                          |                          |                                  |                                |                          |
| B-404             | UD-2              | 33.2              | 84.3             | 52                      | 24                       | 28                       |                                  |                                |                          |
| B-404             | UD-3              | 44                | 73.5             | 116                     | 26                       | 90                       |                                  |                                |                          |
| B-404             | UD-4              | 82                | 34               |                         |                          |                          | 0                                | 85                             | 15                       |
|                   |                   | 84                |                  |                         |                          |                          |                                  |                                |                          |
| B-404             | UD-4              | 82                | 34               |                         |                          |                          | 0                                | 77                             | 23                       |
|                   |                   | 84                |                  |                         |                          |                          |                                  |                                |                          |
| B-404             |                   | 107               | 7                |                         |                          |                          | 0                                | 75                             | 25                       |
|                   |                   | 109               | 9                |                         |                          |                          |                                  |                                |                          |
| B-404B            |                   | 33                | 84.5             | 60                      | 31                       | 29                       |                                  |                                |                          |
| B-405             | UD                | 42                | 110              |                         |                          |                          | 0                                | 51                             | 49                       |
| B-405             |                   | 72                | 80               |                         |                          |                          | 3                                | 52                             | 45                       |
|                   |                   | 74                |                  |                         |                          |                          |                                  |                                |                          |

HNP-2-FSAR-2

TABLE 2A-1 (SHEET 2 OF 6)

| <u>Boring No.</u> | <u>Sample No.</u> | <u>Depth (ft)</u> | <u>Elevation</u> | <u>Liquid Limit (%)</u> | <u>Plastic Limit (%)</u> | <u>Plastic Index (%)</u> | <u>Particle Distribution (%)</u> |                                |                          |
|-------------------|-------------------|-------------------|------------------|-------------------------|--------------------------|--------------------------|----------------------------------|--------------------------------|--------------------------|
|                   |                   |                   |                  |                         |                          |                          | <u>+4.76 mm (gravel)</u>         | <u>4.76 to 0.074 mm (sand)</u> | <u>-0.074 mm (fines)</u> |
| B-405             |                   | 113               | 40               |                         |                          |                          | 0                                | 12                             | 88                       |
| B-406             |                   | 23                | 97               |                         |                          |                          | 0                                | 90                             | 10                       |
|                   |                   | 25                |                  |                         |                          |                          |                                  |                                |                          |
| B-406             | 11                | 45                | 78               | 146                     | 50                       | 96                       |                                  |                                |                          |
| B-406             |                   | 67                | 53               |                         |                          |                          | 0                                | 88                             | 12                       |
|                   |                   | 69                |                  |                         |                          |                          |                                  |                                |                          |
| B-406             | UD                | 77                | 42               |                         |                          |                          | 0                                | 83                             | 17                       |
|                   |                   | 78.5              |                  |                         |                          |                          |                                  |                                |                          |
| B-407             | 8                 | 40                | 70               | 110                     | 32                       | 78                       |                                  |                                |                          |
| B-407             | UD                | 64                | 45               |                         |                          |                          | 0                                | 84                             | 16                       |
|                   |                   | 66                |                  |                         |                          |                          |                                  |                                |                          |
| B-407             | UD                | 89                | 21               |                         |                          |                          | 0                                | 84                             | 16                       |
| B-408             |                   | 37                | 73               |                         |                          |                          | 0                                | 46                             | 54                       |
|                   |                   | 39                |                  |                         |                          |                          |                                  |                                |                          |
| B-408             |                   | 42                | 68               | 163                     | 62                       | 101                      | 0                                | 19                             | 81                       |
| B-408             | UD-7              | 62                | 48               |                         |                          |                          | 0                                | 80                             | 20                       |
| B-408             | UD-8              | 77                | 33               |                         |                          |                          | 0                                | 84                             | 16                       |
|                   |                   | 79                |                  |                         |                          |                          |                                  |                                |                          |
| B-409             |                   | 17                | 88               |                         |                          |                          | 0                                | 47                             | 53                       |
|                   |                   | 19                |                  |                         |                          |                          |                                  |                                |                          |
| B-409             | 3                 | 24                | 81.6             | 116                     | 28                       |                          |                                  |                                |                          |
| B-409             |                   | 28                | 77               |                         |                          |                          | 0                                | 12                             | 88                       |
| B-409             | 6                 | 41                | 64.6             | 47                      | 21                       | 26                       |                                  |                                |                          |
| B-409             | UD                | 64                | 42               |                         |                          |                          | 0                                | 88                             | 12                       |
| B-410             | -                 | 52                | 64               | 122                     | 42                       | 80                       |                                  |                                |                          |
| B-410             | -                 | 67                | 49               | 38                      | 20                       | 18                       |                                  |                                |                          |
| B-410             | -                 | 71                | 45               | 35                      | 22                       | 13                       |                                  |                                |                          |
| B-410             | -                 | 106.5             | 9.5              | 138                     | 84                       | 54                       |                                  |                                |                          |
| B-410D            | UD                | 60                | 55               |                         |                          |                          | 0                                | 57                             | 43                       |
|                   |                   | 62                |                  |                         |                          |                          |                                  |                                |                          |
| B-410D            | UD                | 69                | 47               |                         |                          |                          | 0                                | 67                             | 33                       |
| B-410D            |                   | 74.5              | 42               |                         |                          |                          | 0                                | 89                             | 11                       |
| B-410D            | 60                | 86                | 30               |                         |                          |                          | 0                                | 91                             | 9                        |
|                   |                   | 86.5              |                  |                         |                          |                          |                                  |                                |                          |
| B-410D            | UD                | 97                | 19               |                         |                          |                          | 0                                | 90                             | 10                       |
| B-410D            |                   | 110               | 6                |                         |                          |                          | 0                                | 91                             | 9                        |
| B-410D            | UD                | 115               | 1                |                         |                          |                          | 0                                | 55                             | 45                       |

HNP-2-FSAR-2

TABLE 2A-1 (SHEET 3 OF 6)

| <u>Boring No.</u> | <u>Sample No.</u> | <u>Depth (ft)</u> | <u>Elevation</u> | <u>Liquid Limit (%)</u> | <u>Plastic Limit (%)</u> | <u>Plastic Index (%)</u> | <u>Particle Distribution (%)</u> |                                |                          |
|-------------------|-------------------|-------------------|------------------|-------------------------|--------------------------|--------------------------|----------------------------------|--------------------------------|--------------------------|
|                   |                   |                   |                  |                         |                          |                          | <u>+4.76 mm (gravel)</u>         | <u>4.76 to 0.074 mm (sand)</u> | <u>-0.074 mm (fines)</u> |
| B-411             | S-1               | 4.5               | 139.5-144        |                         |                          |                          | 0                                | 63                             | 37                       |
| B-411             | S-3               | 16-21             | 123-128          |                         |                          |                          | 0                                | 69                             | 31                       |
| B-411             | S-4               | 21-30             | 144-123          |                         |                          |                          |                                  | 62                             | 38                       |
| B-411             |                   | 29-30             |                  | 39                      | 12                       | 17                       |                                  |                                |                          |
| B-411             | UD                | 72                | 72               |                         |                          |                          |                                  | 79                             | 21                       |
| B-411             | UD                | 92                | 52               |                         |                          |                          | 0                                | 85                             | 15                       |
| B-411             | UD                | 112               | 32               |                         |                          |                          | 0                                | 78                             | 22                       |
| B-412             | UD                | 52                | 70               |                         |                          |                          | 0                                | 81                             | 19                       |
| B-412             | UD                | 52                | 70               |                         |                          |                          | 0                                | 70                             | 30                       |
| B-412             |                   | 70                | 52               |                         |                          |                          | 0                                | 75                             | 25                       |
| B-412             | UD                | 77                | 45               |                         |                          |                          | 0                                | 71                             | 29                       |
| B-412             |                   | 78                | 38               | 66                      | 26                       | 40                       |                                  |                                |                          |
| B-412             |                   | 92                | 29               |                         |                          |                          | 0                                | 89                             | 11                       |
| B-413             | UD-2              | 57                | 52               |                         |                          |                          | 0                                | 84                             | 16                       |
|                   |                   | 59                |                  |                         |                          |                          |                                  |                                |                          |
| B-413             | UD-3              | 67                | 42               |                         |                          |                          | 0                                | 81                             | 19                       |
|                   |                   | 69                |                  |                         |                          |                          |                                  |                                |                          |
| B-413             | UD-4              | 88                | 22               |                         |                          |                          | 0                                | 76                             | 24                       |
| B-413             | UD                | 102               | 8                |                         |                          |                          | 0                                | 82                             | 18                       |
| B-413             | UD                | 102               | 7                |                         |                          |                          | 0                                | 88                             | 12                       |
|                   |                   | 104               |                  |                         |                          |                          |                                  |                                |                          |
| B-415A            |                   | 97                | 32               |                         |                          |                          | 0                                | 89                             | 11                       |
|                   |                   | 98                |                  |                         |                          |                          |                                  |                                |                          |
| B-416             | UD                | 82                | 32               |                         |                          |                          | 0                                | 80                             | 20                       |
| B-418             | UD-4              | 72                | 70               |                         |                          |                          | 0                                | 79                             | 21                       |
|                   |                   | 74                |                  |                         |                          |                          |                                  |                                |                          |
| B-418             | UD-5              | 102               | 40               |                         |                          |                          | 0                                | 54                             | 46                       |
|                   |                   | 104               |                  |                         |                          |                          |                                  |                                |                          |
| B-418             |                   | 112               | 30               |                         |                          |                          | 1                                | 83                             | 16                       |
|                   |                   | 114               |                  |                         |                          |                          |                                  |                                |                          |
| B-425             | UD                | 62                | 66               |                         |                          |                          | 0                                | 27                             | 73                       |
|                   |                   | 64                |                  |                         |                          |                          |                                  |                                |                          |
| B-425             | UD                | 73                | 56               |                         |                          |                          | 0                                | 90                             | 10                       |
| B-427             | UD                | 87                | 79               |                         |                          |                          | 0                                | 52                             | 48                       |
|                   |                   | 88                |                  |                         |                          |                          |                                  |                                |                          |
| B-451             |                   | 10                | 127.9            |                         |                          |                          | 0                                | 81                             | 19                       |
| B-451             |                   | 20                | 117.9            |                         |                          |                          | 1                                | 58                             | 41                       |

HNP-2-FSAR-2

TABLE 2A-1 (SHEET 4 OF 6)

| <u>Boring No.</u> | <u>Sample No.</u> | <u>Depth (ft)</u> | <u>Elevation</u> | <u>Liquid Limit (%)</u> | <u>Plastic Limit (%)</u> | <u>Plastic Index (%)</u> | <u>Particle Distribution (%)</u> |                                |                          |
|-------------------|-------------------|-------------------|------------------|-------------------------|--------------------------|--------------------------|----------------------------------|--------------------------------|--------------------------|
|                   |                   |                   |                  |                         |                          |                          | <u>+4.76 mm (gravel)</u>         | <u>4.76 to 0.074 mm (sand)</u> | <u>-0.074 mm (fines)</u> |
| B-451             |                   | 35                | 102.9            |                         |                          |                          | 0                                | 66                             | 34                       |
| B-453             | UD                | 67.33             | 70.0             |                         |                          |                          | 0                                | 68                             | 32                       |
| B-453             | UD                | 67.33             | 70.0             |                         |                          |                          | 0                                | 80                             | 20                       |
| B-453             | UD                | 67.75             | 69.6             |                         |                          |                          | 0                                | 79                             | 21                       |
| B-453             | UD                | 67.75             | 69.6             |                         |                          |                          | 0                                | 77                             | 23                       |
| R-444             |                   | 10                | 135.6            |                         |                          |                          | 0                                | 66                             | 34                       |
| R-444             |                   | 25                | 120.6            |                         |                          |                          | 0                                | 29                             | 71                       |
| R-444             |                   | 25                | 120.6            |                         |                          |                          | 0                                | 59                             | 41                       |
| R-444             |                   | 55                | 90.6             |                         |                          |                          | 0                                | 28                             | 72                       |
| R-444             |                   | 75                | 70.6             |                         |                          |                          | 0                                | 77                             | 23                       |
| R-444             |                   | 85                | 60.6             |                         |                          |                          | 0                                | 78                             | 22                       |
| R-449             |                   | 65                | 75.4             |                         |                          |                          | 0                                | 62                             | 38                       |
| R-449             |                   | 76.5              | 93.9             |                         |                          |                          | 0                                | 80                             | 20                       |
| R-449             |                   | 95                | 45.4             |                         |                          |                          | 0                                | 78                             | 22                       |
| R-449-B           | UD                | 81.75             | 58.75            |                         |                          |                          | 0                                | 80                             | 20                       |
| R-449-B           | UD-2              | 82.25             | 58.25            |                         |                          |                          | 0                                | 85                             | 15                       |
| R-452             |                   | 10                | 127.2            |                         |                          |                          | 0                                | 57                             | 43                       |
| R-452             |                   | 20                | 117.2            |                         |                          |                          | 0                                | 77                             | 23                       |
| R-452             |                   | 25                | 112.2            |                         |                          |                          | 0                                | 76                             | 24                       |
| R-452             |                   | 30                | 107.2            |                         |                          |                          | 3                                | 70                             | 27                       |
| R-452             |                   | 65                | 72.2             |                         |                          |                          | 0                                | 63                             | 37                       |
| R-452             |                   | 77                | 60.2             |                         |                          |                          | 7                                | 62                             | 31                       |
| R-452             |                   | 95                | 42.2             |                         |                          |                          | 0                                | 73                             | 27                       |
| R-452             |                   | 115               | 22.2             |                         |                          |                          | 0                                | 87                             | 13                       |
| R-455             |                   | 60                | 73.0             |                         |                          |                          | 0                                | 78                             | 22                       |
| R-455             |                   | 70                | 63.0             |                         |                          |                          | 0                                | 85                             | 15                       |
| R-455             |                   | 80                | 53.0             |                         |                          |                          | 0                                | 76                             | 24                       |
| R-455             |                   | 95                | 38.0             |                         |                          |                          | 0                                | 81                             | 19                       |
| R-465             |                   | 8.5               | 130.2            |                         |                          |                          | 0                                | 73                             | 27                       |
| R-465             |                   | 16                | 122.7            |                         |                          |                          | 0                                | 41                             | 59                       |
| R-465             |                   | 35                | 103.7            |                         |                          |                          | 0                                | 79                             | 21                       |
| R-465             |                   | 55                | 83.7             |                         |                          |                          | 0                                | 80                             | 20                       |
| R-465             |                   | 70                | 68.7             |                         |                          |                          | 0                                | 47                             | 53                       |
| R-465             |                   | 80                | 58.7             |                         |                          |                          | 0                                | 84                             | 16                       |
| R-465             |                   | 95                | 43.7             |                         |                          |                          | 0                                | 75                             | 25                       |
| R-588             | 1                 | 4.5-6.0           | 123.0            |                         |                          |                          | 0                                | 72                             | 28                       |
| R-588             | 4                 | 19.0-20.5         | 108.5            |                         |                          |                          | 0                                | 60                             | 40                       |

HNP-2-FSAR-2

TABLE 2A-1 (SHEET 5 OF 6)

| <u>Boring No.</u> | <u>Sample No.</u> | <u>Depth (ft)</u> | <u>Elevation</u> | <u>Liquid Limit (%)</u> | <u>Plastic Limit (%)</u> | <u>Plastic Index (%)</u> | <u>Particle Distribution (%)</u> |                                |                          |
|-------------------|-------------------|-------------------|------------------|-------------------------|--------------------------|--------------------------|----------------------------------|--------------------------------|--------------------------|
|                   |                   |                   |                  |                         |                          |                          | <u>+4.76 mm (gravel)</u>         | <u>4.76 to 0.074 mm (sand)</u> | <u>-0.074 mm (fines)</u> |
| R-588             | 11                | 54.0-55.5         | 73.5             |                         |                          |                          | 0                                | 54                             | 46                       |
| R-588             | 13                | 64.0-65.0         | 63.5             |                         |                          |                          | 0                                | 83                             | 17                       |
| R-588             | 15                | 74.0-75.5         | 53.5             |                         |                          |                          | 0                                | 84                             | 16                       |
| R-588             | 16                | 79.0-80.5         | 48.5             |                         |                          |                          | 0                                | 79                             | 21                       |
| R-588             | 23                | 114.0-115.5       | 13.5             |                         |                          |                          | 0                                | 84                             | 16                       |
| R-593             | 1                 | 4.0-5.5           | 124.1            |                         |                          |                          | 0                                | 31                             | 69                       |
| R-593             | 3                 | 19.0-20.5         | 109.1            |                         |                          |                          | 0                                | 48                             | 52                       |
| R-593             | 5                 | 29.0-30.5         | 99.1             |                         |                          |                          | 0                                | 69                             | 31                       |
| R-593             | 13                | 79.0-80.5         | 49.1             |                         |                          |                          | 0                                | 74                             | 26                       |
| R-593             | 19                | 94.0-95.5         | 34.1             |                         |                          |                          | 0                                | 86                             | 14                       |
| R-593             | 19                | 109.0-110.5       | 19.1             |                         |                          |                          | 0                                | 86                             | 14                       |
| R-593             | 21                | 119.0-120.5       | 9.1              |                         |                          |                          | 0                                | 78                             | 22                       |
| T-460             |                   | 8.5               | 134.0            |                         |                          |                          | 0                                | 66                             | 34                       |
| T-460             |                   | 11                | 131.5            |                         |                          |                          | 0                                | 68                             | 32                       |
| T-460             |                   | 15                | 127.5            |                         |                          |                          | 1                                | 57                             | 42                       |
| T-460             |                   | 20                | 122.5            |                         |                          |                          | 0                                | 24                             | 76                       |
| T-460             |                   | 70                | 72.5             |                         |                          |                          | 0                                | 77                             | 23                       |
| T-460             |                   | 80                | 62.5             |                         |                          |                          | 0                                | 41                             | 59                       |
| T-460             |                   | 90                | 52.5             |                         |                          |                          | 0                                | 68                             | 32                       |
| T-460             | UD                | 72.5              | 70.0             |                         |                          |                          | 0                                | 83                             | 17                       |
| T-460             | UD                | 73.75             | 68.75            |                         |                          |                          | 0                                | 80                             | 20                       |
| T-464             |                   | 6                 | 135.7            |                         |                          |                          | 0                                | 42                             | 58                       |
| T-464             |                   | 15                | 126.7            |                         |                          |                          | 0                                | 32                             | 68                       |
| T-464             |                   | 50                | 91.7             |                         |                          |                          | 0                                | 40                             | 60                       |
| T-464             |                   | 80                | 61.7             |                         |                          |                          | 0                                | 79                             | 21                       |
| T-464             |                   | 90                | 51.7             |                         |                          |                          | 0                                | 77                             | 23                       |
| T-600             | 1                 | 4.5-6.0           | 122.6            |                         |                          |                          | 0                                | 33                             | 67                       |
| T-600             | 3                 | 14.0-15.5         | 113.1            |                         |                          |                          | 2                                | 76                             | 22                       |
| T-600             | 7                 | 34.0-35.5         | 93.1             |                         |                          |                          | 0                                | 81                             | 19                       |
| T-600             | 13                | 64.0-65.5         | 63.1             |                         |                          |                          | 0                                | 78                             | 22                       |
| T-600             | 16                | 79.0-80.5         | 48.1             |                         |                          |                          | 0                                | 84                             | 16                       |
| T-600             | 22                | 109.0-110.5       | 18.1             |                         |                          |                          | 0                                | 86                             | 14                       |
| T-600             | 24                | 119.0-120.5       | 8.1              |                         |                          |                          | 0                                | 81                             | 19                       |
| B-578             |                   |                   | 16.0             |                         |                          |                          | 0                                | 87                             | 13                       |
| B-578             |                   |                   | 27.0             |                         |                          |                          | 0                                | 89                             | 11                       |
| B-579             |                   |                   | 21.0             |                         |                          |                          | 0                                | 93                             | 7                        |
| B-579             |                   |                   | 46.0             |                         |                          |                          | 0                                | 88                             | 12                       |



HNP-2-FSAR-2

TABLE 2A-1 (SHEET 6 OF 6)

| <u>Boring No.</u> | <u>Sample No.</u> | <u>Depth (ft)</u> | <u>Elevation</u> | <u>Liquid Limit (%)</u> | <u>Plastic Limit (%)</u> | <u>Plastic Index (%)</u> | <u>Particle Distribution (%)</u> |                                |                          |
|-------------------|-------------------|-------------------|------------------|-------------------------|--------------------------|--------------------------|----------------------------------|--------------------------------|--------------------------|
|                   |                   |                   |                  |                         |                          |                          | <u>+4.76 mm (gravel)</u>         | <u>4.76 to 0.074 mm (sand)</u> | <u>-0.074 mm (fines)</u> |
| B-580             |                   |                   | 19.0             |                         |                          |                          | 0                                | 84                             | 16                       |
| B-580             |                   |                   | 35.0             |                         |                          |                          | 0                                | 87                             | 13                       |
| B-580             |                   |                   | 49.0             |                         |                          |                          | 0                                | 75                             | 25                       |
| B-580             |                   |                   | 78.0             | 126                     | 47                       | 79                       | 0                                | 12                             | 88                       |
| B-581             |                   |                   | 101.0            |                         |                          |                          | 0                                | 60                             | 40                       |
| B-603             |                   |                   | 43.0             |                         |                          |                          | 0                                | 85                             | 15                       |
| B-603             |                   |                   | 53.0             |                         |                          |                          | 1                                | 71                             | 28                       |
| RFI-1             | 1                 |                   | 70.2 - 68.7      |                         |                          |                          | 0                                | 75                             | 25                       |
| RFI-1             | 2                 |                   | 65.2 - 63.7      |                         |                          |                          | 0                                | 23                             | 77                       |
| RFI-1             | 3                 |                   | 60.2 - 58.7      |                         |                          |                          | 2                                | 75                             | 23                       |
| RFI-1             | 4                 |                   | 55.2 - 53.7      |                         |                          |                          | 0                                | 78                             | 22                       |
| RFI-1             | 5                 |                   | 50.2 - 48.7      |                         |                          |                          | 0                                | 79                             | 21                       |
| RFI-1             | 8                 |                   | 35.2 - 33.7      |                         |                          |                          | 3                                | 75                             | 22                       |
| RFI-4             | 1                 |                   | 71.5 - 70.0      |                         |                          |                          | 0                                | 85                             | 15                       |
| RFI-4             | 4                 |                   | 61.5 - 60.0      |                         |                          |                          | 0                                | 80                             | 20                       |
| RFI-6             | 6                 |                   | 51.5 - 50.0      |                         |                          |                          | 0                                | 7                              | 28                       |
| RFI-4             | 7                 |                   | 41.5 - 40.0      |                         |                          |                          | 0                                | 8                              | 20                       |
| 2001A             | 1                 | 10 - 12           |                  | 57                      | 14                       | 43                       | 0                                | 33                             | 67                       |
| 2001A             | 2                 | 20 - 22           |                  | 37                      | 10                       | 27                       | 0                                | 73                             | 27                       |
| 2001A             | 3                 | 30 - 32.5         |                  | 34                      | 18                       | 16                       | 0                                | 48                             | 52                       |
| 2001A             | 4                 | 40 - 42.5         |                  | 33                      | 18                       | 15                       | 0                                | 57                             | 43                       |
| 2001A             | 5                 | 50 - 52.5         |                  |                         |                          |                          | 0                                | 87                             | 13                       |
| 2001A             | 6                 | 55 - 57           |                  | 30                      | 19                       | 11                       | 0                                | 80                             | 20                       |
| 2001A             | 7                 | 60 - 62           |                  | 33                      | 21                       | 12                       | 0                                | 78                             | 22                       |
| 2001A             | 8                 | 72 - 74.5         |                  | 34                      | 19                       | 15                       | 0                                | 76                             | 24                       |
| 2001A             | 9                 | 75 - 77.5         |                  | 36                      | 16                       | 20                       | 0                                | 77                             | 23                       |
| 2001A             | 10                | 80 - 82.5         |                  |                         |                          |                          | 0                                | 82                             | 18                       |
| 2001A             | 11                | 85 - 87.5         |                  | 75                      | 21                       | 54                       | 0                                | 45                             | 55                       |
| 2001A             | 12                | 90 - 92.5         |                  | 28                      | 19                       | 9                        | 0                                | 81                             | 19                       |
| 2001A             | 13                | 100 - 102.5       |                  | 38                      | 21                       | 17                       | 0                                | 83                             | 17                       |

**TABLE 2A-2 (SHEET 1 OF 2)**  
**IN SITU MOISTURE CONTENTS**

| <u>Boring No.</u> | <u>Sample No.</u> | <u>Depth (ft)</u> | <u>Elevation</u> | <u>Moisture Content (%)</u> |
|-------------------|-------------------|-------------------|------------------|-----------------------------|
| B-402             |                   | 18                | 102              | 18.6                        |
| B-402             |                   | 30                | 90               | 19.4                        |
| B-403             | UD-1              | 8                 | 92               | 20.8                        |
| B-404             | UD-1              | 2                 | 106              | 11.9                        |
| B-404             | UD-1              | 13                | 105              | 21.8                        |
| B-404             | UD                | 33                | 85               | 51.8                        |
| B-405             |                   | 43                | 110              | 23.6                        |
| B-405             |                   | 73                | 80               | 83.1                        |
| B-406             |                   | 24                | 97               | 22.6                        |
| B-408             |                   | 26                | 85               | 22.3                        |
| B-409             | UD-2              | 17                | 89               | 23.6                        |
| B-409             | UD-2              | 18                | 88               | 31.0                        |
| B-409             | UD-3              | 23                | 83               | 90.9                        |
| B-412A            | UD-3              | 56                | 66               | 36.4                        |
| B-442             | 1                 | 6                 | 140              | 13.4                        |
| B-442             | 5                 | 20.5              | 125.5            | 20.8                        |
| B-442             | 8                 | 40                | 106              | 18.5                        |
| B-442             | 9                 | 45                | 101              | 15.0                        |
| R-444             | 1                 | 5                 | 141              | 11.9                        |
| R-444             |                   | 10                | 136              | 14.8                        |
| R-444             | 2                 | 15                | 131              | 14.0                        |
| R-444             |                   | 25                | 121              | 26.8                        |
| R-444             |                   | 25                | 121              | 15.3                        |
| R-444             | 7                 | 30                | 116              | 20.1                        |
| R-444             | 8                 | 35                | 111              | 13.1                        |
| R-444             | 10                | 45                | 101              | 22.3                        |
| R-444             |                   | 55                | 91               | 15.2                        |
| R-444             | 12                | 60                | 86               | 21.3                        |
| B-446             | 1                 | 5                 | 138              | 18.5                        |
| B-446             | 3                 | 10                | 133              | 13.5                        |
| R-448             | 1                 | 5                 | 137              | 17.6                        |
| R-448             | 3                 | 10                | 132              | 10.7                        |
| R-448             | 4                 | 15                | 127              | 18.4                        |
| R-448             | 5                 | 20                | 122              | 15.5                        |
| R-448             | 9                 | 40                | 102              | 23.9                        |
| R-448             | 11                | 50                | 92               | 17.5                        |
| B-451             |                   | 10                | 128              | 24.6                        |

HNP-2-FSAR-2

**TABLE 2A-2 (SHEET 2 OF 2)**

| <u>Boring No.</u> | <u>Sample No.</u> | <u>Depth (ft)</u> | <u>Elevation</u> | <u>Moisture Content (%)</u> |
|-------------------|-------------------|-------------------|------------------|-----------------------------|
| B-451             |                   | 20                | 118              | 19.0                        |
| B-451             |                   | 35                | 103              | 24.2                        |
| R-452             | 1                 | 5                 | 132              | 10.8                        |
| R-452             | 2                 | 7.5               | 129.5            | 13.3                        |
| R-452A            | 1                 | 8.5               | 128.5            | 14.3                        |
| R-452             |                   | 10                | 127              | 16.6                        |
| R-452B            | UD-1              | 10                | 127              | 16.6                        |
| R-452A            | 2                 | 11                | 126              | 19.0                        |
| R-452             | 4                 | 15                | 122              | 16.7                        |
| R-452             |                   | 20                | 117              | 28.4                        |
| R-452             |                   | 25                | 112              | 22.6                        |
| R-452             |                   | 30                | 107              | 20.7                        |
| R-452             | 8                 | 35                | 102              | 29.4                        |
| T-460             |                   | 8.5               | 133.5            | 12.8                        |
| T-460             |                   | 11                | 131              | 16.1                        |
| T-460             |                   | 15                | 127              | 17.3                        |
| T-460A            | 1                 | 15.5              | 126.5            | 22.9                        |
| T-460             |                   | 20                | 122              | 23.3                        |
| T-463             | 1                 | 5                 | 139              | 13.4                        |
| T-463             | 3                 | 10                | 134              | 11.8                        |
| T-463             | 4                 | 15                | 129              | 25.2                        |
| T-463             | 6                 | 30                | 114              | 15.3                        |
| T-463             | 8                 | 40                | 104              | 21.2                        |
| T-464             |                   | 6                 | 136              | 17.6                        |
| T-464             |                   | 15                | 127              | 22.4                        |
| T-464A            | 1                 | 17.5              | 124.5            | 25.4                        |
| T-464             | UD-1              | 19                | 123              | 16.4                        |
| T-464             |                   | 50                | 92               | 18.1                        |
| R-465             |                   | 8.5               | 130.5            | 12.4                        |
| R-465             |                   | 16                | 123              | 22.9                        |
| R-465             |                   | 35                | 104              | 14.5                        |
| R-465             |                   | 55                | 84               | 8.4                         |
| R-466             | 1                 | 6                 | 130              | 3.6                         |
| R-466             | 2                 | 8.5               | 127.5            | 16.9                        |

TABLE 2A-3

**X-RAY DIFFRACTION TESTS  
MINERAL COMPOSITION (%)**

| <u>Boring No.</u> | <u>Depth (ft)</u> | <u>Quartz</u>     | <u>Montmorillonite</u> | <u>Illite</u> | <u>Attapulgite-<br/>Sepiolite</u> | <u>Kaolinite</u> | <u>Phosphorite and<br/>Miscellaneous</u> |
|-------------------|-------------------|-------------------|------------------------|---------------|-----------------------------------|------------------|------------------------------------------|
| 403               | 33.5              | 10                | 60                     | 5             | 20                                | 5                |                                          |
| 404               | 60.0              | 10                | 45                     |               | 30                                |                  | 15                                       |
| 405               | 75.0              | 20                | 45                     | 5             | 20                                | 5                | 5                                        |
| 406               | 60.0              | 20                | 30                     |               | 25                                |                  | 25                                       |
| 408               | 55.0              | 20                | 35                     |               | 35                                |                  | 10                                       |
| 409               | 45.0              | 20 <sup>(a)</sup> | 20                     |               | 40                                |                  | 20                                       |
| 410               | 25.0              | 40                | 18                     | 3             |                                   | 39               |                                          |
| 412               | 30.0              | 25                | 26                     | 4             | 20                                |                  |                                          |
| 412               | 65.0              | 15 <sup>(a)</sup> | 60                     | 5             |                                   | 45               |                                          |
| 412               | 70.0              | 20                | 60                     |               | 20                                |                  |                                          |
| 420               | 20.0              | 20 <sup>(a)</sup> | 40                     |               | 35                                |                  | 5                                        |
| 422               | 20.0              | 20 <sup>(a)</sup> | 40                     | 5             | 20                                |                  | 20                                       |
| 426               | 40.0              | 40                | 45                     | 3             |                                   | 12               |                                          |
| 426               | 55.0              | 30                | 45                     | 4             |                                   | 21               |                                          |
| 426               | 90.0              | 20                | 78                     | 2             |                                   |                  |                                          |
| 427               | 125.0             | 8                 | 80                     | 2             | 10                                |                  |                                          |

a. Includes some cristobalite (opal).

HNP-2-FSAR-2

TABLE 2A-4 (SHEET 1 OF 3)

CONSOLIDATION AND SWELL TEST DATA

| <u>Boring No.</u> | <u>Sample No.</u> | <u>(ft)</u> | <u>Elevation</u> | <u>Initial<br/>Void-Ratio</u> | <u>Unit<br/>Weight<br/>(lb/ft<sup>3</sup>)</u> | <u>Moisture<br/>Content (%)</u> | <u>Overburden<br/>Stress (ksf)</u> | <u>Preconsolidation<br/>(ksf)</u> | <u>Compression<br/>Index</u> | <u>Swell<br/>(in./in.)</u> |
|-------------------|-------------------|-------------|------------------|-------------------------------|------------------------------------------------|---------------------------------|------------------------------------|-----------------------------------|------------------------------|----------------------------|
| 401               | UD-5              | 60          | 73               |                               | 117                                            | 15.2                            |                                    | 6.5                               | 0.04                         | 0                          |
| 401               | UD-7              | 100         | 35               | 0.93                          | 106                                            | 35.4                            | 4.8                                | 1.4                               | 0.23                         | 0                          |
| 401               | UD-7              | 100         | 35               | 1.07                          | 105                                            | 40.6                            | 4.5                                | 3.0                               | 0.25                         | 0                          |
| 401               | UD-9              | 140         | -5               | 0.64                          | 116                                            | 25.8                            | 7.2                                | 5.0                               |                              | 0                          |
| 402               | UD-12             | 46          | 74               | 2.39                          | 91.5                                           | 91.6                            | 1.0                                | 6.2                               | 2.16                         | 0                          |
| 402               | UD-15             | 55          | 65               | 3.99                          | 77.8                                           | 140.1                           | 1.5                                | 11.0                              | 2.67                         | 0                          |
| 402               | UD-18             | 65.5        | 54.5             | 1.005                         | 104.0                                          | 31.2                            | 3.1                                | 3.5                               | 0.14                         | 0                          |
| 402               | UD-21             | 75.0        | 45.0             | 1.195                         | 96.6                                           | 34.3                            | 3.6                                | 4.2                               | 0.25                         | 0                          |
| 403               | UD                | 26          | 74               | 1.697                         | 95.9                                           | 63.6                            | 1.6                                | 3.8                               | 0.78                         | 0.0148                     |
| 403               | UD                | 31          | 69               | 2.905                         | 85.4                                           | 110.9                           | 3.0                                | 5.9                               | 0.40                         | 0.0287                     |
| 403               | UD                | 53          | 47               | 1.114                         | 101.4                                          | 30.7                            | 3.5                                | 3.0                               | 0.09                         | 0                          |
| 404               | UD-1              | 12          | 106              | 3.85                          | 134.9                                          | 11.9                            | 0.5                                | 2.8                               | 0.07                         | 0                          |
| 404               | UD                | 33          | 85               | 1.28                          | 103.3                                          | 50.0                            | 2.6                                | 2.3                               | 0.34                         | 0.00351                    |
| 404               | UD                | 43          | 75               | 1.74                          | 94.9                                           | 76.4                            | 3.3                                | 2.1                               | 0.85                         | 0.007                      |
| 404               | UD-4              | 83          | 35               | 0.959                         | 110.0                                          | 33.3                            | 5.0                                | 1.4                               | 0.04                         | 0                          |
| 404               | UD-5              | 93          | 25               | 0.968                         | 107.0                                          | 32.4                            | 5.0                                | 3.0                               | 0.07                         | 0                          |
| 404               | UD-6              | 108         | 10               | 0.982                         | 108.3                                          | 31.4                            | 6.0                                | 3.6                               | 0.13                         | 0                          |
| 405               | UD-1              | 73          | 80               | 2.342                         | 89.4                                           | 83.1                            | 6.5                                | 2.0                               | 0.16                         | 0                          |
| 405               | UD                | 78          | 75               | 2.99                          | 82.0                                           | 110.2                           | 6.5                                | 3.4                               | 0.23                         | 0.0404                     |
| 405               | UD-5              | 87          | 66               | 1.887                         | 92.6                                           | 64.2                            | 7.1                                | 1.5                               | 0.10                         | 0                          |
| 405               | UD                | 88          | 65               | 1.024                         | 107.4                                          | 38.5                            | 7.1                                | 2.9                               | 0.12                         | 0.00074                    |
| 405               | UD                | 112         | 41               | 1.339                         | 94.8                                           | 44.1                            | 9.0                                | 2.8                               | 0.091                        | 0.00085                    |
| 406               | UD-3              | 43          | 76.5             | 2.58                          | 89.3                                           | 99.9                            | 3.3                                | 2.9                               | 1.16                         | 0.0014                     |
| 406               | UD-17             | 68          | 53               | 1.186                         | 103.8                                          | 39.0                            | 4.6                                | 5.0                               | 0.165                        | 0.00069                    |
| 407               | UD-2              | 65          | 45               | 1.145                         | 108.3                                          | 41.5                            | 4.5                                | 2.5                               | 0.087                        | 0.00092                    |
| 407               | UD                | 89          | 21               | 0.93                          | 108.0                                          | 30.8                            | 5.3                                | 2.2                               | 0.11                         | 0                          |
| 408               | UD-3              | 33          | 78               | 0.825                         | 116.1                                          | 29.2                            | 2.6                                | 5.8                               | 0.19                         | 0                          |
| 408               | UD-3              | 34          | 77               | 1.93                          | 96.7                                           | 74.3                            | 2.5                                | 5.9                               | 0.56                         | 0.017                      |
| 408               | UD-4              | 37          | 74               | 1.425                         | 99.0                                           | 63.4                            | 3.0                                | 1.0                               | 0.58                         | 0                          |
| 408               | UD-4              | 38          | 73               | 3.185                         | 83.6                                           | 123.4                           | 2.9                                | 5.5                               | 0.99                         | 0.015                      |
| 408               | UD-5              | 42          | 69               | 2.33                          | 87.0                                           | 111.3                           | 3.1                                | 1.2                               | 0.96                         | 0                          |
| 408               | UD-5              | 43          | 68               | 3.155                         | 83.4                                           | 122.0                           | 2.8                                | 6.2                               | 1.01                         | 0.0095                     |

HNP-2-FSAR-2

TABLE 2A-4 (SHEET 2 OF 3)

| <u>Boring No.</u> | <u>Sample No.</u> | <u>(ft)</u> | <u>Elevation</u> | <u>Initial<br/>Void-Ratio</u> | <u>Unit<br/>Weight<br/>(lb/ft<sup>3</sup>)</u> | <u>Moisture<br/>Content (%)</u> | <u>Overburden<br/>Stress (ksf)</u> | <u>Preconsolidation<br/>(ksf)</u> | <u>Compression<br/>Index</u> | <u>Swell<br/>(in./in.)</u> |
|-------------------|-------------------|-------------|------------------|-------------------------------|------------------------------------------------|---------------------------------|------------------------------------|-----------------------------------|------------------------------|----------------------------|
| 408               | UD                | 53          | 58               | 1.488                         | 94.9                                           | 46.1                            | 3.8                                | 4.5                               | 0.2                          | 0.0012                     |
| 408               | UD-5              | 63          | 48               | 1.015                         | 110.0                                          | 37.9                            | 4.2                                | 1.1                               | 0.09                         | 0.0034                     |
| 409               | UD-2              | 17          | 89               |                               | 125.0                                          | 23.6                            |                                    | 4.9                               | 0.16                         | 0                          |
| 409               | UD-3              | 23          | 83               | 2.51                          | 86.6                                           | 90.9                            | 2.4                                | 3.5                               | 1.20                         | 0                          |
| 409               | UD-4              | 28          | 78               | 3.16                          | 84.8                                           | 124.0                           | 2.5                                | 3.8                               | 2.09                         | 0                          |
| 409               | UD-5              | 33          | 73               | 2.90                          | 86.1                                           | 115.2                           | 2.9                                | 3.4                               | 1.83                         | 0                          |
| 409               | UD-6              | 41          | 63               | 0.853                         | 113.4                                          | 32.6                            | 3.5                                | 4.0                               | 0.127                        | 0.0008                     |
| 409               | UD-8              | 63          | 43               | 1.316                         | 102.3                                          | 46.1                            | 3.6                                | 3.3                               | 0.15                         | 0.00043                    |
| 410D              | UD                | 52          | 64               | 2.17                          | 90.9                                           | 83.4                            | 3.6                                | 3.5                               | 0.48                         | 0.00155                    |
| 410D              | UD                | 59          | 57               | 1.061                         | 106.9                                          | 35.5                            | 4.0                                | 4.9                               | 0.12                         | 0.00048                    |
| 410D              | UD                | 61          | 55               | 0.941                         | 110.4                                          | 36.8                            | 4.0                                | 2.4                               | 0.14                         | 0.00051                    |
| 410D              | UD                | 67          | 49               | 0.824                         | 114.9                                          | 32.4                            | 4.5                                | 2.4                               | 0.14                         | 0.00164                    |
| 410D              | UD                | 71          | 45               | 0.773                         | 118.4                                          | 27.8                            | 4.9                                | 3.2                               | 0.06                         | 0.00028                    |
| 410D              | UD                | 74.5        | 41.5             | 0.8575                        | 115.6                                          | 30.4                            | 5.0                                | 0.63                              | 0.03                         | 0.00027                    |
| 410D              | UD                | 79          | 37               | 1.71                          | 92.4                                           | 58.8                            | 5.3                                | 6.3                               | 0.22                         | 0                          |
| 401D              | UD                | 106.5       | 9.5              | 1.204                         | 105.7                                          | 45.4                            | 7.6                                | 0.8                               | 0.15                         | 0                          |
| 410D              | UD                | 110         | 6                | 0.812                         | 115.4                                          | 28.4                            | 7.0                                | 1.2                               | 0.07                         | 0                          |
| 410D              | UD                | 115         | 1                | 1.537                         | 99.3                                           | 57.0                            | 7.9                                | 1.2                               | 0.08                         | 0.00039                    |
| 411               | UD                | 92          | 52               | 1.076                         | 107.5                                          | 39.5                            | 5.2                                | 3.0                               | 0.19                         | 0                          |
| 411               | UD-20             | 93          | 51               | 1.036                         | 109.8                                          | 38.7                            | 5.1                                | 2.4                               | 0.16                         | 0.00048                    |
| 411               | UD                | 112         | 32               | 0.72                          | 117.6                                          | 24.8                            | 6.1                                | 1.3                               | 0.08                         | 0.00058                    |
| 412               | UD                | 78          | 44               | 1.194                         | 104.2                                          | 43.7                            | 4.5                                | 1.2                               | 0.20                         | 0.0018                     |
| 413               | UD                | 28          | 81               | 1.03                          | 104.0                                          | 30.1                            | 1.7                                | 9.0                               | 0.23                         | 0                          |
| 413               | UD-5              | 58          | 52               | 0.706                         | 118.2                                          | 25.3                            | 4.0                                | 2.6                               | 0.06                         | 0.00029                    |
| 413               | UD-3              | 68          | 42               | 1.248                         | 101.8                                          | 44.3                            | 4.6                                | 3.2                               | 0.11                         | 0.00076                    |
| 413               | UD-4              | 88          | 22               | 1.069                         | 108.0                                          | 41.0                            | 5.7                                | 4.1                               | 0.10                         | 0.0014                     |
| 413               | UD                | 102         | 8                | 0.672                         | 118.8                                          | 23.1                            | 5.8                                | 2.1                               | 0.12                         | 0                          |
| 415A              | UD-2              | 97          | 32.5             | 0.898                         | 112.8                                          | 33.0                            | 7.0                                | 4.0                               | 0.03                         | 0.00079                    |
| 416               | UD-4              | 82          | 32               | 0.891                         | 107.0                                          | 26.1                            | 4.9                                | 1.5                               | 0.07                         | 0                          |
| 417               | UD                | 97          | 30.5             | 3.96                          | 79.7                                           | 121.7                           | 8.1                                | 2.8                               | 0.28                         | 0                          |
| 418               | UD-4              | 73          | 70               | 0.827                         | 109.7                                          | 28.7                            | 6.1                                | 0.38                              | 0.088                        | 0.0011                     |
| 418               | UD-5              | 103         | 40               | 1.975                         | 93.3                                           | 72.2                            | 8.2                                | 5.8                               | 0.23                         | 0.00007                    |
| 418               | UD-6              | 112         | 31               | 0.901                         | 111.7                                          | 32.9                            | 6.0                                | 3.0                               | 0.10                         | 0                          |
| 425               | UD                | 63          | 66               | 1.446                         | 100.5                                          | 52.1                            | 6.5                                | 1.9                               | 0.12                         | 0.0092                     |
| 427               | UD                | 87          | 70.5             | 1.907                         | 92.4                                           | 67.3                            | 9.3                                | 3.0                               | 0.09                         | 0.0038                     |

HNP-2-FSAR-2

TABLE 2A-4 (SHEET 3 OF 3)

| <u>Boring No.</u> | <u>Sample No.</u> | <u>(ft)</u> | <u>Elevation</u> | <u>Initial<br/>Void-Ratio</u> | <u>Unit<br/>Weight<br/>(lb/ft<sup>3</sup>)</u> | <u>Moisture<br/>Content (%)</u> | <u>Overburden<br/>Stress (ksf)</u> | <u>Preconsolidation<br/>(ksf)</u> | <u>Compression<br/>Index</u> | <u>Swell<br/>(in./in.)</u> |
|-------------------|-------------------|-------------|------------------|-------------------------------|------------------------------------------------|---------------------------------|------------------------------------|-----------------------------------|------------------------------|----------------------------|
| R-444             | UD                | 78          | 68               | 0.974                         | 112                                            | 33.7                            | 5.2                                | 4.8                               | 0.15                         |                            |
| R-448             | UD-15             | 72          | 70               | 0.696                         | 119                                            | 21.1                            | 5.2                                | 5.0                               | 0.05                         |                            |
| R-449             | UD                | 85          | 55               | 0.902                         | 115.5                                          | 33.3                            | 5.5                                | 7.8                               | 0.39                         |                            |
| R-455             | UD                | 63          | 70               | 1.001                         | 110                                            | 35.5                            | 3.5                                | 9.0                               | 0.22                         |                            |
| T-460             | UD                | 83          | 69               | 0.991                         | 111                                            | 37.3                            | 5.7                                | 8.0                               | 0.39                         |                            |
| B-411             | Bag               | 0-4.5       | 144-139.5        | 0.414                         | 133.5                                          | 12.9                            |                                    |                                   | 0.07                         |                            |
| B-411             | Bag               | 16          | 123-128          | 0.372                         | 134.2                                          | 10.5                            |                                    |                                   | 0.09                         |                            |
| B-411             | Bag               | 21          | 123-116          | 0.495                         | 127.4                                          | 15.2                            |                                    |                                   | 0.10                         |                            |
| R-587             | UD-1              | 17.75       | 67.25            | 1.95                          | 95.5                                           | 70.5                            |                                    |                                   | 0.84                         |                            |
| R-594             | UD-1              | 61.5        | 66.7             | 0.985                         | 110.5                                          | 33.8                            |                                    |                                   | 0.23                         |                            |
| T-597             | UD-1              | 62.25       | 63.85            | 1.89                          | 95.2                                           | 67.0                            |                                    |                                   | 0.61                         |                            |
| RFI-2             | UD                | 20-22       | 53.7-51.7        | 0.90                          | 115.0                                          | 29.8                            |                                    |                                   | 0.118                        |                            |
| RFI-9             | UD                | 6-8         | 69-67            | 1.65                          | 97.4                                           | 61.2                            |                                    |                                   | 0.185                        |                            |

HNP-2-FSAR-2

**TABLE 2A-5 (SHEET 1 OF 2)**

**TRIAXIAL SHEAR DATA**

| <u>Boring No.</u> | <u>Sample No.</u> | <u>Depth (ft)</u> | <u>Elevation</u> | <u>Type Test</u>         | <u>Saturation (%)</u> | <u>Unit Weight (lb/ft<sup>3</sup>)</u> | <u>Moisture Content (%)</u> | <u>Void-Ratio</u> | <u>Cohesion (ksf)</u> | <u>Friction Angle (degrees)</u> |
|-------------------|-------------------|-------------------|------------------|--------------------------|-----------------------|----------------------------------------|-----------------------------|-------------------|-----------------------|---------------------------------|
| 402               | UD                | 17-19             | 102              | quick                    | 94.0                  | 129.0                                  | 18.6                        | 0.53              | 0.72                  | 16.5                            |
| 402               | UD                | 29-31             | 90               | quick                    | 100.0                 | 130.0                                  | 19.4                        | 0.51              | 1.18                  | 10.5                            |
| 402               | UD                | 45-47             | 74               | quick                    | 92.0                  | 93.9                                   | 69.8                        | 2.05              | 0.43                  | 11.0                            |
| 403               | UD-1              | 7-9               | 92               | quick                    | 99.0                  | 129.0                                  | 20.8                        | 0.57              | 0.67                  | 19.5                            |
| 404               | UD-1              | 13                | 105              | quick                    | 87.0                  | 122.0                                  | 21.8                        | 0.67              | 1.44                  | 8.5                             |
| 404               | UD                | 32-34             | 85               | quick                    | 100.0                 | 105.0                                  | 51.8                        | 1.35              | 0.63                  | 3.8                             |
| 404               | UD-4              | 82                | 36               | quick                    | 100.0                 | 108.0                                  | 47.8                        | 1.27              | 0.90                  | 18.5                            |
| 405               | UD-1              | 42-44             | 110              | quick                    | 100.0                 | 125.0                                  | 23.6                        | 0.60              | 1.11                  | 10.0                            |
| 405               |                   | 78                | 75               | quick                    | 100.0                 | 89.2                                   | 107.6                       | 2.74              | 1.2                   | 15.5                            |
| 406               |                   | 24                | 97               | quick                    | 99.0                  | 125.0                                  | 22.6                        | 0.60              | 1.0                   | 31.5                            |
| 406               | 19                | 78                | 43               | quick                    | 98.0                  | 108.0                                  | 44.3                        | 1.20              | 3.8                   | 19.5                            |
| 408               | UD                | 25-27             | 85               | quick                    | 100.0                 | 129.0                                  | 22.3                        | 0.59              | 2.7                   | 3.5                             |
| 408               | UD                | 34                | 75               | quick                    | 100.0                 | 112.0                                  | 41.3                        | 1.10              | 1.4                   | 0.5                             |
| 408               |                   | 37-39             | 73               | quick                    | 95.0                  | 92.1                                   | 78.8                        | 2.19              | 0.3                   | 31.5                            |
| 409               |                   | 17-19             | 88               | quick                    | 100.0                 | 122.0                                  | 31.0                        | 0.74              | 1.0                   | 2.5                             |
| 409               |                   | 27-29             | 78               | quick                    | 95.0                  | 92.0                                   | 77.8                        | 2.11              | 0.5                   | 8.5                             |
| 413               |                   | 102-104           | 6                | quick                    | 91.0                  | 118.9                                  | 24.6                        | 0.70              | 0.4                   | 39.0                            |
| 441               | UD                | 87-89             | 55               | quick                    | 96.0                  | 117.6                                  | 27.8                        | 0.70              | 1.1                   | 3.0                             |
| 444               | UD                | 77-79             | 67               | quick                    | 98.0                  | 116.2                                  | 33.8                        | 0.91              | 1.75                  | 11.0                            |
| 444               | UD                | 95-97             | 47               | quick                    | 95.0                  | 107.2                                  | 43.8                        | 1.21              | 1.6                   | 0.0                             |
| 446               |                   | 53-56             | 89               | quick                    |                       | 98.3                                   |                             |                   | 0.0                   | 20.5                            |
| 446               | UD                | 87-89             | 55               | quick                    | 90.0                  | 107.8                                  | 37.9                        | 1.10              | 1.9                   | 4.5                             |
| 448               | UD-15             | 70-74             | 70               | unconsolidated-undrained | 89.0                  | 117.6                                  | 26.2                        | 0.79              | 1.8                   | 9.5                             |
| 449               | UD                | 79-81             | 60               | unconsolidated-undrained | 97.0                  | 116.5                                  | 31.5                        | 0.86              | 0.9                   | 12.5                            |
| 449               | UD-4              | 98-100            | 41               | unconsolidated-undrained | 95.0                  | 104.4                                  | 44.8                        | 1.20              | 3.7                   | 16.5                            |
| 451               | UD                | 72-74             |                  | quick                    | 96.0                  | 116.6                                  | 32.0                        | 0.91              | 2.75                  | 11.0                            |
| 452               | UD-1              | 9-11              | 127              | unconsolidated-undrained | 87.0                  | 129.6                                  | 16.6                        | 0.52              | 1.2                   | 16.0                            |
| 452               | UD                | 85-87             | 51               | quick                    | 94.0                  | 105.8                                  | 44.7                        | 1.26              | 1.85                  | 9.5                             |



HNP-2-FSAR-2

**TABLE 2A-5 (SHEET 2 OF 2)**

| <u>Boring No.</u> | <u>Sample No.</u> | <u>Depth (ft)</u> | <u>Elevation</u> | <u>Type Test</u>       | <u>Saturation (%)</u> | <u>Unit Weight (lb/ft<sup>3</sup>)</u> | <u>Moisture Content (%)</u> | <u>Void-Ratio</u> | <u>Cohesion (ksf)</u> | <u>Friction Angle (degrees)</u> |
|-------------------|-------------------|-------------------|------------------|------------------------|-----------------------|----------------------------------------|-----------------------------|-------------------|-----------------------|---------------------------------|
| 456               |                   | 23-25             | 80               | quick                  |                       | 138.9                                  |                             |                   | 0.2                   | 59.0                            |
| 456               | UD                | 42-44             | 63               | quick                  | 100.0                 | 95.2                                   | 77.7                        | 1.44              | 3.3                   | 3.0                             |
| 456               | UD                | 44-46             | 61               | quick                  | 98.0                  | 110.2                                  | 39.4                        | 1.07              | 2.0                   | 0.0                             |
| 458               | UD-1              | 56-58             | 62               | quick                  | 96.0                  | 118.8                                  | 29.2                        | 0.81              | 1.6                   | 11.5                            |
| 458               | UD                | 77-79             | 41               | quick                  | 97.0                  | 102.0                                  | 54.4                        | 1.48              | 1.2                   | 6.0                             |
| 460               | UD                | 72-74             | 70               | quick                  | 93.0                  | 121.0                                  | 24.8                        | 0.71              | 2.8                   | 10.0                            |
| 464               | UD-1              | 18-20             | 123              | consolidated-undrained | 87.0                  | 129.3                                  | 16.4                        | 0.50              | 1.6                   | 5.5                             |
| 411               | 101% std proctor  |                   | 139.5            | quick                  | 89.0                  | 134.9                                  | 12.8                        | 0.40              | 2.4                   | 7.5                             |
| 411               | 100% std proctor  |                   | 123              | quick                  | 76.0                  | 135.0                                  | 10.0                        | 0.37              | 1.5                   | 19.0                            |
| 411               | 100% std proctor  |                   | 116              | quick                  | 81.0                  | 127.2                                  | 15.2                        | 0.50              | 1.3                   | 4.0                             |
| RFI-3             | UD                | 6.0-7.5           | 68.5-67          | consolidated-undrained | 87.0                  | 103.0                                  | 43.5                        | 1.31              | 2.0                   | 22.0                            |
| RFI-6             | UD                | 23.0-27           | 52-50            | consolidated-undrained | 80.0                  | 105.0                                  | 32.9                        | 1.08              | 1.7                   | 19.0                            |
| 2001A             | UD-1              | 10-12             |                  | consolidated-undrained |                       | 127.1                                  | 23.4                        | 0.589             | 1.0                   | 24.0                            |
| 2001A             | UD-2              | 20-22             |                  | consolidated-undrained |                       | 130.6                                  | 15.7                        | 0.488             | 1.0                   | 28.5                            |
| 2001A             | UD-3 and UD-4     | 30-42.5           |                  | consolidated-undrained |                       | 127.9                                  | 14.5                        | 0.497             | 5.0                   | 40.0                            |
| 2001A             | UD-5              | 50-52.5           |                  | consolidated-undrained |                       | 128.6                                  | 19.4                        | 0.566             | 1.5                   | 36.0                            |
| 2001A             | UD-9              | 75-77.5           |                  | consolidated-undrained |                       | 100.2                                  | 48.2                        | 1.456             | 0.3                   | 20.0                            |
| 2001A             | UD-10             | 80-82.5           |                  | consolidated-undrained |                       | 103.6                                  | 42.5                        | 1.315             | 0.9                   | 22.0                            |
| 2001A             | UD-13             | 100-102.5         |                  | consolidated-undrained |                       | 107.3                                  | 30.2                        | 1.008             | 2.5                   | 26.0                            |

**TABLE 2A-6**  
**SUMMARY OF SETTLEMENT ESTIMATE**

|               | <u>Total<br/>(in)</u> | <u>Immediate<br/>(in)</u> | <u>Total<br/>Consolidation<br/>(in)</u> | <u>Consolidation<br/>After<br/>Construction<br/>(in)</u> | <u>Percent<br/>Tilt</u> |
|---------------|-----------------------|---------------------------|-----------------------------------------|----------------------------------------------------------|-------------------------|
| <u>Unit 1</u> |                       |                           |                                         |                                                          |                         |
| Reactor       | 3.1                   | 2.2                       | 0.9                                     | 0.8                                                      | 0                       |
| Turbine       | 1.5                   | 1.0                       | 0.5                                     |                                                          | .05 <sup>(a)</sup>      |
| Radwaste      | 1.5                   | 1.0                       | 0.5                                     |                                                          | .10 <sup>(a)</sup>      |
| <u>Unit 2</u> |                       |                           |                                         |                                                          |                         |
| Reactor       | 4.5                   | 3.2                       | 1.3                                     | 0.5                                                      | 0                       |
| Turbine       | 2.0                   | 1.4                       | 0.6                                     |                                                          | .10 <sup>(a)</sup>      |
| Radwaste      | 3.5                   | 2.4                       | 1.1                                     |                                                          | .10 <sup>(a)</sup>      |
| Control       | 2.0                   | 1.4                       | 0.6                                     |                                                          | .10 <sup>(a)</sup>      |

NOTES:

1. Total settlement - Settlement resulting from structural loads of building and influence of adjacent structural loads.
2. Immediate settlement - Part of the total settlement which occurs immediately upon loading.
3. Total consolidation - Part of the total settlement which occurs after the load is applied and immediate settlement has occurred.
4. Consolidation after construction - Part of consolidation settlement which occurs after completion of construction.
5. Tilt - Tilt obtained by dividing estimated maximum edge-to-edge differential settlement by distance between edges and multiplied by 100.

a. Toward reactor.

TABLE 2A-7 (SHEET 1 OF 2)

## HNP-2 INSPECTION AUGER BORINGS

| <u>Boring No.</u> | <u>Depth (ft)<br/>From - To</u>                | <u>Soil Description</u>                                                                              | <u>Penetration<br/>Resistance (ft)</u> |
|-------------------|------------------------------------------------|------------------------------------------------------------------------------------------------------|----------------------------------------|
| C-1               | N 51 + 12, E 49 + 67<br>el 73 ft<br>0 - 1.0    | Loose-to-firm, green-gray fine sand and clayey fine sand with thin green clay layers.                | 0.2 - 9<br>1.0 - 12                    |
| C-2               | N 50 + 81, E 49 + 67<br>el 72.5 ft<br>0 - 1.0  | Loose-to-firm, light-gray and green-gray fine sand and clayey fine sand with thin green clay layers. | 0.2 - 9<br>1.0 - 12                    |
| C-3               | N 50 + 55, E 49 + 67<br>el 72.7 ft<br>0 - 1.0  | Loose-to-firm, light-gray and green-gray fine sand and clayey fine sand.                             | 0.3 - 8<br>1.0 - 11                    |
| C-4               | N 51 + 12, E 50 + 28<br>el 73.17 ft<br>0 - 1.0 | Loose, light-gray and green-gray fine sand and clayey fine sand.                                     | 0.2 - 7<br>1.0 - 9                     |
| C-5               | N 50 + 87, E 50 + 28<br>el 73.17 ft<br>0 - 1.0 | Loose-to-firm, light-and green-gray fine sand and clayey fine sand.                                  | 0.2 - 7<br>1.0 - 9                     |
| C-6               | N 50 + 55, E 50 + 28<br>el 73.17 ft<br>0 - 1.0 | Loose-to-firm, light-gray and green-gray fine sand and clayey fine sand.                             | 0.2 - 9<br>1.0 - 15                    |
| C-7               | N 51 + 12, E 50 + 90<br>el 73.17 ft<br>0 - 1.0 | Loose, light-gray and green-gray fine sand and clayey fine sand.                                     | 0.2 - 5<br>1.0 - 9                     |
| C-8               | N 50 + 87, E 50 + 90<br>el 73.17 ft<br>0 - 1.0 | Loose-to-firm, light-gray and green-gray fine sand and clayey fine sand.                             | 0.2 - 8<br>1.0 - 11                    |
|                   | <i>Depth (ft)</i>                              |                                                                                                      | <i>Penetration</i>                     |

HNP-2-FSAR-2

**TABLE 2A-7 (SHEET 2 OF 2)**

| <u>Boring No.</u> | <u>From - To</u>                               | <u>Soil Description</u>                                                                         | <u>Resistance (ft)</u> |
|-------------------|------------------------------------------------|-------------------------------------------------------------------------------------------------|------------------------|
| C-9               | N 50 + 55, E 50 + 90<br>el 73.17 ft<br>0 - 1.0 | Loose, light-gray and green-gray fine sand and clayey fine sand.                                | 0.2 - 6<br>1.0 - 8     |
| C-10              | N 50 + 20, E 50 + 90<br>el 73.17 ft<br>0 - 1.0 | Firm, gray, very clayey fine sand.                                                              | 0.2 - 10<br>1.0 - 12   |
| C-11              | N 51 + 12, E 50 + 50<br>el 73.0 ft<br>0 - 1.0  | Loose, green-gray and light-gray fine sand and clayey fine sand with thin, green clay layers.   | 0.2 - 7<br>1.0 - 8     |
| C-12              | N 50 + 87, E 50 + 50<br>el 73.0 ft             | Loose-to-firm, light-gray and green-gray fine sand and clayey fine sand with thin, clay layers. | 0.2 - 7<br>1.0 - 11    |
| C-13              | N 50 + 55, E 50 + 50<br>el 73.17 ft            | Loose-to-firm, light-gray and green-gray fine sand and clayey fine sand with thin, clay layers. | 0.2 - 8<br>1.0 - 11    |
| C-14              | N 51 + 12, E 50 - 70<br>el 72.0 ft             | Loose-to-firm, light-gray and green-gray fine sand and clayey fine sand with thin, clay layers. | 0.2 - 8<br>1.0 - 11    |
| C-15              | N 50 + 87, E 50 + 70<br>el 72.5 ft             | Loose, light-gray and green-gray fine sand and clayey fine sand with thin, clay layers.         | 0.2 - 6<br>1.0 - 8     |

HNP-2-FSAR-2

**TABLE 2A-8**  
**TOTAL SETTLEMENT VALUES**

| <u>Structure</u>          | <u>Values of Predicted Settlement (ft)</u> |                                        |                            |              |                                          | <u>Ratio of Measured to Predicted (%)</u> |
|---------------------------|--------------------------------------------|----------------------------------------|----------------------------|--------------|------------------------------------------|-------------------------------------------|
|                           | <u>Immediate</u>                           | <u>Post-Construction<sup>(a)</sup></u> | <u>Total Consolidation</u> | <u>Total</u> | <u>Measured Settlement<sup>(b)</sup></u> |                                           |
| HNP-2 reactor building    | 0.27                                       | 0.04                                   | 0.11                       | 0.38         | 0.14                                     | 37.3                                      |
| HNP-2 radwaste building   | 0.20                                       | 0.00                                   | 0.09                       | 0.29         | (c)                                      | (c)                                       |
| Control building          | 0.12                                       |                                        | 0.05                       | 0.17         | 0.13                                     | 79.8                                      |
| HNP-2 turbine building    | 0.12                                       | 0.00                                   | 0.05                       | 0.17         | 0.02                                     | 11.4                                      |
| Diesel generator building |                                            |                                        |                            | 0.17         | 0.07                                     | 42.0                                      |
| Main stack                |                                            |                                        |                            | 0.17         | 0.03 <sup>(d)</sup>                      | 16.8                                      |
| Intake structure          |                                            |                                        |                            | 0.17         | 0.12 <sup>(e)</sup>                      | 70.8                                      |
| HNP-1 reactor building    | 0.18                                       |                                        | 0.08                       | 0.26         | 0.23                                     | 87.5                                      |
| HNP-1 radwaste building   | 0.09                                       |                                        | 0.04                       | 0.13         | 0.06                                     | 45.6                                      |
| HNP-1 turbine building    | 0.09                                       |                                        | 0.04                       | 0.13         | 0.10                                     | 80.0                                      |

- a. Post-construction settlement is part of total consolidation settlement.  
 b. Measured settlements as of January 1997.  
 c. Benchmarks established after end of construction: Average settlement indicates heave.  
 d. Benchmarks established after end of construction.  
 e. Benchmarks destroyed and relocated; measure is approximate only.

**TABLE 2A-9**

**CRITERIA FOR DETERMINING ALLOWABLE DIFFERENTIAL  
SETTLEMENTS ACROSS STRUCTURES**

| <u>Structure</u>                 | <u>Criteria</u>                          |
|----------------------------------|------------------------------------------|
| <i>Diesel generator building</i> | <i>a. Appearance</i>                     |
| <i>Main stack</i>                | <i>b. Equipment and system operation</i> |
| <i>Intake structure</i>          |                                          |
| <i>HNP-2 reactor building</i>    | <i>a. Gap between buildings</i>          |
| <i>Control building</i>          | <i>b. Operating basis earthquake</i>     |
| <i>HNP-2 turbine building</i>    |                                          |
| <i>HNP-2 radwaste building</i>   |                                          |

TABLE 2A-10 (SHEET 1 OF 2)

## SUMMARY OF REFERENCE DATES AND ELEVATIONS ACROSS STRUCTURES

| <u>Structure</u>                | <u>Date</u>  | <u>Benchmark</u> | <u>Elevation (ft)</u>  |
|---------------------------------|--------------|------------------|------------------------|
| HNP-2 reactor<br>building       | May 1976     | 1                | 129.914 <sup>(a)</sup> |
|                                 | May 1976     | 2                | 129.877 <sup>(a)</sup> |
|                                 | May 1976     | 3                | 129.918                |
|                                 | May 1976     | 4                | 129.864                |
| HNP-2 radwaste<br>building      | October 1975 | 5                | 132.266                |
|                                 | October 1975 | 6                | 132.240                |
|                                 | October 1975 | 7                | 132.268                |
|                                 | October 1975 | 8                | 132.309                |
| Control<br>building             | January 1975 | 9                | 111.886                |
|                                 | January 1975 | 10               | 111.842                |
|                                 | January 1975 | 11               | 111.923                |
|                                 | January 1975 | 12               | 111.920                |
| HNP-2 turbine<br>building       | May 1976     | 13               | 129.926 <sup>(a)</sup> |
|                                 | May 1976     | 14               | 129.960 <sup>(a)</sup> |
|                                 | May 1976     | 15               | 129.960 <sup>(a)</sup> |
|                                 | January 1976 | 16               | 129.911 <sup>(a)</sup> |
| Diesel<br>generator<br>building | January 1975 | 17               | 131.933 <sup>(a)</sup> |
|                                 | January 1975 | 18               | 131.643 <sup>(a)</sup> |
|                                 | January 1975 | 19               | 131.017 <sup>(a)</sup> |
|                                 | January 1975 | 20               | 131.328 <sup>(a)</sup> |
| Main stack                      | October 1974 | 21               | 199.978                |
|                                 | October 1974 | 22               | 119.972                |
|                                 | October 1974 | 23               | 119.986                |
| Intake<br>structure             | October 1974 | 24               | (b)                    |
|                                 | October 1974 | 25               |                        |
|                                 | October 1974 | 26               |                        |
|                                 | October 1974 | 27               |                        |
| HNP-1 reactor<br>building       | May 1976     | 28               | 129.772                |
|                                 | May 1976     | 29               | 129.718                |
|                                 | May 1976     | 30               | 129.884 <sup>(a)</sup> |
|                                 | May 1976     | 31               | 129.744                |

| <u>Structure</u> | <u>Date</u> | <u>Benchmark</u> | <u>Elevation (ft)</u> |
|------------------|-------------|------------------|-----------------------|
|------------------|-------------|------------------|-----------------------|

*HNP-2-FSAR-2*

**TABLE 2A-10 (SHEET 2 OF 2)**

|                                   |                     |           |                |
|-----------------------------------|---------------------|-----------|----------------|
| <i>HNP-1 turbine<br/>building</i> | <i>January 1975</i> | <i>NE</i> | <i>111.837</i> |
|                                   | <i>January 1975</i> | <i>SE</i> | <i>111.842</i> |
|                                   | <i>January 1975</i> | <i>NW</i> | <i>111.913</i> |
|                                   | <i>January 1975</i> | <i>SW</i> | <i>111.922</i> |

- 
- a. Reference elevations adjusted to account for benchmark alternations.*  
*b. Elevations on intake structure not recorded at end of construction.*



HNP-2-FSAR-2

**TABLE 2A-11**

**SUMMARY OF DIFFERENTIAL SETTLEMENTS ACROSS STRUCTURES**

| <u>Structure</u>          | <u>Reference Date</u> | <u>Direction of Tilt</u> | <u>Between Benchmark Nos.</u> | <u>Differential Settlement (in.)</u> |                               | <u>Ratio of Measured to Allowable (%)</u> |
|---------------------------|-----------------------|--------------------------|-------------------------------|--------------------------------------|-------------------------------|-------------------------------------------|
|                           |                       |                          |                               | <u>Allowable</u>                     | <u>Measured<sup>(a)</sup></u> |                                           |
| HNP-2 reactor building    | May 1976              | N-S                      | 1 and 2                       | 0.40                                 | 0.01                          | 3                                         |
|                           |                       | N-S                      | 3 and 4                       | 0.41                                 | 0.02                          | 6                                         |
|                           |                       | E-W                      | 1 and 3                       | 1.67                                 | 0.12                          | 7                                         |
|                           |                       | E-W                      | 2 and 4                       | 1.61                                 | 0.11                          | 7                                         |
| HNP-2 radwaste building   | October 1975          | N-S                      | 5 and 6                       | 1.85                                 | 0.41                          | 22                                        |
|                           |                       | N-S                      | 7 and 8                       | 1.92                                 | 0.34                          | 18                                        |
|                           |                       | E-W                      | 5 and 7                       | 1.58                                 | 0.04                          | 2                                         |
|                           |                       | E-W                      | 6 and 8                       | 0.96                                 | 0.04                          | 4                                         |
| Control building          | January 1975          | N-S                      | 9 and 10                      | 1.00                                 | 0.16                          | 16                                        |
|                           |                       | N-S                      | 11 and 12                     | 0.95                                 | 0.22                          | 23                                        |
|                           |                       | E-W                      | 9 and 11                      | 3.01                                 | 0.25                          | 8                                         |
|                           |                       | E-W                      | 10 and 12                     | 3.46                                 | 0.19                          | 6                                         |
| HNP-2 turbine building    | May 1976              | N-S                      | 13 and 14                     | 2.69                                 | 0.26                          | 10                                        |
|                           |                       | N-S                      | 15 and 16                     | 2.46                                 | 0.52                          | 21                                        |
|                           |                       | E-W                      | 13 and 15                     | 2.96                                 | 0.30                          | 10                                        |
|                           |                       | E-W                      | 14 and 16                     | 3.37                                 | 0.05                          | 1                                         |
| Diesel generator building | January 1975          | N-S                      | 17 and 18                     | 5.09                                 | 0.28                          | 5                                         |
|                           |                       | N-S                      | 19 and 20                     | 4.73                                 | 0.17                          | 4                                         |
|                           |                       | E-W                      | 17 and 19                     | 2.47                                 | 0.49                          | 20                                        |
|                           |                       | E-W                      | 18 and 20                     | 2.47                                 | 0.05                          | 2                                         |
| Main stack                | October 1974          | N-S                      | 21 and 22                     | 0.44                                 | 0.14                          | 33                                        |
|                           |                       | E-W                      | 21 and 23                     | 0.55                                 | 0.08                          | 15                                        |
|                           |                       | E-W                      | 22 and 23                     | 0.50                                 | 0.06                          | 12                                        |
| Intake structure          | October 1974          | N-S                      | 24 and 25                     | 2.50                                 | 0.12                          | 5                                         |
|                           |                       | N-S                      | 26 and 27                     | 2.50                                 | 0.04                          | 1                                         |
|                           |                       | E-W                      | 24 and 26                     | 0.65                                 | 0.02                          | 4                                         |
|                           |                       | E-W                      | 25 and 27                     | 1.25                                 | 0.11                          | 9                                         |

a. Measured settlements as of January 1997.

**TABLE 2A-12**

**CALCULATION OF MOMENT  $M_D$  DUE TO BUILDING SETTLEMENT  
PENETRATIONS BETWEEN ADJACENT STRUCTURES**

| <u>Method No.</u> | <u>Assumptions</u>                                                                                 | <u>Type of Calculation</u>                                               |
|-------------------|----------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------|
| 1                 | Rigid anchor<br>Double-acting hangers<br>Piping modeled only<br>through 3 or 4 supports            | Hand calculation<br>using basic beam<br>formulas<br>Computer calculation |
| 2                 | Some anchor flexibility<br>Single-acting hangers<br>Piping modeled only<br>through 3 or 4 supports | Computer calculation                                                     |

HNP-2-FSAR-2

**TABLE 2A-13**

**SUMMARY OF PENETRATION DIFFERENTIAL SETTLEMENTS  
HNP-2 REACTOR BUILDING AND SOIL**

| <u>Penetration</u> | <u>Date of Installation</u> | <u>Nearest Benchmark</u> | <u>Maximum Differential Settlement (in.)</u> |             |               | <u>Ratio of Measured to Allowable (%)</u> |               |
|--------------------|-----------------------------|--------------------------|----------------------------------------------|-------------|---------------|-------------------------------------------|---------------|
|                    |                             |                          | <u>Measured to Date<sup>(a)</sup></u>        | <u>Pipe</u> | <u>Anchor</u> | <u>Pipe</u>                               | <u>Anchor</u> |
| 8 in. No. 1        | November 1977               | 1                        | 0.16                                         | 0.73        | 1.03          | 21                                        | 15            |
| 10 in. No. 2       | December 1977               | 1                        | 0.13                                         | 1.22        | 0.96          | 11                                        | 14            |
| 18 in. No. 3       | April 1978                  | 1                        | 0.14                                         | 1.26        | 0.72          | 11                                        | 20            |
| 18 in. No. 4       | March 1978                  | 1                        | 0.18                                         | 1.26        | 0.72          | 14                                        | 25            |
| 6 in. No. 8        | November 1977               | 1                        | 0.16                                         | 1.22        | 0.75          | 13                                        | 21            |
| 10 in. No. 10      | January 1978                | 2                        | 0.19                                         | 1.22        | 0.96          | 16                                        | 20            |
| 18 in. No. 11      | March 1978                  | 2                        | 0.22                                         | 1.26        | 0.72          | 17                                        | 30            |
| 20 in. No. 12      | January 1978                | 2                        | 0.19                                         | 1.13        | 0.56          | 17                                        | 34            |
| 18 in. No. 13      | April 1978                  | 2                        | 0.22                                         | 1.26        | 0.72          | 17                                        | 30            |
| 14 in. No. 24      | November 1977               | 2                        | 0.19                                         | 1.15        | 1.06          | 17                                        | 18            |
| 10 in. No. 41      | February 1977               | 2                        | 0.11                                         | 1.28        | 0.88          | 8                                         | 12            |
| 16 in. No. 42      | March 1978                  | 2                        | 0.22                                         | 1.06        | 0.73          | 20                                        | 30            |
| 14 in. No. 134     | March 1978                  | 1                        | 0.18                                         | 1.15        | 1.13          | 16                                        | 16            |
| 20 in. No. 161     | January 1978                | 1                        | 0.14                                         | 1.13        | 0.71          | 13                                        | 20            |

a. Measured settlements as of January 1997.

**TABLE 2A-14**

**SUMMARY OF PENETRATION DIFFERENTIAL SETTLEMENTS  
DIESEL GENERATOR BUILDING AND SOIL**

| <u>Penetration</u> | <u>Date of Installation</u> | <u>Nearest Benchmark</u> | <u>Maximum Differential Settlement (in.)</u> |             |               | <u>Ratio of Measured to Allowable (%)</u> |               |
|--------------------|-----------------------------|--------------------------|----------------------------------------------|-------------|---------------|-------------------------------------------|---------------|
|                    |                             |                          | <u>Measured to Date<sup>(a)</sup></u>        | <u>Pipe</u> | <u>Anchor</u> | <u>Pipe</u>                               | <u>Anchor</u> |
| 6 in.              | January 1978                | 17                       | 0.06                                         | 0.57        | 0.57          | 11                                        | 11            |
| 10 in.             | December 1971               | 17                       | 0.38                                         | 0.92        | -             | 42                                        | -             |

a. Measured settlements as of January 1997.

TABLE 2A-15

**SUMMARY OF PENETRATION DIFFERENTIAL SETTLEMENTS  
MAIN STACK AND SOIL**

| <u>Penetration</u> | <u>Date of<br/>Installation</u> | <u>Nearest<br/>Benchmark</u> | <u>Maximum Differential<br/>Settlement (in.)</u> |                              | <u>Ratio of<br/>Measured to<br/>Allowable (%)</u> |
|--------------------|---------------------------------|------------------------------|--------------------------------------------------|------------------------------|---------------------------------------------------|
|                    |                                 |                              | <u>Measured<br/>to Date<sup>(a)</sup></u>        | <u>Allowable<br/>in Pipe</u> |                                                   |
| 18 in.             | June 1974                       | 23                           | 0.06                                             | 0.45                         | 5                                                 |
| 12 in.             | May 1974                        | 23                           | 0.06                                             | 0.45                         | 5                                                 |
| 20 in.             | June 1974                       | 22                           | 0.01                                             | 0.46                         | 8                                                 |
| 6 in.              | May 1974                        | 22                           | 0.01                                             | 0.46                         | 8                                                 |

a. Measured settlements as of January 1997.

TABLE 2A-16

**SUMMARY OF PENETRATION DIFFERENTIAL SETTLEMENTS  
INTAKE STRUCTURE AND SOIL**

| <u>Penetration</u>         | <u>Date of<br/>Installation</u> | <u>Nearest<br/>Benchmark</u> | <u>Measured<br/>to Date<sup>(a)</sup></u> | <u>Maximum Differential<br/>Settlement (in.)</u> |                | <u>Ratio of<br/>Measured to<br/>Allowable (%)</u> |                |
|----------------------------|---------------------------------|------------------------------|-------------------------------------------|--------------------------------------------------|----------------|---------------------------------------------------|----------------|
|                            |                                 |                              |                                           | <u>Pipe</u>                                      | <u>Support</u> | <u>Pipe</u>                                       | <u>Support</u> |
| 30 in.<br>el 97.28 ft      | January 1978                    | 25                           | 0.22                                      | 1.38                                             | 0.66           | 16                                                | 33             |
| 12 in.                     | July 1974                       | 25                           | 0.22                                      | 0.99                                             | 1.19           | 22                                                | 18             |
| 18 in. (II)                | February 1978                   | 25                           | 0.22                                      | 2.78                                             | 2.03           | 8                                                 | 11             |
| 30 in.<br>el 91.75 ft (I)  | January 1978                    | 25                           | 0.22                                      | 1.38                                             | 0.66           | 16                                                | 33             |
| 30 in.<br>el 91.75 ft (II) | January 1978                    | 25                           | 0.22                                      | 1.38                                             | 0.66           | 16                                                | 33             |
| 18 in. (I)                 | February 1978                   | 27                           | 0.11                                      | 2.47                                             | 1.27           | 4                                                 | 9              |
| 6 in.                      | April 1976                      | 26                           | 0.07                                      | 1.50                                             | 0.94           | 5                                                 | 8              |

a. Measured differential settlements are estimates only, since complete records do not exist prior to July 1978. Measured settlements are as of January 1997.

b. Allowable settlement is based on both pipe stress and support loads.

TABLE 2A-17

**SUMMARY OF PENETRATION DIFFERENTIAL SETTLEMENTS  
HNP-2 REACTOR BUILDING AND RADWASTE BUILDING**

| <u>Penetration</u> | <u>Date of Installation</u> | <u>Nearest Benchmark</u> | <u>Maximum Differential Settlement (in.)</u> |             |               | <u>Ratio of Measured to Allowable (%)</u> |               |
|--------------------|-----------------------------|--------------------------|----------------------------------------------|-------------|---------------|-------------------------------------------|---------------|
|                    |                             |                          | <u>Measured to Date<sup>(a)</sup></u>        | <u>Pipe</u> | <u>Anchor</u> | <u>Pipe</u>                               | <u>Anchor</u> |
| 1 in. No. 51       | October 1977                | 2 and 5                  | 0.19                                         | 1.54        | -             | 12                                        | -             |
| 6 in. No. 51       | October 1977                | 2 and 5                  | 0.19                                         | 1.14        | -             | 17                                        | -             |
| 1.5 in. No. 102    | November 1977               | 2 and 5                  | 0.18                                         | 1.07        | -             | 17                                        | -             |
| 8 in. No. 153      | February 1977               | 4 and 5                  | 0.12                                         | 1.48        | 0.88          | 8                                         | 14            |

a. Measured settlements as of January 1997.

TABLE 2A-18

**SUMMARY OF PENETRATION DIFFERENTIAL SETTLEMENTS  
HNP-2 REACTOR BUILDING AND CONTROL BUILDING**

| <u>Penetration</u> | <u>Date of Installation</u> | <u>Nearest Benchmark</u> | <u>Maximum Differential Settlement (in.)</u> |             |               | <u>Ratio of Measured to Allowable (%)</u> |               |
|--------------------|-----------------------------|--------------------------|----------------------------------------------|-------------|---------------|-------------------------------------------|---------------|
|                    |                             |                          | <u>Measured to Date<sup>(a)</sup></u>        | <u>Pipe</u> | <u>Anchor</u> | <u>Pipe</u>                               | <u>Anchor</u> |
| 24 in. No. 59      | May 1978                    | 3 and 10                 | 0.30                                         | 26.03       | 13.23         | 1                                         | 2             |
| 3 in. No. 60       | January 1978                | 3 and 10                 | 0.38                                         | 1.48        | 0.62          | 26                                        | 62            |
| 18 in. No. 61      | August 1977                 | 3 and 10                 | 0.40                                         | 9.55        | 1.86          | 4                                         | 21            |
| 24 in. No. 61      | September 1976              | 3 and 10                 | 0.32                                         | 12.14       | 5.06          | 3                                         | 6             |
| 4 in. No. 68       | January 1978                | 3 and 10                 | 0.38                                         | 1.84        | 0.85          | 21                                        | 45            |
| 4 in. No. 69       | January 1978                | 3 and 10                 | 0.38                                         | 1.99        | 0.78          | 19                                        | 49            |

a. Measured settlements as of January 1997.



HNP-2-FSAR-2

**TABLE 2A-19**

**SUMMARY OF PENETRATION DIFFERENTIAL SETTLEMENTS  
HNP-2 REACTOR BUILDING AND TURBINE BUILDING**

| <u>Penetration</u>              | <u>Date of Installation</u> | <u>Nearest Benchmark</u> | <u>Maximum Differential Settlement (in.)</u> |             |               | <u>Ratio of Measured to Allowable (%)</u> |               |
|---------------------------------|-----------------------------|--------------------------|----------------------------------------------|-------------|---------------|-------------------------------------------|---------------|
|                                 |                             |                          | <u>Measured to Date<sup>(a)</sup></u>        | <u>Pipe</u> | <u>Anchor</u> | <u>Pipe</u>                               | <u>Anchor</u> |
| 10 in. No. 43                   | May 1978                    | 4 and 13                 | 0.01                                         | 2.12        | 1.68          | 1                                         | 1             |
| 4 in. No. 44                    | January 1978                | 4 and 13                 | 0.01                                         | 1.30        |               | 1                                         |               |
| 3 in. No. 57                    | November 1977               | 4 and 13                 | 0.01                                         | 4.17        |               | 0                                         |               |
| 18 in. No. 57                   | July 1977                   | 4 and 13                 | 0.14                                         | 9.55        | 1.59          | 2                                         | 9             |
| 24 in. No. 57<br>(el 154.46 ft) | September 1976              | 4 and 13                 | 0.26                                         | 25.13       | 10.59         | 1                                         | 2             |
| 24 in. No. 57<br>(el 154.55 ft) | September 1976              | 4 and 13                 | 0.26                                         | 22.54       | 9.05          | 1                                         | 3             |
| 8 in. No. 84                    | February 1977               | 4 and 13                 | 0.17                                         | 1.13        | 1.01          | 15                                        | 17            |
| 10 in. No. 90                   | January 1978                | 4 and 13                 | 0.01                                         | 2.51        | 1.77          | 0                                         | 1             |
| 3 in. No. 92                    | December 1977               | 4 and 13                 | 0.04                                         | 1.78        | 1.55          | 2                                         | 2             |

a. Measured settlements as of January 1997.

HNP-2-FSAR-2

**TABLE 2A-20**

**SUMMARY OF PENETRATION DIFFERENTIAL SETTLEMENTS  
HNP-2 REACTOR BUILDING AND HNP-1 REACTOR BUILDING**

| <u>Penetration</u> | <u>Date of Installation</u> | <u>Nearest Benchmark</u> | <u>Maximum Differential Settlement (in.)</u> |             |               | <u>Ratio of Measured to Allowable (%)</u> |               |
|--------------------|-----------------------------|--------------------------|----------------------------------------------|-------------|---------------|-------------------------------------------|---------------|
|                    |                             |                          | <u>Measured to Date<sup>(a)</sup></u>        | <u>Pipe</u> | <u>Anchor</u> | <u>Pipe</u>                               | <u>Anchor</u> |
| 8 in. No. 183      | January 1978                | 1 and 29                 | 0.10                                         | 0.99        | 0.53          | 10                                        | 18            |
| 8 in. No. 184      | December 1977               | 1 and 29                 | 0.08                                         | 3.58        | 2.30          | 2                                         | 4             |

a. Measured settlements as of January 1997.

TABLE 2A-21

## CYCLIC TRIAXIAL TEST DATA FROM BORING 2001A

| <u>Sample</u> | <u>Depth<br/>(ft)</u> | <u>Test</u> | <u>Chamber<br/>Pressure<br/>(lb ft<sup>2</sup>)</u> | <u>Deviator<br/>Stress<br/>(lb ft<sup>2</sup>)</u> | <u>Cycles to 5%<br/>Double-<br/>Amplitude<br/>Strain</u> | <u>Cycles to 10%<br/>Double-<br/>Amplitude<br/>Strain</u> | <u>Unit Dry<br/>Weight<br/>(lb ft<sup>3</sup>)</u> | <u>Water<br/>Content<br/>(%)</u> |
|---------------|-----------------------|-------------|-----------------------------------------------------|----------------------------------------------------|----------------------------------------------------------|-----------------------------------------------------------|----------------------------------------------------|----------------------------------|
| 6             | 55-57                 | A           | 6000                                                | 3604                                               | 4.3                                                      | 6                                                         | 95.1                                               | 27.7                             |
|               |                       | B           | 6000                                                | 2956                                               | 15                                                       | 18                                                        | 94.2                                               | 26.8                             |
|               |                       | C           | 6000                                                | 3205                                               | 1.9                                                      | 3.5                                                       | 91.3                                               | 25.0                             |
| 7             | 60-62                 | D           | 6000                                                | 3113                                               | 18                                                       | 25                                                        | 94.5                                               | 28.9                             |
|               |                       | E           | 6000                                                | 3812                                               | 9.4                                                      | 13                                                        | 86.2                                               | 33.3                             |
|               |                       | F           | 6000                                                | 3175                                               | 35                                                       | 41                                                        | 90.9                                               | 31.8                             |
| 8             | 72-74.5               | G           | 6000                                                |                                                    | 1                                                        | 1                                                         | 81.4                                               | 40.3                             |
|               |                       | H           | 6000                                                | 2902                                               | 10                                                       | 13                                                        | 76.0                                               | 43.1                             |
|               |                       | I           | 6000                                                | 2491                                               | 28                                                       | 32                                                        | 74.8                                               | 46.3                             |
| 9             | 75-77.5               | M           | 6000                                                |                                                    | 1                                                        | 1                                                         | 70.7                                               | 49.6                             |
|               |                       | N           | 6000                                                | 2903                                               | 51                                                       | 56                                                        | 69.7                                               | 46.2                             |
|               |                       | O           | 6000                                                | 3116                                               | 32                                                       | 48                                                        | 71.0                                               | 45.4                             |
| 12            | 90-92.5               | J           | 6000                                                | 3699                                               | 3.2                                                      | 7                                                         | 101.0                                              | 23.5                             |
|               |                       | K           | 6000                                                | 3395                                               | 33                                                       | 42                                                        | 92.5                                               | 27.4                             |
|               |                       | L           | 6000                                                | 3515                                               | 90                                                       | 100                                                       | 91.3                                               | 27.3                             |

TABLE 2A-22

**SUMMARY OF DENSITY DETERMINATIONS FROM  
THIN-WALLED TUBE SAMPLES**

| <u>Boring</u> | <u>Depth<br/>(ft)</u> | <u>Recovery<br/>(ft)</u> | <u>Wet</u> | <u>Moisture<br/>(%)</u> | <u>Dry</u> |
|---------------|-----------------------|--------------------------|------------|-------------------------|------------|
| BU-1A         | 7-8.2                 | 1.2                      | 126.4      |                         |            |
|               | 15-17                 | 1.9                      | 118.8      | 6.7                     | 111.0      |
|               | 25-27                 | 2.0                      | 137.9      | 9.2                     | 126.2      |
|               | 40-41.2               | 1.1                      | 117.8      | 11.6                    | 105.6      |
|               | 52-52.9               | 0.8                      | 114.1      | 26.3                    | 90.3       |
| BU-2A         | 4-5.6                 | 1.6                      | 137.1      | 14.0                    | 120.4      |
|               | 8-9.1                 | 1.0                      | 146.3      | 24.1                    | 117.9      |
|               | 5-6.5                 | 1.4                      | 143.3      | 16.5                    | 123.0      |
|               | 11.5-12.4             | 0.6                      | 133.3      | 22.5                    | 108.8      |
| BU-4          | 15-17                 | 1.8                      | 108.5      |                         |            |
|               | 20-22                 | 0.9                      | 107.9      |                         |            |
|               | 47-49                 | 0.8                      | 97.2       |                         |            |
| BU-6A         | 4-6                   | 1.9                      | 122.5      | 15.6                    | 106.0      |
|               | 17-19                 | 1.9                      | 132.5      | 6.4                     | 124.5      |
|               | 27-29                 | 1.9                      | 129.6      | 8.9                     | 119.0      |
|               | 37-38                 | 1.0                      | 122.7      | 10.1                    | 111.4      |
| BU-9A         | 4-5.9                 | 1.8                      | 135.5      | 17.8                    | 115.0      |
|               | 8-9.4                 | 1.2                      | 127.3      | 11.2                    | 114.5      |
| B7-10A        | 4-5.7                 | 1.6                      | 125.9      | 10.9                    | 113.6      |
|               | 11-12.7               | 1.6                      | 86.2       | 15.6                    | 74.6       |
| BU-11         | 11-11.7               | 0.6                      | 134.6      | 14.7                    | 117.4      |
| BU-12         | 9-10.3                | 1.3                      | 135.8      |                         |            |
| BU-13         | 8-10                  | 1.9                      | 144.4      | 12.5                    | 128.4      |
|               | 23-25                 | 1.9                      | 127.8      | 9.7                     | 116.5      |
| BU-14         | 5.5-7.3               | 1.6                      | 139.7      | 12.9                    | 123.7      |
|               | 18-19.3               | 1.2                      | 125.0      | 5.5                     | 118.5      |
|               | 28-29.9               | 1.9                      | 125.6      | 6.1                     | 118.4      |
| BU-15         | 10-11.9               | 1.8                      | 131.1      | 11.3                    | 117.8      |
|               | 18-20                 | 1.9                      | 123.8      | 6.8                     | 115.9      |

TABLE 2A-23 (SHEET 1 OF 2)

**TEST PIT AND DENSITY TEST SUMMARY - MODIFIED PROCTOR**

| <u>Test Pit No.</u> | <u>Test No.</u> | <u>Depth (ft)</u> | <u>Wet Weight (lb/ft<sup>3</sup>)</u> | <u>Moisture (%)</u> | <u>Dry Weight (lb/ft<sup>3</sup>)</u> | <u>Proctor No.</u> | <u>Compaction (%)</u> |
|---------------------|-----------------|-------------------|---------------------------------------|---------------------|---------------------------------------|--------------------|-----------------------|
| TP-1                | 1               | - 3.0             | 107.2                                 | 2.0                 | 105.1                                 | 6                  | 85.8                  |
| TP-1                | 2               | - 3.0             | 105.2                                 | 3.7                 | 101.4                                 | 6                  | 82.5                  |
| TP-1                | 3               | - 5.0             | 129.3                                 | 9.9                 | 117.7                                 | 6                  | 96.1                  |
| TP-1                | 4               | - 5.0             | 128.1                                 | 9.1                 | 117.4                                 | 6                  | 95.8                  |
| TP-1                | 5               | - 7.0             | 129.3                                 | 12.4                | 115.0                                 | 7                  | 97.7                  |
| TP-1                | 6               | - 7.0             | 128.1                                 | 14.4                | 112.0                                 | 7                  | 95.2                  |
| TP-1                | 7               | - 9.0             | 118.1                                 | 4.0                 | 113.6                                 | 7                  | 96.5                  |
| TP-2                | 8               | - 2.0             | 138.2                                 | 11.0                | 124.5                                 | 10                 | 97.3                  |
| TP-2                | 9               | - 4.0             | 128.6                                 | 14.2                | 112.6                                 | 6                  | 91.9                  |
| TP-2                | 10              | - 6.0             | 123.5                                 | 14.7                | 107.7                                 | 6                  | 87.9                  |
| TP-2                | 11              | - 8.0             | 111.9                                 | 12.9                | 99.1                                  | 9                  | 94.6                  |
| TP-4                | 12              | - 3.5             | 122.0                                 | 12.5                | 108.4                                 | 10                 | 84.7                  |
| TP-4                | 13              | - 5.5             | 131.0                                 | 11.7                | 117.3                                 | 11                 | 93.1                  |
| TP-4                | 14              | - 7.5             | 133.1                                 | 27.7                | 104.2                                 | 6                  | 85.1                  |
| TP-4                | 15              | - 6.0             | 123.2                                 | 15.6                | 106.6                                 | 6                  | 87.0                  |
| TP-5                | 16              | - 4.5             | 130.4                                 | 9.5                 | 119.1                                 | 7                  | 100.0                 |
| TP-5                | 17              | - 6.5             | 122.0                                 | 10.4                | 110.5                                 | 6                  | 90.2                  |
| TP-5                | 18              | - 8.5             | 129.5                                 | 16.6                | 111.1                                 | 6                  | 90.7                  |
| TP-5                | 19              | -10.0             | 136.5                                 | 13.8                | 119.9                                 | 7                  | 100.0                 |

HNP-2-FSAR-2

TABLE 2A-23 (SHEET 2 OF 2)

| <u>Proctor No.</u> | <i>Maximum Dry Density<br/>(lb/ft<sup>3</sup>)</i> | <i>Optimum Moisture Content<br/>(%)</i> |
|--------------------|----------------------------------------------------|-----------------------------------------|
| 5                  | 127.2                                              | 8.0                                     |
| 6                  | 122.5                                              | 11.2                                    |
| 7                  | 117.7                                              | 9.0                                     |
| 9                  | 104.8                                              | 13.5                                    |
| 10                 | 128.0                                              | 9.1                                     |
| 11                 | 126.0                                              | 9.0                                     |
| 12                 | 126.7                                              | 9.0                                     |

**TABLE 2A-24**

**RESULTS OF UNCONFINED COMPRESSION STRENGTH  
TESTS ON K-KRETE CYLINDERS**


| <u>Cylinder</u> | <u>Time of<br/>Test<br/>(days)</u> | <u>Stress<br/>(psi)</u> | <u>Strain<br/>(in./in.)</u> | <u>Bulk Unit<br/>Weight<br/>(lb/ft<sup>3</sup>)</u> | <u>Type of<br/>Mix</u> |
|-----------------|------------------------------------|-------------------------|-----------------------------|-----------------------------------------------------|------------------------|
| 1               | 7                                  | 22.3                    | 0.034                       | 127.9                                               | Lab mix                |
| 2               | 7                                  | 24.7                    | 0.089                       | 127.9                                               | Lab mix                |
| 3               | 7                                  | 26.3                    | 0.094                       | 127.9                                               | Lab mix                |
| 4               | 7                                  | 13.4                    | 0.040                       | 133.1                                               | Field mix              |
| 5               | 7                                  | 10.6                    | 0.042                       | 133.1                                               | Field mix              |
| 6               | 7                                  | 13.9                    | 0.058                       | 131.3                                               | Field mix              |
| 7               | 28                                 | 17.0                    | 0.056                       | 133.1                                               | Field mix              |
| 8               | 28                                 | 21.7                    | 0.088                       | 131.3                                               | Field mix              |
| 9               | 28                                 | 21.6                    | 0.076                       | 133.1                                               | Field mix              |

**TABLE 2A-25**

**RESULTS OF UNCONSOLIDATED TRIAXIAL SHEAR TESTS  
UNDRAINED ON K-KRETE**

| <u>Time of Test (days)</u> | <u>Cohesion (c)</u> | <u>Angle of Shear Resistance (<math>\phi</math>)</u> |
|----------------------------|---------------------|------------------------------------------------------|
| 7                          | 1 ksf               | 34°                                                  |
| 14                         | 1.2 ksf             | 29°                                                  |
| 28                         | 1.2 ksf             | 31°                                                  |






HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

FOUNDATION BORINGS  
LOCATION PLAN

FIGURE 2A-1 (SHEET 1 OF 2)




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

FOUNDATION BORINGS  
 LOCATION PLAN

FIGURE 2A-1 (SHEET 2 OF 2)

**LEGEND**  
 ○ PRE CONSTRUCTION TEST BORING  
 ● CONSTRUCTION INSPECTION BORING

SCALE  
 50 0 100 200




*HISTORICAL*  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

BORING AND PROFILE LOCATIONS IN PLANT AREA

FIGURE 2A-2



SECTION A-A

CORRELATION OF PENETRATION RESISTANCE WITH RELATIVE DENSITY AND CONSISTENCY

|                 | NUMBER OF BLOWS, N | RELATIVE DENSITY | CONSISTENCY |
|-----------------|--------------------|------------------|-------------|
| SANDS           | 0 - 4              | VERY LOOSE       |             |
|                 | 4 - 10             | LOOSE            |             |
|                 | 10 - 30            | FIRM             |             |
|                 | 30 - 50            | DENSE            |             |
|                 | OVER 50            | VERY DENSE       |             |
| SILTS AND CLAYS | 0 - 2              | VERY SOFT        |             |
|                 | 2 - 4              | SOFT             |             |
|                 | 4 - 8              | FIRM             |             |
|                 | 8 - 15             | STIFF            |             |
|                 | 15 - 30            | VERY STIFF       |             |
|                 | 30 - 50            | HARD             |             |
|                 | OVER 50            | VERY HARD        |             |

SOIL LITHOLOGIES

- (A) Gray green silty CLAY with fine sand seams
- (B) Gray tan and white slightly clayey fine SAND with clay inclusions and layers
- (C) Gray green slightly clayey fine and very fine SAND with plastic clay layers and inclusions
- (CC) Gray green slightly sandy plastic CLAY
- (D) Light gray slightly clayey fine and very fine SAND with partially cemented clay inclusions
- (DD) Light green gray silty slightly clayey fine and very fine SAND with few clay inclusions
- (E) Gray green clayey partially cemented SAND and CLAY
- (EE) Gray very clayey very fine SAND
- (F) Green gray clayey very fine and fine SAND with clay inclusions
- (FF) Gray slightly clayey fine SAND
- (G) Gray green slightly fine sandy plastic CLAY with thin fine sand seams
- (H) Green gray slightly clayey fine and very fine SAND with plastic clay layers and inclusions
- (HH) Green and gray clayey fine to medium SAND with clay inclusions
- (J) Gray clayey fine to medium SAND with clay inclusions, partially cemented
- (K) Light gray clayey very fine SAND with few clay inclusions
- (L) Gray clayey fine to coarse SAND
- (M) Gray partially cemented fine sandy silty CLAY
- (N) Gray and tan fine to medium sandy CLAY
- (P) Gray very silty fine SAND with partially cemented clay inclusions
- (R) Gray and brown silty fine to medium SAND with clay inclusions


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

SUBSURFACE PROFILES A-A

FIGURE 2A-3 (SHEET 1 OF 7)



SECTION B-B

CORRELATION OF PENETRATION RESISTANCE WITH RELATIVE DENSITY AND CONSISTENCY

|                 | NUMBER OF BLOWS, N | RELATIVE DENSITY |
|-----------------|--------------------|------------------|
| SANDS           | 0 - 4              | VERY LOOSE       |
|                 | 4 - 10             | LOOSE            |
|                 | 10 - 30            | FIRM             |
|                 | 30 - 50            | DENSE            |
|                 | OVER 50            | VERY DENSE       |
| SILTS AND CLAYS |                    | CONSISTENCY      |
|                 | 0 - 2              | VERY SOFT        |
|                 | 2 - 4              | SOFT             |
|                 | 4 - 8              | FIRM             |
|                 | 8 - 15             | STIFF            |
|                 | 15 - 30            | VERY STIFF       |
|                 | 30 - 50            | HARD             |
| OVER 50         | VERY HARD          |                  |

SOIL LITHOLOGIES

- (A) Gray green silty CLAY with fine sand seams
- (B) Gray tan and white slightly clayey fine SAND with clay inclusions and layers
- (C) Gray green slightly clayey fine and very fine SAND with plastic clay layers and inclusions
- (CC) Gray green slightly sandy plastic CLAY
- (D) Light gray slightly clayey fine and very fine SAND with partially cemented clay inclusions
- (DD) Light green gray silty slightly clayey fine and very fine SAND with few clay inclusions
- (E) Gray green clayey partially cemented SAND and CLAY
- (EE) Gray very clayey very fine SAND
- (F) Green gray clayey very fine and fine SAND with clay inclusions
- (FF) Gray slightly clayey fine SAND
- (G) Gray green slightly fine sandy plastic CLAY with thin fine sand seams
- (H) Green gray slightly clayey fine and very fine SAND with plastic clay layers and inclusions
- (HH) Green and gray clayey fine to medium SAND with clay inclusions
- (J) Gray clayey fine to medium SAND with clay inclusions, partially cemented
- (K) Light gray clayey very fine SAND with few clay inclusions
- (L) Gray clayey fine to coarse SAND
- (M) Gray partially cemented fine sandy silty CLAY
- (N) Gray and tan fine to medium sandy CLAY
- (P) Gray very silty fine SAND with partially cemented clay inclusions
- (R) Gray and brown silty fine to medium SAND with clay inclusions


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

SUBSURFACE PROFILES  
B-B

FIGURE 2A-3 (SHEET 2 OF 7)



SECTION C-C

CORRELATION OF PENETRATION RESISTANCE  
WITH  
RELATIVE DENSITY AND CONSISTENCY

|                 | NUMBER OF BLOWS, N | RELATIVE DENSITY   |
|-----------------|--------------------|--------------------|
| SANDS           | 0 - 4              | VERY LOOSE         |
|                 | 4 - 10             | LOOSE              |
|                 | 10 - 30            | FIRM               |
|                 | 30 - 50            | DENSE              |
|                 | OVER 50            | VERY DENSE         |
| SILTS AND CLAYS |                    | <u>CONSISTENCY</u> |
|                 | 0 - 2              | VERY SOFT          |
|                 | 2 - 4              | SOFT               |
|                 | 4 - 8              | FIRM               |
|                 | 8 - 15             | STIFF              |
|                 | 15 - 30            | VERY STIFF         |
|                 | 30 - 50            | HARD               |
|                 | OVER 50            | VERY HARD          |

SOIL LITHOLOGIES

- (A) Gray green silty CLAY with fine sand seams
- (B) Gray tan and white slightly clayey fine SAND with clay inclusions and layers
- (C) Gray green slightly clayey fine and very fine SAND with plastic clay layers and inclusions
- (CC) Gray green slightly sandy plastic CLAY
- (D) Light gray slightly clayey fine and very fine SAND with partially cemented clay inclusions
- (DD) Light green gray silty slightly clayey fine and very fine SAND with few clay inclusions
- (E) Gray green clayey partially cemented SAND and CLAY
- (EE) Gray very clayey very fine SAND
- (F) Green gray clayey very fine and fine SAND with clay inclusions
- (FF) Gray slightly clayey fine SAND
- (G) Gray green slightly fine sandy plastic CLAY with thin fine sand seams
- (H) Green gray slightly clayey fine and very fine SAND with plastic clay layers and inclusions
- (HH) Green and gray clayey fine to medium SAND with clay inclusions
- (J) Gray clayey fine to medium SAND with clay inclusions, partially cemented
- (L) Light gray clayey very fine SAND with few clay inclusions
- (L) Gray clayey fine to coarse SAND
- (M) Gray partially cemented fine sandy silty CLAY
- (N) Gray and tan fine to medium sandy CLAY
- (P) Gray very silty fine SAND with partially cemented clay inclusions
- (R) Gray and brown silty fine to medium SAND with clay inclusions

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

SUBSURFACE PROFILES  
C-C

FIGURE 2A-3 (SHEET 3 OF 7)



SECTION D-D

CORRELATION OF PENETRATION RESISTANCE WITH RELATIVE DENSITY AND CONSISTENCY

|                 | NUMBER OF BLOWS, N | RELATIVE DENSITY |
|-----------------|--------------------|------------------|
| SANDS           | 0 - 4              | VERY LOOSE       |
|                 | 4 - 10             | LOOSE            |
|                 | 10 - 30            | FIRM             |
|                 | 30 - 50            | DENSE            |
|                 | OVER 50            | VERY DENSE       |
| SILTS AND CLAYS |                    | CONSISTENCY      |
|                 | 0 - 2              | VERY SOFT        |
|                 | 2 - 4              | SOFT             |
|                 | 4 - 8              | FIRM             |
|                 | 8 - 15             | STIFF            |
|                 | 15 - 30            | VERY STIFF       |
|                 | 30 - 50            | HARD             |
| OVER 50         | VERY HARD          |                  |

SOIL LITHOLOGIES

- (A) Gray green silty CLAY with fine sand seams
- (B) Gray tan and white slightly clayey fine SAND with clay inclusions and layers
- (C) Gray green slightly clayey fine and very fine SAND with plastic clay layers and inclusions
- (CC) Gray green slightly sandy plastic CLAY
- (D) Light gray slightly clayey fine and very fine SAND with partially cemented clay inclusions
- (DD) Light green gray silty slightly clayey fine and very fine SAND with few clay inclusions
- (E) Gray green clayey partially cemented SAND and CLAY
- (EE) Gray very clayey very fine SAND
- (F) Green gray clayey very fine and fine SAND with clay inclusions
- (FF) Gray slightly clayey fine SAND
- (G) Gray green slightly fine sandy plastic CLAY with thin fine sand seams
- (H) Green gray slightly clayey fine and very fine SAND with plastic clay layers and inclusions
- (HH) Green and gray clayey fine to medium SAND with clay inclusions
- (J) Gray clayey fine to medium SAND with clay inclusions, partially cemented
- (K) Light gray clayey very fine SAND with few clay inclusions
- (L) Gray clayey fine to coarse SAND
- (M) Gray partially cemented fine sandy silty CLAY
- (N) Gray and tan fine to medium sandy CLAY
- (P) Gray very silty fine SAND with partially cemented clay inclusions
- (R) Gray and brown silty fine to medium SAND with clay inclusions

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

SUBSURFACE PROFILES  
D-D

FIGURE 2A-3 (SHEET 4 OF 7)



SECTION E-E

CORRELATION OF PENETRATION RESISTANCE  
WITH  
RELATIVE DENSITY AND CONSISTENCY

|                 | NUMBER OF BLOWS, N | RELATIVE DENSITY |
|-----------------|--------------------|------------------|
| SANDS           | 0 - 6              | VERY LOOSE       |
|                 | 4 - 10             | LOOSE            |
|                 | 10 - 30            | FIRM             |
|                 | 30 - 50            | DENSE            |
|                 | OVER 50            | VERY DENSE       |
| SILTS AND CLAYS | 0 + 2              | VERY SOFT        |
|                 | 2 - 4              | SOFT             |
|                 | 4 - 8              | FIRM             |
|                 | 8 - 13             | STIFF            |
|                 | 15 - 30            | VERY STIFF       |
|                 | 30 - 50            | HARD             |
|                 | OVER 50            | VERY HARD        |

SOIL LITHOLOGIES

- (A) Gray green silty CLAY with fine sand seams
- (B) Gray tan and white slightly clayey fine SAND with clay inclusions and layers
- (C) Gray green slightly clayey fine and very fine SAND with plastic clay layers and inclusions
- (CC) Gray green slightly sandy plastic CLAY
- (D) Light gray slightly clayey fine and very fine SAND with partially cemented clay inclusions
- (DD) Light green gray silty slightly clayey fine and very fine SAND with few clay inclusions
- (E) Gray green clayey partially cemented SAND and CLAY
- (EE) Gray very clayey very fine SAND
- (F) Green gray clayey very fine and fine SAND with clay inclusions
- (FF) Gray slightly clayey fine SAND
- (G) Gray green slightly fine sandy plastic CLAY with thin fine sand seams
- (H) Green gray slightly clayey fine and very fine SAND with plastic clay layers and inclusions
- (HH) Green and gray clayey fine to medium SAND with clay inclusions
- (J) Gray clayey fine to medium SAND with clay inclusions, partially cemented
- (K) Light gray clayey very fine SAND with few clay inclusions
- (L) Gray clayey fine to coarse SAND
- (M) Gray partially cemented fine sandy silty CLAY
- (N) Gray and tan fine to medium sandy CLAY
- (P) Gray very silty fine SAND with partially cemented clay inclusions
- (R) Gray and brown silty fine to medium SAND with clay inclusions

ACAD

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

SUBSURFACE PROFILES  
E-E

FIGURE 2A-3 (SHEET 5 OF 7)





SECTION F-F

CORRELATION OF PENETRATION RESISTANCE WITH RELATIVE DENSITY AND CONSISTENCY

|                 | NUMBER OF BLOWS, N | RELATIVE DENSITY | CONSISTENCY |
|-----------------|--------------------|------------------|-------------|
| SANDS           | 0 - 4              | VERY LOOSE       |             |
|                 | 4 - 10             | LOOSE            |             |
|                 | 10 - 30            | FIRM             |             |
|                 | 30 - 50            | DENSE            |             |
|                 | OVER 50            | VERY DENSE       |             |
| SILTS AND CLAYS | 0 - 2              |                  | VERY SOFT   |
|                 | 2 - 4              |                  | SOFT        |
|                 | 4 - 8              |                  | FIRM        |
|                 | 8 - 15             |                  | STIFF       |
|                 | 15 - 30            |                  | VERY STIFF  |
|                 | 30 - 50            |                  | HARD        |
|                 | OVER 50            |                  | VERY HARD   |

- SOIL LITHOLOGIES
- (A) Gray green silty CLAY with fine sand seams
  - (B) Gray tan and white slightly clayey fine SAND with clay inclusions and layers
  - (C) Gray green slightly clayey fine and very fine SAND with plastic clay layers and inclusions
  - (CC) Gray green slightly sandy plastic CLAY
  - (D) Light gray slightly clayey fine and very fine SAND with partially cemented clay inclusions
  - (DD) Light green gray silty slightly clayey fine and very fine SAND with few clay inclusions
  - (E) Gray green clayey partially cemented SAND and CLAY
  - (EE) Gray very clayey very fine SAND
  - (F) Green gray clayey very fine and fine SAND with clay inclusions
  - (FF) Gray slightly clayey fine SAND
  - (G) Gray green slightly fine sandy plastic CLAY with thin fine sand seams
  - (H) Green gray slightly clayey fine and very fine SAND with plastic clay layers and inclusions
  - (HH) Green and gray clayey fine to medium SAND with clay inclusions
  - (J) Gray clayey fine to medium SAND with clay inclusions, partially cemented
  - (K) Light gray clayey very fine SAND with few clay inclusions
  - (L) Gray clayey fine to coarse SAND
  - (M) Gray partially cemented fine sandy silty CLAY
  - (N) Gray and tan fine to medium sandy CLAY
  - (P) Gray very silty fine SAND with partially cemented clay inclusions
  - (R) Gray and brown silty fine to medium SAND with clay inclusions


HISTORICAL  
REV 17 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

SUBSURFACE PROFILES  
E-E

FIGURE 2A-3 (SHEET 6 OF 7)



SECTION G-G

CORRELATION OF PENETRATION RESISTANCE WITH RELATIVE DENSITY AND CONSISTENCY

|                 | NUMBER OF BLOWS, N | RELATIVE DENSITY |
|-----------------|--------------------|------------------|
| SANDS           | 0 - 4              | VERY LOOSE       |
|                 | 4 - 10             | LOOSE            |
|                 | 10 - 30            | FIRM             |
|                 | 30 - 50            | DENSE            |
|                 | OVER 50            | VERY DENSE       |
| SILTS AND CLAYS | 0 - 2              | VERY SOFT        |
|                 | 2 - 4              | SOFT             |
|                 | 4 - 8              | FIRM             |
|                 | 8 - 15             | STIFF            |
|                 | 15 - 30            | VERY STIFF       |
|                 | 30 - 50            | HARD             |
| OVER 50         | VERY HARD          |                  |

SOIL LITHOLOGIES

- (A) Gray green silty CLAY with fine sand seams
- (B) Gray tan and white slightly clayey fine SAND with clay inclusions and layers
- (C) Gray green slightly clayey fine and very fine SAND with plastic clay layers and inclusions
- (CC) Gray green slightly sandy plastic CLAY
- (D) Light gray slightly clayey fine and very fine SAND with partially cemented clay inclusions
- (DD) Light green gray silty slightly clayey fine and very fine SAND with few clay inclusions
- (E) Gray green clayey partially cemented SAND and CLAY
- (EE) Gray waxy clayey very fine SAND
- (F) Green gray clayey very fine and fine SAND with clay inclusions
- (FF) Gray slightly clayey fine SAND
- (G) Gray green slightly fine sandy plastic CLAY with thin fine sand seams
- (H) Green gray slightly clayey fine and very fine SAND with plastic clay layers and inclusions
- (HH) Green and gray clayey fine to medium SAND with clay inclusions
- (I) Gray clayey fine to medium SAND with clay inclusions, partially cemented
- (K) Light gray clayey very fine SAND with few clay inclusions
- (L) Gray clayey fine to coarse SAND
- (M) Gray partially cemented fine sandy silty CLAY
- (N) Gray and tan fine to medium sandy CLAY
- (P) Gray very silty fine SAND with partially cemented clay inclusions
- (R) Gray and brown silty fine to medium SAND with clay inclusions


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

SUBSURFACE PROFILES  
G-G

FIGURE 2A-3 (SHEET 7 OF 7)



ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**SEISMIC TRAVERSE LINES**

**FIGURE 2A-4**



ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

REFRACTION SURVEY  
LINE 1

FIGURE 2A-5



ACAD


HISTORICAL  
REV 19 7/01









SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

REFRACTION SURVEY  
LINE 2

FIGURE 2A-6



**LEGEND**

-  ALLUVIUM
-  BRANDYWINE FORMATION: gravel, sand, silt
-  HAWTHORN FORMATION ("Hoopans Un differentiated") Sandy clay, sand, gravel.
-  TOPOGRAPHIC CONTOUR (25 FEET INTERVAL)
-  GEOLOGIC CONTACT (APPROXIMATE)
-  GEORGIA GRID SYSTEM  
PLANT GRID SYSTEM

**NOTE:**  
ATTITUDE OF ALL STRATA HORIZONTAL OR SLIGHT DIP TO EAST-SOUTHEAST.









HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

SURFACE DISTRIBUTION  
OF GEOLOGIC FORMATIONS

FIGURE 2A-7









HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 1 OF 34)



HISTORICAL  
 REV 19 7/01









SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 2 OF 34)











HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 3 OF 34)









HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 4 OF 34)









HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 5 OF 34)









HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 6 OF 34)









HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 7 OF 34)









HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 8 OF 34)




HISTORICAL  
 REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

GRAIN SIZE DISTRIBUTION


FIGURE 2A-8 (SHEET 9 OF 34)




| BORING NO | ELEV OR DEPTH | NAT WC | LL | PL | PI | DESCRIPTION OR CLASSIFICATION                        |
|-----------|---------------|--------|----|----|----|------------------------------------------------------|
| B-578     | Elev. 16      |        |    |    |    | LIGHT GRAY BROWN SLIGHTLY CLAYEY MEDIUM TO FINE SAND |



| BORING NO | ELEV OR DEPTH | NAT WC | LL | PL | PI | DESCRIPTION OR CLASSIFICATION  |
|-----------|---------------|--------|----|----|----|--------------------------------|
| B-579     | Elev. 21      |        |    |    |    | LIGHT GRAY MEDIUM TO FINE SAND |



| BORING NO | ELEV OR DEPTH | NAT WC | LL | PL | PI | DESCRIPTION OR CLASSIFICATION                  |
|-----------|---------------|--------|----|----|----|------------------------------------------------|
| B-578 #8  | Elev. 27      |        |    |    |    | LIGHT GRAY SLIGHTLY CLAYEY MEDIUM TO FINE SAND |



| BORING NO | ELEV OR DEPTH | NAT WC | LL | PL | PI | DESCRIPTION OR CLASSIFICATION                 |
|-----------|---------------|--------|----|----|----|-----------------------------------------------|
| B-579     | Elev. 46      |        |    |    |    | LIGHT GRAY SLIGHTLY SILTY MEDIUM TO FINE SAND |

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2


GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 10 OF 34)







| BORING NO | ELEV OR DEPTH | NAT | WC | LL | PL | PI | DESCRIPTION OR CLASSIFICATION                        |
|-----------|---------------|-----|----|----|----|----|------------------------------------------------------|
| B-580     | Elev. 19      |     |    |    |    |    | LIGHT GRAY BROWN SLIGHTLY CLAYEY MEDIUM TO FINE SAND |



| BORING NO | ELEV OR DEPTH | NAT | WC | LL | PL | PI | DESCRIPTION OR CLASSIFICATION               |
|-----------|---------------|-----|----|----|----|----|---------------------------------------------|
| B-580     | Elev. 49      |     |    |    |    |    | LIGHT GRAY TO GREEN SILTY CLAYEY FINE SAND- |



| BORING NO | ELEV OR DEPTH | NAT | WC | LL | PL | PI | DESCRIPTION OR CLASSIFICATION        |
|-----------|---------------|-----|----|----|----|----|--------------------------------------|
| B-580     | Elev. 35      |     |    |    |    |    | LIGHT GRAY SLIGHTLY CLAYEY FINE SAND |



| BORING NO | ELEV OR DEPTH | NAT  | WC  | LL | PL | PI | DESCRIPTION OR CLASSIFICATION                     |
|-----------|---------------|------|-----|----|----|----|---------------------------------------------------|
| B-580     | Elev. 78      | 63.5 | 126 | 47 | 79 |    | GRAY GREEN PLASTIC CLAY WITH FINE SAND INCLUSIONS |




HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 11 OF 34)







HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 12 OF 34)







HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 13 OF 34)







HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 14 OF 34)







HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 15 OF 34)







HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 16 OF 34)







HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 17 OF 34)



HISTORICAL  
REV 19 7/01







SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 18 OF 34)









HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 19 OF 34)







HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 20 OF 34)



HISTORICAL





REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 21 OF 34)





HISTORICAL  
REV 19 7/20



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 22 OF 34)




HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 23 OF 34)



| BOUL<br>DERS      | COBBLES       | GRAVEL |      |        |        | SAND                                  |            |            | FINES |  |
|-------------------|---------------|--------|------|--------|--------|---------------------------------------|------------|------------|-------|--|
|                   |               | COARSE | FINE | COARSE | MEDIUM | FINE                                  | SILT SIZES | CLAY SIZES |       |  |
| BORING NO         | ELEV OR DEPTH | MAT WC | LL   | PL     | PI     | DESCRIPTION OR CLASSIFICATION         |            |            |       |  |
| IFI-1<br>(INTAKE) | 13.5          |        |      |        |        | GRAY TAN FINE TO MEDIUM SAND<br>N= 24 |            |            |       |  |


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 24 OF 34)



| BOUL<br>DERS      | COBBLES       | GRAVEL |      | SAND   |        |                                                     | FINES      |            |
|-------------------|---------------|--------|------|--------|--------|-----------------------------------------------------|------------|------------|
|                   |               | COARSE | FINE | COARSE | MEDIUM | FINE                                                | SILT SIZES | CLAY SIZES |
| BORING NO         | ELEV OR DEPTH | MAT WC | LL   | PL     | PI     | DESCRIPTION OR CLASSIFICATION                       |            |            |
| IF1-1<br>(INTAKE) | 23.5          |        |      |        |        | GRAY TAN SILTY CLAYEY FINE TO MEDIUM SAND<br>N = 17 |            |            |

HISTORICAL  
REV 19 7/01


ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 25 OF 34)



|              |         |        |      |        |        |      |            |            |
|--------------|---------|--------|------|--------|--------|------|------------|------------|
| BOUL<br>DERS | COBBLES | GRAVEL |      | SAND   |        |      | FINES      |            |
|              |         | COARSE | FINE | COARSE | MEDIUM | FINE | SILT SIZES | CLAY SIZES |

| BORING NO         | ELEV OR DEPTH | MAT WC | LL | PL | PI | DESCRIPTION OR CLASSIFICATION               |
|-------------------|---------------|--------|----|----|----|---------------------------------------------|
| IF1-1<br>(INTAKE) | 28.5          |        |    |    |    | GRAY TAN CLAYEY FINE TO MEDIUM SAND<br>N=14 |

ACAD

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 26 OF 34)





| BOUL<br>DERS      | COBBLES       | GRAVEL |      |    | SAND   |                                              |      | FINES      |            |
|-------------------|---------------|--------|------|----|--------|----------------------------------------------|------|------------|------------|
|                   |               | COARSE | FINE |    | COARSE | MEDIUM                                       | FINE | SILT SIZES | CLAY SIZES |
| BORING NO         | ELEV OR DEPTH | MAT WC | LL   | PL | PI     | DESCRIPTION OR CLASSIFICATION                |      |            |            |
| IFI-1<br>(INTAKE) | 33.5          |        |      |    |        | LIGHT GRAY SILTY CLAYEY<br>FINE SAND<br>N=15 |      |            |            |

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 27 OF 34)



| BOULDERS | COBBLES | GRAVEL |      |        | SAND   |      |            | FINES      |  |
|----------|---------|--------|------|--------|--------|------|------------|------------|--|
|          |         | COARSE | FINE | COARSE | MEDIUM | FINE | SILT SIZES | CLAY SIZES |  |

| BORING NO         | ELEV OR DEPTH | MAT WC | LL | PL | PI | DESCRIPTION OR CLASSIFICATION       |
|-------------------|---------------|--------|----|----|----|-------------------------------------|
| IF1-1<br>(INTAKE) | 38.5          |        |    |    |    | LIGHT GRAY CLAYEY FINE SAND<br>N=18 |

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION

FIGURE 2A-8 (SHEET 28 OF 34)



|              |         |        |      |        |        |      |            |            |
|--------------|---------|--------|------|--------|--------|------|------------|------------|
| BOUL<br>DERS | COBBLES | GRAVEL |      | SAND   |        |      | FINES      |            |
|              |         | COARSE | FINE | COARSE | MEDIUM | FINE | SILT SIZES | CLAY SIZES |

| BORING NO         | ELEV OR DEPTH | MAT | WC | LL | PL | PI | DESCRIPTION OR CLASSIFICATION                |
|-------------------|---------------|-----|----|----|----|----|----------------------------------------------|
| IF1-1<br>(INTAKE) | 43.5          |     |    |    |    |    | LIGHT GRAY SILTY CLAYEY<br>FINE SAND<br>N=20 |

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GRAIN SIZE DISTRIBUTION


FIGURE 2A-8 (SHEET 29 OF 34)




○ SAMPLES FROM UNIT 1 REACTOR, RADWASTE, & TURBINE BUILDING BORINGS  
 ■ SAMPLES FROM UNIT 2 REACTOR, RADWASTE, & TURBINE BUILDING BORINGS

ACAD


HISTORICAL  
 REV 19 7/01




Unit 1 Elevation 75.4




Unit 2 Elevation 73.5



Unit 1 Elevation 73.0



Unit 1 Elevation 72.5



Unit 1 Elevation 72.2


HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

COMPARISON OF HNP-1 AND HNP-2 GRAIN SIZE  
CURVES BETWEEN el 72 ft AND 76 ft


FIGURE 2A-8 (SHEET 31 OF 34)




Unit 1 Elevation 63.9



Unit 2 Elevation 63.5



Unit 2 Elevation 63.1



Unit 1 Elevation 63.0


HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

COMPARISON OF HNP-1 AND HNP-2 GRAIN SIZE  
CURVES BETWEEN el 63 ft AND 64 ft


FIGURE 2A-8 (SHEET 32 OF 34)




Unit 2 Elevation 53.5




Unit 1 Elevation 53.0




Unit 1 Elevation 52.5




Unit 1 Elevation 51.7



Unit 2 Elevation 49.1



Unit 2 Elevation 48.5



Unit 2 Elevation 48.1


HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

COMPARISON OF HNP-1 AND HNP-2 GRAIN SIZE  
CURVES BETWEEN el 48 ft AND 54 ft

FIGURE 2A-8 (SHEET 33 OF 34)



Unit 1 Elevation 38.0



Unit 2 Elevation 34.1

HISTORICAL  
REV 19 7/01







SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

COMPARISON OF HNP-1 AND HNP-2 GRAIN SIZE  
CURVES BETWEEN el 34 ft AND 38 ft

FIGURE 2A-8 (SHEET 34 OF 34)









HISTORICAL  
 REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

CONSOLIDATION TEST RESULTS

FIGURE 2A-9 (SHEET 1 OF 4)







HISTORICAL  
 REV 19 7/01



CONSOLIDATION TEST RESULTS

FIGURE 2A-9 (SHEET 2 OF 4)



HISTORICAL  
 REV 19 7/01





SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

CONSOLIDATION TEST RESULTS

FIGURE 2A-9 (SHEET 3 OF 4)

COMPRESSION INDEX -  $C_c$  - 0.185  
 UNIT WEIGHT (pcf) -  $\gamma_m$  (INITIAL) 97.4  $\gamma_m$  (FINAL) 101.0  
 WATER CONTENT (%) -  $w_0$  (INITIAL) 61.2  $w_0$  (FINAL) 64.9  
 SATURATION (%) -  $S_u$  (INITIAL) 93  $S_u$  (FINAL) 96  
 POROSITY 0.623 SPECIFIC GRAVITY 2.60  
 DESCRIPTION GRAY GREEN FINE SANDY PLASTIC CLAY WITH FINE SAND SEAMS  
 N=11




HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

CONSOLIDATION TEST RESULTS

FIGURE 2A-9 (SHEET 4 OF 4)



ACAD



HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2



COMPARISON OF CONSOLIDATION  
TEST CURVES FOR HNP-1 AND HNP-2

FIGURE 2A-10





"UNDERSOIL", c 2.4 ksf  
 ANGLE OF SHEAR RESISTANCE  $\phi$  7.5°  
 UNIT WEIGHT,  $\gamma$  134.9 pcf  
 WATER CONTENT, w 12.8  
 VOID RATIO, e  
 Saturation 82%  
 101' Standard Proctor  
 ba

Brown silty clayey medium to fine sand  
**TRIAxIAL SHEAR TEST**  
 BORING NO. B-11 SAMPLE NO. 3034  
 ELEV. OR DEPTH 133.5 JOG NO. 3034  
 LAW ENGINEERING TESTING CO.





"UNDERSOIL", c 1.5 ksf  
 ANGLE OF SHEAR RESISTANCE  $\phi$  19.0°  
 UNIT WEIGHT,  $\gamma$  135.0 pcf  
 WATER CONTENT, w 10°  
 VOID RATIO, e .37  
 Saturation 76%  
 100' Standard Proctor  
 ba

Red brown silty clayey medium to fine sand  
**TRIAxIAL SHEAR TEST**  
 BORING NO. B-11 SAMPLE NO. 3035  
 ELEV. OR DEPTH E1 123 JOG NO. 3035  
 LAW ENGINEERING TESTING CO.





"UNDERSOIL", c 1.3 ksf  
 ANGLE OF SHEAR RESISTANCE  $\phi$  4.0°  
 UNIT WEIGHT,  $\gamma$  127.2 pcf  
 WATER CONTENT, w 15.2  
 VOID RATIO, e .5  
 Saturation 81%  
 100% Standard Proctor  
 ba

Light brown silty clayey medium to fine sand  
**TRIAxIAL SHEAR TEST**  
 BORING NO. B-11 SAMPLE NO. 3036  
 ELEV. OR DEPTH 116 JOG NO. 3036  
 LAW ENGINEERING TESTING CO.





"UNDERSOIL", c 1.1 ksf,  $C_u = 0.9$  ksf  
 ANGLE OF SHEAR RESISTANCE  $\phi$  3.0°  
 UNIT WEIGHT,  $\gamma$  117.6  
 WATER CONTENT, w 27.8  
 VOID RATIO, e 0.70  
 Retention 96%

Fine Light Gray Clayey Silty Medium to Fine Sand With A Fine Gravelly, Curvy Sand Seam  
**TRIAxIAL SHEAR TEST**  
 BORING NO. B-441 SAMPLE NO. 3037  
 DEPTH 87'-89" JOG NO. 3036  
 E1 55  
 LAW ENGINEERING TESTING CO.



"UNDERSOIL", c 1.75 ksf,  $C_u = .55$  ksf  
 ANGLE OF SHEAR RESISTANCE  $\phi$  11°  
 UNIT WEIGHT,  $\gamma$  116.2  
 WATER CONTENT, w 33.8  
 VOID RATIO, e 0.81  
 Retention 96%

Fine Light Gray Clayey Silty Medium to Fine Sand  
**TRIAxIAL SHEAR TEST**  
 BORING NO. B-444 SAMPLE NO. 3038  
 DEPTH 77'-79" JOG NO. 3036  
 E1 67  
 LAW ENGINEERING TESTING CO.



"UNDERSOIL", c 1.6 ksf  
 ANGLE OF SHEAR RESISTANCE  $\phi$  0.0°  
 UNIT WEIGHT,  $\gamma$  107.2  
 WATER CONTENT, w 43.8  
 VOID RATIO, e 1.21  
 Retention 96%

Fine Light Gray Very Sandy Silty Clay With Some Gray Fine Sand Silty Clay Inclusions  
**TRIAxIAL SHEAR TEST**  
 BORING NO. B-444 SAMPLE NO. 3039  
 DEPTH 25'-27" JOG NO. 3036  
 E1 47  
 LAW ENGINEERING TESTING CO.



HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TRIAxIAL SHEAR TEST RESULTS



FIGURE 2A-11 (SHEET 1 OF 5)



COHESION,  $c = 0.0$  ksf  
 ANGLE OF SHEAR RESISTANCE  $\phi = 20.5$   
 UNIT WEIGHT,  $\gamma = 98.3$  pcf  
 WATER CONTENT,  $w =$   
 VOID RATIO,  $e =$   
 Saturation 90%

Very Dense Gray Clayey fine to Medium Sand, Partially Cemented



**TRIAXIAL SHEAR TEST**  
 SOILS NO. R-446 SAMPLE NO. UD  
 DEPTH 51-56 JOB NO. 2056  
 LAW ENGINEERING TESTING CO.



COHESION,  $c = 1.9$  ksf,  $C_1 = 0.5$  ksf  
 ANGLE OF SHEAR RESISTANCE  $\phi = 6.5$   
 UNIT WEIGHT,  $\gamma = 107.8$   
 WATER CONTENT,  $w = 37.9$   
 VOID RATIO,  $e = 1.10$   
 Saturation 90%

Firm Light Gray Clayey Silty Medium to Fine Sand With Some Cemented Clay Inclusions



**TRIAXIAL SHEAR TEST**  
 SOILS NO. R-446 SAMPLE NO. UD  
 DEPTH 57-59 JOB NO. 2056  
 EL. 55  
 LAW ENGINEERING TESTING CO.



COHESION,  $c = 0.8$  ksf  
 ANGLE OF SHEAR RESISTANCE  $\phi = 9.5$   
 UNIT WEIGHT,  $\gamma = 117.6$   
 WATER CONTENT,  $w = 26.2$   
 VOID RATIO,  $e = 0.79$   
 Saturation 89%

Light Gray Slightly Silty Slightly Clayey Medium to Fine Sand With Some Clay Inclusions



**TRIAXIAL SHEAR TEST**  
 SOILS NO. R-448 SAMPLE NO. UD-15  
 DEPTH 70-74 JOB NO. 2056  
 EL. 70  
 LAW ENGINEERING TESTING CO.



COHESION,  $c = 0.9$  ksf  
 ANGLE OF SHEAR RESISTANCE  $\phi = 12.5$   
 UNIT WEIGHT,  $\gamma = 116.3$   
 WATER CONTENT,  $w = 31.3$   
 VOID RATIO,  $e = 0.86$   
 Saturation 97%

Light Gray Slightly Clayey Slightly Silty Medium to Fine Sand



**TRIAXIAL SHEAR TEST**  
 SOILS NO. R-449-C SAMPLE NO. UD  
 DEPTH 28-31 JOB NO. 2056  
 EL. 60  
 LAW ENGINEERING TESTING CO.



COHESION,  $c = 3.7$  ksf,  $C_1 = 0.25$  ksf  
 ANGLE OF SHEAR RESISTANCE  $\phi = 16.5$   
 UNIT WEIGHT,  $\gamma = 104.6$   
 WATER CONTENT,  $w = 44.8$   
 VOID RATIO,  $e = 1.20$   
 SATURATION 95

Light Gray Clayey Silty Fine Sand (Partially Cemented) With Some Clay Inclusions

**TRIAXIAL SHEAR TEST**  
 SOILS NO. R-449-B SAMPLE NO. UD-6  
 DEPTH 98-100 JOB NO. 2056  
 EL. 41  
 LAW ENGINEERING TESTING CO.



COHESION,  $c = 2.75$  ksf,  $C_1 = 1.5$  ksf  
 ANGLE OF SHEAR RESISTANCE  $\phi = 11$   
 UNIT WEIGHT,  $\gamma = 116.8$   
 WATER CONTENT,  $w = 32.0$   
 VOID RATIO,  $e = 0.81$   
 SATURATION 96%

Firm Light Gray Clayey Silty Medium to Fine Sand with some Clay Inclusions

**TRIAXIAL SHEAR TEST**  
 SOILS NO. R-451 SAMPLE NO. UD  
 DEPTH 72-74 JOB NO. 2056  
 LAW ENGINEERING TESTING CO.



HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2



TRIAXIAL SHEAR TEST RESULTS

FIGURE 2A-11 (SHEET 2 OF 5)





"COHESION",  $c = 1.2 \text{ kef}$   
 ANGLE OF SHEAR RESISTANCE  $\phi = 16.0^\circ$   
 UNIT WEIGHT,  $\gamma = 129.6$   
 WATER CONTENT,  $w = 16.6$   
 VOID RATIO,  $e = 0.52$   
 Saturation 87%

Light Gray, Red-Brown, and Yellowish Brown Silty Clayey Medium To Fine Sand  
 Inconsolidated Undrained  
**TRIAXIAL SHEAR TEST**  
 BORING NO. R-452-B SAMPLE NO. 10-1  
 DEPTH 8-11' JOB NO. 5036  
 EL. 127  
 LAW ENGINEERING TESTING CO.





"COHESION",  $c = 1.85 \text{ kef}$ ,  $C_1 = 1.05 \text{ kef}$   
 ANGLE OF SHEAR RESISTANCE  $\phi = 9.5^\circ$   
 UNIT WEIGHT,  $\gamma = 105.8$   
 WATER CONTENT,  $w = 46.7$   
 VOID RATIO,  $e = 1.26$   
 Saturation 94%

Quick  
 Firm Light Gray Clayey Silty Medium To Fine Sand With Some Cemented Clay Inclusions  
**TRIAXIAL SHEAR TEST**  
 BORING NO. R-452 SAMPLE NO. 10  
 DEPTH 15'-18.2' JOB NO. 5038  
 EL. 51  
 LAW ENGINEERING TESTING CO.





"COHESION",  $c = 0.2$   
 ANGLE OF SHEAR RESISTANCE  $\phi = 59^\circ$   
 UNIT WEIGHT,  $\gamma = 138.9$   
 WATER CONTENT,  $w =$   
 VOID RATIO,  $e =$   
 Saturation 94%

Very Dense Tan and Gray Clayey Silt Sand, Partially Cemented  
**TRIAXIAL SHEAR TEST**  
 BORING NO. B-456 SAMPLE NO. 10-1  
 DEPTH 23'-25' JOB NO. 5038  
 EL. 44  
 LAW ENGINEERING TESTING CO.





"COHESION",  $c = 3.3 \text{ kef}$ ,  $C_1 = 1.6 \text{ kef}$   
 ANGLE OF SHEAR RESISTANCE  $\phi = 3.0^\circ$   
 UNIT WEIGHT,  $\gamma = 93.2$   
 WATER CONTENT,  $w = 77.7$   
 VOID RATIO,  $e = 1.44$   
 Saturation 100%

Stiff Light Gray Slightly Fine Sandy Silty Clay With Fine Sand Seams  
 Quick  
**TRIAXIAL SHEAR TEST**  
 BORING NO. B-456 SAMPLE NO. 10  
 DEPTH 12'-14.1' JOB NO. 5036  
 EL. 53  
 LAW ENGINEERING TESTING CO.



"COHESION",  $c = 2.0 \text{ kef}$ ,  $C_1 = 1.2 \text{ kef}$   
 ANGLE OF SHEAR RESISTANCE  $\phi = 0.0^\circ$   
 UNIT WEIGHT,  $\gamma = 110.2$   
 WATER CONTENT,  $w = 39.4$   
 VOID RATIO,  $e = 1.07$   
 Saturation 96%

Quick  
 Firm Light Gray Clayey Silty Fine Sand With Gray Silty Clay Inclusions  
**TRIAXIAL SHEAR TEST**  
 BORING NO. B-456 SAMPLE NO. 10  
 DEPTH 16'-16.6' JOB NO. 5036  
 EL. 51  
 LAW ENGINEERING TESTING CO.



"COHESION",  $c = 1.6 \text{ kef}$ ,  $C_1 = 1.1 \text{ kef}$   
 ANGLE OF SHEAR RESISTANCE  $\phi = 11.5^\circ$   
 UNIT WEIGHT,  $\gamma = 118.8$   
 WATER CONTENT,  $w = 39.2$   
 VOID RATIO,  $e = 0.81$   
 Saturation 96%

Light Gray Slightly Clayey Slightly Silty Fine Sand With Some Greenish Gray Silty Clay  
**TRIAXIAL SHEAR TEST**  
 BORING NO. B-456 SAMPLE NO. 10-1  
 DEPTH 26'-30' JOB NO. 5036  
 EL. 44  
 LAW ENGINEERING TESTING CO.

HISTORICAL  
 REV 19 7/01





SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TRIAXIAL SHEAR TEST RESULTS

FIGURE 2A-11 (SHEET 3 OF 5)







MOHR DIAGRAMS -  $\phi$

STRESS-STRAIN CURVES

"COHESION", c 1.2 kef,  $C_u = 0.284$   
 ANGLE OF SHEAR RESISTANCE  $\phi = 8.0^\circ$   
 UNIT WEIGHT,  $\gamma = 102.0$   
 WATER CONTENT, w 56.6  
 VOID RATIO, e 1.48  
 Saturation 97%

Firm Light Gray Clayey Silty Fine Sand  
 With Gray Silty Clay Inclusions  
 Quick  
**TRIAXIAL SHEAR TEST**  
 BORING NO. 3-458 SAMPLE NO. 10  
 DEPTH 22'-78" AND NO. 303A  
 EL. 41  
 LAW ENGINEERING TESTING CO.





MOHR DIAGRAMS -  $\phi$

STRESS-STRAIN CURVES

"COHESION", c 2.8 kef,  $C_u = 0.8 kef$   
 ANGLE OF SHEAR RESISTANCE  $\phi = 10^\circ$   
 UNIT WEIGHT,  $\gamma = 121.0$   
 WATER CONTENT, w 24.8  
 VOID RATIO, e 0.71  
 Saturation 93%

Firm Light Gray Clayey Medium To  
 Fine Sand  
 Quick  
**TRIAXIAL SHEAR TEST**  
 BORING NO. T-460 SAMPLE NO. 10  
 DEPTH 22'-74" AND NO. 303A  
 EL. 70  
 LAW ENGINEERING TESTING CO.





MOHR DIAGRAMS -  $\phi$

STRESS-STRAIN CURVES

"COHESION", c 1.857  
 ANGLE OF SHEAR RESISTANCE  $\phi = 3.3^\circ$   
 UNIT WEIGHT,  $\gamma = 122.3$   
 WATER CONTENT, w 16.4  
 VOID RATIO, e 0.50  
 Saturation 87%

Light Gray Medium To Fine Very Stady  
 Silty Clay  
 Unconsolidated Undrained  
**TRIAXIAL SHEAR TEST**  
 BORING NO. J-464 SAMPLE NO. 10-1  
 DEPTH 18'-30" AND NO. 303A  
 EL. 122  
 LAW ENGINEERING TESTING CO.





MOHR DIAGRAMS -  $\phi$

STRESS-STRAIN CURVES

"COHESION", c 2000 PSF  
 ANGLE OF SHEAR RESISTANCE  $\phi = 22^\circ$   
 UNIT WEIGHT,  $\gamma = 103$  (WET), 72 DRY  
 WATER CONTENT, w 33.5  
 VOID RATIO, e 1.31  
 SATURATION 87.5  
 N-16

GRAY GREEN FINE SANDY  
 PLASTIC CLAY WITH FINE SAND  
 SEAMS  
 CONSOLIDATED UNDRAINED  
**TRIAXIAL SHEAR TEST**  
 BORING NO. RFI-3 SAMPLE NO. 10  
 OR DEPTH 6.0-7.5 JOB NO. 5006  
 LAW ENGINEERING TESTING CO.





MOHR DIAGRAMS -  $\phi$

STRESS-STRAIN CURVES

"COHESION", c 1700 PSF  
 ANGLE OF SHEAR RESISTANCE  $\phi = 19^\circ$   
 UNIT WEIGHT,  $\gamma = 105$  (WET), 79 (DRY)  
 WATER CONTENT, w 32.9  
 VOID RATIO, e 1.08  
 SATURATION 80%  
 N-16

GREEN GRAY FINE SAND  
 WITH CLAY INCLUSIONS  
 CONSOLIDATED UNDRAINED  
**TRIAXIAL SHEAR TEST**  
 BORING NO. RFI-6 SAMPLE NO. 10  
 DEPTH 23'-25" JOB NO. 5016  
 LAW ENGINEERING TESTING CO.



MOHR DIAGRAMS -  $\phi$

STRESS-STRAIN CURVES

COHESION, c 1000 psf  
 ANGLE OF SHEAR RESISTANCE  $\phi = 24^\circ$   
 UNIT WEIGHT,  $\gamma = 103.0$  psf  
 WATER CONTENT, w 21.4%  
 VOID RATIO, e 0.589

**TRIAXIAL SHEAR TEST**  
 BORING NO. 2001 SAMPLE NO. UD-1  
 ELEV. OR DEPTH. 10'-12" JOB NO. 5056  
 LAW ENGINEERING TESTING CO.



HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2



TRIAXIAL SHEAR TEST RESULTS

FIGURE 2A-11 (SHEET 4 OF 5)





COHESION, C 1000 psf  
 ANGLE OF SHEAR RESISTANCE,  $\phi$  24°  
 UNIT WEIGHT,  $\gamma$  112.3 pcf  
 WATER CONTENT, w 15.7%  
 VOID RATIO, e 0.486

**TRIAxIAL SHEAR TEST**  
 BORING NO. 2001 SAMPLE NO. UD-2  
 ELEV. OR DEPTH 10'-22" JOB NO. 25056  
 LAW ENGINEERING TESTING CO.





COHESION, C 0.000 psf  
 ANGLE OF SHEAR RESISTANCE,  $\phi$  40°  
 UNIT WEIGHT,  $\gamma$  106.1 pcf 111.7 pcf  
 WATER CONTENT, w 19.2% 14.5%  
 VOID RATIO, e 0.576 0.497

**TRIAxIAL SHEAR TEST**  
 BORING NO. 2001 SAMPLE NO. UD-4  
 ELEV. OR DEPTH 10'-10" 10'-12" JOB NO. 25056  
 LAW ENGINEERING TESTING CO.





COHESION, C 1500 psf  
 ANGLE OF SHEAR RESISTANCE,  $\phi$  16°  
 UNIT WEIGHT,  $\gamma$  107.7 pcf  
 WATER CONTENT, w 19.4%  
 VOID RATIO, e 0.566

**TRIAxIAL SHEAR TEST**  
 BORING NO. 2001 SAMPLE NO. UD-5  
 ELEV. OR DEPTH 10'-12" JOB NO. 25056  
 LAW ENGINEERING TESTING CO.





COHESION, C 300 psf  
 ANGLE OF SHEAR RESISTANCE,  $\phi$  20°  
 UNIT WEIGHT,  $\gamma$  62.6 pcf  
 WATER CONTENT, w 49.2%  
 VOID RATIO, e 1.45%

**TRIAxIAL SHEAR TEST**  
 BORING NO. 2001 SAMPLE NO. UD-9  
 ELEV. OR DEPTH 73'-77.5" JOB NO. 25056  
 LAW ENGINEERING TESTING CO.



COHESION, C 900 psf  
 ANGLE OF SHEAR RESISTANCE,  $\phi$  10°  
 UNIT WEIGHT,  $\gamma$  72.7 pcf  
 WATER CONTENT, w 42.5%  
 VOID RATIO, e 1.215

**TRIAxIAL SHEAR TEST**  
 BORING NO. 2001 SAMPLE NO. UD-10  
 ELEV. OR DEPTH 80'-82.5" JOB NO. 25056  
 LAW ENGINEERING TESTING CO.



COHESION, C 2500 psf  
 ANGLE OF SHEAR RESISTANCE,  $\phi$  26°  
 UNIT WEIGHT,  $\gamma$  82.4 pcf  
 WATER CONTENT, w 3.2%  
 VOID RATIO, e 1.008

**TRIAxIAL SHEAR TEST**  
 BORING NO. 2001 SAMPLE NO. UD-11  
 ELEV. OR DEPTH 107'-102.5" JOB NO. 25056  
 LAW ENGINEERING TESTING CO.


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TRIAxIAL SHEAR TEST RESULTS

FIGURE 2A-11 (SHEET 5 OF 5)



LEGEND

- △ NO LIQUEFACTION AT 100 CYCLES
- NO LIQUEFACTION AT 160 CYCLES
- $\sigma_d = .580 \bar{\sigma}_v$  AT 10 CYCLES

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

INITIAL-TO-PARTIAL LIQUEFACTION

FIGURE 2A-12



LEGEND

- △ NO LIQUEFACTION AT 100 CYCLES
- NO LIQUEFACTION AT 160 CYCLES
- $\sigma_d = .660 \sigma_c$  AT 10 CYCLES

ACAD

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

COMPLETE LIQUEFACTION


FIGURE 2A-13

INTAKE FOUNDATION INSPECTION

BORINGS INCLUDED IN THIS ANALYSIS:

- IFI-1
- IFI-2
- IFI-3
- IFI-4
- IFI-5
- IFI-6

TOTAL "N" VALUES 50  
 "N" VALUE OF LOWEST QUINTILE= 20




INTAKE FOUNDATION INVESTIGATION (RELOCATED)

BORINGS INCLUDED IN THIS ANALYSIS:

- B-457    B-479
- B-476    B-580
- B-477    B-586
- B-478    B-603

"N" VALUES BETWEEN ELEVATION 55 AND ELEVATION 15

TOTAL "N" VALUES 64  
 "N" VALUE OF LOWEST QUINTILE= 25



HISTORICAL

REV 19 7/01


ACAD




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

INTAKE FOUNDATION INSPECTION

FIGURE 2A-14



**AFTER EXCAVATION**  
 TOTAL "N" VALUES - 53  
 "N" VALUE, LOWEST QUINTILE - 13



**BEFORE EXCAVATION**  
 TOTAL "N" VALUES - 254  
 "N" VALUE, LOWEST QUINTILE - 31

ACAD


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2


HNP-1 HISTOGRAMS BEFORE AND AFTER EXCAVATION

FIGURE 2A-15



**AFTER EXCAVATION**  
 TOTAL "N" VALUES - 86  
 "N" VALUE OF LOWEST QUINTILE = 1.5

- BORINGS INCLUDED IN THIS ANALYSIS
- RFI-1
  - RFI-2
  - RFI-3
  - RFI-4
  - RFI-5
  - RFI-6
  - RFI-7
  - RFI-8
  - RFI-9
  - RFI-10



**BEFORE EXCAVATION**  
 TOTAL "N" VALUES - 241  
 "N" VALUE OF LOWEST QUINTILE = 24

- BORINGS INCLUDED IN THIS ANALYSIS:  
 "N" VALUES BELOW ELEVATION 75
- B-401
  - R-587
  - R-588
  - R-589
  - R-590
  - R-591
  - R-592
  - R-593
  - R-594
  - T-595
  - T-596
  - T-597
  - T-598
  - T-599
  - T-600

ACAD

*HISTORICAL*  
 REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

HNP-2 HISTOGRAMS BEFORE  
 AND AFTER EXCAVATION

FIGURE 2A-16

# CONTROL BUILDING



**BENCHMARK NUMBERS AND LOCATIONS**

(Located on EL. 130' Floor)

- No. 9 - NE - 10'-2" West of TA, 1'-3" North of T10
- No. 10 - SE - 5'-3 1/2" West of TA, 4'-0" North of T13
- No. 11 - NW - 4'-11" East of TH, 4'-5" South of T10
- No. 12 - SW - 2'-10" East of TI, 7'-11" South of T12

ACAD 22A1701

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

HNP-2 BUILDING SETTLEMENT

FIGURE 2A-17 (SHEET 1 OF 7)



# REACTOR BUILDING UNIT 2



## BENCHMARK NUMBERS AND LOCATIONS

(Located on EL. 130' Floor)

- No. 1 - NE - 24'-2 3/8" West of RL, on R15
- No. 2 - SE - 15'-0" East of RL, 14'-3 1/2" South of R24
- No. 3 - NW - 13'-0" West of RA, 13'-7" South of R14
- No. 4 - SW - 24'-8" East of RA, on R23

ACAD 22A1702

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

HNP-2 BUILDING SETTLEMENT

FIGURE 2A-17 (SHEET 2 OF 7)

# DIESEL GENERATOR BUILDING



**BENCHMARK NUMBERS AND LOCATIONS**

(Located on Exterior Walls of Building)

- No. 17 - NE - East Wall, 0'-11" South of NE Corner
- No. 18 - SE - East Wall, 0'-1" North of SE Corner
- No. 19 - NW - North Wall, 1'-1" East of NW Corner
- No. 20 - SW - South Wall, 0'-11" East of SW Corner

ACAD 22A1703

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

HNP-2 BUILDING SETTLEMENT

FIGURE 2A-17 (SHEET 3 OF 7)

# OFFGAS STACK



**BENCHMARK NUMBERS AND LOCATIONS**

(Located on EL. 120' Floor)

- No. 21 - NE - 130 Degree Azimuth
- No. 22 - S - 245 Degree Azimuth
- No. 23 - W - 0 Degree Azimuth

ACAD 22A1704

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

HNP-2 BUILDING SETTLEMENT

FIGURE 2A-17 (SHEET 4 OF 7)

# RADWASTE BUILDING - UNIT 2



**BENCHMARK NUMBERS AND LOCATIONS**  
 (Located on EL. 132'-4" Floor)

- No. 5 - NE - 1'-3" East of BD, 3'-0" South of B1
- No. 6 - SE - 0'-9" West of BJ, 5'-6" North of B11
- No. 7 - NW - 2'-6" West of BA, 2'-6" South of B1
- No. 8 - SW - 7'-3" West of BC, 0'-1" North of B11

ACAD 22A1705

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

HNP-2 BUILDING SETTLEMENT

FIGURE 2A-17 (SHEET 5 OF 7)

# TURBINE BUILDING - UNIT 2



**NOTES:**  
 1. NW MARKER INACCESSABLE SINCE 6-27-79.

**BENCHMARK NUMBERS AND LOCATIONS**

- (Located on EL. 130' Floor)
- No. 13 - NE - 10'-2" West of TA, 1'-10" North of T15
  - No. 14 - SE - 13'-2" West of TA, 0'-3" North of T23
  - No. 15 - NW - 2'-5" West of TH, 3'-7 1/2" South of T15
  - No. 16 - SW - 2'-7" East of TI, 17'-10" North of T23

ACAD 22A1706

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

HNP-2 BUILDING SETTLEMENT

FIGURE 2A-17 (SHEET 5 OF 7)

# INTAKE STRUCTURE



**BENCHMARK NUMBERS AND LOCATIONS**  
 ( Located at Building Corners )  
 No. 24 - NE - 1'-3" South  
 No. 25 - SE - 1'-0" West, 1'-0" North  
 No. 26 - NW - 1'-3" South  
 No. 27 - SW - 1'-0" East, 1'-0" North

ACAD 22A1707

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

HNP-2 BUILDING SETTLEMENT

FIGURE 2A-17 (SHEET 7 OF 7)

# REACTOR BUILDING - UNIT 1



## BENCHMARK NUMBERS AND LOCATIONS

(Located on EL. 130' Floor)

- No. 28 - NE - 23'-0" West of RL, on R3
- No. 29 - SE - 23'-11" West of RL, 18'-5" North of R13
- No. 30 - NW - 11'-5" East of RA, 6'-0" South of R2  
(Southeast Anchor for Cable Tray Support 1U-7B)
- No. 31 - SW - 23'-11" East of RA, on R11

ACAD 22A1801

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

HNP-1 BUILDING SETTLEMENT

FIGURE 2A-18 (SHEET 1 OF 3)

# RADWASTE BUILDING - UNIT 1



**BENCHMARK NUMBERS AND LOCATIONS**

(Located on EL. 132'-4" Floor)

- No. 32 - NE - 7'-8" West of WC, 6'-5 1/2" South of W2
- No. 33 - SE - 9'-9 1/2" West of WC, 4'-8 3/4" North of W4
- No. 34 - NW - 2'-5 1/2" East of WA, 7'-4 1/2" South of W2
- No. 35 - SW - 3'-0" East of WA, 1'-0" North of W4

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

HNP-1 BUILDING SETTLEMENT

FIGURE 2A-18 (SHEET 2 OF 3)



# TURBINE BUILDING - UNIT 1



**BENCHMARK NUMBERS AND LOCATIONS**

- (Located on EL. 130' Floor)
- No. 36 - NE - 7'-9" West of TA, 14'-5" South of T2
  - No. 37 - SE - 10'-2" West of TA, 0'-2 1/4" South of T9
  - No. 38 - NW - 5'-3 1/2" East of TH, 15'-0" South of T1
  - No. 39 - SW - 7'-8 1/2" East of TI, 3'-2 1/2" North of T9

**NOTES:**  
 1. MARKER INACCESSIBLE, FROM 7-10-78 TO 1-24-79 AND SINCE 1-16-80.

ACAD 22A1803


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

HNP-1 BUILDING SETTLEMENT

FIGURE 2A-18 (SHEET 3 OF 3)



ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

AVERAGE ELASTIC MODULI

FIGURE 2A-19



HISTORICAL  
REV 19 7/01


ACAD




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

ELASTIC MODULI – SURFICIAL HAWTHORN

FIGURE 2A-20



DENSE SANDS  
(CEMENTED ZONE)



CEMENTED SANDS  
(CEMENTED ZONE)

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

ELASTIC MODULI - UPPER HAWTHORN

FIGURE 2A-21



ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

ELASTIC MODULI – MIDDLE HAWTHORN

FIGURE 2A-22 (SHEET 1 OF 2)



ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

ELASTIC MODULI – MIDDLE HAWTHORN

FIGURE 2A-22 (SHEET 2 OF 2)



ACAD

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

ELASTIC MODULI – LOWER HAWTHORN

FIGURE 2A-23

**SAFETY FACTORS WITH  
RESPECT TO MOMENTARY LIQUEFACTION**

A. Corrected for 60 percent Relative Density

| Piezometric Level            | Location See Figure |      |      |      |      |
|------------------------------|---------------------|------|------|------|------|
|                              | Yard                | B    | D    | F    | K    |
| Max. Observed (77)           | 2.12                | 2.36 | 2.36 | 2.20 | 2.40 |
| 10 Year Flood (85)           | 1.99                | 2.23 | 2.22 | 2.08 | 2.28 |
| 1000 Year Flood (93)         | 1.84                | 2.09 | 2.08 | 1.90 | 2.10 |
| Max. Theoretical Flood (105) | 1.66                | 1.90 | 1.90 | 1.73 | 1.94 |

B. Based on Test of Loosest Materials - Uncorrected for Relative Density

| Piezometric Level            | Location See Figure |      |      |      |      |
|------------------------------|---------------------|------|------|------|------|
|                              | Yard                | B    | D    | F    | K    |
| Max. Observed (77)           | 1.76                | 1.96 | 1.96 | 1.83 | 2.00 |
| 10 Year Flood (85)           | 1.64                | 1.85 | 1.84 | 1.71 | 1.89 |
| 1000 Year Flood (93)         | 1.53                | 1.73 | 1.73 | 1.57 | 1.74 |
| Max. Theoretical Flood (105) | 1.37                | 1.58 | 1.57 | 1.44 | 1.61 |


**SAFETY FACTOR WITH  
RESPECT TO COMPLETE LIQUEFACTION**

A. Corrected for 60 percent Relative Density

| Piezometric Level            | Location See Figure |      |      |      |      |
|------------------------------|---------------------|------|------|------|------|
|                              | Yard                | B    | D    | F    | K    |
| Max. Observed (77)           | 2.40                | 2.69 | 2.68 | 2.50 | 2.74 |
| 10 Year Flood (85)           | 2.25                | 2.53 | 2.52 | 2.34 | 2.58 |
| 1000 Year Flood (93)         | 2.09                | 2.38 | 2.37 | 2.16 | 2.39 |
| Max. Theoretical Flood (105) | 1.87                | 2.16 | 2.15 | 1.97 | 2.20 |

B. Based on Tests of Loosest Material - Uncorrected for Relative Density

| Piezometric Level            | Location Figure |      |      |      |      |
|------------------------------|-----------------|------|------|------|------|
|                              | Yard            | B    | D    | F    | K    |
| Max. Observed (77)           | 2.00            | 2.22 | 2.22 | 2.07 | 2.26 |
| 10 Year Flood (85)           | 1.88            | 2.10 | 2.09 | 1.96 | 2.15 |
| 1000 Year Flood (93)         | 1.74            | 1.97 | 1.97 | 1.79 | 1.98 |
| Max. Theoretical Flood (105) | 1.57            | 1.79 | 1.78 | 1.64 | 1.82 |



*HISTORICAL*  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

LIQUEFACTION STUDY

FIGURE 2A-24





ALLOWABLE SLOPE  $\theta = \frac{d}{h}$  (FOR SMALL ANGLES)

AND  $d = \frac{3'' - (S_1 + S_2)}{2}$

- WHERE:
- $\theta$  = ALLOWABLE SLOPE OF THE BUILDING
  - $d$  = ALLOWABLE HORIZONTAL COMPONENT OF TILT TOWARDS AN ADJACENT BUILDING
  - $h$  = HEIGHT OF BUILDING
  - $S_1$  = OBE DEFLECTION OF BUILDING AT TOP
  - $S_2$  = OBE DEFLECTION OF ADJACENT BUILDING AT SAME ELEVATION

ACAD

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

ALLOWABLE SETTLEMENT PROFILE SLOPE  
CALCULATION PROCEDURE



FIGURE 2A-26

**KEY**

- SOIL 1 - SANDY SILTY CLAY AND CLAYEY COARSE TO FINE SAND
- SOIL 2 - CLAYEY SILTY COARSE TO FINE SAND (CEMENTED)
- SOIL 3 - SILTY FINE SAND, MEDIUM TO FINE SAND AND CLAYEY SILTY FINE SAND
- SOIL 4 - CLAYEY SILTY FINE SAND AND SILTY FINE SAND
- SOIL 5 - SLIGHTLY CLAYEY FINE SAND

**SOIL PROPERTY TABLE**

| SOIL | TOTAL STRENGTH          |                      |         |
|------|-------------------------|----------------------|---------|
|      | $\gamma_T = \text{PCF}$ | $\phi - \text{DEG.}$ | C - PSF |
| 1    | 135                     | 24                   | 1000    |
| 2    | 130                     | 40                   | 5000    |
| 3    | 130                     | 36                   | 1500    |
| 4    | 110                     | 20                   | 300     |
| 5    | 115                     | 25                   | 100     |




HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

PSEUDOSTATIC STABILITY ANALYSIS OF  
RIVER BLUFF FOR DBE

FIGURE 2A-27



ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

CYCLIC STRENGTH FOR SOILS AT RIVER BLUFF

FIGURE 2A-28



Chamber pressure 6000 psf  
 Unit dry weight 95.1 pcf  
 Water content 27.7%

HISTORICAL  
 REV 19 7/01


ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

CYCLIC TRIAXIAL TEST BORING NO. 2001  
 SAMPLE NO. UD-6 TEST SAMPLE A

FIGURE 2A-29 (SHEET 1 OF 13)



Chamber pressure      600 psf  
 Unit dry weight      94.2 pcf  
 Water content          26.8%

*HISTORICAL*  
**REV 19 7/01**


ACAD



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**CYCLIC TRIAXIAL TEST BORING NO. 2001**  
**SAMPLE NO. UD-6 TEST SAMPLE A**

**FIGURE 2A-29 (SHEET 2 OF 13)**



Chamber pressure      6000 osf  
 Unit dry weight      91.3 pcf  
 Water content      25.0%

HISTORICAL  
 REV 19 7/01


ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

CYCLIC TRIAXIAL TEST BORING NO. 2001  
 SAMPLE NO. UD-6 TEST SAMPLE A

FIGURE 2A-29 (SHEET 3 OF 13)



Chamber pressure 6000 psf  
 Unit dry weight 94.5 pcf  
 Water content 28.9%

HISTORICAL  
 REV 19 7/01


ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

CYCLIC TRIAXIAL TEST BORING NO. 2001  
 SAMPLE NO. UD-6 TEST SAMPLE A

FIGURE 2A-29 (SHEET 4 OF 13)



Chamber pressure    6000 psf  
 Unit dry weight    86.2 pcf  
 Water content       33.3%

HISTORICAL  
 REV 19 7/01

ACAD




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

CYCLIC TRIAXIAL TEST BORING NO. 2001  
 SAMPLE NO. UD-6 TEST SAMPLE A

FIGURE 2A-29 (SHEET 5 OF 13)





Chamber pressure 6000 psf  
 Unit dry weight 90.9 pcf  
 Water content 31.8%

HISTORICAL  
 REV 19 7/01


ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

CYCLIC TRIAXIAL TEST BORING NO. 2001  
 SAMPLE NO. UD-6 TEST SAMPLE A

FIGURE 2A-29 (SHEET 6 OF 13)



Chamber pressure 6000 psf  
 Unit dry weight 76.0 pcf  
 Water content 43.1%

HISTORICAL  
 REV 19 7/01


ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

CYCLIC TRIAXIAL TEST BORING NO. 2001  
 SAMPLE NO. UD-6 TEST SAMPLE A

FIGURE 2A-29 (SHEET 7 OF 13)



Chamber pressure 6000 psf  
 Unit dry weight 74.8 pcf  
 Water content 46.3%

HISTORICAL  
 REV 19 7/01


ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

CYCLIC TRIAXIAL TEST BORING NO. 2001  
 SAMPLE NO. UD-6 TEST SAMPLE A

FIGURE 2A-29 (SHEET 8 OF 13)



Chamber pressure 6000 psf  
 Unit dry weight 101.0 pcf  
 Water content 23.5%


HISTORICAL  
 REV 19 7/01

ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2


CYCLIC TRIAXIAL TEST BORING NO. 2001  
 SAMPLE NO. UD-6 TEST SAMPLE A



Chamber pressure 6000 psf  
 Unit dry weight 92.5 pcf  
 Water content 27.4%

HISTORICAL  
 REV 19 7/01

ACAD



CHAMBER PRESSURE 6000 lb/ft<sup>2</sup>  
 UNIT DRY WEIGHT 91.3 percent  
 WATER CONTENT 27.3 percent

HISTORICAL  
 REV 19 7/01


ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

CYCLIC TRIAXIAL TEST BORING NO. 2001  
 SAMPLE NO. UD-6 TEST SAMPLE A

FIGURE 2A-29 (SHEET 11 OF 13)



Chamber pressure      6000 psf  
 Unit dry weight      69.7 pcf  
 Water content        46.2%

HISTORICAL  
 REV 19 7/01


ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

CYCLIC TRIAXIAL TEST BORING NO. 2001  
 SAMPLE NO. UD-6 TEST SAMPLE A

FIGURE 2A-29 (SHEET 12 OF 13)



Chamber pressure    6000 psf  
 Unit dry weight    71.0 pcf  
 Water content       45.4%

HISTORICAL  
 REV 19 7/01


ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

CYCLIC TRIAXIAL TEST BORING NO. 2001  
 SAMPLE NO. UD-6 TEST SAMPLE A






HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

RIVER BANK SOIL PROFILE

FIGURE 2A-30



PROFILE  
(BASED ON  
2001)

EFFECTIVE NORMAL STRESS  
K SF

SHEAR STRESS PSF

FACTOR OF SAFETY  
 $\tau_f / \tau_d$

$\tau_f$  CYCLIC SHEAR STRESS REQUIRED TO CAUSE  
10 PERCENT DOUBLE AMPLITUDE STRAIN IN  
5 UNIFORM STRESS CYCLES

$\tau_d$  EQUIVALENT AVERAGE UNIFORM SHEAR  
STRESS INDUCED BY THE DESIGN BASIS  
EARTHQUAKE

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

FACTORS OF SAFETY AGAINST LIQUEFACTION  
FOR SANDS AT RIVER BLUFF


FIGURE 2A-31

**KEY**

- SOIL 1 - SANDY SILTY CLAY AND CLAYEY COARSE TO FINE SAND
- SOIL 2 - CLAYEY SILTY COARSE TO FINE SAND (CEMENTED)
- SOIL 3 - SILTY FINE SAND, MEDIUM TO FINE SAND AND CLAYEY FINE SAND
- SOIL 4 - CLAYEY SILTY FINE SAND AND SILTY FINE SAND
- SOIL 5 - SLIGHTLY CLAYEY FINE SAND

**SOIL PROPERTY TABLE**

| SOIL | DENSITY                 | TOTAL STRESS         |                  |
|------|-------------------------|----------------------|------------------|
|      | $\gamma_T = \text{PCF}$ | $\phi - \text{DEG.}$ | $C - \text{PSF}$ |
| 1    | 135                     | 24                   | 1000             |
| 2    | 130                     | 40                   | 5000             |
| 3    | 130                     | 36                   | 1500             |
| 4    | 110                     | 0                    | 0                |
| 5    | 115                     | 0                    | 0                |



HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

ZERO STRENGTH ANALYSIS OF RIVER BLUFF


FIGURE 2A-32

**KEY**


- SOIL 1 – SANDY SILTY CLAY AND CLAYEY COARSE TO FINE SAND
- SOIL 2 – CLAYEY SILTY COARSE TO FINE SAND (CEMENTED)
- SOIL 3 – SILTY FINE SAND, MEDIUM TO FINE SAND AND CLAYEY SILTY FINE SAND
- SOIL 4 – CLAYEY SILTY FINE SAND AND SILTY FINE SAND
- SOIL 5 – SLIGHTLY CLAYEY FINE SAND

**SOIL PROPERTY TABLE**

| SOIL | DENSITY          |               | TOTAL STRENGTH |  |
|------|------------------|---------------|----------------|--|
|      | $\gamma_s$ - pcf | $\phi$ - DEG. | c - psf        |  |
| 1    | 135              | 24            | 1000           |  |
| 2    | 130              | 40            | 5000           |  |
| 3    | 130              | 36            | 1500           |  |
| 4    | 110              | 20            | 300            |  |
| 5    | 115              | 25            | 100            |  |



PSEUDOSTATIC STABILITY ANALYSIS OF RIVER BLUFF FOR DESIGN BASIS EARTHQUAKE ASSUMING EXTENDED LOOSE ZONE OF SOIL 4



HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

STABILITY ANALYSIS FOR DBE ASSUMING  
EXTENDED LOOSE ZONE OF SOIL 4


FIGURE 2A-33

**SOIL PROPERTY TABLE**

| SOIL | DENSITY<br>$\gamma_+ - \text{pcf}$ | TOTAL STRENGTH       |                  |
|------|------------------------------------|----------------------|------------------|
|      |                                    | $\phi - \text{DEG.}$ | $c - \text{psf}$ |
| 1    | 135                                | 24                   | 1000             |
| 2    | 130                                | 50                   | 0                |
| 3    | 130                                | 36                   | 1500             |
| 4    | 110                                | 20                   | 300              |
| 5    | 115                                | 25                   | 100              |

**KEY**

- SOIL 1 – SANDY SILTY CLAY AND CLAYEY COARSE TO FINE SAND
- SOIL 2 – CLAYEY SILTY COARSE TO FINE SAND (CEMENTED)
- SOIL 3 – SILTY FINE SAND, MEDIUM TO FINE SAND AND CLAYEY SILTY FINE SAND
- SOIL 4 – CLAYEY SILTY FINE SAND AND SILTY FINE SAND
- SOIL 5 – SLIGHTLY CLAYEY FINE SAND



PSEUDOSTATIC STABILITY ANALYSIS OF  
 RIVER BLUFF FOR DESIGN BASIS  
 EARTHQUAKE ASSUMING EXTENDED  
 LOOSE ZONE SOIL 4 AND REEVALUATED  
 STRENGTH FOR SOIL 2

HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

STABILITY ANALYSIS FOR DBE  
 EXTENDED LOOSE ZONE OF SOIL 4 AND  
 REEVALUATED STRENGTH FOR SOIL 2


FIGURE 2A-34

**KEY**

- SOIL 1 – SANDY SILTY CLAY AND CLAYEY COARSE TO FINE SAND
- SOIL 2 – CLAYEY SILTY COARSE TO FINE SAND (CEMENTED)
- SOIL 3 – SILTY FINE SAND, MEDIUM TO FINE SAND AND CLAYEY SILTY FINE SAND
- SOIL 4 – CLAYEY SILTY FINE SAND AND SILTY FINE SAND
- SOIL 5 – SLIGHTLY CLAYEY FINE SAND

**SOIL PROPERTY TABLE**

| SOIL | DENSITY          |               | TOTAL STRENGTH |  |
|------|------------------|---------------|----------------|--|
|      | $\gamma_s$ - pcf | $\phi$ - DEG. | c - psf        |  |
| 1    | 135              | 24            | 1000           |  |
| 2    | 130              | 40            | 5000           |  |
| 3    | 130              | 36            | 1500           |  |
| 4    | 110              | 20            | 300            |  |
| 5    | 115              | 25            | 100            |  |



PSEUDOSTATIC STABILITY ANALYSIS OF  
 RIVER BLUFF FOR DESIGN BASIS  
 EARTHQUAKE ASSUMING WATER IN  
 SLOPE AT el 122 ft


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

STABILITY ANALYSIS FOR DBE ASSUMING  
 WATER IN SLOPE AT el 122 ft

FIGURE 2A-35




HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

EARTH PRESSURE DIAGRAM

FIGURE 2A-36



NOTES:  
 1. LIMITS OF CIRCULATING WATER TUNNEL NOT SHOWN.  
 2. BACKFILL TO BE COMPACTED TO 90% OF THE RELATIVE MAXIMUM DRY DENSITY BY MODIFIED PROCTOR TEST, EXCEPT AS NOTED.  
 3. THIS AREA TO REMAIN OPEN UNTIL OFFGAS PIPING IS PLACED IN CHARGE.

HISTORICAL  
 REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

EXCAVATION PLAN AND SECTIONS

FIGURE 2A-37





SAMPLE NO. 1

MAXIMUM DRY DENSITY 126.8 LB. PER CU. FT.

OPTIMUM MOISTURE 10.6 %

METHOD OF TEST - ASTM 1557, METHOD C

TYPE MATERIAL - BROWN SILTY CLAYEY MEDIUM TO FINE SAND

SAMPLE FROM - B-411, EL. 139 1/2 - 144

FIELD MOISTURE -

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

COMPACTION TEST

FIGURE 2A-38 (SHEET 1 OF 9)



SAMPLE NO. 2

MAXIMUM DRY DENSITY 128.3 LB. PER CU. FT.

OPTIMUM MOISTURE 9.3 %

METHOD OF TEST - ASTM, D 1557, METHOD C

TYPE MATERIAL - BROWN SILTY CLAYEY MEDIUM TO FINE SAND

SAMPLE FROM - B-411, EL. 139 1/2 - 144

FIELD MOISTURE -

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

COMPACTION TEST

FIGURE 2A-38 (SHEET 2 OF 9)



SAMPLE NO. 3

MAXIMUM DRY DENSITY 130.4 LB. PER CU. FT.

OPTIMUM MOISTURE 8.2 %

METHOD OF TEST - ASTM D 1557, METHOD C

TYPE MATERIAL - RED BROWN SILTY CLAYEY MEDIUM TO FINE SAND

SAMPLE FROM - B-411, EL. 123 - 128

FIELD MOISTURE -

ACAD


*HISTORICAL*  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

COMPACTION TEST

FIGURE 2A-38 (SHEET 3 OF 9)



SAMPLE NO. 4

MAXIMUM DRY DENSITY 121.8 LB. PER CU. FT.

OPTIMUM MOISTURE 12.3 %

METHOD OF TEST - ASTM D 1557, METHOD C

TYPE MATERIAL - LIGHT BROWN MEDIUM TO FINE SANDY CLAY

SAMPLE FROM - B-411, EL. 128 - 132

FIELD MOISTURE -

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

COMPACTION TEST

FIGURE 2A-38 (SHEET 4 OF 9)



SAMPLE NO. B-405

MAXIMUM DRY DENSITY 126.6 LB. PER CU. FT.

OPTIMUM MOISTURE 8.8 %

METHOD OF TEST - ASTM D 1557, METHOD C

TYPE MATERIAL - RED BROWN SILTY CLAYEY MEDIUM TO FINE SAND

SAMPLE FROM - B-405, EL. 138 - 15 1 1/2

FIELD MOISTURE -

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

COMPACTION TEST

FIGURE 2A-38 (SHEET 5 OF 9)



SAMPLE NO. \_\_\_\_\_

MAXIMUM DRY DENSITY 130.7 LB. PER CU. FT.

OPTIMUM MOISTURE 6.7 %

METHOD OF TEST - ASTM D 1557, METHOD C

TYPE MATERIAL - BROWN CLAYEY MEDIUM TO FINE SAND

SAMPLE FROM - B-418, EL. 136 - 142

FIELD MOISTURE -

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

COMPACTION TEST

FIGURE 2A-38 (SHEET 6 OF 9)



ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

COMPACTION TEST

FIGURE 2A-38 (SHEET 7 OF 9)



SAMPLE IDENTIFICATION: # 1C + # 2, @ 3', COMBINED

MAXIMUM DRY DENSITY: 120.3 LB./CU. FT.

OPTIMUM MOISTURE CONTENT: 12.7 PERCENT

METHOD OF TEST: ASTM D 1557 (MODIFIED)

% - 200 = 40.9

LL = 34

PL = 21

PI = 13

TYPE MATERIAL: TAN BROWN VERY FINE SANDY SILTY CLAY

LOCATION: OFF SITE BORROW AREA NO. 3

IN SITU MOISTURE: # 1C = 19.6 PERCENT

# 2 = 19.1 PERCENT

ACAD

HISTORICAL

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

COMPACTION TEST

FIGURE 2A-38 (SHEET 8 OF 9)





SAMPLE IDENTIFICATION: # 2A + # 2B, @ 7', COMBINED

MAXIMUM DRY DENSITY: 118.8 LB./CU. FT.

OPTIMUM MOISTURE CONTENT: 13.2 PERCENT

METHOD OF TEST: ASTM D 1557

% - 200 = 34.7

LL = 36

PL = 19

PI = 17

TYPE MATERIAL: BROWN SILTY SLIGHTLY CLAYEY MEDIUM-FINE

LOCATION: OFF SITE BORROW AREA NO. 3

IN SITU MOISTURE: # 2A = 16.2 PERCENT

# 2B = 16.9 PERCENT

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

COMPACTION TEST

FIGURE 2A-38 (SHEET 9 OF 9)



ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

LOCATION OF ASPHALT  
PAVEMENT FAILURE

FIGURE 2A-39



EXISTING CONDITIONS

SECTION A-A (FROM FIG. 2A35)

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

EXISTING CONDITIONS SECTION A-A  
(FROM FIGURE 2A-39) SUMMARY OF  
PHASES I AND II FIELD INVESTIGATIONS

FIGURE 2A-40



NOTE:  
 FOR NOTES, LEGEND & REFERENCE DWG'S  
 SEE Dwg. H-25128.


HISTORICAL  
 REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

SUBSURFACE PROFILES

FIGURE 2A-41



PRECONSTRUCTION CONDITIONS  
SECTION A-A



HISTORICAL  
REV 19 7/01

ACAD




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

PRECONSTRUCTION CONDITIONS  
SECTION A-A (FROM FIGURE 2A-39)

FIGURE 2A-42

### CONSTRUCTION SEQUENCE:

- |                                                                                                                                                                                                         |                                                                                                                                   |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------|
| <p>① EXCAVATION MADE IN THE DRY WITH CELLULAR COFFERDAM.</p> <p>② STRUCTURE BUILT INCLUDING SOUTHERN OVERHANGS WITH COUNTERFORTS.</p> <p>③ RIVER SAND BACKFILL PLACED TO EL. 90±. (90% ASTM D-1557)</p> | <p>④ PIPES INSTALLED WITH SUPPORTS NEAR INTAKE AND IN TRENCH</p> <p>⑤ CLAYEY SAND BACKFILL PLACED TO GRADE. (90% ASTM D-1557)</p> |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------|



ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2


CONSTRUCTION PROCEDURE  
SECTION A-A (FROM FIGURE 2A-39)

FIGURE 2A-43



**KEY PLAN**

**NOTE: 1. DYNAMIC CONE PENETROMETER RESIST.  
2. CRUSHED STONE GRAVEL IN SPOON**





ACAD

HISTORICAL  
REV 19 7/01

**SOUTHERN COMPANY**  
Energy to Serve Your World®  
SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

SPT RESULTS FOR BACKFILL IN EAST SIDE OF INTAKE STRUCTURE

FIGURE 2A-44



ACAD

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2


SPT RESULTS FOR BACKFILL IN WEST SIDE  
OF INTAKE STRUCTURE

FIGURE 2A-45





**NOTE: 1. DYNAMIC CONE PENETROMETER RESIST.**




ACAD

HISTORICAL  
REV 19 7/01

**SOUTHERN NUCLEAR OPERATING COMPANY**  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

SPT RESULTS FOR BACKFILL IN SOUTH SIDE OF INTAKE STRUCTURE

FIGURE 2A-46



HISTORICAL  
REV 19 7/01


ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

HORIZONTAL PLATE LOAD TEST ON SAND  
BACKFILL. TP-1 18-in.-DIAMETER PLATE AT  
DEPTH OF 10 ft ON WEST WALL

FIGURE 2A-47



ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

HORIZONTAL PLATE LOAD TEST ON SAND  
BACKFILL, TP-1 30-in.-DIAMETER PLATE AT  
DEPTH OF 12 ft ON EAST WALL

FIGURE 2A-48



ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

VERTICAL PLATE LOAD TEST ON SAND  
BACKFILL, TP-2 12-in. PLATE  
AT DEPTH OF 10 ft

FIGURE 2A-49



ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

HORIZONTAL PLATE LOAD TEST ON SAND  
BACKFILL, TP-5 12-in. SQUARE PLATE AT  
DEPTH OF 10 ft WEST WALL

FIGURE 2A-50




ACAD

HISTORICAL  
REV 19 7/01

**SOUTHERN NUCLEAR OPERATING COMPANY**  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

HORIZONTAL PLATE LOAD TEST ON SAND  
BACKFILL, TP-5 18-in.-DIAMETER PLATE AT  
DEPTH OF 10 ft ON EAST WALL

FIGURE 2A-51



ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

7-DAY VERTICAL PLATE LOAD TEST ON  
K-KRETE 18-in.-DIAMETER PLATE SOUTH END  
OF TEST SLAB

FIGURE 2A-52



ACAD

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

7-DAY VERTICAL PLATE LOAD TEST ON  
K-KRETE 30-in.-DIAMETER PLATE SOUTH END  
OF TEST SLAB

FIGURE 2A-53





ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

APPROXIMATE ELEVATIONS OF VIRGIN  
GROUND BEFORE K-KRETE BACKFILL


FIGURE 2A-54



- REFERENCE DRAWINGS**
- H-29128 INTAKE STR. EXPLORATION PLAN SUB SURFACE PROFILES
  - H-29129 INTAKE STR. SUB SURFACE PROFILES
  - H-29130 INTAKE STR. PROPOSED EXCAVATION SUPPORT & BACKFILL CONCEPT

- LEGEND**
- EXISTING GRADE
  - EXISTING FACILITIES
  - NEW GRADE
  - /// SLOPE EMBANKMENT
  - LIMITS OF K-KRETE
  - LIMITS OF PAVEMENT
  - DITCH & FLOW
  - T/P TOP OF PAVEMENT ELEV.
  - D.I. DITCH INVERT ELEV.
  - P.V.I. POINT OF VERTICAL INTERS.
  - V.C. VERTICAL CURVE
  - P.V.C. POINT OF VERTICAL CURVATURE
  - S.I. SWALE INVERT

**FINISHED GRADING & PAVING PLAN**  
SCALE: 1"=10'



**SECTION A**  
SCALE: HORIZ. 1"=10' VERT. 1"=4'

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

INTAKE STRUCTURE  
FINISHED GRAVELING AND PAVING PLAN

FIGURE 2A-55

# BORING 102



87% % CORE RECOVERY. ( 4" VACUUM CORE BARREL ).  
BALANCE OF BORING DRILLED WITH 4" HAWTHORNE BIT.

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. 102

FIGURE 2B-1

# BORING 103



87% CORE RECOVERY. ( 4" VACUUM CORE BARREL ).  
BALANCE OF BORING DRILLED WITH 4" HAWTHORNE BIT.

ACAD

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. 103

FIGURE 2B-2

# BORING 109



BORING DRILLED WITH 4" HAWTHORNE BIT.

ACAD

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. 109

FIGURE 2B-3

# BORING I10

ELEVATION 129.5 MSL DATE DRILLED 3-5-67 TO 3-5-67



BORING DRILLED WITH 4" HAWTHORNE BIT.

ACAD

HISTORICAL  
 REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NO. 110

FIGURE 2B-4

# BORING 300



## LOG OF BORING

3/8 % CORE RECOVERY. ( 4" VACUUM CORE BARREL ). BALANCE OF BORING DRILLED WITH 1/2" HAWTHORNE BIT.

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. 300

FIGURE 2B-5

# BORING 301



87% % CORE RECOVERY, ( 4" VACUUM CORE BARREL ),  
BALANCE OF BORING DRILLED WITH 4" HAWTHORNE BIT.

## LOG OF BORING

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. 301

FIGURE 2B-6



# BORING 306



## LOG OF BORING

87% CORE RECOVERY. ( 4" VACUUM CORE BARREL ).  
BALANCE OF BORING DRILLED WITH 3/4" HAWTHORNE BIT.

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. 306

FIGURE 2B-7

# BORING 307



87% % CORE RECOVERY. ( 4" VACUUM CORE BARREL ).  
BALANCE OF BORING DRILLED WITH 4" HAWTHORNE BIT.

ACAD

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. 307

FIGURE 2B-8

# BORING 309



87% % CORE RECOVERY. ( 4" VACUUM CORE BARREL ).  
BALANCE OF BORING DRILLED WITH 4" HAWTHORNE BIT.

ACAD

HISTORICAL  
REV 19 7/01


**SOUTHERN NUCLEAR OPERATING COMPANY**  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
RECORD NO. 309

FIGURE 2B-9

# BORING 317

ELEVATION 118.1 MSL DATE DRILLED 8-26-67 TO 8-26-67



87% % CORE RECOVERY. ( 4" VACUUM CORE BARREL ).  
BALANCE OF BORING DRILLED WITH 4" HAWTHORNE BIT.

ACAD

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
RECORD NO. 317

FIGURE 2B-10

# BORING 318



87% % CORE RECOVERY. ( 4" VACUUM CORE BARREL ).  
BALANCE OF BORING DRILLED WITH 4" HAWTHORNE BIT.

ACAD

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
RECORD NO. 318

FIGURE 2B-11

# BORING 320



87% % CORE RECOVERY. ( 4" VACUUM CORE BARREL )  
BALANCE OF BORING DRILLED WITH 4" HAWTHORNE BIT.

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
RECORD NO. 320

FIGURE 2B-12



#1 MEDIUM SAND  
 #2 TO COARSE SAND  
 #3 PARTIALLY CEMENTED CLAY

**TEST BORING RECORD**

BORING NO. B-401  
 DATE DRILLED 3/12-16/67  
 JOB NO. 5056-B  
 LAW ENGINEERING TESTING CO.


ACAD

*HISTORICAL*  
 REV 19 7/01

**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
 UNIT 2

**TEST BORING RECORD**  
**RECORD NO. 401**

**FIGURE 2B-13**




- \*1 ORGANIC MATTER
- \*2 CEMENTED CLAY INCLUSIONS
- \*3 INCLUSIONS
- \*4 PARTIALLY CEMENTED SAND SEAMS
- \*5 PARTIALLY CEMENTED CLAY SEAMS AND INCLUSIONS

**TEST BORING RECORD**  
 RECORD NO. 402  
 DATE BORING MADE 2/2/67  
 JOB NO. 5050-B  
 LAW ENGINEERING TESTING CO.

HISTORICAL  
 REV 19 7/01

ACAD





**TEST BORING RECORD**

BORING NO. B-403  
 DATE DRILLED 8/16  
 JOB NO. 5056-B

LAW ENGINEERING TESTING CO.  
 DE

- \*1 PARTIALLY CEMENTED CLAY
- \*2 CEMENTED CLAY SEAMS AND CLAY INCLUSIONS
- \*3 SILTY FINE SAND

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**RECORD NO. 403**

**FIGURE 2B-15**



#1 VERY SILTY FINE TO MEDIUM SAND  
 #2 SANDY CLAY  
 #3 SAND SEAMS  
 #4 FINE SAND

**TEST BORING RECORD**  
 BORING NO. B-404  
 DATE BORING R/2/21/67  
 JOB NO. 5028-B  
 LAFORGE ENGINEERING SERVICE CO. INC.


ACAD

HISTORICAL  
 REV 19 7/01

**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

TEST BORING RECORD  
 RECORD NO. 404

FIGURE 2B-16



**TEST BORING RECORD**

BORING NO. B-405  
 DATE DRILLED 8/27-28 '67  
 JOB NO. 3056-B

LAW ENGINEERING TESTING CO.

\*1 CLAY

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING No. 405**

**FIGURE 2B-17**




**TEST BORING RECORD**

\*1 MEDIUM SAND  
 \*2 LAYERS  
 \*3 CLAY  
 \*4 CEMENTED CLAY AND CEMENTED SAND  
 BORING AND SAMPLING MEETS ASTM D-1586  
 CORE DRILLING MEETS ASTM D-4131  
 PENETRATION IS THE NUMBER OF BLOWS OF 140 LB. HAMMER FALLING 30 IN. REQUIRED TO DRIVE 1.25 IN. 1.0. SAMPLER 1 FT.

BORING NO. B-406  
 DATE DRILLED 8/28-31/67  
 JOB NO. 5052-S  
 LAW ENGINEERING TESTING CO.


WATER TABLE, 24 HR.  
 WATER TABLE, 1 HR.  
 UNDISTURBED SAMPLE  
 LOSS OF DRILLING WATER  
 60% ROCK CORE RECOVERY



**TEST BORING RECORD**


BORING NO. B-407  
 DATE DRILLED 8/13-16/67  
 JOB NO. 5052-B  
 LAW ENGINEERING TESTING CO.

HISTORICAL  
REV 19 7/01



TEST BORING RECORD  
BORING NOS. 406 AND 407

FIGURE 2B-18



**TEST BORING RECORD**

BORING NO. B-408  
 DATE DRILLED 8/23-25/67  
 JOB NO. 505a-B  
 LAW ENGINEERING TESTING CO

\*1 CLAY SEAMS  
 \*2 CLAYEY SAND WITH CEMENTED FINE SAND SEAMS

ACAD


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NO. 408

FIGURE 2B-19



- \*1 TO MEDIUM SAND
- \*2 CEMENTED CLAY WITH THIN FINE SAND SEAMS
- \*3 PARTIALLY CEMENTED CLAY LAYERS

**TEST BORING RECORD**

BOREING NO. B-409  
 DATE DRILLED 9/5/66  
 JOB NO. 5056-B

ACAD


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NO. 409

FIGURE 2B-20



- \*1 TO MEDIUM SAND
- \*2 CEMENTED CLAY LAYERS
- \*3 CEMENTED CLAY
- \*4 OF PARTIALLY CEMENTED CLAY
- \*5 SLIGHTLY CLAYEY FINE SAND WITH GREEN CLAY SEAMS

**TEST BORING RECORD**

BORING NO. B-113  
 DATE DRILLED 9/11/67  
 JOB NO. 3056-B

LAW ENGINEERING TESTING CO.

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 410**

**FIGURE 2B-21**



**TEST BORING RECORD**

BORING NO. B-411  
 DATE DRILLED 9/9/11/67  
 JOB NO. 5056-B  
 LAW ENGINEERING TESTING CO.

•• LAYERS  
 •• AND PARTIALLY INDURATED CLAY INCLUSIONS

*HISTORICAL*  
**REV 19 7/01**




**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 411**

**FIGURE 2B-22**





- \*1 SAND
- \*2 LAYERS
- \*3 SAND WITH THIN LAYERS OF PARTIALLY CEMENTED CLAY
- \*4 OF PARTIALLY CEMENTED CLAY
- \*5 THIN LAYERS OF PARTIALLY CEMENTED CLAY
- \*6 CEMENTED CLAY

**TEST BORING RECORD**

BORING NO. B-412  
 DATE DRILLED 9/8/10/67  
 JOB NO. 3056-B

LAW ENGINEERING TESTING CO.


ACAD

*HISTORICAL*  
**REV 19 7/01**

**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 412**

**FIGURE 2B-23**



- \*1 AND PARTIALLY CEMENTED CLAY
- \*2 WHITE VERY FINE SAND
- \*3 CLAY SEAMS
- \*4 PARTIALLY CEMENTED SEAMS

**TEST BORING RECORD**

BORING NO. B-413  
 DATE DRILLED 8/30/31/67  
 JOB NO. 5056-B

ACAD


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NO. 413

FIGURE 2B-24



- \*1 FINE SAND-TOPSOIL
- \*2 CEMENTED SAND LAYERS
- \*3 CLAY INCLUSIONS
- \*4 CEMENTED CLAY WITH CLAYEY  
FINE SAND LAYERS
- \*5 CEMENTED CLAY
- \*6 CEMENTED CLAY SEAMS
- \*7 SEAMS

**TEST BORING RECORD**

BORING NO. B-415  
 DATE DRILLED 10/11-17/67  
 JOB NO. 5056-B

ACAD


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 RECORD NO. 415

FIGURE 2B-25



- \*1 WITH FINE SAND SEAMS
- \*2 WITH FINE SAND SEAMS
- \*3 SEAMS

**TEST BORING RECORD**

BORING NO. B-416  
 DATE DRILLED 9-23-67  
 JOB NO. 5056-R

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**RECORD NO. 416**

**FIGURE 2B-26**



- \*1 MATERIAL (FILL)
- \*2 SAND LAYERS
- \*3 INCLUSIONS
- \*4 CLAY LAYERS AND INCLUSIONS
- \*5 SLIGHTLY CLAYEY FINE TO MEDIUM SAND

TEST BORING RECORD

RECORD NO. R-417  
 DATE 9/25/67  
 JOB NO. 5056-B

ACAD


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NO. 417

FIGURE 2B-27



\* CALCAREOUS FINE TO MEDIUM SAND

**TEST BORING RECORD**

BORING NO. B-418  
 DATE DRILLED 3-12/18/67  
 JOB NO. 5056-B


ACAD

*HISTORICAL*  
 REV 19 7/01

**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
 UNIT 2

**TEST BORING RECORD**  
**BORING NO. 418**

FIGURE 2B-28



**TEST BORING RECORD**

BORING NO. B-419  
 DATE DRILLED 9-23-67  
 JOB NO. 5056-B

ACAD


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NO. 419

FIGURE 2B-29



\*PARTIALLY CEMENTED CLAY  
 \*\*PARTIALLY CEMENTED CLAY SEAMS

**TEST BORING RECORD**

BORING NO. B-420  
 DATE DRILLED 9-19-20-67  
 JOB NO. 5056-B

ACAD

HISTORICAL  
 REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NO. 420

FIGURE 2B-30





\*1 FINE SAND

**TEST BORING RECORD**

BORING NO. B-421  
 DATE DRILLED 3/23/72  
 JOB NO. 5056-B

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 421**

**FIGURE 2B-31**



- \*1 FINE SAND SEAMS
- \*2 SILTY CLAY WITH THIN SAND SEAMS

**TEST BORING RECORD**

BORING NO. R-422  
 DATE DRILLED 9-20/21-67  
 JOB NO. 5056-B

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 422**

**FIGURE 2B-32**



\*FINE SAND WITH CEMENTED SAND PARTICLES

**TEST BORING RECORD**

BORING NO. B-423  
 DATE DRILLED 11/30/67  
 JOB NO. 5056-B

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 423**

**FIGURE 2B-33**




**TEST BORING RECORD**

BORING AND SAMPLING DATA APRIL 9-1966  
 CORE DRILLING WITH JACO 5-115  
 PENETRATION IS THE NUMBER OF BLOWS OF 140 LB. HAMMER  
 FALLING 30 IN. REQUIRED TO DRIVE 1.0 IN. SAMPLE 1 FT.

BORING NO. B-424  
 DATE DRILLED 11/28/67  
 JOB NO. 5056-B

LAW ENGINEERING TESTING CO.




**TEST BORING RECORD**

BORING AND SAMPLING DATA APRIL 9-1966  
 CORE DRILLING WITH JACO 5-115  
 PENETRATION IS THE NUMBER OF BLOWS OF 140 LB. HAMMER  
 FALLING 30 IN. REQUIRED TO DRIVE 1.0 IN. SAMPLE 1 FT.

BORING NO. B-425  
 DATE DRILLED 10/18/67  
 JOB NO. 5056-B

LAW ENGINEERING TESTING CO.



**TEST BORING RECORD**

BORING AND SAMPLING DATA APRIL 9-1966  
 CORE DRILLING WITH JACO 5-115  
 PENETRATION IS THE NUMBER OF BLOWS OF 140 LB. HAMMER  
 FALLING 30 IN. REQUIRED TO DRIVE 1.0 IN. SAMPLE 1 FT.

BORING NO. B-426  
 DATE DRILLED 10/23/67  
 JOB NO. 5056-B

LAW ENGINEERING TESTING CO.


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NOS. 424, 425, AND 426

FIGURE 2B-34



\*1 TOPSOIL  
\*2 FINE SAND SEAMS AND CEMENTED CLAY SEAMS

**TEST BORING RECORD**

BORING NO. B-427  
DATE DRILLED 10/19/67  
JOB NO. 5056-B

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. 427

FIGURE 2B-35



NO GROUND WATER ENCOUNTERED  
 \*1 WITH PARTIALLY CEMENTED CLAY SEAMS AND INCLUSIONS  
 \*2 INCLUSIONS  
 \*3 CEMENTED CLAY

**TEST BORING RECORD**

BORING NO. B-428  
 DATE DRILLED 11/16/67  
 JOB NO. 5056-B

ACAD


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NO. 428

FIGURE 2B-36



NO GROUND WATER ENCOUNTERED  
#1 WHITE SAND

**TEST BORING RECORD**

BORING NO. B-429  
DATE DRILLED 11/20/67  
JOB NO. 5056-A

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 429**

**FIGURE 2B-37**



**TEST BORING RECORD**

BORING NO. 2-430  
 DATE DRILLED 11/22/67  
 JOB NO. SC56-5

ACAD

*HISTORICAL*  
**REV 19 7/01**


**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**



**TEST BORING RECORD**  
**BORING NO. 430**

**FIGURE 2B-38**





**TEST BORING RECORD**

BORING NO. 1-431  
 DATE BORING 12/6/67  
 JOB NO. 1CS 6-3

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 431**

**FIGURE 2B-39**



NO GROUND WATER ENCOUNTERED  
#1 AND INCLUSIONS

**TEST BORING RECORD**

BORING NO. B-432  
DATE DRILLED 11/20/67  
JOB NO. 5056-B

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 432**

**FIGURE 2B-40**



CEMENTED CLAY WITH SANDY SEAMS

**TEST BORING RECORD**

BORING NO. B-433  
 DATE DRILLED 1-15-58  
 JOB NO. 5030-B


ACAD

*HISTORICAL*  
**REV 19 7/01**

**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 433**

**FIGURE 2B-41**



- \*1 WITH PARTIALLY CEMENTED SAND LAYERS
- \*2 CEMENTED SAND FRAGMENTS
- \*3 SEAMS
- \*4 CLAYEY FINE SAND

**TEST BORING RECORD**

BORING NO. B-434  
 DATE DRILLED 1-17-68  
 JOB NO. SC56-B

ACAD


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NO. 434

FIGURE 2B-42




- \*1 FINE SAND 78' TO 82' HARD GREEN GRAY PARTIALLY CEMENTED CLAY WITH THIN SAND SEAMS
- \*2 SAND WITH PARTIALLY CEMENTED CLAY SEAMS
- \*3 CLAY WITH PARTIALLY CEMENTED CLAY SEAMS
- \*4 FRAGMENTS

**TEST BORING RECORD**

BORING NO. B-435  
 DATE DRILLED 1/18/68  
 JOB NO. 5056-B

ACAD

*HISTORICAL*  
**REV 19 7/01**



\*CLAYEY FINE-COARSE SAND

**TEST BORING RECORD**

BORING NO. B-436  
 DATE DRILLED 1-21-68  
 JOB NO. 1056-B

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 436**

**FIGURE 2B-44**



**TEST BORING RECO**  
 BORING NO. 3-37  
 DATE DRILLED 1-8-68  
 JOB NO. SC56-B

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 437**

**FIGURE 2B-45**



**TEST BORING RECORD**

BORING NO. B-438  
 DATE BORING 1-3-68  
 JOB NO. 1028-B

\*1 SAND LAYERS  
 \*2 CLAY FRAGMENTS

*HISTORICAL*  
**REV 19 7/01**

ACAD




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NO. 438

FIGURE 2B-46





- \*1 SANDY CLAY WITH PARTIALLY CEMENTED SAND LAYERS
- \*2 SAND FRAGMENTS
- \*3 CLAYEY FINE TO MEDIUM SAND WITH CLAY SEAMS

**TEST BORING RECORD**

BORING NO. B-439  
 DATE BORER 1/23/68  
 JOB NO. 5056-B

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 439**

**FIGURE 2B-47**



\*INCLUSIONS AND THIN SEAMS  
\*\*INCLUSIONS

**TEST BORING RECORD**

BORING NO. B-440  
DATE BORERED 6/13/64  
JOB NO. 5056

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. 440

FIGURE 2B-48



\*MATERIAL  
\*\*GRAY CLAY SEAMS

**TEST BORING RECORD**

BORING NO. 3-441  
DATE DRILLED 12/25/68  
JOB NO. 3736

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**


**TEST BORING RECORD**  
**BORING NO. 441**

**FIGURE 2B-49**




\*MATERIAL TEST BORING RECORD

BORING NO. B-442  
DATE DRILLED 6/22-27/66



\*CEMENTED CLAY INCLUSIONS \*\*SAND SEAMS TEST BORING RECORD

BORING NO. B-443  
DATE DRILLED 6/28-29/66



\*LAYERS \*\* LAYERS AND INCLUSIONS \*\*\*SAND SEAMS TEST BORING RECORD

BORING NO. B-444  
DATE DRILLED 6/21-22/66


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NOS. 442, 443, AND 444


FIGURE 2B-50



\* LAYERS AND INCLUSIONS  
 \*\* SAND SEAMS  
 \*\*\* CEMENTED CLAY INCLUSIONS

**TEST BORING RECORD**


BORING NO. T-445  
 DATE DRILLED 6-12/13-68



\* LAYERS AND INCLUSIONS

**TEST BORING RECORD**

BORING NO. R-446  
 DATE DRILLED 7/12/68



\* FINE SAND WITH ROOTS AND ORGANIC MATERIAL

**TEST BORING RECORD**

BORING NO. R-448  
 DATE DRILLED 7/19/22/68


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NOS. 445, 446, AND 448


FIGURE 2B-51



\* SLIGHTLY CLAYEY FINE SAND WITH CLAYEY INCLUSIONS  
 \*\* AND INCLUSIONS  
 \*\*\* INCLUSIONS

TEST BORING RECORD


BORING NO. R-449  
 DATE DRILLED 5/12-13/68



\* MATERIAL

TEST BORING RECORD

BORING NO. R-450  
 DATE DRILLED 6/6/68



\* ORGANIC MATERIAL  
 \*\* GREEN PLASTIC CLAYEY LAYERS AND INCLUSIONS  
 \*\*\* SEAMS OF SANDY CLAY - \*\*\*\* INCLUSIONS

TEST BORING RECORD

BORING NO. R-451  
 DATE DRILLED 7/1-2/68


HISTORICAL  
 REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NOS. 449, 450, AND 451


FIGURE 2B-52



**TEST BORING RECORD**  
 BOREHOLE AND SAMPLES MADE AFTER 9:00 AM  
 DATE BORER 2/22/68  
 JOB NO. 5056  
 LAW ENGINEERING TESTING CO. INC.



**TEST BORING RECORD**  
 BOREHOLE AND SAMPLES MADE AFTER 9:00 AM  
 DATE BORER 6/14/68  
 JOB NO. 5056  
 LAW ENGINEERING TESTING CO. INC.



**TEST BORING RECORD**  
 BOREHOLE AND SAMPLES MADE AFTER 9:00 AM  
 DATE BORER 6/16-17/68  
 JOB NO. 5056  
 LAW ENGINEERING TESTING CO. INC.


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NOS. 452, 453, AND 454

FIGURE 2B-53



\* MATERIAL \*\* CLAY

TEST BORING RECORD

BORING NO. S-55  
DATE DRILLED 2-13-63  
JOB NO. 513

ACAD

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. 455

FIGURE 2B-54





\* LAYERS AND INCLUSIONS

**TEST BORING RECORD**

BORING NO. R-456  
 DATE DRILLED 12-18-56  
 JOB NO. 5056

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 456**

**FIGURE 2B-55**



\*INCLUSIONS

**TEST BORING RECORD**

BORING NO. B-457  
 DATE DRILLED 6/28/88  
 JOB NO. 5056


ACAD

HISTORICAL  
 REV 19 7/01

**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

TEST BORING RECORD  
 BORING NO. 457

FIGURE 2B-56




**TEST BORING RECORD**

BORING NO. B-458  
 DATE DRILLED 7/24-25/68  
 JOB NO. 345n

*HISTORICAL*  
**REV 19 7/01**

ACAD



\*SAND

**TEST BORING RECORD**

BORING NO. B-459

DATE DRILLED 7-26-68

JOB NO. 5056

ACAD


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. 459

FIGURE 2B-58



\* AND ORGANIC MATERIAL

**TEST BORING RECORD**

BORING NO. T-460  
 DATE DRILLED 7-16-17-68  
 JOB NO. 5056

ACAD


HISTORICAL  
 REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NO. 460


FIGURE 2B-59



**TEST BORING RECORD**  
 BORING NO. T-461  
 DATE DRILLED 7/16-15/68



**TEST BORING RECORD**  
 BORING NO. T-462  
 DATE DRILLED 7/17/68



**TEST BORING RECORD**  
 BORING NO. T-463  
 DATE DRILLED 7/17-18/68




HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NOS. 461, 462, AND 463

FIGURE 2B-60




HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NOS. 464, 465, AND 466

FIGURE 2B-61



\*FINE SAND, CLAY INCLUSIONS AT 80'

**TEST BORING RECORD**

BORING NO. B-475  
 DATE DRILLED 2-6-69  
 JOB NO. 505b

ACAD

*HISTORICAL*  
**REV 19 7/01**




**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 475**

**FIGURE 2B-62**





**TEST BORING RECORD**

BORING NO. B-477  
 DATE DRILLED 1-11-64  
 JOB NO. 305

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 477**

**FIGURE 2B-63**



**TEST BORING RECORD**

BORING NO. B-478  
 DATE DRILLED 11-1-69  
 JOB NO. 1056

*HISTORICAL*  
**REV 19 7/01**


ACAD



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 478**

**FIGURE 2B-64**



**TEST BORING RECORD**

BORING NO. 2-479  
 DATE DRILLED 1-12-68  
 JOB NO. 4-10

*HISTORICAL*  
**REV 19 7/01**


ACAD



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 479**

**FIGURE 2B-65**



**TEST BORING RECORD**

BORING NO. B-440  
 DATE DRILLED 2-12-64  
 JOB NO. 3756

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 480**

**FIGURE 2B-66**



**TEST BORING RECORD**

BORING NO. B-481  
 DATE DRILLED 2-12-60  
 JOB NO. 5056

*HISTORICAL*  
 REV 19 7/01


ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NO. 481

FIGURE 2B-67



**TEST BORING RECORD**

BORING NO. B-482  
 DATE DRILLED 7-14-01  
 JOB NO. 5016

*HISTORICAL*  
**REV 19 7/01**


ACAD



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 482**

**FIGURE 2B-68**



**TEST BORING RECORD**

BORING NO. B-483  
 DATE DRILLED 2-14-77  
 JOB NO. 5056

*HISTORICAL*  
**REV 19 7/01**


ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2


TEST BORING RECORD  
 BORING NO. 483

FIGURE 2B-69



**TEST BORING RECORD**

BORING NO. B-484  
 DATE DRILLED 5/5/69  
 JOB NO. 5056



\*SAND WITH FINE GRAVEL (ALLUVIUM)

**TEST BORING RECORD**

BORING NO. B-485  
 DATE DRILLED 4/17/69  
 JOB NO. 5056

ACAD

*HISTORICAL*  
**REV 19 7/01**




**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**RECORD NOS. 484 AND 485**

**FIGURE 2B-70**






\*CEMENTED INCLUSIONS  
\*\*CLAY WITH FINE SAND INCLUSIONS

**TEST BORING RECORD**

BORING NO. R-486  
DATE DRILLED 4/16/69  
JOB NO. 5056



\*LAYERS AND INCLUSIONS  
\*\*CLAY WITH FINE SAND LAYERS AND INCLUSIONS

**TEST BORING RECORD**

BORING NO. R-487  
DATE DRILLED 4/15/69  
JOB NO. 5056

ACAD


*HISTORICAL*  
**REV 19 7/01**




**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NOS. 486 AND 487**

**FIGURE 2B-71**



BORING NO. 488  
 DATE DRILLED 4-3-69  
 JOB NO. 5056



BORING NO. 489  
 DATE DRILLED 4/8/69  
 JOB NO. 5056

HISTORICAL  
 REV 19 7/01


ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NO.S 488 AND 489

FIGURE 2B-72




\*CLAYEY FINE SAND      \*\*INCLUSIONS

**TEST BORING RECORD**

BORING NO. B-490  
 DATE DRILLED 4/17/69  
 JOB NO. 5756

*HISTORICAL*  
 REV 19 7/01

ACAD



\* TO FINE SAND

**TEST BORING RECORD**

\*1 WITH FINE SANDY BORING NO. B-94  
 INCLUSIONS DATE DRILLED 2-28-69  
 JOB NO. 5056

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 494**

**FIGURE 2B-74**



\*1 FRAGMENTS  
\*2 ... ..

**TEST BORING RECORD**

BORING NO. B-495  
DATE DRILLED 3/5/69  
JOB NO. 3056

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORDS**  
**BORING NO. 495**

**FIGURE 2B-75**



\*WITH FINE SAND INCLUSIONS

**TEST BORING RECORD**

BORING NO. B-511  
 DATE DRILLED 4/1/69  
 JOB NO. 5056

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORDS**  
**BORING NO. 511**

**FIGURE 2B-76**



\*SAND \*\*CLAY WITH FINE SAND INCLUSIONS **TEST BORING RECORD**

BORING NO. B-512  
 DATE DRILLED 4/2/69  
 JOB NO. 5056

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 512**

**FIGURE 2B-77**



**TEST BORING RECORD**

BORING NO. B-516  
 DATE DRILLED 4-2-69  
 JOB NO. 5056

ACAD

*HISTORICAL*  
**REV 19 7/01**




**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 516**

**FIGURE 2B-78**





\*SAND  
 \*\*LAYERS AND INCLUSIONS  
 \*\*\*INCLUSIONS

**TEST BORING RECORD**

BORING NO. 519  
 DATE DRILLED 4/8/69  
 JOB NO. 5056

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 519**

**FIGURE 2B-79**



TEST BORING RECORD

BORING NO. 521  
 DATE DRILLED 4/7/69  
 JOB NO. SC56

HISTORICAL  
 REV 19 7/01


ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NO. 521

FIGURE 2B-80



\*CLAY INCLUSIONS \*\*INCLUSIONS

**TEST BORING RECORD**

BORING NO. B-522  
 DATE DRILLED 11.1.89  
 JOB NO. 5756

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 522**

**FIGURE 2B-81**



SANDY CLAY, PARTIALLY CEMENTED

**TEST BORING RECORD**

BORING NO. B-529  
 DATE BORING 4-20-69  
 JOB NO. 5056

ACAD


*HISTORICAL*  
**REV 19 7/01**



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NO. 529

FIGURE 2B-82



**TEST BORING RECORD**

BORING NO. B-548  
 DATE DRILLED 4-30-60  
 JOB NO. 5056

ACAD


*HISTORICAL*  
**REV 19 7/01**



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**TEST BORING RECORD**  
**BORING NO. 548**

**FIGURE 2B-83**




\*SP. CLAY  
\*\*INCLUSIONS

TEST BORING RECORD

BORING NO. B-549  
 DATE DRILLED 5-5-69  
 JOB NO. 3056

LAW ENGINEERING TESTING CO.



TEST BORING RECORD

BORING NO. B-550  
 DATE DRILLED 5-1-69  
 JOB NO. 3256

HISTORICAL

REV 19 7/01


ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NOS. 549 AND 550


FIGURE 2B-84



**TEST BORING RECORD**

BORING NO. B-551  
 DATE DRILLED 3-2-69  
 JOB NO. 5056

LAW ENGINEERING TESTING CO.



\*INCLUSIONS

**TEST BORING RECORD**

BORING NO. B-552  
 DATE DRILLED 3-12-69  
 JOB NO. 5056

*HISTORICAL*  
**REV 19 7/01**


ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NOS. 551 AND 552


FIGURE 2B-85



\* FINE SANDY CLAY  
\*\* TO FINE SAND

**TEST BORING RECORD**

BORING NO. B-556  
 DATE DRILLED 3-8-69  
 JOB NO. 5056



\* CLAY INCLUSIONS

**TEST BORING RECORD**

BORING NO. B-557  
 DATE DRILLED 3-9-69

*HISTORICAL*  
**REV 19 7/01**

ACAD




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NOS. 556 AND 557


FIGURE 2B-86





**TEST BORING RECORD**

BORING NO. B-558  
 DATE BORING 5-8-69  
 JOB NO. 5056



**TEST BORING RECORD**

BORING NO. B-559  
 DATE BORING 5-7-69  
 JOB NO. 5056

*HISTORICAL*  
**REV 19 7/01**


ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NOS. 558 AND 559

FIGURE 2B-87




\*SAND (FILL)

**TEST BORING RECORD**

BORING NO. B-560  
 DATE DRILLED 5-6-69  
 JOB NO. 5056

LAW ENGINEERING TESTING CO.



**TEST BORING RECORD**

BORING NO. B-561  
 DATE DRILLED 5-6-69  
 JOB NO. 5056

*HISTORICAL*  
**REV 19 7/01**


ACAD



**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**


**TEST BORING RECORD**  
**BORING NOS. 560 AND 561**

**FIGURE 2B-88**




TEST BORING RECORD

BORING NUMBER B-562  
 DATE DRILLED 6/19/69  
 JOB NUMBER 5056




TEST BORING RECORD

BORING NUMBER 564  
 DATE DRILLED 6/19/69  
 JOB NUMBER 5056




TEST BORING RECORD

BORING NUMBER 566  
 DATE DRILLED 6/20/69  
 JOB NUMBER 5056




TEST BORING RECORD

BORING NUMBER B-563  
 DATE DRILLED 6/20/69  
 JOB NUMBER 5056



TEST BORING RECORD

BORING NUMBER 565  
 DATE DRILLED 6/13/69  
 JOB NUMBER 5056



TEST BORING RECORD

BORING NUMBER 567  
 DATE DRILLED 9/1/69  
 JOB NUMBER 5056







HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NOS. 562 THRU 567

FIGURE 2B-89




HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2


TEST BORING RECORD  
 BORING NOS. 568 THRU 573

FIGURE 2B-90



TEST BORING RECORD

BORING NUMBER 574  
 DATE DRILLED 7/18/69  
 JOB NUMBER 5056



TEST BORING RECORD

\*1 LAYERS  
 \*2 LAYERS  
 \*3 SAND AND CLAYEY FINE SAND WITH THIN CLAY LAYERS

BORING NUMBER 575  
 DATE DRILLED 7/17/69  
 JOB NUMBER 5056

ACAD


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NOS. 574 AND 575

FIGURE 2B-91




ACAD

HISTORICAL  
REV 19 7/01

DEPTH  
FEET

DESCRIPTION

PENETRATION BLOWS PER FOOT



- \*1 MATTER (ALLUVIUM)
- \*2 INCLUSIONS
- \*3 SILTY CLAY WITH OCCASIONAL FINE SAND INCLUSIONS

ACAD


HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. 577

FIGURE 2B-93



TEST BORING RECORD  
 BORING NUMBER B-578  
 DATE DRILLED 12/3-5/69



TEST BORING RECORD  
 BORING NUMBER B-579  
 DATE DRILLED 11/25-26/69

HISTORICAL  
 REV 19 7/01

ACAD




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2


TEST BORING RECORD  
 BORING NOS. 578 AND 579

FIGURE 2B-94






\*1 SAND (ALTERNATE LAYERS) TEST BORING RECORD  
 BORING NUMBER B-580  
 DATE DRILLED 11/24-23/69



\*1 SAND (TOPSOIL)  
 \*2 SAND INCLUSIONS  
 \*4 INCLUSIONS TEST BORING RECORD  
 BORING NUMBER B-581  
 DATE DRILLED 11/18-21/69



\*1 CLAY TEST BORING RECORD  
 BORING NUMBER B-584  
 DATE DRILLED 12/18-19/69


HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NOS. 580, 581, AND 584

FIGURE 2B-95



\*1 GREEN CLAY INCLUSIONS

TEST BORING RECORD

BORING NUMBER B-585  
DATE DRILLED 12/11, 12, 17, 18/6

ACAD

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. 585

FIGURE 2B-96


DEPTH FEET                      DESCRIPTION                      PENETRATION BLOWS PER FOOT



- \*1 (ALLUVIUM)
- \*2 CEMENTED INCLUSIONS
- \*3 GRAY GREEN PLASTIC CLAY


ACAD

HISTORICAL  
REV 19 7/01




\* PLASTIC CLAY LAYERS AND INCLUSIONS  
 \*\* SAND WITH CLAY INCLUSIONS

**TEST BORING RECORD**  
 BORING NUMBER R-587  
 DATE DRILLED 4/17/70  
 JOB NUMBER 5056



\* FINE SAND WITH CLAY INCLUSIONS  
 \*\* WITH FINE SAND SEAMS

**TEST BORING RECORD**  
 BORING NUMBER R-588  
 DATE DRILLED 4/29/70  
 JOB NUMBER 5056



\* WITH THIN FINE SAND SEAMS

**TEST BORING RECORD**  
 BORING NUMBER R-589  
 DATE DRILLED 4/17/70  
 JOB NUMBER 5056


HISTORICAL  
 REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NOS. 587, 588, AND 589


FIGURE 2B-98



\* PLASTIC CLAY LAYERS AND INCLUSIONS  
**TEST BORING RECORD**  
 BORING NUMBER R-590  
 DATE DRILLED 4/17/70  
 JOB NUMBER 5056



\* SANDY CLAY LAYERS  
 \*\* PLASTIC CLAY LAYERS AND INCLUSIONS  
 \*\*\* INCLUSIONS  
**TEST BORING RECORD**  
 BORING NUMBER R-591  
 DATE DRILLED 4/16/70  
 JOB NUMBER 5056



\* CLAYEY VERY FINE SAND WITH THIN PLASTIC CLAY LAYERS AND INCLUSIONS  
 \*\* SANDY PLASTIC CLAY  
 \*\*\* PLASTIC CLAY LAYERS AND INCLUSIONS  
**TEST BORING RECORD**  
 BORING NUMBER R-592  
 DATE DRILLED 4-16-70  
 JOB NUMBER 5056




HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NOS. 590, 591, AND 592

FIGURE 2B-99






HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NOS. 593, 594, AND 595

FIGURE 2B-100




HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2


TEST BORING RECORD  
CORNIG NOS. 596, 597, AND 598

FIGURE 2B-101



TEST BORING RECORD  
 BORING NUMBER T-599  
 DATE DRILLED 4/18/70  
 JOB NUMBER 5056

\* AND SLIGHTLY CLAYEY VERY FINE SAND WITH THIN PLASTIC CLAY LAYERS AND INCLUSIONS.  
 \*\* THIN PLASTIC CLAY LAYERS AND INCLUSIONS.  
 \*\*\* THIN PLASTIC CLAY LAYERS AND INCLUSIONS.



TEST BORING RECORD  
 BORING NUMBER T-600  
 DATE DRILLED 4/22/70  
 JOB NUMBER 5056

\* FINE SAND

HISTORICAL  
 REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 CORING NOS. 599 AND 600

FIGURE 2B-102





TEST BORING RECORD

BORING NUMBER B-603  
 DATE DRILLED 5/6/70

ACAD

HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NO. 603

FIGURE 2B-103

| GEOLOGIC LOG |       | BORING NO.                                                                                                   | LOCATION              |
|--------------|-------|--------------------------------------------------------------------------------------------------------------|-----------------------|
|              |       | 1001                                                                                                         | N. 64 + 18 E. 30 + 47 |
| DEPTH        | ELEV. | VISUAL DESCRIPTION                                                                                           | GEOLOGIC UNIT         |
|              | 125.2 |                                                                                                              |                       |
|              |       | Gray, brown, and red silty clayey fine to coarse SAND and sandy CLAY, with organic material in upper 6 feet. | COLLUVIUM             |
| 10           | 113.2 | Green-gray clayey fine to medium SAND.                                                                       |                       |
| 20           |       |                                                                                                              | UNIT 6                |
| 30           | 92.7  | Gray and green fine to coarse sandy partially cemented CLAY.                                                 |                       |
| 40           |       |                                                                                                              | UNIT 5                |
| 50           | 77.2  | Green, gray, brown, and tan slightly clayey very fine to coarse SAND with clay inclusion.                    |                       |
| 60           | 67.2  | Green-gray silty very fine to fine SAND with clayey silt layers and cemented clayey sand seams.              | UNIT 4                |
| 70           |       |                                                                                                              |                       |
| 80           | 42.2  | Gray-tan silty slightly clayey fine to medium SAND with partially cemented clay layers and inclusions.       | UNIT 3                |
| 90           |       |                                                                                                              |                       |
| 100          | 28.2  | Gray-tan cemented fine to medium sandy CLAY and cemented SAND with clay inclusions.                          | UNIT 2                |
| 110          | 9.7   | Light green cemented fine sandy silty CLAY with fine sand seams.                                             |                       |
| 120          | 4.7   | Bottom at 4.7 ft MSL.                                                                                        |                       |
| 130          |       |                                                                                                              |                       |
| 140          |       |                                                                                                              |                       |
| 150          |       |                                                                                                              |                       |

BORING NUMBER 1001

| GEOLOGIC LOG |        | BORING NO.                                                                                   | LOCATION              |
|--------------|--------|----------------------------------------------------------------------------------------------|-----------------------|
|              |        | 1002                                                                                         | N. 61 + 95 E. 34 + 42 |
| DEPTH        | ELEV.  | VISUAL DESCRIPTION                                                                           | GEOLOGIC UNIT         |
|              | 114.0  |                                                                                              |                       |
|              |        | Tan to green-gray clayey fine to medium SAND.                                                | ALLUVIUM              |
| 10           |        |                                                                                              |                       |
| 20           | 92.0   | Green-gray very clayey fine to coarse SAND with cemented clay inclusions.                    | UNIT 5                |
| 30           | 79.5   | Gray-green fine sandy CLAY with fine sand seams.                                             |                       |
| 40           |        |                                                                                              | UNIT 4                |
| 50           | 67.5   | Green-gray silty clayey fine SAND with partially cemented sandy clay layers.                 |                       |
| 60           |        |                                                                                              | UNIT 3                |
| 70           | 45.5   | Green-gray clayey silty fine SAND with clay inclusions.                                      |                       |
| 80           | 36.0   | Gray-tan clayey silty fine to medium SAND with partially cemented clay and fine sand layers. | UNIT 2                |
| 90           |        |                                                                                              |                       |
| 100          | 6.0    | Gray-green fine sandy silty CLAY with white fine sand seams.                                 |                       |
| 110          | (-1.5) | Bottom at (-1.5) ft MSL.                                                                     |                       |
| 120          |        |                                                                                              |                       |
| 130          |        |                                                                                              |                       |
| 140          |        |                                                                                              |                       |
| 150          |        |                                                                                              |                       |

BORING NUMBER 1002

| GEOLOGIC LOG |       | BORING NO.                                                                               | LOCATION              |
|--------------|-------|------------------------------------------------------------------------------------------|-----------------------|
|              |       | 1003                                                                                     | N. 57 + 00 E. 34 + 42 |
| DEPTH        | ELEV. | VISUAL DESCRIPTION                                                                       | GEOLOGIC UNIT         |
|              | 141.0 |                                                                                          |                       |
|              |       | Gray and brown clayey fine to coarse SAND and sandy CLAY.                                | UNIT 6                |
| 10           |       |                                                                                          |                       |
| 20           | 124.0 | Gray clayey partially cemented fine to coarse SAND and sandy CLAY.                       | UNIT 5                |
| 30           |       |                                                                                          |                       |
| 40           |       |                                                                                          | UNIT 4                |
| 50           | 78.0  | Gray and green silty clayey very fine to fine SAND with clay layers and inclusions.      |                       |
| 60           |       |                                                                                          | UNIT 3                |
| 70           |       |                                                                                          |                       |
| 80           |       |                                                                                          | UNIT 2                |
| 90           | 34.0  | Gray and tan clayey silty fine to medium SAND with clay inclusions and some clay layers. |                       |
| 100          |       |                                                                                          |                       |
| 110          |       |                                                                                          |                       |
| 120          |       |                                                                                          |                       |
| 130          |       |                                                                                          |                       |
| 140          | 4.0   | Gray fine sandy silty CLAY with fine sand seams.                                         | UNIT 2                |
| 140          | 0.5   | Bottom at 0.5 ft MSL.                                                                    |                       |
| 150          |       |                                                                                          |                       |

BORING NUMBER 1003

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NOS. 1001, 1002, AND 1003

FIGURE 2B-104

| GEOLOGIC LOG |        | BORING NO.                                                                                                                                   | LOCATION              |
|--------------|--------|----------------------------------------------------------------------------------------------------------------------------------------------|-----------------------|
|              |        | 1006                                                                                                                                         | N. 50 + 62 E. 38 + 63 |
| DEPTH        | ELEV.  | VISUAL DESCRIPTION                                                                                                                           | GEOLOGIC UNIT         |
|              | 128.0  |                                                                                                                                              |                       |
| 10           |        | Red, brown, and gray clayey fine to medium <u>SAND</u> .                                                                                     | UNIT 6                |
| 20           | 111.5  | Gray and gray-green cemented fine sandy <u>CLAY</u> and clayey <u>SAND</u> .                                                                 | UNIT 5                |
| 30           |        |                                                                                                                                              |                       |
| 40           |        |                                                                                                                                              |                       |
| 50           | 76.5   | Gray and gray-green fine sandy <u>CLAY</u> and clayey fine <u>SAND</u> with clay layers, sand seams, and partially cemented clay inclusions. | UNIT 4                |
| 60           |        |                                                                                                                                              |                       |
| 70           |        |                                                                                                                                              |                       |
| 80           |        |                                                                                                                                              |                       |
| 90           | 36.0   | Gray-tan silty clayey fine to medium <u>SAND</u> with partially cemented clay and sandy clay inclusions.                                     | UNIT 3                |
| 100          |        |                                                                                                                                              |                       |
| 110          |        |                                                                                                                                              |                       |
| 120          | 5.0    | Green fine sandy silty <u>CLAY</u> with fine sand seams.                                                                                     | UNIT 2                |
| 130          | (-2.5) | Bottom at (-2.5) ft MSL                                                                                                                      |                       |
| 140          |        |                                                                                                                                              |                       |
| 150          |        |                                                                                                                                              |                       |

BORING NUMBER 1006

| GEOLOGIC LOG |       | BORING NO.                                                                 | LOCATION              |
|--------------|-------|----------------------------------------------------------------------------|-----------------------|
|              |       | 1005                                                                       | N. 48 + 05 E. 34 + 42 |
| DEPTH        | ELEV. | VISUAL DESCRIPTION                                                         | GEOLOGIC UNIT         |
|              | 148.0 |                                                                            |                       |
| 10           |       | FILL: clayey fine to medium sand.                                          | FILL                  |
| 20           |       |                                                                            |                       |
| 30           | 124.0 | Gray-brown fine sandy <u>CLAY</u> .                                        | UNIT 6                |
| 40           | 121.0 | Gray clayey fine to coarse <u>SAND</u> with cemented sand and clay layers. | UNIT 5                |
| 50           |       |                                                                            |                       |
| 60           |       |                                                                            |                       |
| 70           | 76.0  | Green-gray clayey silty fine <u>SAND</u> with clay layers and inclusions.  | UNIT 4                |
| 80           |       |                                                                            |                       |
| 90           |       |                                                                            |                       |
| 100          |       |                                                                            |                       |
| 110          |       |                                                                            |                       |
| 120          | 30.5  | Gray-tan slightly clayey silty fine <u>SAND</u> with some clay inclusions. | UNIT 3                |
| 130          |       |                                                                            |                       |
| 140          | 9.0   | Light green fine sandy silty <u>CLAY</u> with fine sand seams.             | UNIT 2                |
| 150          | 2.5   | Bottom at 2.5 ft MSL                                                       |                       |

BORING NUMBER 1005

| GEOLOGIC LOG |        | BORING NO.                                                                                                   | LOCATION              |
|--------------|--------|--------------------------------------------------------------------------------------------------------------|-----------------------|
|              |        | 1004                                                                                                         | N. 52 + 29 E. 34 + 42 |
| DEPTH        | ELEV.  | VISUAL DESCRIPTION                                                                                           | GEOLOGIC UNIT         |
|              | 144.5  |                                                                                                              |                       |
| 10           |        | Gray, red, and purple clayey fine to medium <u>SAND</u> .                                                    | UNIT 6                |
| 20           | 123.0  | Gray to gray-green clayey partially cemented fine to medium <u>SAND</u> and sandy <u>CLAY</u> .              | UNIT 5                |
| 30           |        |                                                                                                              |                       |
| 40           |        |                                                                                                              |                       |
| 50           |        |                                                                                                              |                       |
| 60           |        |                                                                                                              |                       |
| 70           | 77.0   | Gray to gray-green clayey silty fine to medium <u>SAND</u> with clay layers and inclusions.                  | UNIT 4                |
| 80           |        |                                                                                                              |                       |
| 90           |        |                                                                                                              |                       |
| 100          |        |                                                                                                              |                       |
| 110          |        |                                                                                                              |                       |
| 120          | 27.5   | Gray-tan silty clayey very fine to fine <u>SAND</u> with clay layers and partially cemented clay inclusions. | UNIT 3                |
| 130          |        |                                                                                                              |                       |
| 140          | 7.0    | Green slightly fine sandy silty <u>CLAY</u> with fine sand seams.                                            | UNIT 2                |
| 150          | (-1.0) | Bottom at (-1.0) ft MSL                                                                                      |                       |

BORING NUMBER 1004

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NOS. 1004, 1005, AND 1006

FIGURE 2B-105

| GEOLOGIC LOG |        | BORING NO.                                                                                      | LOCATION              |
|--------------|--------|-------------------------------------------------------------------------------------------------|-----------------------|
|              |        | 1007                                                                                            | N. 47 + 20 E. 44 + 80 |
| DEPTH        | ELEV.  | VISUAL DESCRIPTION                                                                              | GEOLOGIC UNIT         |
|              | 131.0  | Red and gray fine to medium sandy <u>CLAY</u> .                                                 | UNIT 6                |
| 10           | -124.0 | Green-gray clayey fine to coarse <u>SAND</u> .                                                  |                       |
| 20           | -116.5 | Green-gray cemented clayey fine to coarse <u>SAND</u> with clay inclusions.                     | UNIT 5                |
| 60           | -76.0  | Green-gray slightly clayey silty fine <u>SAND</u> with clay layers and inclusions.              |                       |
| 80           |        | fine sandy silty clay layer, 82.0' - 87.0'                                                      | UNIT 4                |
| 90           | -39.0  | Gray-tan silty clayey very fine to medium <u>SAND</u> with occasional cemented clay inclusions. |                       |
| 120          | -8.0   | Gray-green slightly fine sandy silty <u>CLAY</u> with fine sand seams.                          | UNIT 2                |
| 130          | -1.2   | Bottom at 1.2 ft MSL                                                                            |                       |

BORING NUMBER 1007

| GEOLOGIC LOG |        | BORING NO.                                                                                       | LOCATION              |
|--------------|--------|--------------------------------------------------------------------------------------------------|-----------------------|
|              |        | 1008                                                                                             | N. 43 + 48 E. 41 + 45 |
| DEPTH        | ELEV.  | VISUAL DESCRIPTION                                                                               | GEOLOGIC UNIT         |
|              | 134.0  | Gray clayey fine <u>SAND</u> with cemented clay inclusions.                                      | UNIT 6                |
| 10           | -127.0 | Gray clayey fine to coarse partially cemented <u>SAND</u> with clay layers.                      |                       |
| 20           | -116.0 | Gray and green clayey fine to medium partially cemented <u>SAND</u> with fine sandy clay layers. | UNIT 5                |
| 60           | -80.0  | Gray and tan slightly clayey fine to medium <u>SAND</u> .                                        |                       |
| 70           | -67.0  | Gray-green clayey silty fine <u>SAND</u> with some partially cemented clay inclusions.           | UNIT 4                |
| 90           | -46.0  | Gray-green silty clayey very fine to fine <u>SAND</u> with clay layers and inclusions.           |                       |
| 120          | -21.0  | Gray-tan clayey silty fine to medium <u>SAND</u> with clay inclusions.                           | UNIT 3                |
| 140          | -2.0   | Blue-green silty clayey fine to medium <u>SAND</u> with clay layers.                             | UNIT 2                |
| 140          | (-1.5) | Bottom at (-1.5) ft MSL                                                                          |                       |

BORING NUMBER 1008

| GEOLOGIC LOG |        | BORING NO.                                                                                                     | LOCATION              |
|--------------|--------|----------------------------------------------------------------------------------------------------------------|-----------------------|
|              |        | 1009                                                                                                           | N. 43 + 35 E. 44 + 60 |
| DEPTH        | ELEV.  | VISUAL DESCRIPTION                                                                                             | GEOLOGIC UNIT         |
|              | 135.0  | Mottled clayey fine to very coarse <u>SAND</u> .                                                               | UNIT 6                |
| 10           | -124.0 | Gray-green fine to medium sandy <u>CLAY</u> with clayey sand seams.                                            |                       |
| 20           | -118.0 | Green-gray clayey medium to very coarse <u>SAND</u> .                                                          | UNIT 5                |
| 30           | -105.5 | Gray and gray-green partly silty clayey fine <u>SAND</u> .                                                     |                       |
| 50           | -92.0  | Green-gray cemented silty fine <u>SAND</u> .                                                                   | UNIT 4                |
| 70           | -70.0  | Green-gray silty clayey fine to medium <u>SAND</u> with cemented clay inclusions.                              |                       |
| 90           | -48.0  | Gray-tan silty clayey very fine to medium <u>SAND</u> with cemented clay and sandy clay layers and inclusions. | UNIT 3                |
| 120          | -12.0  | Blue-green fine sandy silty <u>CLAY</u> with fine to medium sand seams.                                        |                       |
| 130          | -9.5   | Bottom at 9.5 ft MSL                                                                                           |                       |

BORING NUMBER 1009


HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NOS. 1007, 1008, AND 1009


FIGURE 2B-106



BORING NUMBER 1012



BORING NUMBER 1010



BORING NUMBER 1011

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
CORING NOS. 1010, 1011, AND 1012

FIGURE 2B-107

| GEOLOGIC LOG |        | BORING NO.<br>1013                                                                          | LOCATION<br>N. 39 + 95 E. 44 + 40 |               |
|--------------|--------|---------------------------------------------------------------------------------------------|-----------------------------------|---------------|
| DEPTH        | ELEV.  | VISUAL DESCRIPTION                                                                          |                                   | GEOLOGIC UNIT |
|              | 131.0  | Mottled clayey fine to coarse SAND.                                                         |                                   | UNIT 6        |
| 10           |        |                                                                                             |                                   |               |
| 20           | -112.0 | Gray and brown fine to medium sandy CLAY.                                                   |                                   | UNIT 5        |
| 30           |        |                                                                                             |                                   |               |
| 40           | -100.0 | Gray silty partially cemented fine to medium SAND with cemented clay layers.                |                                   | UNIT 4        |
| 50           |        |                                                                                             |                                   |               |
| 60           | -79.0  | Green-gray slightly clayey silty fine SAND with fine sandy clay layers and clay inclusions. |                                   | UNIT 3        |
| 70           |        |                                                                                             |                                   |               |
| 80           |        |                                                                                             |                                   | UNIT 2        |
| 90           |        |                                                                                             |                                   |               |
| 100          | -29.0  | Gray-tan fine SAND with partially cemented clay layers.                                     |                                   | UNIT 1        |
| 110          |        |                                                                                             |                                   |               |
| 120          | -18.0  | Gray-tan slightly clayey fine to medium SAND with clay inclusions.                          |                                   | UNIT 1        |
| 130          |        |                                                                                             |                                   |               |
| 140          | -3.0   | Blue-green fine sandy CLAY with fine sand seams.                                            |                                   | UNIT 1        |
| 150          |        |                                                                                             |                                   |               |
|              |        | Bottom at (-3.5) ft MSL                                                                     |                                   |               |

BORING NUMBER 1013

| GEOLOGIC LOG |        | BORING NO.<br>1014                                                                           | LOCATION<br>N. 38 + 75 E. 48 + 35 |               |
|--------------|--------|----------------------------------------------------------------------------------------------|-----------------------------------|---------------|
| DEPTH        | ELEV.  | VISUAL DESCRIPTION                                                                           |                                   | GEOLOGIC UNIT |
|              | 139.0  | Red clayey fine to coarse SAND.                                                              |                                   | UNIT 6        |
| 10           |        |                                                                                              |                                   |               |
| 20           | -132.5 | Purple and red fine to coarse sandy CLAY with fine to coarse sand seams.                     |                                   | UNIT 5        |
| 30           |        |                                                                                              |                                   |               |
| 40           | -122.0 | Tan and brown fine to medium sandy cemented CLAY.                                            |                                   | UNIT 4        |
| 50           |        |                                                                                              |                                   |               |
| 60           | -112.5 | Green-gray clayey fine to coarse partially cemented SAND with clay inclusions.               |                                   | UNIT 3        |
| 70           |        |                                                                                              |                                   |               |
| 80           | -101.5 | Gray-green fine to medium sandy cemented CLAY.                                               |                                   | UNIT 2        |
| 90           |        |                                                                                              |                                   |               |
| 100          |        |                                                                                              |                                   | UNIT 1        |
| 110          |        |                                                                                              |                                   |               |
| 120          | -82.0  | Green and gray silty slightly clayey very fine to fine SAND with clay layers and inclusions. |                                   | UNIT 1        |
| 130          |        |                                                                                              |                                   |               |
| 140          | -27.0  | Gray-tan silty slightly clayey very fine to medium SAND with clay inclusions.                |                                   | UNIT 1        |
| 150          |        |                                                                                              |                                   |               |
|              |        | Bottom at (-0.5) ft MSL                                                                      |                                   |               |

BORING NUMBER 1014

| GEOLOGIC LOG |        | BORING NO.<br>1015                                                               | LOCATION<br>N. 39 + 60 E. 51 + 30 |               |
|--------------|--------|----------------------------------------------------------------------------------|-----------------------------------|---------------|
| DEPTH        | ELEV.  | VISUAL DESCRIPTION                                                               |                                   | GEOLOGIC UNIT |
|              | 130.0  | Red, gray, and purple clayey fine to medium SAND.                                |                                   | UNIT 6        |
| 10           |        |                                                                                  |                                   |               |
| 20           | -113.0 | Green-gray fine sandy silty CLAY and clayey fine to coarse SAND.                 |                                   | UNIT 5        |
| 30           |        |                                                                                  |                                   |               |
| 40           | -89.0  | Gray clayey cemented fine to medium SAND and cemented sandy CLAY.                |                                   | UNIT 4        |
| 50           |        |                                                                                  |                                   |               |
| 60           | -78.0  | Gray and gray-green clayey fine SAND with clay inclusions and sandy clay layers. |                                   | UNIT 3        |
| 70           |        |                                                                                  |                                   |               |
| 80           |        |                                                                                  |                                   | UNIT 2        |
| 90           |        |                                                                                  |                                   |               |
| 100          | -25.0  | Green-gray cemented clayey silty fine SAND.                                      |                                   | UNIT 1        |
| 110          |        |                                                                                  |                                   |               |
| 120          | -22.0  | Gray-tan silty clayey fine SAND with clay layers and inclusions.                 |                                   | UNIT 1        |
| 130          |        |                                                                                  |                                   |               |
| 140          | -2.5   | Blue-green and gray fine sandy silty CLAY with fine sand seams.                  |                                   | UNIT 1        |
| 150          |        |                                                                                  |                                   |               |
|              |        | Bottom at (-5.5) ft MSL                                                          |                                   |               |

BORING NUMBER 1015

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NOS. 1013, 1014, AND 1015

FIGURE 2B-108

| GEOLOGIC LOG |        | BORING NO.<br>1016                                                                                       | LOCATION<br>N. 59 + 18 E. 30 + 01 |                              |
|--------------|--------|----------------------------------------------------------------------------------------------------------|-----------------------------------|------------------------------|
| DEPTH        | ELEV.  | VISUAL DESCRIPTION                                                                                       |                                   | GEOLOGIC UNIT                |
|              | 124.5  | Brown slightly clayey fine to medium SAND with organic material.                                         |                                   | ALLUVIUM                     |
| 10           | 116.5  | Gray clayey fine to medium SAND.                                                                         |                                   |                              |
|              | 108.0  | Fine sandy cemented CLAY.                                                                                |                                   | UNIT 5                       |
| 20           | 101.5  | Gray clayey fine to medium partially cemented SAND with clay inclusions.                                 |                                   |                              |
|              | 66.5   | Green-gray silty clayey very fine to fine SAND with occasional clay layers and cemented sand inclusions. |                                   | HAWTHORN FORMATION<br>UNIT 4 |
| 60           | 37.0   | Gray-tan clayey silty fine to medium SAND, cemented at top, with clay inclusions.                        |                                   |                              |
|              | 1.5    | Light green silty CLAY with fine sand seams.                                                             |                                   | UNIT 2                       |
| 120          | (-1.5) | Bottom at (-1.5) ft MSL.                                                                                 |                                   |                              |
| 130          |        |                                                                                                          |                                   | UNIT 3                       |
| 140          |        |                                                                                                          |                                   |                              |
| 150          |        |                                                                                                          |                                   |                              |

BORING NUMBER 1016

| GEOLOGIC LOG |        | BORING NO.<br>1017                                                                                      | LOCATION<br>N. 35 + 51 E. 45 + 64 |                              |
|--------------|--------|---------------------------------------------------------------------------------------------------------|-----------------------------------|------------------------------|
| DEPTH        | ELEV.  | VISUAL DESCRIPTION                                                                                      |                                   | GEOLOGIC UNIT                |
|              | 140.0  | Red, gray, and purple fine to medium sandy CLAY and clayey SAND.                                        |                                   | UNIT 6                       |
| 10           |        |                                                                                                         |                                   |                              |
|              | 116.5  | Green-gray very clayey partially cemented fine to coarse SAND with clay inclusions and fine sand seams. |                                   | UNIT 5                       |
| 20           |        |                                                                                                         |                                   |                              |
|              | 79.5   | Green-gray silty clayey very fine to medium SAND with occasional clay layers and inclusions.            |                                   | HAWTHORN FORMATION<br>UNIT 4 |
| 60           |        |                                                                                                         |                                   |                              |
|              | 29.5   | Gray-tan silty clayey fine to medium SAND with clay layers and inclusions.                              |                                   | UNIT 3                       |
| 110          |        |                                                                                                         |                                   |                              |
|              | 2.0    | Blue-green silty CLAY with fine sand lenses.                                                            |                                   | UNIT 2                       |
| 140          | (-0.5) | Bottom at (-0.5) ft MSL.                                                                                |                                   |                              |
| 150          |        |                                                                                                         |                                   |                              |

BORING NUMBER 1017

| GEOLOGIC LOG |                  | BORING NO.<br>1018                                                                  | LOCATION<br>N. 35 + 46 E. 47 + 69 |                              |
|--------------|------------------|-------------------------------------------------------------------------------------|-----------------------------------|------------------------------|
| DEPTH        | ELEV.            | VISUAL DESCRIPTION                                                                  |                                   | GEOLOGIC UNIT                |
|              | 141.5            | Red, gray, and purple clayey fine to coarse SAND.                                   |                                   | UNIT 6                       |
| 10           |                  |                                                                                     |                                   |                              |
|              | 129.5            | Red and gray fine to coarse sandy CLAY.                                             |                                   | UNIT 5                       |
| 20           |                  |                                                                                     |                                   |                              |
|              | 117.0            | Gray-green slightly fine sandy CLAY.                                                |                                   | HAWTHORN FORMATION<br>UNIT 4 |
| 30           |                  |                                                                                     |                                   |                              |
|              | 107.0            | Green-gray cemented clayey fine SAND with clay inclusions and sandy clay layers.    |                                   | UNIT 3                       |
| 40           |                  |                                                                                     |                                   |                              |
|              | 81.5             | Gray-green clayey silty fine to medium SAND with occasional cemented clay layers.   |                                   | UNIT 4                       |
| 60           |                  |                                                                                     |                                   |                              |
|              | 44.5             | Light gray fine sandy silty CLAY with fine sand seams and clay layers.              |                                   | UNIT 3                       |
| 100          |                  |                                                                                     |                                   |                              |
|              | 36.5             | Gray-tan cemented silty clayey fine to medium SAND with fine sandy clay inclusions. |                                   | UNIT 2                       |
| 110          |                  |                                                                                     |                                   |                              |
|              | (-2.5)<br>(-4.0) | Gray-green and blue-green silty CLAY with fine sand seams.                          |                                   | UNIT 2                       |
| 140          |                  |                                                                                     |                                   |                              |
| 150          |                  | Bottom at (-4.0) ft MSL.                                                            |                                   |                              |

BORING NUMBER 1018


HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NOS. 1016, 1017, AND 1018


FIGURE 2B-109



BORING NUMBER 1021



BORING NUMBER 1019



BORING NUMBER 1020

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NOS. 1019, 1020, AND 1021

FIGURE 2B-110



| GEOLOGIC LOG |        | BORING NO.                                                                       | LOCATION              |
|--------------|--------|----------------------------------------------------------------------------------|-----------------------|
|              |        | 1022                                                                             | N. 41 + 25 E. 43 + 10 |
| DEPTH        | ELEV.  | VISUAL DESCRIPTION                                                               | GEOLOGIC UNIT         |
|              | 132.5  | Light gray clayey cemented fine to coarse <u>SAND</u> .                          | UNIT 6                |
| 10           |        |                                                                                  |                       |
|              | -117.5 | Gray-green fine sandy <u>CLAY</u> with cemented clay inclusions.                 | UNIT 5                |
| 20           | -111.5 | Light gray slightly clayey partially cemented fine to medium <u>SAND</u> .       |                       |
| 30           |        |                                                                                  |                       |
| 40           |        |                                                                                  |                       |
| 50           |        |                                                                                  |                       |
|              | 78.0   | Gray fine sandy silty <u>CLAY</u> with clayey sand seams.                        | UNIT 4                |
| 60           |        |                                                                                  |                       |
|              | 67.5   | Green-gray silty clayey very fine to fine <u>SAND</u> with some clay inclusions. |                       |
| 70           |        |                                                                                  |                       |
| 80           |        |                                                                                  |                       |
| 90           |        |                                                                                  |                       |
|              | 33.5   | Gray-tan silty clayey fine to medium <u>SAND</u> with some clay inclusions.      | UNIT 3                |
| 100          |        |                                                                                  |                       |
| 110          |        |                                                                                  |                       |
|              | 11.5   | Blue-green fine sandy silty <u>CLAY</u> with fine sand seams.                    | UNIT 2                |
| 120          |        |                                                                                  |                       |
|              | 2.0    | Bottom at 2.5 ft MSL                                                             |                       |
| 130          |        |                                                                                  |                       |
| 140          |        |                                                                                  |                       |
| 150          |        |                                                                                  |                       |

BORING NUMBER 1022

| GEOLOGIC LOG |        | BORING NO.                                                                                                             | LOCATION              |
|--------------|--------|------------------------------------------------------------------------------------------------------------------------|-----------------------|
|              |        | 1023                                                                                                                   | N. 43 + 30 E. 49 + 70 |
| DEPTH        | ELEV.  | VISUAL DESCRIPTION                                                                                                     | GEOLOGIC UNIT         |
|              | 134.0  | Red, brown, and gray clayey fine to medium <u>SAND</u> .                                                               | UNIT 6                |
| 10           | -125.0 | Purple slightly clayey to clayey fine to coarse <u>SAND</u> .                                                          |                       |
| 20           |        |                                                                                                                        |                       |
|              | -105.0 | Green-gray clayey fine to coarse <u>SAND</u> .                                                                         | UNIT 5                |
| 30           | -100.0 | Gray clayey fine <u>SAND</u> with sandy clay layers and inclusions.                                                    |                       |
| 40           |        |                                                                                                                        |                       |
| 50           |        |                                                                                                                        |                       |
|              | 81.0   | Gray clayey fine to medium partially cemented <u>SAND</u> .                                                            | UNIT 4                |
| 60           |        |                                                                                                                        |                       |
|              | 70.0   | Green-gray clayey silty very fine to fine <u>SAND</u> with cemented clay layers, clay inclusions, and fine sand seams. |                       |
| 70           |        |                                                                                                                        |                       |
| 80           |        |                                                                                                                        |                       |
| 90           |        |                                                                                                                        |                       |
|              | 27.0   | Green-gray silty clayey fine to medium <u>SAND</u> with some partially cemented clay inclusions.                       | UNIT 3                |
| 100          |        |                                                                                                                        |                       |
| 110          |        |                                                                                                                        |                       |
|              | 1.0    | Blue-green silty <u>CLAY</u> with partially cemented fine sand seams.                                                  | UNIT 2                |
| 120          |        |                                                                                                                        |                       |
|              | (-1.5) | Bottom at (-1.5) ft MSL                                                                                                |                       |
| 130          |        |                                                                                                                        |                       |
| 140          |        |                                                                                                                        |                       |
| 150          |        |                                                                                                                        |                       |

BORING NUMBER 1023

| GEOLOGIC LOG |        | BORING NO.                                                                                                          | LOCATION              |
|--------------|--------|---------------------------------------------------------------------------------------------------------------------|-----------------------|
|              |        | 1024                                                                                                                | N. 37 + 51 E. 43 + 09 |
| DEPTH        | ELEV.  | VISUAL DESCRIPTION                                                                                                  | GEOLOGIC UNIT         |
|              | 145.5  | Gray, purple, and red clayey fine to coarse <u>SAND</u> .                                                           | UNIT 6                |
| 10           | -133.5 | Red and gray fine sandy <u>CLAY</u> .                                                                               |                       |
| 20           |        |                                                                                                                     |                       |
|              | -122.0 | Green-gray and gray very clayey partially cemented fine <u>SAND</u> with partially cemented fine sandy clay layers. | UNIT 5                |
| 30           |        |                                                                                                                     |                       |
| 40           |        |                                                                                                                     |                       |
| 50           |        |                                                                                                                     |                       |
|              | 78.5   | Green-gray silty slightly clayey very fine to fine <u>SAND</u> with sandy clay layers and clay inclusions.          | UNIT 4                |
| 60           |        |                                                                                                                     |                       |
| 70           |        |                                                                                                                     |                       |
| 80           |        |                                                                                                                     |                       |
| 90           |        |                                                                                                                     |                       |
|              | 28.5   | Gray-tan clayey silty fine to medium <u>SAND</u> .                                                                  | UNIT 3                |
| 100          |        |                                                                                                                     |                       |
| 110          |        |                                                                                                                     |                       |
|              | 3.0    | Blue-green very clayey fine to medium <u>SAND</u> with clay layers.                                                 | UNIT 2                |
| 120          |        |                                                                                                                     |                       |
|              | 0      | Bottom at 0 ft MSL                                                                                                  |                       |
| 130          |        |                                                                                                                     |                       |
| 140          |        |                                                                                                                     |                       |
| 150          |        |                                                                                                                     |                       |

BORING NUMBER 1024

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NOS. 1022, 1023, AND 1024

FIGURE 2B-111

| GEOLOGIC LOG       |       | BORING NO.                                                                             | LOCATION              |        |  |
|--------------------|-------|----------------------------------------------------------------------------------------|-----------------------|--------|--|
| DEPTH              | ELEV. | 1025                                                                                   | N. 37 + 12 E. 47 + 37 |        |  |
| VISUAL DESCRIPTION |       |                                                                                        | GEOLOGIC UNIT         |        |  |
|                    | 143.5 |                                                                                        |                       |        |  |
|                    |       | Red, gray, and purple fine sandy <u>CLAY</u> .                                         |                       |        |  |
| 10                 | 137.0 | Red, gray, and purple very clayey fine to medium <u>SAND</u> .                         |                       | UNIT 6 |  |
|                    | 128.5 | Red and purple fine sandy <u>CLAY</u> .                                                |                       |        |  |
| 20                 | 122.5 | Gray clayey fine to coarse partially cemented <u>SAND</u> with some clay layers.       |                       | UNIT 5 |  |
|                    | 96.0  | Gray-green slightly fine sandy cemented <u>CLAY</u> .                                  |                       |        |  |
|                    | 90.5  | Green-gray clayey fine to medium <u>SAND</u> with clay inclusions.                     |                       |        |  |
| 60                 | 81.5  | Green-gray silty clayey very fine to fine <u>SAND</u> with clay layers and inclusions. |                       | UNIT 4 |  |
|                    | 42.0  | Green-gray silty partially cemented <u>CLAY</u> with fine sand seams.                  |                       |        |  |
| 110                | 32.5  | Green-gray clayey fine <u>SAND</u> with clay inclusions.                               |                       |        |  |
| 120                | 26.5  | Gray-tan silty clayey fine to medium <u>SAND</u> with clay layers and inclusions.      |                       | UNIT 3 |  |
| 130                | 5.5   | Blue-green fine sandy silty <u>CLAY</u> .                                              |                       | UNIT 2 |  |
| 140                | 3.0   | Bottom at 3.0 ft MSL                                                                   |                       |        |  |

BORING NUMBER 1025

| GEOLOGIC LOG       |       | BORING NO.                                                                                                               | LOCATION              |        |  |
|--------------------|-------|--------------------------------------------------------------------------------------------------------------------------|-----------------------|--------|--|
| DEPTH              | ELEV. | 1026                                                                                                                     | N. 39 + 82 E. 41 + 33 |        |  |
| VISUAL DESCRIPTION |       |                                                                                                                          | GEOLOGIC UNIT         |        |  |
|                    | 132.0 |                                                                                                                          |                       |        |  |
|                    |       | Red, brown, purple, and gray clayey fine to medium <u>SAND</u> and sandy <u>CLAY</u> .                                   |                       |        |  |
| 10                 |       |                                                                                                                          |                       | UNIT 6 |  |
|                    | 113.5 | Gray partially cemented clayey fine <u>SAND</u> .                                                                        |                       |        |  |
| 20                 |       |                                                                                                                          |                       | UNIT 5 |  |
|                    | 79.5  | Green-gray slightly clayey very fine to fine <u>SAND</u> and silty <u>CLAY</u> with clay inclusions and fine sand seams. |                       |        |  |
| 60                 |       | partially cemented, 74.0' - 78.0'                                                                                        |                       | UNIT 4 |  |
|                    | 30.5  | Gray-tan very fine to fine <u>SAND</u> with clay layers and partially cemented sand layers.                              |                       |        |  |
| 110                | 19.5  | Gray-tan fine to medium <u>SAND</u> with clay inclusions and some cemented sand seams.                                   |                       | UNIT 3 |  |
| 120                |       |                                                                                                                          |                       |        |  |
| 130                | 5.0   | Blue-green fine sandy silty <u>CLAY</u> with fine sand seams.                                                            |                       | UNIT 2 |  |
| 130                | 1.5   | Bottom at 1.5 ft MSL                                                                                                     |                       |        |  |

BORING NUMBER 1026

| GEOLOGIC LOG       |       | BORING NO.                                                                                      | LOCATION              |        |  |
|--------------------|-------|-------------------------------------------------------------------------------------------------|-----------------------|--------|--|
| DEPTH              | ELEV. | 1028                                                                                            | N. 62 + 05 E. 31 + 66 |        |  |
| VISUAL DESCRIPTION |       |                                                                                                 | GEOLOGIC UNIT         |        |  |
|                    | 134.0 |                                                                                                 |                       |        |  |
|                    |       | Gray, brown, and red clayey fine to medium <u>SAND</u> with clay layers.                        |                       |        |  |
| 10                 |       |                                                                                                 |                       | UNIT 6 |  |
|                    | 122.0 | Gray fine sandy clayey partially cemented <u>SILT</u> .                                         |                       |        |  |
| 20                 | 111.5 | Gray clayey fine <u>SAND</u> and fine sandy silty partially cemented <u>CLAY</u> .              |                       |        |  |
| 30                 |       |                                                                                                 |                       | UNIT 5 |  |
|                    | 97.0  | Gray slightly clayey cemented fine <u>SAND</u> .                                                |                       |        |  |
| 40                 |       |                                                                                                 |                       |        |  |
|                    | 81.0  | Gray slightly clayey fine to medium <u>SAND</u> with clay inclusions.                           |                       |        |  |
| 60                 |       |                                                                                                 |                       |        |  |
|                    | 62.0  | Green-gray slightly clayey silty very fine to fine <u>SAND</u> with clay layers and inclusions. |                       | UNIT 4 |  |
| 80                 |       |                                                                                                 |                       |        |  |
|                    | 36.0  | Gray-tan slightly clayey fine <u>SAND</u> with clay inclusions.                                 |                       |        |  |
| 100                |       |                                                                                                 |                       | UNIT 3 |  |
| 110                |       |                                                                                                 |                       |        |  |
|                    | 16.0  | Light green slightly fine sandy very silty <u>CLAY</u> with very fine to fine sand seams.       |                       | UNIT 2 |  |
| 120                |       |                                                                                                 |                       |        |  |
| 130                | 3.5   | Bottom at 3.5 ft MSL                                                                            |                       |        |  |

BORING NUMBER 1028

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2


TEST BORING RECORD  
BORING NOS. 1025, 1026, AND 1028

FIGURE 2B-112

DEPTH  
FEET

DESCRIPTION

ELEV. PENETRATION-BLOWS PER FOOT  
0 5 10 15 20 30 40 60 80 100



REMARKS: \*PLASTIC CLAY LAYERS AND INCLUSIONS

N- 51+58  
E- 49+99

BORING NUMBER RFI-1  
DATE DRILLED 10-6-71  
JOB NUMBER 5056

ACAD

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. RFI-1


FIGURE 2B-113

DEPTH  
FEET

DESCRIPTION

ELEV. PENETRATION-BLOWS PER FOOT  
0 5 10 15 20 30 40 60 80 100

73.7



REMARKS: \*WITH GREEN PLASTIC CLAY LAYERS AND INCLUSIONS N- 51+58  
 \*\*PLASTIC CLAY LAYERS AND INCLUSIONS E- 50+57

BORING NUMBER RFI-2  
 DATE DRILLED 10-4-71  
 JOB NUMBER 5056

ACAD


HISTORICAL  
 REV 19 7/01

**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
 UNIT 2

TEST BORING RECORD  
 BORING NO. RFI-2

FIGURE 2B-114

DEPTH DESCRIPTION ELEV. PENETRATION-BLOWS PER FOOT  
 FEET O 5 10 15 20 30 40 60 80 100



REMARKS: \*LAYERS AND INCLUSIONS

N-51+22  
 E-49+70

BORING NUMBER RFI-3  
 DATE DRILLED 10-6-71  
 JOB NUMBER 5056

ACAD

HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2


TEST BORIN RECORD  
 BORING NO. RFI-3

FIGURE 2B-115

DEPTH  
FEET

DESCRIPTION

ELEV. PENETRATION-BLOWS PER FOOT  
0 5 10 15 20 30 40 60 80 100



REMARKS: \*INCLUSIONS

N-51+22  
E-50+28

BORING NUMBER RFI-4  
DATE DRILLED 10/11/71  
JOB NUMBER 5056

ACAD

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2


TEST BORING RECORD  
BORING NO. RFI-4

FIGURE 2B-116

DEPTH  
FEET

DESCRIPTION

ELEV. PENETRATION-BLOWS PER FOOT  
0 5 10 15 20 30 40 50 60 70 100



REMARKS:

N-51+22  
E-50+85

BORING NUMBER RFI-5  
DATE DRILLED 10/11/77  
JOB NUMBER 5056

ACAD

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2


TEST BORING RECORD  
BORING NO. RFI-5

FIGURE 2B-117

DEPTH  
FEET

DESCRIPTION

ELEV. PENETRATION-BLOWS PER FOOT  
0 5 10 15 20 30 40 60 80 100



REMARKS:

N-50+86  
C-49+99

BORING NUMBER RFI-6  
DATE DRILLED 10/7/71  
JOB NUMBER 5056

ACAD

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. RFI-6


FIGURE 2B-118



DEPTH  
FEET

DESCRIPTION

ELEV. PENETRATION-BLOWS PER FOOT  
0 5 10 15 20 30 40 60 80 100



REMARKS:

N-50+86  
E-50+57

BORING NUMBER RFI-7  
DATE DRILLED 10/8/71  
JOB NUMBER 5056

ACAD

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. RFI-7


FIGURE 2B-119

DEPTH  
FEET

DESCRIPTION

ELEV. PENETRATION-BLOWS PER FOOT  
0 5 10 15 20 30 40 60 80 100

77.0



REMARKS:

N-50+50  
E-49+70

BORING NUMBER RFI-8  
DATE DRILLED 10/4/71  
JOB NUMBER 5056

ACAD

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2


TEST BORING RECORD  
BORING NO. RFI-8

FIGURE 2B-120

DEPTH  
FEET

DESCRIPTION

ELEV. PENETRATION-BLOWS PER FOOT  
0 5 10 15 20 30 40 50 60 70 80 90 100



REMARKS:

N-50+50  
E-50+28

BORING NUMBER RFI-9  
DATE DRILLED 10/7/71  
JOB NUMBER 5056

ACAD

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2


TEST BORING RECORD  
BORING NO. RFI-9

FIGURE 2B-121

DEPTH  
FEET

DESCRIPTION

ELEV. PENETRATION-BLOWS PER FOOT  
0 5 10 15 20 30 40 60 80 100



REMARKS: \*SAND SEAMS

N-50+50  
E-50+85

BORING NUMBER RFI-10  
DATE DRILLED 10/12/71  
JOB NUMBER 5056

ACAD

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2


TEST BORING RECORD  
BORING NO. RFI-10

FIGURE 2B-122

DEPTH  
FEET

DESCRIPTION

ELEV. PENETRATION-BLOWS PER FOOT  
0 5 10 15 20 30 40 50 60 100



REMARKS: \*GRAY CLAY LAYERS

N- 52+53  
E- 56+86

BORING NUMBER B-646  
DATE DRILLED 10-15-71  
JOB NUMBER 5056

ACAD

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2


TEST BORING RECORD  
BORING NO. B-646

FIGURE 2B-123

DEPTH  
FEET

DESCRIPTION

ELEV. PENETRATION-BLOWS PER FOOT  
0 5 10 15 20 30 40 50 60 100



REMARKS: \*CLAYEY FINE SAND WITH GRAY GREEN CLAY LAYERS  
\*\*LAYERS AND INCLUSIONS

H- 52+69  
E- 56\_67

BORING NUMBER B-647  
DATE DRILLED 10-21/22-71  
JOB NUMBER 5056

ACAD

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2


TEST BORING RECORD  
BORING NO. B-647

FIGURE 2B-124

DEPTH  
FEET

DESCRIPTION

ELEV. PENETRATION-BLOWS PER FOOT  
0 5 10 15 20 30 40 60 80 100



N- 51+66  
E- 55+70

BORING NUMBER B-648  
DATE DRILLED 10-25/26-71  
JOB NUMBER 5056

ACAD

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2


TEST BORING RECORD  
BORING NO. B-648

FIGURE 2B-125

DEPTH  
FEET

DESCRIPTION

ELEV. PENETRATION-BLOWS PER FOOT  
0 5 10 15 20 30 40 60 80 100



REMARKS:

N- 51+30  
E- 56+37

BORING NUMBER B-649  
DATE DRILLED 10-71  
JOB NUMBER 5056

ACAD

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. B-649

FIGURE 2B-126






REMARKS: \* LAYERS

DRILLED BY \_\_\_\_\_  
 LOGGED BY \_\_\_\_\_  
 CHECKED BY \_\_\_\_\_  
 COORDINATES: N-52+30  
 E-55+20

BORING NUMBER B-650  
 DATE STARTED \_\_\_\_\_  
 DATE COMPLETED 4/8&9/72  
 JOB NUMBER 5056



REMARKS:

DRILLED BY \_\_\_\_\_  
 LOGGED BY \_\_\_\_\_  
 CHECKED BY \_\_\_\_\_  
 COORDINATES: N-52+30  
 E-55+20

BORING NUMBER B-650  
 DATE STARTED \_\_\_\_\_  
 DATE COMPLETED 4/8&9/72  
 JOB NUMBER 5056


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. B-650

FIGURE 2B-127




REMARKS:

DRILLED BY \_\_\_\_\_  
 LOGGED BY \_\_\_\_\_  
 CHECKED BY \_\_\_\_\_

BORING NUMBER B-651  
 DATE STARTED 4/7&8/72  
 DATE COMPLETED 5056  
 JOB NUMBER \_\_\_\_\_

COORDINATES: N-51+35  
 E-55+20



REMARKS: \* CLAY INCLUSIONS

DRILLED BY \_\_\_\_\_  
 LOGGED BY \_\_\_\_\_  
 CHECKED BY \_\_\_\_\_

BORING NUMBER B-651  
 DATE STARTED 4/7&8/72  
 DATE COMPLETED 5056  
 JOB NUMBER \_\_\_\_\_

COORDINATES: N-51+35  
 E-55+20

HISTORICAL  
 REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TEST BORING RECORD  
 BORING NO. B-651

FIGURE 2B-128

| BORING LOG             |           | PROJECT                                   | JOB NO.              | SHEET NO.                         | BORING NO.     |                          |                         |    |    |     |      |    |
|------------------------|-----------|-------------------------------------------|----------------------|-----------------------------------|----------------|--------------------------|-------------------------|----|----|-----|------|----|
| BLUFFS AT RIVER        |           | HATCH UNITS 1 & 2                         | 6511                 | 1 OF 2                            | B-2001         |                          |                         |    |    |     |      |    |
| LOCATION               |           | COORDINATES                               |                      | ANGLE FROM HORIZ.                 | BEARING        |                          |                         |    |    |     |      |    |
| BLUFFS AT RIVER        |           | N 64 + 31 E 40 + 27                       |                      | 90°                               |                |                          |                         |    |    |     |      |    |
| BEGIN                  | COMPLETED | DRILLER                                   | DRILL MAKE AND MODEL | HOLE SIZE                         | OVERBURDEN FT. | ROCK (FT.)               | TOTAL DEPTH             |    |    |     |      |    |
| 6-9-76                 | 6-9-76    | LETCo. - C. Ivey                          | CME - 55             | 5"                                | 100.5          |                          | 100.5                   |    |    |     |      |    |
| CORE RECOVERY (FT/%)   |           | CORE BOXES                                | SAMPLES              | EL. TOP CASING                    | GROUND EL.     | DEPTH / EL. GROUND WATER | DEPTH / EL. TOP OF ROCK |    |    |     |      |    |
|                        |           | 20                                        | 20                   | 121.7                             | 121.7          | 31.3/90.6 @ 24 hr.       |                         |    |    |     |      |    |
| SAMPLE HAMMER WY./FALL |           | CASING LEFT IN HOLE: DIA. / LENGTH        |                      | LOGGED BY:                        |                |                          |                         |    |    |     |      |    |
| 2 in. O.D. 140#/30"    |           |                                           |                      | H. BIZNDY                         |                |                          |                         |    |    |     |      |    |
| ELEV.                  | DEPTH     | DESCRIPTION - VISUAL                      | GRAPHIC LOG          | PENETRATION RESISTANCE BLOWS/FOOT |                |                          |                         | N  |    |     |      |    |
| 121.7                  |           | Red-Tan-Gray Sandy Silty CLAY             |                      | 0                                 | 10             | 20                       | 30                      | 50 | 70 | 100 | +100 |    |
|                        | 5         |                                           |                      |                                   |                |                          |                         |    |    |     |      |    |
| 111.7                  | 10        |                                           |                      |                                   |                |                          |                         |    |    |     |      |    |
|                        | 15        |                                           |                      |                                   |                |                          |                         |    |    |     |      |    |
| 101.7                  | 20        | Tan Gray Clayey coarse to fine SAND       |                      |                                   |                |                          |                         |    |    |     |      |    |
|                        | 25        | Tan Gray Sandy Silty CLAY                 |                      |                                   |                |                          |                         |    |    |     |      |    |
| 91.7                   | 30        | Tan Gray Clayey Silty coarse to fine SAND |                      |                                   |                |                          |                         |    |    |     |      |    |
|                        | 35        | (cemented)                                |                      |                                   |                |                          |                         |    |    |     |      |    |
| 81.7                   | 40        | (cemented)                                |                      |                                   |                |                          |                         |    |    |     |      |    |
|                        | 45        |                                           |                      |                                   |                |                          |                         |    |    |     |      |    |
| 71.7                   | 50        | Tan Gray Clayey fine SAND                 |                      |                                   |                |                          |                         |    |    |     |      | 45 |
|                        | 55        | Light Gray Green Clayey Silty fine SAND   |                      |                                   |                |                          |                         |    |    |     |      | 10 |
| 61.7                   | 60        |                                           |                      |                                   |                |                          |                         |    |    |     |      | 8  |
|                        | 65        | (clay inclusions)                         |                      |                                   |                |                          |                         |    |    |     |      | 4  |
| REMARKS                |           | LOCATION                                  |                      | BORING NO.                        |                |                          |                         |    |    |     |      |    |
|                        |           | BLUFFS AT RIVER                           |                      | B-2001                            |                |                          |                         |    |    |     |      |    |

| BORING LOG      |       | PROJECT                                                 | JOB NO.     | SHEET NO.                         | BORING NO. |    |    |    |    |     |      |    |
|-----------------|-------|---------------------------------------------------------|-------------|-----------------------------------|------------|----|----|----|----|-----|------|----|
| BLUFFS AT RIVER |       | HATCH UNITS 1 & 2                                       | 6511        | 2 OF 2                            | B-2001     |    |    |    |    |     |      |    |
| ELEV.           | DEPTH | DESCRIPTION - VISUAL                                    | GRAPHIC LOG | PENETRATION RESISTANCE BLOWS/FOOT |            |    |    | N  |    |     |      |    |
| 51.7            | 70    | Light Gray Green Clayey Silty fine SAND                 |             | 0                                 | 10         | 20 | 30 | 50 | 70 | 100 | +100 | 4  |
|                 | 75    |                                                         |             |                                   |            |    |    |    |    |     |      | 2  |
| 41.7            | 80    | Light Gray Green fine SAND (clay inclusions)            |             |                                   |            |    |    |    |    |     |      | 3  |
|                 | 85    |                                                         |             |                                   |            |    |    |    |    |     |      | 4  |
| 31.7            | 90    | (clay inclusions)                                       |             |                                   |            |    |    |    |    |     |      | 25 |
|                 | 95    | Light Tan Gray Clayey Silty fine SAND (clay inclusions) |             |                                   |            |    |    |    |    |     |      | 12 |
|                 |       | Light Tan Gray Silty fine SAND                          |             |                                   |            |    |    |    |    |     |      | 34 |
| 21.7            | 100   | Boring terminated 6-9-76                                |             |                                   |            |    |    |    |    |     |      | 43 |
| REMARKS         |       | LOCATION                                                |             | BORING NO.                        |            |    |    |    |    |     |      |    |
|                 |       | BLUFFS AT RIVER                                         |             | 2001                              |            |    |    |    |    |     |      |    |

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. B-2001

FIGURE 2B-129

| BORING LOG             |            | PROJECT                                                | JOB NO.              | SHEET NO.                         | BORING NO.               |                         |             |    |    |     |      |                          |
|------------------------|------------|--------------------------------------------------------|----------------------|-----------------------------------|--------------------------|-------------------------|-------------|----|----|-----|------|--------------------------|
| BLUFFS AT RIVER        |            | HATCH UNITS 1 & 2                                      | 6511                 | 1 OF 2                            | 2001A                    |                         |             |    |    |     |      |                          |
| COORDINATES            |            | ANGLE FROM HORIZ.                                      |                      | BEARING                           |                          |                         |             |    |    |     |      |                          |
| N 64 + 31 E 40 + 23    |            | 90°                                                    |                      |                                   |                          |                         |             |    |    |     |      |                          |
| BEGIN                  | COMPLETED  | DRILLER                                                | DRILL MAKE AND MODEL | HOLE SIZE                         | OVERBURDEN FT.           | ROCK (FT.)              | TOTAL DEPTH |    |    |     |      |                          |
| 6-18-76                | 6-20-76    | LETCo - C. Ivey                                        | CME - 55             | 6"                                |                          |                         | 102.5       |    |    |     |      |                          |
| CORE RECOVERY (F77%)   | CORE BOXES | SAMPLES                                                | EL. TOP CASING       | GROUND EL.                        | DEPTH / EL. GROUND WATER | DEPTH / EL. TOP OF ROCK |             |    |    |     |      |                          |
|                        |            |                                                        | 121.7                |                                   | N.A.                     |                         |             |    |    |     |      |                          |
| SAMPLE HAMMER WT./FALL |            | CASING LEFT IN HOLE: DIA. / LENGTH                     |                      | LOGGED BY:                        |                          |                         |             |    |    |     |      |                          |
| U.D. SAMPLES           |            |                                                        |                      | M. BLENDY                         |                          |                         |             |    |    |     |      |                          |
| ELEV.                  | DEPTH      | DESCRIPTION - VISUAL                                   | GRAPHIC LOG          | PENETRATION RESISTANCE BLOWS/FOOT |                          |                         |             | N  |    |     |      |                          |
| 121.7                  |            |                                                        |                      | 0                                 | 10                       | 20                      | 30          | 50 | 70 | 100 | +100 |                          |
|                        | 5          |                                                        |                      |                                   |                          |                         |             |    |    |     |      |                          |
|                        | 10         | Red - Brown - Gray Sandy Silty CLAY                    |                      |                                   |                          |                         |             |    |    |     |      | UD - 1 (Shelby Tube)     |
|                        | 15         |                                                        |                      |                                   |                          |                         |             |    |    |     |      |                          |
|                        | 20         | Red - Gray Clayey coarse to fine SAND                  |                      |                                   |                          |                         |             |    |    |     |      | UD - 2 (Shelby Tube)     |
|                        | 25         |                                                        |                      |                                   |                          |                         |             |    |    |     |      |                          |
|                        | 30         | Tan - Gray Clayey Silty coarse to fine SAND (cemented) |                      |                                   |                          |                         |             |    |    |     |      | UD - 3 (Pitcher Sampler) |
|                        | 35         |                                                        |                      |                                   |                          |                         |             |    |    |     |      |                          |
|                        | 40         | Tan - Gray Clayey Silty coarse to fine SAND (cemented) |                      |                                   |                          |                         |             |    |    |     |      | UD - 4 (Pitcher Sampler) |
|                        | 45         |                                                        |                      |                                   |                          |                         |             |    |    |     |      |                          |
|                        | 50         | Light Tan Gray Green medium to fine SAND               |                      |                                   |                          |                         |             |    |    |     |      | UD - 5 (Pitcher Sampler) |
|                        | 55         | Light Gray Green Slightly Clayey Silty fine SAND       |                      |                                   |                          |                         |             |    |    |     |      | UD - 6 (Piston Sampler)  |
|                        | 60         | Light Tan Gray Green Clayey Silty fine SAND            |                      |                                   |                          |                         |             |    |    |     |      | UD - 7 (Shelby Tube)     |
| REMARKS                |            | LOCATION                                               |                      |                                   |                          | BORING NO.              |             |    |    |     |      |                          |
|                        |            | BLUFFS AT RIVER                                        |                      |                                   |                          | B-2001A                 |             |    |    |     |      |                          |

| BORING LOG      |       | PROJECT                                   | JOB NO.     | SHEET NO.                         | BORING NO. |            |    |    |    |     |      |                           |
|-----------------|-------|-------------------------------------------|-------------|-----------------------------------|------------|------------|----|----|----|-----|------|---------------------------|
| BLUFFS AT RIVER |       | HATCH UNITS 1 & 2                         | 6511        | 2 OF 2                            | 2001A      |            |    |    |    |     |      |                           |
| ELEV.           | DEPTH | DESCRIPTION - VISUAL                      | GRAPHIC LOG | PENETRATION RESISTANCE BLOWS/FOOT |            |            |    | N  |    |     |      |                           |
| 65              |       |                                           |             | 0                                 | 10         | 20         | 30 | 50 | 70 | 100 | +100 |                           |
| 51.7            | 70    | Light Tan Green Clayey Silty fine SAND    |             |                                   |            |            |    |    |    |     |      | UD - 8 (Pitcher Sampler)  |
|                 | 75    | Light Gray Green Slightly Silty fine SAND |             |                                   |            |            |    |    |    |     |      | UD - 9 (Pitcher Sampler)  |
| 41.7            | 80    | Light Gray Green Slightly Silty fine SAND |             |                                   |            |            |    |    |    |     |      | UD - 10 (Pitcher Sampler) |
|                 | 85    | Light Tan Gray Silty Clayey fine SAND     |             |                                   |            |            |    |    |    |     |      | UD - 11 (Pitcher Sampler) |
| 31.7            | 90    | Light Tan Gray Silty fine SAND            |             |                                   |            |            |    |    |    |     |      | UD - 12 (Pitcher Sampler) |
|                 | 95    |                                           |             |                                   |            |            |    |    |    |     |      |                           |
| 21.7            | 100   | Tan Gray Slightly Clayey Silty fine SAND  |             |                                   |            |            |    |    |    |     |      | UD - 13 (Pitcher Sampler) |
| REMARKS         |       | LOCATION                                  |             |                                   |            | BORING NO. |    |    |    |     |      |                           |
|                 |       | BLUFFS AT RIVER                           |             |                                   |            | 2001 A     |    |    |    |     |      |                           |



HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
CORING NO. B-2001A

FIGURE 2B-130



HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. B-2002

FIGURE 2B-131

| BORING LOG                  |            | PROJECT<br>HATCH UNITS 1 & 2                                              |                      | JOB NO.<br>6511                      |                          | SHEET NO.<br>1 OF 2     |             | BORING NO.<br>2003 |    |          |       |
|-----------------------------|------------|---------------------------------------------------------------------------|----------------------|--------------------------------------|--------------------------|-------------------------|-------------|--------------------|----|----------|-------|
| LOCATION<br>BLUFFS AT RIVER |            | COORDINATES<br>N 62 + 95 E 40 + 38                                        |                      | ANGLE FROM HORIZ.<br>90°             |                          | BEARING                 |             |                    |    |          |       |
| BEGUN                       | COMPLETED  | DRILLER                                                                   | DRILL MAKE AND MODEL | HOLE SIZE                            | OVERBURDEN FT            | ROCK (FT.)              | TOTAL DEPTH |                    |    |          |       |
| 6-11-76                     | 6-14-76    | LZCo - C. Ivey                                                            | CHE - 55             | 5"                                   | 120.5                    |                         | 120.5       |                    |    |          |       |
| CORE RECOVERY (FT/%)        | CORE BOXES | SAMPLES                                                                   | EL. TOP CASING       | GROUND EL.                           | DEPTH / EL. GROUND WATER | DEPTH / EL. TOP OF ROCK |             |                    |    |          |       |
|                             |            | 24                                                                        |                      | 127.8                                | 34' / 93.8 @ 24 hr.      |                         |             |                    |    |          |       |
| SAMPLE HAMMER WT./FALL      |            | CASING LEFT IN HOLE: DIA. / LENGTH                                        |                      | LOGGED BY:                           |                          |                         |             |                    |    |          |       |
| 2 in. O.D. 140#/30"         |            |                                                                           |                      | M. BLENDY                            |                          |                         |             |                    |    |          |       |
| ELEV.                       | DEPTH      | DESCRIPTION - VISUAL                                                      | GRAPHIC LOG          | PENETRATION RESISTANCE<br>BLOWS/FOOT |                          |                         |             |                    | N  |          |       |
|                             |            |                                                                           |                      | 0                                    | 10                       | 20                      | 30          | 50                 | 70 | 100 +100 |       |
| 127.8                       |            |                                                                           |                      |                                      |                          |                         |             |                    |    |          |       |
|                             | 5          | Red Brown Clayey coarse to fine SAND (Trace gravel)                       |                      |                                      |                          |                         |             |                    |    |          | 13    |
| 117.8                       | 10         |                                                                           |                      |                                      |                          |                         |             |                    |    |          | 17    |
|                             | 15         | Purple, Brown, and Gray Sandy Silty CLAY                                  |                      |                                      |                          |                         |             |                    |    |          | 17    |
| 107.8                       | 20         | Tan Gray Sandy Silty CLAY                                                 |                      |                                      |                          |                         |             |                    |    |          | 16    |
|                             | 25         |                                                                           |                      |                                      |                          |                         |             |                    |    |          | 11    |
| 97.8                        | 30         |                                                                           |                      |                                      |                          |                         |             |                    |    |          | 11    |
|                             | 35         | Gray Clayey Silty medium to fine SAND (cemented)                          |                      |                                      |                          |                         |             |                    |    |          | 35/1" |
| 87.8                        | 40         | (cemented)                                                                |                      |                                      |                          |                         |             |                    |    |          | 63/6" |
|                             | 45         | Light Tan Gray Silty medium to fine SAND and Tan Gray coarse to fine SAND |                      |                                      |                          |                         |             |                    |    |          | 60    |
| 77.8                        | 50         |                                                                           |                      |                                      |                          |                         |             |                    |    |          | 45    |
|                             | 55         |                                                                           |                      |                                      |                          |                         |             |                    |    |          | 89    |
| 67.8                        | 60         |                                                                           |                      |                                      |                          |                         |             |                    |    |          | 54    |
|                             | 65         |                                                                           |                      |                                      |                          |                         |             |                    |    |          | 73    |
| REMARKS                     |            | LOCATION<br>BLUFFS AT RIVER                                               |                      |                                      |                          | BORING NO.<br>2003      |             |                    |    |          |       |

| BORING LOG |       | PROJECT<br>HATCH UNITS 1 & 2                                              |             | JOB NO.<br>6511                      |    | SHEET NO.<br>2 OF 2 |    | BORING NO.<br>2003 |    |          |    |
|------------|-------|---------------------------------------------------------------------------|-------------|--------------------------------------|----|---------------------|----|--------------------|----|----------|----|
| ELEV.      | DEPTH | DESCRIPTION - VISUAL                                                      | GRAPHIC LOG | PENETRATION RESISTANCE<br>BLOWS/FOOT |    |                     |    |                    | N  |          |    |
|            |       |                                                                           |             | 0                                    | 10 | 20                  | 30 | 50                 | 70 | 100 +100 |    |
| 65         |       | Light Tan Gray Silty medium to fine SAND and Tan Gray coarse to fine SAND |             |                                      |    |                     |    |                    |    |          | 73 |
| 57.8       | 70    |                                                                           |             |                                      |    |                     |    |                    |    |          | 70 |
|            | 75    |                                                                           |             |                                      |    |                     |    |                    |    |          | 31 |
| 47.8       | 80    | Light Gray Green Clayey Silty fine SAND (clay inclusions)                 |             |                                      |    |                     |    |                    |    |          | 4  |
|            | 85    | (clay inclusions)                                                         |             |                                      |    |                     |    |                    |    |          |    |
| 37.8       | 90    | (clay, inclusions)                                                        |             |                                      |    |                     |    |                    |    |          | 12 |
|            | 95    |                                                                           |             |                                      |    |                     |    |                    |    |          |    |
| 27.8       | 100   | Tan Gray Silty medium to fine SAND                                        |             |                                      |    |                     |    |                    |    |          | 36 |
|            | 105   | (clay inclusions)                                                         |             |                                      |    |                     |    |                    |    |          | 35 |
| 17.8       | 110   | (clay inclusions)                                                         |             |                                      |    |                     |    |                    |    |          | 32 |
|            | 115   |                                                                           |             |                                      |    |                     |    |                    |    |          |    |
|            | 119   |                                                                           |             |                                      |    |                     |    |                    |    |          | 24 |
|            | 120   | Boring terminated 6-14-76                                                 |             |                                      |    |                     |    |                    |    |          | 29 |
|            |       |                                                                           |             |                                      |    |                     |    |                    |    |          | 39 |
| REMARKS    |       | LOCATION<br>BLUFFS AT RIVER                                               |             |                                      |    | BORING NO.<br>2003  |    |                    |    |          |    |

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. B-2003


FIGURE 2B-132

DEPTH  
FEET

DESCRIPTION

ELEV. PENETRATION-BLOWS PER FOOT  
0 5 10 15 20 30 40 50 60 80 100

53.5



REMARKS: BORING TERMINATED  
\*WITH CLAY INCLUSIONS

N- 64+60  
E- 49+55

BORING NUMBER IFI-1  
DATE DRILLED 9-9-71  
JOB NUMBER 5056

ACAD

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2


TEST BORING RECORD  
BORING NO. IFI-1

FIGURE 2B-133

DEPTH  
FEET

DESCRIPTION

ELEV. PENETRATION-BLOWS PER FOOT  
0 5 10 15 20 30 40 50 60 100



REMARKS: BORING TERMINATED

\*INCLUSIONS

N- 63+85  
E- 49+63

BORING NUMBER IFI-2  
DATE DRILLED 9-9-71  
JOB NUMBER 5056

ACAD

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. IFI-2


FIGURE 2B-134



DEPTH  
FEET

DESCRIPTION

ELEV. PENETRATION-BLOWE PER FOOT  
0 5 10 15 20 30 40 50 60 80 100



REMARKS: \*WITH PARTIALLY CEMENTED CLAY LAYERS AND INCLUSIONS

N- 64+10  
E- 49+83

BORING NUMBER IFI-3  
DATE DRILLED 9-11-71  
JOB NUMBER 5056

ACAD

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2


TEST BORING RECORD  
BORING NO. IFI-3

FIGURE 2B-135

DEPTH  
FEET

DESCRIPTION

ELEV. PENETRATION-BLOWS PER FOOT  
0 5 10 15 20 30 40 60 80 100



REMARKS: BORING TERMINATED

N- 63+55  
E- 49+83

BORING NUMBER IFI-4  
DATE DRILLED 9-11-71  
JOB NUMBER 5056

ACAD

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. IFI-4

FIGURE 2B-136

DEPTH DESCRIPTION ELEV. PENETRATION-BLOWS PER FOOT  
 FEET 0 5 10 15 20 30 40 50 60 80 100



FIRM TO DENSE LIGHT GRAY VERY FINE SAND AND CLAYEY VERY FINE SAND WITH PARTIALLY CEMENTED CLAY INCLUSIONS

6.5

VERY DENSE LIGHT GRAY VERY FINE SAND AND SLIGHTLY CLAYEY VERY FINE SAND WITH PARTIALLY CEMENTED CLAY LAYERS AND INCLUSIONS

10.0

BORING TERMINATED

REMARKS: NO GROUND WATER ENCOUNTERED

N- 64+10  
 E- 49+43

BORING NUMBER IFI-5  
 DATE DRILLED 9-71  
 JOB NUMBER 5056

HISTORICAL  
 REV 19 7/01

ACAD

**SOUTHERN COMPANY**  
 Energy to Serve Your World<sup>®</sup>  
 SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2


TEST BORING RECORD  
 BORING NO. IFI-5

FIGURE 2B-137

DEPTH  
FEET

DESCRIPTION

ELEV. PENETRATION-BLOWS PER FOOT  
0 5 10 15 20 30 40 50 60 100



REMARKS:

N- 63+55  
E- 49+43

BORING NUMBER IFI-6  
DATE DRILLED 9-11-71  
JOB NUMBER 5056

HISTORICAL  
REV 19 7/01

ACAD



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TEST BORING RECORD  
BORING NO. IFI-6

FIGURE 2B-138

### 3.0 DESIGN OF STRUCTURES, COMPONENTS, EQUIPMENT, AND SYSTEMS

#### 3.1 CONFORMANCE WITH NUCLEAR REGULATORY COMMISSION (NRC) GENERAL DESIGN CRITERIA

*This section discusses the extent to which the design criteria for the Hatch Nuclear Plant-Unit 2 (HNP-2) plant structures, system, and components important to safety meet the General Design Criteria for Nuclear Power Plants, specified in Appendix A to 10 CFR 50. For each criterion, a summary is provided to show how the principal design features meet the criterion. Any exceptions to criteria are identified, with the justification for each exception, in the summary. In the discussion of each criterion, the section of the Final Safety Analysis Report (FSAR) where more detailed information is presented to demonstrate compliance with or exceptions to the criterion is also provided.*

##### Criterion 1 - Quality Standards and Records

*"Structures, systems, and components important to safety shall be designed, fabricated, erected, and tested to quality standards commensurate with the importance of the safety functions to be performed. Where generally recognized codes and standards are used, they shall be identified and evaluated to determine their applicability, adequacy, and sufficiency and shall be supplemented or modified as necessary to assure a quality product in keeping with the required safety function. A quality assurance program shall be established and implemented in order to provide adequate assurance that these structures, systems, and components will satisfactorily perform their safety functions. Appropriate records of the design, fabrication, erection, and testing of structures, systems, and components important to safety shall be maintained by or under the control of the nuclear power unit licensee throughout the life of the unit."*

##### *Design Evaluation*

*Structures, systems, and components important to safety are designed, fabricated, erected, and tested under a quality assurance (QA) program which satisfies the intent of Appendix B of 10 CFR 50. The QA program was designed and organized to ensure the HNP is designed, fabricated, and constructed in conformance with the regulatory requirements and design bases outlined in the license application.*

*Design requirements and other information regarding implementation of the QA program are described in various sections of the FSAR. Codes and standards which apply to safety-related, pressure-retaining piping and equipment are included in subsection 3.2.2. Building codes and standards are discussed in paragraphs 3.8.3.2, 3.8.4.2, and 3.8.5.2. Detailed seismic requirements are outlined in supplements 3.7A and 3.7B.*

*Structures, systems, and components are first classified with regard to location, service, and relationship to the safety function to be performed. Recognized codes and standards are applied to the equipment in keeping with the appropriate classification. Where codes are not available or where the existing code must be modified, a rigorous justification is provided in the FSAR.*

*Documents and records are required providing objective evidence that the requirements of the QA program have been satisfied. The documentation shows that the required codes, standards, and specifications were observed, that specified materials were used, that correct procedures were utilized,*

## HNP-2-FSAR-3

*that qualified personnel performed the work, and that inspections and tests verify that finished parts and components meet the applicable specifications. All applicable records are maintained during the operational life of the plant and are readily available for reference. The QA program developed by the applicant and his contractors satisfies the requirements of General Design Criterion (GDC) 1.*

### Criterion 2 - Design Bases for Protection Against Natural Phenomena

*"Structures, systems, and components important to safety shall be designed to withstand the effect of natural phenomena such as earthquakes, tornadoes, hurricanes, floods, tsunamis, and seiches without loss of capability to perform their safety functions. The design bases for these structures, systems, and components shall reflect: (1) appropriate consideration of the most severe of the natural phenomena that have been historically reported for the site and surrounding area, with sufficient margin for the limited accuracy, quantity, and period of time in which the historical data have been accumulated, (2) appropriate combinations of the effects of normal and accident conditions with the effects of the natural phenomena and (3) the importance of the safety functions to be performed."*

#### *Design Evaluation*

*The design basis for protection against natural phenomena is in accordance with GDC 2. Structures, systems, and components important to safety are designed to withstand the effects of natural phenomena such as earthquakes, tornadoes, and floods without loss of the capability to perform those safety functions necessary to cope with appropriate margin to account for uncertainties in the historical data. The natural phenomena postulated in the design are presented in sections 2.3, 2.4, and 2.5. The design criteria for the structures, systems, and components affected by each natural phenomenon are presented in sections 3.2, 3.3, 3.4, 3.5, and 3.8; and supplements 3.7A and 3.7B. Those combinations of natural phenomena and plant-originated accidents that are considered in the design are identified in sections 3.8, 3.9, 3.10, and 3.11.*

### Criterion 3 - Fire Protection

*"Structures, systems, and components important to safety shall be designed and located to minimize, consistent with other safety requirements, the probability and effect of fires and explosions. Noncombustible and heat resistant materials shall be used wherever practical throughout the unit, particularly in locations such as the containment and control room. Fire detection and fighting systems of appropriate capacity and capability shall be provided and designed to minimize the adverse effects of fires on structures, systems, and components important to safety. Fire-fighting systems shall be designed to assure that their rupture or inadvertent operation does not significantly impair the safety capability of these structures, systems, and components."*

#### *Design Evaluation*

*Structures, systems, and components important to safety are designed to minimize the probability and effect of fires and explosions. Noncombustible and heat-resistant materials are used whenever practical throughout the plant, particularly in the containment, control room, and in areas containing engineered safeguards.*

## HNP-2-FSAR-3

*Appropriate equipment and facilities for fire protection, including detection, alarm, and extinguishment of fires, are provided to protect plant equipment and personnel from fire, explosions, and the resultant release of toxic vapors. Automatic and manual types of fire protection equipment are provided.*

*The fire protection system provides an adequate supply of water to the deluge systems, sprinkler systems, and hose stations located throughout the plant. Carbon dioxide systems are used to protect the cable spreading room, the computer room, and the emergency diesel generators and associated switchgear areas. Portable and mobile chemical fire extinguishers are provided throughout the plant. A complete description of the fire protection design bases is provided in the **Edwin I. Hatch Nuclear Plant Units 1 and 2 Fire Hazards Analysis and Fire Protection Program (incorporated by reference into the FSAR)** submitted to the Nuclear Regulatory Commission on July 22, 1986. Fire-fighting systems are designed to ensure that their rupture or inadvertent operation does not significantly impair safety-related systems.*

*The fire protection system consists of a reliable, partially automatic unit designed and installed in accordance with the requirements of the National Fire Protection Association, Nuclear Mutual Limited (NML), and the Occupational Safety and Health Act, in addition to the applicable local codes and regulations.*

*A fire and smoke detection system is provided throughout the plant for immediate detection and identification of fire and smoke. Ionization-type detectors are provided in the control room.*

*The equipment and systems are inspected and tested in accordance with the requirements of local and state authorities and have the approval of NML. The fire protection system is provided with test valves and facilities for periodic testing. All equipment is accessible for periodic inspection.*

### Criterion 4 - Environmental and Dynamic Effects Design Bases

*"Structures, systems, and components important to safety shall be designed to accommodate the effects of and to be compatible with the environmental conditions associated with normal operation, maintenance, testing, and postulated accidents, including loss-of-coolant accidents. These structures, systems, and components shall be appropriately protected against dynamic effects, including the effects of missiles, pipe whipping, and discharging fluids that may result from equipment failures and from events and conditions outside the nuclear power unit."*

#### *Design Evaluation*

*Structures, systems, and components important to safety are designed to accommodate the effects of and to be compatible with the environmental conditions associated with normal operation, maintenance, testing, and postulated accidents, including the design basis LOCA. These structures, systems, and components are appropriately protected against dynamic effects and discharging fluids that may result from equipment failures. Normal and postulated accident effects and load combinations are given in sections 3.6, 3.8, 3.9, and 3.10.*

*Special attention was directed to the effects of pipe movement, jet forces, and missiles within the primary containment. Pipe whip restraints have been provided to the extent practical. The structures, systems, and components important to safety are protected from dynamic effects by separating redundant counterparts so that no single event can prevent a required safety action and by routing and locating, to the extent practical, these components to avoid potentially hazardous areas.*

## HNP-2-FSAR-3

*Dynamic effects external to the plant, induced by natural phenomena, i.e., tornado-produced missiles, are appropriately considered in section 3.5.*

*Section 3.11 contains a discussion of design environmental conditions.*

### *Criterion 5 - Sharing of Structures, Systems, and Components*

*"Structures, systems, and components important to safety shall not be shared among nuclear power units unless it can be shown that such sharing will not significantly impair their ability to perform their safety functions, including in the event of an accident in one unit an orderly shutdown and cooldown of the remaining units."*

#### *Design Evaluation*

*The two units of the HNP share the facilities and equipment below. Reactor safety is not impaired by sharing these facilities and equipment.*

#### *A. Shared Facilities*

- *Main stack.*
- *Intake structure.*
- *Diesel generator building.*
- *Control building. (Main control room panels are separate; the units are controlled separately.)*
- *Refueling floor of reactor buildings.*
- *Service buildings.*
- *Water treatment building.*
- *Fire protection pump house.*
- *Waste gas treatment building.*
- *Discharge pipe to the river.*
- *High-voltage switchyard.*
- *Decontamination facility.*
- *Chlorine building.*
- *Auxiliary boiler.*



## HNP-2-FSAR-3

- *Turbine building (above el 164 ft).*
- *Hydrogen storage facility.*
- *Calibration facility.*
- *Hot machine shop.*
- *Central alarm station building.*
- *Hot tool room.*

### *B. Shared Equipment*

- *One standby ac-power supply (diesel generator).*
- *Fuel pool cooling and cleanup (FPCC) systems.*
- *Fire protection system.*
- *Makeup water treatment system.*
- *Plant service water/circulating water chemical addition system.*
- *Potable and sanitary water system.*
- *Plant communication system.*
- *Main control room environmental control system.*
- *Main stack radiation monitoring system.*
- *Turbine building cranes.*
- *Reactor building crane.*
- *Fuel transfer canal.*
- *Seismic instrumentation.*
  - *Free-field strong-motion triaxial, time-history accelerograph.*
  - *Peak accelerographs - intake structure, diesel generator building, and control building.*
  - *Response spectrum recorder.*

## HNP-2-FSAR-3

- *Plant security system.*
- *Control building chilled water system.*

### Criterion 10 - Reactor Design

*"The reactor core and associated coolant, control, and protection systems shall be designed with appropriate margin to assure that specified acceptable fuel design limits are not exceeded during any condition of normal operation, including the effects of anticipated operational occurrences."*

#### *Design Evaluation*

*The reactor core components consist of fuel assemblies, control rods, incore ion chambers, neutron sources, and related items. The mechanical design is based on conservative application of stress limits, operating experience and experimental test results. The fuel is designed to provide high integrity over a complete range of power levels, including transient conditions.*

*The core is sized with sufficient heat transfer area and coolant flow to ensure that there is no fuel damage under normal conditions or anticipated operational occurrences (AOOs).*

*The reactor protection system (RPS) is designed to monitor certain reactor parameters, sense abnormalities, and scram the reactor, thereby preventing fuel damage when trip points are exceeded. Scram-trip setpoints are selected on operating experience and by the safety design basis. There is no case in which the scram-trip setpoints allow the core to exceed the thermal-hydraulic safety limits. Power for the protection system is supplied by its own high inertia ac motor-generator sets. Alternate electrical power is available to the RPS buses.*

*An analysis and evaluation of the effects upon core fuel following adverse plant operating conditions were made. The results of AOOs are presented in section 15.2 and show that the specified acceptable fuel design limits are not exceeded, thereby assuring adequate fuel protection.*

*The reactor core and associated coolant, control, and protection systems are designed to ensure that the specified fuel-design limits are not exceeded during conditions of normal or abnormal operation and, therefore, meet the requirements of GDC 10.*

*For further discussion, see sections 4.2, 4.3, 4.4, 5.5, and 7.2, and chapter 15.*

### Criterion 11 - Reactor Inherent Protection

*"The reactor core and associated coolant systems shall be designed so that in the power operating range the net effect of the prompt inherent nuclear feedback characteristics tends to compensate for a rapid increase in reactivity."*

#### *Design Evaluation*

*The reactor core is designed to have a reactivity response that regulates or damps changes in power level and spatial distributions of power production to a level consistent with safe and efficient operation.*

## HNP-2-FSAR-3

*The inherent dynamic behavior of the core is characterized in terms of:*

- *Fuel temperature or Doppler coefficient.*
- *Moderator void coefficient.*
- *Moderator temperature coefficient.*

*The combined effect of these coefficients in the power range is termed the power coefficient.*

*Doppler reactivity feedback occurs simultaneously with a change in fuel temperature and opposes the power change that caused it; thus, it contributes to system stability. Since the Doppler reactivity opposes load changes, it is desirable to maintain a large ratio of moderator void coefficient to Doppler coefficient for optimum load-following capability. The boiling water reactor (BWR) has an inherently large moderator-to-Doppler coefficient ratio which permits use of coolant flowrate for load following. Load following is not used at Plant Hatch.*

*In a BWR, the moderator void coefficient is of primary importance during operation at power. Nuclear design is based on the void coefficient inside the fuel channel being negative. The negative void reactivity coefficient provides an inherent negative feedback during power transients. Because of the large negative moderator coefficients of reactivity, the BWR has a number of inherent advantages, such as:*

- *Use of coolant flow as opposed to control rods for load following.*
- *Inherent self-flattening of the radial power distribution.*
- *Ease of control.*
- *Spatial xenon stability.*

*The reactor is designed so that the moderator temperature coefficient is small and positive in the cold condition; however, the overall power reactivity coefficient is negative.*

*The reactor core and associated coolant system are designed so that in the power operating range prompt inherent dynamic behavior tends to compensate for any rapid increase in reactivity in accordance with GDC 11.*

*For further discussion, see sections 4.3 and 4.4.*

### *Criterion 12 - Suppression of Reactor Power Oscillations*

*"The reactor core and associated coolant, control, and protection systems are designed to ensure that power oscillations which can result in conditions exceeding specified acceptable fuel design limits are not possible or can be reliably and readily detected and suppressed."*

## HNP-2-FSAR-3

### *Design Evaluation*

*The reactor core is designed to ensure that no power oscillation will cause fuel-design limits to be exceeded. The power reactivity coefficient is the composite simultaneous effect of the fuel temperature or Doppler coefficient, moderator void coefficient, and moderator temperature coefficient to the change in power level. It is negative and well within the range required for adequate damping of power and spatial xenon disturbances. Operating experience has shown large BWRs to be inherently stable against xenon-induced power instability. The large negative operating coefficients provide:*

- *Good load following with well damped behavior and little undershoot or overshoot in the heat transfer response.*
- *Load following with recirculation flow control.*
- *Strong damping of spatial power disturbances.*

*The RPS design provides protection from excessive fuel-cladding temperatures and protects the nuclear system process barrier from excessive pressures which threaten the integrity of the system. Local abnormalities are sensed, and, if protection system limits are reached, corrective action is initiated through an automatic scram. High integrity of the protection system is achieved through the combination of logic arrangement, trip channel redundancy, power supply redundancy, and physical separation.*

*The reactor core and associated coolant, control, and protection systems are designed to suppress any power oscillations which could result in exceeding of fuel-design limits. These systems assure that GDC 12 is met.*

*For further discussion, see sections 4.2, 4.3, 4.4, 5.2, 7.2, 7.7, and chapter 15.*

### *Criterion 13 - Instrumentation and Control*

*"Instrumentation shall be provided to monitor variables and systems over their anticipated ranges for normal operations, for anticipated operational occurrences, and for accident conditions as appropriate to assure adequate safety, including those variables and systems that can affect the fission process, the integrity of the reactor core, the reactor coolant pressure boundary, and the containment and its associated systems. Appropriate controls shall be provided to maintain these variables and systems within prescribed operating ranges."*

### *Design Evaluation*

*The fission process is monitored and controlled for all conditions from source range through power operating range. The neutron monitoring system (NMS) detects core conditions that threaten the overall integrity of the fuel barrier due to excess power generation and provides a signal to the RPS. Fission counters, located in the core, are used for the source range through power operating range. The detectors are located to provide maximum sensitivity to control rod movement during startup and to provide optimum monitoring in the intermediate and power ranges.*

## HNP-2-FSAR-3

*The source range monitor (SRM) subsystem provides neutron flux information during reactor startup and low flux level operations. Detectors are inserted into the core for a reactor startup and may be withdrawn after neutron flux is indicated on the intermediate range monitor (IRM) subsystem. The SRMs can provide detection of less than a 20-s period under the worst possible startup conditions and provides SRM period annunciation.*

*The IRMs monitor neutron flux from the upper portion of the SRMS to the lower portion of the average power range monitor (APRM) subsystem. The IRMs are capable of generating a trip signal to block rod withdrawal or to scram the reactor.*

*The local power range monitor (LPRM) subsystem consists of fission chambers located through the core, the signal conditioning equipment, and trip functions. LPRM signals are also used in the average power range monitor (APRM) subsystem, rod block monitor (RBM) subsystem, and process computer. The RBMs are designed to prevent local fuel damage as a result of a single rod withdrawal error under a condition of allowed IRM bypass.*

*The traversing incore probe (TIP) subsystem provides a signal proportional to the axial neutron flux distribution of the core. This system is used in the calibration of the LPRM signal by correlation with the TIP signal.*

*The RPS protects the fuel barriers and the nuclear process barrier by monitoring plant parameters and causing a reactor scram when predetermined setpoints are exceeded.*

*The reactor manual control system (RMCS) consists of the electrical circuitry, switches, indicators, and alarm devices required to provide for the manipulation of the control rods and surveillance equipment. Separation of the scram and normal rod control function prevents failures in the reactor manual control circuitry from affecting the scram circuitry.*

*Reactor vessel instrumentation monitors the transient reactor vessel process temperatures, water levels, water flow, internal pressure, and water leakage detection from the top head flange. This information is used to assess conditions existing inside the vessel and the physical condition of the reactor vessel. Reactor vessel temperatures are recorded on a multipoint recorder in the control room. Controlled heating and cooling rates allow thermal stress to be appropriately limited. Reactor vessel water level is also indicated in the control room. Recirculation loop flow, core flow, and differential pressure between the reactor vessel annulus outside of the core and the core inlet plenum are indicated in the control room.*

*To provide protection against the consequences of accidents involving the release of radioactive material from the fuel and nuclear system process barrier, the primary containment and reactor vessel isolation control system initiates automatic isolation of appropriate pipelines which penetrate the primary containment whenever monitored variables exceed preselected operational limits.*

*Nuclear system leakage limits are established so that appropriate action can be taken to ensure the integrity of the nuclear system process barrier. Nuclear system leakage rates are classified as identified and unidentified, which correspond respectively to the flow to the equipment drain and drywell floor drain sumps. The permissible total leakage rate limit to these sumps is based upon the makeup capabilities of various reactor component systems. Flow integrator and recorders are used to determine the leakage flow pumped from the drain sumps. The unidentified leakage rate, as established in chapter 5, is limited to a value that is less than the value that has been conservatively calculated to be a*

## HNP-2-FSAR-3

*minimum leakage from a crack large enough to propagate rapidly but which still allows time for identification and corrective action before integrity of the process barrier is threatened.*

*A process computer system receives input from plant variables, including all variables of the RPS. The inputs are scanned and monitored for change of state and provide a quick and accurate determination of the core thermal performance. Certain inputs are annunciated to aid in general plant operation. The process computer system provides inputs to the rod block circuitry. The data reduction, accounting, and logging functions supplement procedural requirements for control rod manipulation during reactor startup and shutdown. Although the process computer is a valuable aid to the operator, it is not required for the safe operation of the plant.*

*For further discussion, see sections 4.2, 6.2, 7.2, 7.3, 7.6, and 7.7.*

### *Criterion 14 - Reactor Coolant Pressure Boundary*

*"The reactor coolant pressure boundary shall be designed, fabricated, erected, and tested so as to have an extremely low probability of abnormal leakage, of rapidly propagating failure, and of gross rupture."*

#### *Design Evaluation*

*The piping and equipment pressure parts within the reactor coolant pressure boundary (RCPB) through the outer isolation valve are designed, fabricated, erected, and tested to provide a high degree of integrity throughout the plant lifetime. Subsection 3.2.2 classifies the systems and components within the RCPB as Quality Group A. The design requirements and codes and standards applied to the quality group ensure a quality product in keeping with the safety functions to be performed.*

*In order to minimize the possibility of brittle fracture within the RCPB, the fracture or notch properties and the operating temperature of ferritic materials are controlled to ensure adequate toughness when the system is pressurized to more than 20% of the design pressure. Section 5.2 describes the methods utilized to control toughness properties. Materials to be impact tested are tested by the Charpy V-notch method in accordance with American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section III. Service temperature of these materials is maintained above the nil ductility transition temperature (NDTT). The fracture toughness temperature requirements of the RCPB materials also apply for the RCPB piping which penetrates the containment.*

*Piping and equipment pressure parts of the RCPB are assembled and erected by welding unless applicable codes permit flanged or screwed joints. Welding procedures are employed which produce welds of complete penetration, of complete fusion, and free of unacceptable defects. All welding procedures, welders, and welding machine operators are qualified in accordance with the requirements of Section IX of the ASME Boiler and Pressure Vessel Code for the materials to be welded. Qualification records, including the results of procedure and performance qualification tests and identification symbols assigned to each welder, are maintained.*

*Section 5.2 contains the detailed material and examination requirements for the piping and equipment of the RCPB prior to and after its assembly and erection. Leakage testing and surveillance is accomplished as described in the evaluation against GDC 30.*

## HNP-2-FSAR-3

*The design, fabrication, erection, and testing of the RCPB assure an extremely low probability of failure or abnormal leakage, thus satisfying the requirements of GDC 14.*

*For further discussion, see sections 3.2, 5.2, 5.4, 5.5, and 7.6, and chapters 15 and 17.*

### Criterion 15 - Reactor Coolant System Design

*"The reactor coolant system and associated auxiliary, control, and protection systems shall be designed with sufficient margin to assure that the design conditions of the reactor coolant pressure boundary are not exceeded during any condition of normal operation, including anticipated operational occurrences."*

#### *Design Evaluation*

*The RCS consists of the reactor vessel and appurtenances, the reactor recirculation system (RRS), the pressure relief system, the main steam lines, the reactor core isolation cooling (RCIC) system, and the residual heat removal (RHR) system. These systems are designed, fabricated, erected, and tested to stringent quality requirements and appropriate codes and standards which assure high integrity of the RCPB throughout the plant lifetime. The RCS is designed and fabricated to meet the requirements of the ASME Boiler and Pressure Vessel Code, Section III.*

*The auxiliary, control, and protection systems associated with the RCS act to provide sufficient margin to assure that the design conditions of the RCPB are not exceeded during any condition of normal operation, including AOOs. As described in the evaluation of GDC 13, instrumentation is provided to monitor essential variables to ensure that they are within prescribed operating limits. If the monitored variables exceed their predetermined settings, the auxiliary, control, and protection systems automatically respond to maintain the variables and systems within allowable design limits.*

*An example of the integrated protective action scheme which provides sufficient margin to ensure that the design conditions of the RCPB are not exceeded is the automatic initiation of the pressure relief system upon receipt of an overpressure signal. To accomplish overpressure protection, a number of pressure-operated relief valves are provided that can discharge steam from the nuclear system to the pressure suppression pool. The pressure relief system also provides for automatic depressurization of the nuclear system in the event of a LOCA in which the vessel is not depressurized by the accident. The depressurization of the nuclear system in this situation allows operation of the low-pressure emergency core cooling system (ECCS) subsystems to supply enough cooling water to adequately cool the core. In a similar manner, other auxiliary, control, and protection systems provide assurance that the design conditions of the RCPB are not exceeded during any conditions of normal operation, including AOOs.*

*The application of appropriate codes, standards, and high quality requirements to the RCS and the design features of its associated auxiliary, control, and protection systems ensure that the requirements of GDC 15 are satisfied.*

*For further discussion, see sections 5.2, 5.4, 5.5, 7.6 and chapter 15.*

### Criterion 16 - Containment Design

*"Reactor containment and associated systems shall be provided to establish an essentially leaktight barrier against the uncontrolled release of radioactivity to the environment and to assure that the*

## HNP-2-FSAR-3

*containment design conditions important to safety are not exceeded for as long as postulated accident conditions require."*

### *Design Evaluation*

*The reactor is housed within a drywell containment vessel made of steel plates of 13/16-in. to 4-in. thickness. Reinforced concrete ranging in thickness from 5 ft 7 in. to 10 ft is placed around the drywell vessel. The ability of the containment vessel to provide a leaktight barrier against uncontrolled release of radioactivity is verified by a preoperational leakage test and during the life of the plant. Additional description of the primary containment is found in subsection 3.8.2.*

*In order to prevent the containment design conditions important to safety from being exceeded, the containment is provided with the following:*

- *A pressure suppression chamber and vent system by which steam escaping into the drywell is condensed through contact with a supply of stored water (subsection 3.8.2).*
- *Cooling systems to remove heat from the water in the suppression pool (subsection 6.2.2).*
- *Drywell and suppression chamber water spraying systems to condense steam in the drywell and to cool noncondensable gases in the suppression chamber (subsection 6.2.2).*

*A description of the primary containment response to the postulated design basis LOCA is provided in chapter 6.*

### *Criterion 17 - Electric Power Systems*

*"An onsite electric power system and an offsite electric power system shall be provided to permit functioning of structures, systems, and components important to safety. The safety function for each system (assuming the other system is not functioning) shall be to provide sufficient capacity and capability to assure that (1) specified acceptable fuel design limits and design conditions of the reactor coolant pressure boundary are not exceeded as a result of anticipated operational occurrences and (2) the core is cooled and containment integrity and other vital functions are maintained in the event of postulated accidents.*

*The onsite electric power supplies, including the batteries, and the onsite electric distribution system, shall have sufficient independence, redundancy, and testability to perform their safety functions assuming a single failure.*

*Electric power from the transmission network to the onsite electric distribution system shall be supplied by two physically independent circuits (not necessarily on separate rights of way) designed and located so as to minimize to the extent practical the likelihood of their simultaneous failure under operating and postulated accident and environmental conditions. A switchyard common to both circuits is acceptable. Each of these circuits shall be designed to be available in sufficient time following a loss of all onsite ac power supplies and the other offsite electric power circuit, to assure that specified acceptable fuel design limits and design conditions of the reactor coolant pressure boundary are not exceeded. One of these*



## HNP-2-FSAR-3

*circuits shall be designed to be available within a few seconds following a loss-of-coolant accident to assure that core cooling, containment integrity, and other vital safety functions are maintained.*

*Provisions shall be included to minimize the probability of losing electric power from any of the remaining supplies as a result of, or coincident with, the loss of power generated by the nuclear power unit, the loss of power from the transmission network, or the loss of power from the onsite electric power supplies."*

### *Design Evaluation*

*Both onsite and offsite electric power systems are provided to permit functioning of structures, systems, and components important to safety. With total loss-of-offsite power (LOSP), the onsite power system provides sufficient capacity and capability to assure that:*

- *Specified acceptable fuel-design limits and design conditions of the RCPB are not exceeded as a result of AOOs.*
- *The core is cooled, and containment integrity and other vital functions are maintained in the event of postulated accidents.*

*The description and design bases of the onsite power system (ac and dc) are discussed in subsections 8.3.1 and 8.3.2. The onsite electric power system has sufficient independence, redundancy, and testability to perform its safety function assuming a single failure.*

*All the Class 1E ac loads are divided into two load groups and are connected to the three 4160-V essential buses 2E, 2F, and 2G. These two load groups are independent of each other to ensure the measures specified by the bulleted items above are met considering a postulated single failure.*

*All the Class 1E dc loads are divided into two load groups and are connected to the two 250/125 V-dc essential buses 2A and 2B. These two load groups are independent of each other to ensure that the measures specified by the bulleted items above are met considering a postulated single failure.*

*Physically independent circuits as described in section 8.2 are provided from the switchyard to the startup auxiliary transformers. These circuits are fed by at least three independent transmission lines, physically separated as they approach the switchyard so that the failure of one line does not cause failure of another line. From the switchyard to the onsite electrical distribution system, separation is also provided so that failure of one circuit does not cause the failure of the other circuit.*

*Each of the incoming transmission lines is normally connected to the switchyard, except for short maintenance periods. One of these lines is continually connected to startup transformer 2D to supply power immediately to the essential 4160-V buses in the event of a LOCA. In the event of failure of startup transformer 2D, the essential 4160-V buses are automatically transferred to startup transformer 2C. In the event that all offsite circuits are lost, the emergency buses are isolated from the remaining portion of the onsite power system and connected to the onsite emergency diesel generators.*

*The turbine-generator is automatically isolated from the switchyard following a turbine or reactor trip. Therefore, its loss does not affect the ability of either the transmission network or the onsite power*

## HNP-2-FSAR-3

*supplies to provide power to the Class 1E system. Transmission system stability studies indicate that the trip of the most critical fully loaded generating unit does not impair the ability of the system to supply plant station service.*

### Criterion 18 - Inspection and Testing of Electric Power Systems

*"Electric power systems important to safety shall be designed to permit appropriate periodic inspection and testing of important areas and features, such as wiring, insulation, connections, and switchboards, to assess the continuity of the systems and the condition of their components. The systems shall be designed with a capability to test periodically (1) the operability and functional performance of the components of the systems, such as onsite power sources, relays, switches, and buses, and (2) the operability of the systems as a whole and, under conditions as close to design as practical, the full operational sequence that brings the systems into operation, including operation of applicable portions of the protection system, and the transfer of power among the nuclear power unit, the offsite power system, and the onsite power system."*

#### *Design Evaluation*

*The primary circuit breakers are inspected, maintained, and tested on a routine basis. This can be accomplished without removing the generators, transformers, and transmission lines from service.*

*Transmission line protective relaying is tested on a routine basis. This can be accomplished without removing the transmission lines from service. Generator, unit auxiliary transformer, and startup auxiliary transformer relaying is tested during refueling. Automatic transfers of 4160-V buses 2E, 2F, and 2G from startup transformers to emergency standby diesel generators are tested during the refueling of the unit to prove the operability of the system.*

*The 4160-V and 600-V circuit breakers and associated equipment may be tested while individual equipment is shutdown. The circuit breakers may be placed in the "test" position and tested functionally. The breaker opening and closing may also be exercised. Circuit breakers and contactors for redundant or duplicated circuits may be tested in service without interfering with the operation of the plant.*

*The dc system has detectors to indicate when there is a ground existing on any portion of the system. A ground on one portion of the dc systems does not cause any equipment to malfunction. Spurious activation of a system in the "safe" direction is not considered a malfunction. The batteries are under continuous automatic charging and are inspected and checked on a routine basis while the unit is in service.*

*To verify that the emergency power system responds within the required time limit, and properly when required, the following typical tests are performed periodically:*

- A. Manually initiated demonstration of the ability of the diesel generators to start and deliver power up to nameplate rating when operating in parallel with normal power sources. Normal plant operation is not affected. The duration of the test is long enough for the diesels to reach equilibrium operating temperatures.*

## HNP-2-FSAR-3

- B. *Manual initiation of permanently installed testing devices demonstrate the ability of the control system to automatically start the diesel generator and restore power to vital equipment by simulating an LOSP and/or a LOCA.*

*These tests include:*

- *Test for automatic transfer of emergency buses being supplied by the normal offsite power source to the alternate offsite power source.*
- *Test for automatically starting, connecting the diesel generators to the emergency bus, and loading the diesel generators upon LOSP sources.*
- *Test for automatically starting diesel generators upon a LOCA signal.*
- *Test for automatically starting, connecting diesel generators to the emergency buses, and sequentially loading the diesel generators upon a LOCA signal accompanied by an LOSP signal.*

*The capability to perform the above tests complies with the intent of GDC 18.*

### Criterion 19 - Control Room

*"A control room shall be provided from which actions can be taken to operate the nuclear power unit safely under normal conditions and to maintain it in a safe condition under accident conditions, including loss-of-coolant accidents. Adequate radiation protection shall be provided to permit access and occupancy of the control room under accident conditions without personnel receiving radiation exposures in excess of 5 rem whole body, or its equivalent to any part of the body, for the duration of the accident.*

*Equipment at appropriate locations outside the control room shall be provided (1) with a design capability for prompt hot shutdown of the reactor, including necessary instrumentation and controls to maintain the unit in a safe condition during hot shutdown and (2) with a potential capability for subsequent cold shutdown of the reactor through the use of suitable procedures."*

### *Design Evaluation*

*A control room has been provided in which appropriate controls and instrumentation are located to permit personnel to safely operate the unit under normal conditions or maintain it in a safe condition under accident conditions. The MCR and associated post-accident ventilation systems are designed in accordance with Category I requirements.*

*The design of the control room permits access and occupancy during a LOCA. Previous analyses demonstrate that the LOCA is the limiting event for radiological exposures to operators in the MCR. Therefore, for extended power uprate conditions (2763 MWt), only the LOCA was analyzed for MCR radiological exposures. The results of the analysis bound the subsequent power uprate conditions (2804 MWt) including the conditions for the reactor operating pressure increase to 1060 psia. Sufficient shielding and ventilation are provided to permit occupancy of the control room for a period of 30 days*

## HNP-2-FSAR-3

following the LOCA, without receiving more than 5-rem integrated whole-body dose or its equivalent to any part of the body. An analysis of exposures within the control room is presented in section 15.3.

The ability for prompt hot shutdown of the reactor and the potential capability for subsequent cold shutdown through the use of suitable procedures from locations outside the control room is provided by the remote shutdown system, should the control room become inaccessible. The remote shutdown system has the capability for prompt hot shutdown of the reactor, including necessary instrumentation and control to maintain the unit in a safe condition during hot shutdown, and subsequent cold shutdown of the reactor through use of administrative procedures. The remote shutdown system panel contains controls for the following equipment:

- A. RHR system - The controls for one loop of the RHR system are provided on the remote shutdown panel. All modes of the RHR system operation, low-pressure coolant injection (LPCI), suppression pool cooling, containment spray cooling, and shutdown cooling can be operated from the remote shutdown panel.
- B. RCIC system - All basic RCIC equipment can be controlled from the remote shutdown panel.
- C. Reactor recirculation system - The suction valve of one recirculation pump can be controlled from the remote shutdown panel.
- D. Automatic depressurization system (ADS) - Two manual blowdown valves can be operated from the remote shutdown panel.

In addition, the diesel generator can be operated from the local panel in the diesel generator building.

### Criterion 20 - Protection System Functions

"The protection system shall be designed (1) to initiate automatically the operation of appropriate systems including the reactivity control system, to assure that specified acceptable fuel design limits are not exceeded as a result of anticipated operational occurrences and (2) to sense accident conditions and to initiate the operation of systems and components important to safety."

#### *Design Evaluation*

The RPS is designed to provide timely protection against the onset and consequences of conditions that threaten the integrity of the fuel barrier and nuclear system process barrier. Fuel damage is prevented by initiation of an automatic reactor shutdown if monitored nuclear system variables exceed preestablished limits of AOOs. Scram trip settings are selected and verified to be far enough above or below operating levels to provide proper protection but not be subject to spurious scrams. The RPS includes the motor-generator power system, sensors, relays, bypass circuitry, and switches that signal the control rod system to scram and shutdown the reactor. The scrams initiated by NMS variables, nuclear system high-pressure, turbine stop valve closure, turbine control valve fast closure, and reactor vessel low water level prevent fuel damage following AOOs. Specifically, these process parameters initiate a scram in time to prevent the core from exceeding thermal-hydraulic safety limits during AOOs. Response by the RPS is prompt, and the total scram time is short.

## HNP-2-FSAR-3

*A fully withdrawn control rod (withdrawn to 144 in.) traverses 90% of its full stroke in less than 5 s, which is sufficient to assure that acceptable fuel-design limits are not exceeded.*

*In addition to the RPS which provides for automatic shutdown of the reactor to prevent fuel damage, protection systems are provided to sense accident conditions and initiate automatically the operation of other systems and components important to safety. Subsystems, such as the ECCS, are initiated automatically to limit the extent of fuel damage following a LOCA. Other systems automatically isolate the reactor vessel or the primary containment to limit the extent of fuel damage following a postulated LOCA and prevent the release of significant amounts of radioactive material from the fuel and the nuclear system process barrier. The control and instrumentation for the ECCS and the isolation systems are initiated automatically when monitored variables exceed preselected operational limits. The design of the protection system satisfies the functional requirements as specified in GDC 20.*

*For further discussion, see sections 4.2, 6.3, 7.2, 7.3, and 7.6 and chapter 15.*

### Criterion 21 - Protection System Reliability and Testability

*"The protection system shall be designed for high functional reliability and inservice testability commensurate with the safety functions to be performed. Redundancy and independence designed into the protection system shall be sufficient to assure that (1) no single failure results in loss of the protection function and (2) removal from service of any component or channel does not result in loss of the required minimum redundancy unless the acceptable reliability of operation of the protection system can be otherwise demonstrated. The protection system shall be designed to permit periodic testing of its functioning when the reactor is in operation, including capability to test channels independently to determine failures and losses of redundancy that may have occurred."*

#### *Design Evaluation*

*The RPS design fulfills single-failure criteria by providing redundant channels. No single component failure, intentional bypass maintenance operation, calibration operation, or test to verify operational availability impairs the ability of the system to perform its intended safety function. Additionally, the system design assures that when a scram trip point is exceeded there is a high scram probability. However, should a scram not occur, other monitored components scram the reactor if their trip points are exceeded. There is sufficient electrical and physical separation between channels and between trip logics monitoring the same variable to prevent environmental factors, electrical transients, and physical events from impairing the ability of the system to respond correctly.*

*The RPSs include design features that permit inservice testing. This ensures the functional reliability of the system should the reactor variable exceed the corrective action setpoint.*

*The RPS initiates an automatic reactor shutdown if the monitored plant variables exceed preestablished limits. The protection system consists of two independently powered trip systems. Each trip system has three trip logics, two of which produce an automatic trip signal. The logic scheme is a one-out-of-two-taken-twice arrangement.*

*The RPS can be tested during reactor operation. Manual scram testing is performed by operating the two manual scram controls. This tests one trip system. The total test verifies the ability to deenergize the*

## HNP-2-FSAR-3

*scram pilot valve solenoids. Indicating lights verify that the actuator contacts have opened. This capability for a thorough testing program significantly increases reliability.*

*Control rod drive (CRD) operability can be tested during normal reactor operation. Drive position indicators and the incore neutron detectors are used to verify control rod movement. Each control rod can be withdrawn one notch and then reinserted to the original position without significantly perturbing the reactor system. One control rod is tested at a time. Control rod mechanism overdrive demonstrates rod-to-drive coupling integrity. Hydraulic supply subsystem pressures can be observed on control room instrumentation. More importantly, the hydraulic control unit scram accumulator and the scram discharge volume level are continuously monitored.*

*The main steam isolation valves (MSIVs) may be tested during full reactor operation. They can be closed to 90% of full-open position without affecting the reactor operation. If reactor power is reduced to 75% of full power, an isolation valve may be fully closed. Provisions are provided to evaluate valve stem leakage during reactor shutdown. During refueling operation, valve leakage rates can be determined.*

*The RHR system testing can be performed during normal operation. Main system pumps can be evaluated by taking suction from the suppression pool. System design and operating procedures also permit testing the discharge valves to the reactor recirculation loops and discharge valves to the containment spray headers. The LPCI mode can be tested after reactor shutdown. Each ECCS active component which operates in a DBA is designed to be testable.*

*The high functional reliability, redundancy, and inservice testability of the protection system satisfy the requirements specified in GDC 21.*

*For further discussion, see sections 9.2, 5.5, 6.2, 6.3, 7.2, 7.3, and chapter 15.*

### Criterion 22 - Protection System Independence

*"The protection system shall be designed to assure that the effects of natural phenomena and of normal operating, maintenance, testing, and postulated accident conditions on redundant channels do not result in loss of the protection function, or shall be demonstrated to be acceptable on some other defined basis. Design techniques, such as functional diversity or diversity in component design and principles of operation, shall be used to the extent practical to prevent loss of the protection function."*

#### *Design Evaluation*

*The components of protection systems are designed so that the mechanical and thermal environment resulting from any emergency situation in which the components are required to function do not interfere with that function. Wiring for the RPS outside of the control room enclosures is run in rigid metallic conduits or raceways segregated from all other wiring. The wires from duplicate sensors on a common process tap are run in separate conduits. The system sensors are electrically and physically separated. Only one trip actuator logic circuit from each trip system may be run in the same wireway.*

*The RPS is designed to permit maintenance and diagnostic work while the reactor is operating without restricting the plant operation or hindering the output of any safety functions. The flexibility in design embodied in the protection system allows operational system testing by the use of an independent trip channel for each trip logic input. When an essential monitored variable exceeds its scram trip point, it is*

## HNP-2-FSAR-3

*sensed by at least two independent sensors in each trip system. An intentional bypass, maintenance operation, calibration operation, or test results in a single channel trip. This leaves at least two trip channels per monitored variable capable of initiating a scram. Only one trip channel in each trip system must trip to initiate a scram. Thus, the arrangement of two trip channels per trip system assures that a scram occurs as a monitored variable exceeds its scram setting.*

*The protection system meets the design requirements for functional and physical independence as specified in GDC 22.*

*For further discussion, see sections 4.2, 5.5, 6.3, 7.2, 7.3, and 7.6.*

### Criterion 23 - Protection System Failure Modes

*"The protection system shall be designed to fail into a safe state or into a state demonstrated to be acceptable on some other defined basis if conditions such as disconnection of the system, loss of energy (e.g., electric power, instrument air), or postulated adverse environments (e.g., extreme heat or cold, fire, pressure, steam, water, and radiation) are experienced."*

#### *Design Evaluation*

*The RPS is designed to fail into a safe state. Use of an independent trip channel for each trip logic allows the system to sustain any trip channel failure without preventing other sensors monitoring the same variable from initiating a scram. A single sensor or trip channel failure causes a channel trip. Only one trip channel must trip in each trip system to initiate a scram. Intentional bypass, maintenance operation, calibration operation, or test results in a single channel trip. A failure of any one RPS input or subsystem component produces a trip in one of two channels. This condition is insufficient to produce a reactor scram, but the system is ready to perform its protection function upon another trip.*

*The environmental conditions in which the instrumentation and equipment of the RPS must operate were considered in establishing the component specifications. Instrumentation specifications for the reactor and turbine buildings are based on the worst expected ambient conditions in which the instruments must operate.*

*The failure modes of the protection system are such that it fails into a safe state as required by GDC 23.*

*For further discussion, see sections 3.11, 6.3, 7.2, 7.3, 7.6, and chapter 8.*

### Criterion 24 - Separation of Protection and Control Systems

*"The protection system shall be separated from control systems to the extent that failure of any single control system component or channel, or failure or removal from service of any single protection system component or channel which is common to the control and protection systems leaves intact a system satisfying all reliability, redundancy, and independence requirements of the protection system. Interconnection of the protection and control systems shall be limited to assure that safety is not significantly impaired."*

## HNP-2-FSAR-3

### *Design Evaluation*

*There is separation between the RPS and the process systems. Sensors, trip channels, and trip logics of the RPS are not used directly for automatic control of process systems. Therefore, failure in the controls and instrumentation of process systems cannot induce failure of any portion of the protection system. High scram reliability is designed into the RPS and hydraulic control unit for the CRD. The scram signal and mode of operation overrides all other signals.*

*The containment and reactor vessel isolation control systems are designed so that any one failure, maintenance operation, calibration operation, or test to verify operational availability not impair the functional ability of the isolation control system to respond to essential variables.*

*The RPS is separated from control systems as required in GDC 24.*

*For further discussion, see sections 6.3, 7.2, 7.3, and 7.6.*

### *Criterion 25 - Protection System Requirements for Reactivity Control Malfunctions*

*"The protection system shall be designed to assure that specified acceptable fuel design limits are not exceeded for any single malfunction of the reactivity control systems, such as accidental withdrawal (not ejection or dropout) of control rods."*

### *Design Evaluation*

*The RPS provides protection against the onset and consequences of conditions that threaten the integrity of the fuel barrier and the nuclear system process barrier. Any monitored variable which exceeds the scram setpoint initiates an automatic scram and does not impair the remaining variables from being monitored and, if one channel fails, the remaining portions of RPS shall function.*

*The RMCS is designed so that no single failure can negate the effectiveness of a reactor scram. The circuitry for the RMCS is completely independent of the circuitry controlling the scram valves. This separation of the scram and normal rod control functions prevents failures in the reactor manual control circuitry from affecting the scram circuitry. Because each control rod is controlled as an individual unit, a failure that results in energizing any of the insert or withdraw solenoid valves can affect only one control rod. The effectiveness of a reactor scram is not impaired by the malfunctioning of any one control rod.*

*The most serious rod withdrawal errors occur when an out-of-sequence rod is continuously withdrawn while the reactor is just subcritical. The rod worth minimizer (RWM) would normally prevent the withdrawal of out-of-sequence control rods.*

*If such a continuous rod withdrawal were to occur, the increase in fuel temperature subsequent to scram would not be sufficient to exceed acceptable fuel-design limits.*

*The design of the protection system assures that specified acceptable fuel-design limits are not exceeded for any single malfunction of the reactivity control systems as specified in GDC 25.*

*For further discussion, see sections 4.2, 4.3, 4.4, 7.2, 7.7, and chapter 15.*



## HNP-2-FSAR-3

### Criterion 26 - Reactivity Control System Redundancy and Capability

*"Two independent reactivity control systems of different design principles shall be provided. One of the systems shall use control rods, preferably including a positive means for inserting the rods, and shall be capable of reliably controlling reactivity changes to assure that under conditions of normal operation, including anticipated operational occurrences, and with appropriate margin for malfunctions such as stuck rods, specified acceptable fuel design limits are not exceeded. The second reactivity control system shall be capable of reliably controlling the rate of reactivity changes resulting from planned, normal power changes (including xenon burnout) to assure that acceptable fuel design limits are not exceeded. One of the systems shall be capable of holding the reactor core subcritical under cold conditions."*

#### *Design Evaluation*

*Two independent reactivity control systems utilizing different design principles are provided. The normal method of reactivity control employs control rod assemblies which contain boron-carbide ( $B_4C$ ) powder. Control of reactivity is operationally provided by a combination of these movable control rods, burnable poisons, and reactor coolant recirculation system flow. These systems accommodate fuel burnup, load changes, and long-term reactivity changes.*

*Reactor shutdown by the CRD system is sufficiently rapid to prevent exceeding of acceptable fuel-design limits for normal operation and all AOOs. The circuitry for manual insertion or withdrawal of control rods is completely independent of the circuitry for reactor scram. This separation of the scram and normal rod control functions prevents failures in the reactor manual control circuitry from affecting the scram circuitry. Because each control rod is controlled as an individual unit, a failure that results in energizing any of the insert or withdraw solenoid valves can affect only one control rod. Two sources of scram energy (accumulator pressure and reactor vessel pressure) provide needed scram performance over the entire range of reactor pressure, i.e., from operating conditions to cold shutdown.*

*The design of the CRD system includes appropriate margin for malfunctions, such as stuck rods, in the highly unlikely event that they do occur. Control rod withdrawal sequences and patterns are selected prior to operation to achieve optimum core performance, and, simultaneously, low individual rod worths. The operating procedures to accomplish such patterns are supplemented by the RWM program of the process computer, which prevents rod withdrawals yielding a rod worth greater than permitted by the preselected rod withdrawal pattern. An additional safety design basis of the CRD system requires that the core in its maximum reactivity condition be subcritical with the control rod of the highest worth fully withdrawn and all other rods fully inserted. Because of the carefully planned and regulated rod withdrawal sequence, prompt shutdown of the reactor can be achieved with the insertion of a small number of the many independent control rods. In the event that a reactor scram is necessary, the unlikely occurrence of a limited number of stuck rods does not hinder the capability of the CRD system to render the core subcritical.*

*A standby liquid control system containing neutron absorbing sodium pentaborate solution is the independent backup system. This system has the capability to shut the reactor down from full power and maintain it in a subcritical condition at any time during the core life. The reactivity control provided to reduce reactor power from rated to a shutdown condition with the control rods withdrawn in the power pattern accounts for the reactivity effects of xenon decay, eliminating steam voids, change in water density due to the reduction in water temperature, Doppler effect in uranium, changing neutron leakage from boiling to cold, and changing rod worth as boron affects neutron migration length.*

## HNP-2-FSAR-3

*The redundancy and capabilities of the reactivity control systems for the BWR satisfy the requirements of GDC 26.*

*For further discussion, see sections 4.2, 7.4, 7.6, and 7.7.*

### *Criterion 27 - Combined Reactivity Control Systems Capability*

*"The reactivity control systems shall be designed to have a combined capability, in conjunction with poison addition by the emergency core cooling system, of reliably controlling reactivity changes to assure that, under postulated accident conditions and with appropriate margin for stuck rods, the capability to cool the core is maintained."*

#### *Design Evaluation*

*There is no credible event applicable to the BWR which requires combined capability of the CRD system and poison additions by the emergency core cooling network. The primary reactivity control system for the BWR during postulated accident conditions is the CRD system. Abnormalities are sensed, and, if protection system limits are reached, corrective action is initiated through an automatic scram. High integrity of the protection system is achieved through the combination of logic arrangement, trip channel redundancy, and physical separation. High reliability of reactor scram is further achieved by separation of scram and manual control circuitry, individual control units for each control rod, and fail-safe design features built into the CRD system. Response by the RPS is prompt, and the total scram time is short.*

*In operating the reactor, there is a spectrum of possible control rod worths, depending on the reactor state and the control rod pattern chosen for operation. Control rod withdrawal sequences and patterns are selected to achieve optimum core performance and low individual rod worths. The RWM prevents rod withdrawal other than by the preselected rod withdrawal pattern. These functions assist the operator with an effective backup control rod monitoring routine that enforces adherence to established startup, shutdown, and low-power-level operations. As a result of this carefully planned procedure, prompt shutdown of the reactor can be achieved with scram insertion of less than half of the many independent control rods. If accident conditions require a reactor scram, this can be accomplished rapidly with appropriate margin for the unlikely occurrence of malfunctions such as stuck rods.*

*The reactor core design assists in maintaining the stability of the core under accident conditions as well as during power operation. Reactivity coefficients in the power range that contribute to system stability are:*

- Fuel temperature or Doppler coefficient.*
- Moderator void coefficient.*
- Moderator temperature coefficient.*

*The overall power reactivity coefficient is negative and provides a strong negative reactivity feedback under severe power transient conditions.*

## HNP-2-FSAR-3

*The design of the reactivity control systems assures reliable control of reactivity under postulated accident conditions with appropriate margin for stuck rods. The capability to cool the core is maintained under all postulated accident conditions; thus, GDC 27 is satisfied.*

*For further discussion, see sections 4.2, 4.3, 4.4, 7.2, 7.6, 7.7, 7.10, and chapter 15.*

### Criterion 28 - Reactivity Limits

*"The reactivity control systems shall be designed with appropriate limits on the potential amount and rate of reactivity increase to assure that the effects of postulated reactivity accidents can neither (1) result in damage to the reactor coolant pressure boundary greater than limited local yielding nor (2) sufficiently disturb the core, its support structures or other reactor pressure vessel internals to impair significantly the capability to cool the core. These postulated reactivity accidents shall include consideration of rod ejection (unless prevented by positive means), rod dropout, steam line rupture, changes in reactor coolant temperature and pressure, and cold water addition."*

#### *Design Evaluation*

*The CRD system design incorporates appropriate limits on the potential amount and rate of reactivity increase. Control rod withdrawal sequences and patterns are selected to achieve optimum core performance and low individual rod worths. The RWM prevents withdrawal other than by the preselected rod withdrawal pattern. These functions assist the operator with an effective backup control rod monitoring routine that enforces adherence to established startup, shutdown, and low-power-level control rod procedures.*

*The control rod mechanical design incorporates a hydraulic velocity limiter in the control rod which prevents rapid rod ejection. This engineered safeguard protects against a high reactivity insertion rate by limiting the control rod velocity to  $< 5$  ft/s.*

*The safety analysis (chapter 15) evaluates the postulated reactivity accidents as well as the AOOs in detail. Analyses are included for rod dropout, steam line rupture, changes in reactor coolant temperature and pressure, and cold water addition. The initial conditions, assumptions, calculational models, sequence of events, and anticipated results of each postulated occurrence are covered in detail. The results of these analyses indicate that none of the postulated AOOs or accidents result in damage to the RCPB. In addition, the integrity of the core, its support structures, or other reactor pressure vessel internals are maintained so that the capability to cool the core is not impaired for any of the postulated reactivity accidents described in the safety analysis.*

*The design features of the reactivity control system which limit the potential amount and rate of reactivity increase ensure that GDC 28 is satisfied for all postulated reactivity accidents.*

*For further discussion, see sections 4.2, 4.3, 4.5, 5.2, 5.4, 5.5, and chapters 3 and 15.*

### Criterion 29 - Protection Against Anticipated Operational Occurrences

*"The protection and reactivity control systems shall be designed to assure an extremely high probability of accomplishing their safety functions in the event of anticipated operational occurrences."*

## HNP-2-FSAR-3

### *Design Evaluation*

*The high functional reliability of the protection and reactivity control systems is achieved through the combination of logic arrangement, redundancy, physical and electrical independence, functional separation, fail-safe design, and inservice testability. These design features are discussed in GDC 21, 22, 23, 24, and 26.*

*An extremely high probability of correct protection and reactivity control systems response to AOOs is maintained by a thorough program of inservice testing and surveillance. Active components can be tested or removed from service for maintenance during reactor operation without compromising the protection or reactivity control functions even in the event of a subsequent single failure. Components important to safety such as CRDs, MSIVs, pumps, etc., are tested during normal reactor operation. Functional testing and calibration schedules are developed using available failure rate data, reliability analyses, and operating experience. These schedules represent an optimization of protection and reactivity control system reliability by considering, on one hand, the reliability effects during individual component testing on the portion of the system not undergoing test. The capability for inservice testing ensures the high functional reliability of protection and reactivity control systems should a reactor variable exceed the corrective action setpoint.*

*The capabilities of the protection and reactivity control systems to perform their safety functions in the event of AOOs are satisfied in agreement with the requirements of GDC 29.*

*For further discussion, see sections 4.2, 5.5, 6.2, 6.3, 7.2, 7.3, 7.6, and chapter 15.*

### *Criterion 30 - Quality of Reactor Coolant Pressure Boundary*

*"Components which are part of the reactor coolant pressure boundary shall be designed, fabricated, erected, and tested to the highest quality standards practical. Means shall be provided for detecting and, to the extent practical, identifying the location of the source of reactor coolant leakage."*

### *Design Evaluation*

*By utilizing conservative design practices and detailed quality control procedures, the pressure retaining components of the RCPB are designed and fabricated to retain their integrity during normal and postulated accident conditions. Accordingly, components which comprise the RCPB are designed, fabricated, erected, and tested in accordance with recognized industry codes and standards listed in chapter 5. Further product and process quality planning is provided to assure conformance with the applicable codes and standards and to retain appropriate documented evidence verifying compliance. Because the subject matter of this criterion deals with the aspects of the RCPB, further discussion on this subject is treated in the response to GDC 14.*

*Means are provided for detecting reactor coolant leakage. The leak detection system consists of sensors and instruments to detect, annunciate, and, in some cases, isolate the RCPB from potential hazardous leaks before predetermined limits are exceeded. Small leaks are detected by temperature and pressure changes, increased frequency of sump pump operation, and by measuring fission product concentration in the primary containment atmosphere. In addition to these means of detection, large leaks are detected by flowrates in process lines and changes in reactor water level. The allowable leakage rates have been based on the predicted and experimentally determined behavior of cracks in pipes, the ability to makeup*

## HNP-2-FSAR-3

coolant system leakage, the normally expected background leakage due to equipment design, and the detection capability of the various sensors and instruments. The total leakage rate limit is established so that, in the absence of normal ac power concomitant with a loss of feedwater supply, makeup capabilities are provided by the CRD and RCIC systems. While the leak detection system provides protection from small leaks, the ECCS network provides protection for the complete range of discharges from ruptured pipes. Thus, protection is provided for the full spectrum of possible discharges.

The RCPB and the leak detection system are designed to meet the requirements of GDC 30.

For further discussion, see sections 5.2, 5.4, 5.5, 7.6, and chapters 3 and 15.

### Criterion 31 - Fracture Prevention of Reactor Coolant Pressure Boundary

"The reactor coolant pressure boundary shall be designed with sufficient margin to assure that, when stressed under operating, maintenance, testing, and postulated accident conditions (1) the boundary behaves in a nonbrittle manner and (2) the probability of rapidly propagating fracture is minimized. The design shall reflect consideration of service temperatures and other conditions of the boundary material under operating, maintenance, testing, and postulated accident conditions and the uncertainties in (1) determining material properties, (2) the effects of irradiation on material properties, (3) residual, steady state, and transient stresses, and (4) size of flaws."

#### *Design Evaluation*

Brittle fracture control of pressure-retaining ferritic materials is provided to ensure protection against nonductile fracture. To minimize the possibility of brittle fracture failure of the reactor pressure vessel, it is designed to meet the requirements of the ASME Boiler and Pressure Vessel Code, Section III.

The NDTT is defined as the temperature below which ferritic steel breaks in a brittle rather than ductile manner. The NDTT increases as a function of neutron exposure at integrated neutron exposures greater than about  $3.8 \times 10^{17}$  nvt with neutrons of energies in excess of 1 MeV. Since the material NDTT dictates the minimum operating temperature at which the reactor vessel can be pressurized, it is desirable to keep the NDTT as low as possible.

The reactor assembly design provides an annular space from the outermost fuel assemblies to the inner surface of the reactor vessel that serves to attenuate the fast neutron flux incident upon the reactor vessel wall. This annular volume contains the core shroud, jet pump assemblies, and reactor coolant. Assuming plant operation at rated power availability of 100% and a plant life of 40 years, the fast neutron fluence at the inner surface of the vessel is calculated to be  $3.8 \times 10^{17}$  nvt. (A fast neutron fluence consists of neutrons having energies  $> 1$  MeV.)

The end-of-life NDTT provides a substantial margin for the prevention of brittle fracture because the vessel cannot be pressurized until coolant temperatures exceed 212°F. For hydrostatic test, the vessel is not pressurized until the vessel temperature exceeds the NDTT by at least 60°F. Therefore, during operation when pressure depends on temperature, brittle failure of the vessel is not possible until the neutron fluence of the reactor vessel reaches a value of the order of  $10^{20}$  nvt. This value is more than 250 times the maximum fast neutron fluence calculated during the lifetime of this plant.

## HNP-2-FSAR-3

*The RCPB is designed, maintained, and tested such that adequate assurance is provided so that the boundary behaves in a nonbrittle manner throughout the life of the plant.*

*For further discussion, see sections 5.2, 5.4, and chapter 15.*

### Criterion 32 - Inspection of Reactor Coolant Pressure Boundary

*"Criteria which are part of the reactor coolant pressure boundary shall be designed to permit (1) periodic inspection and testing of important areas and features to assess their structural and leaktight integrity, and (2) an appropriate material surveillance program for the reactor pressure vessel."*

#### *Design Evaluation*

*The HNP-2 design conforms with the intent of GDC 32. The unit's RCPB design meets the requirements of the ASME Boiler and Pressure Vessel Code, Section XI, including Summer 1971 Addenda, except replacement of recirculation piping, stainless steel portions of RHR, and portions of RWC which meet the inspection requirements of the Winter 1980 Addenda which requires access for all required inspections. The design also permits the conduct of a material surveillance program for the reactor pressure vessel. Additional details of these features can be found in subsections 5.2.8 and 5.2.4.*

*The reactor recirculation piping and main steam piping were hydrostatically tested with the reactor pressure vessel at a test pressure that is in accordance with Section III of the ASME Code. Current hydrostatic testing is in accord with Section XI requirements (subsection 5.2.8).*

*Vessel material surveillance samples are located within the reactor pressure vessel to enable periodic monitoring of material properties with exposure. The program includes specimens of the base metal, heat-affected zone within the base metal, and weld metal.*

*For further discussion, see sections 5.2, 5.4, 5.5, and chapter 3.*

### Criterion 33 - Reactor Coolant Makeup

*"A system to supply reactor coolant makeup for protection against small breaks in the reactor coolant pressure boundary shall be provided. The system safety function shall be to assure that specified acceptable fuel design limits are not exceeded as a result of reactor coolant loss due to leakage from the reactor coolant pressure boundary and rupture of small piping or other small components which are part of the boundary. The system shall be designed to assure that for onsite electric power system operation (assuming offsite power is not available) and for offsite electric power system operation (assuming onsite power is not available) the system safety function can be accomplished using the piping, pumps, and valves used to maintain coolant inventory during normal reactor operation."*

## HNP-2-FSAR-3

### *Design Evaluation*

*The total leakage rate limit is established so that, in the absence of normal ac power concomitant with a loss of feedwater supply, makeup capabilities are provided by the CRD and RCIC systems. While the leak detection system provides protection from small leaks, the ECCS provides protection for the complete range of discharges from ruptured pipes. Thus, protection is provided for the full spectrum of possible discharges to the extent that fuel-cladding temperature limits are not exceeded.*

*The plant is designed to provide ample reactor coolant makeup for protection against small leaks in the RCPB for AOOs and postulated accident conditions. The design of these systems meets the requirements of GDC 33.*

*For further discussion, see sections 5.2, 5.6, 6.3, and 7.6.*

### *Criterion 34 - Residual Heat Removal*

*"A system to remove residual heat shall be provided. The system safety function shall be to transfer fission-product decay heat and other residual heat from the reactor core at a rate such that specified acceptable fuel design limits and the design conditions of the reactor coolant pressure boundary are not exceeded.*

*Suitable redundancy in components and features and suitable interconnections, leak detection, and isolation capabilities shall be provided to assure that for onsite electric power system operation (assuming offsite power is not available) and for offsite electric power system operation (assuming onsite power is not available) the system safety function can be accomplished, assuming a single failure."*

### *Design Evaluation*

*The RHR system provides the means to:*

- *Remove decay heat and residual heat from the nuclear system so that refueling and nuclear system servicing can be performed.*
- *Supplement the FPCC system capacity during shutdown to provide additional cooling capacity.*

*The major equipment of the RHR system consists of two heat exchangers, four main system pumps, and four service water pumps. The equipment is connected by associated valves and piping, and the controls and instrumentation are provided for proper system operation. The main system pumps are sized on the basis of the flow required during the LPCI mode of operation, which is the mode requiring the maximum flowrate. The heat exchangers are sized on the basis of the required duty for the shutdown cooling function, which is the mode requiring the maximum heat exchanger capacity.*

*One loop, consisting of a heat exchanger, two main system pumps in parallel, and associated piping, is located in one area of the reactor building. The other heat exchanger, pumps, and piping forming a second loop, are located in another area of the reactor building to minimize the possibility of a single physical event causing the loss of the entire system. The two loops of the RHR system are*

## HNP-2-FSAR-3

*cross-connected by a single header, making it possible to supply either loop from the pumps in the other loop. Either of these redundant loops can meet fully the most limiting of the three modes of operation.*

*The RHR system is designed for three modes of operation:*

- *Shutdown cooling.*
- *Containment cooling.*
- *LPCI.*

*Both normal ac power and auxiliary onsite power systems provide adequate power to operate all the auxiliary loads necessary for plant operation. The power sources for the plant auxiliary power system are sufficient in number and of such electrical and physical independence that no single probable event could interrupt all auxiliary power at one time.*

*The plant auxiliary buses supplying power to engineered safety features (ESFs) and RPSs and those auxiliaries required for safe shutdown are connected by appropriate switching to the standby diesel-driven generators located in the plant. Each power source, up to the point of its connection to the auxiliary power buses, is capable of complete and rapid isolation from any other source.*

*Loads important to plant operation and safety are split and diversified between switch gear sections, and means are provided for detection and isolation of system faults.*

*The plant layout is designed to effect physical separation of essential bus sections, standby generators, switchgear, interconnections, feeders, power centers, motor control centers, and other system components.*

*Three standby diesel generators (one shared with HNP-1) are provided to supply a source of electrical power which is self-contained within the plant and is not dependent on external sources of supply. The standby generators produce ac power at a voltage and frequency compatible with the normal bus requirements for essential equipment within the plant. Each of the diesel generators has sufficient capacity to start and carry the essential loads it is expected to drive. All of the auxiliary loads required for safe and orderly shutdown, including components of the RHR system, are duplicated and connected to separate buses.*

*The RHR systems are adequate to remove residual heat from the reactor core to assure fuel and RCPB design limits are not exceeded. Redundant offsite and onsite electric power systems are provided. The design of the RHR system, including their power supplies, meets the requirements of Criterion 34.*

*For further discussions, see sections 5.5, 6.3, 7.3, 8.3, 9.2, and chapter 15.*

### Criterion 35 - Emergency Core Cooling

*"A system to provide abundant emergency core cooling shall be provided. The system safety function shall be to transfer heat from the reactor core following any loss of reactor coolant at a rate such that*



## HNP-2-FSAR-3

*(1) fuel and clad damage that could interfere with continued effective core cooling is prevented and  
(2) clad metal-water reaction is limited to negligible amounts.*

*Suitable redundancy in components and features and suitable interconnections, leak detection, isolation, and containment capabilities shall be provided to assure that for onsite electric power system operation (assuming offsite power is not available) and for offsite electric power system operation (assuming onsite power is not available) the system safety function can be accomplished, assuming a single failure."*

### *Design Evaluation*

*The ECCS consists of the following subsystems:*

- *High-pressure coolant injection (HPCI) system.*
- *ADS.*
- *Core spray (CS) system.*
- *LPCI (an operating mode of the RHR system).*

*The ECCS is designed to limit fuel-cladding temperature over the complete spectrum of possible break sizes in the nuclear system process barrier, including a complete and sudden circumferential rupture of the largest pipe connected to the reactor vessel.*

*The HPCI system consists of a steam turbine, a constant-flow pump, system piping, valves, controls, and instrumentation. The HPCI system is provided to assure that the reactor core is adequately cooled to prevent excessive fuel-cladding temperatures for breaks in the nuclear system which do not result in rapid depressurization of the reactor vessel. The HPCI system continues to operate until reactor vessel pressure is below the pressure at which LPCI operation or CS system operation maintains core cooling. Two sources of water are available, namely the condensate storage tank or the suppression pool.*

*In case the capability of the feedwater pumps, CRD water pumps, and RCIC and HPCI systems is not sufficient to maintain the reactor water level, the ADS functions to reduce the reactor pressure so that flow from LPCI and the CS system enters the reactor vessel in time to cool the core and prevent excessive fuel-cladding temperature. The ADS uses several of the nuclear system pressure relief valves to relieve the high pressure steam to the suppression pool.*

*Two independent loops are provided as a part of the CS system. Each loop consists of a centrifugal water pump driven by an electric motor, a spray sparger in the reactor vessel above the core, piping, and valves to convey water from the suppression pool to the sparger, and the associated controls and instrumentation. In case of low water level in the reactor vessel or high pressure in the drywell, the CS system automatically sprays water onto the top of the fuel assemblies in time and at a sufficient flowrate to cool the core and prevent excessive fuel temperature. LPCI starts from the same signals which initiate the CS and operates independently to achieve the same objective by flooding the reactor vessel.*

*In case of low water level in the reactor or high pressure in the containment drywell, the LPCI mode of operation of the RHR system pumps water into the reactor vessel in time to flood the core and prevent*

## HNP-2-FSAR-3

*excessive fuel temperature. LPCI operation provides protection to the core for the case of a large break in the nuclear system when the feedwater pumps and the HPCI system are unable to maintain reactor vessel water level. Protection provided by LPCI also extends to a small break where the ADS has operated to lower the reactor vessel pressure so LPCI and the CS system start to provide core cooling.*

*Results of the performance of the ECCS for the entire spectrum of liquid line breaks are discussed in section 6.3.*

*The ECCS provided is adequate to prevent fuel and cladding damage which could interfere with effective core cooling and do limit clad metal-water reaction to a negligible amount. Redundant offsite and onsite electric power systems are provided. The design of each ECCS subsystem, including power supplies, meets the requirements of GDC 35.*

*For further discussion, see sections 5.5, 6.3, 7.3, 8.3, 9.2, and chapter 15.*

### Criterion 36 - Inspection of Emergency Core Cooling System

*"The emergency core cooling system shall be designed to permit appropriate periodic inspection of important components, such as spray rings in the reactor pressure vessel, water injection nozzles, and piping, to assure the integrity and capability of the system."*

#### *Design Evaluation*

*The CS spargers within the vessel are accessible for remote visual inspection during refueling outages. Removable plugs in the sacrificial shield and/or panels in the insulation provide access for examination of nozzles from the vessel outside diameter. Removable insulation is provided on the ECCS piping out to and including the first isolation valve outside containment. Inspection of the ECCS is in accordance with the intent of Section XI of the ASME Code insofar as is practicable.*

*During plant operations, the pumps, valves, piping, instrumentation, wiring, and other components outside the primary containment can be visually inspected at any time. Components inside the primary containment can be inspected when the drywell is open for access. When the reactor vessel is open for refueling or other purposes, the spargers and other internals can be inspected. Portions of the ECCS which are part of the RCPB are designed to specifications for inservice inspection to detect defects which might affect the cooling performance. Particular attention is given to the reactor nozzles, CS, and feedwater spargers. The design of the reactor vessel and internals for inservice inspection and the plant testing and inspection program ensures that the requirements of GDC 36 are met. Refer to subsection 5.2.8 for a further discussion on ECCS inservice inspection.*

## HNP-2-FSAR-3

### Criterion 37 - Testing of Emergency Core Cooling System

*"The emergency core cooling system shall be designed to permit appropriate periodic pressure and functional testing to assure (1) the structural and leaktight integrity of its components, (2) the operability and performance of the active components of the system, and (3) the operability of the system as a whole and, under conditions as close to design as practical, the performance of the full operational sequence that brings the system into operation, including operation of applicable portions of the protection system, the transfer between normal and emergency power sources, and the operation of the associated cooling water system.*

#### *Design Evaluation*

*The ECCS consists of the HPCI system, ADS, LPCI mode of the RHR system, and the CS system. Each of these systems is provided with sufficient test connections and isolation valves to permit appropriate periodic pressure testing to assure the structural and leaktight integrity of its components.*

*The HPCI system, LPCI, and CS system are designed to permit periodic testing to assure the operability and performance of the active components of each system.*

*The complete ECCS is subjected to tests to verify the performance of the full operational sequence that brings each system into operation.*

*The operation of the associated cooling-water systems is discussed in the response to GDC 46."*

### Criterion 38 - Containment Heat Removal

*"A system to remove heat from the reactor containment shall be provided. The system safety function shall be to reduce rapidly, consistent with the functioning of other associated systems, the containment pressure and temperature following any loss-of-coolant accident and to maintain them at acceptably low levels.*

*Suitable redundancy in components and features and suitable interconnections, leak detection, isolation, and containment capabilities shall be provided to assure that for onsite electric power system operation (assuming offsite power is not available) and for offsite electric power system operation (assuming onsite power is not available) the system safety function can be accomplished, assuming a single failure."*

#### *Design Evaluation*

*In the event of a LOCA within the reactor containment, the pressure suppression system rapidly condenses the steam to prevent containment overpressure. The containment feature of pressure suppression employs two separate compartmented sections of the primary containment: the drywell that houses the nuclear system and the suppression chamber containing a large volume of water. Any increase in pressure in the drywell from a leak in the nuclear system is relieved below the surface of the suppression chamber water pool by connecting vent lines, thereby condensing steam being released to the drywell. The pressure buildup in the suppression chamber is equalized with the drywell by a vent line and vacuum breaker arrangement. Cooling systems remove heat from the reactor core, the drywell, and from the water in the suppression chamber during accident condition and, thus, continuous cooling of the primary containment is provided.*

## HNP-2-FSAR-3

*The ECCS is actuated to provide core cooling in the event of a LOCA. Low water level in the reactor vessel or high pressure in the drywell initiates the ECCS to prevent excessive fuel temperature. Sufficient water is provided in the suppression pool to accommodate the initial energy which can transiently be released into the drywell from the postulated pipe failure.*

*The suppression chamber is sized to contain this water plus the water displaced from the reactor primary system, together with the free air initially contained in the drywell.*

*Either or both RHR heat exchangers can be manually activated to remove energy from the containment. The redundancy and capability of the offsite and onsite electrical power systems for the RHR system is presented in the evaluation against GDC 34.*

*The pressure suppression system is capable of rapid containment pressure and temperature reduction following a LOCA to assure that the design limits are not exceeded. Redundant offsite and onsite electrical power systems are provided. The design of the containment RHR meets the requirements of GDC 38.*

*For further discussion, see sections 5.5, 6.2, 6.3, 7.3, and chapters 8, 9, and 15.*

### Criterion 39 - Inspection of Containment Heat Removal System

*"The containment heat removal system shall be designed to permit appropriate periodic inspection of important components, such as the torus, sumps, spray nozzles, and piping, to assure the integrity and capability of the system."*

#### *Design Evaluation*

*Provisions are made to facilitate periodic inspections of active components and other important equipment of the containment pressure-reducing systems. During plant operations, the pumps, valves, piping, instrumentation, wiring, and other components outside the primary containment can be visually inspected periodically. Components inside the primary containment can be inspected when the drywell is open for access. The testing frequencies of most components are correlated with the component inspection.*

*The suppression chamber is designed to permit appropriate periodic inspection. Space is provided outside the chamber for inspection and maintenance. There are two hatches that permit access to the suppression chamber for inspection.*

*The containment heat removal system is designed to permit periodic inspection of major components both outside and within the primary containment. This design meets the requirements of Criterion 39.*

*For further discussion, see sections 5.5, 6.2, 6.3, 7.3, and 9.2.*

### Criterion 40 - Testing of Containment Heat Removal System

*"The containment heat removal system shall be designed to permit appropriate periodic pressure and functional testing to (1) assure the structural and leaktight integrity of its components, (2) the operability and performance of the active components of the system, and (3) the operability of the system as a whole*

## HNP-2-FSAR-3

*and, under conditions as close to the design as practical, the performance of the full operational sequence that brings the system into operation, including operation of applicable portions of the protection system, the transfer between normal and emergency power sources, and the operation of the associated cooling water system."*

### *Design Evaluation*

*The containment heat removal function is accomplished by the containment cooling mode of the RHR system. This mode consists of the suppression pool cooling subsystem and containment spray subsystem.*

*The RHR system is provided with sufficient test connections and isolation valves to permit periodic pressure testing. The pumps and valves of the RHR system are operated periodically to verify operability.*

### *Criterion 41 - Containment Atmosphere Cleanup*

*"Systems to control fission products, hydrogen, oxygen, and other substances which may be released into the reactor containment shall be provided as necessary to reduce, consistent with the functioning of other associated systems, the concentration and quantity of fission products released to the environment following postulated accidents and to control the concentration of hydrogen or oxygen and other substances in the containment atmosphere following postulated accidents to assure that containment integrity is maintained.*

*Each system shall have suitable redundancy in components and features and suitable interconnections, leak detection, isolation, and containment capabilities to assure that, for onsite electric power system operation (assuming offsite power is not available) and for offsite electric power system operation (assuming onsite power is not available), its safety function can be accomplished, assuming a single failure."*

### *Design Evaluation*

*Fission products released into the reactor building following postulated accidents are automatically processed by the SGTS. The SGTS initiation follows high radiation signals from monitors in the refueling floor exhaust duct, monitors in the reactor building exhaust duct or from the primary containment isolation system. The ability of this system to remove radioactivity from the process stream is discussed in subsection 6.2.4. The SGTS is composed of two trains which are separated physically and electrically so that a single failure does not prevent its function. The redundancy of this system is also discussed in subsection 6.2.4.*

*A combustible gas control system (CGCS), which is now removed and piping retired in place, consisted of redundant hydrogen recombiners to maintain hydrogen and oxygen concentrations below flammable limits following a postulated LOCA. The system processed the primary containment atmosphere continuously following manual initiation. The system was designed in accordance with the Branch Technical Position CSB 6-2, attached to USNRC Regulatory Standard Review Plan, Subsection 6.2.5, March 1975, and met the requirements of an ESF system. The title 10 CFR 50.44 no longer defines a design-basis LOCA hydrogen release and no longer requires hydrogen control systems to mitigate such a release. The hydrogen and oxygen concentrations are maintained below flammable limits following a postulated LOCA by the containment atmospheric dilution (CAD) system, a subsystem to the primary containment purge and inerting system. A detailed description is provided in paragraph 6.2.5.6.*

## HNP-2-FSAR-3

### Criterion 42 - Inspection of Containment Atmosphere Cleanup Systems

*"The containment atmosphere cleanup systems shall be designed to permit appropriate periodic inspection of important components, such as filter frames, ducts, and piping, to assure the integrity and capability of the system."*

#### *Design Evaluation*

*Inspection of the internal structure of the SGTS filter banks is facilitated by access doors installed in each unit to allow entry to the unit for visual inspection of structural members and filter faces.*

*Each charcoal bed is provided with facilities for taking a sample of charcoal.*

*For a further discussion of the SGTS inspection features, refer to paragraph 6.2.4.5.*

### Criterion 43 - Testing of Containment Atmosphere Cleanup Systems

*"The containment atmosphere cleanup systems shall be designed to permit appropriate periodic pressure and functional testing to assure (1) the structural and leaktight integrity of its components, (2) the operability and performance of the active components of the systems such as fans, filters, dampers, pumps, and valves, and (3) the operability of the systems as a whole and, under conditions as close to design as practical, the performance of the full operational sequence that brings the system into operation, including operation of applicable portions of the protection system, the transfer between normal and emergency power sources, and the operation of associated systems."*

#### *Design Evaluation*

*Each unit of the SGTS is operated periodically to ascertain the operability and performance of the major active components such as fans, filters, motors, and valves, and structural integrity of the unit. This test also verifies the operability of the system as a whole and operability of all associated subsystems. See paragraph 8.3.1.1 for a discussion of the testing of the auxiliary power system.*

*The leaktightness of the high-efficiency particulate air (HEPA) filters is measured by the dioctyl phthalate (DOP) test. The charcoal beds are checked for bypass with halogenated hydrocarbon. The efficiency of the charcoal adsorbers is checked by lab testing. For further discussion on testing, refer to paragraph 6.2.4.5.*

### Criterion 44 - Cooling Water

*"A system to transfer heat from structures, systems, and components important to safety to an ultimate heat sink shall be provided. The system safety function shall be to transfer the combined heat load of these structures, systems, and components under normal operating and accident conditions.*

*Suitable redundancy in components and features and suitable interconnections, leak detection, and isolation capabilities shall be provided to assure that for onsite electric power system operation (assuming offsite power is not available) and for offsite electric power system operation (assuming onsite power is not available) the system safety function can be accomplished, assuming a single failure."*

## HNP-2-FSAR-3

### *Design Evaluation*

*The RHR service water (RHRSW) system (subsection 9.2.7) and the plant service water (PSW) system (subsection 9.2.1) transfer the heat loads from structures, systems, and components important to safety during normal operating, shutdown, and accident conditions to the ultimate heat sinks (subsection 9.2.5).*

*The RHRSW and PSW systems are designed with sufficient redundancy of components and piping so that no single failure can prevent the achieving of the safety cooling objective. Assuming a single failure, the electrical power supplies to valving are such that at least one train of cooling water is provided. Sufficient redundancy exists in the electrical power supply to ensure minimum safety pumping requirements are met. (See paragraph 8.3.1.4.)*

### *Criterion 45 - Inspection of Cooling-Water System*

*"The cooling water system shall be designed to permit appropriate periodic inspection of important components, such as heat exchangers and piping, to assure the integrity and capability of the system."*

### *Design Evaluation*

*To the extent practical and consistent with other design considerations, the components of the RHRSW and PSW systems are located to facilitate visual inspection. (See subsections 9.2.7 and 9.2.1.)*

### *Criterion 46 - Testing of Cooling-Water System*

*"The cooling water system shall be designed to permit appropriate periodic pressure and functional testing to assure (1) the structural and leaktight integrity of its components, (2) the operability and the performance of the active components of the system, and (3) the operability of the system as a whole and, under conditions as close to design as practical, the performance of the full operational sequence that brings the system into operation for reactor shutdown and for loss-of-coolant accidents, including operation of applicable portions of the protection system and the transfer between normal and emergency power sources."*

### *Design Evaluation*

*The pumps and automatic valves are tested periodically to verify operation. Since the PSW system is normally in operation, no special tests are required to ensure that the system can operate in an emergency. Periodic tests are conducted to verify the operation of the RHRSW system. The specific tests which are to be conducted are discussed more fully in the Technical Specifications, the associated Bases, and plant procedures. Chapter 8 discusses the tests which are conducted to ensure the availability of electrical power. The pumps and valves of these systems which must operate in an emergency are powered from a standby ac distribution system.*

### *Criterion 50 - Containment Design Basis*

*"The reactor containment structure, including access openings, penetrations, and the containment heat removal system, shall be designed so that the containment structure and its internal compartments can accommodate, without exceeding the design leakage rate and, with sufficient margin, the calculated pressure and temperature conditions resulting from any loss-of-coolant accident. This margin shall*

## HNP-2-FSAR-3

reflect consideration of (1) the effects of potential energy sources which have not been included in the determination of the peak conditions, such as energy in steam generators and energy from metal-water and other chemical reactions that may result from degraded emergency core cooling functioning, (2) the limited experience and experimental data available for defining accident phenomena and containment responses, and (3) the conservatism of the calculational model and input parameters."

### *Design Evaluation*

The containment structure, access openings, penetrations, heat removal system, and internal compartments are designed with sufficient margin to meet the intent of GDC 50.

### Criterion 51 - Fracture Prevention of Containment Pressure Boundary

"The reactor containment boundary shall be designed with sufficient margin to assure that, under operating, maintenance, testing, and postulated accident conditions, (1) its ferritic materials behave in a nonbrittle manner and (2) the probability of rapidly propagation fracture is minimized. The design shall reflect consideration of service temperatures and other conditions of the containment boundary material during operation maintenance, testing, and postulated accident conditions and the uncertainties in determining (1) material properties, (2) residual, steady-state, and transient stresses, and (3) size of flaws."

### *Design Evaluation*

The reactor containment vessel is fabricated to the requirements of the ASME Boiler and Pressure Vessel Code, Section III, Subsection NE for Class ML components. This code in article NE-2000 gives due recognition to the requirement that containment materials behave in a ductile manner for all conditions of service, thus assuring that its ferritic materials behave in a nonbrittle manner and that the probability of rapidly propagating fracture is minimized. The lowest design service temperature is conservatively taken as 30°F. The actual service temperature is calculated to be ~ 135°F. Thus, sufficient margin is inherent in the design to account for the various uncertainties involved in design and fabrication.

### Criterion 52 - Capability for Containment Leakage Rate Testing

"The reactor containment and other equipment which may be subjected to containment test conditions shall be designed so that periodic integrated leakage rate testing can be conducted at containment design pressure."

### *Design Evaluation*

The primary reactor containment and other equipment including the personnel airlock and isolation valves are designed to permit type A, B, and C leakage tests to be conducted in accordance with Appendix J of 10 CFR 50. A more complete discussion can be found in subsection 3.8.2 and in the Technical Specifications.

### Criterion 53 - Provisions for Containment Testing and Inspection

"The reactor containment shall be designed to permit (1) appropriate periodic inspection of all important areas, such as penetrations, (2) an appropriate surveillance program, and (3) periodic testing at



## HNP-2-FSAR-3

*containment design pressure of the leaktightness of penetrations which have resilient seals and expansion bellows."*

### *Design Evaluation*

*The reactor containment is designed to optimize the accessibility of important areas to permit required inspection and surveillance.*

*All penetrations with resilient seals or expansion bellows are the double seal type. The space between the seals may be periodically pressurized to containment design pressure and their leaktightness verified. This is discussed in subsection 3.8.2.*

### *Criterion 54 - Piping Systems Penetrations Containment*

*"Piping systems penetrating primary reactor containment shall be provided with leak detection, isolation, and containment capabilities having redundancy, reliability, and performance capabilities which reflect the importance to safety of isolating these piping systems. Such piping systems shall be designed with a capability to test periodically the operability of the isolation valves and associated apparatus and to determine if valve leakage is within acceptable limits."*

### *Design Evaluation*

*Piping systems which penetrate the drywell have been accorded special design considerations to reflect their importance in accomplishing safety-related functions and in achieving isolation, if required. The penetrations are discussed in subsections 3.8.2 and 6.2.1. Both the isolation valving and system which initiates isolation use components whose quality maximizes reliability and are provided with sufficient independence and redundancy, to optimize the isolation function should it be required. Containment isolation is discussed in subsections 3.8.2 and 6.2.5, and the system which initiates isolation is discussed in subsection 7.3.2.*

*The operation of remote manual isolation valves is periodically verified according to the Technical Specifications. Sufficient test connections are provided to each of these piping systems to ensure that minimal valve leakage is achieved and maintained (paragraph 6.2.1.4).*

### *Criterion 55 - Reactor Coolant Pressure Boundary Penetrating Containment*

*"Each line that is part of the reactor coolant pressure boundary and that penetrates the primary reactor containment shall be provided with containment isolation valves as follows unless it can be demonstrated that the containment isolation provisions for a specific class of lines, such as instrument lines, are acceptable on some other defined basis:*

- (1) One locked-closed isolation valve inside and one locked-closed isolation valve outside containment.*
- (2) One automatic isolation valve inside and one locked-closed isolation valve outside containment.*

## HNP-2-FSAR-3

- (3) *One locked-closed isolation valve inside and one automatic isolation valve outside containment. A simple check valve may not be used as the automatic isolation valve outside containment.*
- (4) *One automatic isolation valve inside and one automatic isolation valve outside containment. A simple check valve may not be used as the automatic isolation valve outside containment."*

*Isolation valves outside containment shall be located as close to the containment as practical and upon loss of actuating power automatic isolation valves shall be designed to take the position that provides greater safety.*

*Other appropriate requirements to minimize the probability or consequences of an accidental rupture of these lines or of lines connected to them shall be provided as necessary to assure adequate safety. Determination of the appropriateness of these requirements, such as higher quality in design, fabrication, testing, additional provisions for inservice inspection, protection against more severe natural phenomena, and additional isolation valves and containment, shall include consideration of the population density, use characteristics, and physical characteristics of the site environs."*

### *Design Evaluation*

*The RCPB consists of the RPV, the pressure-retaining appurtenance attached to the vessel, and valves and pipes which extend from the RPV up to and including the outermost isolation valve. The lines of the RCPB which penetrate the primary containment are capable of isolating the containment, thereby precluding any significant release of radioactivity. Similarly, for lines which do not penetrate the primary containment but which form a portion of the RCPB the design ensures that isolation from the RCPB can be achieved.*

### *Influent Lines*

*Influent lines which penetrate the primary containment and connect directly to the RPV are equipped with two isolation valves; one inside the containment and the other outside located as close to the containment as possible or a single isolation valve outside but as close to containment as possible with a closed system as the second isolation barrier.*

*Table 3.1-1 lists those influent pipes that comprise the RCPB. The purpose of this table is to review the design of each line with respect to the requirements imposed by GDC 55. The following discussion provides additional detail on the specific conformance of each line with GDC 55. (The comment numbers link applicable information to specific influent lines in table 3.1-1.)*

### *Comment 55.1*

*The portion of the feedwater line which forms part of the RCPB and penetrated the primary containment has three isolation valves. The valve inside the containment is a simple check valve while the two valves outside the containment are air assisted check valves.*

## HNP-2-FSAR-3

*The air-assisted check valve is an internal balance type in that the disc arm is cut out and mated with a shaft dog. With instrument air established on the spring loaded air cylinder, the valve disc is free to swing without movement of the shaft.*

*During normal feedwater flow, the valve disc is fully open by action of the force on the disc, due to flow alone. Upon reversal of flow the valve closes as a free swinging check valve. In addition, the control room operator may assist in starting valve closure by removing the open signal from the solenoid valve. The solenoid valve isolates the air supply to the cylinder and exhausts the cylinder air to the atmosphere. The air cylinder closing spring forces the piston downward, which in turn, acting through the piston rod, pulls down the closing lever on the shaft, and by means of closing dogs on the shaft and disc arm, closes and holds the disc to its seat.*

*The valve remains in this position until air pressure is again established in the cylinder and the piston is moved upward. During accidental loss of instrument air, the valve remains open because the force of the flow overcomes the spring force. The amount of valve opening is proportionate to the amount of flow. Should a break occur in the feedwater line, the check valves prevent significant loss of inventory and offer immediate isolation. During the postulated LOCA, it is desirable to maintain reactor coolant makeup from all sources of supply. For this reason, the outer feedwater isolation gate valve does not automatically isolate upon a signal from the primary containment isolation protection system.*

### *Comment 55.2*

*Influent lines which connect to process piping but do not penetrate the primary containment must adequately reflect the importance to safety of isolating these piping systems. Pipes of this type include those portions of the RCIC, the reactor water cleanup (RWC), and the HPCI lines that tie into the feedwater line. The RCIC and HPCI lines have motor-operated, automatic, and remote-manually actuated gate valves that are closed during normal operation, whereas the RWC line is open during operation and has a simple check valve to provide positive assurance of isolation in the event of a break upstream of this valve. In addition to the check valve, the RWC line has a normally open, remote, manually actuated, motor-operated globe valve capable of providing leakage control.*

### *Comment 55.3*

*The RHR suction and return lines to and from the recirculation system and the CS lines have a single, normally closed, automatic, and remote-manually actuated isolation valve as the inboard isolation barrier in each line. The isolation valve is installed outside primary containment and as close to the containment as possible. Since the CS and RHR systems meet the criteria for closed systems outside primary containment and are operating post-LOCA, adequate containment isolation provisions are provided and no additional primary containment isolation valves are required.*

*However, additional valves are provided inside primary containment on each of the subject lines to afford dual barriers between high- and low-pressure systems. The CS and RHR return lines utilize a check valve for this purpose. The RHR suction from the recirculation line uses a motor-operated gate valve.*

*The motor-operated gate valves in the suction line automatically close when primary coolant pressure is greater than the RHR system design pressure. Both suction gate valves also receive automatic primary containment isolation signals. Thus, the gate valve inside primary containment also serves as a backup to the isolation valve.*

## HNP-2-FSAR-3

*For the postulated LOCA, the protection system initiates automatic opening of the CS and LPCI valves at the appropriate time.*

### *Comment 55.6*

*The standby liquid control line utilizes a simple check valve as the isolation valve inside as well as outside the primary containment. GDC 55 states that a simple check valve may not be used as the automatic isolation valve outside the containment; however, should insertion of the liquid poison become necessary, it is imperative that the injection line be open. In the design of this system, it has been the accepted practice to omit an automatic valve that opens on signal as this introduces a possible failure mechanism. As a means of providing assurance for reliable timely actuation, an explosive valve is used. In this manner, the availability of the line is assured. Because the standby liquid control line is a closed, nonflowing line, rupture of this line is very remote. However, should a break occur, the check valves provide positive actuation for immediate isolation.*

### *Comment 55.7*

#### *Other*

#### *1. CRD Insert and Withdraw Lines*

*GDC 55 applies to lines of the RCPB which penetrate the primary reactor containment. The CRD insert and withdraw lines are not part of the RCPB.*

*The basis to which the CRD lines are designed is commensurate with the safety importance of isolating these lines. Since these lines are vital to the scram function, their operability is of utmost concern.*

*In the design of this system, it has been accepted practice to omit automatic valves for isolation purposes as this introduces a possible failure mechanism. As a means of providing positive actuation, manual shutoff valves are used. In the event of a break of these lines, the manual valves may be closed to ensure isolation. In addition, a ball valve located in the insert line is designed to automatically seal this line in the event of a break.*

*Finally, several breaks and combinations of breaks in the CRD lines have been postulated and analyzed (chapter 4). The results of these analyses indicate that the worst situation causes a leak rate which is negligible compared to the makeup capability.*

#### *2. TIP System*

*Since the TIP system lines do not communicate freely with the containment atmosphere and since they do not comprise a portion of the RCPB, GDC 56 and 55 are not directly applicable to this specific class of lines. The basis to which these lines are designed is more closely described by GDC 54, which states, in effect, that isolation capability of a system be commensurate with the safety importance of the isolation. Furthermore, even though the failure of the TIP system lines presents no safety hazard, the TIP system has redundant isolation capabilities. These and other safety features are described in the following paragraphs.*

## HNP-2-FSAR-3

*When the TIP system cable is inserted, the ball valve of the select tube opens automatically so that the probe and cable may advance. A maximum of four valves may be opened at any one time to conduct the calibration, and any one guide tube is used, at most, a few hours per year.*

*If closure of the line is required during calibration, a signal causes the cable to be retracted and the ball valve to close automatically after completion of cable withdrawal. To ensure isolation capability if a TIP cable fails to withdraw or a ball valve fails to close, an explosive shear valve is installed in each line. Upon receipt of a signal, this explosive valve shears the TIP cable and seal the guide tube.*

### *Comment 55.8*

*The recirculation pump seal water line extends from the recirculation pump through the drywell and connects to the CRD supply line outside the containment. Isolation is provided by a check valve installed inside primary containment and a check valve outside primary containment, installed as close to containment, as possible. Since the seal water line does form a part of the RCPB the consequence of breaking this line has been evaluated. This evaluation shows that the consequence of breaking this line is less severe than that of failing an instrument line. The recirculation pump seal water line is 3/4-in. Quality Group B from the recirculation pump through the second check valve. From this valve to the CRD connection the line is Quality Group D. Should this line be postulated to fail and either one of the check valves is assumed not to close, the flowrate through the broken line has been calculated to be substantially less than that permitted for a broken instrument line.*

*Therefore, the two check valves in series provide sufficient isolation capability for postulated failure of this line. Installation of an automatic power actuated valve outside primary containment would increase the probability of inadvertent isolation of the seal water supply, which could result in failure of the recirculation pump seal and a possibly avoidable breach of the primary coolant boundary during normal reactor operation.*

### *Effluent Lines*

*Effluent lines, except instrument sensing lines, and the RHR recirculation system suction which form part of the RCPB and penetrate the primary containment are equipped with two isolation valves; one inside the containment and the other outside located as close to the containment as possible.*

*Table 3.1-2 lists those effluent pipes that comprise the reactor coolant pressure boundary and which penetrate the primary containment.*

*Aside from the MSIVs, each valve is a motor-operated, automatic, or remote-manually actuated gate valve capable of providing adequate isolation protection in the event of a break in these lines. The MSIVs are air-operated, automatic, and remote-manually actuated globe valves which provide two distinct barriers against containment leakage. Upon loss of actuating power, automatic isolation valves assume the position that provides greater safety. The protection system initiates automatic isolation under accident conditions for effluent lines which are normally open during operation and which are not part of the overall safety system network.*

*Instrument lines are designed in accordance with Regulatory Guide 1.11, as discussed in subsection 6.2.5.*

## HNP-2-FSAR-3

### *Summary*

*In order to assure protection against the consequences of accidents involving the release of radioactive material, pipes which form the RCPB have been shown to provide adequate isolation capabilities on a case-by-case basis. In all cases, a minimum of two barriers is shown to protect against the release of radioactive materials. Adequate isolation capabilities were also demonstrated for pipes that connect to the feedwater line outside the primary containment.*

*In addition to meeting the isolation requirements stated in GDC 55, the pressure retaining components which comprise the RCPB are designed to meet other appropriate requirements which minimize the probability or consequences of an accidental rupture. The quality requirements for these components ensure that they are designed, fabricated, and tested to the highest quality standards of all reactor plant components.*

*It can, therefore, be concluded that the design of piping systems which comprise the RCPB satisfies GDC 55.*

*For further discussion, see subsections 6.2.5 and 7.3.2.*

### *Criterion 56 - Primary Containment Isolation*

*"Each line that connects directly to the containment atmosphere and penetrates the primary reactor containment shall be provided with containment isolation valves, as follows, unless it can be demonstrated that the containment isolation provisions for a specific class of lines, such as instrument lines, are acceptable on some other defined basis:*

- (1) One locked-closed isolation valve inside and one locked-closed isolation valve outside containment; or*
- (2) One automatic isolation valve inside and one locked-closed isolation valve outside containment; or*
- (3) One locked-closed isolation valve inside and one automatic isolation valve outside containment. A simple check valve may not be used as the automatic isolation valve outside containment; or*
- (4) One automatic isolation valve inside and one automatic isolation valve outside containment. A simple check valve may not be used as the automatic isolation valve outside containment.*

*Isolation valves outside containment shall be located as close to the containment as practical and, upon loss of actuating power, automatic isolation valves shall be designed to take the position that provides greater safety."*

### *Design Evaluation*

*Lines which penetrate the primary containment and communicate with the containment interior may be grouped into four categories:*

## HNP-2-FSAR-3

- *Pipes which communicate with the drywell or suppression chamber atmosphere.*
- *Influent lines to the suppression pool.*
- *Effluent lines from the suppression pool.*
- *Instrumentation sensing lines.*

### *Lines Which Communicate with the Drywell or Suppression Chamber Atmosphere*

*Several lines which penetrate the primary containment and communicate with the drywell or suppression pool atmosphere are provided with isolation valves outside primary containment, rather than one isolation valve inside and one isolation valve outside primary containment. These lines are identified in **Technical Requirements Manual (TRM) table T7.0-1 (incorporated by reference into the FSAR)**.*

*This deviation from the GDC is considered safe and adequate for the following reasons:*

- A. *Lines which penetrate the containment for atmosphere sampling or processing presently terminate at the inboard end of the welded-in drywell penetration sleeve. The sleeve and the piping connected to it on the outboard side of the primary containment are Seismic Category I, Quality Group B up to and including at least the second primary containment isolation valve.*

*Installation of the inboard isolation valve inside primary containment would require supporting the valves from the drywell shell, resulting in additional welds, and/or extending the piping, and adding supports from other structural members within the drywell. Since there is limited space within the drywell, placing these valves inside would severely impede accessibility for inspection and maintenance of the valves and other equipment.*

- B. *Placing the valves inside the containment would subject them to an inimical environment and, thus, increase the probability of failure.*

*The environment within the drywell and torus post-LOCA could be especially detrimental to the operation of the drywell and torus spray valves, since these modes of RHR would be used after the postulated event and the spray lines valves would be required to function during the postulated containment pressure transient.*

*The design spray coverage further necessitates the location of the spray header as close as practical to the interior of the drywell and torus shells.*

*Therefore, the isolation valve for each torus spray and drywell spray line is installed outside primary containment. The outboard isolation barrier is the closed RHR system. This system is Quality Group B, Seismic Category I, and has been evaluated for missile hazards.*

## HNP-2-FSAR-3

*In addition to the two barriers required by GDC 56, the torus and drywell spray lines each have a motor-operated valve installed inboard of the containment isolation valve. This design reflects the importance of avoiding an inadvertent initiation of containment sprays during plant operation. These valves also contribute additional conservatism to the containment isolation provisions since they will shut, if open, upon receipt of the same isolation signals as the isolation valves.*

- C. Several of the lines which fall into this category are not in use during normal operation and are, therefore, isolated. Valves which are normally closed during plant operation are identified in **TRM table T7.0-1**.*
- D. Valves are accessible in systems which must be available for long-term operation following an accident. Examples are the containment atmosphere monitoring lines and the H<sub>2</sub> recombiner system.*
- E. Isolation valves installed outside primary containment are compatible with minimizing personnel exposure during maintenance and inspections.*

*Isolation valves for this category of line are either locked closed, administratively closed, or are automatically closed upon receipt of an isolation signal (**TRM table T7.0-1**).*

*The isolation valves in each line are installed as close together and as close to the primary containment as practical.*

### *Influent Lines of Suppression Pool*

*The reasons for not placing valves inside the suppression chamber are similar to those mentioned in the preceding section. The following discussion provides unique considerations as to the types of valves and isolation capabilities for the RCIC and HPCI turbine exhaust lines, HPCI turbine condensate line, and RCIC vacuum pump discharge line.*

*These lines penetrate the torus and discharge below the minimum suppression pool water level. Two primary containment isolation valves are provided outside the torus on each line. The inboard isolation valve for each line is a locked open globe stop check valve. When in its normal position, open, the valve allows flow into the suppression pool. The valve may be manually closed by a local handwheel to provide long-term leakage control. When closed, the valve exhibits characteristics identical to a standard globe valve and tightly seals against flow in either direction. The outboard isolation valve is a simple swing check valve and functions as a redundant isolation valve to ensure backflow from the suppression pool is prohibited.*

*The HPCI and RCIC turbines are designed to operate with an exhaust pressure < 65 psia. A high-exhaust pressure trip and isolation signal are provided to avoid damage to the turbine and/or steam release to the secondary containment through the turbine seals. The installation of remotely operated or automatically operated isolation valves in these lines would increase the probability of inadvertent isolation of the exhaust lines for the HPCI and RCIC turbines and would, therefore, be detrimental to the operability of the systems.*



## HNP-2-FSAR-3

*The HPCI turbine condensate line is the normal drain path from the HPCI turbine exhaust line drain pot. Failure to maintain the drain pot adequately drained could ultimately result in a high-exhaust pressure. Therefore, the same design considerations apply to the isolation valves on this line as on the exhaust lines.*

*Operation of the turbine gland-seal condenser components is required to prevent outleakage from the turbine shaft seals. Therefore, the RCIC vacuum pump discharge line utilizes two check valves as isolation valves to reduce the probability of inadvertent isolation.*

*It should be noted that each of the lines in this category are Seismic Category I and Quality Group B, as required for ESF-related systems. Also, leak detection is provided, as described in paragraph 5.2.7.2.3.7.*

### *Suppression Chamber-to-Reactor Building Vacuum Relief Lines.*

*The suppression chamber-to-reactor building vacuum breakers consist of two lines penetrating into the suppression chamber atmosphere, each with a self actuating check valve and an air operated butterfly valve. This design does not meet the explicit statement of GDC 56 because the GDC prohibits the use of a simple check valve. However, the GDC also states that other criteria are acceptable if "...it can be demonstrated that the containment isolation provisions for a specific class of lines, ..., are acceptable on some other defined basis."*

*In the case of the suppression chamber-to-reactor building vacuum relief lines, the "other defined basis" is the GE design specification for these valves which explicitly states that one of these vacuum breaker valves may be self actuated instead of remotely operated, i.e., a simple check valve. This was reviewed and approved by the NRC and, as a result, the HNP-2 design for the suppression chamber to reactor building vacuum breakers complies with GDC 56 via the "other defined basis" portion of the GDC.*

### *Minimum Flow and Test Lines*

*These lines have isolation capabilities which are commensurate with the importance to safety of isolating these lines. The HPCI and RCIC minimum flow lines have two valves in series, both of which are located outside the primary containment. The RHR and CS minimum flow lines have single isolation valves, each a normally open, motor-operated gate valve, and the closed RHR or CS system serves as the second containment isolation barrier.*

*The HPCI and RCIC minimum flow lines utilize a normally shut, motor-operated globe valve as the inboard isolation barrier and an upstream check valve as the outboard isolation barrier. The globe valves also function as flow control devices and automatically shut when no start signal is present for the HPCI and RCIC turbines or when flow is established in the system.*

*The CS and RHR minimum flow line isolation valves cycle as required by system flow conditions. However, the valves may be remote-manually shut and leakage detection is provided as described in subsection 5.2.7.*

*In addition to the isolation valve, each CS and RHR minimum flow line has a swing check valve installed for reverse flow prevention. The check valve in each CS minimum flow line is installed inboard of the isolation valve, the RHR minimum flow check valves are installed outboard of the isolation valve. In each*

## HNP-2-FSAR-3

case, the check valve acts against flow from the primary containment direction and, therefore, provides additional conservatism in the containment isolation provisions designed for this class of line.

The jockey pump system maintains the CS and RHR pump discharge lines constantly full of water with two continuously running pumps. Minimum flow lines are provided for the jockey pumps to avoid overheating and damaging cavitation, either of which could occur if the pumps were continually running at shutoff head. The jockey pump minimum flow lines return water to the suppression pool via the CS test line. A single-globe stop check valve is installed in each minimum flow line as an isolation valve. Since the system is continually pressurized and operating, further isolation provisions are not required. Since the operation of the bypass lines discussed in the previous paragraphs is required to ensure the pumps are not damaged, the lines are important to the operations of the safety systems. Since automatic isolation valves could degrade the reliability of these systems, no further valving has been incorporated.

The CS test line has a single automatic isolation valve installed outside primary containment. The CS system is a Quality Group B, Seismic Category I, missile protected systems. Therefore, the closed system is the second isolation barrier and no further isolation is required. Also, CS operating pressure post-LOCA is  $> P_a$ .

The RHR test line has a single automatic isolation valve outside primary containment. RHR relief valves 2E11-F025A&B, -F029, and -F097 discharge into the test lines downstream of the containment isolation valves. Each relief valve has a setpoint  $< 1.5$  times the containment design pressure. Since RHR is a closed system and operates post-LOCA at a pressure greater than peak pressure, no further containment isolation provisions are provided in the relief valve lines or the RHR test line.

RHR relief valves 2E11-F055A&B and recombiner valves 2T49-F009A&B discharge into the suppression pool through two other penetrations. Design characteristics and isolation provisions of these lines are the same as for the relief valves discharging into the RHR test line.

All lines in this category terminate below the water level of the suppression pool. Each line is ESF related, is Seismic Category I, Quality Group B, and is part of a Seismic Category I, Quality Group B system. Leakage detection is available for this category of lines, as discussed in subsection 5.2.7.

### *Effluent Lines from Suppression Pool (RHR, CS, HPCI, RCIC)*

It should be noted that GDC 56 does not reflect consideration of the BWR suppression pool design. Certain lines, such as the RHR, CS, HPCI, and RCIC suction lines, penetrate below the waterline in the suppression pool and, therefore, do not communicate with the containment atmosphere. These lines do not have an isolation valve located inside the containment as this would necessitate placement of the valve under water. In effect, this would result in introducing a potentially unreliable valve in a highly reliable system, thereby compromising design. For this reason, these lines incorporate isolation valves outside the containment.

The HPCI and RCIC suction lines have two remote-manually operated isolation valves. The inboard valve is an air-operated butterfly valve located as close to the containment as possible. The second valve is a motor-operated gate valve.

The RHR and CS suction lines have a single, remote-manual, gate valve as a containment isolation valve. The second isolation barrier is provided by the respective closed system. In addition, the RHR and CS

## HNP-2-FSAR-3

*suction lines have an air-operated butterfly valve installed as close to the containment as possible, to facilitate isolating the gate valve for maintenance and testing.*

*Because of the importance of the above suction lines to core cooling, none of these valves receive an automatic isolation signal. Leakage detection capabilities are for those lines which have remote-manually operated isolation valves. The leakage detection provisions are discussed in paragraph 5.2.7.2.3.1 and subsection 9.3.3.*

*The torus drainage and purification system vacuum drag line has two air-operated butterfly valves with automatic isolation signals. The torus cleanup transfer system has two locked-closed manual gate valves and the piping downstream is blank flanged during normal operation to assure greater protection from fluid leakage.*

### *Instrumentation Lines which Communicate with the Primary Containment Atmosphere*

*Instrumentation sensing lines are designed in accordance with Regulatory Guide 1.11. Each line has a manual blocking valve for maintenance and testing and a remotely operated control valve for isolation.*

*Leakage in one of these sensing lines would be indicated by abnormal instrument outputs.*

*The instrumentation lines are further discussed in subsection 6.2.5.*

### *Hydrogen Recombiner System (This system equipment is removed and the piping retired in place.)*

*The hydrogen recombiner supply and return lines utilize a single remote-manual, motor-operated gate valve installed in each line as the inboard primary containment isolation barrier. The second, or outboard isolation barrier is provided by the closed system.*

*The remote-manually operated isolation valve has been utilized in consideration of the fact that the system is designed to be operated post-LOCA and is ESF related. Installation of the valve outside of primary containment ensures accessibility of the system for maintenance and testing.*

*In lieu of leakage detection, which is difficult and unreliable for a gaseous system operating under the conditions of the recombiner system, the hydrogen recombiner system is designed to minimize the possibility of leakage.*

*The blower and motor are contained in a single canned housing to ensure any leakage through the blower seal would be contained.*

*An additional motor-operated gate valve is installed in each supply and return line inboard of the isolation valve to facilitate testing of the isolation valve and to ensure that any part of the system, including the isolation valves, may be isolated from the primary containment for maintenance, if required.*

## HNP-2-FSAR-3

### *Drywell Pneumatic System*

*The design of the drywell pneumatic system satisfies the requirements of 10 CFR 50, Appendix A, GDC 56, concerning containment isolation. Two automatic isolation valves are provided for the compressor inlet and for each discharge header in the drywell pneumatic system.*

*Isolation of the two discharge headers during a LOCA is provided by the pneumatic system instrumentation which will generate a high-flow signal and automatically close the redundant isolation valves should an air header be ruptured inside the drywell. The redundant isolation valves ensure single-failure proof containment isolation in the event that the system is breached during a LOCA. Provisions are included to allow containment leakage testing per 10 CFR 50, Appendix J.*

### *Summary*

*To assure protection in the event of accidents involving release of significant amounts of radioactive materials into the primary containment, pipes that penetrate the primary containment have been provided with isolation capabilities in accordance with the intent of GDC 56. In all cases, these pipes are provided with a minimum of two protective barriers against containment leakage and in some cases more.*

### *Criterion 57 - Closed-System Isolation Valves*

*"Each line that penetrates the primary reactor containment and is neither part of the reactor coolant pressure boundary nor connected directly to the containment atmosphere shall have at least one containment isolation valve which shall be either automatic, locked closed, or capable of remote manual operation. This valve shall be outside the containment and located as close to the containment as practical. A simple check valve may not be used as the automatic isolation valve."*

### *Design Evaluation*

*The drywell chilled water (2P64) and reactor building closed cooling water (2P42) systems are closed systems inside primary containment. Piping for both systems is Seismic Category I, missile protected and Quality Group D. The Quality Group D classification is improved by including both systems, inside primary containment, in the ASME Section XI inservice inspection program for Nuclear Class 3 piping.*

*A single remote-manually operated isolation valve is provided outside containment and as close to the containment as practical on each supply and return line for the subject systems. Leakage detection is provided by the monitored drywell sump as described in subsection 5.2.7 and by process instrumentation.*

### *Criterion 60 - Control of Releases of Radioactive Materials to the Environment*

*"The nuclear power unit design shall include means to control suitably the release of radioactive materials in gaseous and liquid effluents and to handle radioactive solid wastes produced during normal reactor operation, including anticipated operational occurrences. Sufficient holdup capacity shall be provided for retention of gaseous and liquid effluents containing radioactive materials, particularly where unfavorable site environmental conditions can be expected to impose unusual operational limitations upon the release of such effluents to the environment."*

## HNP-2-FSAR-3

### *Design Evaluation*

*The liquid radwaste system is designed with the intent to process and recycle the liquid waste collected in the waste holdup tanks to the extent practicable. Liquid waste collected in chemical or floor drain tanks is normally discharged to the environment after treatment and dilution with cooling tower blowdown. A floor drain filter was added to the liquid radwaste system to provide further capability for minimizing liquid radioactive releases. During normal plant operation, the annual average whole-body radiation dose to individuals from both reactors on the site, resulting from these routine liquid waste discharges, is expected to be ~ 3% of 10 CFR 20.1 - 20.601 (found in 10 CFR published before January 1994) limits. Short-term release from the plant resulting from equipment malfunctions or operational transients is within the 10 CFR 20.1 - 20.601 (found in 10 CFR published before January 1994) limits. Solid wastes are packaged in suitable containers for offsite shipment and burial.*

*The air ejector off-gas radioactive wastes are treated by an ambient charcoal bed adsorption system before discharge to the environment. An off-gas recombiner was added downstream of the steam jet air ejectors (SJAE) to recombine hydrogen and oxygen and thereby, increase holdup time. The charcoal adsorption system was also added. This system increases the effective holdup time for the isotopes of krypton and xenon and significantly reduces their release to the environment. The annual average exposure at the site boundary due to noble gases from both units during normal operation is not expected to exceed 30 mrem.*

*The liquid and gaseous effluents from the treatment systems are continuously monitored, and the discharges are terminated if the effluents exceed preset radioactivity levels.*

*The radioactive waste treatment system design discussed in this section limits the radioactivity releases to the environment from HNP to levels as low as reasonably achievable.*

### *Criterion 61 - Fuel Storage and Handling and Radioactivity Control*

*"The fuel storage and handling, radioactive waste, and other systems which may contain radioactivity shall be designed to assure adequate safety under normal and postulated accident conditions. These systems shall be designed (1) with a capability to permit appropriate periodic inspection and testing of components important to safety, (2) with suitable shielding for radiation protection, (3) with appropriate containment, confinement, and filtering systems, (4) with a residual heat removal capability having reliability and testability that reflects the importance to safety of decay heat and other residual heat removal, and (5) to prevent significant reduction in fuel storage coolant inventory under accident conditions."*

### *Design Evaluation*

#### *A. New-Fuel Storage*

*New fuel is placed in dry storage in the new-fuel storage vault which is located inside the secondary containment reactor building. The storage vault within the reactor building provides adequate shielding for radiation protection. Storage racks preclude accidental criticality. (See evaluation against GDC 62.) The new-fuel storage racks do not require any special inspection and testing for nuclear safety purposes.*

## HNP-2-FSAR-3

### B. *Spent-Fuel Handling and Storage*

*The handling of new- and spent-fuel assemblies for reactor refueling is within the reactor building which serves as the primary containment during refueling operations. The reactor well and spent-fuel pool are filled directly from the condensate storage tank in order to provide shielding above the reactor and spent fuel. Fuel pool water is circulated through the fuel pool cooling and cleanup (FPCC) system to maintain fuel pool water temperature, purity, water clarity, and water level. Storage racks preclude accidental criticality. (See evaluation against GDC 62.)*

*Reliable decay heat removal is provided by a single train, closed-loop FPCC system. One of two cooling trains of HNP-1 is shared during refueling. The HNP-2 system consists of one circulating pump, one heat exchanger, one filter-demineralizer, two skimmer surge tanks, and the required piping, valves, and instrumentation. The pool water is circulated through the system, and suction is taken from surge tanks by the pump. Flow passes through the heat exchanger and filters and is discharged through diffusers at the bottom of the fuel pool. Pool water temperature is maintained below 125°F when removing the normal heat load from the pool with the reactor building closed cooling water temperature at its maximum. If the pool temperature exceeds 150°F, the FPCC system is connected to the RHR system. This increases the cooling capacity of the FPCC system up to a full core.*

*The decay heat removal (DHR) system is provided for use during refueling outages to remove decay heat from the spent fuel pool. This additional cooling system allows the RHR system and/or the FPCC system to be taken out of service for inspections, repairs, and/or modifications during outages. There are no connections to the fuel storage pool which could allow the fuel pool to be drained below the pool gate between the reactor well and fuel pool. Check valves are provided on lines terminating at the bottom of the pool to prevent syphoning of the pool water. The high and low level switches indicate pool water level changes in the control room and annunciator indication on 2H21-P157 at the 185-ft level of the reactor building. Fission product concentration in the pool water is minimized by use of the filter-demineralizer. This minimizes the release from the pool to the reactor building environment. No special tests are required because the FPCC system is continuously in operation while fuel is stored in the pool. Routine visual inspection of the system components, instrumentation, and trouble alarms is adequate to verify system operability.*

### C. *Radioactive Waste Systems*

*The radioactive waste systems provide all the equipment necessary to collect, process, and prepare for disposal all radioactive liquids, gases, and solid waste produced as a result of reactor operation.*

*Liquid radwastes are classified, contained, and treated as high or low purity, chemical, detergent, or sludges. Processing includes filtration, ion exchange, and dilution. Liquid wastes are also decanted, and sludge is accumulated for disposal as solid radwaste. Wet and dry solid wastes are packaged in appropriate containers and dewatered for shipment. Gaseous radwastes are monitored, processed, recorded, and controlled so that radiation doses to persons outside the controlled area are below those allowed by 10 CFR 20.1 - 20.601 (found in 10 CFR published before January 1994).*

## HNP-2-FSAR-3

*Accessible portions of the reactor and radwaste buildings shall have sufficient shielding to maintain dose rates within the limits set forth in 10 CFR 20.1 - 20.601 (found in 10 CFR published before January 1994). The radwaste building is designed to preclude accidental release of radioactive materials to the environs.*

*The radwaste systems are used on a routine basis and do not require specific testing to assure operability. Performance is monitored by radiation monitors during operation.*

*The fuel storage and handling and radioactive waste systems are designed to assure adequate safety under normal and postulated accident conditions.*

*The design of these systems meets the requirement of GDC 61.*

*For further discussion, see chapter 11; sections 6.2, 9.4, and 12.1; and subsections 5.5.7, 9.1.1, 9.1.2, and 9.1.3.*

### Criterion 62 - Prevention of Criticality in Fuel Storage and Handling

*"Criticality in the fuel storage and handling system shall be prevented by physical systems or processes, preferably by use of geometrically safe configurations."*

#### *Design Evaluation*

*Appropriate plant fuel handling and storage facilities are provided to preclude accidental criticality for new and spent fuel. Criticality in new- and spent-fuel storage is prevented by the geometrically safe configuration of the storage rack. There is sufficient spacing between the assemblies to assure that the array, when fully loaded, is substantially subcritical. Fuel elements are limited by rack design to only top loading and fuel assembly positions. The new- and spent-fuel storage racks are designed to Seismic Category I requirements.*

*New fuel is placed in dry storage in the top-loaded new-fuel storage vault. The vault contains a drain to prevent the accumulation of water. The new-fuel storage vault racks (located inside the secondary containment reactor building) are designed to prevent an accidental critical array, even in the event the vault becomes flooded or subjected to seismic loadings. The 6.625-in. center-to-center new-fuel assembly spacing limits the effective multiplication factor of the array to not more than 0.90 for new dry fuel.  $K_{eff}$  does not exceed 0.95 if the new fuel is flooded.*

*Spent fuel is stored under water in the spent-fuel pool. The racks in which spent-fuel assemblies are placed are designed and arranged to ensure subcriticality in the storage pool. Spent fuel is maintained at a subcritical multiplication factor  $K_{eff}$  of  $< 0.90$  under normal conditions and 0.95 for abnormal conditions. Abnormal conditions may result from an earthquake, accidental dropping of equipment, or damage caused by the horizontal movement of fuel-handling equipment without first disengaging the fuel from the hoisting equipment.*

*Refueling interlocks include circuitry which senses conditions of the refueling equipment and the control rods. These interlocks reinforce operational procedures that prohibit making the reactor critical. The fuel-handling system is designed to provide a safe, effective means of transporting and handling fuel and is designed to minimize the possibility of mishandling or maloperation.*

## HNP-2-FSAR-3

*The use of geometrically safe configurations for new- and spent-fuel storage and the design of fuel-handling systems precludes accidental criticality in accord with GDC 62.*

*For further discussion of criticality monitoring, reference section 9.1.*

### Criterion 63 - Monitoring Fuel and Waste Storage

*"Appropriate systems shall be provided in fuel storage and radioactive waste systems and associated handling areas (1) to detect conditions that may result in loss of residual heat removal capability and excessive radiation levels and (2) to initiate appropriate safety actions."*

#### *Design Evaluation*

*Appropriate systems are provided to meet the requirements of this criterion. A malfunction of the FPCC system which could result in loss of RHR capability and excessive radiation levels is alarmed in the control room. Alarmed conditions include low fuel pool cooling water pump discharge pressure, high and low levels in the fuel storage pool, low level in the skimmer surge tank, and flow in the drain lines between fuel pool gates located between the fuel pool and the reactor well. System temperature is also continuously monitored and alarmed in the control room. Spent-fuel storage is discussed in subsection 9.1.2, and the FPCC system is discussed in subsection 9.1.3.*

*The reactor building and refueling floor ventilation radiation monitoring systems detect abnormal amounts of radioactivity and initiate appropriate action to control the release of radioactive material to the environs. These systems are discussed in sections 9.4 and 11.4.*

*Area radiation and tank and sump levels are monitored and alarmed to give indication of conditions which may result in excessive radiation levels in radioactive waste system areas. These systems are discussed in chapter 11.*

### Criterion 64 - Monitoring Radioactivity Releases

*"Means are provided for monitoring the reactor containment atmosphere, spaces containing components for recirculation of loss-of-coolant accident fluids, effluent discharge paths, and the plant environs for radioactivity that may be released from normal operations, including anticipated operational occurrences, and from postulated accidents."*

#### *Design Evaluation*

*A fission products monitoring system samples the containment (both drywell and torus) atmosphere for radioactive particulates, noble gases, and iodine during normal operation. A hydrogen-oxygen analyzer system monitors the oxygen-hydrogen concentration in the containment during normal operation and following an accident.*

*Radioactive effluent discharge paths and the site environs are monitored for radioactivity releases.*



**DOCUMENTS INCORPORATED BY REFERENCE INTO THE FSAR**

*Technical Requirements Manual Table T7.0-1, Primary Containment Penetrations.*

*Edwin I. Hatch Nuclear Plant Units 1 and 2 Fire Hazards Analysis and Fire Protection Program.*

TABLE 3.1-1

**REACTOR COOLANT PRESSURE BOUNDARY INFLUENT LINES**

| <u>Penetration</u> | <u>Influent Lines</u>         | <u>Inner Barrier</u> | <u>Outer Barrier</u> | <u>Comments</u> |
|--------------------|-------------------------------|----------------------|----------------------|-----------------|
| X9A&B              | Feedwater                     | CV                   | AO-CV                | 55.1            |
|                    | • HPCI return                 |                      | MOV                  | 55.2            |
|                    | • RCIC return                 |                      | MOV                  | 55.2            |
|                    | • Cleanup return              |                      | CV                   | 55.2            |
| X13A&B             | RHR return to recirculation   | MOV <sup>(a)</sup>   | Closed system        | 55.3            |
| X16A&B             | CS                            | MOV <sup>(a)</sup>   | Closed system        | 55.3            |
| X17                | Disconnected                  |                      |                      |                 |
| X42                | Standby liquid control        | CV                   | CV                   | 55.6            |
| X27C & X57C        | Recirculation pump seal water | CV                   | CV                   | 55.8            |
|                    | Other                         |                      |                      | 55.7            |

LEGEND

CV - Check valve  
MOV - Motor-operated valve  
AO-CV - Air-operated check valve

a. Both barriers are outside the primary containment.

**TABLE 3.1-2**

**REACTOR COOLANT PRESSURE BOUNDARY EFFLUENT LINES**

| <u>Penetration</u> | <u>Effluent Lines</u> | <u>Inside Drywell</u> | <u>Outside Drywell</u> |
|--------------------|-----------------------|-----------------------|------------------------|
| X7A-D              | Main steam            | AOV                   | AOV, MOV               |
| X14                | RWC                   | MOV                   | MOV                    |
| X12                | RHR shutdown cooling  |                       | MOV, closed system     |
| X8                 | Main steam line drain | MOV                   | MOV                    |
| X10                | RCIC turbine steam    | MOV                   | MOV                    |
| X11                | HPCI turbine steam    | MOV                   | MOV                    |

## **3.2 CLASSIFICATION OF STRUCTURES, COMPONENTS, AND SYSTEMS**

### **3.2.1 SEISMIC CLASSIFICATION**

A two-level system is used for the seismic classification of the structures, components, and systems of the facility:

- Seismic Category I structures, components, and systems.
- Category II structures, components, and systems.

#### **3.2.1.1 Definitions**

Seismic Category I structures, components, and systems are those that must function for safe shutdown, immediate or long-term core cooling, or for activity confinement following a loss-of-coolant accident to ensure that the public is protected in accordance with 10 CFR 100 guidelines.

Seismic Category I structures, components, and systems are designed to withstand the effects of the design basis earthquake (DBE) and operating basis earthquake (OBE) as discussed in supplements 3.7A and 3.7B.

When a system as a whole is referred to as Seismic Category I, portions not associated with loss of function of the system may be designated as Category II.

Category II structures, components, and systems are those whose failure would not result in the release of significant radioactivity and would not prevent reactor shutdown. All equipment not specifically listed as Seismic Category I is included as Category II. The failure of Category II structures, components, and systems may interrupt power generation.

All Category II structures are designed to conform to paragraph 2.3.1.4 of the 1970 edition of the Uniform Building Code.

None of the structures in the Hatch Nuclear Plant (HNP) have classifications that are partially Seismic Category I and partially Category II; however, portions of nonseismic Category II systems are seismically supported if their failure could cause damage to Seismic Category I components.

Seismic classification of structures, systems, and components is in accordance with Regulatory Guide 1.29, (August 1973).

**3.2.1.2 Seismic Category I Structures**

Reactor building

- Primary containment structure
- Spent-fuel pool
- New-fuel storage vault

Diesel generator building

Control building

Intake structure

Main stack

Structures supporting or housing Seismic Category I equipment

- Wall around condensate storage tank (CST)
- Liquid nitrogen storage tank and foundation
- Diesel generator fuel oil storage tanks

**3.2.1.3 Seismic Category I Mechanical Components and Systems**

Seismic Category I mechanical components and systems are listed in table 3.2-1.

**3.2.1.4 Seismic Category I (Class 1E) Electrical Equipment**

Switchgear & buses

- 4160-V buses 2E, 2F, and 2G
- 600-V load centers 2C and 2D
- 250 V-dc buses 2A and 2B
- 4160-V recirculation pump trip (RPT) switchgear

## HNP-2-FSAR-3

### Transformers

- 1190-1368-kVA, 4160-600-V essential transformers
- 112.5 kVA, 600-208/120-V essential transformers
- 225-kVA, 75-kVA 4160-600-V transformers 2F1 and 2F2

600-V bus duct associated with 600-V load centers 2C and 2D and 4160-600-V transformer 2CD

### Motors (4 kV)

- Residual heat removal service water (RHRSW) pump motors (4)
- Plant service water (PSW) pump motors (4)
- Residual heat removal (RHR) pump motors (4)
- Core spray (CS) pump motors (2)

ac & dc lighting and miscellaneous power cabinets - control and diesel generator buildings

### ac & dc motor control centers (MCCs)

- 600 V-ac essential MCC - reactor building (7)
- 250 V-dc essential MCC - reactor building (2)
- 600-208 V-ac essential MCC - diesel generator building (3)
- 600 V-ac essential MCC - intake structure (2)

### Batteries and chargers

- 125-250-V station batteries 2A and 2B
- 125-V diesel batteries 2A and 2C
- 125-V battery chargers 2A-2F (station batteries)
- 125-V battery chargers 2G and 2J (diesel batteries)

## HNP-2-FSAR-3

Diesel generators 2A, 2C, and 1B (1B is shared with HNP-1.)

Neutral grounding resistors for diesels

Primary electrical penetrations (drywell)

Power and control cable for essential equipment and instruments

Raceway supports associated with essential systems & equipment

- Pull boxes and junction boxes
- Underground ducts, fittings, and encasement

Reactor protection system (RPS) breaker protection panels (2C71-P003A through F)

### **3.2.1.5 Seismic Category I Instrumentation and Control Systems Equipment**

RPS (except distribution cabinets and motor-generator sets)

Primary containment and reactor vessel isolation control system

Power range monitors in nuclear boiler system

Emergency core cooling system (ECCS) initiating channels and logic and automatic depressurization system initiating channels and logic

Essential instrumentation and controls on the following systems:

- Nuclear boiler
- Control rod drive (CRD)
- RHR and RHRSW
- CS
- High-pressure coolant injection (HPCI) system
- Reactor core isolation cooling (RCIC) system
- Standby gas treatment system (SGTS)
- PSW

## HNP-2-FSAR-3

Instrumentation and controls for the following:

- Standby liquid control system (SLCS)
- Safeguard equipment emergency room coolers and main control room (MCR) air-handling and condensing units

Neutron monitoring system (NMS)

Portions of radiation monitoring systems

Oxygen and hydrogen analyzer

MCR panels and local instrument racks for the above instrumentation and control systems

Leak detection systems in the HPCI system and pipe chase rooms

Switchboards and panels

- Control boards
  - Reactor and containment cooling and isolation board (2H11-P601)
  - Power range neutron monitoring cabinet (2H11-P608)
  - Channel A primary isolation and RPS vertical board (2H11-P609)
  - Channel B primary isolation and RPS vertical board (2H11-P611)
  - Steam, feedwater condensate, circulating, and service water bench board (2H11-P650)
  - Emergency diesel generator 2A vertical board
  - Emergency diesel generator 1B vertical board
  - Emergency diesel generator 2C vertical board

} (2H11-P652)  
(with physical partitions)

- Reactor water cleanup (RWC) and recirculation benchboard (2H11-P602)
- Reactor control benchboard (2H11-P603)



## HNP-2-FSAR-3

### Protective relay board

- Channel A RHR relay vertical board (2H11-P617)
- Channel B RHR relay vertical board (2H11-P618)
- HPCI relay vertical board (2H11-P620)
- RCIC relay vertical board (2H11-P621)
- Inboard isolation valve relay vertical board (2H11-P622)
- Outboard isolation valve relay vertical board (2H11-P623)
- Channel A CS relay vertical board (2H11-P626)
- Channel B CS relay vertical board (2H11-P627)
- Auto blowdown relay vertical board (2H11-P628)
- Heating, venting, and air-conditioning systems control boards (2H11-P654 and 2H11-P657)

### Other panels

- Reactor building instrument enclosure (2H21-P151)
- Diesel generator 2A relay panel (2H21-P200)
- Diesel generator 1B relay panel (2H21-P201)
- Diesel generator 2C relay panel (2H21-P202)
- Diesel generator 2A relay panel (2H21-P230)
- Diesel generator 1B relay panel (2H21-P231)
- Diesel generator 2C relay panel (2H21-P232)
- 600-V bus 2C control panel (2H21-P245)
- 600-V bus 2D control panel (2H21-P246)
- 250-V bus, switchgear 2A control panel (2H21-P248)
- 250-V bus, switchgear 2B control panel (2H21-P249)

## HNP-2-FSAR-3

- Motor-operated valve (MOV) and fuel pumps control panel Division I - diesel building (2H21-P255)
- MOV and fuel pumps control panel Division II - diesel building (2H21-P256)
- Diesel generator 2A heat and ventilation control panel - diesel building (2H21-P257)
- Diesel generator 2C heat and ventilation control panel - diesel building (2H21-P259)
- Switchgear 2E - room heat and ventilation control panel - diesel building (2H21-P260)
- Switchgear 2F - room heat and ventilation control panel - diesel building (2H21-P261)
- Switchgear 2G - room heat and ventilation control panel - diesel building (2H21-P262)
- Station battery 2A shunt panel P - control building (2H21-P285)
- Station battery 2A shunt panel PN - control building (2H21-P286)
- Station battery 2A shunt panel N - control building (2H21-P287)
- Station battery 2B shunt panel P - control building (2H21-P288)
- Station battery 2B shunt panel PN - control building (2H21-P289)
- Station battery 2B shunt panel N - control building (2H21-P290)
- Diesel battery 2A shunt panel - diesel building (2H21-P291)
- Diesel battery 2C shunt panel - diesel building (2H21-P293)
- Radiation monitor battery 2A shunt panel - control building (2H21-P294)
- Radiation monitor battery 2B shunt panel - control building (2H21-P295)
- Radiation monitor battery 2A charger shunt box - control building (2H21-P296)
- Radiation monitor battery 2B charger shunt box - control building (2H21-P297)

## HNP-2-FSAR-3

- Diesel generator 2A leading timer panel (2H21-P303)
- Diesel generator 1B leading timer panel (2H21-P304)
- Diesel generator 2C leading timer panel (2H21-P305)
- Vital ac battery fuse panel (2H21-P317)
- Diesel generator 2A battery metering panel (2R43-P002A)
- Diesel generator 2C battery metering panel (2R43-P002C)
- Remote shutdown panels (2H21-P173 and 2C82-P001)
- Analyzer ventilation and leak detection panel (2H11-P700)
- Diesel battery 2A shunt box (2H21-P198)
- Diesel battery 2C shunt box (2H21-P199)
- Local instrument racks containing Class 1E components (65)
- Radwaste building ventilation control panel (2H21-P182)
- Analog transmitter trip system panels and associated distribution buses (H11-P921, H11-P922, H11-P923, H11-P924, H11-P925, H11-P926, H11-P927, and H11-P928)

Radiation monitors of MCR intake

### 3.2.2 SYSTEM QUALITY GROUP CLASSIFICATIONS

System quality group classifications, as defined in Nuclear Regulatory Commission (NRC) Regulatory Guide 1.26 (September 1974), were determined for each water, steam, or radioactive waste containing component of those applicable fluid systems relied upon to:

- Prevent or mitigate the consequences of accidents and malfunctions originating within the reactor coolant pressure boundary (RCPB).
- Provide safe shutdown capability of the reactor and maintain it in a safe shutdown condition.
- Contain radioactive material.

A tabulation showing the quality group classification for each mechanical component so defined is shown in table 3.2-1 under the heading, Quality Group Classification. Drawing no. H-26095 is

## HNP-2-FSAR-3

a diagram which depicts the relative locations of these components along with their quality group classifications. Table 3.2-4 lists the individual systems and the drawing number in which the quality group classifications for the components of the system are indicated.

System quality group classifications and design and fabrication requirements, as indicated in tables 3.2-1 and 3.2-3, meet the requirements of Regulatory Guide 1.26 (September 1974).

Because of the long lead time between purchase and delivery of valves at HNP-2, it was necessary, to avoid construction delays, to consider the use on HNP-2 of certain valves purchased as spares for HNP-1. The valves utilized (table 3.2-6) are small (2 in. and under), manually operated, quality group B valves purchased in compliance with the 1968 Draft American Society of Mechanical Engineers (ASME) Code for Pumps and Valves.

Regulatory Guide 1.26 refers to 10 CFR 50.55a for guidance when determining the code and addenda to be applied for quality group B valves. This guidance indicates that the applicable code for HNP-2, based on its construction permit date of December 1972, should be the 1971 edition of the ASME Boiler and Pressure Vessel (B&PV) Code. The following is a summary report which demonstrates that these valves meet the intent of the 1971 ASME Code.

### A. Function of Valves

The valves described in table 3.2-6 are generally used as follows: (See table 3.2-6 notes for exceptions.)

- Low point drain connections for any process lines.
- High point vent connections for any process lines.
- Root valves for instruments.

These valves are not used in process lines which may be required for emergency shutdown of the plant but may be used in drain and vent lines for such process lines.

### B. Degree of Compliance with 1968 Code

The subject valves are in full compliance with the 1968 Draft ASME Code for Pumps and Valves and ASME Section III addenda through March of 1970, with the interpretation that, prior to 1971, N stamping of data reports was not required for nuclear Class 2 or 3 valves.

The valves given in table 3.2-6 are designed to the criteria of American National Standards Institute (ANSI) B-16.5 and, thus, meet the requirements of paragraph NC-3511 of the 1971 edition of Section III of the ASME Code.

## HNP-2-FSAR-3

### C. Comparison With HNP-2 Code With Justification of Differences

For valves ordered more than 12 months prior to the construction permit, the effective ASME Code, according to the guidance of 10 CFR 50.55a, should be the 1971 edition. However, the only discernible difference between the ASME Code, 1971 edition, and the 1968 Draft ASME Pump and Valve Code is the requirement for a code data report and official N stamp. The design, fabrication, inspection, and testing requirements are common to both codes.

The code data report was not required for nuclear Class 2 and 3 valves by the 1968 Code and therefore was not generated. However, all the required documentation for the code data report is available. This consists of chemical and physical mill certificates, nondestructive examination, plus hydro and seal leakage tests. This is the exact information required by the 1971 NPV-1 form except that an authorized inspector must witness the hydro tests and certify the documentation package. The valves are hydrotested again with the piping system, although not at the higher pressures of SP-61.

The official N stamp was not applied to the valves, although the manufacturer did have the authorization for nuclear Class I valve stamping. A nuclear symbol is applied to certain valves, and all valves are tagged with the manufacturer's name and the design pressure at coincident temperature.

Therefore, because these valves are designed, fabricated, inspected, and tested in accordance with the 1968 Draft ASME Pump and Valve Code, it is considered that these valves meet the intent of the 1971 ASME B&PV Code.

HNP-2-FSAR-3

TABLE 3.2-1 (SHEET 1 OF 11)

SEISMIC CATEGORY I SYSTEMS AND MECHANICAL COMPONENTS

| <u>Principal Components</u>                                              | <u>Scope of Supply</u> <sup>(b)</sup> | <u>Seismic Category</u> <sup>(c)</sup> | <u>Quality Group Classification</u> <sup>(d)</sup> | <u>Principal Construction/ Design Code</u> <sup>(f)</sup> | <u>Notes</u> |
|--------------------------------------------------------------------------|---------------------------------------|----------------------------------------|----------------------------------------------------|-----------------------------------------------------------|--------------|
| <b>Reactor System</b>                                                    |                                       |                                        |                                                    |                                                           |              |
| Reactor pressure vessel (RPV)                                            | GE                                    | I                                      | A                                                  | III-A                                                     |              |
| RPV support                                                              | GE                                    | I                                      | NA                                                 | None                                                      |              |
| RPV appurtenances pressure-retaining portions                            | GE                                    | I                                      | NA                                                 | III-A                                                     |              |
| CRD housing                                                              | GE                                    | I                                      | A                                                  | III-A                                                     |              |
| Reactor internal structures, engineered safety features, shroud          | GE                                    | I                                      | NA                                                 | None                                                      |              |
| Reactor internal structures, CS lines                                    | GE                                    | I                                      | NA                                                 | None                                                      | 10           |
| Control rods                                                             | GE                                    | I                                      | NA                                                 | None                                                      |              |
| CRDs                                                                     | GE                                    | I                                      | NA                                                 | III-A                                                     |              |
| Core support structures                                                  | GE                                    | I                                      | NA                                                 | None                                                      |              |
| Power range detector hardware in core guide tube seal                    | GE                                    | I                                      | B                                                  | III-B                                                     |              |
| Fuel assemblies - RPV stabilizer                                         | GE                                    | I                                      | NA                                                 | None                                                      |              |
| <b>Nuclear Boiler System</b>                                             |                                       |                                        |                                                    |                                                           |              |
| Vessels, level instrumentation chambers                                  | GE                                    | I                                      | A                                                  | III-A                                                     |              |
| Vessels, air accumulators                                                | B                                     | I                                      | B                                                  | III-2                                                     |              |
| Piping, relief valve discharge                                           | B                                     | I                                      | C                                                  | III-3                                                     |              |
| Piping, main steam, within outermost isolation valve                     | GE                                    | I                                      | A                                                  | III-1                                                     | 1            |
| Piping, feedwater from vessel through third shutoff valve                | B                                     | I                                      | A                                                  | III-1                                                     | 7            |
| Piping, feedwater, from third shutoff valve through fourth shutoff valve | B                                     | I                                      | B                                                  | III-2                                                     | 7            |
| Pipe supports, main steam                                                | GE                                    | I                                      | NA                                                 | None                                                      |              |
| Pipe restraints, main steam                                              | B/GE                                  | I                                      | NA                                                 | None                                                      |              |
| Piping, other within outermost isolation valves                          | B                                     | I                                      | A                                                  | III-1                                                     | 1            |
| Piping instrumentation beyond outermost isolation valves                 | B                                     | NA                                     | D                                                  | B31.1                                                     | 1            |
| Safety & relief valves                                                   | TR                                    | I                                      | A                                                  | III-1                                                     |              |
| Valves, MSIVs                                                            | GE                                    | I                                      | A                                                  | NPVC-1                                                    |              |
| Valves, within outermost isolation valves                                | B                                     | I                                      | A                                                  | NPVC-1                                                    | 1            |
| Valves, instrumentation beyond outermost isolation valves                | B                                     | I                                      | D                                                  | B31.1                                                     | 1            |

HNP-2-FSAR-3

TABLE 3.2-1 (SHEET 2 OF 11)

| <u>Principal Components</u>                       | <u>Scope of Supply</u> <sup>(b)</sup> | <u>Seismic Category</u> <sup>(c)</sup> | <u>Quality Group Classification</u> <sup>(d)</sup> | <u>Principal Construction/ Design Code</u> <sup>(f)</sup> | <u>Notes</u> |
|---------------------------------------------------|---------------------------------------|----------------------------------------|----------------------------------------------------|-----------------------------------------------------------|--------------|
| <b>Reactor Recirculation System</b>               |                                       |                                        |                                                    |                                                           |              |
| Piping (replaced in 1984)                         | GE                                    | I                                      | A                                                  | III-1                                                     | 1, 12        |
| Pipe suspension, recirculation line               | GE                                    | I                                      | NA                                                 | None                                                      | 1, 19        |
| Pipe restraints, recirculation line               | GE                                    | I                                      | NA                                                 | None                                                      |              |
| Pumps                                             | GE                                    | I                                      | A                                                  | NPVC-1                                                    |              |
| Valves                                            | GE                                    | I                                      | A                                                  | NPVC-1                                                    | 1            |
| Motor/pump                                        | GE                                    | S                                      | NA                                                 | None                                                      |              |
| <b>CRD Hydraulic (CRDH) System</b>                |                                       |                                        |                                                    |                                                           |              |
| Valves, isolation, water return line              | B                                     | I                                      | B                                                  | III-1                                                     | 7            |
| Valves, scram discharge volume lines              | B                                     | I                                      | B                                                  | III-2                                                     | 1            |
| Valves, insert & withdraw lines                   | GE                                    | I                                      | A                                                  | NPVC-II                                                   |              |
| Valves, other                                     | B                                     | NA                                     | D                                                  | B31.1                                                     | 1            |
| Piping, water return line within isolation valves | B                                     | I                                      | B                                                  | III-1                                                     |              |
| Piping, scram discharge volume lines              | B                                     | I                                      | B                                                  | III-2                                                     |              |
| Piping, insert & withdraw lines                   | B                                     | I                                      | A                                                  | III-1                                                     |              |
| Piping, other                                     | B                                     | NA                                     | D                                                  | B31.1                                                     | 1            |
| Hydraulic control unit                            | GE                                    | I                                      | D                                                  | None                                                      | 2            |
| <b>SLCS</b>                                       |                                       |                                        |                                                    |                                                           |              |
| Standby liquid control tank                       | GE                                    | I                                      | B                                                  | API 650/VIII                                              |              |
| Pump                                              | GE                                    | I                                      | B                                                  | NPVC-2                                                    |              |
| Pump motor                                        | GE                                    | S                                      | NA                                                 | None                                                      |              |
| Valves, explosive                                 | GE                                    | I                                      | B                                                  | NPVC-2                                                    |              |
| Valves, isolation & within                        | B                                     | I                                      | A                                                  | III-1                                                     | 1            |
| Valves beyond isolation valves                    | B                                     | I                                      | B                                                  | III-2                                                     | 1            |
| Piping within isolation valves                    | B                                     | I                                      | A                                                  | III-1                                                     | 1            |
| Piping beyond isolation valves                    | B                                     | I                                      | B                                                  | III-2                                                     | 1            |
| Accumulator                                       | GE                                    | I                                      | B                                                  | III-C                                                     |              |
| <b>NMS</b>                                        |                                       |                                        |                                                    |                                                           |              |
| Piping, traversing incore probe (TIP)             | B                                     | I                                      | B                                                  | III-2                                                     | 23           |
| Valves, isolation, TIP subsystem                  | GE                                    | I                                      | B                                                  | III-2                                                     | 23           |

HNP-2-FSAR-3

**TABLE 3.2-1 (SHEET 3 OF 11)**

| <u>Principal Components</u>                                   | <u>Scope of Supply<sup>(b)</sup></u> | <u>Seismic Category<sup>(c)</sup></u> | <u>Quality Group Classification<sup>(d)</sup></u> | <u>Principal Construction/ Design Code<sup>(f)</sup></u> | <u>Notes</u> |
|---------------------------------------------------------------|--------------------------------------|---------------------------------------|---------------------------------------------------|----------------------------------------------------------|--------------|
| <b>RHR System</b>                                             |                                      |                                       |                                                   |                                                          |              |
| Heat exchangers, primary side                                 | GE                                   | I                                     | B                                                 | III-C & TEMA-C                                           | 11           |
| Heat exchangers, secondary side                               | GE                                   | I                                     | C                                                 | VIII & TEMA-C                                            |              |
| Piping (only SS) within outermost isolation valves            | B/GE,                                | I                                     | A                                                 | III-1                                                    | 1, 13        |
| Piping beyond outermost isolation valves                      | B                                    | I                                     | B                                                 | III-2                                                    | 1            |
| Pumps                                                         | GE                                   | I                                     | B                                                 | NPVC-2                                                   | 20           |
| Pump motors                                                   | GE                                   | S                                     | NA                                                | None                                                     |              |
| Valves, isolation, LPCI line                                  | B                                    | I                                     | A                                                 | III-1                                                    |              |
| Valves, isolation, other                                      | B                                    | I                                     | A/B                                               | III-1/2                                                  | 1            |
| Valves beyond isolation valves                                | B                                    | I                                     | B                                                 | III-2                                                    | 1            |
| <b>CS</b>                                                     |                                      |                                       |                                                   |                                                          |              |
| Piping within outermost isolation valves                      | B                                    | I                                     | A                                                 | III-1                                                    | 1            |
| Piping beyond outermost isolation valves                      | B                                    | I                                     | B                                                 | III-2                                                    | 1            |
| Pumps                                                         | GE                                   | I                                     | B                                                 | NPVC-2                                                   | 1            |
| Pump motors                                                   | GE                                   | S                                     | NA                                                | None                                                     |              |
| Valves, isolation & within                                    | B                                    | I                                     | A                                                 | III-1                                                    | 1            |
| Valves beyond outermost isolation                             | B                                    | I                                     | B                                                 | III-2                                                    | 1            |
| <b>HPCI System</b>                                            |                                      |                                       |                                                   |                                                          |              |
| Piping, suction line to CST                                   | B                                    | I                                     | B                                                 | III-2                                                    |              |
| Piping, turbine steam supply & discharge                      | B                                    | I                                     | B                                                 | III-2                                                    |              |
| Piping, return test line to CST beyond second isolation valve | B                                    | I                                     | D                                                 | B31.1                                                    |              |
| Piping within outermost isolation valve                       | B                                    | I                                     | A                                                 | III-1                                                    |              |
| Piping, suppression pool suction & pump discharge             | B                                    | I                                     | B                                                 | III-2                                                    | 1            |
| Pump                                                          | GE                                   | I                                     | B                                                 | NPVC-2                                                   |              |
| Turbine                                                       | GE                                   | I                                     | NA                                                | None                                                     | 3            |
| Valves beyond outermost isolation valves                      | GE                                   | I                                     | B                                                 | NPVC-2                                                   |              |
| Valves, outer isolation & within                              | B                                    | I                                     | A                                                 | III-1                                                    | 1            |
| Valves beyond isolation valves, motor operated                | GE                                   | I                                     | B                                                 | HPVC-2                                                   |              |
| Valves, other                                                 | B                                    | I                                     | B                                                 | III-2                                                    |              |



HNP-2-FSAR-3

**TABLE 3.2-1 (SHEET 4 OF 11)**

| <u>Principal Components</u>                                                                                                                | <u>Scope of Supply</u> <sup>(b)</sup> | <u>Seismic Category</u> <sup>(c)</sup> | <u>Quality Group Classification</u> <sup>(d)</sup> | <u>Principal Construction/ Design Code</u> <sup>(f)</sup> | <u>Notes</u> |
|--------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------|----------------------------------------|----------------------------------------------------|-----------------------------------------------------------|--------------|
| <b>RCIC System</b>                                                                                                                         |                                       |                                        |                                                    |                                                           |              |
| Piping within outermost isolation valves                                                                                                   | B                                     | I                                      | A                                                  | III-1                                                     | 1            |
| Piping beyond outermost isolation valves                                                                                                   | B                                     | I                                      | B                                                  | III-2                                                     | 1            |
| Piping, return test line to CST beyond second isolation valve                                                                              | B                                     | I                                      | D                                                  | B31.1                                                     |              |
| Vacuum pump discharge line to containment isolation valves                                                                                 | B                                     | I                                      | B                                                  | III-2                                                     | 1            |
| <b>Pumps</b>                                                                                                                               |                                       |                                        |                                                    |                                                           |              |
| Valves, isolation & within                                                                                                                 | B                                     | I                                      | A                                                  | III-1                                                     | 1            |
| Valves, return test line to condensate storage beyond second isolation valve, & vacuum pump discharge line to containment isolation valves | B                                     | I                                      | B                                                  | III-2                                                     |              |
| Valves, other                                                                                                                              | B                                     | I                                      | B                                                  | III-2                                                     | 1            |
| Turbine                                                                                                                                    | GE                                    | I                                      | NA                                                 | None                                                      | 3            |
| <b>Fuel Service Equipment</b>                                                                                                              |                                       |                                        |                                                    |                                                           |              |
| Fuel preparation machine                                                                                                                   | GE                                    | I                                      | NA                                                 | None                                                      |              |
| General purpose grapple                                                                                                                    | GE                                    | I                                      | NA                                                 | None                                                      |              |
| <b>RPV Service Equipment</b>                                                                                                               |                                       |                                        |                                                    |                                                           |              |
| Steam line plugs                                                                                                                           | GE                                    | I                                      | NA                                                 | None                                                      |              |
| Dryer, separator sling, & hard strongback                                                                                                  | GE                                    | I                                      | NA                                                 | None                                                      |              |
| <b>In-Vessel Service Equipment</b>                                                                                                         |                                       |                                        |                                                    |                                                           |              |
| Control rod grapple                                                                                                                        | GE                                    | I                                      | NA                                                 | None                                                      |              |
| <b>Refueling Equipment</b>                                                                                                                 |                                       |                                        |                                                    |                                                           |              |
| Refueling equipment platform assembly                                                                                                      | GE                                    | I                                      | NA                                                 | None                                                      | 18           |
| Refueling bellows                                                                                                                          | GE                                    | I                                      | B                                                  | III-2                                                     |              |
| <b>Storage Equipment</b>                                                                                                                   |                                       |                                        |                                                    |                                                           |              |
| Fuel storage racks                                                                                                                         | GE                                    | I                                      | NA                                                 | None                                                      |              |
| Defective fuel storage container                                                                                                           | GE                                    | I                                      | NA                                                 | None                                                      |              |

HNP-2-FSAR-3

TABLE 3.2-1 (SHEET 5 OF 11)

| <u>Principal Components</u>                         | <u>Scope of Supply</u> <sup>(b)</sup> | <u>Seismic Category</u> <sup>(c)</sup> | <u>Quality Group Classification</u> <sup>(d)</sup> | <u>Principal Construction/ Design Code</u> <sup>(f)</sup> | <u>Notes</u> |
|-----------------------------------------------------|---------------------------------------|----------------------------------------|----------------------------------------------------|-----------------------------------------------------------|--------------|
| <b>Radwaste System</b>                              |                                       |                                        |                                                    |                                                           |              |
| Tanks, atmospheric vessels                          | GE/B                                  | NA                                     | D/C                                                | API-650, III-3, & B96.1                                   | 22           |
| Heat exchangers & evaporators                       | GE/B                                  | NA                                     | D                                                  | VIII & TEMA-Cq                                            | 4, 22        |
| Piping                                              | B                                     | NA                                     | C/D                                                | III-3 and B31.1                                           | 4, 22        |
| Pumps                                               | GE/B                                  | NA                                     | C/D                                                | III-3 and B31.1                                           | 1, 4, 22     |
| Valves, containment isolation                       | B                                     | I                                      | B                                                  | III-2                                                     | 4, 22        |
| Valves, flow control & filter system                | B                                     | NA                                     | C                                                  | III-3                                                     | 4, 22        |
| Valves, other                                       | B                                     | NA                                     | C                                                  | III-3                                                     | 22           |
| <b>RWC System</b>                                   |                                       |                                        |                                                    |                                                           |              |
| Vessels, filter-demineralizer                       | GE                                    | NA                                     | C                                                  | III-3                                                     |              |
| Heat exchangers regenerator & nonregenerating       | GE                                    | NA                                     | C                                                  | VIII & TEMA-C                                             |              |
| Piping within outermost isolation valves            | GE                                    | I                                      | A                                                  | III-1                                                     | 14           |
| Piping beyond outermost isolation valves            | B                                     | NA                                     | C                                                  | III-3                                                     |              |
| Pumps                                               | GE                                    | NA                                     | C                                                  | NPVC-3                                                    |              |
| Valves, isolation valves & within                   | B                                     | I                                      | A                                                  | III-1                                                     | 1, 5         |
| Valves beyond outermost isolation valves            | B                                     | NA                                     | C                                                  | III-3                                                     | 1, 5         |
| Phase separator                                     | GE                                    | NA                                     | C                                                  | III-3                                                     | 1, 5         |
| <b>Spent-Fuel Pool Cooling &amp; Cleanup System</b> |                                       |                                        |                                                    |                                                           |              |
| Vessels (filter-demineralizer & resin trap)         | B                                     | NA                                     | C                                                  | III-3                                                     |              |
| Vessels (precoat tank)                              | B                                     | NA                                     | D                                                  | Atmospheric                                               |              |
| Heat exchanger                                      | B                                     | NA                                     | C/D                                                | III-3/VIII, & TEMA-C                                      |              |
| Pumps (main & holding)                              | B                                     | NA                                     | C                                                  | III-3                                                     |              |
| Precoat pump                                        | B                                     | NA                                     | D                                                  | Hydraulic Institute                                       |              |
| Precoat piping & valves                             | B                                     | NA                                     | D                                                  | B31.1                                                     |              |
| All other piping & valves                           | B                                     | I/NA                                   | C                                                  | III-3                                                     |              |
| <b>Off-Gas System</b>                               |                                       |                                        |                                                    |                                                           |              |
| Tanks                                               | GE                                    | NA                                     | D                                                  | API 650                                                   |              |
| Heat exchangers                                     | GE                                    | NA                                     | D                                                  | VIII & TEMA                                               |              |
| Piping                                              | B                                     | NA                                     | D                                                  | B31.1                                                     |              |
| Valves, flow control                                | B                                     | NA                                     | D                                                  | B31.1                                                     |              |
| Valves, other                                       | B                                     | NA                                     | D                                                  | B16.5                                                     |              |
| Pressure vessels                                    | GE                                    | NA                                     | D                                                  | VIII                                                      |              |

HNP-2-FSAR-3

**TABLE 3.2-1 (SHEET 6 OF 11)**

| <u>Principal Components</u>                                            | <u>Scope of Supply<sup>(b)</sup></u> | <u>Seismic Category<sup>(c)</sup></u> | <u>Quality Group Classification<sup>(d)</sup></u> | <u>Principal Construction/ Design Code<sup>(f)</sup></u> | <u>Notes</u> |
|------------------------------------------------------------------------|--------------------------------------|---------------------------------------|---------------------------------------------------|----------------------------------------------------------|--------------|
| <b>RHRSW System</b>                                                    |                                      |                                       |                                                   |                                                          |              |
| Piping                                                                 | B                                    | I                                     | C                                                 | III-3                                                    |              |
| Pumps                                                                  | B                                    | I                                     | C                                                 | III-3                                                    |              |
| Pump motors                                                            | B                                    | I                                     | NA                                                | None                                                     |              |
| Valves                                                                 | B                                    | I                                     | C                                                 | III-3                                                    |              |
| <b>PSW System</b>                                                      |                                      |                                       |                                                   |                                                          |              |
| Piping (intake structure, reactor building, diesel generator building) | B                                    | I                                     | C                                                 | III-3                                                    |              |
| Piping (underground)                                                   | SCS                                  | I                                     | C                                                 | USAS B31.7                                               |              |
| Pumps                                                                  | B                                    | I                                     | C                                                 | III-3                                                    |              |
| Pump motors                                                            | B                                    | I                                     | NA                                                | None                                                     |              |
| Valves                                                                 | B                                    | I                                     | C                                                 | III-3                                                    |              |
| All other piping & valves                                              | B                                    | NA                                    | D                                                 | B31.1                                                    |              |
| <b>Reactor Building Closed Cooling Water (RBCCW) System</b>            |                                      |                                       |                                                   |                                                          |              |
| Piping & valves forming part of primary containment boundary           | B                                    | I                                     | B                                                 | III-2                                                    | 21           |
| <b>Instrument &amp; Service Air System</b>                             |                                      |                                       |                                                   |                                                          |              |
| Accumulators & piping between accumulators & valves for outboard MSIVs | B                                    | I                                     | B                                                 | III-2                                                    |              |
| Accumulators & piping in noninterruptible air system                   | B                                    | I                                     | D                                                 | B31.1<br>VIII                                            |              |
| Piping & valves forming part of containment boundary                   | B                                    | I                                     | B                                                 | III-2                                                    | 16           |
| Compressors                                                            | B                                    | NA                                    | D                                                 | B31.1                                                    |              |
| All other piping, valves, & receivers                                  | B                                    | NA                                    | D                                                 | B31.1                                                    |              |
| <b>Drywell Pneumatic System</b>                                        |                                      |                                       |                                                   |                                                          |              |
| Piping forming a part of containment                                   | B                                    | I                                     | B                                                 | III-2                                                    |              |
| Piping, valves, & accumulators inside drywell                          | B                                    | I                                     | B                                                 | III-2                                                    |              |
| Compressors, piping, & valves to receivers                             | B                                    | NA                                    | D                                                 | B31.1                                                    |              |
| Receivers, piping, & valves to containment isolation                   | B                                    | I                                     | B                                                 | III-2                                                    |              |

HNP-2-FSAR-3

**TABLE 3.2-1 (SHEET 7 OF 11)**

| <u>Principal Components</u>                                                                                                                                                                                         | <u>Scope of Supply</u> <sup>(b)</sup> | <u>Seismic Category</u> <sup>(c)</sup> | <u>Quality Group Classification</u> <sup>(d)</sup> | <u>Principal Construction/ Design Code</u> <sup>(f)</sup> | <u>Notes</u> |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------|----------------------------------------|----------------------------------------------------|-----------------------------------------------------------|--------------|
| <b>Diesel Generator System</b>                                                                                                                                                                                      |                                       |                                        |                                                    |                                                           |              |
| Day tanks                                                                                                                                                                                                           | SCS                                   | I                                      | C                                                  | VIII                                                      | 8            |
| Piping & valves fuel oil system                                                                                                                                                                                     | SCS                                   | I                                      | C                                                  | B31.1                                                     | 9            |
| Piping & valves expansion tank makeup inside diesel generator building                                                                                                                                              | B                                     | I                                      | D                                                  | B31.1                                                     |              |
| Piping & valves diesel service water system                                                                                                                                                                         | B                                     | I                                      | C                                                  | III-3                                                     |              |
| Pumps fuel oil system                                                                                                                                                                                               | B                                     | I                                      | C                                                  | III-3                                                     |              |
| Pumps diesel service water system                                                                                                                                                                                   | B                                     | I                                      | C                                                  | III-3                                                     |              |
| Pump motor fuel oil system                                                                                                                                                                                          | B                                     | I                                      | NA                                                 | None                                                      |              |
| Pump motors diesel service water system                                                                                                                                                                             | B                                     | I                                      | NA                                                 | None                                                      |              |
| Diesel generators                                                                                                                                                                                                   | SCS                                   | I                                      | NA                                                 | None                                                      |              |
| <b>CAD</b>                                                                                                                                                                                                          |                                       |                                        |                                                    |                                                           |              |
| Primary containment purge (includes CAD)                                                                                                                                                                            | B                                     | I                                      | B                                                  | III-2                                                     |              |
| <b>SGTS</b>                                                                                                                                                                                                         |                                       |                                        |                                                    |                                                           |              |
| Filter train housing                                                                                                                                                                                                | B                                     | I                                      | B                                                  | III-2                                                     | 17           |
| Valves                                                                                                                                                                                                              | B                                     | I                                      | B                                                  | III-2                                                     |              |
| Piping                                                                                                                                                                                                              | B                                     | I                                      | B                                                  | III-2                                                     |              |
| Damper in reactor building to maintain integrity of secondary containment                                                                                                                                           | B                                     | I                                      | C                                                  | NA                                                        |              |
| <b>ECCS Equipment Area Cooling System</b>                                                                                                                                                                           |                                       |                                        |                                                    |                                                           |              |
| All components with safety function                                                                                                                                                                                 | B                                     | I                                      | C                                                  | III-3                                                     |              |
| <b>Power Conversion Systems</b>                                                                                                                                                                                     |                                       |                                        |                                                    |                                                           |              |
| Main steam piping to turbine stop valves, bypass valves, steam seal isolation valve, steam jet air ejector isolation valve, reactor feed pump turbine isolation valve, moisture-separator reheater isolation valves | B                                     | I                                      | B                                                  | III-2                                                     |              |
| All above valves except turbine stop & bypass valves                                                                                                                                                                | B                                     | I                                      | B                                                  | III-2                                                     | 6            |
| Piping & valves, others                                                                                                                                                                                             | B                                     | NA                                     | D                                                  | B31.1                                                     |              |

HNP-2-FSAR-3

**TABLE 3.2-1 (SHEET 8 OF 11)**

| <u>Principal Components</u>          | <u>Scope of Supply<sup>(b)</sup></u> | <u>Seismic Category<sup>(c)</sup></u> | <u>Quality Group Classification<sup>(d)</sup></u> | <u>Principal Construction/ Design Code<sup>(f)</sup></u> | <u>Notes</u> |
|--------------------------------------|--------------------------------------|---------------------------------------|---------------------------------------------------|----------------------------------------------------------|--------------|
| Condensate Storage & Transfer System |                                      |                                       |                                                   |                                                          |              |
| CST                                  | B                                    | NA                                    | C                                                 | III-3                                                    |              |
| Piping & valves                      | B                                    | NA                                    | C/D                                               | III-3 & B31.1                                            |              |
| Condensate transfer pump             | B                                    | NA                                    | D                                                 | Hydraulic Institute                                      |              |

a. (deleted)

b. GE - General Electric.

B - Bechtel Power Corporation.

SCS - Southern Company Services, Inc.

TR - Target Rock Corporation.

c. I - The equipment is constructed in accordance with the seismic requirements for the DBE described in section 3.7.

NA - The seismic requirements for the DBE are not applicable to the equipment.

S - The equipment meets the seismic requirements described in the purchase specification.

d. The equipment is constructed in accordance with the codes listed in table 3.2-2.

e. (deleted)

f. Notations for principal construction/design codes are:

- III-A, B, C, 1, 2, 3, NF, NE - ASME Boiler and Pressure Vessel Code, Section III, Class A, B, C, 1, 2, 3, NF or NE. (Earlier versions of the code used the Class A, B, C designation, while later versions used the Class 1, 2, 3, NE designation. Equipment was ordered throughout a period requiring use of both designations.)
- VIII - ASME Boiler and Pressure Vessel Code, Section VIII, Pressure Vessels, Division I.
- B31.7 - USAS Code for Pressure Piping.
- B31.1 - ANSI B31.1 Standard Code for Pressure Piping, Power Piping.
- NPVC-1,2,3 - Draft ASME Code for Pumps and Valves for Nuclear Power, Class I, II, III.
- TEMA-B, C - Tubular Exchanger Manufacturers Association (TEMA), Standards Class B, C.
- API 650 - Welded Steel Tanks for Oil Storage; Atmospheric Tanks.
- API 620 - Standards for Large Welded Low-Pressure Storage Tanks.
- B96.1 - USAS B96.1 - Welded Aluminum Alloy Field-Erected Storage Tanks.
- B16.5 - ANSI B16.5 - Steel Pipe Flanges and Flanged Fittings.

**NOTES:**

1. All instrument lines connected to the RCPB and are not used to actuate safety systems are Quality Group D from the outer isolation valve or the process shutoff valve (root valve) to the sensing instrumentation.

## HNP-2-FSAR-3

**TABLE 3.2-1 (SHEET 9 OF 11)**

All other instrument lines:

- Through the root valve, shall be of the same classification as the system to which they are attached.
- Beyond the root valve, if used to actuate a safety system, shall be of the same classification as the system to which they are attached.
- Beyond the root valve, if not used to actuate a safety system, are Quality Group D.

All sample lines from the outer isolation valve or the process root valve through the remainder of the sampling system are Quality Group D.

2. The hydraulic control unit (HCU) is a GE factory assembled engineered module of valves, tubing, piping, and stored water which controls a single CRD by the application of precisely timed sequences of pressures and flows. This is accomplished by slow insertion or withdrawal of the control rods for power control and rapid insertion for reactor scram.

Although the HCU, as a unit, is field installed and connected by process piping, many of its internal parts differ markedly from process piping components because of the more complex functions they must provide. Although the codes and standards invoked by the Quality Group A, B, C, and D pressure integrity quality levels clearly apply at all levels to the interfaces between the HCU and the connecting conventional piping components; e.g., pipe nipples, fittings, simple hand valves, etc., it is considered that they do not apply to the specialty parts; e.g., solenoid valves, pneumatic components, and instruments.

The design and construction specifications for the HCU do invoke such codes and standards as can be reasonably applied to individual parts in developing required quality levels, but these codes and standards are supplemented with additional requirements for these parts and for the remaining parts and details. For example, all welds are low-pressure inspected, all socket welds are inspected for gap between pipe and socket bottom, all welding is performed by qualified welders, and all work is done according to written procedures.

Quality Group D is generally applicable because the codes and standards invoked by that group contain clauses which permit the use of manufacturer's standards and proven design techniques which are not explicitly defined within the codes of Quality Groups A, B, or C. This is supplemented by the quality control techniques described above.

3. The RCIC and HPCI turbines do not fall within the applicable design codes. To ensure that the turbines are fabricated to the standards commensurate with their safety and performance requirements, GE established specific design requirements for this component. These requirements are given in the appropriate GE internal documents.
4. Quality Group D, Section VIII of the ASME Boiler and Pressure Vessel (B&PV) Code, Division I, and ANSI B31.1 apply downstream of the outermost isolation valves.

## HNP-2-FSAR-3

**TABLE 3.2-1 (SHEET 10 OF 11)**

5. RWC influent to the system has one isolation valve inside and one outside the containment. Downstream of the outside isolation valve, the system is Quality Group C.  
  
RWC return to the feedwater is Quality Group C upstream of the check valve and Quality Group B downstream of the spring loaded piston actuated check valve.
6. The turbine stop and control valves, bypass valves, and main steam leads meet all the requirements of quality group certification. Certification is defined in the April 19, 1974, letter from Mr. J. M. Hendrie, Deputy Director for Technical Review, Directorate of Licensing to Mr. J. A. Hinds, Manager, Safety and Licensing, General Electric Company.
7. The outermost valve of the three isolatable valves in the feedwater lines and the CRD hydraulic system water return line is similar to a boiler feed pump check valve.  
  
The spring loaded piston operator of the valve is held open by air pressure during normal operation. Fail-open solenoid valves are used to release air pressure and to permit the check valve piston operators to close. The valves are remote manually operated from the main control room, using signals which indicate loss of feedwater flow or loss of CRD hydraulic system water return line flow, respectively.
8. The day tanks were purchased prior to July 1, 1971. Nondestructive examination (NDE) requirements were in accordance with ASME Section VIII, Division I.
9. Piping and valves for the fuel oil system that were installed with HNP-2 meet the requirements for ASME Section III, Class 3, except for materials traceability and N-stamp requirements. NDE and testing are performed according to the requirements for Quality Group C (ASME, Section III, Class 3).
10. This portion of the CS system is designed in accordance with the methods of the 1971 edition of the ASME B&PV Code, Section III for Class 1 components (documentation was not required). Due to the design, hydrostatic testing was not possible.
11. The containment spray system is a mode of the RHR system and is Seismic Category I. No credit is taken for the containment spray system operation in the mitigation of accidents analyzed in chapter 15.
12. In the replacement of the recirculation system, the piping and fittings are in accordance with ASME B&PV Code, Section III, Subsection NB, 1980 Edition, up to and including Winter 1980 Addenda for materials, testing, and manufacturing. Design for the replacement is in accordance with ASME B&PV Code, Section III, Subsection NB, 1980 Edition, up to and including Winter 1981 Addenda.
13. The stainless steel portion of the RHR piping (suction and return) between the tee connection to the recirculation piping and the first RHR isolation valve was replaced. This replaced portion of piping was supplied by GE to the same code of construction as the recirculation piping. (See note 12.)
14. Portions of the RWC piping, from its connection to the contour nozzle on the 20-in. RHR suction up to the first valve (MO-F004) beyond the penetration (with the exception of the penetration) and a small section of pipe between valve MO-F001 and the penetration, were replaced. These replaced portions were supplied by GE to the same code of construction as the recirculation piping. (See note 12.)

## HNP-2-FSAR-3

**TABLE 3.2-1 (SHEET 11 OF 11)**

15. (deleted)
16. The torus-to-drywell vacuum breaker air test lines were installed as ANSI B31.1 (the stainless steel lines between the test solenoid valves and the air operators for vacuum breakers). These lines were subsequently modified to be Seismic Category I. The NRC granted an exemption for the lines to be treated as ANSI B31.1 upgraded to Class 2 for ASME Section III, with Section XI inspection and testing requirements (NRC letter to GPC, dated March 17, 1988).
17. The SGTS filter train housing is constructed to meet the intent of ASME Section III, Nuclear Class 2 requirements. The rules of subsection NC were followed even though the filter train manufacturer did not have an N stamp.
18. The safety-related components of the refueling equipment platform assembly are: all load-supporting members of the bridge; all load-supporting members of the trolley; and the support frame for the frame-mounted and monorail auxiliary hoists. The following refueling platform subassemblies and components are considered nonsafety related: the fuel grapple and associated cable; all electrical control components; wiring, relays, limit switches, etc; the drive train for the bridge, trolley, and monorail; the frame-mounted auxiliary hoist; the monorail auxiliary hoist; the pneumatic system; the brake assemblies for all the hoists; the hoisting cables for all hoists; and the main hoist. For the nonsafety-related components as specified in the GE Master Parts List F15-E003, the components and/or subassemblies are purchased commercially; consequently, they do not fall under any 10 CFR 50, Appendix B, quality assurance program, nor are any seismic requirements imposed on the equipment.
19. Modified recirculation pipe hangers HA3, HA4, HB3, and HB4 were installed in accordance with ASME Section III, Subsection NF.
20. The RHR pump seal coolers were replaced with similar coolers with shells made of cast steel instead of cast iron. The replacement coolers were purchased as commercial-grade components dedicated to safety-related service in accordance with the requirements of NRC Generic Letter 89-09.
21. The sections of piping from valves 2P42-F051 and 2P42-F052 through the containment penetration sleeves are Quality Group B. The remainder of the system inside containment is Quality Group D, Seismic Category I, and is covered under the plant's ASME Section XI inservice inspection and surveillance program for Nuclear Class 3 piping.
22. Except for primary containment isolation valves and associated piping from these valves to the containment penetrations, replacement components may be designed to the requirements specified in table 11.2-1.
23. This equipment is designed to GE Code, Class E specifications, which are equivalent to ASME Code, Section III, Class 2 requirements.



HNP-2-FSAR-3

**TABLE 3.2-2 (SHEET 1 OF 3)**  
**CODE REQUIREMENTS FOR BWR COMPONENTS AND SYSTEMS**  
 ORDERED PRIOR TO JULY 1, 1971

|                                              | CLASSIFICATION GROUP                                      |                                                                                                                                                          |                                                                                                                                                                    |                                                            |
|----------------------------------------------|-----------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|
|                                              | <u>A</u>                                                  | <u>B</u>                                                                                                                                                 | <u>C</u>                                                                                                                                                           | <u>D</u>                                                   |
| Reactor containment pressure vessels (steel) | -                                                         | ASME B&PV Code, Section III, Class B                                                                                                                     | -                                                                                                                                                                  | -                                                          |
| Pressure vessels                             | ASME B&PV Code, Section III, Class A                      | ASME B&PV Code, Section III, Class C                                                                                                                     | ASME B&PV Code, Section VIII, Division 1                                                                                                                           | ASME B&PV Code, Section VIII, Division I                   |
| Piping                                       | USAS B31.7 Nuclear Power Piping, Class I                  | USAS B31.7 Nuclear Power Piping, Class II                                                                                                                | USAS B31.7 Nuclear Power Piping, Class III                                                                                                                         | USAS B31.1 Code for Pressure Piping                        |
| Pumps and valves                             | ASME Code for Pumps and Valves for Nuclear Power, Class I | ASME Codes for Pumps and Valves for Nuclear Power, Class II                                                                                              | ASME Code for Pumps and Valves for Nuclear Power, Class III                                                                                                        | USAS B31.1 Code for Pressure Piping                        |
| Low-pressure storage tanks 0 to 15 psig      | -                                                         | API-620 with NDT supplementary examination requirements per applicable code or standard                                                                  | API-620 with NDT requirements in accordance with ASME Section VIII, Division I                                                                                     | API-620 or equivalent                                      |
| Atmospheric storage tank                     | -                                                         | Applicable storage tank codes such as API-650 AWWAD110 or ANSI B96.1 with the NDT supplementary examination requirements per applicable code or standard | Applicable storage tank codes such as API-650 AWWAD100 or ANSI B96.1 with the NDT examination requirements in accordance with ASME Section VIII, Division 1 or API | API-650, AWWAD100 or ANSI B96.1 or equivalent              |
| Heat exchangers                              | ASME B&PV Code, Section III, Class A                      | ASME B&PV Code, Section III, Class C, and TEMA Class C                                                                                                   | ASME B&PV Code, Section VIII, Division 1, and TEMA Class C                                                                                                         | ASME B&PV Code, Section VIII, Division 1, and TEMA Class C |

HNP-2-FSAR-3

**TABLE 3.2-2 (SHEET 2 OF 3)**  
 ORDERED AFTER TO JULY 1, 1971

|                                              | CLASSIFICATION GROUP                                   |                                                                                                                          |                                                                                                            |                                                            |
|----------------------------------------------|--------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|
|                                              | <u>A</u>                                               | <u>B</u>                                                                                                                 | <u>C</u>                                                                                                   | <u>D</u>                                                   |
| Reactor containment pressure vessels (steel) | -                                                      | ASME B&PV Code, Section III, Class MC                                                                                    | -                                                                                                          | -                                                          |
| Pressure vessels                             | ASME B&PV Code, Section III, Class 1                   | ASME B&PV Code, Section III, Class 2                                                                                     | ASME B&PV Code, Section III, Class 3                                                                       | ASME B&PV Codes, Section VIII, Division 1                  |
| Piping                                       | ASME B&PV Code, Section III, Class 1                   | ASME B&PV Code, Section III, Class 2                                                                                     | ASME B&PV Code, Section III, Class 3                                                                       | ANSI B31.1 Code for Pressure Piping                        |
| Pumps and valves                             | ASME B&PV Code, Section III, Class 1                   | ASME B&PV Code, Section III, Class 2                                                                                     | ASME B&PV Code, Section III, Class 3                                                                       | ANSI B31.1 Code for Pressure Piping                        |
| Low-pressure storage tanks 0 to 15 psig      | -                                                      | API-620 with the NDT supplementary examination requirements                                                              | API-620 with the NDT supplementary examination requirements                                                | API-620 or equivalent                                      |
| Atmospheric storage tank                     | -                                                      | Applicable storage tank codes such as API-650 AWWAD100 or ANSI B96.1 with the NDT supplementary examination requirements | Applicable storage tank codes such as API-650 AWWAD100 or ANSI B96.1 with the NDT examination requirements | API-650, AWWAD100 or ANSI B96.1 or equivalent              |
| Heat exchangers                              | ASME B&PV Code, Section III, Class 1, and TEMA Class C | ASME B&PV Code, Section III, Class 2, and TEMA Class C                                                                   | ASME B&PV Code, Section III, Class 3, and TEMA Class C                                                     | ASME B&PV Code, Section VIII, Division 1, and TEMA Class C |

## HNP-2-FSAR-3

### TABLE 3.2-2 (SHEET 3 OF 3)

#### NOTES:

1. Pumps operating above 150 psi and 212°F, ASME Section VIII, Division 1 of the B&PV Code, are used as a guide for calculating the thickness of pressure retaining parts. In sizing cover bolting below 150 psi and 212°F, manufacturer standards for service intended are used.
2. Nuclear piping, pumps, and valves meet the provisions of ASME B&PV Code, Section III, paragraph N-153, including Summer 1969 Addenda, with the exception of the recirculation piping and stainless steel portions of the RHR and portions of the RWC piping which were replaced in 1984 in accordance with the ASME B&PV Code, Section III, Subsection NB, 1980 Edition including Winter of 1980 Addenda.
3. Cast parts > 2 in. and < 4 in. in Quality Groups A and B are nondestructively tested where possible in accordance with the 1971 Winter Addenda of ASME Section III.
4. Supplementary examination requirements for tanks ordered after 7/1/71:
  - a. 100% volumetric examination of the sidewall and roof weld joints for plates over 3/16-in. thick and 100% surface examination of weld joints for plates 3/16-in. thick or less and the sidewall-to-bottom and sidewall-to-roof joints. These examination requirements are to be performed in accordance with the rules of applicable codes.
  - b. 100% volumetric examination of the sidewall weld joints for plates over 3/16-in. thick and 100% surface examination of weld joints for plates 3/16-in. thick or less and the sidewall-to-bottom joint. These examination requirements are to be performed in accordance with the rules of applicable codes.
5. This table documents an agreement reached with the NRC that, for HNP Units 1 and 2, all new components ordered after July 1, 1971, would meet the ASME Code. This agreement applied to new components ordered as part of the construction process and did not address repair and replacement components or parts. For Unit 1, this agreement is documented in the FSAR Questions and Answers (see Q&A 1.1).

#### LEGEND:

NDT = Nondestructive testing  
API = American Petroleum Institute

HNP-2-FSAR-3

**TABLE 3.2-3**

**CODE STATUS OF CLASS I PRIMARY PRESSURE BOUNDARY COMPONENTS**

| <u>Component Description</u>    | <u>Plant Identification System No.</u> | <u>Code Specified</u>       | <u>Code Required in Accordance with 10 CFR 50.55a</u> |
|---------------------------------|----------------------------------------|-----------------------------|-------------------------------------------------------|
| RPV                             | B11-A001                               | ASME III, 70S               | ASME III, 70S                                         |
| RPV head nozzle                 | B11-D072                               | ASME III, 70S               | ASME III, 73                                          |
| CRD housings                    | B11-D141,142,143,144                   | ASME III, 70S               | ASME III, 70S                                         |
| CRD                             | B11-D146                               | ASME III, 69W               | ASME III, 70S                                         |
| Incore housing                  | B11-D190,198                           | ASME III, 70S               | ASME III, 70S                                         |
| Jet pump instrument penetration | B11-D235                               | ASME III, 70S               | ASME III, 70S                                         |
| Safety relief valve             | B21-F013                               | ASME III, 1968-1970 Addenda | ASME III, 1968-1970 Addenda                           |
| MSIV inboard                    | B21-F022                               | ASME III, 71W               | ASME III, 71                                          |
| MSIV outboard                   | B21-F028                               | ASME III, 71W               | ASME III, 71                                          |
| Primary steam piping            | B21-G001                               | ASME III, 71W               | ASME III, 71W                                         |
| Main steam flow element         | B21-N005                               | B31.7, 69 & ASME III, 71    | ASME III, 71                                          |
| Recirculation pump              | B31-C001                               | NPVC, 70                    | NPVC, 70                                              |
| Recirculation gate valve        | B31-F023                               | NPVC, 70                    | NPVC, 70                                              |
| Recirculation gate valve        | B31-F031                               | NPVC, 70                    | NPVC, 70                                              |
| Recirculation piping            | B31-G001                               | ASME III, 1980 Edition, 80W | ASME III, 71W                                         |
| Recirculation flow element      | B31-N013                               | ASME III, 1980 Edition, 80W | ASME III, 71S                                         |

TABLE 3.2-4 (SHEET 1 OF 4)

## SYSTEM P&amp;IDs SHOWING QUALITY GROUP CLASSIFICATIONS

| <u>System</u>                                                     | <u>Drawing No.</u>           |
|-------------------------------------------------------------------|------------------------------|
| CRD                                                               | H-26007                      |
| CRDH                                                              | H-26006                      |
| SLC                                                               | H-26009                      |
| Nuclear boiler                                                    | H-26000, H-26001,<br>H-26189 |
| RRS                                                               | H-26003                      |
| RCIC                                                              | H-26023, H-26024             |
| RHR                                                               | H-26014, H-26015             |
| RWC                                                               | H-26036, H-26037             |
| Primary containment purge                                         | H-26084                      |
| SGT                                                               | H-26078                      |
| Primary containment atmosphere H <sub>2</sub> -O <sub>2</sub>     | H-26048, H-26049             |
| HPCI                                                              | H-26020, H-26021             |
| CS                                                                | H-26018                      |
| Jockey pump                                                       | H-26019                      |
| Post-accident reactor coolant and containment atmosphere sampling | H-26384                      |
| Spent-fuel pool cooling                                           | H-26039                      |
| Spent-fuel pool cleanup                                           | H-26040                      |
| PSW                                                               | H-21033, H26050,<br>H-26051  |

**TABLE 3.2-4 (SHEET 2 OF 4)**

| <u>System</u>                                                                    | <u>Drawing No.</u>                                         |
|----------------------------------------------------------------------------------|------------------------------------------------------------|
| RBCCW                                                                            | H-26054, H-26055                                           |
| Reactor and radwaste buildings condensate storage and transfer                   | H-26046                                                    |
| RHRSW                                                                            | H-21039                                                    |
| Plant service noninterruptible instrument air                                    | H-21028, H-21077,<br>H-26064, H-26070,<br>H-26260, H-26261 |
| Leak detection                                                                   | H-26076                                                    |
| Control building drainage                                                        | H-21063                                                    |
| Drywell pneumatic                                                                | H-26066, H-28023                                           |
| Torus drainage and purification                                                  | H-26042                                                    |
| Auxiliary steam                                                                  | H-26063                                                    |
| Control room ventilation                                                         | H-16042, H-26094                                           |
| Reactor zone HVAC                                                                | H-26067                                                    |
| Reactor building safeguard equipment emergency cooling                           | H-26071                                                    |
| Reactor building refueling floor HVAC                                            | H-26072                                                    |
| Radwaste building HVAC                                                           | H-26090                                                    |
| Turbine building HVAC                                                            | H-26086                                                    |
| Diesel generator building ventilation                                            | H-12619                                                    |
| Primary containment (drywell) HVAC                                               | H-26074                                                    |
| Control building ventilation                                                     | H-16041, H-26093                                           |
| Control building - computer, waste analysis, and cold lab rooms air-conditioning | H-16035, H-40056                                           |

**TABLE 3.2-4 (SHEET 3 OF 4)**

| <u>System</u>                                | <u>Drawing No.</u>                         |
|----------------------------------------------|--------------------------------------------|
| Waste gas treatment building HVAC            | H-16549                                    |
| Technical support center HVAC                | H-26002                                    |
| Reactor and radwaste buildings chilled water | H-26025, H-26008,<br>H-50563               |
| Primary containment (drywell) chilled water  | H-26080, H-26081                           |
| Control building chilled water               | H-51178                                    |
| Control building chilled water cooling units | H-51179                                    |
| Diesel engine and fuel oil                   | H-21074                                    |
| Fuel oil diesel oil                          | H-11037                                    |
| Main steam                                   | H-21012, H-21056                           |
| Main condenser gas removal                   | H-21030, H-21056                           |
| Circulating water                            | H-21026                                    |
| Condensate polishing demineralizer           | H-21018, S-60192                           |
| Condensate and feedwater                     | H-21037, Sheets 1-5<br>H-21038, Sheets 1-3 |
| Radwaste                                     | H-26026 through<br>H-26032                 |
| Radwaste support                             | H-26035                                    |
| Offgas                                       | H-26045                                    |
| Process radiation monitoring                 | H-26011, H-26012<br>H-26013, H-16564       |
| Fission products monitoring                  | H-16173, H-16274                           |

**TABLE 3.2-4 (SHEET 4 OF 4)**

GENERAL NOTES:

Piping classes on the referenced piping and instrumentation diagrams are designated by a three-letter code. The first letter indicates the primary valve and flange rating, the second letter the type of material, and the third letter the code to which the piping is designed.

The designations are as follows:

First Letter

- A Specified pressure at specific temperature
- B 2500# ANSI
- C 1500# ANSI
- D 900# ANSI
- E 600# ANSI
- F 400# ANSI
- G 300# ANSI
- H 150# ANSI
- J } For general use as designated
- K } on pipe class sheets
- L }
- M }

Second Letter

- A Stainless steel
- B Carbon steel
- C } For general use
- D }
- E }
- F }
- G }
- H }
- K }
- L }
- M }

Third Letter

- A Nuclear Power Piping, ASME Section III, Class 1
- B Nuclear Power Piping, ASME Section III, Class 2
- C Nuclear Power Piping, ASME Section III, Class 3
- E Code for Pressure Piping, ANSI B31.1
- F No code requirements

AEC Quality  
GP Class

- A
- B
- C
- D



HNP-2-FSAR-3

TABLE 3.2-6 (SHEET 1 OF 2)

PLACEMENT OF HNP-1 VALVES IN NUCLEAR SYSTEMS IN HNP-2

| Nominal<br>Pipe Size<br>(in.) | Valve<br>Type | Service<br>System MPL<br>No. | Service <sup>(1)</sup> | Total<br>Valves<br>Used | System<br>Design<br>Pressure | System<br>Design<br>Temperature | Valve<br>Pressure<br>Rating | Explanatory<br>Notes |
|-------------------------------|---------------|------------------------------|------------------------|-------------------------|------------------------------|---------------------------------|-----------------------------|----------------------|
| 1                             | Globe         | 2T48                         | R                      | 4                       | 62                           | 353                             | 600                         | -                    |
| 1                             | Globe         | 2G31                         | D                      | 5                       | 150                          | 150                             | 600                         | -                    |
| 1                             | Globe         | 2P41                         | D                      | 11                      | 150                          | 150                             | 600                         | -                    |
| 1                             | Globe         | 2P11                         | D                      | 1                       | 150                          | 150                             | 600                         | -                    |
| 1                             | Globe         | 2G11                         | O                      | 1                       | 150                          | 150                             | 600                         | 5                    |
| 1                             | Globe         | 2G11                         | D                      | 5                       | 150                          | 150                             | 600                         | -                    |
| 1                             | Globe         | 2G11                         | R                      | 2                       | 150                          | 150                             | 600                         | -                    |
| 1                             | Globe         | 2C41                         | O                      | 2                       | 150                          | 150                             | 1500                        | 2                    |
| 1                             | Check         | 2G11                         | O                      | 5                       | 150                          | 150                             | 600                         | 3                    |
| 1                             | Check         | 2P41                         | O                      | 1                       | 150                          | 150                             | 600                         | 4                    |
| 3/4                           | Globe         | 2G11                         | R                      | 26                      | 150                          | 150                             | 600                         | -                    |
| 3/4                           | Globe         | 2G11                         | V                      | 8                       | 150                          | 150                             | 600                         | -                    |
| 3/4                           | Globe         | 2P41                         | R                      | 24                      | 150                          | 150                             | 600                         | -                    |
| 3/4                           | Globe         | 2P41                         | V                      | 8                       | 150                          | 150                             | 600                         | -                    |
| 3/4                           | Globe         | 2P70                         | R                      | 5                       | 150                          | 150                             | 600                         | -                    |
| 3/4                           | Globe         | 2G41                         | R                      | 1                       | 150                          | 150                             | 600                         | -                    |
| 3/4                           | Globe         | 2G41                         | O                      | 2                       | 150                          | 150                             | 600                         | 6                    |
| 3/4                           | Globe         | 2G41                         | V                      | 1                       | 150                          | 150                             | 600                         | -                    |
| 3/4                           | Globe         | 2P11                         | V                      | 1                       | 150                          | 150                             | 600                         | -                    |
| 3/4                           | Globe         | 2E21                         | V                      | 8                       | 377                          | 400                             | 600                         | -                    |
| 3/4                           | Globe         | 2E21                         | D                      | 8                       | 377                          | 400                             | 600                         | -                    |
| 1/2                           | Check         | 2G11                         | O                      | 1                       | 150                          | 150                             | 600                         | 7                    |

**TABLE 3.2-6 (SHEET 2 OF 2)**

NOTES:

1. R = Instrument root valve  
V = System high point vent valve  
D = System low point drain valve  
O = Other: see explanatory notes column
2. These valves function as service air and demineralized water system boundary valves. In service, the valves are normally closed, locked closed.
3. These valves function in the radioactive waste treatment system as reverse flow preventers. Failure of the valves to perform their design function would not result in adverse plant conditions, nor would their failure to function result in any increase in the release of radioactive effluents.
4. This valve serves as a reverse flow preventer in the swing-diesel generator service water fill piping. Failure of this valve to perform its intended function will not adversely affect diesel generator operation.
5. This valve serves as an isolation valve for an air-hose connection to the floor drain filter backwash piping. In service, the valve is normally closed. Failure of this valve to perform its intended function would not result in adverse conditions within the plant because the valve is backed up in its function by a check valve and a pipe cap fitting.
6. These valves function as sample connection isolation valves. In service, these valves are normally open. Failure of these valves to perform their intended function would not result in adverse conditions for the system or the plant.
7. This valve serves as a reverse flow preventer in a filtered, service air connection to the radwaste system waste filter vessel. Failure of the valve to perform its intended function would not result in adverse conditions for the system or the plant.

### **3.3 WIND AND TORNADO LOADINGS**

#### **3.3.1 WIND LOADINGS (HNP-1 AND HNP-2)**

Wind loadings for Seismic Category I structures were selected on the basis of American Society of Civil Engineers (ASCE) Paper No. 3269, "Wind Forces on Structures."<sup>(1)</sup>

##### **3.3.1.1 Design Wind Velocity**

Seismic Category I structures are designed to withstand a basic wind velocity of 105 mph. The recurrence interval of this wind velocity is estimated to be at least 100 years.<sup>(1)</sup> The variation of wind velocity with height is shown in table 3.3-1.

##### **3.3.1.2 Basis for Wind Velocity Selection**

The fastest mile of wind at the Hatch plant site is shown, according to Figure 1(b) in the ASCE paper,<sup>(1)</sup> to be 105 mph.

##### **3.3.1.3 Vertical Velocity Distribution and Gust Factor**

The wind pressures resulting from the wind velocities shown in table 3.3-1 incorporate the shape factors in both horizontal and vertical directions.

The gust factor of 1.1 was selected which allows for a gust of ~ 10-s duration which, in a 105-mph basic wind, would have a length downwind of ~ 1540 ft; this factor is described as adequate in ASCE Paper No. 3269 for structures having a horizontal dimension, transverse to the wind, of 125 ft and larger.

##### **3.3.1.4 Determination of Applied Forces**

The design wind dynamic pressure is calculated by:

$$q = 0.002558 (V^2)$$

where:

$$q = \text{pressure (lb/ft}^2\text{)}.$$

$$V = \text{velocity (mph)}.$$

A shape coefficient of 1.3 is applied with all wind loads. Of the total of  $1.3 q$ ,  $0.8 q$  is applied as positive pressure to the windward walls, and  $0.5 q$  is applied as negative pressure on the leeward walls, where applicable.

Wind loads are applied to the structures as uniform static loads on the vertical areas of the walls.

The applied force of the magnitude and the distribution for Seismic Category I structures is shown in table 3.3-1.

### **3.3.2 TORNADO LOADINGS**

All above-ground Seismic Category I structures are designed to withstand tornado loadings and tornado-generated missiles.

If tornadic winds traverse the site, the reactor is capable of being shut down and secured in a safe shutdown mode. Superstructure damage could be incurred to the reactor building, turbine building, storage tanks, and incoming power lines without affecting the ability to shut down the reactor and maintain integrity of containment and essential heat removal systems during and following a tornado which might traverse the site. Simultaneous damage to all of these items is not expected. However, as a design objective, the reactor is capable of being safely shut down and maintained in a safe-shutdown condition with the loss of all such equipment.

Components which directly affect the ultimate safe shutdown of the plant are located either under the protection of reinforced concrete or underground. These components include the following:

- Reactor coolant system.
- Control rod drive system.
- Standby liquid control system.
- Primary containment and isolation valves.
- Reactor core isolation cooling system.
- Residual heat removal system and associated cooling systems.
- Battery system.
- Standby diesel generator system.
- Electrical controls and instrumentation (for above systems).

- Main control room (MCR).
- Plant instrument air system.
- Intake structure (portions essential to systems listed above).

With the above equipment protected, the plant has the capability to maintain a safe shutdown condition for prolonged periods.

### 3.3.2.1 Applicable Design Parameters

For Seismic Category I structures designed to withstand tornadoes and tornado-generated missiles, the following parameters are applied in combinations producing the most critical conditions:

#### A. Dynamic Wind Pressure

The dynamic wind pressure is caused by a tornado funnel having a peripheral tangential velocity of 300 mph and a forward progression of 60 mph. The applicable portions of wind design methods described in ASCE Paper No. 3269 are used to determine the proper drag and shape coefficients. The provisions for gust factors and variation of wind velocity with height are not applied. The average tornado design dynamic wind pressure is  $q = 230 \text{ lb/ft}^2$  based on an average wind velocity of 300 mph.

#### B. Pressure Differential

The structure interior bursting pressure is taken as rising 1 psi/s for 3 s, followed by a 3-s calm, then decreasing at 1 psi/s for 3 s. This cycle accounts for reduced pressure in the eye of a passing tornado. All fully enclosed Category I structures are designed to withstand the full 3-psi pressure differential.

#### C. Missile Impingement

A tornado missile is defined as any object dangerously set in motion and erratically propelled by a tornado. Two types of tornado missiles are considered; each type is assumed to act independently and only one type may be generated at any one time. It is also assumed that the missiles do not tumble while in flight, and are at any time oriented to have the maximum value:

$$\frac{C_d A}{W}$$

where:

$$C_d = \text{drag coefficient.}$$

## HNP-2-FSAR-3

A = projected area of missile exposed to wind.

W = weight of missile.

The two types of missiles are as follows:

- A 12-ft-long piece of wood 4 in. x 12 in. in size (108 lb) traveling end-on at a speed of 300 mph and striking the structure at any elevation.
- A 4000-lb automobile, traveling end-on at a speed of 50 mph and striking the structure on an impact area of 20 ft<sup>2</sup>, with any portion of the impact area being not more than 25 ft above grade.

### D. Torsional Moment

A torsional moment results from applying the wind specified in A on one-half of the structure and a wind velocity equal to one-half that specified in A applied to the other half of the building in the opposite direction.

### 3.3.2.2 Critical Load Combination for Tornado Load

The loading combination (7) listed below controls the design in determining total tornado load  $W_t$ . Other loading combinations were found not to control the design in determining total tornado load.

1.  $W_t = W_w$
2.  $W_t = W_p$
3.  $W_t = W_m$
4.  $W_t = W_w + .5W_p$
5.  $W_t = W_w + W_m$
6.  $W_t = W_w + .5W_p + W_m$
7.  $W_t = W_w + W_p + W_m$

where:

$W_t$  = total tornado load.

$W_w$  = tornado wind load.

$W_p$  = tornado differential pressure load.

$W_m$  = tornado missile load.

### **3.3.2.3 Depressurization and Blowout Panels**

A rapid depressurization of the air surrounding the structures occurs if the funnel of a tornado suddenly engulfs the structure. Necessary provisions are made for venting the structures (other than primary containment) which affect equipment necessary for safe shutdown. Venting is accomplished by placing blowout panels, designed to fail at a pressure lower than the safe building capability for internal pressure, that relieve excess pressure in all essential parts of such structures.

For those compartments that are vented, a flow analysis of all air volumes and interconnecting vent areas is performed and the maximum transient pressure differential across every wall, floor, and roof are calculated using the principles of fluid mechanics to determine its maximum transient pressure differential. Finally, each structural component is checked to ensure that it can withstand the maximum calculated transient pressure differential which it experiences.

The blowout panels used for venting the reactor and control building roofs are designed and tested initially to:

- Open against a wind velocity of 300 mph and remain open.
- Open when the internal static pressure in the building is increased to 55 lb/ft<sup>2</sup>.
- Release when the internal static pressure in the building is increased to 55 lb/ft<sup>2</sup> if the principal mechanism fails to operate.

Since they are designed to open during a tornado, the impact of tornado missiles was not considered in the designing of the blowout panels.

### **3.3.2.4 Structural Strength Considerations**

The structural steel frame, precast concrete wall panels, and roof deck of the reactor building above the refueling floor are designed to withstand the forces of a tornado.

### **3.3.2.5 Determination of Forces on Structures**

Tornado loads are applied to the Seismic Category I structures in the same manner as the wind loads described in paragraph 3.3.1.4 with the exception that gust factor and variation of wind velocity with height do not apply. The load combinations involving tornadoes are given in paragraphs 3.8.2.3, 3.8.3.3, 3.8.4.3, and 3.8.5.3.

The load factor selected for tornado loadings is 1.0, based on the short duration of the loading condition, the low probability of a tornado striking a specific geographic point, and the degree of conservatism in the selection of design tornado velocity.

The exterior walls of the reactor building are selected as representative of the design procedure. Using a model of the building and normalized Hoecker pressure profile, suction and airflows within the building were computed using the principles of compressible fluid flow. The maximum transient crushing and bursting pressures were computed. These pressures were applied to the walls as uniform loads to develop moment and shear diagrams. Additionally, the exterior walls were designed for dynamic concentrated loads representing the tornado missile impacts. These loads were obtained from dynamic analysis of the walls subjected to a pulse loading. The pulse was fitted to each case, i.e. span length, thickness, and missile energy, by trial and correction to satisfy energy and momentum principles. The moments and shears due to missiles were combined with those from crushing. The bursting moments and shears, or carryover moments from missile impact if larger, were used to design the opposite face reinforcement.

In most cases practical wall designs required a portion of the missile impact energy to be dissipated in the plastic range in the struck span. The ductility ratio as a general rule was limited to 10. This ratio in no case exceeds 20.

#### **3.3.2.5.1 Safety Consideration for Tornado Relief Vent Openings**

The structural steel angle framed safety grills provided under each of the tornado relief vent openings probably deflect the postulated tornado missile upon entering. However, even considering no deflection of the missile, the energy area ratio is not sufficient to cause failure of the spent-fuel racks in the reactor building spent-fuel pool or the heating, ventilation, and air-conditioning (HVAC) ductwork on the control building roof at el 180 ft-0 in. Failure of the MCR HVAC equipment, such as the MCR chiller units, could possibly result from the falling missile; however, failure of this equipment would not be sufficient to render the plant incapable of being shut down safely.

A sketch of the grill system is shown in figure 3.3-1. This grill was installed for safety reasons and was not designed for missile protection. The analysis of the effect of the Hatch 2 missile that could penetrate the tornado relief vent openings; i.e., the 4-in. x 12-in. x 12-ft wooden plank weighing 108 lb on the spent-fuel pool and control building roof, did not assume any deflection (change in direction from the end-on missile) from the grill, although deflection would most likely take place.

The mechanism of failure for the structural grill system upon the impact of the 12-ft-long wooden plank, 4-in. x 12-in., weighing 108 lb, and traveling end-on at a speed of 300 mph, is based on the energy absorption capacity of each angle of the grill. The angles may fail either by bending or by shearing, depending on where the missile strikes.

The angles in the structural grill system would most likely not fail in a manner to generate secondary missiles since the angles are welded at both ends. However, should secondary missiles be generated from the grill, neither the plank missiles nor the angles from the grill have



## HNP-2-FSAR-3

targets available which are required for safe plant shutdown either on the control room roof at el 180 ft or on the refueling floor at el 228 ft. There is only one relief vent directly over the spent-fuel pool, and if the plank hits the grill, a maximum of three angles could be generated as secondary missiles with a maximum energy of 2000 ft-lb each. The General Electric spent-fuel storage racks, which are protected by 21 ft of water cover, are designed to withstand an impact of ~ 9000 ft-lb<sup>(2)</sup> over a 3-in.-diameter (or larger) area before the racks would be damaged to the extent that special tooling is required to remove the fuel bundles. Additionally, the Holtec spent-fuel storage racks are able to withstand an impact of ~ 6600 ft-lb.<sup>(3)</sup>

The Seismic Category I structures, systems, and components which may be impacted by the postulated plank missile falling through the reactor building tornado relief vents or the secondary missiles generated by the failure of the angles in the grill system on the refueling floor include the reactor building overhead crane, the refueling bridge, the spent-fuel storage racks in the spent-fuel pool, and a service water system hose station, as well as the refueling floor itself. Seismic Category I structures which may be impacted by the postulated plank missile or the secondary missiles generated by the failure of the angles in the grill system on the control room roof (el 180 ft) include the MCR environmental control system equipment.

These items were not designed to resist postulated vertical missiles. However, the refueling floor has a slab thickness of a minimum of 18 in. with concrete of  $f'_c = 5000$  psi. The control room roof at el 180 ft has a thickness of 30 in. with concrete of  $f'_c = 4000$  psi.

After passing through the safety grill at the tornado vents and due to the hydrodynamic and buoyancy effects of the water in the fuel pool, the plank missile will have ~ 920 ft-lb of kinetic energy at a depth of 21 ft in the fuel pool. Since the General Electric spent-fuel storage racks are designed to withstand an impact of ~ 9000 ft-lb before the racks are damaged to the extent special tooling is required to remove the fuel bundles, the effect of the plank missile is negligible. The effect of the plank missile on the Holtec racks, which are able to withstand ~ 6600 ft-lb, is also negligible. This energy represents the design capability of the fuel racks even though considerably more energy would be required before fuel damage occurs.

Damage to other components identified above does not prevent safe shutdown of the plant.

### **3.3.2.6 Ability of Seismic Category I Structures to Perform Despite Failure of Structures not Designed for Tornado Loads**

Failure of Category II structures not designed for tornado loads does not affect the ability of Seismic Category I structures to perform their functions for the following reasons:

- A. Tornado missiles that may be formed by the failure of Category II structures do not exceed the force of those postulated and described in paragraph 3.3.2.1, against which Seismic Category I structures are designed.
- B. The structural frame of the Category II turbine building has been designed against collapse when subjected to tornado loadings.

## HNP-2-FSAR-3

### REFERENCES

1. "Wind Forces on Structures," Transactions of the ASCE, Paper No. 3269, 1961.
2. "Tornado Protection for the Spent-Fuel Storage Pool," APED 5696, General Electric, November 1968.
3. Southern Nuclear Operating Company letter HL-5752, "Spent Fuel Pool Storage Expansion Request for License Amendment," from H. L. Sumner, Jr., to NRC, dated April 6, 1999.

HNP-2-FSAR-3


**TABLE 3.3-1**

**WIND LOADS  
(HNP-1 AND HNP-2)**


| Height<br>(ft) | Velocity<br>(mph) | Dynamic<br>Pressure<br><u>q (lb/ft<sup>2</sup>)</u> | Wall Load<br>(lb/ft <sup>2</sup> ) |                        | Roof Load<br>(lb/ft <sup>2</sup> ) |
|----------------|-------------------|-----------------------------------------------------|------------------------------------|------------------------|------------------------------------|
|                |                   |                                                     | Pressure<br><u>0.8q</u>            | Suction<br><u>0.5q</u> | Suction<br><u>0.75q</u>            |
| 0 - 50         | 105               | 28                                                  | 22                                 | 14                     | 21                                 |
| 50 - 150       | 131               | 44                                                  | 35                                 | 22                     | 33                                 |
| 150 - 400      | 161               | 66                                                  | 53                                 | 33                     | 50                                 |

The design wind loads for the main stack are as follows:

| <u>ft</u> | <u>Effective Pressure (lb/ft<sup>2</sup>)</u> |
|-----------|-----------------------------------------------|
| 0-50      | 19                                            |
| 50-150    | 28                                            |
| 150-400   | 43                                            |
| 400-TOP   | 57                                            |



PLAN  
STRUCTURAL GRILL SYSTEM



SECTION A

ACAD

REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

STRUCTURAL GRILL SYSTEM

FIGURE 3.3-1

### 3.4 **WATER LEVEL (FLOOD) DESIGN (HNP-1 and HNP-2)**

Seismic Category I structures and components are designed for the protection of safety-related equipment from external flooding. The design maximum flood elevations used in the design of each Seismic Category I structure are described in subsection 2.4.3 and are as follows:

- Primary containment - el 105 ft.
- Reactor building - el 105 ft.
- Diesel generator building - el 105 ft.
- Control building - el 105 ft.
- Intake structure - el 105 ft.
- Main stack - el 105 ft.

Since all Category I structures except the intake structure are not affected by the maximum flood level of the Altamaha River, the design basis for buoyancy and static-water force effects is the ground water level at el 122 ft msl. For the intake structure, the maximum water level considered was 105 ft.

#### 3.4.1 **FLOOD PROTECTION**

All Seismic Category I systems and components located below flood level are protected by watertight Seismic Category I structures designed to withstand the flood condition.<sup>(1)</sup>

- A. There are no safety-related systems or components located below the design maximum flood elevation of 105 ft that are not protected against flood. When safety-related equipment is located in subgrade levels of Seismic Category I structures, the equipment is protected from the effects of ground water and natural flooding levels by the design of the structures.

The grade elevations for the Seismic Category I structures are as follows:

- Reactor building - el 129 ft.
- Diesel generator building - el 129 ft.
- Control building - el 129 ft.
- Intake structure - el 110 ft.
- Main stack - el 120 ft.

All exterior entrances are at or above the grade level for these structures. Therefore, flood protection for the entrances is not required. A list of exterior entrances is found in table 3.4-1.

Safety-related equipment is protected from the effects of ground water level by sealing each below-grade penetration with an appropriate seal. Seal designs used are shown on drawing no. H-16110.

- B. Structures described above housing safety-related equipment do not have exterior or access openings and penetrations below the design flood levels. Access to these structures is possible only from above grade level, which is el 129 ft.
- C. Such means as pumping systems, stoplogs, watertight doors, and drainage systems for flood protection are not required because access openings and penetrations are not provided below the design flood levels. Drains and sumps of adequate sizes are provided in all Seismic Category I structures and components to cope with potential inleakage from such phenomena as cracks in structure walls and leaking waterstops.

The wave crest at maximum discharge in the Altamaha River is calculated to reach an elevation of 108.3 ft. The wave runup may splash water onto the roadfill around the intake structure which is at el 110 ft and eventually leak into the building. Floor drains in the intake structure building are designed to handle such an inleakage.

### **3.4.2 ANALYSIS PROCEDURES**

The foundation slabs and exterior walls of safety-related structures are designed to resist upward and lateral pressures caused by the maximum flood level given in the preceding paragraph.

The hydrostatic pressure acting uniformly at the bottom of the structure is the product of the height to the design flood level and the water weight taken as 63 lb/ft<sup>3</sup> (figure 3.4-1). The horizontal pressure acting on the exterior walls varies with height, from maximum value at the bottom of the wall to zero value at the design flood level (figure 3.4-1).

The grade elevations for all safety-related structures, with the exception of the intake structure, are provided in subsection 3.4.1. Based on these high grade elevations, such phenomena as flood current, wind wave, hurricane, or tsunami were not considered to generate dynamic water forces on these structures. The possible maximum wind wave height considered for the design of the intake structure was based on the procedure described in reference 2. Based on a maximum upstream fetch of 18 miles, a maximum sustained wind velocity of 45 mph, and with a duration of more than 1 h, the wave crest at maximum discharge would reach an elevation of 108.3 ft. The reinforced concrete intake pump structure walls which may be affected by the wave runup are designed for an impact load of 4000 lb at 50 mph over an area of 25 ft<sup>2</sup>.

## HNP-2-FSAR-3

### REFERENCES


1. "Design Basis for Protection Against Natural Phenomena," 10 CFR 50, Appendix A, General Design Criterion 2.
2. Saville, McClendon, and Cochran, "Freeboard Allowances for Water in Inland Reservoirs," Journal of Water Ways Division, ASCE, May 1962.

TABLE 3.4-1

**SEISMIC CATEGORY I STRUCTURES EXTERIOR ENTRANCE  
(HNP-1 AND HNP-2)**

| <u>Structure</u>          | <u>Entrance<br/>Size</u> | <u>Elevation</u> | <u>Type of Door</u>   |
|---------------------------|--------------------------|------------------|-----------------------|
| Reactor building          | 12 ft x 14 ft            | 130 ft 0 in.     | Airtight door         |
|                           | 3 ft x 7 ft              | 130 ft 0 in.     | Airtight door         |
|                           | 3 ft x 7 ft              | 130 ft 0 in.     | Airtight door         |
| Diesel generator building | 6 ft x 7 ft              | 130 ft 6 in.     | Double security doors |
|                           | 6 ft x 7 ft              | 130 ft 6 in.     | Double security doors |
|                           | 6 ft x 7 ft              | 130 ft 6 in.     | Double security doors |
|                           | 6 ft x 7 ft              | 130 ft 6 in.     | Double security doors |
|                           | 6 ft x 7 ft              | 130 ft 6 in.     | Double security doors |
|                           | 6 ft x 7 ft              | 130 ft 6 in.     | Double security doors |
| Control building          | 9 ft 1/2 in. x 10 ft     | 130 ft 0 in.     | Metal rollup door     |
|                           | 3 ft 6 in. x 7 ft        | 130 ft 0 in.     | Security door         |
| Intake structure          | 3 ft 8 in. x 7 ft        | 111 ft 0 in.     | Security door         |
|                           | 3 ft 8 in. x 7 ft        | 111 ft 0 in.     | Security door         |
| Main stack                | 3 ft x 7 ft              | 120 ft 0 in.     | Security door         |
|                           | 3 ft x 7 ft              | 120 ft 0 in.     | Security door         |
|                           | 16 ft x 16 ft            | 120 ft 0 in.     | Rollup door           |





ACAD

REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

WATER PRESSURE ON STRUCTURES

FIGURE 3.4-1

### 3.5 MISSILE PROTECTION

Seismic Category I structures are designed to protect safety-related equipment and components from damage by internal and exterior missiles.

Systems and components required to ensure integrity of the reactor coolant pressure boundary (RCPB), as defined section 5.1, are contained within two structures -- the primary containment drywell and the reactor building, below el 228 ft 0 in. The primary containment drywell vessel described in paragraphs 3.8.2.1.1 and 6.2.1.2.1.1 is wholly contained within the concrete biological shield having a minimum concrete thickness of 60 in. The biological shield is in turn housed within the reactor building described in paragraphs 3.8.4.1 and 6.2.1.2.2. Structural design features of the reactor building are illustrated on drawing nos. H-26096 and H-26098 through H-26105. As may be determined from the referenced drawings, the reactor building has a minimum wall thickness of 18 in. and a minimum cover; i.e., floor at el 228 ft 0 in., of 18 in. ( $f'_c = 5000$  psi).

Systems and components required to ensure the capability of shutting down (and cooling down) the reactor and maintaining the reactor in a safe condition may be considered to include, exclusive of the RCPB components discussed above, the following:

- Reactor core isolation cooling (RCIC).
- Residual heat removal (RHR).
- Residual heat removal service water (RHRSW).
- Plant service water (PSW).
- Standby ac power and diesel generator auxiliary systems.
- dc power systems.
- Emergency core cooling system (ECCS) pump room coolers.

The RCIC and RHR systems, along with the ECCS pump room coolers described in subsections 5.5.6, 5.5.7, and 9.4.2, respectively, are housed in the reactor building. The standby ac power system and associated diesel generator auxiliary systems are housed in the diesel generator building described in paragraph 3.8.4.1. The diesel generator building is constructed with a minimum wall thickness of 30 in. and a minimum roof thickness of 24 in. The dc power system is housed in the control building described in paragraph 3.8.4.1. The control building is provided with 24-in. walls and a 30-in. roof. The standby ac power system and the dc power system are described in chapter 8. A description of the diesel generator auxiliary systems is provided in subsections 9.5.4 through 9.5.7. The PSW and RHRSW systems are housed in the intake structure described in paragraph 3.8.4.1. The intake structure is constructed with minimum wall and roof thicknesses of 30 in. Portions of the RHRSW and the PSW systems are also housed in the diesel generator building, the reactor building, and the

control building; some of the piping is buried a minimum of 3 1/2 ft underground. Descriptions of the PSW and RHRSW systems are provided in subsections 9.2.1 and 9.2.7, respectively.

Systems and components required to ensure the capability of preventing accidents that could result in potential offsite exposures not within the guideline values of Title 10 Code of Federal Regulations (CFR) Part 100 are included in the previous discussions.

A discussion of turbine missiles is presented in subsection 10.2.3.

Table 3.5-3 is a tabulation summary of the foregoing discussion.

### **3.5.1 MISSILE BARRIERS AND LOADINGS**

The missile shields and barriers are designed to resist the selected missiles described in subsection 3.5.2.

#### **3.5.1.1 Accident/Incident-Generated Missiles (Inside Primary Containment)**

The design philosophy is that no missiles are allowed to penetrate the primary containment. This is accomplished, in practice, through the specific design of the containment and containment systems that takes into account the potential for missile generation and minimizes the possibility of containment violation.

Safety-related equipment within the primary containment is protected from the effects of missiles by redundancy and separation. Therefore, missile barriers are not required to ensure the capability of safely shutting down the plant.

#### **3.5.1.2 Internally Generated Missiles (Outside Primary Containment)**

Safety-related equipment is primarily protected from internally generated missiles by separation through the design of the Seismic Category I structures.

#### **3.5.1.3 Environmentally Generated Missiles**

Seismic Category I structures, housing equipment and components vital to a safe shutdown, were designed to withstand penetration of the tornado missiles described in paragraph 3.3.2.1C. These structures, having at least 1-ft 6-in.-thick concrete exterior walls, constitute barriers against missile penetration. Calculations show that the deepest missile penetration of the concrete barriers would be 10 in. Therefore, the 1-ft 6-in.-thick slabs provide ample protection. A tabulation of all outdoor safety-related components, including the ventilation intakes and exhausts and the vents for safety-related tanks, is provided in table 3.5-4. This table indicates the tornado missile protection provided for all listed items.

## HNP-2-FSAR-3

The condensate storage tank provides the source of makeup water to the steam cycle on the boiling water reactor (BWR). This tank is protected from the penetration of tornado missiles by a Seismic Category I structure as described in section 9.2.6.3.

The BWR is not fitted with an auxiliary feedwater system.

The PSW pump and the RHRSW system pump intake structure are described in paragraph 3.8.4.1D and, as designed, afford tornado missile protection for the service water pumps.

The RHRSW and PSW Division I and II piping headers pass through the valve pit en route to the service connections in the plant complex. The automatic backwash strainers for the PSW system are located in the valve pit. Flooding of the valve pit was evaluated, and the result would be the loss of the automatic feature of the backwashable strainers. Loss of this automatic feature would not jeopardize the continued operation of the PSW system. Pipe routing and equipment location in the valve pit are shown on drawing no. H-21102. The Borden metal grating on the valve pit is capable of withstanding the energy imposed by the postulated missile impacts.

### **3.5.1.4 Site Proximity Missiles**

*The nearest airport with scheduled passenger service is located in Savannah, Georgia, ~ 67 miles northeast of the site. Small municipal fields not used for scheduled commercial services are located in Baxley ~ 13 miles south; in Hazlehurst, ~ 16 miles southwest; in Vidalia, ~ 20 miles north; in Alma, 28 miles south, and in Waycross, ~ 48 miles south. The nearest defense facility is Fort Stewart, with the nearest boundary 30 miles from the site. The closest firing range is R 3006 located ~ 45 miles from the site. For these reasons, the site is considered sufficiently distant from aircraft and guided missile installations; therefore, the plant is neither designed nor operated with special provisions to protect the facility against the effects of the installations and/or the aircraft.*

## **3.5.2 MISSILE SELECTION**

### **3.5.2.1 Accident/Incident-Generated Missiles (Inside Primary Containment)**

The following missiles are postulated to be generated within the primary containment:

- Recirculation pump missiles.
- Relief valve bonnets.
- Thermowells - with and without resistance temperature detectors (RTDs).
- Valve bonnets (small and large).

## HNP-2-FSAR-3

- Valve stems.
- Control rod drive (CRD) housings.

The valve bonnets and the thermowells are jet-propelled missiles. Valve stems are piston-type missiles.

Recirculation pump missiles are discussed in paragraph 1.5.1.2.5.

The CRD housings are restrained from becoming missiles by supports designed to allow a maximum deflection of 3 in. A detailed discussion of the CRD housings and the support members is included in paragraph 4.2.3.2.3.1.

### **3.5.2.2 Internally Generated Missile Selection (Outside Primary Containment)**

There are three types of postulated internally generated missiles outside the primary containment:

- Rotating-equipment missiles.
- Piston-type missiles.
- Jet-propelled missiles.

Pump impellers are considered to remain within the pump casing; therefore, the only postulated missiles from rotating equipment are couplings and turbine-generator missiles discussed in subsection 10.2.3. Equipment for which coupling missiles were evaluated is as follows:

- Core spray pump.
- High-pressure coolant injection pump.
- Hydraulic fluid power unit.
- RCIC pump.
- RHR pump.
- RHRSW pump.
- PSW pump.
- Reactor water cleanup (RWC) pump.

Other internal missiles selected are piston-type and jet-propelled missiles. These missiles are:

- Valve stems.
- Valve bonnets (large and small).
- Thermowells.

The valve stems are considered as piston-type missiles; valve bonnets and thermowells are considered as jet-propelled missiles.

### **3.5.2.3 Environmentally Generated Missile Selection**

The tornado-generated missiles selected for the design of Seismic Category I structures and the structural frame of the Category II turbine building are described in subsection 3.3.2.

## **3.5.3 SELECTED MISSILES**

### **3.5.3.1 Selected Accident/Incident-Generated Missiles (Inside Primary Containment)**

Velocities for missiles postulated within the primary containment were determined by the same methods used for the missiles postulated outside the primary containment (paragraph 3.5.3.2). Missile velocities and steel penetrations are tabulated in table 3.5-2.

The maximum steel thickness required to prevent perforation by the worst case postulated missile is 0.61 in. Since the drywell shell thickness in the region where postulated missiles would be generated is a minimum of 1.125 in., no missile is capable of penetrating the primary containment.

### **3.5.3.2 Selected Internal Missiles (Outside Primary Containment)**

Missiles from rotating equipment described in paragraph 3.5.2.2 were evaluated for protection requirements.

The hydraulic fluid power unit, the RCIC pump, and the RWC pump use full coupling guards in their constructions. The coupling guards minimize the consequences of a coupling failure, in addition to providing personnel protection.

The remaining pumps have couplings installed within the motor support. The cylindrical motor support has access openings through which parts of a coupling may escape. However, the area of the access openings is small relative to the area of the motor support walls. Therefore, the coupling would probably ricochet and lose energy before leaving the confines of the motor support.

## HNP-2-FSAR-3

Just as the aforementioned equipment is safety-related and protected by redundancy and separation, the consequences of rotating-equipment missiles do not exceed the safety-related equipment design spectra.

The internal missiles postulated for HNP-2 are the missiles resulting from the turbine-generator failure and the missiles originating in the recirculation system pump following a postulated pipe rupture. The turbine missile analysis and evaluation are discussed in subsection 10.2.3.

For HNP-2, the break locations are defined by the criteria recommended in the Nuclear Regulatory Commission Standard Review Plans 3.6.1 and 3.6.2. The American Society of Mechanical Engineers (ASME) Code, Section III, Class I piping stress report was used to establish break locations.

### Scope

Studies conducted on plants closely resembling HNP-2 indicate that HNP-2 is adequately safeguarded against adverse effects that may result from recirculation pump-generated missiles. The following indicates the work performed to evaluate the consequences of recirculation pump overspeed that leads to potential pump impeller missile generation following a postulated design basis loss-of-coolant accident for a typical General Electric BWR 4, Mark I containment nuclear power plant. The power plants selected for this probability study were Browns Ferry Nuclear Plant-Units 1, 2, and 3.

#### A. Probabilistic Model

The analysis used for evaluation of a typical BWR 4, Mark I containment plant was based on the USNRC pipe break criteria.

#### B. Break Locations

The break locations were determined using the criteria described in section 3.6.

#### C. Conclusions

Application of break location criteria delineated in section 3.6 indicated no damage to the primary containment, any major piping system, or to an inboard main steam isolation valve. Absence of damage is because the trajectories of postulated missiles do not intersect these systems.

#### D. Definition

Safe - A break is considered safe if the postulated missile:

- Is contained within the piping system.
- May leave the piping system at a velocity insufficient to perforate the containment or an essential piping system.

### HNP-2-FSAR-3

- Will impact a nonessential target that does not escalate the consequences of the accident.

Using conservative assumptions, it was determined that neither piston-type missiles nor jet-propelled missiles from fluid lines have sufficient velocity to penetrate the walls of the area in which they are produced.

The piston-type missile velocity was determined by assuming that all work done during ejection of the missile is converted to the kinetic energy of the missile. No friction loss or air resistance was assumed. The velocity of the missile is expressed as:<sup>(1)</sup>

$$V = \left( \frac{2PAL}{m} \right)^{1/2}$$

where:

V = velocity at end of piston stroke (ft/s).

P = pressure of fluid (psia).

A = cross-sectional area of piston (in.<sup>2</sup>).

L = length of stroke (ft) (assumed to be stem length).

m = mass of missile (lb-s<sup>2</sup>/ft).

The operating pressure of the HNP-2 safety systems or systems in proximity to safety systems is not sufficient to impart a velocity to stem missiles great enough to penetrate the drywell or the walls of the area in which the missile occurs. Therefore, the safety systems are protected from valve stem missiles by the walls of the Seismic Category I structures.

Jet-propelled missile (valve bonnets and thermowells) velocity was determined by first determining the jet velocity at the throat of the line penetration.

The velocity of the missile is induced by the mass and the velocity of the escaping fluid and is predicted by the following equation:<sup>(1)</sup>

$$\frac{-V}{V_f} - \ln \left( 1 - \frac{V}{V_f} \right) = \frac{K_2}{r_o} - \frac{K_2}{r_o + X \tan \beta}$$

where:

V = missile velocity (ft/s).

V<sub>f</sub> = jet velocity at throat (ft/s).

r<sub>o</sub> = radius of throat (ft).



### HNP-2-FSAR-3

$X$  = distance traveled (ft).

$\beta$  = half-angle expansion of jet.

and  $K_2 = \frac{A_o A_m}{\bar{V}_f m \pi \tan \beta}$  = constant for a particular missile.

where:

$A_o$  = break area (ft<sup>2</sup>).

$A_m$  = missile area (ft<sup>2</sup>).

$\bar{V}_f$  = specific volume of jet fluid at break (ft<sup>3</sup>/lbm).

$m$  = mass of missile.

and zero initial velocity is assumed.

Velocity analyses for jet-propelled missiles were conservative in that a half-angle expansion of only 15 degrees was assumed, and the missile was assumed to retain the velocity attained at the point where the fluid jet assumed asymptotic properties.

Velocities were determined for missiles from pressurized systems containing saturated steam, saturated water, and subcooled water. Velocities of the fluid jets were determined by methods outlined in references 2 and 3. Missile velocities, in all cases, were not sufficient to enable significant concrete penetration or any spalling. Therefore, safety-related equipment is considered to be protected from jet-propelled missiles by the walls of the Seismic Category I structures. No additional missile barriers are required. The selected missiles are described in table 3.5-1.

#### **3.5.3.3 Selected Environmentally Generated Missiles**

The origin, weight, size, impact velocity, orientation, and material composition for each selected missile are given in paragraph 3.3.2.1.

The two types of tornado-generated missiles considered in the HNP-2 design are as follows:

- A 12-ft-long piece of wood, 4 in. x 12 in. in size (108 lb), traveling end-on at 300 mph and striking the structure at any elevation.
- A 4000-lb automobile traveling end-on at 50 mph and striking the structure on an impact area of 20 ft<sup>2</sup>, with any portion of the impact area being no more than 25 ft above grade.

## HNP-2-FSAR-3

These missiles were tested, using a 16-in.-thick concrete slab, by the Environmental Test Department of Sandia Laboratories; and the results are reported by A. E. Stephenson in "Tornado Vulnerability Nuclear Production Facilities," April 1975, and also in "Addendum to Tornado Vulnerability Nuclear Production Facilities." The tests demonstrate that the two tornado-generated missiles under consideration do not penetrate or cause spalling; therefore, it can be concluded that they will not impair the structural integrity of the HNP-2 facilities.

Because of the test results, the material coefficient of penetration is not applicable.

As discussed in subsection 3.5.4, the overall structural response was limited to checking the flexural adequacy of the barriers, using a ductility ratio of 5.0 for computing the maximum flexural resistance. Thus, the equivalent static load and the deflection were not computed. Based on the evaluation of this structural response, typical percentages of steel reinforcement provided for the exterior walls are:

- el 130 to 158 ft - 0.00441.
- el 158 to 185 ft - 0.00208.
- el 185 to 203 ft - 0.00278.
- el 203 to 228 ft - 0.00204.

To assess the degree of protection comparability against tornado missiles provided by the HNP-2 design accepted at the construction permit stage of review, the following information is submitted:

Category I structures and appurtenances having walls or roofs with thicknesses < 2 ft are as follows:

HNP-2-FSAR-3

| <u>Category I<br/>Structures/Appurtenances</u>                 | <u>Minimum<br/>Wall Thickness</u>                                        | <u>Minimum<br/>Roof Thickness</u>               |
|----------------------------------------------------------------|--------------------------------------------------------------------------|-------------------------------------------------|
| Reactor building                                               | 1-ft 6-in. concrete wall; 8-in. concrete panel between el 185 and 228 ft | 3-in. concrete over Robertson Q-floor 21-18     |
| Reactor building vestibule area on el 228-ft floor             | 1 ft 0 in.                                                               | 10 in.                                          |
| Reactor building precast concrete panels above el 228 ft 0 in. | 0 ft 8 in.                                                               | -                                               |
| Intake structure valve pit                                     | Below grade                                                              | Borden 2 1/4-in. by 3/16-in. type W/D grating   |
| Control building precast concrete panels above el 164 ft 0 in. | 0 ft 8 in.                                                               | 3-in. concrete over Robertson Q-floor section 3 |
| Main stack                                                     | 1 ft 0 in.                                                               | 0 ft 6 in.                                      |

Tornado-generated missiles from a vertical direction were not considered in the design of roofs. The main stack was not designed for tornado winds and associated missiles.

The precast panels and the walls previously identified as having thicknesses < 2 ft are located above 30 ft from the finished grade, and only an 8-lb steel rod that is 1 in. in diameter and 3 in. in length was considered in computing the following velocities:

HNP-2-FSAR-3

| <u>Description</u>                                                                                                                                                     | <u>Velocity Required For Complete Penetration<sup>(4)</sup></u> | <u>Velocity Below Which Generation of Secondary Missiles Will Not Occur<sup>(4)</sup></u> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------|-------------------------------------------------------------------------------------------|
| 1-ft 6-in.-thick concrete walls in reactor building above el 185 ft 0 in. made of concrete with minimum compressive strength $f'_c = 4000$ psi.                        | 438 ft/s                                                        | 260 ft/s                                                                                  |
| 1-ft 0-in.-thick concrete walls in reactor building vestibule area above el 228 ft 0 in. made of concrete with $f'_c = 4000$ psi. No equipment is placed in this area. | 323 ft/s                                                        | 192 ft/s                                                                                  |
| 8-in.-thick precast concrete panel in control building above el 164 ft 0 in. and in reactor building above el 228 ft 0 in. made of concrete with $f'_c = 5000$ psi.    | 259 ft/s                                                        | 154 ft/s                                                                                  |

**3.5.3.4 Turbine-Generated Missiles**

The origin, weight, size, impact velocity, and orientation for the turbine-generated missiles are given in subsection 10.2.3.

**3.5.4 BARRIER DESIGN PROCEDURES**

The missile barriers were designed to resist missile penetration. The analysis for the depth of missile penetration was conducted using the following modified Petry formula for concrete:<sup>(5)</sup>

$$D = KApV'$$

$$V' = \log_{10} \left[ 1 + \frac{V^2}{215,000} \right]$$

$$D' = D \left[ 1 + e^{-4(a'-2)} \right]$$

$$a' = \frac{T}{D}$$

### HNP-2-FSAR-3

- D = depth of penetration of an infinitely thick slab.
- K = an experimentally obtained materials coefficient penetration (K = 0.00276 for 4000-psi reinforced concrete).
- Ap = sectional pressure, obtained by dividing weight of missile by maximum cross-sectional area (expressed as lb/ft<sup>2</sup>).
- V' = velocity factor.
- V = terminal or striking velocity in ft/s.
- D' = actual depth of penetration.
- T = thickness of resisting slab.

Missile penetration in a steel barrier was determined by using the Ballistics Research Laboratory formula, modified by setting a material constant K = 1.<sup>(4)</sup> The steel thickness, T, which will just be perforated by a missile, is solved as follows:

$$T = \frac{\left(\frac{MV_s^2}{2}\right)^{2/3}}{672D}$$

- T = steel plate thickness to just perforate (in.).
- M = mass of missile (lb-s<sup>2</sup>/ft).
- D = diameter of missile (in.).
- V<sub>s</sub> = striking velocity of missile, normal to target.

The thickness of steel required to prevent perforation is t<sub>p</sub>, where:

$$t_p = 1.25 \text{ (reference 4)}$$

The overall response evaluation of structural barriers to missile impact was not a design requirement at the time of the HNP-2 application; however, the exterior walls forming the structural barriers were considered to act as simple spans supported by various floors and checked for flexural adequacy of missile impact, using equation 5.16<sup>(6)</sup> for computing the required maximum resistance, and assuming a value of 5.0 for a ductility ratio and the ultimate strength design method for calculating the actual resistance of the slab barrier.

The structural steel framing was designed to carry all the loads from the floors and the roof. Typical compressive loads on the exterior walls that form a structural barrier are those due to the weight of the barrier itself. A typical structural barrier for the reactor building was evaluated.

## HNP-2-FSAR-3

The computed compressive stresses on the barrier did not exceed a maximum of 110 psi, which is significantly lower than the allowable compressive stress; therefore, limiting values of the ductility ratios subjected to compressive and combined (flexure and compression) loadings were not calculated.

### **3.5.5 MISSILE BARRIER FEATURES**

Drawing nos. H-12192, H-12320, H-12405, H-12406, H-12627, H-12629, H-12631, H-16249, H-22250, H-25000, H-26096, H-26098 through H-26105, H-40429, and H-40430 show the layout and principal design features of the barriers and structures designed to resist missiles. Additional information is provided in subsection 3.5.4 and paragraph 3.5.3.3.

## HNP-2-FSAR-3

### REFERENCES

1. R. C. Gwaltney, "Missile Generation and Protection in Light-Water-Cooled Power Reactor Plants," Oak Ridge National Laboratory, ORNL-NSIC-22, September 1968.
2. F. J. Moody, "Prediction of Blowdown Thrust and Jet Forces," ASME Publication 69-HT-31, August 1969.
3. F. J. Moody, "Maximum Two Phase Vessel Blowdown from Pipes," General Electric, APED-4827, April 20, 1965.
4. "Design of Structures for Missile Impact," Bechtel Topical Report BC-TOP-9A, Rev 2, September 1974.
5. A. Amirikian, "Design of Protective Structures," Bureau of Yards and Docks, Publication No. NAVDOCKS P-51, Department of Navy, Washington D. C., August 1950.
6. Biggs, J. M., Introduction to Structural Dynamics, McGraw Hill Book Company, chapter 5, p. 223, 1964.

TABLE 3.5-1

## SELECTED MISSILES OUTSIDE PRIMARY CONTAINMENT

| <u>Missile Description</u>         | <u>Missile Weight (lb)</u> | <u>Maximum Velocity (ft/s)</u> | <u>Kinetic Energy (ft-lb)</u> | <u>Depth of Penetration in 2-ft-Thick Concrete Barrier (in.)</u> |
|------------------------------------|----------------------------|--------------------------------|-------------------------------|------------------------------------------------------------------|
| 4-in. globe valve bonnet and motor | 625                        | 64                             | 39,784                        | 0.07                                                             |
| 4-in. globe valve bonnet           | 250                        | 99                             | 38,078                        | 0.84                                                             |
| 1-in. globe valve bonnet           | 15                         | 103                            | 2473                          | 0.24                                                             |
| 6-in. gate valve bonnet and motor  | 925                        | 102                            | 149,557                       | 0.24                                                             |
| Thermowell                         | 3                          | 202                            | 1902                          | 0.36                                                             |
| RTD and thermowell                 | 8                          | 220                            | 6017                          | 0.36                                                             |
| 1 1/2-in. diameter valve stem      | 20                         | 132                            | 5415                          | 1.92                                                             |
| 1 1/4-in. diameter valve stem      | 11                         | 123                            | 2586                          | 1.32                                                             |



**TABLE 3.5-2**  
**SELECTED MISSILES INSIDE PRIMARY CONTAINMENT**

| <u>Missile Description</u>                  | <u>Mass (lb-s<sup>2</sup>/ft)</u> | <u>Diameter (in.)</u> | <u>Velocity (ft/s)</u> | <u>Steel Thickness Just Perforated (in.)</u> | <u>Steel Thickness Not Perforated (in.)</u> |
|---------------------------------------------|-----------------------------------|-----------------------|------------------------|----------------------------------------------|---------------------------------------------|
| Main steam relief valve bonnet              | 9.32                              | 6.76                  | 150                    | 0.49                                         | 0.61                                        |
| 4-in. motor-operated valve bonnet and motor | 19.40                             | 22.0                  | 77                     | 0.10                                         | 0.13                                        |
| 4-in. valve bonnet                          | 7.76                              | 6.0                   | 118                    | 0.36                                         | 0.46                                        |
| 1-in. valve bonnet                          | 0.47                              | 3.0                   | 103                    | 0.09                                         | 0.11                                        |
| 6-in. motor-operated valve bonnet and motor | 28.70                             | 25.0                  | 107                    | 0.19                                         | 0.23                                        |
| Thermowell                                  | 0.09                              | 2.0                   | 202                    | 0.11                                         | 0.14                                        |
| RTD                                         | 0.25                              | 3.6                   | 220                    | 0.14                                         | 0.18                                        |
| 1 1/2-in. diameter valve stem               | 0.62                              | 1.5                   | 132                    | 0.31                                         | 0.39                                        |
| 1 1/4-in. valve stem                        | 0.34                              | 1.25                  | 123                    | 0.22                                         | 0.28                                        |

**TABLE 3.5-3**  
**TORNADO/TURBINE MISSILE PROTECTIVE BARRIERS**

| <u>System/Component</u>                                                                                                                                    | <u>Location</u>                               | <u>Protective Barrier - Minimum Thickness (in.)</u>    |
|------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------|--------------------------------------------------------|
| RCPB systems and components                                                                                                                                | Drywell                                       | Walls = 60<br>Cover = 72                               |
|                                                                                                                                                            | Reactor building<br>(el 228 ft 0 in. & below) | Walls = 18 <sup>(a)</sup><br>Cover = 18 <sup>(b)</sup> |
| Systems and components required to ensure capability to shut down reactor and maintain reactor in a safe condition (excluding RCPB systems and components) | Reactor building<br>(el 228 ft 0 in. & below) | Walls = 18 <sup>(a)</sup><br>Cover = 18 <sup>(b)</sup> |
|                                                                                                                                                            | Diesel generator building                     | Walls = 30<br>Cover = 24                               |
|                                                                                                                                                            | Intake structure                              | Walls = 30<br>Cover = 30                               |
|                                                                                                                                                            | Control building                              | Walls = 24<br>Cover = 30 <sup>(c)</sup>                |

- 
- a. Reactor building walls are also provided with exterior mounted, 8-in.-thick precast concrete panels.  
b. This slab is fabricated of concrete of  $f'_c = 5000$  psi.  
c. Thickness applies to the roof of the main control room.

TABLE 3.5-4 (SHEET 1 OF 2)

**TABULATION OF ITEMS AND DESCRIPTION OF  
PROTECTION AGAINST TORNADO MISSILES**

| <u>Components</u>                 | <u>Description of Protection Provided</u>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |
|-----------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| A. Liquid nitrogen storage tanks  | The liquid nitrogen storage tanks are located on each side of the HNP-1 reactor building railway airlock and are used in HNP-2 as a source of motive gas for essential air-operated valves and instruments. Drawing no. H-16147 shows the configuration of tank placement with respect to the railway air lock.                                                                                                                                                                                                                                                                                                                                                                                                                                      |
| B. Ventilation system air intakes | Drawing no. H-16249 shows a typical arrangement for missile protection of the ventilation system air intakes, specifically illustrating the main control room ventilation air intake tornado missile protection system. This system for tornado missile protection is provided for the main control room ventilation system air intake, the reactor building ventilation system air intake, and the refueling area ventilation system air intake. With the exception of the diesel generator building combined ventilation and combustion air intakes discussed in item D, all other ventilation air intakes do not form a part of essential structures and are therefore not provided with tornado missile protection systems.                      |
| C. Ventilation system exhausts    | Exhaust air from the turbine building, the radwaste building, the main control room, the reactor building, and the refueling area ventilation systems is discharged through the reactor building exhaust air vent plenum. Although the reactor building exhaust air vent plenum is not a missile-proof structure, missile damage to the vent plenum would not cause penetration of any essential structure. The air discharge from the standby gas treatment system is routed from the reactor building to the main stack via underground piping. The diesel generator building exhaust air system consists of relatively low-profile, roof-mounted Seismic Category I ventilators that are protected by the diesel generator building parapet wall. |

**TABLE 3.5-4 (SHEET 2 OF 2)**

| <u>Components</u>                         | <u>Description of Protection Provided</u>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |
|-------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| D. Diesel generator combustion air intake | Drawing no. H-12619 shows the arrangement for a typical diesel generator room, battery room, switchgear room, and oil storage room. Combustion air for diesel generator operation is supplied through the corridor and then through the individual diesel generator room combustion air louvers. Tornado missile protection is provided by the corridor exterior wall immediately opposite the combustion air louvers. Drawing no. H-12320 further illustrates the general arrangement of the diesel generator building, showing that the corridor itself is protected from tornado missiles by the labyrinth at each end of the diesel generator building. |
| E. Diesel generator engine exhaust        | Each generator diesel drive exhausts through a Seismic Category I muffler located on the roof of the diesel generator building. The mufflers present a relatively low-profile target and are protected from missiles by the building roof parapet. In addition, the engine exhaust mufflers are separated from each adjacent muffler by ~ 30 ft.                                                                                                                                                                                                                                                                                                            |
| F. Vents for safety-related tanks         | <p>The following tanks are considered to be safety-related:</p> <ul style="list-style-type: none"> <li>• Diesel fuel oil day tanks.</li> <li>• Diesel fuel oil storage tanks.</li> </ul> <p>Each diesel fuel oil day tank is vented to its enclosure. Each diesel fuel oil storage tank is a buried tank and is vented to the atmosphere via a single vent pipe below grade elevation. Missile damage would be highly unlikely.</p>                                                                                                                                                                                                                         |

### **3.6 PROTECTION AGAINST DYNAMIC EFFECTS ASSOCIATED WITH THE POSTULATED RUPTURE OF PIPING**

#### **3.6.1 SYSTEMS IN WHICH DESIGN BASIS PIPING BREAKS OCCUR**

Piping breaks have been postulated in those portions of the following systems inside containment which are pressurized during normal operation and hot standby:

- Reactor recirculation.
- Main steam.
- Feedwater.
- Residual heat removal (RHR).
- Core spray (CS).
- High-pressure coolant injection (HPCI) (steam).
- Reactor core isolation cooling (RCIC) (steam).
- Reactor water cleanup (RWC).
- Main steam drainage.
- Standby liquid control (SLC).
- Vessel drain (2 in.).
- Head vent (2 in.).
- Equalizing column (1 1/2 in.) and level-sensing line to reactor pressure vessel (RPV) nozzles N11A and B.
- Recirculation drainage.

Piping breaks for systems outside containment are identified and discussed in supplement 15A.

### 3.6.2 DESIGN BASIS PIPING BREAK CRITERIA

#### 3.6.2.1 Postulated Failure Characteristics

The following types of pipe failures are postulated to occur at the corresponding locations specified in paragraph 3.6.2.2:

##### A. Circumferential Break

A circumferential break is a complete severance of a high-energy pipe, perpendicular to the pipe axis, resulting in an instantaneous release of mechanical internal pipe forces across the break. The resulting dynamic forces are assumed to separate the piping axially with at least a one-diameter lateral displacement of the ruptured piping sections except for certain break locations in the main steam, feedwater, RHR, and HPCI lines where pipe restraints were added to restrain pipe movement. The design of restraints is described in subsection 3.6.3. For analyzing the containment pressure and temperature responses as the result of postulated pipe breaks, at least one-diameter lateral displacement was assumed for all cases except the recirculation outlet nozzle breaker. For the recirculation outlet line, the penetration through the sacrificial shield was redesigned to restrict pipe movement as a result of a postulated nozzle break. Figure 3.6-1 provides a diagram of the modified penetration. The effective cross-sectional flow area of the pipe is used in the jet discharge evaluation. Movement is assumed to occur in the plane defined by piping geometry and configuration and in the direction of the jet reaction.

##### B. Longitudinal Break

A longitudinal break is an opening in a high-energy pipe wall parallel to the pipe axis without pipe severance, having a length of two inside pipe diameters and a cross-section area of one inside the pipe flow area. Dynamic forces resulting from such breaks are assumed to cause lateral pipe movement in a direction normal to the pipe axis.

#### 3.6.2.2 Location of Postulated High-Energy Piping Failures

The requirements of the pipe break criteria in a post IEB 79-14 context were reviewed utilizing the guidelines presented in the Standard Review Plan (SRP), section 3.6.2, revision 1, which was in effect at the time of the review. The guidelines presented in SRP section 3.6.2, revision 1, state that, as a result of piping reanalysis, the highest stress locations may be shifted; however, the initially determined intermediate break locations need not be changed unless one of the following conditions existed:

- (i) Maximum stress ranges or cumulative usage factors exceed the threshold levels identified in Branch Technical Position (BTP) MEB 3-1, paragraph B.1.c(1)(b) or B.1.c(1)(c).

## HNP-2-FSAR-3

- (ii) A change is required in pipe parameters such as major differences in pipe size, wall thickness, and routing.
- (iii) Breaks at the new highest stress locations are significantly apart from the original locations and result in consequences to safety-related systems requiring additional safety protection.

To determine whether intermediate break locations required reanalysis, the guidance provided in items i and ii above were utilized. Item iii would have resulted in a complete reevaluation, unless the break locations had not changed at all, which would have required a massive engineering effort. In addition, IEB 79-14 requirements were primarily invoked to reconcile the as-built systems with the design. It was not the intent of the Bulletin to repostulate the breaks and design the plant for a set of new break locations. Furthermore, the entire concept of postulating two intermediate breaks, even if the stresses in the pipe are below the threshold levels, is totally arbitrary.

It is evident and recognized in BTP MEB 3-1, section A, that pipe breaks are, at best, only a remote possibility, whether at postulated locations or otherwise. In addition, the inservice inspection requirements in effect provide reasonable assurance of the system integrity on a continued basis. Thus, the locations of postulated high-energy piping failures, as presented below, are not revised for each stress calculation revision. A safety impact review and break location changes will be done only for the following cases:

- A. The revised pipe stress or cumulative usage factor exceeds the threshold levels.
- B. There is a major change in the pipe diameter or routing.
- C. Terminal ends have changed.

The 0.1 cumulative usage factor (CUF) criterion in BTP MEB 3-1 represents a screening criterion so that a sufficient number of postulated break locations is developed. The screening criterion of 0.1 CUF is not tied to the plant operating license term as applied to the HNP-2 stress calculations.

### **3.6.2.2.1 ASME Section III, Class I Piping (Other Than Between Containment Isolation Valves)**

For the ASME Code, Section III, Class 1 piping listed in subsection 3.6.1, (except replaced recirculation, RHR, and RWC piping) pipe breaks are postulated to occur at terminal ends and at all intermediate locations throughout a piping system where the following criteria are not met (paragraph 3.6.2.2.1.1):

- A. The stress range  $S_n$  does not exceed  $2.4 S_m$ .
- B. The stress range  $S_n$  as calculated by equation 10 of Paragraph NB-3653 exceeds  $2.4 S_m$  but is  $< 3.0 S_m$ , and the cumulative usage factor is  $< 0.1$ .

- C. The stress range  $S_n$  exceeds  $3.0 S_m$ , but the stresses computed by equations 12 and 13 of subparagraph NB-3653 are  $< 2.4 S_m$  and the usage factor is  $< 0.1$ .

Where the stresses calculated for a particular run of piping between terminal ends are everywhere less than the stress limits stated above, so that all intermediate pipe break locations are considered unlikely, a minimum of two locations is chosen based on highest stress and/or usage factor.

At each postulated break location, circumferential breaks are assumed to occur in pipes larger than 1 in., and longitudinal breaks are assumed to occur in pipes 4 in. and larger, except where detailed stress analysis at a particular postulated break location demonstrates that either:

- A. The maximum stress is in the longitudinal direction and is a factor of 1.5 higher than the circumferential stress at that point on the cross-section, in which case only a circumferential break is postulated at that location.
- B. The maximum stress is in the circumferential direction and is a factor of 1.5 higher than the longitudinal stress at that point on the cross-section, in which case only a longitudinal break is postulated at that location and is oriented around the circumference at the point of maximum stress.

Longitudinal breaks are not postulated at terminal ends if the pipe does not have a longitudinal weld.

Longitudinal breaks are not postulated at intermediate locations where the criterion for a minimum number of break locations must be satisfied.

**3.6.2.2.1.1 Criteria for Break Locations in Recirculation Pipe Replacement.** The replaced recirculation, RHR, and RWC piping were all modeled and dynamically analyzed as a common piping system. The criteria used for postulating break locations are as follows:

- Terminal ends.
- Intermediate locations where the maximum stress range between any two load sets (including zero load set) according to subarticle NB-3600, ASME Code, Section III, 1980 Edition with Addenda through Winter 1981 for Service Levels A and B (including an operating basis earthquake (OBE) event transient as calculated by equation 10 of the Code and either equation 12 or 13) exceeds  $2.4 S_m$ .
- Intermediate location where the cumulative usage factor exceeds 0.1.
- If two or more intermediate locations cannot be determined by either of the two preceding criteria, a total of two intermediate locations, as a minimum, is identified based upon the highest stress calculated by equation 10.



**3.6.2.2.1.2 Criteria for Break Types.** For the replaced recirculation, RHR, and RWC piping, the following criteria have been used to determine break type:

- A. Circumferential breaks are assumed at all terminal ends and at intermediate locations identified by the criteria in paragraph 3.6.2.2.1.1.
- B. At each of the intermediate postulated break locations identified to exceed the stress and usage factor limits of the criteria in paragraph 3.6.2.2.1.1, either a circumferential or a longitudinal break or both is postulated per the following:
  - 1. Circumferential breaks are postulated at fitting joints.
  - 2. Longitudinal breaks are postulated in the center of the fitting at two diametrically opposed points (but not concurrently) located so that the reaction force is perpendicular to the plane of the piping and produces out-of-plane bending.
  - 3. Consideration shall be given to the occurrence of either a longitudinal or circumferential break. Examination of the stress state in the vicinity of the postulated break location will be used to identify the most probable type of break.
  - 4. At intermediate locations chosen to satisfy the minimum break location criteria, only the circumferential breaks are postulated.

**3.6.2.2.2 ASME Code, Section III, Class 2 and 3 Piping (Other Than Between Containment Isolation Valves)**

There is no high-energy Class 2 or 3 piping inside containment. Supplement 15A provides a discussion of high-energy lines outside containment.

**3.6.2.2.3 Piping Penetrating Containment**

All high-energy piping between containment isolation valves is ASME Code, Section III, Class 1.

Pipe breaks are not postulated in portions of high-energy piping extending from the containment penetration to the first inside and/or outside isolation valve provided the following requirements are met:

- A. The following design stress and fatigue limits are not exceeded:

For ASME Code, Section III, Class I Piping

- 1. The stress range  $S_n$  does not exceed  $2.4 S_m$ .

## HNP-2-FSAR-3

2. The stress range  $S_n$  as calculated by equation 10 in subparagraph NB-3653 exceeds  $2.4 S_m$  but is  $< 3.0 S_m$ , and the cumulative usage factor is  $< 0.1$ .
  3. The stress range  $S_n$  exceeds  $3.0 S_m$ , but the stresses computed by equations 12 and 13 of subparagraph NB-3653 are  $< 2.4 S_m$  and the usage factor is  $< 0.1$ .
- B. The pipe is anchored or restrained at the containment penetration so that the forces and moments associated with failure of piping beyond the outboard isolation valve are not transmitted through the pipe to the containment penetration or the inboard isolation valve; and the forces and moments associated with failure of piping beyond the inboard isolation valve are not transmitted through the pipe to the containment penetration or the outboard isolation valve.
- C. The extent of piping run between isolation valves is reduced to the minimum length practical.
- D. The design at points of pipe fixity; e.g., pipe anchors or welded connections at containment penetrations, do not require welding directly to the outer surface of the piping; e.g., flued integrally forged pipe fittings are acceptable designs, except where such welds are 100% volumetrically examinable in service to the maximum extent practicable without imposing design changes.

Stress analyses have been completed for ASME Class 1 piping between containment isolation valves. The results of the analyses indicate that there are no Class 1 pipes between containment isolation valves that have calculated stress levels and fatigue usage factors in excess of the limits specified.

### **3.6.2.3 Moderate-Energy Piping Failures**

- A. The remaining piping within the containment not listed in subsection 3.6.1 is considered moderate energy. Because the high-energy line breaks within containment are more severe than any crack in a moderate-energy line, cracks are not postulated in this piping.
- B. Piping cracks in moderate-energy piping systems outside containment are discussed in supplement 15A.

### 3.6.3 DESIGN LOADING COMBINATIONS

#### 3.6.3.1 Design of Pipe Whip Restraints

##### A. Design Loads

The magnitude of loads for the pipe restraint and support steel design is determined by the following formula:

$$F = K_1 K_2 PA \text{ lb}$$

where:

- $K_1$  = thrust multiplication factor for the change in momentum due to a two-phase flow. A value of 2.0 is for cold (nonflashing) water. Unless it can be justified that pipe friction, flow restriction, and capacity of available energy reservoir reduce the thrust coefficient, a magnitude of 1.26 PA will be used for steam-water mixtures or saturated water. Figure 3.6-4 from American Society of Civil Engineers (ASCE) Structural Design of Nuclear Power Plants, Volume 1, 1973, will be used for steady state subcooled water (flashing) blowdown. Feedwater, although subcooled while within its pressure boundary, will flash to a steam-water mixture as a result of a line break. This phenomenon does not immediately occur, resulting in a situation where subcooled water is being expelled from the broken pipe. This initial force, however, is only PA. The steady state condition does not occur until the subcooled water in the line is expelled and the vessel stagnation pressure is reached. The broken-ended pipe toward the vessel experiences a maximum steady thrust of 1.26 PA because of the saturated water source in the vessel. The other end of the severed pipe is subjected to the feedwater pump head. If allowed, the flow and head would increase following a line break until the pump trips on overspeed. A feedwater break within the containment, however, would isolate the main steam lines and cut steam flow to the reactor feed pump turbines. The effect of this is a reduced pump head which results in thrust forces well below those on the vessel side. This reasoning is supported by F. J. Moody, Fluid Reaction and Impingement Loads, Conference on Structural Design of Nuclear Power Plant Facilities, ASCE, Chicago, December 1973 and by BN-TOP-2, Revision 2.
- $K_2$  = dynamic load factor to account for the effects of rapidly applied load. All pipe whip restraints whose dynamic loadings include gap effects use a dynamic load factor ( $K_2$ ) of 2.0. Design adequacy is then determined by using the energy balance methods specified in BN-TOP-2, Revision 2.

## HNP-2-FSAR-3

The anchors and restraints at the flued heads which normally contact the pipe are designed in accordance with ASME Section III, Appendix F, and the American Institute of Steel Construction (AISC) and use the ultimate strength of the pipe for design loads. Normal operating loads are also considered in accordance with ASME Section III, but these loadings are minor compared to the rupture loads.

P = operating pressure.

A = pipe internal area, in<sup>2</sup>.

### B. Design Stress

Restraints and supporting steel within the elastic range are designed in accordance with the AISC code, seventh edition, using a 50% increase in code allowable stresses using forces as described in A on the preceding page. Restraints are designed using American Society of Testing Materials (ASTM) A-36 steel. The design stress limits for main steam line restraints and anchors were limited to the yield point in all cases when a 50% increase in code allowable stresses was used. Since the yield point stress was not exceeded, this approach is more conservative than imposing a maximum design strain limit not exceeding 0.5 of the ultimate uniform strain for ASTM A-36 restraint material.

Restraints which deform plastically are analyzed using the displacement techniques explained in BN-TOP-2, which require the restraint strains to be below 50% of strain of ultimate stress.

The restraints used on the recirculation system are of a low clearance design with a structural restraint frame attached to the supporting structure and high-strength carbon steel wire ropes used to restrain the pipe. The criteria used to determine the adequacy of the restraint load-carrying capacity are as follows:

- A. The permanent deformation in the carbon steel restraint frame is limited to a deflection corresponding to 0.5 ultimate uniform strain of the material. This is in compliance with the acceptance criteria.
- B. For the high-strength carbon steel wire ropes, the maximum acceptable load was 90% of the load-carrying capacity of the cable in the restraint configuration. This corresponds to a design load limited to 75% of a minimum certified load-carrying capacity of the cable in tension. To demonstrate the adequacy of such cable pipe whip restraints, a comprehensive testing program was undertaken by General Electric (GE). The test results provide sufficient verification and a basis for the use of these design criteria which are reported in detail in sections 4.3 and 5 of reference 1. The overall conclusion that can be drawn from the results of these tests is that there is sufficient conservatism in the design concept of cable-type restraints used in HNP-2 and that these restraints are effective with sufficient margins to meet all the safety design requirements.

Although not as conservative as the acceptance criteria, the estimated margin on energy capacity for the worst case loading event, it is sufficient for the conservative assumptions employed. The direct application of a strain limit for the high-strength carbon steel cables was not employed in the design of this type of restraint. In each case, an evaluation of the potential for rebound has been made based on the actual predicted thrust-time loading for the breaks postulated. These breaks are delineated in HNP-2 stress calculations, as specified in subsection 3.6.4.

For the cable restraints, it has been shown that no rebound gap actually occurs on the 12-in. riser line. This can be attributed to the very high elastic force deflection characteristics of the cables that hold the pipe (and the low stored elastic energy that results due to the steep curve).

For the recirculation suction nozzle break, these restraints have stainless steel bars replacing the original cables, and their force deflection curve is somewhat softer and a rebound gap of 0.184 in. does result. However, reimposition of the load through this clearance does not result in further strain of the restraint material because the pipe is softer and absorbs the energy.

The description of the analytical methods used to evaluate the pipe restraint and blowdown calculations is delineated in reference 1.

### **3.6.3.2 Jet Impingement Forces**

The magnitude of jet impingement forces is determined in accordance with methods indicated in BN-TOP-2, Revision 2. Jet thrust pressures at the target distance are determined by using the Moody development<sup>(2)</sup> for jet expansion, and impingement target effective areas are determined as described in BN-TOP-2, Revision 2. The resulting jet impingement force is then the calculated pressure times the effective target area.

## **3.6.4 DYNAMIC ANALYSES**

Break locations for high-energy piping in the containment are provided in HNP-2 stress calculations which were reviewed and revised (if necessary) as part of the overall pipe stress reanalysis effort performed for NRC Inspection and Enforcement Bulletin (IEB) 79-14. These HNP-2 stress calculations also provide stress intensities and usage factors for the various data points analyzed on the high-energy piping. However, the stress intensities and usage factors are not reviewed for each stress calculation revision. These values will only be updated if the stress calculation revisions define new break locations as described in paragraph 3.6.2.2.

The pipe break criteria given in subsection 3.6.2 are satisfied as described below:

### **Main Steam Piping**

Breakpoints and stress levels for the main steam piping are included in HNP-2 stress calculations. Stress intensities and usage factors are not revised for each stress calculation revision. The values will be updated only if the stress calculation revisions define new break locations as explained in paragraph 3.6.2.2. Circumferential breaks have been postulated at

terminal ends, but because the pipe is seamless, longitudinal breaks are not considered. These postulated breaks are at the vessel nozzles and at the anchor outside the primary containment, which is discussed in supplement 15A. Branch lines above 2 in. in diameter have been modeled with the steam lines and dynamically analyzed together. All stress levels are sufficiently low so as not to exceed the specified criteria in paragraph 3.6.2.2.1. Therefore, two intermediate circumferential breaks were chosen, based on the highest stress intensity and/or usage factor. The breaks at the elbows have an opening equivalent to the cross-sectional area of the 24-in. main steam line. The sweepolet breaks are considered circumferential and occur at the base. The effective opening is equivalent to a 15-in.-diameter longitudinal break in the steam line.

### Feedwater Piping

The two feedwater loops are symmetrical but located on opposite sides of the containment, and, therefore, the following discussion is limited to one side but is typical for both.

The feedwater penetrates the containment with an 18-in. diameter run which splits into two 12-in. runs. Because all piping has been modeled together in a dynamic analysis and the pipe diameters are reasonably close, the branch point is not considered a terminal end. Therefore, with the 18-in. run being anchored outside the containment, the only terminal ends in the feedwater piping inside the primary containment are at the vessel nozzles. As there are no seam welds in the piping, only circumferential breaks are postulated.

Intermediate circumferential and longitudinal breaks were chosen where the stress intensities calculated by equation 10 exceed  $3.0 S_m$  and the cumulative usage factor exceeds 0.1. These points are indicated in HNP-2 stress calculations, which also provide the stress levels and cumulative usage factors. Stress intensities and usage factors are not revised for each stress calculation revision. The values will be updated only if the stress calculation revisions define new break locations as explained in paragraph 3.6.2.2. A minimum of two breaks is postulated on each run from the vessel nozzle to the anchor outside the containment.

There are no breaks between isolation valves; because the cumulative usage factors are below 0.1, and the stress intensities calculated by equations 12 and 13 do not exceed  $2.4 S_m$ .

### HPCI Steam

The 10-in. HPCI seamless piping connection to main steam line C is considered a terminal end for the HPCI line, and thus a circumferential break is postulated. The other terminal end is at the anchor outside the containment. However, no break is assumed at this point, because it is between the containment isolation valves with the equation 10 stresses below  $2.4 S_m$ .

Two intermediate breaks were chosen, based on the highest equation 10 stress intensity and cumulative usage factor. Because neither exceeds the specified limits, only circumferential breaks are postulated. These points and the calculated stresses are indicated in HNP-2 stress calculations. Stress intensities and usage factors are not revised for each stress calculation revision. The values will be updated only if the stress calculation revisions define new break locations as explained in paragraph 3.6.2.2.

### RCIC Steam

The 4-in. RCIC seamless pipe connection to main steam line A is considered a terminal end for the RCIC line, and thus a circumferential break is postulated. As was the case with the HPCI line, the other terminal end is the anchor at the flued head outside the containment. However, no break is assumed at this point because it is between isolation valves with the equation 10 stresses below  $2.4 S_m$ .

Two intermediate breaks were chosen, based upon the highest equation 10 stress intensity and cumulative usage factor. Because neither exceeds the specified limits, only circumferential breaks are postulated. These points and the calculated stresses are indicated in HNP-2 stress calculations. Stress intensities and usage factors are not revised for each stress calculation revision. The values will be updated only if the stress calculation revisions define new break locations as explained in paragraph 3.6.2.2.

### RHR Return

The two RHR return lines inside the primary containment are symmetrical but located on opposite sides of the containment; therefore, the following discussion is limited to one side but is typical for both.

The RHR system is not used during normal plant operation. However, the drywell piping does experience reactor pressure and, therefore, is considered as high-energy. The 24-in. RHR return header has been dynamically analyzed with the 28-in. recirculation piping; therefore, the branch point is not considered to be a terminal end.

The analysis model terminates at the flued-head anchor outside the containment, but the terminal end and, thus, the circumferential break are assumed at the first normally closed valve, which is the inboard isolation check valve. Although the piping between isolation valves may become pressurized due to valve leakage, a break in this area would be inconsequential since the break is isolated from the energy source by the inboard isolation valve. The piping connected to the inboard isolation valve is seamless, and as a result, only a circumferential break is possible.

HNP-2 stress calculations specify the stress levels for this piping and indicate the postulated breakpoints for the entire model. Stress intensities and usage factors are not revised for each stress calculation revision. The values will be updated only if the stress calculation revisions define new break locations as explained in paragraph 3.6.2.2. Because usage factors are below 0.1 and equations 12 and 13 stresses do not exceed  $2.4 S_m$ , a minimum of two intermediate circumferential breaks are chosen points of highest stress. These occur on the RHR piping.

### RHR Suction

The RHR suction line is similar to the RHR return lines in that it is analyzed with the recirculation piping and is considered high energy only up to the first normally closed valve, which is the inboard isolation valve.

## HNP-2-FSAR-3

A circumferential break is postulated at this terminal end. HNP-2 stress calculations specify stress levels for the piping and indicate breakpoints for the entire model. Stress intensities and usage factors are not revised for each stress calculation revision. The values will be updated only if the stress calculation revisions define new break locations as explained in paragraph 3.6.2.2. The 20-in. RHR suction pipe was dynamically analyzed with the 28-in. recirculation piping; therefore, the branch point is not considered to be a terminal end. Stress levels do not exceed the specified criteria for postulating breaks, but a minimum of two intermediate circumferential breaks have been chosen at the points of highest stress.

### Core Spray

The two CS lines have similar stress levels and identical breakpoints. These points are indicated in HNP-2 stress calculations and consist of the following:

- A. A circumferential break at the vessel nozzle was assumed, because it is considered a terminal end. The other terminal end of the run is the first normally closed valve which, as was the case of the RHR, is the inboard isolation check valve. Because the pipe is seamless, only a circumferential break is postulated.
- B. The two intermediate breaks on these lines occur at either end of the normally open, hand-operated valve closest to the vessel. Only circumferential breaks are postulated because the stresses calculated by equations 12 and 13 are within  $2.4 S_m$ , and the cumulative usage factors are below 0.1.

Stress intensities and usage factors shown are not revised for each stress calculation revision. The values will be updated only if the stress calculation revisions define new break locations as explained in paragraph 3.6.2.2.

### RWC

HNP-2 stress calculations provide the equation 10 stresses for the RWC piping at the break locations. Stress intensities and usage factors are not revised for each stress calculation revision. The values will be updated only if the stress calculation revisions define new break locations as explained in paragraph 3.6.2.2.

The 6-in. RWC piping was dynamically analyzed with the 20-in. RHR and recirculation piping system. Since the RWC piping is small relative to the 20-in. RHR piping, the branch point (sweeplet connection) is considered to be a terminal end.

The other end of the RWC piping is at the flued-head anchor outside the containment; however, a break point was not considered at this point since the stresses calculated by equation 10 are below  $2.4 S_m$ .

A circumferential intermediate break is postulated at the elbow closest to the RHR and the inlet to the first valve, and a longitudinal break is postulated at the center of the same elbow. These breaks are postulated since the stress ratio calculated by equations 10 and 12 exceeds the  $2.4 S_m$  stress limit.



### Main Steam Condensate Drainage

The main steam condensate drainage piping in the drywell consists of 3-, 2-, 1 1/2-, and 1-in.-diameter piping. The 1-in.-diameter piping does not require evaluation in this section, and the others require only circumferential breaks since they are under 4-in. in diameter. The results of the analyses and the postulated breakpoints are summarized in HNP-2 stress calculations. Stress intensities and usage factors are not revised for each stress calculation revision. The values will be updated only if the stress calculation revisions define new break locations as explained in paragraph 3.6.2.2.

This piping was analyzed separately from the main steam piping, and there are terminal ends at the connection to the steam lines and HPCI line. There is another terminal end at the first normally closed valve, which is the inboard isolation valve. Circumferential breaks are assumed at all these points. Because the piping was analyzed together and the relative sizes are similar, no terminal ends were assumed at branch points.

All usage factors on the piping are below 0.1, and equation 10 stresses are below  $3 S_m$ . Therefore, only two intermediate circumferential breaks are postulated per run.

### SLC, Vessel Drain, Head Vent Equalizing Column, Recirculation Loop Drains, and Pipe to RPV Nozzles N11A and B

The 1 1/2- and 2-in.-diameter lines inside the containment are not restrained, because the energy associated with their whipping is unable to damage any structure or component important to safety, except for other small-bore piping, valve actuators, or electrical conduit. The routing of these lines was reviewed to ensure that they cannot be damaged by jet impingement or whip into any of the small-bore piping, valve actuators, or electrical conduit required for safe shutdown following a small-bore piping break.

The postulated break locations are indicated in HNP-2 stress calculations. Stress intensities and usage factors are not revised for each stress calculation revision. The values will be updated only if the stress calculation revisions define new break locations as explained in paragraph 3.6.2.2.

#### **3.6.4.1 Design Bases for GE Recirculation Loop Pipe Whip Restraints**

The restraint design used on this plant is of the type used on a number of GE boiling water reactor (BWR) 4 and BWR 5 product line recirculation systems. The restraint uses a moderately low-clearance design with a frame attached to a support and either high-strength carbon steel wire ropes or stainless steel bars restraining the pipe.

The analytical methods used in the design are not dissimilar to those used on Fermi II and Duane Arnold recirculation piping. They have, however, been upgraded by applying the latest force-deflection data available on wire rope and using GE's preliminary design approval (PDA) code for the dynamic analysis. Load capacities for the restraint frames were developed by using the SAP code (a finite element structural analysis program), and were confirmed by a test series using slowly applied loading methods to determine restraint load-deflection data in the

tangential direction, that is, parallel to the restraint base. (Refer to section 5, reference 1 for test results.) The criteria used to determine the adequacy of the restraint load-carrying capacity are as follows:

- A. For the high-strength carbon steel wire ropes, the maximum acceptable load was 90% of the load-carrying capacity of the cable in the restraint configuration. This limit takes into consideration efficiency reduction experienced when a cable is wrapped around a pipe. This means that the design load is limited to 75% of a minimum certified load-carrying capacity of the cable in tension.
- B. The permanent deformation in the carbon steel restraint frame is limited to a deflection corresponding to 0.5 ultimate uniform strain of the material. This is in compliance with the acceptance criteria.

Although not as conservative as the acceptance criteria (the estimated margin on energy capacity for the worst case loading event) it is sufficient for the conservative assumptions employed. The direct application of a strain limit for the high-strength carbon steel cables was not employed in the design of this type of restraint.

To demonstrate the adequacy of such cable pipe whip restraints, a comprehensive testing program was undertaken by GE. The test results provide sufficient verification and a basis for the use of these design criteria which are reported in detail in sections 4.3 and 5 of reference 1. The overall conclusion that can be drawn from the results of these tests is that there is sufficient conservatism in the design concept of cable-type restraints used in HNP-2 and that these restraints are effective with sufficient margins to meet all the safety design requirements.

Reference 1 delineates restraint loads, configuration, and deflections pertinent to the HNP-2 application.

#### **3.6.4.2 Dynamic Analysis (PDA Code)**

An instantaneous circumferential or longitudinal break is the event which initiates the pipe/restraint system response. The instant the break occurs, and before any movement can take place, the broken pipe assumes the configuration shown in figure 3.6-2 (if the break is circumferential), while figure 3.6-3 is a typical configuration if the break is longitudinal. Several elements can be seen in these sketches. In either case the thrust load,  $F_t$ , is the forcing function which activates the system response. This load, which can vary with time, acts along a line perpendicular to the break area and is applied at the break.

The circumferential break pipe/restraint system will be described first because it is the simpler of the two. The break area in this system may be at the end of the pipe tail, which can be some distance from an elbow or significant change in direction. The pipe immediately upstream of the elbow is loaded as a cantilever whose point of fixity is the next elbow, the nonpiping component element such as a pump, vessel, or containment penetration. The weight of these pipes is small compared to the thrust load. Therefore, gravitational forces are neglected in the model. However, the inertial effects of these masses to the applied load cannot be neglected.

Therefore, the weight of the pipe tail and any fitting, valve, or other concentrated load which may be located within the tail is treated as a point mass applied to the end of the beam section.

The weight of the beam section is treated as a distributed load which includes the weight located between the point fixity, and the restraint is treated as an additional distributed mass. If the concentrated weight in the beam is between the restraint and the broken end, it is treated in the model as an additional point mass transferred to the end of the beam. The restraint closest to the broken end provides controlled deceleration of the pipe masses. Any other restraint along the beam section of pipe is neglected in the analysis. It may, however, be included as a guide or installed to protect against other potential breaks.

The break shown in figure 3.6-3 is a longitudinal break along the outside bend of the elbow. The model element is generally similar to those of the circumferential break. However, an additional element, the equivalent beam restraint,  $L_3$ , can be discerned in figure 3.6-3. This element shares the applied load with the beam element from the instant the break occurs.

The applied load in figure 3.6-3 has two components. The first,  $F_{BA}$ , acts parallel to the axis of the equivalent restraint beam and places it in compression. Unless the equivalent restraint beam ends in a true point of fixity, i.e., a vessel, containment penetration, etc., it would load some other combination of beams and equivalent restraint beam. The tail of the case presently being considered becomes one of the beam elements of this new system. The second component,  $F_{BB}$ , acts perpendicular to the equivalent restraint beam and to the beam. The pipe tail and beam are similar to the element previously defined for the circumferential break and will not be further discussed. The equivalent restraint beam is treated in the model as a beam spring whose force is directly opposite to the thrust load. However, its mass cannot be neglected. It is, therefore, treated along with any concentrated loads it may contain, and an additional equivalent point mass applied to the end of the beam section. The model makes two additional assumptions:

- A. The break region has no bending resistance. Therefore, it acts as a pinned connection.
- B. From assumption A, the linear displacement and velocities of the equivalent restraint beam end are equal to the total linear displacement and velocities of the end of the beam.

The model recognized the following pipe modes of response:

- A. The first mode is the free movement of the pipe system before it contacts the restraint. In this mode, the energy which is not absorbed as deformation energy of the beam in the circumferential break and of the beam and equivalent beam restraint in the longitudinal break is stored as kinetic energy of the beam system.
- B. The instant the pipe hits the restraint the system passes from the first response mode to the second response mode. This is the most complex mathematical model because the multilink response of the system required a Lagrangian transform solution for the acceleration of the various components of the system. In this mode the independent variable is a small time step interval. During this

interval the thrust force, restraint forces, and pipe bending resisting moments are considered constant. The accelerations, velocities, and displacements at the broken end of the pipe are computed. Then the displacement at the restraint is compared to its value during the previous time interval. If the current value is less than its previous value, it is assumed that the restraint has reached its maximum displacement and stopped. Therefore, the third mode of response is analyzed. If the current value of the restraint displacement is greater than its value in the previous time interval, the relative magnitude of the displacement of the end of the pipe is checked. If the current displacement of the free end of the pipe, relative to the bound section, is less than its value in the previous time interval, it is assumed that the free end has reached its maximum relative displacement. Therefore, the fourth mode of response is analyzed.

If the current free beam displacement relative to the bound beam displacement is greater than its previous value, new values of the forces and moments are calculated. Then the process is repeated for the next time interval.

- C. In the third mode, the restraint and bound end of the pipe have stopped but the free end is still in motion. In this mode the independent variable is a small displacement step. During each displacement step the forces and moments of the various load elements are computed, then the energy balance is computed and checked to assure that the kinetic energy is positive. If it is positive, the velocities and displacement time interval are calculated and the process is repeated for the next displacement interval. If the kinetic energy is zero or negative, it is assumed that the free end is stopped.
- D. In the fourth mode, the motion of the free end of the beam relative to the bound end is zero. The independent variable is a small displacement and the computation sequence is the same as in mode C.
- E. The fifth mode, mode E, is the steady state response. The model compares the steady state load to the maximum allowable restraint load. A comparison is also made of the allowable restraint deflection to the actual restraint deflection. If the actual load and deflection are less than the maximum allowable, the requirements have been satisfied.

#### **3.6.4.3 Bechtel-Designed Restraints**

Restraints designed not to contact the pipe normally are designed according to the procedures outlined in BN-TOP-2, Revision 2. A circumferential or longitudinal break with a thrust force equal to  $K_1PA$ , as explained in paragraph 3.6.3.1, is assumed in the analysis. The thrust force is assumed constant with no rise time and is radially applied to the restraint as a concentrated load. Alternatively, nonlinear dynamic time-history analyses are performed.

Whip restraints at the flued heads are designed according to ASME Section III, Appendix F, and the AISC.

### 3.6.5 PROTECTIVE MEASURES

#### 3.6.5.1 Pipe Restraints

The locations of pipe whip restraints for systems containing high-energy piping are identified on plant drawings controlled by the HNP configuration control management program. Additional information on whip restraint design in the main steam, feedwater, and reactor recirculation systems are as follows:

##### A. Reactor Recirculation System

The recirculation system piping loops are restrained against pipe movement in the event of a pipe break. Both circumferential and longitudinal-type pipe breaks are considered in the design of pipe restraints. The pipe breaks are assumed to occur anywhere in the system. The restraints are located and spaced, in accordance with the criteria of reference 1, so as to protect the primary containment pressure boundary, to assure that the design basis accident pipe break area is not exceeded, and to assure sufficient emergency core cooling capability for safe shutdown of the reactor.

##### B. Main Steam and Feedwater

A feasibility study was made to provide as many pipe restraints as possible on main steam and feedwater lines inside the drywell. The results of this study showed that these lines can be restrained only partially due to space and structural limitations.

Specifically, restraints are provided on the vertical risers of the main steam and feedwater lines where the sacrificial shield wall is available for anchoring of the restraints. These restraints serve to protect the CS injection lines from a rupture of the main steam lines and to protect the containment shell from a rupture of a main steam or feedwater line in this area. A typical restraint for main steam and feedwater is shown on drawing no. H-29026.

#### 3.6.5.2 Protective Barriers

Circumferential pipe breaks at weld joints in all unrestrained pipes inside the drywell larger than 1 in. and forming a part of the reactor coolant pressure boundary were studied and their effects on the drywell were determined. All drywell areas where the broken pipe is postulated to contact the primary containment pressure boundary were then analyzed to determine if the broken pipe had sufficient energy to rupture the primary containment. Areas where the possibility of the primary containment rupture exists are then protected by providing barriers consisting of steel plates welded directly to the drywell.

The primary containment shell and the containment spray headers have been designed to withstand the jet forces resulting from a break in the largest pipe inside the containment.

Stiffened steel barriers mounted on a structural steel frame between redundant divisions of the plant service water (PSW) system pump motors provide protection from jet impingement on the PSW pump motors due to a critical crack in the PSW line.

### **3.6.5.3 Physical Separation**

Essential equipment within the primary containment including components of the engineered safety features has been located so as to mitigate the consequences of blowdown jet forces and pipe whip.

The equipment associated with engineered safety systems such as the CS and the low-pressure coolant injection (LPCI) are segregated in such a manner that the failure of one cannot cause the failure of the other. CS lines enter at the upper cylindrical portion of the drywell whereas the equipment associated with the LPCI is located in the lower spherical portion of the drywell. Also, components of the various redundant engineered safety systems are physically separated so that any single failure in one system will not jeopardize the functioning of the other redundant system. The two CS injection lines are 180 degrees apart. The two LPCI injection lines are 29 ft 4 in. apart at the closest point.

The four nonautomatic depressurization system safety relief valves are designated as low-low set (LLS) valves and are required to function to mitigate the consequences of a small- or intermediate-break accident inside the drywell. Each of the four LLS valves, together with its air supply (pipe, accumulator, check valve, flex hose, etc.) and its power and control cables, constitutes one target. An evaluation assured that no postulated break, which is < 10 in. in diameter, can disable more than one LLS valve.


All the main steam lines are designed Seismic Category I out to the turbine stop valves. As indicated in HNP-2 stress calculations performed in response to NRC IEB 79-14 requirements (subsection 3.6.4), the only postulated breakpoint in that run of main steam piping located in close proximity to the cable spreading room and the switchgear room is breakpoint 888E. As stated in subsection 15A.3.2.D, the only equipment or instrumentation located in the turbine building proper which would obviate the ability to shut down the reactor safely from a main steam line high-energy line failure are cables routed in conduits which are protected by a steel barrier. Due to the configuration of the pipe and the location of the breakpoint (888E), the main steam pipe whip was evaluated and it was determined that the line will not whip into either the wall of the cable spreading room or the switchgear room.

Separation is provided between the safety relief valves and the associated pneumatic supply header and cables on one side of the drywell, the same for safety relief valves on the opposite side of the drywell, and the inboard RHR shutdown cooling valve and associated cables. No high-energy line break smaller than three safety relief valve port areas can damage more than one of the above targets at a time. If a single, active failure disables a second of the above targets, one path still remains available for long-term shutdown cooling of the reactor.

## HNP-2-FSAR-3

### REFERENCES

1. Sargent, K. G., et al, "Design Report Recirculation System Pipe Whip Restraint for the BWR-4, 218-251 Mark I and Mark II Product Line Plant," Report 22A4046, General Electric Company, June 1974.
2. Moody, F. J., Fluid Reaction and Impingement Loads, Conference on Structural Design of Nuclear Power Plant Facilities, ASCE, Chicago, December 1973.
3. "Recirculation Piping System Design Report," 25A5746, Revision 0, and 25A5747, Revision 0, General Electric Company.
4. "Recirculation, RHR, and RWC Pipe Break Postulation," 23A1951, Revision 1, General Electric Company, August 17, 1984.



ACAD

REV 19 7/01





SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

RECIRCULATION OUTLET  
NOZZLE CONFIGURATION

FIGURE 3.6-1





ACAD



REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

RECIRCULATION SYSTEM  
CIRCUMFERENTIAL BREAK MODEL  
FOR GE-DESIGNED RESTRAINTS

FIGURE 3.6-2



ACAD



REV 19 7/01



**SOUTHERN NUCLEAR OPERATING COMPANY**  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

RECIRCULATION SYSTEM  
LONGITUDINAL BREAK MODEL  
FOR GE-DESIGNED RESTRAINTS

FIGURE 3.6-3



ACAD

REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

STEADY BLOWDOWN FORCE

FIGURE 3.6-4

## **SUPPLEMENT 3.7A**

### **SEISMIC DESIGN**

Supplements 3.7A and 3.7B describe the seismic design requirements used to determine the seismic adequacy of mechanical and electrical equipment including cable and conduit raceway systems. The criteria for verifying the seismic adequacy of equipment in a general manner or for specific equipment applications remain valid and may continue to be used as described. However, as an alternative, the methodology based on earthquake experience data developed by the Seismic Qualification Utility Group and documented in the Generic Implementation Procedure (GIP), Revision 2, plus any addition to the GIP reviewed and accepted by the NRC, for resolving Unresolved Safety Issue A-46 in response to NRC Generic Letter 87-02 may be used to verify the seismic adequacy of currently installed equipment after the equipment has been walked down and any outliers resolved, as well as new and replacement mechanical and electrical equipment within the scope of the GIP. This alternative method of verifying the seismic adequacy of equipment used for modifications and replacement equipment assemblies, subassemblies, and devices that are a part of the assemblies is acceptable where no specific NRC commitment to use IEEE 344-1975 was made.

This section describes the seismic design requirements and methods used for Hatch Nuclear Plant-Unit 2 (HNP-2), and the seismic design and analysis of nonnuclear steam supply system equipment. Non-NSSS Seismic Category I equipment installed at HNP-2 was seismically qualified in accordance with either IEEE 344-1971, as amended by this supplement and supplement 3.7A.A, or IEEE 344-1975. In addition, the qualification of some non-NSSS equipment was established using the SQUG criteria discussed above. Seismic design of nuclear steam supply system (NSSS) equipment is described in supplement 3.7B.

In response to Generic Letter (GL) 87-02, Supplement 1, Edwin I. Hatch Nuclear Plant submitted a USI A-46 summary report as a response to the NRC request for information per 10 CFR 50.54(f). The GIP, Revision 2 and the staff's Supplemental Safety Evaluation Report No. 2 for resolution of USI A-46 formed the basis for developing the Plant Hatch response. The NRC's safety evaluation of the Plant Hatch A-46 program, dated September 24, 1998, concluded Plant Hatch had adequately addressed the purpose of the 10 CFR 50.54(f) request for information and had provided sufficient basis to close the USI A-46 review at the facility.

#### **3.7A.1 SEISMIC INPUT**

The two types of seismic inputs used in the seismic analyses were the ground design spectra and the associated synthetic accelerogram.

##### **3.7A.1.1 DESIGN RESPONSE SPECTRA**

Ground design spectra were established through extensive investigations on the geological conditions of the plant site and past seismological history of the neighborhood areas. The details of these investigations and the resulting recommendations are presented in section 2.5.

The recommendations were given in the form of maximum horizontal acceleration values of the ground, 0.08 g and 0.15 g for operating basis earthquake (OBE) and design basis earthquake (DBE), respectively. The modified Newmark design spectra associated with these acceleration levels were adopted and are shown in figures 3.7A-1 and 3.7A-2. They are characterized by a maximum amplification factor of 3.5 for 2% of critical damping and no amplification for frequencies beyond 30 Hz.

### **3.7A.1.2 SYNTHETIC TIME HISTORIES**

#### **3.7A.1.2.1 Modified TAFT Time History**

The synthetic acceleration time history shown in figure 3.7A-3 was developed for use as input to the time history analyses that resulted in the generation of the floor response spectra (FRS) used to seismically qualify subsystems until April 4, 1985.

In developing this synthetic accelerogram, the first 20 s of the TAFT 1952 horizontal earthquake component was selected as the input motion. It was then modified using spectrum suppressing and spectrum raising techniques<sup>(1)</sup> such that its response spectra enveloped the corresponding design spectra at all but a few frequencies. At the few points where the design spectra were not enveloped, the calculated response spectra were within 10% of the design spectra. Figures 3.7A-4 and 3.7A-5 show comparisons of response spectra for the modified TAFT earthquake time history with the ground design spectra.

The spectra of the time history were computed at the following 71 frequencies (in Hz):

0.2 . . . (increment = 0.1 Hz) . . . 3.0, 3.15, 3.3, 3.45, 3.6, 3.8, 4.0, 4.2, 4.4, 4.7, 5.0, 5.25, 5.5, 5.75, 6.0, 6.25, 6.5, 6.75, 7.0, 7.3, 7.6, 8.0, 8.5, 9.0, 9.5, 10.0, 10.5, 11.0, 11.5, 12.0, 12.5, 13.0, 13.5, 14.0, 14.5, 15.0, 16.5, 18.0, 20.0, 22.0, 25.0, 28.0, and 33.0.

These frequencies were chosen so that most of the increments do not exceed 5% within the range of 1 to 15 Hz.

#### **3.7A.1.2.2 Synthetic Time Histories (1984)**

A review was performed in 1984 to address the FSAR peak-broadening requirements for FRS, and it was concluded that no significant safety issue exists with the subsystems that were seismically qualified using the existing FRS. As a part of the review, two updated (1984) acceleration time histories were developed for use in generating new FRS. The two time histories developed (one for use in OBE analyses and one for use in DBE analyses) are shown in figures 3.7A-18 and 3.7A-19. Figure 3.7A-20 presents a plot comparing the 3% damped spectrum for the OBE time history with the corresponding design spectrum. Similarly, figure 3.7A-21 presents a plot comparing the 5% damped response spectrum for the DBE time history with the corresponding design spectrum. The calculated spectra shown in both figures were computed at the 71 frequencies defined in paragraph 3.7A.1.2.1. Comparison of these two figures with the corresponding figures for the original time history (i.e., figures 3.7A-4 and

3.7A-5) demonstrates that the two updated time histories provide a more realistic representation of the design response spectra than does the original time history discussed in paragraph 3.7A.1.2.1.

The new (1984) FRS were developed during the seismic review to reflect the as-built conditions of the structures and to provide a more realistic representation of the specified seismic design environment. These new spectra, which were developed using the updated time histories in conjunction with the applicable methodology defined in the balance of this section, are used, as of April 4, 1985, to seismically qualify subsystems.

### **3.7A.1.3 DAMPING VALUES**

Energy dissipation in structures is generally represented by equivalent viscous damping. Evaluation of damping coefficients is based on the material, the predicted stress and strain level, and the type of connections used in the structural system. Table 3.7A-1 summarizes the damping values used in the seismic analyses. The values listed for structures, assemblies, and piping were adopted from Newmark's paper.<sup>(2)</sup> As noted in table 3.7A-1, in lieu of using the soil damping values presented in the table, the equations in table 3.7A-2 could be used to calculate the soil damping coefficients. As of April 4, 1985, damping per figures 3.7A-22 and 3.7A-23 for piping systems and cable tray supports, respectively, is used for all new and replacement systems and load reconciliation work.

### **3.7A.1.4 BASES FOR SITE DEPENDENT ANALYSIS**

Site dependent analysis is not used. Subsection 2.5.2 describes the bases for specifying the vibratory ground motion for design use.

### **3.7A.1.5 SOIL-SUPPORTED SEISMIC CATEGORY I STRUCTURES**

Except for the main stack, which is supported on piles, the Seismic Category I structures are supported on soil. The soil underlying the structures extends to a depth of at least 4000 ft before bedrock is encountered.

### **3.7A.1.6 SOIL-STRUCTURE INTERACTION**

The lumped representation and equivalent soil springs and dampers were used to account for soil-structure interaction in the mathematical model for all Seismic Category I structures. The lumped representation is derived from analyzing a model composed of a rigid plate resting on the surface of an elastic half-space. The resulting foundation compliance is frequency dependent but can be approximated by a constant compliance for engineering application.<sup>(3)</sup> The foundation compliance is a function of the mass and dimensions of the foundation mat and the properties of the foundation medium. As a mechanical analog this compliance function can be represented by equivalent springs and dampers. Expressions for the equivalent soil spring

constants used in the seismic analyses are defined in table 3.7A-2. The soil-damping values used are described in subsection 3.7A.1.3.

### **3.7A.2 SEISMIC SYSTEM ANALYSIS**

#### **3.7A.2.1 SEISMIC ANALYSIS METHODS**

Response of Seismic Category I structures, systems, and components was determined analytically using the methods described in the following sections. Where the analytical method of analysis cannot ensure the functional integrity of a structure, system, or component, dynamic testing was employed. The procedures of dynamic testing are described in paragraph 3.7A.2.1.2.

##### **3.7A.2.1.1 Modal Superposition**

The method of modal superposition was used for the seismic analysis of all Seismic Category I structures, systems, and components. The mathematical model of each of the structures, systems, and components consists of lumped masses and weightless members and was represented by natural frequencies and the associated natural modes. A typical modal equation is given as follows:

$$\ddot{q}_j + 2\beta_j\omega_j\dot{q}_j + \omega_j^2q_j = -\Gamma_j\ddot{u} \quad (1)$$

where:

$q_j$  = jth displacement coordinate.

$\omega_j$  = jth circular natural frequency.

$\beta_j$  = jth modal damping ratio.

$\Gamma_j$  = jth modal participation factor.

$\ddot{u}$  = base motion expressed in terms of acceleration.

For engineering purposes, all those modes with frequencies lower than 33 Hz were considered in the analysis. The mathematical models of the Seismic Category I structures are shown in figures 3.7A-8 through 3.7A-17.

Depending on the form of earthquake inputs and the information required, two different techniques, response spectrum technique and time-history analysis, were engaged in the computation.

A. Response Spectrum Technique

With the input given in terms of design spectra, the modal displacement response is determined by:

$$q_{j,max} = \Gamma_j(SA)_j / \omega_j^2 \quad (2)$$

where:

(SA) = the value of spectral acceleration at the frequency  $f_j (f_j = \omega_j / 2\pi)$  and for damping  $\beta_j$ . The displacement response per mode at any mass point,  $i$ , is:

$$\chi_{ij,max} = \phi_{ij} q_{j,max}$$

where:  $\phi_{ij}$  = modal coordinate

Other structural response quantities per mode, such as shears and moments, can be obtained from  $\chi_{ij,max}$  by making use of the stiffness properties of the structural members.

With the modal responses determined, the total response is computed according to the criterion of "the square root of the sum of the squares (SRSSs) of individual modal responses." When modes are closely spaced, they are first divided into groups such that in each group the deviation in frequency between the first and the last modes does not exceed 10% of the lower frequency. The criterion of "the sum of absolute values" is then applied to each group and the results from all the groups and the remaining modal responses are combined according to the criterion of SRSSs.

B. Time History Analysis

With the input given in the form of an acceleration time-history, the modal responses are evaluated by a step-by-step integration process using equation 1. The total response of interest is then determined by directly superimposing the modal responses in the time domain.

**3.7A.2.1.2 Testing Procedures**

For certain Seismic Category I equipment and components where dynamic testing was required to demonstrate functional integrity during and after specified seismic conditions, one of the following approaches was used to satisfy the requirements:



- A. Performance data of equipment which, under the specified conditions, were subjected to equal or greater dynamic loads than those to be experienced under the specified seismic conditions.
- B. Test data from previously tested comparable equipment which, under similar conditions, were subjected to equal or greater dynamic loads than those specified.
- C. Actual dynamic testing was in accordance with subsection 3.7A.A.3.2.
- D. Alternate test procedures that satisfied the requirements are specified in subsection 3.7A.A.3.2.

### **3.7A.2.2 NATURAL FREQUENCIES AND RESPONSE LOADS**

Table 3.7A-3 presents the first five frequencies for Seismic Category I structures. In addition, the SRSSs response loads for the reactor building are also presented. The mathematical models of the major Seismic Category I structures whose natural frequencies appear in table 3.7A-3 are shown in figures 3.7A-8 through 3.7A-17.

For Seismic Category I structures, the response spectra for different damping values were generated at all mass points in the mathematical model on which the equipment is supported.

### **3.7A.2.3 PROCEDURES USED TO LUMP MASSES**

A structure is modeled as a discrete mass system by lumping the mass of the structure, equipment, and components at various locations of high-mass concentration such as floors and/or locations of Seismic Category I equipment. In general, the weight of any one member together with the loads acting on it were equally lumped at two adjacent points where the member was connected. An equipment, component, or system was usually lumped into the supporting structure mass if its estimated weight was less than one-tenth that of the supporting mass; otherwise, the equipment, component, or system would be itself a mass point. In any case, the number of lumped masses was at least twice the number of the highest mode used in the analysis unless the seismic behavior of the structure was adequately described using a lesser number.

### **3.7A.2.4 ROCKING AND TRANSLATIONAL RESPONSE SUMMARY**

A lumped representation to account for the soil-structure interaction effect was assumed for all Seismic Category I structures and is described in subsection 3.7A.1.6.

### **3.7A.2.5 METHODS USED TO COUPLE SOIL WITH SEISMIC-SYSTEM STRUCTURES**

Finite element analyses were not used for HNP-2.

### **3.7A.2.6 DEVELOPMENT OF FLOOR RESPONSE SPECTRA**

The multi-mass time history method was used to develop the FRS. The spectra were generated at various floors or other locations of concern based on the time history motions obtained from the time history analysis of the structures as described in paragraph 3.7A.2.1.1B. The spectra were calculated at the structural frequencies as well as at additional selected frequencies such that the frequency interval between consecutive frequencies typically did not exceed 10% and in no case exceeded 13% of the lower frequency for the frequency range from 1 to 22 Hz. For example, the 1984 spectra were calculated at the following 124 frequencies (Hz) in addition to the structural frequencies:

0.1, 0.15, . . . (increments = 0.05 Hz) . . . 1.0, 1.1, (increments = 0.1 Hz) . . . 10.0, 11.0, 12.0, . . . (increments = 1.0 Hz) . . . 25.0.

### **3.7A.2.7 DIFFERENTIAL SEISMIC MOVEMENT OF INTERCONNECTED COMPONENTS**

The method of analysis discussed in paragraph 3.7A.2.1.1A was used to compute stresses for any interconnected components between floors. The input floor response spectrum is the envelope of the spectra for the floors to which the components are connected.

### **3.7A.2.8 EFFECTS OF VARIATIONS ON FLOOR RESPONSE SPECTRA**

To account for the effect of possible variations in structural frequencies and subsequently the FRS due to the uncertainties in the material properties of the structure and soil, the computed FRS were smoothed, and peaks associated with the structural frequencies were widened by  $\pm 10\%$ .

### **3.7A.2.9 USE OF CONSTANT VERTICAL LOAD FACTORS**

No constant vertical load factors were used for Seismic Category I structures. The same method of analysis described in subsection 3.7A.2.1 was also used for the vertical direction. Two-thirds of the horizontal ground spectrum and the horizontal modified accelerogram were used as the minimum vertical input for analysis.

### **3.7A.2.10 METHODS USED TO ACCOUNT FOR TORSIONAL EFFECTS**

For those Seismic Category I structures which are nearly symmetric and have torsional frequencies much higher than the corresponding translational frequencies, the slight eccentricity between the center of mass and rigidity is unlikely to cause any significant effect on the total response. Therefore, the torsional coupling was neglected in the mathematical model of these structures. Static torsional moments were computed, however, to ensure the adequacy of the design.

For those Seismic Category I structures and components which are unsymmetric in nature, including all Class 1 piping systems, torsional coupling was included in the multimass model for computing coupled dynamic response.

### 3.7A.2.11 COMPARISON OF RESPONSES

Table 3.7A-4 shows the comparison of responses at selected points in the Seismic Category I structures.

### 3.7A.2.12 METHODS FOR SEISMIC ANALYSIS OF DAMS

Dams were not constructed to impound bodies of water to serve as heat sinks.

### 3.7A.2.13 METHODS TO DETERMINE SEISMIC CATEGORY I STRUCTURE OVERTURNING MOMENT

The overturning moments of the Seismic Category I structures were calculated by the response spectrum method. The stability of the structures is checked by combining the overturning moment, dead load of the structure, and vertical acceleration. The soil reaction under the containment is obtained by considering the linear stress distribution under a rigid base mat subjected to the worst combined effects of overturning moment, dead load, and vertical acceleration.

### 3.7A.2.14 ANALYSIS PROCEDURE FOR DAMPING

For structures composed of major subsystems that are made of different materials, the composite modal damping was computed using either the mass proportional, stiffness proportional, modal weighting, or Tsai method. A description of the mass proportional method is illustrated below; the first step involves the formation of the following matrix:

$$[C] = [\phi]^T [\beta] [M] [\phi] \quad (3)$$

where:

$[\phi]$  = the modal matrix.

$[M]$  = the mass matrix.

$[\beta]$  = a diagonal matrix made up of the damping value specified for the subsystems.

The composite damping is then obtained from [C] by using the diagonal terms after they are divided by the generalized mass of the corresponding mode where the generalized mass is defined by  $\bar{M}_j$  as follows:

$$[\bar{M}_j] = [\phi]^T [M] [\phi] \quad (4)$$

### **3.7A.3 SEISMIC SUBSYSTEM ANALYSIS**

#### **3.7A.3.1 DETERMINATION OF NUMBER OF EARTHQUAKE CYCLES**

##### **3.7A.3.1.1 Seismic Category I Structures**

The number of maximum amplitude cycles is not a consideration for Seismic Category I structures.

##### **3.7A.3.1.2 Piping and Other Systems and Components**

During the 20- to 30-s duration of an earthquake event, strong motion is typically experienced for 4 to 6 s. Frequencies of vibration for which the response is significant are mostly in the range from 1 to 20 Hz with the highest responses occurring within a more narrow range, usually 3 to 8 Hz. One DBE and two OBEs are considered in the design.

The number of cycles for the DBE then can be estimated by multiplying 20 Hz by 6 s by one earthquake which yields 120 cycles. Similarly, the number of cycles for the OBE can be estimated by multiplying 20 Hz by 6 s by two earthquakes which yields 240 cycles. To be conservative, the following total number of loading cycles were used in the design:

- DBE - 300 cycles.
- OBE - 600 cycles.

##### **3.7A.3.2 BASIS FOR SELECTION OF FORCING FREQUENCIES**

The methods used to analyze subsystems for dynamic loadings can be either the time history method or the response-spectrum technique. In general, these loadings are in the form of acceleration, velocity, or displacement time histories, or they may be in the form of FRS.

In both of these methods of describing the seismic environment, the structural amplifications are reflected. Therefore, when these loads are used as inputs to the subsystems, each mode responds according to the amplification that was predetermined in the time history analysis of the supporting structure.

It is considered good practice to avoid the regions of load amplification with any system being designed. This is easily identified by observing the frequencies of all predominant modes which lie near the region of spectral amplification; however, it is sometimes found to be impractical or impossible. In these cases, the subsystem is analyzed and designed for the amplified loadings.

### **3.7A.3.3 ROOT MEAN SQUARE BASIS**

The term "root mean square basis" is not used in describing the procedure for the combination of modal responses for HNP-2.

### **3.7A.3.4 PROCEDURES FOR COMBINING MODAL RESPONSES**

The discussion of the procedures for combining modal responses is referred to in paragraph 3.7A.2.1.1A.

### **3.7A.3.5 SIGNIFICANT DYNAMIC RESPONSE MODES**

IEEE 344-1971, as amended by supplement 3.7A.A, and IEEE 344-1975 describe the analysis techniques to be used if the peak of the spectra is used by equipment suppliers. The design and analysis of instrumentation and electrical equipment are described in section 3.10.

### **3.7A.3.6 DESIGN CRITERIA AND ANALYTICAL PROCEDURES FOR PIPING**

Piping systems are anchored and restrained to floors and walls of buildings. The relative seismic displacements between buildings, between floors in buildings, and between major components are applied to the piping, anchors, and restraints in a rational and conservative manner. Seismic movements are always considered to be out of phase between independent structures so that maximum relative displacements are used. The resulting stresses are classified as secondary and are combined with other secondary stresses. The sum of secondary stresses is held within the limits of the applicable piping code.

The seismic inputs to the original OBE and DBE piping systems analyses were defined using the 0.5% and 1.0% damped FRS, respectively. As of April 4, 1985, damping per figure 3.7A-22 is used in response spectrum analyses performed for all new and replacement systems and load reconciliation work. If as a result of using these damping values, piping supports are removed, modified or eliminated, the expected increased piping displacements due to greater piping flexibility will be checked to assure that they can be accommodated and that there will be no adverse interaction with adjacent structures, components, and equipment. The damping criteria established by this figure are consistent with the frequency-dependent approach established by the Pressure Vessel Research Council Technical Committee on Piping Systems.<sup>(5)</sup>

### **3.7A.3.7 BASES FOR COMPUTING COMBINED RESPONSE**

The basis for combining the modal responses, i.e., displacements, effective inertia forces and accelerations, internal forces and moments, and support reactions, is the SRSS method. To obtain conservative results, the three directional (one vertical and two horizontal) responses obtained by the modal combination of each direction are combined by the SRSSs method, or by the absolute sum of the worst horizontal with the vertical.

Having the total internal moments computed by either of the above procedures, stresses were then calculated and combined with the stresses due to other loadings. The combined stresses are held within the stress limits of the applicable code.

### **3.7A.3.8 AMPLIFIED SEISMIC RESPONSES**

A constant vertical load factor is not used for seismic design of Seismic Category I structures, components, or equipment.

### **3.7A.3.9 USE OF SIMPLIFIED DYNAMIC ANALYSIS**

Simplified dynamic analysis is not used for Seismic Category I structures and is normally applied to field-routed, 2-in. and under piping and some subsystems.

To perform a simplified dynamic analysis on a system, it must have a first mode natural frequency in the rigid range of the response spectrum. The rigid range of the response spectrum curve is defined as that portion in which there is no significant change in spectral acceleration with increasing frequencies. (See point "A" on figure 3.7A-6.) If piping is supported and restrained so that the first mode of vibration occurs in this range, it is classified as rigid.

Rigid piping systems are analyzed with static equivalent loads corresponding to the acceleration in the rigid range of the response spectrum curves for the applicable floor elevations. Both horizontal and vertical static equivalent loads are applied to the rigid piping systems. The response of the component for two horizontal and one vertical direction is combined on a SRSSs basis. The stresses are then computed in accordance with American Society for Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section III, Nuclear Power Plant Components, including 1971 Winter Addenda. The rigid range is dependent on building response and as such is determined on a case basis. The rigid range of floor spectrum typically begins at ~ 20 Hz.

Classification of a specific piping system may be made in either of the following ways:

- A. Restraints are located such that no span between rigid restraints exceeds the length of a simple support beam with a rigid range frequency. In addition, restraints are located at changes in direction, concentrated masses, and extended masses.

- B. A dynamic analysis is run to obtain the mode shapes of the piping system. If the first mode frequency is found to be in the rigid range, the system can be assumed rigid.

A summary of typical results comparing the simplified dynamic methods and the response spectrum modal analysis method is contained in Appendix D of BP-TOP-1, Revision 1.<sup>(4)</sup>

When piping is analyzed by simplified methods all supports and components attached to the piping are required to be in the rigid range so that no amplification of seismic motion exists.

### **3.7A.3.10 MODAL PERIOD VARIATION**

The procedures used to account for modal period variation in models of Seismic Category I structures are discussed in subsection 3.7A.2.8.

### **3.7A.3.11 TORSIONAL EFFECTS OF ECCENTRIC PIPING**

The seismic mass model accounts for the effect of masses that are offset from the pipe centerline. Components with eccentric masses are modeled by placing the component's mass at the component's calculated center of gravity and connecting this mass to the pipe centerline with a rigid connection thereby accounting for its torsional effects.

### **3.7A.3.12 PIPING OUTSIDE CONTAINMENT**

Applicable subsections of sections 3.7A.2 and 3.7A.3 are used for design and analysis of Seismic Category I piping inside and outside containment.

The techniques and criteria used to analyze structural stresses in buried Seismic Category I piping and electrical ducts are presented in supplement 3.7A.B.

### **3.7A.3.13 INTERACTION OF OTHER PIPING WITH SEISMIC CATEGORY I PIPING**

The interface between Seismic Category I piping and non-Category I piping is always an anchor. The anchor is designed to prevent interaction between seismic and nonseismic piping under the most conservative combination of thermal, weight, and seismic loads.

### **3.7A.3.14 LOCATION OF SUPPORTS AND RESTRAINTS**

Seismic supports and restraints for Seismic Category I piping are located so that the stresses, as determined by the dynamic analysis, are less than the appropriate code allowable limits. When rigid seismic supports result in excessive thermal loads on piping or equipment, snubbers or dampers are used.

The pipe support contractors' pipe restraint locations and detailed support drawings are reviewed by pipe stress engineers to ensure that they conform to requirements. In addition, a field inspection of the pipe supports is made by stress engineers to ensure that supports have been installed properly and meet design requirements.

For 2-in. and under Seismic Category I piping, a Bechtel field installation manual is provided so that field engineers can properly design and locate pipe supports and restraints. When the field engineers have completed their designs, they are reviewed by pipe stress engineers.

### **3.7A.3.15 SEISMIC ANALYSIS FOR FUEL ELEMENTS, CONTROL ROD ASSEMBLIES, AND CONTROL ROD DRIVES**

The seismic analysis for fuel elements, control rod assemblies, and control rod drives is discussed in paragraph 3.7B.2.1.6.3.

### **3.7A.3.16 SEISMIC ANALYSIS OF CABLE TRAY SUPPORTS**

Cable tray supports are designed to withstand the calculated seismic loads using the FRS corresponding to the locations where the supports are attached. The simultaneous application of the horizontal and vertical earthquake components, which create the highest stresses, is used to design the cable tray supports. Stresses are limited to the allowables specified in paragraph 3.10.2.1.1.

In the original cable tray support analyses, the applicable damping values were established, based upon the supports' type of construction, using the values specified in table 3.7A-1. As of April 4, 1985, damping per figure 3.7A-23 is used for all new and replacement systems and load reconciliation work. The damping criteria specified in figure 3.7A-23 provide a conservative estimate of damping for cable tray supports based upon a test program.<sup>(6)</sup> As an alternative, the Seismic Qualification Utility Group (SQUG) Generic Implementation Procedure (GIP) criteria, discussed in the beginning of this supplement, may also be applied to existing, new, and replacement cable and conduit raceway systems.

## **3.7A.4 SEISMIC INSTRUMENTATION PROGRAM**

### **3.7A.4.1 COMPARISON WITH NUCLEAR REGULATORY COMMISSION GUIDE 1.12**

The seismic instrumentation program complies with the requirements of Regulatory Guide 1.12 (April 1974), with the following additional explanations:

- A. Response spectrum recorders at locations other than the containment foundation, which are required by subsection C.1.c of the Guide, are not supplied as discrete instruments. Data from these instruments is not required immediately following the earthquake and is used only in the subsequent post-earthquake



## HNP-2-FSAR-3

analysis. Time-history strong-motion accelerometers are provided at the locations specified for response-spectrum recorders.

- B. Ranges, set points, damping values, and recording times for the instruments are based on the site seismicity and estimated structural response, and satisfy the guide as far as commercial availability permits.

### 3.7A.4.2 LOCATION AND DESCRIPTION OF INSTRUMENTATION

The following instrumentation is used to measure plant response to earthquake motion:

- A. Four strong-motion triaxial time-history accelerographs are installed at appropriate locations to provide data on the frequency, amplitude, and phase relationship of the seismic response of the reactor building structure and to provide data on the seismic input to other Seismic Category I structures, systems, and components.

These accelerographs are activated on a common time base by a seismic trigger, which is shared with HNP-1, located in the free field. They are rigidly mounted and located so that they are accessible for servicing. The output from these accelerograph sensors are recorded on magnetic tape which are available for playback following an earthquake. These records are the primary means of determining the severity of any earthquake which may be experienced. A visual signal in the control room alerts the operator that a recording has been made.

1. One strong-motion accelerograph is installed in the switchyard to measure the free-field-ground acceleration. The accelerograph is used for HNP-1 also.
  2. Two strong-motion accelerographs are located in the reactor building: one on the east side of the reactor building drywell pedestal at el 87 ft and the other inside the drywell on the feedwater discharge line to the reactor pressure vessel (RPV). These two strong-motion accelerographs in the reactor building are oriented so that the three axes of the sensors on one accelerograph are pointing in the same directions as the three axes of the other accelerograph. These provide data on the frequency, amplitude, and phase relationship of the seismic response of the containment structure.
  3. One strong-motion accelerograph is installed in the diesel generator building at el 130 ft. This accelerograph is used for HNP-1 also.
- B. A magnetic tape recorder and playback system is located in the main control room and receives all the output signals from the strong-motion accelerograph from both HNP-1 and HNP-2.

### HNP-2-FSAR-3

- C. Two seismic switches are provided with a strong-motion accelerograph as described in A.2 above. The seismic switches are set to actuate at the OBE level of estimated response. These two switches annunciate in the HNP-2 main control room (MCR).
- D. Peak recording accelerometers are provided to record the actual peak response of the locations listed below. (All except items 5, 6, and 7 are shared with HNP-1.)
1. Diesel generator base support.
  2. Intake structure.
  3. Control building floor el 112 ft.
  4. Control building - main control room floor.
  5. Reactor building refueling floor.
  6. Inside biological shield on reactor pedestal.
  7. Reactor piping - feedwater discharge line to the RPV.
- E. Triaxial peak acceleration recorders are installed inside the drywell in the HNP-2 reactor building. The locations of the peak acceleration recorders are provided at known points of amplified response which permit an evaluation of the actual amplification factors to the design values.
- The triaxial acceleration recorder consists of metal plates on which scratch lengths are mechanically etched in the three axes by diamond styli as the component or structure moves. The zero reference line is established when the plates are inserted and removed. When the component or structure experiences any movement, a record of the displacement is scratched permanently on the metal plate. Normally, the maximum displacement from the zero line, regardless of direction, is recorded. The length etched on each plate is measured by placing it under a calibrated microscope. Each scratch length (displacement) is then multiplied by its acceleration sensitivity (a constant supplied by the vendor) to convert it to acceleration.
- F. One triaxial peak acceleration spectrum recording unit is provided on the HNP-1 containment foundation for measuring both horizontal motions and the vertical motion. This recording unit is used also for HNP-2 since the seismic response for HNP-2 is essentially the same as that for HNP-1. This instrument is electrically connected to an annunciator unit in the main control room to provide an alarm indicating that the specified preset response acceleration has been exceeded.

### **3.7A.4.3 MCR OPERATOR NOTIFICATION**

The strong-motion accelerographs record their signals on magnetic tape in the MCR. An audio/visual signal in the MCR alerts the operator that the recording system is in operation.

Immediately after the seismic occurrence, the output data from the sensors is processed and played back graphically in a way that makes possible a comparison with calculated design spectra of Seismic Category I structures and other components.

The two seismic switches in the reactor building are electrically connected to the annunciator for immediate indication that specific preset response accelerations have been exceeded.

MCR indication provides immediate information which could provide a basis for plant shutdown if an OBE should be exceeded. It also provides a permanent record of data for analysis of design parameters.

### **3.7A.4.4 COMPARISON OF MEASURED AND PREDICTED RESPONSES**

Plant operators are provided with seismic criteria and procedures to follow after a seismic event to determine whether the plant can continue to operate or if it must be shut down. An outline of the order of actions to be taken after a seismic event is provided in figure 3.7A-7. Evaluations of whether the ground motion has exceeded the OBE input are based on recordings from strong motion accelerographs described in subsection 3.7A.4.2.

### **3.7A.5 SEISMIC DESIGN CONTROL**

The primary design organizations involved in the seismic design of the various structures, systems, and components are General Electric Company, Bechtel Power Corporation, and Southern Company Services, Inc.

Components designed by others which fall under one of the three primary areas of responsibility are designed to the overall seismic requirements and checked by one of these organizations.

The original seismic design responsibilities are summarized below:

A. General Electric Company

The General Electric Company was responsible for design of the NSSS. This includes the reactor vessel, recirculation system, main steam line piping up to the second isolation valve, and equipment for safety-related systems.

B. Bechtel Power Corporation

The Bechtel Power Corporation was responsible for design of the containment, reactor building, main stack, parts of the turbine building, radwaste building, and associated piping for safety-related systems. In addition, Bechtel had

responsibility for reviewing seismic designs originated by Southern Company Services, Inc.

C. Southern Company Services, Inc.

Southern Company Services, Inc. had responsibility for basic design criteria and detail design responsibility for the control and diesel generator buildings and intake structure.

Subsequent to commercial operation, the responsibility for design control was changed. Primary design responsibility was assigned to Southern Company Services, Inc. Bechtel Power Corporation and General Electric Company perform designs as directed by Southern Company Services, Inc. and Georgia Power Company. Effective March 22, 1997, SNC is the exclusive operating licensee and has accepted the assignment of the primary design responsibility to Southern Company Services, Inc.

### **3.7A.5.1 GENERAL ELECTRIC-SUPPLIED EQUIPMENT AND COMPONENTS**

For General Electric-supplied equipment and components, see section 3.7B.5.

### **3.7A.5.2 BECHTEL POWER CORPORATION SPECIFIED EQUIPMENT AND COMPONENTS**

Safety-related systems, structures, and components are seismically designed and checked using design control measures within the organization. Although not specifically identified as seismic quality assurance provisions, the quality assurance provisions of chapter 17 ensure the adequacy of Seismic Category I components to perform their intended functions during and after seismic disturbance.

#### Equipment and Component Specifications

Specifications for Seismic Category I equipment incorporate a section on seismic design criteria. This section includes seismic-response spectra, generated by a time history, which were developed for the particular equipment location and a list of damping factors. This specification requires one of the following:

- Perform a seismic analysis based on the appropriate damping factor and response spectrum as well as the natural frequency of the equipment.
- If it is not practical to calculate the natural frequency of the equipment, use the maximum acceleration of the spectrum curve for the seismic analysis.
- Subject prototype equipment to a test demonstrating its ability to perform its intended function during and after seismic disturbance.

Certification that this equipment functions during and after seismic disturbance is required from each vendor. This certification may consist of calculations checked by an engineer knowledgeable in the design of such equipment or it may consist of a written certification acknowledging the equipment has successfully passed tests of forces equal to or higher than those stated in the seismic requirement and has been exposed to these severe vibration requirements. The method of analysis, calculation, or testing is reviewed and approved by the responsible engineer.

Inspection plans require that a certification of calculations be delivered with each Seismic Category I component. This is required on the applicable documentation checklist which is included in the inspection plan approved by engineering. Release for shipment is not provided without all documentation being provided.

### **3.7A.5.3 SOUTHERN COMPANY SERVICES, INC., SPECIFIED EQUIPMENT AND COMPONENTS**

#### Equipment and Component Specifications

Seismic-response spectra for each location in the plant is developed for use by the design engineer. The design engineer is responsible for including the appropriate seismic-response spectra in the equipment purchase specification in a form that is meaningful to the vendor. All purchase specifications are reviewed by engineers competent in seismic analysis and testing for verification acknowledging complete and correct seismic requirements have been included.

Vendor analyses and/or test data are submitted to the responsible design engineer as agreed upon as part of the purchase specification. The responsible design engineer agrees with the submitted material in writing only after he is satisfied that it meets the design specification requirements. Guidance and counsel of engineers competent in the applicable discipline are made available to the responsible design engineer in the course of such reviews.

The quality assurance program is described in chapter 17 and provides a description of the review and approval of purchase specifications and vendor documents by competent engineering personnel.

## HNP-2-FSAR-3

### REFERENCES

1. Tsai, N.C., "Spectrum - Compatible Motions for Design Purposes," Journal of Engineering Mechanics Division, ASCE, Vol. 98, No. EM2, April 1972.
2. Newmark, N.M., Design Criteria for Nuclear Reactors Subjected to Earthquake Hazards, Proc. IAEA Panel on Aseismic Design and Testing of Nuclear Facilities, Japan Earthquake Engineering Promotion Society, Tokyo, Japan, 1967.
3. Richart, Jr., F.E., Hall, Jr., J.R., and Woods, R.D., Vibrations of Soil and Foundations, Prentice Hall, Inc., New Jersey, 1970.
4. "Seismic Analysis Piping System," BP-TOP-1, Revision 1, February 1974.
5. "Welding Research Council Bulletin Number 300: Technical Position on Criteria Establishment; Technical Position on Damping Values for Piping-Interim Summary Report; Technical Position on Response Spectra Broadening; and Technical Position on Industry Practice," 1984.
6. Cable Tray and Conduit Raceway Seismic Test Program, Release 4, Report 1053-21.1-4, ANCO Engineers, Inc., December 15, 1978.

**TABLE 3.7A-1**  
**DAMPING FACTORS FOR SEISMIC ANALYSIS**  
**IN PERCENT OF CRITICAL DAMPING<sup>(a)</sup>**

|                                                            | <u>OBE</u> | <u>DBE</u> |
|------------------------------------------------------------|------------|------------|
| Reinforced concrete structures                             | 3.0        | 5.0        |
| Steel frame structures                                     | 3.0        | 5.0        |
| Bolted and riveted assemblies                              | 3.0        | 5.0        |
| Welded assemblies                                          | 2.0        | 3.0        |
| Vital piping                                               | 0.5        | 1.0        |
| Translation and rotation of foundation soil <sup>(b)</sup> | 4.0        | 5.0        |

a. As of April 4, 1985, damping per figures 3.7A-22 and 3.7A-23 for piping systems and cable tray supports, respectively, is used for all new and replacement systems and load reconciliation work.

b. In lieu of using the soil damping values specified in this table, the equations in table 3.7A-2 may be used to calculate soil damping coefficients.

TABLE 3.7A-2 (SHEET 1 OF 2)

FORMULAS FOR EQUIVALENT FOUNDATION SPRING CONSTANTS  
AND DAMPING COEFFICIENTS  
(RECTANGULAR BASE)

| <u>Motion</u> | <u>Equivalent Spring Constant</u>              | <u>Equivalent Damping Coefficient</u>                      |
|---------------|------------------------------------------------|------------------------------------------------------------|
| Horizontal    | $k'_x = 2(1 + \nu) G \beta_x \sqrt{BL}$        | $c'_x = 0.576 k_x R \sqrt{\rho/G}$                         |
| Rocking       | $k'_\psi = \frac{G}{1 - \nu} \beta_\psi B^2 L$ | $c'_\psi = \frac{0.30}{1 + B_\psi} k_\psi R \sqrt{\rho/G}$ |
| Vertical      | $k'_z = \frac{G}{1 - \nu} \beta_z \sqrt{BL}$   | $c'_z = 0.85 k_z R \sqrt{\rho/G}$                          |

where:

B = width of the base mat in the plane of horizontal excitation.

L = length of the base mat perpendicular to the plane of horizontal excitation.

$\nu$  = Poisson's ratio of foundation medium.

G = shear modulus of foundation medium.

$\rho$  = density of foundation medium.

R = equivalent radius of the base mat as defined below.

$\beta_x, \beta_\psi, \beta_z$  = constants that are functions of the dimensional ratio, B/L (from figure 10-16 in reference 3).


$$B_\psi = \frac{3(1 - \nu)I_o}{8\rho R^5}$$

where:

$I_o$  = total mass moment of inertia of structure and base mat about the rocking axis at the base.



TABLE 3.7A-2 (SHEET 2 OF 2)



**(EQUIVALENT RADIUS FOR RECTANGULAR BASE)**

For a rectangular base having a dimension of B x L (B = width of base in the plane of horizontal vibration), the equivalent radius, R, is taken to be the smallest of parameters,  $R_x$ ,  $R_\psi$ , and  $R_z$ , defined below:

$$R_x = \frac{(1 + \nu)(7 - 8\nu)\beta_x \sqrt{BL}}{16(1 - \nu)}$$

$$R_\psi = \sqrt[3]{3\beta_\psi B^2 L / 8}$$

$$R_z = \beta_z \sqrt{BL/4}$$

HNP-2-FSAR-3

TABLE 3.7A-3 (SHEET 1 OF 2)

SUMMARY OF FREQUENCY AND RESPONSE LOADS

|            | <u>Reactor Bldg</u>       |                            | <u>Control Bldg</u>       |                            | <u>Diesel Generator Bldg<sup>(a)</sup></u> |                            | <u>Intake Structure</u>   |                            | <u>Main Stack</u>         |                            |
|------------|---------------------------|----------------------------|---------------------------|----------------------------|--------------------------------------------|----------------------------|---------------------------|----------------------------|---------------------------|----------------------------|
|            | <u>E-W</u><br><u>(Hz)</u> | <u>Vert</u><br><u>(Hz)</u> | <u>E-W</u><br><u>(Hz)</u> | <u>Vert</u><br><u>(Hz)</u> | <u>E-W</u><br><u>(Hz)</u>                  | <u>Vert</u><br><u>(Hz)</u> | <u>E-W</u><br><u>(Hz)</u> | <u>Vert</u><br><u>(Hz)</u> | <u>E-W</u><br><u>(Hz)</u> | <u>Vert</u><br><u>(Hz)</u> |
| Freq No. 1 | 1.61                      | 6.45                       | 1.01                      | 2.37                       | 4.12                                       | 4.59                       | 7.04                      | 14.60                      | 0.60                      | 8.64                       |
| Freq No. 2 | 3.73                      | 20.41                      | 5.38                      | 9.44                       | 7.76                                       | 83.25                      | 21.13                     | 66.27                      | 2.24                      | 18.02                      |
| Freq No. 3 | 8.37                      | 26.26                      | 7.00                      | 13.71                      | 36.20                                      | NA                         | 35.32                     | 106.73                     | 4.88                      | 24.60                      |
| Freq No. 4 | 9.39                      | 29.00                      | 11.07                     | 37.87                      | NA                                         | NA                         | 44.41                     | 136.26                     | 8.14                      | 34.74                      |
| Freq No. 5 | 9.74                      | NA                         | 15.27                     | 49.11                      | NA                                         | NA                         | 53.74                     | 178.87                     | 11.66                     | 43.98                      |

a. The diesel generator building natural frequencies specified are those associated with the mean soil properties for this building.

TABLE 3.7A-3 (SHEET 2 OF 2)

REACTOR BUILDING SRSSs RESPONSES<sup>(a)</sup>

| <u>Elevation</u>               | <u>87 ft</u>       |                     | <u>130 ft</u>      |                     | <u>158 ft</u>      |                     | <u>185 ft</u>      |                     |
|--------------------------------|--------------------|---------------------|--------------------|---------------------|--------------------|---------------------|--------------------|---------------------|
|                                | <u>E-W<br/>DBE</u> | <u>Vert<br/>DBE</u> | <u>E-W<br/>DBE</u> | <u>Vert<br/>DBE</u> | <u>E-W<br/>DBE</u> | <u>Vert<br/>DBE</u> | <u>E-W<br/>DBE</u> | <u>Vert<br/>DBE</u> |
| Accel (g)                      | 0.15               | 0.10                | 0.19               | 0.10                | 0.26               | 0.11                | 0.33               | 0.12                |
| Disp (ft 10 <sup>-4</sup> )    | 48.9               | 17.4                | 99.5               | 19.3                | 146.6              | 21.4                | 190.8              | 22.6                |
| Force (kips 10 <sup>3</sup> )  | 42.1               | 16.4                | 40.3               | 15.7                | 34.2               | 12.2                | 27.5               | 9.2                 |
| Moment (K-ft 10 <sup>4</sup> ) | 414.6              | NA                  | 228.7              | NA                  | 133.5              | NA                  | 60.1               | NA                  |
| <u>Elevation</u>               | <u>203 ft</u>      |                     | <u>228 ft</u>      |                     | <u>256 ft</u>      |                     | <u>280 ft</u>      |                     |
|                                | <u>E-W<br/>DBE</u> | <u>Vert<br/>DBE</u> | <u>E-W<br/>DBE</u> | <u>Vert<br/>DBE</u> | <u>E-W<br/>DBE</u> | <u>Vert<br/>DBE</u> | <u>E-W<br/>DBE</u> | <u>Vert<br/>DBE</u> |
| Accel (g)                      | 0.38               | 0.12                | 0.45               | 0.12                | 0.60               | 0.14                | 0.67               | 0.14                |
| Disp (ft 10 <sup>-4</sup> )    | 217.2              | 23.1                | 253.6              | 23.5                | 621.4              | 25.0                | 1692.3             | 25.4                |
| Force (kips 10 <sup>3</sup> )  | 19.1               | 6.2                 | 10.2               | 3.4                 | 2.0                | 0.7                 | 1.4                | 0.3                 |
| Moment (K-ft 10 <sup>4</sup> ) | 26.9               | NA                  | 7.6                | NA                  | 3.3                | NA                  | 0.0                | NA                  |


a. These responses were not updated to reflect the 1984 analysis discussed in paragraph 3.7A.1.2.2.

**TABLE 3.7A-4**  
**COMPARISON OF RESPONSES<sup>(a)</sup>**

| Mass<br>Point                                  | Acceleration (g) |      |      |      | Displacement (ft 10 <sup>-4</sup> ) |       |      |      |
|------------------------------------------------|------------------|------|------|------|-------------------------------------|-------|------|------|
|                                                | E-W              |      | Vert |      | E-W                                 |       | Vert |      |
|                                                | SRSS             | TH   | SRSS | TH   | SRSS                                | TH    | SRSS | TH   |
| Reactor Building (OBE)                         |                  |      |      |      |                                     |       |      |      |
| 1                                              | 0.08             | 0.09 | 0.05 | 0.06 | 26.6                                | 29.3  | 9.4  | 8.8  |
| 2                                              | 0.10             | 0.12 | 0.05 | 0.06 | 54.3                                | 56.0  | 10.5 | 9.8  |
| 3                                              | 0.14             | 0.15 | 0.06 | 0.06 | 80.0                                | 80.2  | 11.6 | 10.7 |
| 4                                              | 0.18             | 0.18 | 0.06 | 0.06 | 104.2                               | 101.9 | 12.2 | 11.2 |
| 5                                              | 0.21             | 0.19 | 0.06 | 0.06 | 118.6                               | 115.9 | 12.5 | 11.5 |
| Control Building (OBE)                         |                  |      |      |      |                                     |       |      |      |
| 1                                              | 0.11             | 0.13 | 0.08 | 0.10 | 16.9                                | 20.0  | 7.2  | 9.0  |
| 2                                              | 0.16             | 0.19 | 0.09 | 0.11 | 26.8                                | 30.0  | 8.1  | 10.0 |
| 3                                              | 0.20             | 0.22 | 0.09 | 0.12 | 32.8                                | 35.0  | 8.7  | 11.0 |
| 4                                              | 0.23             | 0.24 | 0.10 | 0.12 | 37.6                                | 40.0  | 9.1  | 11.0 |
| 5                                              | 0.19             | 0.19 | 0.18 | 0.21 | 721.3                               | 770.0 | 15.7 | 19.0 |
| Diesel Generator Building (OBE) <sup>(b)</sup> |                  |      |      |      |                                     |       |      |      |
| 1                                              | 0.20             | 0.23 | 0.13 | 0.15 | 94.6                                | 110.0 | 49.9 | 58.1 |
| 2                                              | 0.21             | 0.24 | 0.13 | 0.16 | 100.7                               | 117.0 | 50.2 | 58.4 |
| Intake Structure (OBE)                         |                  |      |      |      |                                     |       |      |      |
| 1                                              | 0.06             | 0.09 | 0.06 | 0.08 | 7.0                                 | 7.0   | 2.0  | 3.0  |
| 2                                              | 0.10             | 0.12 | 0.06 | 0.08 | 15.0                                | 16.0  | 2.0  | 3.0  |
| 3                                              | 0.16             | 0.17 | 0.07 | 0.09 | 25.0                                | 26.0  | 2.0  | 3.0  |
| 4                                              | 0.23             | 0.23 | 0.07 | 0.09 | 36.0                                | 38.0  | 3.0  | 3.0  |
| 5                                              | 0.29             | 0.29 | 0.07 | 0.09 | 44.0                                | 46.0  | 3.0  | 3.0  |

a. These responses were not updated to reflect the 1984 analysis discussed in paragraph 3.7A.1.2.2

b. Responses are those associated with the mean soil properties for this building.



ACAD


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

DESIGN SPECTRUM FOR OBE

FIGURE 3.7A-1



ACAD


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

DESIGN SPECTRUM FOR DBE

FIGURE 3.7A-2



ACAD


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

MODIFIED ACCELEROGRAM

FIGURE 3.7A-3



ACAD

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

DESIGN SPECTRUM COMPARED WITH RESPONSE  
SPECTRUM OF MODIFIED ACCELEROGRAM FOR  
OBE WITH 3% DAMPING

FIGURE 3.7A-4





ACAD


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

DESIGN SPECTRUM COMPARED WITH  
RESPONSE SPECTRUM OF MODIFIED  
ACCELEROGRAM FOR DBE WITH 5% DAMPING

FIGURE 3.7A-5



ACAD


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

MODIFIED RESPONSE SPECTRUM CURVE

FIGURE 3.7A-6



ACAD



REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2


POST-SEISMIC EVENT PLANT PROCEDURES

FIGURE 3.7A-7



ACAD

REV 19 7/01




**LEGEND**

- i     $i^{\text{th}}$  JOINT WITH LUMPED MASS
- j     $j^{\text{th}}$  MASSLESS MEMBER
- △     $k^{\text{th}}$  JOINT WITHOUT MASS
- ⬡     $l^{\text{th}}$  MASSLESS SPRING

ACAD

REV 19 7/01



ACAD


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

SEISMIC MODEL  
CONTROL BLDG: LATERAL

FIGURE 3.7A-10



- NOTES:
- 1)  $M_1$  THROUGH  $M_8$  = LUMPED MASSES
  - 2)  $K_1$  THROUGH  $K_8$  = VERTICAL STRUCTURAL SPRINGS
  - 3)  $K_s$  = VERT. SOIL SPRING

ACAD


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

SEISMIC MODEL  
 CONTROL BLDG: VERTICAL

FIGURE 3.7A-11




- N MASS POINT NO.
- N MEMBER NO.
- SPRING

ACAD

REV 19 7/01





○ N MASS POINT NO.

□ N SPRING NO.

ACAD



REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

SEISMIC MODEL  
DIESEL GENERATOR BLDG: VERTICAL

FIGURE 3.7A-13



$K_H$  = HORIZONTAL SOIL IMPEDANCE INCLUDING EMBEDMENT EFFECTS.  
 $K_\psi$  = ROTATIONAL SOIL IMPEDANCE INCLUDING EMBEDMENT EFFECTS.  
 $H_C$  = DISTANCE FROM BASE TO EFFECTIVE CENTROID OF SOIL IMPEDANCE INCLUDING EMBEDMENT EFFECTS.

ACAD



REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

SEISMIC MODEL  
 INTAKE STRUCTURE: LATERAL

FIGURE 3.7A-14



ACAD


REV 19 7/01

LEGEND

● i = JOINT WITH LUMPED MASS

○ i = MASSLESS MEMBER

□ K = MASSLESS SOIL SPRING



ACAD


REV 19 7/01



**SOUTHERN NUCLEAR OPERATING COMPANY**  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

SEISMIC MODEL  
MAIN STACK: LATERAL

FIGURE 3.7A-16



**LEGEND**

- i = JOINT WITH LUMPED MASS
- J = MASSLESS MEMBER
- K = MASSLESS SOIL SPRING

ACAD


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

SEISMIC MODEL  
MAIN STACK: VERTICAL

FIGURE 3.7A-17



ACAD


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

OBE SYNTHETIC ACCELEROGRAM (1984)

FIGURE 3.7A-18



ACAD


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

DBE SYNTHETIC ACCELEROGRAM (1984)

FIGURE 3.7A-19



ACAD

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

DESIGN SPECTRUM COMPARED WITH RESPONSE SPECTRUM  
 OF OBE SYNTHETIC ACCELEROGRAM (1984) FOR 3% DAMPING

FIGURE 3.7A-20





ACAD


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

DESIGN SPECTRUM COMPARED WITH RESPONSE SPECTRUM  
 OF DBE SYNTHETIC ACCELEROGRAM (1984) FOR 5% DAMPING

FIGURE 3.7A-21



**NOTES**

1. Applicable to both OBE and DBE, independent of pipe diameter.
2. As of April 4, 1985, damping per this figure is used for all new and replacement systems and load reconciliation work.

ACAD


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

DAMPING CRITERIA FOR SEISMIC  
ANALYSIS OF PIPING SYSTEMS

FIGURE 3.7A-22



**NOTES:**

1. For unloaded tray, use damping values specified in Table 3.7A-1 for steel structures. For tray loaded less than 50% linear, interpolation is used to determine the applicable design damping value.
2. As of April 4, 1985, damping per this figure is used for all new and replacement systems and load reconciliation work.

ACAD

REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

DAMPING CRITERIA FOR SEISMIC  
ANALYSIS OF CABLE TRAY SUPPORTS

FIGURE 3.7A-23

**SUPPLEMENT 3.7A.A**

**CRITERIA FOR SEISMIC QUALIFICATION OF  
SEISMIC CATEGORY I EQUIPMENT AND PIPING**

**3.7A.A.1    SCOPE**

All Seismic Category I systems and equipment (assemblies and devices) supplied must withstand the postulated seismic occurrence as specified below. This supplement contains criteria that were used, in conjunction with IEEE 344-1971, to define the methods and procedures to be used in establishing the seismic qualification of the non-NSSS Seismic Category I equipment installed originally at HNP-2. For piping system analysis, the techniques in Bechtel Topical Report BP-TOP-1 were utilized. For loading combinations and allowable stress levels for seismic events, refer to section 3.9.

The maximum values of the codirectional responses caused by each of the components of earthquake are combined either by the summation of absolute values or by the square-root-of-the-sum-of-the-squares.

The summation of the codirectional inter-modal responses is by the square-root-of-the-sum-of-the-squares.

The equipment supplier is responsible for ensuring safe operation of the equipment and systems under the seismic conditions specified below. The supplier shall verify that the equipment will meet the stated functional requirements for continued operation without malfunction or loss of function during and after a postulated seismic event.

The "Institute of Electrical and Electronic Engineers (IEEE) Guide for Seismic Qualification of Class 1 Electric Equipment for Nuclear Power Generating Stations," IEEE Standard 344-1971 is used except as amended herein. The amendments listed below define and provide minimal values needed to verify the equipment capability. The term "electrical equipment" used throughout the Guide refers to all types of Seismic Category I equipment. Complete qualification procedures and monitoring techniques shall be presented by the equipment supplier to the buyer for review prior to the actual start of qualification work.

**3.7A.A.2    DEFINITION**

Add the following new paragraphs to IEEE Standard 344 as numbered below:

2.8    Operating Basis Earthquake (OBE)

The OBE is the largest earthquake which could reasonably be expected to occur at the site during the life of the plant and for which the equipment must remain operational or be able to shut down and start up again.

## 2.9 Fluid Systems

Those systems or equipment, such as pipes, pumps, valves, vessels, and tanks, that are part of a fluid-containing barrier. The support structure for a fluid system is an integral part of that system.

## 2.10 Malfunction or Functional Impairment

Equipment malfunction or functional impairment is the failure of equipment to perform its function in the same manner in which it would have in the absence of a seismic disturbance. For protective systems, malfunction is the loss of capability to initiate or sustain a protective action and not to initiate an action spuriously.

### **3.7A.A.3 PROCEDURE**

Add the following to the end of paragraph 3 of IEEE Standard 344:

When the malfunctioning of Class I equipment is considered, testing is the method recommended to verify the functional requirements.

### **3.7A.A.3.1 ANALYSIS**

#### **3.7A.A.3.1.1 Add the following to the end of paragraph 3.1.1 Standard 344:**

The number of masses shall be sufficient to define the dynamic behavior of the equipment (the mathematical model shall be shown even for a single degree of freedom system).

#### **3.7A.A.3.1.2 Add the following to the end of paragraph 3.1.2 of IEEE Standard 344:**

The equipment natural frequencies as determined shall be assumed to have a minimum variation of  $\pm 10$  percent. The actual variation shall depend on the expected accuracy of the calculations.

#### **3.7A.A.3.1.3 Add the following sentence to the end of paragraph 3.1.5 of IEEE Standard 344:**

Further, if the equipment is part of a fluid system, then the liquid should be considered in the analysis. Fluctuation of pressures due to acceleration, sloshing, compression waves, breathing modes, hydraulic transients, etc., shall be considered.

**3.7A.A.3.1.4 Add the following new paragraph as 3.1.6 to IEEE Standard 344:**

Seismic Category I equipment shall be designed for gravity loads, normal operating loads, operating temperature loads, and other loads that are included in the specification, combined with appropriate seismic loads. The seismic load shall include both the vertical and horizontal components acting simultaneously. The loading combination that will produce the maximum stress shall be considered.

The combined normal operating primary stresses and the primary stress due to the OBE shall be maintained equal to or below allowable working stress limits that are accepted as good practice and set forth in appropriate design standards and codes. However, no increase in the allowable working stress will be permitted because of dynamic loads except when permitted by the standards and codes for nuclear service. Local, primary, and self-limiting secondary stresses shall conform to the allowable values permitted by the appropriate code.

The normal operating primary stresses combined with the design basis earthquake (DBE) shall not exceed 90 percent of the minimum guaranteed yield strength\* of the material as stated in the American Society for Testing and Materials ASTM standards with applicable reduction due to temperature of stability. For mechanical equipment the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code shall be used where specified. Local, primary, and self-limiting secondary stresses may exceed yield stress levels to the extent permitted by the appropriate codes as long as malfunction is prevented.

**3.7A.A.3.2 TESTING**

**3.7A.A.3.2.1 Add the following to the end of paragraph 3.2.2.1 of IEEE Standard 344:**

Biaxial testing in the vertical and horizontal directions simultaneously is allowed and preferred.

**3.7A.A.3.2.2 Add the following sentence to the end of paragraph 3.2.2.3.1 of IEEE Standard 344:**

The minimum frequency range shall be from 1 to 35 cps; however, an extended frequency range shall be used where it is necessary because of special conditions.

---

\* In no case shall the algebraic difference between the maximum and minimum principal stresses be greater than 90 percent of minimum guaranteed yield stress.

**3.7A.A.3.2.3 Add the following sentence to the end of paragraph 3.2.2.4.1 of IEEE Standard 344:**

The minimum time duration for each condition and direction shall be 20 seconds and in no case less than that required to produce the desired amplification. If the location of the device necessitates a longer duration for a conservative test, then the above duration should be increased accordingly.

**3.7A.A.3.2.4 Delete the fourth sentence of paragraph 3.2.2.4.2 of IEEE Standard 344 in its entirety and replace with the following:**

For a test at any frequency, five beats are normally used; however, enough additional beats shall be added to make a total excitation duration of 5 seconds in any axis. There shall be a pause between the beats such that there results no significant superposition of motion.

**3.7A.A.3.2.5 Add the following sentence to the end of paragraph 3.2.2.4.3 of IEEE Standard 344:**

Before other tests are used, the test procedures and justifications shall be submitted to the buyer for review. If the buyer concurs with the proposed tests and procedures, then they may be used.

**3.7A.A.3.2.6 Add the following to the end of paragraph 3.2.3.1 of IEEE Standard 344:**

Biaxial testing in the vertical and horizontal directions simultaneously is allowed and preferred. The majority of Seismic Category I equipment is single-axis tested and qualified in accordance with the requirements of IEEE 344-1971.

**3.7A.A.3.2.7 The following sentence shall be added to the end of paragraph 3.2.3.4 of IEEE Standard 344:**

The minimum frequency range shall be from 1 to 35 cps; however, an extended frequency range shall be used where it is necessary because of special conditions.

**3.7A.A.3.2.8 Add the following new paragraph as 3.2.3.5 to IEEE Standard 344:**

The magnitude of the test input acceleration shall be determined from the appropriate DBE response spectra, the method of testing, the duration of excitation, and the damping of the equipment. The theoretical correlation of the response spectra and the test input is presented in figure 3.7A.A-1. The curves are based upon analysis of a linear single-degree-of-freedom mass-spring-damper model with the designated base input. The vibration magnification curves are calculated over a range of damping values (percent of critical).

**NOTE:** Conservative values of damping shall be used when the actual value is not known. In testing, this is usually the higher value of damping. The table input should include the necessary factor to account for other mode contribution for multi-degree-of-freedom systems. It is suggested that a factor of 1.5 be used until future evidence indicates other values.

The damping values referred to are the ones used to compute a response spectrum curve from random time-history motion. The amplification factor associated with random time-history motion, which is the ratio of peak response to floor response, is less than the amplification factor associated with sinusoidal motion, which is generally used as input for equipment testing. A method for obtaining the required peak input motion from a response spectrum curve is to take the peak response and divide that by the proper amplification factor. Therefore, by using a response spectrum curve with the higher damping factor,  $B_n$ , and dividing that by the amplification factor with testing motion for the same damping factor,  $B_n$ , one would obtain a higher peak input response.

This 50 percent increase in input to the shaker table input motion is analogous to the recommendations for the static load method of analysis presented in paragraph II.1.b.3 of Nuclear Regulatory Commission Standard Review Plan 3.7.2.

**3.7A.A.3.2.9 Add the following new paragraphs as 3.2.4, 3.2.5, and 3.2.6 to IEEE Standard 344:**

3.2.4 Post-Test Inspection

The tested item shall be thoroughly inspected for any damage sustained during testing. A detailed description of damage and repair and/or replacement shall be included in the test report.

3.2.5 Equipment Malfunction

If the equipment fails, malfunctions (change in status due to dynamic motion), or will not operate after the test, the supplier shall redesign the system and resubmit drawings and data for approval. A new test shall be conducted on the redesigned equipment to show compliance with the specification at no additional expense to the buyer.

3.2.6 Schedules and Delivery

Modifications of testing procedures, reanalysis, redesign, or resubmittals to satisfy these criteria in obtaining the engineer's concurrence shall not be the basis for late delivery of systems, equipment, and components. The supplier is invited to submit his proposed seismic analysis, design, and testing program prior to actual implementation to minimize such delays. Such delays shall remain the supplier's responsibility. Any changes that may be required due to the seismic analysis or testing shall automatically void prior approval or concurrence of drawings that have been submitted earlier.



**3.7A.A.4 DOCUMENTATION**

**3.7A.A.4.1 ADD THE FOLLOWING TO THE END OF PARAGRAPH 4.1 OF IEEE STANDARD 344:**

This documentation shall be submitted in report form to the buyer.

**3.7A.A.4.2 ADD THE FOLLOWING TO THE END OF PARAGRAPH 4.2 OF IEEE STANDARD 344:**

It shall also include a summary and conclusion with reference to the analysis where information for the conclusion can be reviewed.

**3.7A.A.4.3 DELETE PARAGRAPH 4.3(5) AND ADD NEW PARAGRAPH 4.3(5) TO IEEE STANDARD 344 AS FOLLOWS:**

- (5) Test data shall include natural frequencies, response accelerations, stresses, calibration history of test equipment, damping values, reactions, and mounting details.

**3.7A.A.4.4 DELETE PARAGRAPH 4.3 (6) AND ADD NEW PARAGRAPH 4.3 (6) TO IEEE STANDARD 344 AS FOLLOWS:**

- (6) Data analysis and evaluation (including the resultant response spectra for the surface upon which the equipment was mounted when tested).

**3.7A.A.4.5 ADD THE FOLLOWING NEW PARAGRAPH AS 4.4 TO IEEE STANDARD 344:**

Certification of Compliance


All the test data submitted by the supplier to satisfy the requirements of this specification shall be supervised, witnessed, and reviewed by a supplier's competent engineer. The test data, design calculations, and the certification submitted shall be signed and approved for compliance to the specification under the seal of a registered professional engineer and the supplier. These documents must be submitted for the buyer's approval prior to the release of shipment of the equipment.

**3.7A.A.5 ADD THE FOLLOWING NEW PARAGRAPH AS 6.0 TO IEEE STANDARD 344:**

Design Response Spectra

The attached operating basis earthquake and DBE horizontal and vertical floor-response spectra reflect the instructure floor accelerations resulting from the dynamic analysis.

Equipment location, special orientation, and appropriate response spectra are supplied to the suppliers for the seismic qualification of their equipment.



ACAD

REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

VIBRATION MAGNIFICATION  
AT RESONANCE

FIGURE 3.7A.A-1

**SUPPLEMENT 3.7A.B****ANALYSIS OF LONG-BURIED STRUCTURES****3.7A.B.1 INTRODUCTION**

This section outlines the methods used for seismic analysis of buried Seismic Category I piping and electrical ducts. It was assumed that the soil does not lose its integrity during an earthquake. Pipes and electrical ducts were assumed to move with the soil as the seismic wave propagates across them. The effect of soil-pipe and soil-duct interactions was neglected in the analysis. This assumption is necessary because of the present level of analytical techniques; however, this assumption is considered justifiable as discussed in a previous study,<sup>(1)</sup> particularly if the size of the pipe or the duct is small compared to the other parameters of the problem. It was further assumed that the earthquake wave would come only in one direction parallel to the longitudinal axis of the buried structures and that it would have no change in shape.

**3.7A.B.1.1 METHOD OF ANALYSIS**

Two separate approaches are employed in the analysis of the problem. The following are brief formulations of both approaches.

**3.7A.B.1.1.1 Free-Field Case**

For the portion of a pipe or duct far from two ends, free of any external barrier except the surrounding soil, it is reasonable to assume that this portion of the pipe or duct will move together with the soil as the seismic wave propagates. The effect of interaction between the buried member and soil will probably be negligible if its size is relatively small in relationship to the other dimensions. In this regard, Newmark<sup>(2)</sup> first proposed two equations using the wave propagation approach. The two equations which expressed the strains of the soil in terms of the velocity of the acceleration of the incoming seismic wave are the basis of this portion of the study.

Consider two points, points A and B, at a distance,  $d$ , apart, as shown in figure 3.7A.B-1.  $u$  is the displacement at A, and  $u$  plus an increment as shown is the displacement at B. It is noted that the second derivative of  $u$  with respect to  $x$  is significant only if  $d$  is very large. Now, consider a wave propagating from A towards B, with a displacement in the form of:

$$u = f(x - ct) \tag{1}$$

where:  $c$  = the velocity of wave propagation and  $t$  is the time.

### HNP-2-FSAR-3

Differentiating equation 1 with respect to  $x$  and  $t$ , respectively, one has:

$$\frac{\partial u}{\partial x} = f'(x - ct) \quad (2)$$

$$\frac{\partial u}{\partial t} = -cf'(x - ct) \quad (3)$$

From equations 2 and 3, it follows that:

$$\frac{\partial u}{\partial x} = -\frac{1}{c} \frac{\partial u}{\partial t} \quad (4)$$

In the case where  $u$  is in the direction of  $x$ , equation 4 leads to:

$$\varepsilon_m = -\frac{\dot{u}_m}{c} \quad (5)$$

where:  $\varepsilon_m$  = the maximum strain at point A, and  $\dot{u}_m$  the maximum particle velocity at point A.

In the case where  $u$  is perpendicular to the direction of  $x$ , either horizontally or vertically, one may differentiate equations 2 and 3 to obtain the expression for maximum curvature. It then follows:

$$\frac{\partial^2 u}{\partial x^2} = f''(x - ct) \quad (6)$$

$$\frac{\partial^2 u}{\partial t^2} = c^2 f''(x - ct) \quad (7)$$

They lead to:

$$\frac{\partial^2 u}{\partial x^2} = \frac{1}{c^2} \frac{\partial^2 u}{\partial t^2} \quad (8)$$

Thus,

$$\xi_m = \frac{\ddot{u}_m}{c^2} \quad (9)$$

where:  $\xi_m$  = the maximum curvature at point A, and  $\ddot{u}_m$  = the maximum particle acceleration at A.

Having the maximum strains obtained from equations 5 and 9, the maximum stresses experienced by pipes or ducts may then be determined by the simple stress-strain relationship; i.e.,

$$S_{\max} = (\epsilon_m + \xi_m r)E$$

where:  $S_{\max}$  = the maximum stress and E is the modulus of elasticity.  $r$  = the radius in case of a pipe and the distance of the extreme fiber to the neutral axis of the cross section in case of a duct.

### 3.7A.B.1.1.2 End-Connection Case

For the portion of a pipe or duct connected to a building, the behavior is a little different due to the fact that the mass of the structure is significant as compared to the surrounding soil, and there will be a relative movement of the structure to the surrounding soil. Two considerations may be undertaken:

- The case where the relative movement of the building is in the direction of the pipe or duct.
- The case where the relative movement of the building is perpendicular to the direction of the pipe or duct.

For the first case, methods are developed for straight and bent members, while for the second case, the method of beams on an elastic foundation is adopted.

#### 3.7A.B.1.1.2.1 **Relative Movement in the Direction of the Pipe or Duct**

##### A. Straight Members

Consider a straight member connected to a building as shown in figure 3.7A.B-2. The stress,  $s$ , at a point with a distance,  $x$ , from the building is equal to:

$$s(x) = (P - FX)/A \quad \text{for } d < P/F$$

$$F = \gamma H \phi \tan \alpha$$

where:

$P$  = the end force.

$F$  = the frictional force per unit length.

$A$  = the cross-sectional area.

### HNP-2-FSAR-3

- $\gamma$  = the unit weight of soil.  
 $H$  = the height of overburden soil.  
 $\phi$  = the perimeter of the member.  
 $\alpha$  = the frictional angle of the soil.

The total deformation of the member through the length,  $d$ , is then given by

$$\delta = \int_0^d \frac{s(x)}{E} dx = \int_0^d \frac{(P - Fx)}{EA} dx$$

$$\delta = \left( Pd - \frac{Fd^2}{2} \right) / EA$$

But,  $d = P/F$  and  $\delta = \Delta x$

$$\text{Thus, } P = \sqrt{2FEA\Delta x} \quad (10)$$

Where:  $\Delta x$  = the relative movement of the building in the direction of member.

#### B. Bent Members

Consider a bent member connected to a building as shown in figure 3.7A.B-3. The total deformation of the member through a length,  $L$ , is given by:

$$\Delta L = (PL - FL^2/2) / EA$$

$$\text{and } R = P - FL$$

The net displacement of point A is equal to:

$$\delta = \Delta x - \frac{1}{EA} \left( PL - \frac{FL^2}{2} \right) \quad (11)$$

Now consider a beam of finite length with free ends on both sides surrounded by soil. The displacement at one end induced by a concentrated load  $P^*$  acting at that end is equal to:

$$y = \frac{2P^* \lambda}{k} C \quad (12)$$

where:

$$C = \frac{\sinh\lambda h \cosh\lambda h - \sin\lambda h \cos\lambda h}{\sin^2 \lambda h - \sinh^2 \lambda h}$$

$k$  =  $bk_o$  for vertical movement.

=  $0.5 bk_o$  for horizontal movement.<sup>(4)</sup>

$K_o$  = modulus of subgrade reaction.

$b$  = dimension of the contact width of the member.

$h$  = length of the member.

$$\lambda = \sqrt[4]{\frac{k}{4EI}}$$

$EI$  = flexural rigidity of the member.

To keep point A in equilibrium, it is necessary that the force

$$P^* = R = P - FL \tag{13}$$

and the compatibility relationship at point A leads to:

$$y = \delta = \Delta x - \frac{1}{EA} \left( PL - \frac{FL^2}{2} \right) \tag{14}$$

From equations 13 and 14, one obtains:

$$P = \frac{2EAK\Delta x + FL^2k + 4FL\lambda CEA}{2(2\lambda CEA + Lk)} \tag{15}$$

It is noted that the above derivation involves a certain degree of approximation because of the assumption made in using equation 12. It is believed, however, that the effect of this approximation will have little significance in the result.

### 3.7A.B.1.1.2.2 Relative Movement Perpendicular to the Pipe or the Duct

Consider a member subjected to an end movement as shown in figure 3.7A.B-4. While the solution of this problem may be found in reference 3, a brief description is given below. Since all pipes are welded to the connections and flexible joints are inserted between the conduit inside the electrical ducts at connections, two end conditions are considered.



## HNP-2-FSAR-3

### A. Fixed End

The end-conditioning force induced by a movement of fixed end is equal to:

$$P_o = -\frac{2k}{y} \Delta y \quad (16)$$

Substituting this force to the solution of an infinite beam, one obtains:

Moment at any point of x

$$M(x) = \frac{k}{2\lambda^2} \Delta y C_{\lambda x} \quad (17)$$

Shear at any point of x

$$Q(x) = -\frac{k}{\lambda} \Delta y D_{\lambda x} \quad (18)$$

where:

$$C_{\lambda x} = e^{-\lambda x} (\cos \lambda x - \sin \lambda x)$$

$$D_{\lambda x} = e^{-\lambda x} \cos \lambda x$$

$C_{\lambda x}$  and  $D_{\lambda x}$  are maximum at  $x = 0$ . Thus,

$$\begin{aligned} M_{\max} &= \frac{k}{2\lambda^2} \Delta y \\ Q_{\max} &= -\frac{k}{\lambda} \Delta y \end{aligned} \quad (19)$$

### B. Hinged End

The end-conditioning force induced by a movement of hinged end is given by:

$$\begin{aligned} P_o &= -\frac{2k}{\lambda} \Delta y \\ M_o &= \frac{K}{\lambda^2} \Delta y \end{aligned} \quad (20)$$

Similarly, these forces will lead to a solution

HNP-2-FSAR-3

$$M(x) = \frac{k}{2\lambda^2} \Delta y (D_{\lambda x} - C_{\lambda x})$$

$$Q(x) = \frac{k}{\lambda} \Delta y \left( D_{\lambda x} - \frac{A_{\lambda x}}{2} \right)$$
(21)

where:  $A_{\lambda x} = e^{-\lambda x} (\cos \lambda x + \sin \lambda x)$

The maximum values of  $M(x)$  and  $Q(x)$  are at

$\lambda x = \frac{\pi}{4}$  and  $\lambda x = 0$ , respectively. Thus,

$$M_{\max} = 0.3224 \frac{k}{2\lambda^2} \Delta y$$

$$Q_{\max} = \frac{k}{2\lambda} \Delta y$$
(22)

The dynamic analysis of all Seismic Category I structures has been performed, and the relative displacement of the reactor building, control building, intake structure, and the diesel generator building obtained from the seismic analysis of these structures is presented in table 3.7A.B-1. Carbon steel pipe sleeves, 4 in. greater in diameter than the process pipes, are provided on the exterior walls of the Seismic Category I structures for each system piping connection. The piping passes through these penetrations at specified elevations which are at the centerline elevation of the sleeves. Before fuel loading, all of these penetrations will be sealed as shown on figure 3.7A.B-5. At the time of fuel loading, the major portion of the predicted settlement will have occurred. The remaining estimated consolidation of ~ 1/2 in. will take place over a period of years. The sand bedding below the piping in the vicinity of the penetration will minimize stresses in the seal welds. Using the method of analysis described above and the equation

$$S = \frac{P}{A} \pm \frac{Mr}{I},$$
(23)

the stresses were computed for ducts and pipes in the free field and at the end of pipes when they were connected to the structures.

Computed stress intensities are shown in tables 3.7A.B-2 through 3.7A.B-4.

It is noted that in the case of hinged end, the maximum moment does not occur at the end. But equation 23 is still used in computing the stress simply because the axial force at the point of maximum moment is not expected to differ significantly in magnitude due to the frictional force.

It is also noted that for pipes, stresses obtained in both paragraphs 3.7A.B.1.1.1 and 3.7A.B.1.1.2 have to be added to the stress due to the internal pressure. The magnitude of this stress =  $pr/2t$ , where:  $p$  = the internal pressure,  $r$  = the radius of the pipe, and  $t$  = the thickness of the pipe.

### **3.7A.B.2 REVISED STRESS ANALYSIS OF INTAKE STRUCTURE BURIED PIPING AND CONCRETE DUCTS**

The original static, thermal, internal pressure, and seismic analyses performed for the intake structure buried piping and concrete ducts were recalculated to reflect the structural properties of the new backfill material described in paragraph 2A.9.2.6. A finite element computer program<sup>(5)</sup> was used to obtain the static and thermal stresses. The methodology specified in subsection 3.7A.B.1 was followed for the seismic analysis. The structural properties of the K-Krete backfill material and the intake structure relative displacements (table 3.7A.B-1) were used to calculate seismic pipe and duct stresses at the intake structure wall pipe penetrations and duct end connections. The resulting seismic stresses for the relative displacement cases are given in table 3.7A.B-5. For the K-Krete covered portions of pipes and ducts far from the intake structure wall, free-field case analyses were performed. The resulting seismic stresses are given in table 3.7A.B-5. The maximum stresses obtained for all load cases are summarized in table 3.7A.B-6. The maximum combined stresses as shown in the same table are less than the allowable stresses specified in Section III of the American Society of Mechanical Engineers Code.

## HNP-2-FSAR-3

### REFERENCES

1. Sakurai, A., and Takahasi, T., "Dynamic Stresses of Underground Pipe Lines During Earthquake," Fourth World Conference on Earthquake Engineering, 1969.
2. Newmark, N.M., "Problems in Wave Propagation in Soil and Rock," International Symposium on Wave Propagation and Dynamic Properties of Earth Material, Albuquerque, New Mexico, 1967.
3. Hetenyi, M., Beams on Elastic Foundation, The University of Michigan Press, 1946.
4. Richart, Jr., F.E., Hall, Jr., J.R., and Woods, R.D., Vibration of Soils and Foundations, Prentice-Hall, New Jersey, 1970.
5. Bechtel Structural Analysis Program, BSAR-User's Manual Version D, Bechtel Power Corporation, December 1979.

TABLE 3.7A.B-1

## RELATIVE MOVEMENTS OF VARIOUS BUILDINGS

| <u>Building</u>                        | Horizontal<br>Movement<br>(ft) | Vertical<br>Movement<br>(ft) |
|----------------------------------------|--------------------------------|------------------------------|
| Reactor building at el 130 ft          | 0.0065                         | 0.0053                       |
| Control building at el 130 ft          | 0.00272                        | 0.00081                      |
| Intake structure at el 109 ft 9 in.    | 0.0036                         | 0.00025                      |
| Diesel generator building at el 129 ft | 0.009928                       | 0.004993                     |

TABLE 3.7A.B-2

## STRESSES IN DUCTS BURIED IN THE FREE FIELD

| <u>Duct Size</u>                | <u><math>\sigma_1</math>(psi)</u> | <u><math>\sigma_2</math>(psi)</u> | <u><math>\sigma_3</math>(psi)</u> |
|---------------------------------|-----------------------------------|-----------------------------------|-----------------------------------|
| 2 ft 8 1/4 in. x 2 ft 1 1/2 in. | 500                               | 468                               | 4083                              |
| 4 ft 4 1/2 in. x 2 ft 8 1/4 in. | 510                               | 459                               | 4163                              |
| 3 ft 9 3/4 in. x 2 ft 8 1/4 in. | 507                               | 462                               | 4137                              |
| 1 ft 11 in. x 1 ft 5 1/2 in.    | 496                               | 473                               | 4045                              |
| 7 ft 4 1/4 in. x 4 ft 1/2 in.   | 533                               | 436                               | 4350                              |
| 7 ft 7 in. x 5 ft 3 1/4 in.     | 532                               | 437                               | 4344                              |
| 7 ft 4 1/4 in. x 5 ft 1 1/4 in. | 536                               | 432                               | 4381                              |

$\sigma_1$  = maximum concrete extreme fiber stress.

$\sigma_2$  = minimum concrete extreme fiber stress.

$\sigma_3$  = maximum steel stress.

TABLE 3.7A.B-3

## STRESSES IN DUCTS CONNECTED TO BUILDING STRUCTURES

| <u>Duct Size</u>            | <u>Connected to</u>       | <u><math>\sigma_1</math>(psi)</u> | <u><math>\sigma_2</math>(psi)</u> | <u><math>\sigma_3</math>(psi)</u> | <u><math>\sigma_4</math>(psi)</u> |
|-----------------------------|---------------------------|-----------------------------------|-----------------------------------|-----------------------------------|-----------------------------------|
| 7 ft 8 in. x 1 ft 6 in.     | Reactor building          | 405                               | 69                                | 4345                              | 10                                |
| 6 ft 10 in. x 2 ft 2 in.    | Control building          | 153                               | -5                                | 1861                              | 2                                 |
| 8 ft 6 in. x 2 ft 2 in.     | Control building          | 113                               | -3                                | 1470                              | 2                                 |
| 10 ft 2 in. x 2 ft 2 in.    | Control building          | 112                               | -2                                | 1414                              | 2                                 |
| 1 ft 2 in. x 1 ft 11 in.    | Diesel generator building | 554                               | -73                               | 18,734                            | 12                                |
| 5 ft 6 in. x 1 ft 11 in.    | Diesel generator building | 424                               | 16                                | 20,588                            | 9                                 |
| 1 ft 10 in. x 1 ft 11 in.   | Diesel generator building | 499                               | -43                               | 19,679                            | 11                                |
| 4 ft 6 in. x 1 ft 11 in.    | Diesel generator building | 438                               | 7                                 | 19,774                            | 9                                 |
| 3 ft 6 in. x 1 ft 11 in.    | Diesel generator building | 446                               | -4                                | 19,645                            | 9                                 |
| 6 ft 6 in. x 1 ft 11 in.    | Diesel generator building | 421                               | 23                                | 21,215                            | 9                                 |
| 13 ft 9 in. x 1 ft 10 in.   | Diesel generator building | 411                               | 47                                | 20,270                            | 10                                |
| 19 ft 1/2 in. x 1 ft 10 in. | Diesel generator building | 401                               | 55                                | 20,698                            | 9                                 |

$\sigma_1$  = maximum concrete extreme fiber stress.

$\sigma_2$  = minimum concrete extreme fiber stress.

$\sigma_3$  = maximum steel stress.

$\sigma_4$  = maximum shear stress.

**TABLE 3.7A.B-4**  
**STRESSES IN BURIED PIPE**

| <u>Piping System</u>                            | Pipe Size<br>(in.) | <u>Stresses in Free Field</u> |                  | <u>Stresses at End</u> |                  |                  |
|-------------------------------------------------|--------------------|-------------------------------|------------------|------------------------|------------------|------------------|
|                                                 |                    | $\sigma_1$ (psi)              | $\sigma_2$ (psi) | $\sigma_1$ (psi)       | $\sigma_2$ (psi) | $\sigma_3$ (psi) |
| To high-pressure coolant injection pump         | 16 $\phi$ x 0.188  | 4577                          | 4450             | 8996                   | -2849            | 442              |
| Residual heat removal service water (RHRSW)     | 18 $\phi$ x 0.5    | 7788                          | 7645             | 11,713                 | 4104             | 225              |
| Plant service water (PSW)                       | 6 $\phi$ x 0.28    | -                             | -                | 11,311                 | 1144             | 211              |
| PSW                                             | 10 $\phi$ x 0.356  | 4834                          | 4749             | -                      | -                | -                |
| PSW                                             | 8 $\phi$ x 0.322   | -                             | -                | 10,677                 | 1197             | 217              |
| Conduit to reactor core isolation cooling       | 6 $\phi$ x 0.134   | 4317                          | 4264             | 15,719                 | 1022             | 367              |
| Standby gas                                     | 18 $\phi$ x 0.375  | 4353                          | 4210             | 6293                   | -2576            | 279              |
| Service water pipe to diesel generator building | 8 $\phi$ x 0.322   | 4752                          | 4684             | 15,783                 | -588             | 241              |
| RHRSW to intake structure                       | 30 $\phi$ x 0.375  | 6301                          | 6062             | 4347                   | 810              | 146              |
| RHRSW to intake structure                       | 18 $\phi$ x 0.5    | 7788                          | 7645             | 8045                   | 2531             | 91               |

$\sigma_1$  = maximum fiber stress.

$\sigma_2$  = minimum fiber stress.

$\sigma_3$  = maximum shear stress.



TABLE 3.7A.B-5

**MAXIMUM STRESSES IN BURIED PIPES AND  
DUCTS DUE TO SEISMIC LOAD**


| <u>Pipe/Duct Size</u>     | <u>Stresses In<br/>Free Field (psi)</u> | <u>Stresses At End (psi)</u>                      |                                                    |
|---------------------------|-----------------------------------------|---------------------------------------------------|----------------------------------------------------|
|                           |                                         | <u>In Direction<br/>of Pipe/Duct<br/>Movement</u> | <u>Perpendicular<br/>To Pipe/Duct<br/>Movement</u> |
| 30 in. § pipe x 0.375 in. | 5051                                    | 5150                                              | 425                                                |
| 18 in. § pipe x 0.500 in. | 508                                     | 8940                                              | 1126                                               |
| 12 in. § pipe x 0.375 in. | 5092                                    | 10,030                                            | 1260                                               |
| 2 in. § pipe x 0.218 in.  | 5115                                    | 12,860                                            | 1450                                               |
| 12 ft 3 in. x 3 ft duct   | 630                                     | 600                                               | 58                                                 |

TABLE 3.7A.B-6

**MAXIMUM STRESSES IN BURIED PIPES  
(K-KRETE BACKFILL)**

| Pipe<br>Size (in.) | Location<br>Feet From<br>Intake<br>Structure | A                                    | B                                              | C                          | D                       | E                             | Combination of Stresses <sup>(a)</sup> |                                 |                                       |
|--------------------|----------------------------------------------|--------------------------------------|------------------------------------------------|----------------------------|-------------------------|-------------------------------|----------------------------------------|---------------------------------|---------------------------------------|
|                    |                                              | DL Stress +<br>Shear Stress<br>(psi) | Stress Due<br>to Internal<br>Pressure<br>(psi) | Thermal<br>Stress<br>(psi) | Seismic<br>End<br>(psi) | Stress<br>Free Field<br>(psi) | A+B<br>15,000<br>(psi)                 | A+B+(D or E)<br>18,000<br>(psi) | A+B+C+<br>(D or E)<br>37,500<br>(psi) |
| 30 x 0.375         | 0.0<br>In structure                          | 30 + 502                             | 2200                                           | 2960                       | 5150                    | -                             | 2732                                   | 7882                            | 10,842                                |
| 30 x 0.375         | 0.1<br>In K-Krete                            | 18.5 + 502                           | 2200                                           | 4875                       | 5150                    | -                             | 2721                                   | 7871                            | 12,746                                |
| 30 x 0.375         | 10.75<br>In K-Krete                          | 650                                  | 2200                                           | 4630                       | -                       | 5051                          | 2850                                   | 7901                            | 12,531                                |
| 18 x 0.500         | 0.1<br>In K-Krete                            | 7.2 + 314.3                          | 3735                                           | 4875                       | 8940                    | -                             | 4056                                   | 12,996                          | 17,871                                |
| 12 x 0.375         | 0.1<br>In K-Krete                            | 16.3 + 314                           | 1190                                           | 4875                       | 10,030                  | -                             | 1520                                   | 11,550                          | 16,425                                |
| 2 x 0.218          | 0.1<br>In K-Krete                            | 7.2 + 190                            | 340                                            | 4875                       | 12,860                  | -                             | 537                                    | 13,400                          | 18,275                                |

a. From Section III, ASME Code.



ACAD


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

RELATIVE DISPLACEMENT

FIGURE 3.7A.B-1



ACAD




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

END MOVEMENT IN DIRECTION  
OF MEMBER-STRAIGHT BAR

FIGURE 3.7A.B-2



ACAD


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

END MOVEMENT IN DIRECTION  
OF MEMBER-BENT BAR

FIGURE 3.7A.B-3



ACAD



REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

END MOVEMENT PERPENDICULAR  
TO MEMBER

FIGURE 3.7A.B-4



ACAD

REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TYPICAL PIPE CONNECTION  
TO CATEGORY I STRUCTURES

FIGURE 3.7A.B-5

**SUPPLEMENT 3.7B**

**SEISMIC DESIGN - NUCLEAR STEAM SUPPLY SYSTEM**

The seismic design of systems, components, and structures within the nuclear steam supply system (NSSS) scope of responsibility is presented in the following pages. The information presented in this supplement is intended to add to the information presented in supplement 3.7A in order to better differentiate responsibilities in the seismic design of Edwin I. Hatch Nuclear Plant-Unit 2 (HNP-2). As a result, not all subsections have a response but rather refer to the corresponding subsection in 3.7A.

**3.7B.1 SEISMIC INPUT**

**3.7B.1.1 DESIGN RESPONSE SPECTRA**

This subsection is covered in subsection 3.7A.1.1.

**3.7B.1.2 DESIGN RESPONSE SPECTRA DEVIATION**

This subsection is covered in subsection 3.7A.1.2.

**3.7B.1.3 CRITICAL DAMPING VALUES**

The damping factors indicated in table 3.7B-1 were used in the response analysis of various structures and systems and in preparation of floor response spectra used as forcing inputs for piping and equipment analysis or testing.

**3.7B.1.4 BASES FOR SITE-DEPENDENT ANALYSIS**

This subsection is covered in subsection 3.7A.1.4.

**3.7B.1.5 SOIL-SUPPORTED SEISMIC CATEGORY I STRUCTURE**

This subsection is covered in subsection 3.7A.1.5.

**3.7B.1.6 SOIL-STRUCTURE INTERACTIONS**

This subsection is covered in subsection 3.7A.1.6.



## 3.7B.2 SEISMIC SYSTEM ANALYSIS

### 3.7B.2.1 SEISMIC ANALYSIS METHODS

#### 3.7B.2.1.1 Introduction

The modal-superposition method is used for the reactor vessel and internals, except as noted in paragraph 3.7B.2.1.4. This method involves two steps:

- The solution of the characteristic value problem represented by the free vibration response of the system.
- The transformation to normal coordinates utilizing the mode shapes of the system.

This procedure uncouples the equations of motion so that the response of the system in each individual mode may be evaluated independently.

The stress, strain, and deformation criteria are described in sections 3.8, 3.9, and 3.10.

#### 3.7B.2.1.2 Equations of Dynamic Equilibrium

Assuming velocity proportional damping, the dynamic equilibrium equations for a lumped mass, distributed stiffness system are expressed in matrix form as:

$$[M]\{\ddot{u}(t)\} + [C]\{\dot{u}(t)\} + [K]\{u(t)\} = \{P(t)\} \quad (1)$$

where:

$u(t)$  = time-dependent displacement of nonsupport points relative to the supports.

$\dot{u}(t)$  = time-dependent velocity of nonsupport points relative to the supports.

$\ddot{u}(t)$  = time-dependent acceleration of nonsupport points relative to the supports.

$\{M\}$  = diagonal matrix of lumped masses.

$[C]$  = damping matrix.

$[K]$  = stiffness matrix.

$P(t)$  = time-dependent inertial forces acting at nonsupport points.

The manner in which a distributed mass, distributed stiffness system is idealized into a lumped mass, distributed stiffness system of the building is described in supplement 3.7A, along with a

schematic representation of relative acceleration  $\ddot{u}(t)$ , support acceleration  $\ddot{u}_s(t)$ , and total acceleration  $\ddot{u}_t(t)$ .

**3.7.B.2.1.2.1 Equations of Dynamic Equilibrium for Multi-Support Excitations of Piping, Systems, Components, and Equipment**

Analytical procedures for obtaining force and displacement responses engendered by time-dependent base support excitation are discussed in the preceding sections. In a multi-support system, the relative motion among the individual multi-support points gives rise to time varying displacements at the nonsupport points.

The governing equations of motion of a multi-supported piping system, component, or equipment undergoing individual multi-support excitations may be expressed in the following matrix form:

$$[M]\{\ddot{u}\} + [C]\{\dot{u}\} + [K]\{u\} = \{F\} \tag{2}$$

where:

$\{u\} = \{u(t)\} =$  the corresponding dynamic model nodal displacement vector of absolute displacements.

The general case is considered in which  $k$  of the total  $n$  degrees-of-freedom corresponds to the individual multi-support points which undergo known time-history motions. The nodal displacement vector of absolute displacements can be partitioned and written as:

$$\{u\} = \begin{Bmatrix} u_a \\ \bar{u}_s \end{Bmatrix} = \begin{Bmatrix} u_a^d + u_a^s \\ \bar{u}_s \end{Bmatrix} \tag{3}$$

where:

$\{u_a\} =$  absolute displacement vector of the active (unsupported) degrees-of-freedom.

$\{\bar{u}_s\} =$  known absolute displacement vector corresponding to the multi-supported degrees-of-freedom.

The vector  $\{u_a\}$  in equation 3 was further separated into a dynamic part and a pseudo-static part

## HNP-2-FSAR-3

where:

$$\{u_a^d\} = \text{dynamic part of } \{u_a\}$$

$$\{u_a^s\} = \text{pseudo-static part of } \{u_a\}$$

Multi-support excitation may require the use of all modes which span the  $\{u_a\}$  space of active (unsupported) degrees-of-freedom in the modal superposition to obtain reliable solutions of equation 2. Substitution of equation 3 enables the circumventing of that very costly requirement. Only the dynamic part  $\{u_a^d\}$  is obtained by modal superposition which does not require all modes. The pseudo-static part  $\{u_a^s\}$  is obtained from the known multi-support excitation.

The partition equations of motion are obtained by substituting equation 3 into equation 2 to yield:

$$\begin{bmatrix} M_a & 0 \\ 0 & M_s \end{bmatrix} \begin{Bmatrix} \ddot{u}_a^d + \ddot{u}_a^s \\ \ddot{u}_s \end{Bmatrix} + \begin{bmatrix} C_{aa} & C_{as} \\ C_{sa} & C_{ss} \end{bmatrix} \begin{Bmatrix} \dot{u}_a^d + \dot{u}_a^s \\ \dot{u}_s \end{Bmatrix} + \begin{bmatrix} K_{aa} & K_{as} \\ K_{sa} & K_{ss} \end{bmatrix} \begin{Bmatrix} u_a^d + u_a^s \\ \bar{u} \end{Bmatrix} = \begin{Bmatrix} F_a \\ F_s \end{Bmatrix} \quad (4)$$

where:

$$\{u_a^d\} = \text{dynamic part (as defined by equation 3) of the absolute displacement vector of the active (unsupported) degree-of-freedom.}$$

$$\{u_a^s\} = \text{pseudo-static part (as defined by equation 3) of the absolute displacement vector of the active (unsupported) degree-of-freedom.}$$

$$[M_a] \text{ and } [M_s] = \text{lumped diagonal mass matrices associated with the active degrees-of-freedom and the multi-support points, respectively.}$$

$$[C_{aa}] \text{ and } [K_{aa}] = \text{damping matrix and elastic stiffness matrix, respectively, relating the forces developed in the active degrees-of-freedom to the motion of the active degrees-of-freedom.}$$

$$[C_{ss}] \text{ and } [K_{ss}] = \text{support forces due to unit velocities and displacements, respectively, of the multi-support points.}$$

$$[C_{as}] \text{ and } [K_{as}] = \text{damping and stiffness matrices denoting the coupling forces developed in the active degrees-of-freedom due to the motion of the supports, vice versa.}$$

HNP-2-FSAR-3

$\{F_a\}$  = prescribed time-dependent applied load vector corresponding to the active degrees-of-freedom.

$\{\bar{F}_s\}$  = reaction force vector corresponding to the system multi-support points.

( $\dot{\quad}$ ) = dot appearing over a time-varying variable indicates total differentiation with respect to time.

The procedure used to construct the damping matrix is discussed in paragraph 3.7.2.15(B). The mass matrix and elastic stiffness matrix are formulated by standard procedure.

Since the components of  $\{\ddot{u}_s\}$ , hence of  $\{\dot{u}_s\}$  and  $\{u_s\}$ , are known functions of time, only the first partitioned equation of 4 is of interest.

$$[M_a]\{\ddot{u}_a^d\} + [M_a]\{\dot{u}_a^s\} + [C_{aa}]\{\dot{u}_a^d\} + \boxed{[C_{aa}]\{\dot{u}_a^s\} + [C_{as}]\{\dot{u}_s\}} + [K_{aa}]\{u_a^d\} + \boxed{[K_{as}]\{u_a^s\} + [K_{as}]\{u_s\}} = \{F_a\} \quad (5)$$

The pseudo-static displacement vector is written in terms of the multi-support displacement vector by taking

$$[K_{aa}]\{u_a^s\} + [K_{as}]\{u_s\} = \{0\} \quad (6)$$

Therefore,

$$\{u_a^s\} = -[K_{aa}]^{-1}[K_{as}]\{u_s\} \quad (7)$$

It follows from equation 6 that

$$[C_{aa}]\{\dot{u}_a^s\} + [C_{as}]\{\dot{u}_s\} = \{0\} \quad (8)$$

The partitioned equation is reduced to its final form by substituting equations 6, 7, and 8 into equation 5 to yield:

$$[M_a]\{\ddot{u}_a^d\} + [C_{aa}]\{\dot{u}_a^d\} + [K_{as}]\{u_a^d\} = \{F_a\} + [M_a][K_{aa}]^{-1}[K_{as}]\{\ddot{u}_s\} \quad (9)$$

The solution in time of equation 9 for  $\{u_a^d\}$  is readily obtained by the standard normal mode solution methodology. Once  $\{u_a^d\}$  is obtained, the total solution for the absolute displacement vector  $\{u_a\}$ , corresponding to the active degrees-of-freedom, is given by substituting  $\{u_a^d\}$  from equation 9 and  $\{u_a^s\}$  from equation 7 into equation 3.

After obtaining the absolute displacement vector response of the active degrees-of-freedom,  $\{u_a\}$ , the second partitioned equation of 4 can be used to calculate the reaction force vector  $\{\bar{F}_s\}$  corresponding to the multi-support degrees-of-freedom. That is,

$$\{\bar{F}_s\} = [M_s]\{\ddot{u}_s\} + [C_{sa}]\{\dot{u}_a\} + [C_{ss}]\{\dot{u}_s\} + [K_{sa}]\{u_a\} + [K_{ss}]\{u_s\} \quad (10)$$

Note that  $\{\bar{F}_s\}$  is the total external force vector applied to the multi-support degrees-of-freedom required to produce the given multi-support excitation  $\{\ddot{u}_s\}$ . The interaction force vector  $\{F_s\}$  corresponding to the reaction of the active degrees-of-freedom portion of the dynamic model on the multi-support points is given by:

$$\{F_s\} = [C_{sa}]\{\dot{u}_a\} + [K_{sa}]\{u_a\} \quad (11)$$

The interaction for vector  $\{F_s\}$  can also be expressed in terms of the multi-support excitation input motion  $\{u_s\}$  by substituting equations 7 and 3 into equation 11 to yield:

$$\{F_s\} = [C_{sa}]\{u_a^d\} + [K_{sa}]\{u_a^d\} - [C_{sa}][K_{aa}]^{-1}[K_{as}]\{\dot{u}_s\} - [K_{sa}][K_{aa}]^{-1}[K_{as}]\{u_s\} \quad (12)$$

### 3.7B.2.1.3 Solution of the Equations of Motion by Mode Superposition

The second technique used for the solution of the equations of motion is the method of modal superposition.

The set of homogeneous equations represented by the undamped free vibration of the system is:

$$[M]\{\ddot{u}(t)\} + [K]\{u(t)\} = 0 \quad (13)$$

Since the free oscillations are assumed to be harmonic, the displacements can be written as:

$$\{u(t)\} = \{\phi\}e^{i\omega t} \quad (14)$$

where:

- $\{\phi\}$  = column matrix of the amplitude of displacements  $\{u\}$ .
- $\omega$  = circular frequency of oscillation.
- $t$  = time.

Substituting equation 14 and its derivatives in equation 13 and noting that  $e^{i\omega t}$  is not necessarily zero for all values of  $\omega t$  yields:

$$[-\omega^2[M] + [K]]\{\phi\} = \{0\} \quad (15)$$

Equation 15 is the classical algebraic eigenvalue problem wherein the eigenvalues yield the frequencies of vibration,  $\omega_i$ , and the eigenvectors are the mode shapes,  $\{\phi\}_i$ .

For each frequency  $\omega_i$  there is a corresponding solution vector  $\{\phi\}_i$ . It can be shown that the mode shape vectors are orthogonal with respect to the weighting matrix  $[K]$  in the n-dimensional vector space.

The mode shape vectors are also orthogonal with respect to the mass matrix  $[M]$ .

The orthogonality of the mode shapes is used to effect a coordinate transformation of the displacements, velocities, and accelerations so that the response in each mode is independent of the response of the system in any other mode. Thus, the problem becomes one of solving n independent differential equations rather than n simultaneous differential equations; and, since the system is linear, the principle of superposition holds, and the total response of the system oscillating simultaneously in n modes is determined by direct addition of the responses in the individual modes.

#### **3.7B.2.1.4 Analysis by Response Spectrum**

As an alternative to the step-by-step mode superposition method described in paragraph 3.7B.2.1.3, the response spectrum method is used. The response spectrum method is based on the fact that the modal responses can be expressed as a set of integral equations rather than as a set of differential equations. The advantage of this form of solution is that for a given ground motion the only variables under the integral are the damping factor and the frequency. Thus, for a specified damping factor, it is possible to construct a curve that gives a maximum value of the integral as a function of frequency. This curve is called a response spectrum for the particular input motion and the specified damping factor.

Using the calculated natural frequencies of vibration of the system, the maximum values of the modal responses are determined directly from the appropriate response spectrum. The modal maxima are then combined as discussed in subsection 3.7B.3.4.

The calculated maximum responses due to one horizontal directional earthquake excitation are combined with the responses due to the vertical earthquake by the sum of the absolute values method. The maximum responses due to another perpendicular horizontal earthquake are also combined with the responses due to the vertical earthquake in the same manner. The larger of the two values is used for design. The basis of combining loads is discussed in subsection 3.7B.3.7.

Contributions due to the three spatial components of seismic excitation are combined, as described in paragraph 3.7B.2.1.7.2, for replacement recirculation piping.

### 3.7B.2.1.5 Support Displacements in Multisupported Structures

The preceding sections have discussed analysis procedures for forces and displacement induced by time-dependent support accelerations. In a multisupported structure there are, in addition, time-dependent support displacements, which produce additional displacements at nonsupport points and pseudostatic forces at both support and nonsupport points. The total force vector due to both support accelerations and support displacements are given by:

$$\begin{Bmatrix} F(t) \\ F_s(t) \end{Bmatrix} = [\bar{K}] \begin{Bmatrix} u(t) \\ u_s(t) \end{Bmatrix} \quad (16)$$

where:

$F(t)$  = time-dependent forces at nonsupport points.

$F_s(t)$  = time-dependent forces at support points (reactions).

$u(t)$  = time-dependent displacements at nonsupport points due to support accelerations.

$u_s(t)$  = time-dependent displacements at support points.

$[\bar{K}]$  = stiffness matrix of the free structure, i.e., a singular matrix, and it is built up from the static stiffness coefficients of each element without the application of displacement boundary conditions.

Similarly, the total or absolute displacement of nonsupport points is given by:

$$\{u_t(t)\} = \{u(t)\} + [R]\{u_s(t)\} \quad (17)$$

where:

$\{u_t(t)\}$  = total displacement.

$[R]$  = transformation matrix that relates displacements at nonsupport points due to unit displacements at support points.

### **3.7B.2.1.6 Modeling Techniques for Seismic Category I Structures, Systems, and Components**

An important step in the seismic analysis of Seismic Category I systems or structures is the procedure used for modeling. The techniques currently being used are represented by lumped masses and a set of spring dashpots idealizing both the inertia and stiffness properties of the system. The details of the mathematical models are determined by the complexity of the actual structures and the information required for the analysis. The input data of the building is provided in supplement 3.7A.

#### **3.7B.2.1.6.1 Modeling of Piping Systems**

The continuous piping system is modeled as an assemblage of beams. The mass of each beam is lumped at the nodes connected by a weightless elastic member, representing the physical properties of each segment. The pipe lengths between mass points are no greater than the length that would have a natural frequency of 33 Hz when calculated as a simply supported beam with uniformly distributed mass. All concentrated weights on the piping system such as main valves, relief valves, pumps, and motors are modeled as lumped masses. The torsional effects of the valve operators and other equipment with offset centers of gravity with respect to centerline of the pipe is included in the analytical model. If the torsional effect is expected to cause pipe stresses < 500 psi, this effect may be neglected.

#### **3.7B.2.1.6.2 Modeling of Equipment**

For dynamic analysis, Seismic Category I equipment is represented by lumped mass systems, which consist of discrete masses connected by weightless springs. The criteria used to lump masses are as follows:

- A. The number of modes of a dynamic system is controlled by the number of masses used. Therefore, the number of masses is chosen so that all significant modes are included. The modes are considered as significant if the corresponding natural frequencies are < 33 Hz and the stresses calculated from these modes are > 10% of the total stresses obtained from lower modes.
- B. Mass is lumped at any point where a significant concentrated weight is located. Examples are the motor in the analysis of pump motor stand, the impeller in the analysis of pump shaft, etc.
- C. If the equipment has a free-end overhang span whose flexibility is significant compared to the center span, a mass is lumped at the overhang span.
- D. When a mass is lumped between two supports, it is located at a point where the maximum displacement is expected to occur. This tends to conservatively lower the natural frequencies of the equipment. Similarly, in the case of live loads (mobile) and a variable support stiffness, the location of the load and the magnitude of support stiffness are chosen so as to yield the lowest frequency



content for the system. This is to ensure conservative dynamic loads since equipment frequencies are such that the floor spectra peak is in the lower frequency range. If this is not the case, the model is adjusted to give more conservative results.

### **3.7B.2.1.6.3 Modeling of Reactor Pressure Vessel and Internals**

The seismic loads on the reactor pressure vessel (RPV) and internals are based on a dynamic analysis of an entire RPV building complex with the appropriate forcing function supplied at ground level. The seismic model of the RPV and internals is given in figure 3.7B-1.

This mathematical model consists of lumped masses connected by elastic (linear) members. Using the elastic properties of the structural components, the stiffness properties of the model are determined. This includes the effects of both bending and shear. To facilitate hydrodynamic mass calculations, several mass points (fuel, shroud, vessel) are selected at the same elevation. The various lengths of control rod drive (CRD) housings are grouped into the two representative lengths shown. These lengths represent the longest and shortest housings in order to adequately represent the full range of frequency response of the housings. The high fundamental natural frequencies of the CRD housings result in very small seismic loads. Furthermore, the small frequency differences between the various housings due to the length differences result in negligible differences in dynamic response. Hence, the modeling of intermediate length members becomes unnecessary. Not included in the mathematical model are light components such as jet pumps, incore guide tubes and housings, spargers, and their supply headers. This is done to reduce the complexity of the dynamic model. If the seismic responses of these components are needed, they can be determined after the system response has been found.

The presence of a fluid and other structural components; e.g., fuel within the RPV, introduces a dynamic coupling effect. Dynamic effects of water enclosed by the RPV are accounted for by introduction of a hydrodynamic mass matrix, which serves to link the acceleration terms of the equations of motion of points at the same elevation in concentric cylinders with a fluid entrapped in the annulus. The seismic model of the RPV and internals has two horizontal coordinates for each mass point considered in the analysis. The remaining translational coordinate (vertical) is excluded, because the vertical frequencies of RPV and internals are well above the significant horizontal frequencies. Furthermore, all support structures, building and containment walls, have a common centerline, and, hence, the coupling effects are negligible. A separate vertical analysis is performed as discussed in sections 3.7B.2 and 3.7B.3. Dynamic loads due to vertical motion are added to or subtracted from the static weight of components, whichever is the more conservative. The two rotational coordinates about each node point are excluded because the moment contribution of rotary inertia from surrounding nodes is small. Since all deflections are assumed to be within the elastic range, the rigidity of some components may be accounted for by equivalent linear springs.

The shroud support plate is loaded in its own plane during a seismic event and, hence, is extremely stiff and may be modeled as a rigid link in the translational direction. The shroud support gussets and the local flexibilities of the RPV and shroud contribute to the rotational flexibilities and are modeled as an equivalent torsional spring.

The RPV system model assumed use of 100-mil-thick fuel assembly channels. The effects of using 80-mil channels on RPV internal loadings were evaluated<sup>(1)</sup> and found to be negligible.

#### **3.7B.2.1.6.4 Vertical Seismic Analysis**

The seismic loads acting on the structures within the RPV are based on a vertical dynamic analysis of a model shown in figure 3.7B-1.

The mathematical model represents the RPV, RPV internals, pedestal, and the shield wall. The system is represented by lumped masses and a set of springs idealizing both the inertial and stiffness properties of the system. Between mass points, the structural properties are reduced to uniform beam segments of cross-sectional area, effective shear area, and moment of inertia. The base is considered to be fixed. The effect of the surrounding water inside the RPV is included by applying concentrated mass unit to the node points in the mathematical model.

Seismic analysis is performed to determine the system natural frequencies and mode shapes. The relative displacement, acceleration, and load response are then determined for each node of interest and for each mode of vibration. The square-root-of-the-sum-of-the-squares (SRSSs) of these responses is then used for design calculations.

As shown in table 3.9-4, vertical seismic loads are applied to the reactor internals as a function of component weight statically applied. Because the fuel assembly with 80-mil channels weighs ~ 2% less than with 100-mil channels, the loads reported in table 3.9-4 conservatively bound the vertical seismic loads that would result if 80-mil channels were used.

#### **3.7B.2.1.7 Dynamic Analysis of Seismic Category I Structures, Systems, and Components**

Time-history techniques and the response spectrum technique are used as applicable for the dynamic analysis of Seismic Category I structures, systems, and components that are sensitive to dynamic seismic events.

##### **3.7B.2.1.7.1 Dynamic Analysis of Piping Systems**

Each pipeline is idealized as a mathematical model consisting of lumped masses connected by elastic members. The stiffness matrix for the piping system is determined using the elastic properties of the pipe. This includes the effects of torsional, bending, shear, and axial deformations as well as change in stiffness due to curved members. Next the mode shapes and the undamped natural frequencies are obtained. The dynamic response of the system is calculated by using the response spectrum method of analysis. When the piping system is being anchored and supported at points with different excitation, the response spectrum analysis is performed using the response spectrum above the center of mass of the piping system.

The relative displacement between anchors is determined from the dynamic analysis of the structures. The results of the relative anchor point displacement are used for a static analysis to determine the additional stresses due to relative anchor point displacements.

The dynamic model of the steam line piping system is given in figure 3.7B-2.

### 3.7B.2.1.7.2 Dynamic Analysis of Replacement Recirculation Piping

- A. The replacement recirculation piping seismic design adequacy evaluation is completed by applying the multi-support excitation response spectrum methodology associated with the theoretical development described in paragraph 3.7B.2.1.2.1.
- B. The continuous piping system is modeled as an assemblage of one-dimensional straight- or curved-pipe elements. The mass of each pipe element is lumped at its end nodes. The mass nodes are interconnected by an assemblage of weightless pipe elements. The weightless pipe element section properties reflect the stiffness characteristics of the corresponding segments of the piping system. The pipe element lengths between mass points are no greater than that of a simply supported beam of uniformly distributed mass having a fundamental frequency of 33 Hz. In addition, mass nodes are located at ends of elbows, tees, and at all pipe-mounted components, such as valves, pumps, and motors. The rotational effects of valve operators and other equipment with offset centers of gravity are included in the analytical model.
- C. To account for the effects of parameter variations on the primary structure (reactor building) calculated frequencies, the piping input response spectra are peak broadened  $\pm 10\%$ .
- D. Maximum colinear response contributions due to the three spatial components of seismic excitation are combined by the SRSSs method.
- E. Peak modal responses are combined by the double sum method which accounts for the effects of closely spaced modes. This method is defined mathematically by:

$$R = \left[ \sum_{k=1}^N \sum_{s=1}^N |R_k R_s| \epsilon_{ks} \right]^{1/2} \quad (18)$$

where:

- R = representative maximum value of a particular response in a given element due to a given component of excitation.
- $R_k$  = peak value of the response of the element due to the  $k^{\text{th}}$  mode.
- N = number of significant modes included in the modal superposition.

HNP-2-FSAR-3

$R_s$  = peak value of the element response contributed by the  $s^{\text{th}}$  mode.

Also,

$$\epsilon_{ks} \left[ 1 + \left( \frac{\omega'_k - \omega'_s}{\beta_k \omega_k + \beta_s \omega_s} \right)^2 \right]^{-1} \quad (19)$$

in which

$$\omega'_k = \omega_k (1 - \beta_k^2) \quad (20)$$

and

$$\beta'_k = \beta_k + \frac{2}{t_{dk}} \quad (21)$$

The quantities  $\omega_k$  and  $\beta_k$  are the modal frequency and modal damping coefficient, respectively, for the  $k^{\text{th}}$  mode;  $t_d$  is the duration of the earthquake. If there are no closely spaced modes, the double sum and SRSSs methods yield identical results.

- F. Piping structural damping, specified in table 3.7B-1, is 0.5% for operating basis earthquake (OBE) and 1.0% for design basis earthquake (DBE).
- G. The cut-off frequency for the seismic analysis is 33 Hz which corresponds approximately to the zero period acceleration frequency of the floor response spectra. The seismic free-field input motion for OBE and DBE analyses performed for HNP-2 are defined in figures 3.7A-1 and 3.7A-2.
- H. Combination of Primary and Secondary Stresses - The inertia and displacement effects due to differential support motion are dynamic in nature, and their peak values have a very low probability of occurring at the same instant in time. Therefore, a combination of the peak inertia and the differential anchor displacement responses is conservative. Moreover, anchor movement effects are computed from static analyses in which the displacements are applied in the most unfavorable manner possible to produce the most conservative responses. In view of this, inertia and displacement effects can be combined by the SRSSs method.
- I. Multi-Support Response Spectrum Analysis - The theoretical basis for the multi-support excitation methodology is described in paragraph 3.7B.2.1.2.1. For the multi-support response spectrum method, all input motions corresponding to piping support points located at the same elevation of the same primary structure substructure (e.g., RPV inlet manifold) are assumed to be 100% correlated. Consequently, corresponding response contributions due to each of the input motions are algebraically combined in the computer analysis.

Piping input motions for supports located at different elevations on the same substructure or located on different substructures are assumed to be uncorrelated in the analysis. Associated response contributions for the uncorrelated input motions are combined in the analysis by the SRSSs method.

In the computer analysis, different support points with the same input motion designation number are treated as correlated. Corresponding responses due to each of these identical input motions are consequently algebraically combined. Support points with different input motion designation numbers are treated as uncorrelated, and corresponding responses are combined by the SRSSs method.

### **3.7B.2.1.7.3 Dynamic Analysis of Equipment**

Equipment is idealized as a mathematical model consisting of lumped masses connected by elastic members or springs. Results for some selected large Seismic Category I equipment are given in table 3.7B-2.

Seismic loadings due to two orthogonal horizontal directions and the vertical are combined as detailed in paragraph 3.7B.2.1.4.

When the equipment is supported at more than two points located at different elevations in the building, the response spectra at the elevation near the center of gravity of the equipment is chosen as the design spectra.

The relative displacement between supports is determined from the dynamic analysis of the structure. The relative support point displacements are used for a static analysis to determine the additional stresses due to support displacements. Further details are given in subsection 3.7B.2.7.

### **3.7B.2.1.8 Seismic Qualification by Testing**

For certain Seismic Category I equipment and components where dynamic testing is necessary to ensure functional integrity, test performance data and results reflect the following:

- Performance data of equipment that, under the specified conditions, has been subjected to dynamic loads equal to or greater than those to be experienced under the specified seismic conditions.
- Test data from previously tested comparable equipment that, under similar conditions, was subjected to dynamic loads equal to or greater than those specified.
- Actual testing of equipment in accordance with one of the methods described in sections 3.9 and 3.10.

Alternate test procedures that satisfy the requirements of these criteria are allowed.

### **3.7B.2.2 NATURAL FREQUENCIES AND RESPONSE LOADS**

This subsection is covered in subsection 3.7A.2.2.

### **3.7B.2.3 PROCEDURES USED TO LUMP MASSES**

Paragraph 3.7B.2.1.6.2 discusses criteria used by General Electric in lumping masses.

### **3.7B.2.4 ROCKING AND TRANSLATIONAL RESPONSE SUMMARY**

This subsection is covered in subsection 3.7A.2.4.

### **3.7B.2.5 METHODS USED TO COUPLE SOIL WITH SEISMIC-SYSTEM STRUCTURES**

This subsection is covered in subsection 3.7A.2.5.

### **3.7B.2.6 DEVELOPMENT OF FLOOR RESPONSE SPECTRA**

This subsection is covered in subsection 3.7A.2.6.

### **3.7B.2.7 DIFFERENTIAL SEISMIC MOVEMENT OF INTERCONNECTED COMPONENTS**

The procedure for considering differential displacements for equipment anchored and supported at points with different displacement excitation is discussed in the following paragraphs.

The relative displacements between the supporting points induce additional stresses in the equipment supported at these points. These stresses can be evaluated by performing a static analysis where each of the supporting points is displaced a prescribed amount. From the dynamic analysis of the complete structure, the time history of displacement at each supporting point is available. These displacements are used to calculate stresses. The time history of stresses thus obtained is a superposition of all modal displacements of the structure at each instant of time.

In the static calculation of the stresses due to relative displacements in the response spectrum method, the maximum value of the modal displacement is used. Therefore, the mathematical model of the equipment is subjected to a maximum displacement at its supporting points obtained from the modal displacements. This procedure is repeated for the significant modes (modes contributing most to the total displacement response at the supporting point) of the structure. The total stresses due to relative displacement are obtained by combining the modal results using the SRSSs method. Since the maximum misplacements for different modes do not occur at the same time, the SRSSs method is a realistic and practical method.

When a component is covered by the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, the stresses due to relative displacement as obtained above are treated as secondary stresses.

**3.7B.2.8 EFFECTS OF VARIATIONS ON FLOOR RESPONSE SPECTRA**

Except for replacement recirculation piping input spectra, this paragraph is covered in subsection 3.7A.2.8. Peak broadening for the replacement recirculation piping is covered in paragraph 3.7B.2.1.7.2.

**3.7B.2.9 USE OF CONSTANT VERTICAL LOAD FACTORS**

This subsection is covered in subsection 3.7A.2.9.

**3.7B.2.10 METHODS USED TO ACCOUNT FOR TORSIONAL EFFECTS**

This subsection is covered in subsection 3.7A.2.10.

**3.7B.2.11 COMPARISON OF RESPONSES**

The comparison between the calculated seismic load in the RPV and internals is given in table 3.7B-3.

**3.7B.2.12 METHODS FOR SEISMIC ANALYSIS OF DAMS**

This subsection is covered in subsection 3.7A.2.12.

**3.7B.2.13 METHODS USED TO DETERMINE SEISMIC CATEGORY I STRUCTURE OVERTURNING MOVEMENTS**

This subsection is covered in subsection 3.7A.2.13.

**3.7B.2.14 ANALYSIS PROCEDURE FOR DAMPING**

This subsection is covered in subsection 3.7A.2.14.

### 3.7B.3 SEISMIC SUBSYSTEM ANALYSIS

#### 3.7B.3.1 DETERMINATION OF NUMBER OF EARTHQUAKE CYCLES

To evaluate the number of cycles that exist within a given earthquake, a typical boiling water reactor building-reactor dynamic model was excited by three different recorded time histories - May 18, 1940, El Centro NS component 29.4 s; 1952, Taft, N 69° W component, 30 s; and March 1957, Golden Gate S80E component, 13.2 s. The modal response was truncated so that the response of three different frequency bandwidths could be studied: 0 to 10 Hz, 10 to 20 Hz, and 20 to 50 Hz. This was done to give a good approximation to the cyclic behavior expected from structures with different frequency content.

By enveloping the results from the three earthquakes and by averaging the results from several different points of the dynamic model, the cyclic behavior, as given in table 3.7B-4, was determined.

Independent of earthquake or component frequency, 99.5% of the stress reversals occur below 75% of the maximum stress level, and 95% of the reversals lie below 50% of the maximum stress level. This relationship is graphically shown in figure 3.7B-3.

In summary, the cyclic behavior number of fatigue cycles of a component during an earthquake is found in the following manner:

- A. The fundamental frequency and peak seismic loads are found by a standard seismic analysis.
- B. The number of cycles that the component experiences are found in table 3.7B-4 according to the frequency range within which the fundamental frequency lies.
- C. For fatigue evaluation, 0.5% of these cycles is conservatively assumed to be at the peak load 4.5% at three-quarter peak. The remainder of the cycles will have negligible contribution to fatigue usage.

The DBE has the highest level of response. However, the encounter probability of the DBE is so small that it is not necessary to postulate the possibility of more than one DBE during the 40-year life of a plant. Fatigue evaluation due to the DBE is not necessary since it is a faulted condition and thus not required by ASME Code, Section III.

The OBE is an upset condition and, therefore, must be included in fatigue evaluations according to ASME Code, Section III. Investigation of seismic histories in preliminary safety analysis reports (PSARs) of many plants shows that during a 40-year life it is probable that five earthquakes with intensities one-tenth of the DBE intensity and one earthquake ~ 20% of the proposed DBE intensity will occur. Therefore, the probability of even an OBE is extremely low. To cover the combined effects of these earthquakes and the cumulative effects of even lesser earthquakes, one OBE intensity earthquake is postulated for fatigue evaluation.



### 3.7B.3.2 BASIS FOR SELECTION OF FORCING FREQUENCIES

All frequencies in the range of 0.25 Hz to 33 Hz are considered in the analysis and testing of structures, systems, and components.

### 3.7B.3.3 SQUARE-ROOT-OF-THE-SUM-OF-THE-SQUARES

The SRSSs combination of modal responses is defined mathematically as:

$$R = \sqrt{\sum_{i=1}^n (R_i)^2} \quad (22)$$

where:

R = combined response.

R<sub>i</sub> = response in the i<sup>th</sup> mode.

n = number of modes considered in the analysis.

### 3.7B.3.4 PROCEDURE FOR COMBINING MODAL RESPONSES

When the response spectra method of modal analysis is used, all modes are combined by the SRSSs method as described in paragraph 3.7B.2.1.4.

Modal responses for the replacement recirculation piping seismic analysis are combined by the double sum method as described in paragraph 3.7B.2.1.7.2.

### 3.7B.3.5 SIGNIFICANT DYNAMIC RESPONSE MODES

When the natural frequency of a structure or component is unknown, it may be analyzed by applying a static force at the center of mass. To conservatively account for the possibility of more than one significant dynamic mode, the static force is calculated as 1.5 times the mass times the maximum acceleration from the response spectra of the point of attachments of multi-span structures. For structures that be reasonably approximated by a single-degree-of-freedom model, the peak spectral acceleration is used.

### 3.7B.3.6 DESIGN CRITERIA AND ANALYTICAL PROCEDURES FOR PIPING

This subsection is covered in subsection 3.7A.3.6.

### **3.7B.3.7 BASIS FOR COMPUTING COMBINED RESPONSE**

The two horizontal components and one vertical component of ground motion are accounted for by obtaining two sets of seismic results. First, the maximum value of the horizontal component of the earthquake is assumed to act in one horizontal direction simultaneous with the vertical component, and the loads are computed for this combination. Next, the maximum value of the horizontal component of the earthquake is assumed to act perpendicular to the direction previously assumed and simultaneous with the vertical component, and loads are computed for this combination. The larger of these two loads at each point in the system is used for design.

This method of analysis is based on the fact that the seismologist specifies the maximum resultant value of the horizontal component of the earthquake when specifying the horizontal component of the DBE. This method conservatively assumes that the horizontal and vertical components of the earthquake response occur simultaneously.

For the replacement recirculation piping seismic analysis, the corresponding colinear responses due to the three spatial components of seismic excitation are combined by the SRSSs method as described in paragraph 3.7B.2.1.7.2.

### **3.7B.3.8 AMPLIFIED SEISMIC RESPONSES**

This subsection is covered in subsection 3.7A.3.8.

### **3.7B.3.9 USE OF SIMPLIFIED DYNAMIC ANALYSIS**

For equipment and piping supplied or analyzed by the General Electric Company, a simplified dynamic analysis is not used.

### **3.7B.3.10 MODAL PERIOD VARIATION**

This subsection is covered in subsection 3.7A.3.10.

### **3.7B.3.11 TORSIONAL EFFECTS OF ECCENTRIC MASSES**

Torsional effects of eccentric masses are discussed in paragraph 3.7B.2.1.6.1.

When the torsional effect of an eccentric mass is likely to have a significant effect on the results of an analysis, the eccentric mass is included in the analytical mode. If the pipe stresses due to an eccentric mass are expected to be insignificant, the offset moment due to the eccentric mass is usually negligible.

### **3.7B.3.12 PIPING OUTSIDE CONTAINMENT STRUCTURE**

This subsection is covered in subsection 3.7A.3.12.

### **3.7B.3.13 INTERACTION OF OTHER PIPING WITH SEISMIC CATEGORY I PIPING**

When other piping is attached to Seismic Category I piping, the other piping is analytically simulated in a manner that does not significantly degrade the accuracy of the analysis of the Seismic Category I piping. Furthermore, the other piping is designed to withstand the DBE without failing in a manner that would cause the Seismic Category I piping to fail.

### **3.7B.3.14 FIELD LOCATION OF SUPPORTS AND RESTRAINTS**

The field location of seismic supports and restraints for Seismic Category I piping and piping system components is selected to satisfy the following two conditions:

- A. The location selected must furnish the required response to control strain within allowable limits.
- B. Adequate building strength for attachment of the components must be available.

The final location of seismic supports and restraints for Seismic Category I piping, piping system components, and equipment, including the placement of snubbers, is checked against the drawings and instructions issued by the engineer. An additional examination of these supports and restraints devices by an engineer who is competent in the design of Seismic Category I systems and components is made to assure that the location and characteristics of these supports and restraining devices are consistent with the dynamic and static analyses of the systems.

### **3.7B.3.15 SEISMIC ANALYSIS FOR FUEL ASSEMBLIES, CONTROL RODS, AND CRDs**

The seismic analysis of the reactor is described in paragraph 3.7B.2.1.6.3.

### **3.7B.4 SEISMIC INSTRUMENTATION PROGRAM**

This section is covered in section 3.7A.4.

### **3.7B.5 SEISMIC DESIGN CONTROL**

#### **3.7B.5.1 SEISMIC INPUT DATA OF PURCHASE SPECIFICATION FOR SEISMIC CATEGORY I COMPONENTS AND EQUIPMENT**

The seismic design specification includes criteria for application to purchase equipment. These criteria stipulate the minimum design requirements for Seismic Category I equipment attached to the structure in which it is located.

The seismic criteria are in the form of conservative static coefficients based on expected response spectra from seismic history data.

The responsible equipment design engineers include the appropriate static responses in the purchase specifications. Guidance and counsel of expert dynamicists are available to the design engineers. The applicable discipline chief engineer or expert dynamicist design review includes purchase specifications for proper inclusion and display of necessary data.

#### **3.7B.5.2 PROGRAM FOR AUDITING VENDOR SEISMIC ANALYSIS AND TESTS OF SEISMIC CATEGORY I COMPONENTS AND EQUIPMENT**

The responsible equipment design engineers ensure the adequacy and validity of the analyses and/or tests employed by the vendors of Seismic Category I components and equipment.

Vendor analyses and/or test plans and data are submitted to the responsible design engineer. The material to be submitted has been agreed upon as a part of the purchase specification. The responsible engineer agrees with the submitted material, in writing, only after he is satisfied that it meets the design specification requirements. Guidance and counsel of expert dynamicists from the applicable discipline chief engineer's staff are made available to the responsible design engineers in the course of such reviews.

#### **3.7B.5.3 EQUIPMENT TESTING AND TEST EVALUATION**

Seismic Category I equipment, which is difficult to represent in a mathematical model for calculations or which was required to demonstrate its ability to remain operating without changing the mode or its operation (such as level switch, which should not switch from on to off or vice versa during the earthquake) was subjected to actual vibration inputs on shake tables.

These shake tests were performed by qualified laboratories for the equipment suppliers.

The seismic qualification in the laboratory generally followed the same procedures, which consisted of the following:

- A. The equipment was mounted on the shake table in such a manner as to represent its installed condition.

## HNP-2-FSAR-3

- B. Sine sweep tests were performed, covering all practical frequency ranges with constant or variable acceleration levels to determine the resonance frequencies of the equipment. This procedure permits the determination of the predominant mode periods by monitoring the output response.
- C. With the predominant period thus obtained, it was used for the determination of the necessary acceleration levels, which were obtained from the applicable floor response spectra developed for 1% damping.
- D. With acceleration levels and predominant frequencies obtained, the full level of endurance tests was performed to establish the capability of equipment to withstand and to function during the effects of the accelerations corresponding to the resonance frequency. This is accomplished by one of the following methods:
  - 1. Sine dwell test

This test uses a sine wave function with one of the equipment natural frequencies and the corresponding acceleration levels as input vibrations. The test duration is generally 30 s, during which time the behavior of the equipment is observed and recorded.
  - 2. Sine beat tests

A sine beat function with number of beats and cycles per beat corresponding to the equipment natural frequency and with predetermined acceleration level is used as input motion to test and record the behavior of the equipment tested.

A slightly different procedure was also used by Wyle Laboratories in testing sensitive instrumentation and control equipment. In lieu of resonance search and endurance tests, a sine wave function, which when integrated resulted in the same shape and intensity as the given floor response spectra for 1%, was developed. The equipment was then tested using this function as an input. This approach simulates the actual conditions that the equipment would undergo during the actual specified earthquake. The behavior of the equipment was observed and recorded to ensure its capability to withstand the input vibrations.

In all cases the testing was performed for both horizontal and vertical vibrations separately.

### **3.7B.5.4 ACCEPTANCE**

Where calculations were performed, using the seismic coefficients or floor response spectra curves, the equipment was generally modeled as a multi- or single-lumped mass model for frequency analysis.

All calculations, test procedures, and results supplied by equipment manufacturers or their laboratories were reviewed and accepted by qualified specialist engineers prior to release of equipment for shipment.

## HNP-2-FSAR-3

### REFERENCES

1. Letter SLI-8305, R. E. Engel (S. Levy, Inc.) to L. T. Gucwa (GPC), "Edwin I. Hatch Nuclear Plant, Unit 2, Evaluation of 80-mil Fuel Assembly Channels," May 6, 1983.

TABLE 3.7B-1

## CRITICAL DAMPING RATIOS FOR DIFFERENT MATERIALS

| <u>Item</u>                                                    | <u>Percent Critical Damping</u> |                      |
|----------------------------------------------------------------|---------------------------------|----------------------|
|                                                                | <u>OBE Condition</u>            | <u>DBE Condition</u> |
| Reinforced concrete structures                                 | 3.0                             | 5.0                  |
| Welded structural assemblies<br>(equipment and supports)       | 2.0                             | 3.0                  |
| Bolted or riveted structural assemblies                        | 3.0                             | 5.0                  |
| Vital piping systems                                           | 0.5                             | 1.0                  |
| Drywell - building (coupled)                                   | 3.0                             | 5.0                  |
| Suppression chamber                                            | 2.0                             | 3.0                  |
| RPV, support skirt, shroud head,<br>separator, and guide tubes | 2.0                             | 3.0                  |
| Fuel                                                           | 7.0                             | 7.0                  |
| Steel frame structures                                         | 3.0                             | 5.0                  |
| Translation and rotation of soil                               | 4.0                             | 5.0                  |

- 
1. Other values may be used if they are indicated to be reliable by experiment or study.
  2. As of April 4, 1985, damping per figures 3.7A-22 and 3.7A-23 for piping systems and cable tray supports, respectively, is used for all new and replacement systems and load reconciliation work.

TABLE 3.7B-2

**COMPARISON OF CALCULATED SEISMIC LOADS TO DESIGN  
SEISMIC LOADS OF SEISMIC CATEGORY I EQUIPMENT, DBE CONDITION**

| <u>Equipment</u>                                 | <u>Calculated Results</u>     |                          | <u>Design<br/>Seismic<br/>Load</u> |
|--------------------------------------------------|-------------------------------|--------------------------|------------------------------------|
|                                                  | <u>Natural<br/>Frequency</u>  | <u>Seismic<br/>Loads</u> |                                    |
| High-pressure coolant injection pump and turbine | > 33 Hz                       | 0.43 g                   | 1.5 g                              |
| Reactor core isolation cooling pump and turbine  | > 33 Hz                       | 0.43 g                   | 1.5 g                              |
| Standby liquid control tank                      | > 33 Hz                       | 0.80 g                   | 1.5 g                              |
| Spent-fuel racks <sup>(c)</sup>                  | 8.5-12.1 Hz <sup>(a)(b)</sup> | 0.46 g                   | 1.5 g                              |
| Defective-fuel racks                             | 8.5-12.1 Hz <sup>(a)(b)</sup> | 0.46 g                   | 1.5 g                              |
| New-fuel racks                                   | 18.75 Hz <sup>(a)</sup>       | 0.22 g                   | 1.5 g                              |
| Refueling platform                               | 1.9 Hz                        | 26,400 psi               | 36,000 psi                         |
| Control room panels <sup>(c)</sup>               | -                             | -                        | -                                  |
| Fuel prep machine                                | > 0.79 Hz                     | 0.10 g                   | 1.5 g                              |
| Residual heat removal heat exchanger             | > 31 Hz                       | 0.40 g                   | 1.5 g                              |
| Hydraulic control unit                           | > 2.2 Hz                      | 1.40 g                   | 4.9 g                              |

a. 2% damping calculated lowest natural frequency.

b. Function of mode design and arrangement.

c. Holtec spent-fuel storage racks in the contaminated equipment storage area were analyzed using nonlinear dynamic analysis. Natural frequency and static acceleration coefficients are not applicable.



TABLE 3.7B-3

## COMPARISON OF THE MAXIMUM SEISMIC LOADS OF RPV AND INTERNALS

| <u>Location</u>                | <u>DBE Seismic Loads<sup>(a)(b)</sup></u> |                       | <u>Allowable Loads</u> |
|--------------------------------|-------------------------------------------|-----------------------|------------------------|
|                                | <u>N-S Excitation</u>                     | <u>E-W Excitation</u> |                        |
| Top guide shear (kips)         | 189                                       | 195                   | 430                    |
| Core plate shear (kips)        | 180                                       | 186                   | 430                    |
| Stabilizer force (kips)        | 514                                       | 916                   | 1800                   |
| Shroud moment (in.-kips)       | $165 \times 10^3$                         | $174 \times 10^3$     | $300 \times 10^3$      |
| Shroud shear (kips)            | 723                                       | 755                   | 1200                   |
| Vessel skirt moment (in.-kips) | $243 \times 10^3$                         | $277 \times 10^3$     | $900 \times 10^3$      |
| Vessel skirt shear (kips)      | 843                                       | 970                   | 2400                   |

a. OBE moment is 8250 in.-lb/ bundle, and DBE moment is 16,500 in.-lb/ bundle.


b. Calculated loads shown assumed 100-mil-thick fuel channels.

HNP-2-FSAR-3

**TABLE 3.7B-4**

**NUMBER OF DYNAMIC RESPONSE CYCLES  
EXPECTED DURING A SEISMIC EVENT**

| Frequency band (Hz)   | 0 <sup>+</sup> to 10 | 10 to 20 | 20 to 5 |
|-----------------------|----------------------|----------|---------|
| No. of seismic cycles | 168                  | 359      | 643     |



ACAD


REV 19 7/01





**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**

**MATHEMATICAL MODEL**  
**RPV AND INTERNALS**

**FIGURE 3.7B-1**



- LEGEND:
- HANGER
  - ⊥ SHOCK SUPPRESSOR
  - ⊕ GUIDE
  - |> FLOW ELEMENT
  - ⊗ ANCHOR



ACAD 20307B2


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TYPICAL DYNAMIC MODEL OF  
STEAM LINE PIPING SYSTEM

FIGURE 3.7B-2



ACAD 20307B03

REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

DENSITY OF STRESS REVERSALS

FIGURE 3.7B-3

### **3.8 DESIGN OF SEISMIC CATEGORY I STRUCTURES**

#### **3.8.1 CONCRETE CONTAINMENT**

A steel containment system was selected for the Hatch Nuclear Plant (HNP); therefore, this section does not apply to the design.

#### **3.8.2 STEEL CONTAINMENT SYSTEM (AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME) CLASS MC COMPONENTS)**

The steel containment structure is designed to house the primary nuclear system and is referred to as the containment in the following sections. The steel containment structure is a part of the containment system whose functional requirement is the control of the release of radioactivity from the primary nuclear system. This section describes the structural design consideration for the containment. The following material discusses the information relative to the containment which provides the bases for design, construction, testing, and surveillance for the steel containment system.

The primary containment system houses the reactor pressure vessel (RPV), the reactor coolant recirculation system (RCRS), and other branch connections of the reactor coolant system (RCS). The primary containment is a pressure suppression system consisting of a drywell, pressure suppression chamber which stores a large volume of water, a connecting vent system between the drywell and pressure suppression chamber, isolation valves, a vacuum relief system, containment cooling systems, and other service equipment. The drywell is a steel pressure vessel in the shape of a light bulb, and the pressure suppression chamber is a torus-shaped steel pressure vessel located below and encircling the drywell. A vertical section of the drywell and suppression chamber is shown on drawing no. H-25000.

The primary containment system is designed to withstand the pressures resulting from a breach of the nuclear system process piping up to and including an instantaneous circumferential break of the reactor recirculation piping and provides a holdup for decay of any radioactive material released. The primary containment system also stores sufficient water to condense the steam released as a result of a breach in the nuclear system primary barrier and to supply the emergency core cooling system (ECCS).

##### **3.8.2.1 Description of the Containment**

###### **3.8.2.1.1 Drywell**

The drywell, shown on drawing no. H-25000, is a steel pressure vessel with a spherical lower portion 65 ft in diameter, a cylindrical upper portion 37 ft 1 in. in diameter, and an elliptical top head 30 ft 3 in. in diameter. The overall height is ~ 111 ft. The drywell rests on a concrete foundation and the inside is filled with concrete up to el 114 ft 6 in. Portions of the shell backed up by concrete resist local deformation and buckling. A sand pocket outside the drywell

between el 113 ft 2 in. and el 114 ft 6 in. provides a transition from fixed to free condition. The drywell is enclosed in a reinforced concrete structure for shielding purposes. Above the transition zone the drywell is separated from the reinforced concrete by an airgap of ~ 2 in. The airgap permits the containment vessel shell to deflect sufficiently, thereby allowing the jet load to be transferred to the surrounding concrete without rupturing the shell. Shielding over the top of the drywell is provided by removable, segmented, reinforced concrete shield plugs. In addition to the drywell head, one double-door airlock and two bolted equipment hatches are provided for access into the drywell.

The top portion of the drywell is removed during refueling operations. The head is held in place by bolts and is sealed with a double seal arrangement. The head is bolted closed when primary containment is required and is opened only when the primary coolant temperature is below 212°F and the pressure-suppression system is not required to be operational.

The double seal on the head flange provides a method for determining the leaktightness after the drywell head was replaced.

The design, fabrication, inspection, and testing of the drywell vessel comply with requirements of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section III, Nuclear Power Plant Components, Subsection NE, Requirements for Class MC Components, 1971 Edition, including 1971 Summer Addenda which pertain to containment vessels for nuclear power plants. The steel head and shell of the drywell are fabricated of SA-516 GR70 steel plate. Thermal stress in the steel shell due to temperature gradients is considered in the design.

Charpy V-notch impact tests were performed on specimens of all plate and forged materials.

Plates, forgings, and pipes of the drywell have an initial nil ductility transition temperature (NDTT) of ~ 0°F when tested in accordance with the appropriate code for these materials. It can be reasonably expected that the drywell is neither pressurized nor subjected to a substantial stress at temperatures below 30°F.

Provisions for protection of the drywell against missiles and pipe whip that can damage the primary containment are discussed in section 3.6.

#### **3.8.2.1.2 Pressure Suppression Chamber and Vent System**

The pressure suppression chamber is a steel torus-shaped pressure vessel located below and encircling the drywell, with a major diameter of 107 ft 1 in. and a cross-sectional inside diameter (ID) of 28 ft 1 in. The pressure suppression chamber contains the suppression pool and the airspace above the pool. Drawing no. H-25000 shows the section of the suppression chamber.

Large vent pipes connect the drywell and the pressure suppression chamber. A total of eight circular vent pipes are provided, each having an internal diameter of 6 ft 3 in. Jet deflectors are provided in the drywell at the entrance of each vent pipe to prevent possible damage to the vent pipes from jet forces which might accompany a pipe break in the drywell. The vent pipes are

provided with expansion joints which are enclosed within sleeves to accommodate differential motion between the drywell and suppression chamber.

The drywell vents are connected to a 4-ft-6-in.-diameter vent header in the form of a torus which is contained within the airspace of the suppression chamber. Projecting downward from the header are 80 downcomer pipes, 24 in. in diameter and terminating 4 ft 4 in. below the water surface of the pool.

The pressure suppression pool, which is contained in the pressure suppression chamber, initially serves as the heat sink for any postulated transient or accident condition in which the normal heat sink (main condenser or shutdown cooling system) is unavailable. Energy is transferred in the form of steam and water to the pressure suppression pool by either the discharge piping from the reactor pressure relief valves or the drywell vent system. The steam is condensed by the suppression pool. The condensed steam and any water carryover cause an increase in pool volume and temperature. Energy is removed from the suppression pool when the residual heat removal (RHR) system is operating in the suppression pool cooling mode. The pressure suppression pool also serves as a source of water for the ECCS.

Modifications made to the pressure suppression chamber and the drywell vent system due to hydrodynamic loads identified during the Mark I Containment Long-Term Program are presented in Supplement 3.8B.

### **3.8.2.1.3 Personnel and Equipment Access Locks**

One personnel access lock is provided for access to the drywell. The lock has two gasketed doors in series. The doors are mechanically interlocked to ensure that at least one door is locked during times when primary containment is required. However, breakglass stations are provided inside the drywell as well as inside the airlock and a selector switch is provided inside the reactor building to defeat these interlocks in case of a threat to the safety of plant personnel. Breaking of the glass or operation of the selector switch is annunciated in the control room. The locking mechanisms are designed so that a tight seal is maintained when the doors are subjected to either internal or external pressure. The seals on this access opening are capable of being tested for leakage. A general arrangement of the personnel lock is shown on drawing no. S-26583.

A personnel access hatch with double, testable seals is provided in the drywell head. This hatch is bolted in place.

Two equipment access hatches with double, testable seals are also provided. These hatches are bolted in place.

Personnel and equipment hatches are sized and located with full consideration of service required; accessibility for maintenance and periodic testing programs. A 2-in. minimum gap is maintained around the barrel of the personnel and equipment hatches as they pass through or enter into the concrete shield wall.



A control rod drive (CRD) removal hatch with double, testable seals is provided. This hatch is bolted in place and permits extensive maintenance of the drive mechanism if required.

Access to the pressure suppression chamber is provided at two locations. These are two 4-ft-diameter manhole entrances with double-gasketed bolted covers connected to the chamber by 4-ft-diameter steel pipes. These access ports are bolted closed when primary containment is required and are opened only when the primary system temperature is below 212°F and the pressure suppression system is not required to be operational.

The drywell head personnel access hatch, the drywell equipment door assembly, the drywell CRD removal hatch, the suppression chamber manhole entrance, and a typical detail of the double, testable seal are shown in figure 3.8-1.

#### **3.8.2.1.4 Penetrations**

Two general types of pipe penetrations are provided: those which must accommodate thermal movement as illustrated by figure 3.8-2, and those which experience relatively little thermal stress as shown by figures 3.8-3 and 3.8-4. Figure 3.8-5 shows a typical instrument penetration. Figures 3.8-6 and 3.8-7 show typical electrical penetration structural components and assembly details. Figure 3.8-8 shows typical traversing incore probe (TIP) penetrations.

Some piping penetrations such as those used for the steam lines have special provisions for thermal movement. In these penetrations, the process line is enclosed in a guard pipe that is attached to the main steam line through a multiple-head fitting. This fitting is a one-piece forging with integral flues. The guard pipe and flued head are designed to the same pressure requirements as the process line. The process line penetration sleeve is welded to the drywell and extends through the biological shield where it is welded to a two-ply expansion bellows assembly which in turn is welded to the flued-head fitting. The pipe is guided through pipe supports at the end of the penetration assembly to allow steam line movement parallel to the penetration and to limit pipe reactions of the penetration to allowable stress levels.

The bellows assembly on the condensate drain line penetration X-8 is a single layer clamshell design welded over the existing bellows assembly as shown in figure 3.8-2, sheet 3. The bellows assembly for the reactor main feedwater line penetration X-9A consists of two layers of clamshell-design bellows longitudinally welded together as shown on figure 3.8-2, sheet 4. The modifications to the bellows assemblies for penetrations X-8 and X-9A utilized and comply with the guidance provided in USNRC Generic Letter 89-09.

Where necessary, the penetration assemblies are anchored outside the containment to limit the movement of the line relative to the containment. The bellows accommodates the relative movement between the pipe and the containment shell.

The cold piping, ventilation duct, and instrument line penetrations are generally welded directly to the sleeves. In some cases, where stress analyses indicate the need, double flued-head fittings are used. Bellows and guard pipes are not necessary in these designs since the thermal stresses are small and are accounted for in the design of the weld joint.

The electrical penetrations are hermetically sealed with provisions for periodic leak testing at design pressure. The penetration canisters are factory assembled and tested, with the number of field welds held to a minimum. These seals meet the intent of Section III of the ASME Code.

TIP guide tube penetrations pass from the reactor building through the primary containment. Penetration of the guide tubes through the primary containment is sealed by means of brazing, which meets the requirements of the ASME Boiler and Pressure Vessel Code, Section VIII. These seals also meet the intent of Section III of the ASME Code.

The designation and function of these penetrations are shown in ***Technical Requirements Manual (TRM) table T7.0-1 (incorporated by reference into the FSAR)***.

### **3.8.2.2 Applicable Codes, Standards, and Specifications**

The following codes, standards, and specifications apply to the design, fabrication, erection, and testing of the containment:

- A. Regulations
  - 1. Title 10 Code of Federal Regulations (CFR) Part 50, Appendix J, "Primary Reactor Containment Leakage Testing for Water-Cooled Power Reactors."
  - 2. 29 CFR 1910, "Occupational Safety and Health Standards."
- B. Codes and Standard Specifications
  - 1. ASME Boiler and Pressure Vessel Code, Section III, Nuclear Power Plant Components, 1971 Edition including 1971 Summer Addenda.
  - 2. Institute of Electrical and Electronics Engineers (IEEE) Standard No. 317-1971, "Standard for Electrical Penetration Assemblies in Containment Structure for Nuclear Fueled Power Generating Stations."

#### Code Classification

The steel containment vessel is classified Class MC in accordance with Subarticle NA-2130, Section III of the ASME Code.

#### Code Compliance

The steel cylindrical shell and dome of the steel containment vessel, including all penetrations and attachments within the code jurisdictional boundaries defined in paragraph 3.8.2.1.4, is designed and constructed in strict accordance with Subsection NE, Class MC Components, including the requirements for quality assurance of Article NA-4000, and inspection requirements of Article NA-5000 of Section III of the ASME Code.

## HNP-2-FSAR-3

The containment vessel is code-stamped in accordance with the ASME Boiler and Pressure Vessel Code, Section III, Paragraph N-1610.

The bellows assemblies for penetrations X-9A (figure 3.8-2, sheet 4) and X-8 (figure 3.8-2, sheet 3) were modified in 1989. Design and fabrication of the new bellows assemblies conform to the requirements of subsection NE, Class MC Components, of Section III of the ASME Code, except for materials and stamping. Replacement materials for the new bellows assemblies for penetrations X-9A and X-8 are not code stamped but have been procured under the guidelines of NRC Generic Letter 89-09.

### C. Code Cases

1. ASME Code Case 1330-3, "Special Equipment Requirements," Section III, Approved by Council March 9, 1972.
2. ASME Code Case 1177-7, "Expansion Joints," Section VIII, Division 1, Approved by Council February 27, 1970.
3. ASME Code Case 1431, SA-350, Grade LF-2, for Class MC, Approved by Council August 8, 1969.
4. ASME Code Case 1443-1, "Radiography for Pipe," Section III, Approved by Council August 10, 1970.
5. ASME Code Case 1517, "Material Used in Pipe Fittings," Section III, Approved by Council March 9, 1972.

### D. State and Local Building Codes

Southern Standard Building Code (SSBC), 1969 Edition

### E. Nuclear Regulatory Commission (NRC), Regulatory Guides, General Design Criteria (GDC), Industry Standards and Specifications

1. NRC Regulatory Guides (Compliance is discussed in Appendix A.)  
  
Regulatory Guide 1.11, "Instrument Lines Penetrating Primary Reactor Containment" (March 1971).  
  
Regulatory Guide 1.29, "Seismic Design Classification" (August 1973).  
  
Regulatory Guide 1.46, "Protection Against Pipe Whip Inside Containment" (May 1973).  
  
Regulatory Guide 1.54, "Quality Assurance Requirements for Protective Coatings Applied to Water-Cooled Nuclear Power Plants" (June 1973).

## HNP-2-FSAR-3

Regulatory Guide 1.57, "Design Limits and Loading Combinations for Metal Primary Reactor Containment System Components" (June 1973).

Regulatory Guide 1.59, "Design Basis Floods for Nuclear Power Plants" (August 1973).

Regulatory Guide 1.63, "Electric Penetration Assemblies in Containment Structures for Water-Cooled Nuclear Power Plants" (October 1973).

*Regulatory Guide 1.64, "Quality Assurance Program Requirements for the Design of Nuclear Power Plants" (October 1973).* This guidance has been superseded by that contained in ASME NQA-1-1994, as described in the SNC Quality Assurance Topical Report (QATR).

2. GDC of 10 CFR 50 (Compliance is discussed in section 3.1.)

GDCs 1, 2, 3, 4, 16, 50, 52, and 53

3. Industry Standards

Nationally recognized industry standards, such as those published by American Society for Testing and Materials (ASTM), are used whenever possible to describe material properties, testing procedures, fabrication, and construction methods.

Applicable ASTM and American Welding Society (AWS) Material Standard Specifications permitted by Article NE-2000 of Section III of the ASME Code.

Applicable ASTM Standard Specifications for nondestructive methods of examination referenced in Article X-3000 of Section III of the ASME Code.

4. Specifications

The specification "For Furnishing and Delivery of Reactor Drywell and Suppression Chamber Containment Systems for Edwin I. Hatch Nuclear Plant - Unit 2," prepared in accordance with the requirements of paragraph NA-3350 of the ASME Code, Section III, was used for the design, furnishing, fabrication, delivery, unloading, erection, painting, and testing of the primary containment. A summary of the structural and other design requirements from this specification is given in paragraph 3.8.2.2.1 and other applicable portions in this chapter.

5. Bechtel Power Corporation Topical Report BN-TOP-1, "Testing Criteria for Integrated Leak Rate Testing of Primary Containment Structures for Nuclear Power Plants," Rev 1, November 1972.

### **3.8.2.2.1 Structural Specifications**

Structural specifications are prepared to cover the areas related to design and construction of the containment. These specifications emphasize important points of the industry standards for the design and construction of the containment and reduce options that otherwise would be permitted by the industry standards. The ASME Code cases listed in paragraph 3.8.2.2 were used to supplement the code requirements. The following areas are covered in the specifications and a summary of these requirements is described in paragraphs 3.8.2.3, 3.8.2.4, 3.8.2.5, 3.8.2.6:

- Design loads, loading combinations, and allowable stresses for the drywell, suppression chamber, ventlines, penetrations, and accessories.
- Materials for pressure retaining parts and appurtenances.
- Fabrication methods including welding requirements.
- Nondestructive examinations.

### **3.8.2.3 Loads and Loading Combinations**

The containment is designed for all credible conditions of loadings, including normal loads, loads resulting from a loss-of-coolant accident (LOCA), test loads, and loads due to adverse environmental conditions.

Critical loading combinations are those caused by a postulated loss of reactor coolant, by a postulated earthquake, or by a pipe rupture in the containment.

Wind and tornado loads, flood design bases, and seismic loads are given in sections 3.3, 3.4, and 3.7, respectively. Missile effects and the postulated pipe rupture effects are discussed in sections 3.5 and 3.6.

Chapter 15 provides information on the design pressure load.

#### **3.8.2.3.1 Loads**

The following loads are considered: dead loads, live loads, LOCA loads, thermal loads, wind and tornado loads, hydrostatic loads, earthquake loads, jet impingement loads, test loads, and penetration loads.

##### **A. Dead Loads (D)**

Structural dead loads consist of the weight of the containment shell, drywell concrete floor, welding pads, jet deflectors, vents, penetrations, pipe supports, supporting structures, platforms, handrails, spray headers, strainers, monorails,

## HNP-2-FSAR-3

drywell water seal assemblies, expansion bellows, suppression pool water, and accessories.

### B. Live Loads (L)

Live loads consist of design platform loads, equipment live loads specified by the equipment manufacturers, and all other live loads transmitted by the internal structures.

A live load of 40,000 lb was considered acting on any one of the drywell equipment access doors at any given time.

Weight of the water used to fill the drywell from el 203 ft 4 in. to el 227 ft during refueling was considered a live load for the drywell design.

Weight of air during initial and final testing of the containment vessels was considered a live load.

All catwalks and platforms, with the exception of the personnel lock, were designed for a live load of 75 lb/ft<sup>2</sup>.

A live load of 150 lb/ft<sup>2</sup> was considered for the personnel lock floor area.

### C. Earthquake Loads (E, E<sup>1</sup>)

Operating basis earthquake (OBE) loads E and design basis earthquake (DBE) loads E<sup>1</sup> obtained from the seismic analysis described in paragraph 3.8.2.4.6 were used in the containment design.

### D. Test Pressure and Temperature Loads (P<sub>t</sub>, T<sub>t</sub>)

Upon completion of erection, the bare containment vessel and its penetrations and appurtenances were tested for 70-psig (125% of the design pressure) pressure followed by a leak rate testing at 56 psig. This is the initial containment pressure testing.

The containment vessel was also tested for leakage before the plant went into operation and a few other times during the life of the plant. This is considered as final testing in design.

The pressure P<sub>t</sub> and the corresponding temperature at the time of the test T<sub>t</sub> for initial and final pressure testing were considered in design.

### E. Thermal Loads (T<sub>o</sub>, T<sub>a</sub>)

T<sub>o</sub> = Thermal effects and loads during normal operating or shutdown conditions, based on the most critical transient or steady-state condition.

## HNP-2-FSAR-3

$T_a$  = Thermal loads under thermal conditions generated by the postulated break and including  $T_o$ .

### F. Pipe Reaction Loads ( $R_o$ , $R_a$ , $R_e$ )

$R_o$  = Pipe reactions during normal operating or shutdown conditions, based on the most critical transient or steady-state condition.

$R_a$  = Pipe reactions under thermal conditions generated by the postulated break and including  $R_o$ .

$R_e$  = Pipe reactions under thermal conditions during event causing external pressure.

### G. External Pressure and Temperature Loads ( $P_e$ , $T_e$ )

The following external pressure,  $P_e$ , and temperature,  $T_e$ , were considered in design:

#### 1. Drywell and Vent Systems

|                             |                   |
|-----------------------------|-------------------|
| Design external pressure    | 2 psig at 150°F   |
| Operating external pressure | < 2 psig at 150°F |

#### 2. Suppression Chamber

|                             |                          |
|-----------------------------|--------------------------|
| Design external pressure    | 2 psig at 150°F          |
| Operating external pressure | < 2 psig at 50° to 100°F |

### H. Pressure Loads Due to LOCA ( $P_a$ )

The design pressure and temperature of the containment are greater than the peak pressure and temperature that would result from a postulated complete blowdown of the reactor coolant. This might occur through the rupture of the RCS up to and including the hypothetical double-ended severance of the largest reactor coolant pipe. Pressure transients resulting from a LOCA (section 15.3) serve as the basis for a containment design pressure.

The design pressure,  $P_a$ , is not exceeded during any subsequent long-term pressure transients caused by the combined effects of heat sources. These effects are overcome by the combination of safety features and heat sinks.

The following pressure and temperature loads were used in the design:

HNP-2-FSAR-3

1. Drywell and Vent Systems

Design internal pressure      56 psig at 340°F  
 Operating internal pressure    < 2 psig at 150°F

2. Suppression Chamber

Design internal pressure      56 psig at 340°F  
 Operating internal pressure    < 2 psig at 50° to 100°F

The design internal pressure is 90% of the maximum internal pressure.

I. Pipe Rupture Loads ( $Y_r$ ,  $Y_j$ ,  $Y_m$ )

$Y_r$  = Equivalent static load on the structure generated by the reaction on the broken high-energy pipe during the postulated break, and including an appropriate dynamic load factor to account for the dynamic nature of the load.

$Y_j$  = Jet impingement equivalent static load on a structure generated by the postulated break and including an appropriate dynamic load factor to account for the dynamic nature of the load.

The containment is designed for the following jet impingement loads resulting from pipe ruptures within the containment:

| <u>Location</u>                        | <u>Jet Force</u> | <u>Area of Influence</u> |
|----------------------------------------|------------------|--------------------------|
| Drywell sphere                         | 709,000 lb       | 3.94 ft <sup>2</sup>     |
| Drywell knuckle                        | 472,000 lb       | 2.63 ft <sup>2</sup>     |
| Drywell cylinder up to el 203 ft 9 in. | 472,000 lb       | 2.63 ft <sup>2</sup>     |
| Drywell head                           | 32,600 lb        | 0.181 ft <sup>2</sup>    |

The jet forces consist of steam and/or water at 340°F. Only one of the above jet forces is considered to act in the drywell at a given time.

$Y_m$  = Missile impact equivalent static load on a structure generated by or during the postulated break, as from pipe whipping, and including an appropriate dynamic load factor to account for the dynamic nature of the load.

J. Containment Flooding Loads ( $F_L$ )

$F_L$  = Loads generated by the post-LOCA flooding of the containment. In the event of a LOCA, the entire containment, including the suppression chamber, vent system, and the drywell, are flooded up to el 227 ft, and the resulting hydrostatic load,  $F_L$ , was considered in the containment design.



K. Hydrodynamic Loads for the Suppression Chamber

In performing large scale testing of an advanced design pressure suppression containment (Mark III), and during inplant testing of Mark I containments, suppression pool hydrodynamic loads not explicitly included in the original Mark I containment design basis were identified. These additional loads could result from dynamic effects of drywell air and steam being rapidly forced into the suppression pool during a postulated LOCA, and from suppression pool response to safety relief valve operation generally associated with plant transient operating conditions. Since these hydrodynamic loads were not explicitly considered in the original design of the Mark I containment, the NRC staff in early 1975 requested a detailed reevaluation of the containment system from each domestic utility with a Mark I containment. A two-phase program was established; it was described to the NRC in letters submitted during the week of May 5, 1975.

The phase I effort, called Short-Term Program (STP), provided a rapid confirmation of the adequacy of the containment to maintain its integrity under the most probable course of the postulated LOCA considering the latest available information on the important suppression pool dynamic loads. The STP was completed July 12, 1977, following the docketed submittal by Georgia Power Company (GPC) to the NRC of the HNP-2 plant-unique analysis report.<sup>(1)</sup> Review of this documentation led to issuance of the "Mark I Containment Short-Term Program Safety Evaluation Report," in December 1977.<sup>(2)</sup> This report concluded that licensed domestic boiling water reactor (BWR) Mark I facilities could continue to operate safely, without undue risk to health and safety of the public, during an interim period while the Long-Term Program (LTP) was conducted.

The phase II effort, the LTP, was initiated in June 1976. The LTP included detailed testing and analytical work to define more precisely the specific hydrodynamic loads appropriate for the anticipated life of the Mark I BWR facility. It also included detailed structural evaluation and modifications to restore the originally intended design-safety margins for the containment system.

The LTP was completed on September 16, 1983, following the docketed submittal by GPC to the NRC of the Plant Unique Analysis report.<sup>(21)</sup>

The hydrodynamic loads considered and a description of the pressure suppression chamber and drywell vent system modifications made during the STP and LTP are provided in supplement 3.8B.

**3.8.2.3.2 Effects of the Induced Strains on the Shell**

The primary membrane stresses were maintained within yield range for all loading combinations except when jet loadings were considered. As elastoplastic finite element analysis performed for jet impingement loading showed that the maximum computed total equivalent strain at the centerline of the jet load on the outer surface of the drywell shell backed up by concrete was

3.65%, which corresponded to a maximum computed equivalent stress of 45.1 ksi, which satisfies the fatigue requirements of figure I-9-1 of Section III of the ASME Code for 10 cycles.

### 3.8.2.3.3 Loading Combinations

The different loading combinations considered for the containment design were initial testing, final testing, normal operating, refueling, accident, and flooded. The loading combinations for the suppression pool hydrodynamic loads are included in supplement 3.8B.

#### A. Initial and Final Testings

The containment is subjected to the following loads associated with the initial and final testings for the containment:

$$D + L + P_t + T_t + E$$

$$D + L + P_t + T_t + E^1$$

#### B. Normal Operating

The containment vessel is under this condition for most of its lifetime. Applicable loads considered for this condition are:

$$D + L + T_o + R_o + E$$

$$D + L + T_o + R_o + E^1$$

$$D + L + T_e + R_e + P_e + E$$

$$D + L + T_e + R_e + P_e + E^1$$

#### C. Refueling

The plant is shut down for refueling operations about a month every year and the containment vessel is subjected to the following loads:

$$D + L + E$$

$$D + L + E^1$$

#### D. Accident

To maintain the integrity of the containment vessel, the following postulated LOCA loads were considered in the design:

$$D + L + T_a + R_a + P_a + E$$

$$D + L + T_a + R_a + P_a + E^1$$

$$D + L + T_a + R_a + P_a + Y_r + Y_j + Y_m + E^1$$

E. Flooded

The containment is flooded for accident recovery after a long period of time (months) following a LOCA. The loads corresponding to this condition are:

$$D + L + E + F$$

**3.8.2.3.4 Loading Combinations on Localized Areas**

A. Penetration Locations

Loads on penetrations due to thermal expansion, weight, earthquakes, and valve closure (when applicable) were obtained from corresponding piping system analysis and these penetration loads were applied to the shell at points of intersections and the combined effect of this load and containment internal design pressure were computed.

B. Drywell Embedment Zone

The drywell shell was analyzed at the point of embedment for the discontinuity stresses due to the pressure loads, differential thermal gradient loads, and shell dead and live loads, including seismic loads.

C. Drywell Knuckle Area

The drywell shell is analyzed in the region of the knuckle for the accident condition to determine the discontinuity stresses caused by pressure loads acting normal to the shell and by vertical loads resulting from dead, live, and seismic loads applied by the cylindrical shell.

D. Drywell Cone-to-Cylinder Intersections

Adequacy of the drywell cone-to-cylinder intersections is checked using ASME Code rules for design internal pressure acting at accident temperature coincident with the other loads specified in the loading combinations.

E. Drywell Top Head

The top head along with a portion of the cylinder above the flange is analyzed for the effects of the design internal pressure acting at accident temperature coincident with other loads specified in the loading combinations.

F. Drywell - Vent Line - Bellows Collar

The vent line along with its connection to the drywell and to the expansion bellows is analyzed for the effects of the design internal pressure, acting at accident temperature, in conjunction with the loads due to the bellows attachment resulting from the differential deflection of the vent line and suppression chamber due to thermal and pressure expansions and other loading specified in the loading combinations.

G. Drywell-to-Pedestal Intersection

The drywell shell in the region of the pedestal is analyzed for two sets of loading conditions. The first set of conditions is the construction condition with the operating and DBE loads along with the loads imposed by the weight of the shell and live loads contributed by scaffolding and other applicable temporary construction fixtures on the containment. The second set of loading conditions includes an overload test internal pressure of 70 psi in addition to all other loads considered above for the construction condition.

H. Drywell Flange

The drywell shell is analyzed in the region of the drywell flange for the accident condition to determine the discontinuity stresses. Pressure loads, thermal loads, bellows loads, and shell loads resulting from the preload on the flange bolts were considered for this analysis.

**3.8.2.4 Design and Analysis Procedures**

The steel containment vessel, which consists of a vertical freestanding cylindrical shell, elliptical top head, spherical bottom, and numerous penetrations and attachments, is considered to act as an independent structural component within the shield building.

The containment is analyzed for various loading combinations, taking into account the values of individual loads that generate the most significant stress condition for each component and member of the structure. The critical areas for analysis are as follows:

- Drywell.
- Pressure suppression chamber and vent system.
- Personnel and equipment access locks.

- Penetrations.
- Localized areas of discontinuities.

#### **3.8.2.4.1 Drywell**

The drywell shell is analyzed for stresses due to the loads and loading combinations given in paragraph 3.8.2.3. Primary membrane stresses are computed for each of the loading combinations and the resulting stresses are compared to ASME Code allowables. Membrane theory is used to compute primary membrane stresses due to internal pressure and vertical loads. Simple bending theory is used to determine the bending stresses due to horizontal shear and moment caused by lateral earthquake. Formulas from Section VIII of the ASME Code were used to design the top head, the cone, and the cylinder. The pressure stress resultants in the knuckle section are computed using the pressure area method outlined in L. P. Zick's paper.<sup>(3)</sup>

The sand pocket between el 113 ft 2 in. and el 114 ft 6 in. was considered to provide a transition zone at el 113 ft 2 in. and the drywell shell was assumed to dilate from a fixed to a free condition at this level. The drywell shell was considered as a freestanding shell fixed at the base and supported laterally by eight star truss connection lugs at ~ el 188 ft. No friction or bond resistance was considered to exist between the drywell and the concrete at the base.

#### **3.8.2.4.2 Pressure Suppression Chamber and Vent System**

The suppression chamber shell is analyzed for the effects of gaseous pressure loads, water pressure loads, and for the loads due to the seismic action on the weight of shell and contained water for the various design conditions given in paragraph 3.8.2.3.

Circumferential shell stresses are calculated based on an internal pressure that consists of internal gas pressure plus the hydrostatic head of water with seismic loads acting on the water using membrane theory.

Longitudinal stresses due to internal pressure consisting of internal gas pressure plus the hydrostatic head of water with seismic loads acting on the water are computed using membrane theory. Longitudinal stresses due to the weight of the shell and water acting together with seismic loads are computed by simple bending stress theories.

The suppression chamber shell is also checked for external pressure using applicable formulas in ASME Code, Section VIII.

Design and analysis procedures used in the evaluation of the pressure suppression chamber and vent system are summarized in supplement 3.8B.

#### 3.8.2.4.3 Personnel and Equipment Access Locks

The personnel lock has two gasketed doors in series which are mechanically interlocked so that one door cannot be opened unless the other door is sealed. Each door is designed so that, with the other door open, it is capable of withstanding an internal pressure inside the containment vessel of 56 psi or an external pressure of 2 psi. In addition, the interior door is equipped with tiedown devices so that the space between the doors can be tested. The interior door and interior bulkhead are designed to withstand a jet load of 709 kips over a circular area of 3.94 ft<sup>2</sup>. Analysis is accomplished by modeling the doors and bulkheads as beam structures.

The personnel lock barrel is designed as a cylindrical pressure vessel for internal and external pressures in accordance with the ASME Code rules. The shell insert plate is proportioned for area replacement and is checked for stresses due to weight of the lock and dynamic loading resulting from seismic activity. The lock floor is designed for a live load of 150 lb/ft<sup>2</sup>.

The equipment hatch is arranged so that the drywell internal pressure and/or jet load tend to force the head onto the barrel, thus seating the gaskets. However, the external pressure tends to force the hatch open and so the closure bolts are preloaded sufficiently to maintain leaktightness. The bolts are preloaded to create adequate friction against the displacement due to the weight of the head and seismic loads acting on it.

The equipment hatch is provided with a floor at 130 ft to facilitate access into the drywell. The floor and its attachments to the barrel are designed for a 40-kip load evenly distributed on two wheels at 70-in. centers with vertical and horizontal seismic loads acting with it. Other parts of the floor are designed to support a live load of 150 lb/ft<sup>2</sup>.

#### 3.8.2.4.4 Penetrations

Two types of penetrations considered on the spherical and cylindrical sections of the containment are those that have no mechanical loads applied and those that have mechanical loads applied.

The analysis of penetrations with no external loads consists of proportioning the pipe neck for pressure according to ASME Code, Section VIII, and proportioning the insert reinforcing plate according to ASME Code, Section III, requirements. The insert reinforcing plates are proportioned using a computer program developed to check the adequacy of preselected reinforcing plate dimensions and weld sizes in accordance with the area replacement criteria of ASME Code, Sections III and VIII.

The following steps were followed in the analysis of penetration with external loads:

- A. The pipe neck and the insert reinforcing plate were proportioned using the same methods as those applied for penetrations with no external loads.
- B. Penetration loads on the suppression chamber shell obtained from the piping system analysis were resolved into radial and tangential components. These loads and the penetration loads on the drywell were used to check the stresses on the

individual penetration necks using a computer program. This computer program computes maximum stress intensity for both the inside and outside surfaces based on basic Mohr's circle equations. The principal stresses are printed out and the stresses resulting from bending, axial load, shear loads, and torsion, as well as the value of the loads which cause the maximum stressed condition, are obtained.

- C. Initial pressure stresses are assumed in the insert reinforcing area in accordance with the requirements of ASME Code, Section III.
- D. Stresses in the shell and insert plate are checked using methods of Welding Research Council Bulletin 107.<sup>(4)</sup> This analysis is done by a computer program which is designed to determine the stress intensities in a sphere or cylinder at 12 different points around an externally loaded circular attachment. The program superimposes those stresses resulting from external loads on the initial pressure stresses. Stresses are computed at three levels of plate thicknesses: outside, inside, and centerline. Points selected for checking the stresses are: edge of attachment,  $1/2\sqrt{Rt}$  from the edge of attachment, and the edge of reinforcement where R is the inside radius of the vessel and t is the nominal thickness of the vessel. The program determines the normal stresses parallel to the vessel's longitudinal axis, the normal stresses in circumferential direction, and the shear stresses.

Flanges and penetration caps were designed in accordance with the rules of ASME Code, Section VIII.

#### **3.8.2.4.5 Localized Areas of Discontinuities**

The localized areas of discontinuities, with the exception of cone-to-cylinder intersections, are analyzed for loadings associated with accident conditions using the program for shells of revolution developed by A. Kalnins of Yale University.<sup>(5)</sup> This program is based upon a method of analysis published in the "Journal of Applied Mechanics," Volume 31, September 1964 and is derived from the fact that a rotationally symmetric shell may be divided into a number of short segments in the meridional direction and that the stiffness properties of each of these segments can be determined in relation to eight fundamental variables. By enforcing equilibrium and compatibility between segments and applying boundary conditions, the values of the fundamental variables were determined for each segment. Values between each segment end were determined by integration.

Adequacy of the drywell cone-to-cylinder intersections was checked using ASME Code rules. The half-apex angle is 30 degrees and, as a result, paragraph UA-5 of ASME Code, Section VIII, was applied. The intersections were checked for the accident condition with an internal pressure of 56 psi and allowable stresses based on 340°F.

#### 3.8.2.4.6 Seismic Analysis

The evaluation of the structural integrity of the steel containment vessel when excited by seismic motion is based on a dynamic analysis.

The steel containment vessel is designed to act as an independent structural component within the concrete bioshield building. The associated internals within the steel containment vessel are also designed to act as independent components. This independency and uncoupling of the major structural components of the containment internal system enables a very detailed dynamic mathematical model to be developed which provides for the realistic response of the containment system, and for which response spectra and/or time histories can be generated at the component interfaces, or at any point desired. These component response spectra and/or time histories were used to perform detailed dynamic analyses of the individual components.

In the dynamic analysis of the steel containment vessel component, a dynamic mathematical model is formulated which incorporates the general structural geometry and all significant boundary conditions present. The design of the numerous penetrations is such that any restraining forces on the steel containment vessel which could be developed can be considered as negligible. In the determination of the seismic response of the steel containment vessel a 2% damping value has been used for both OBE and DBE excitations.

The resulting equations of motion for the steel containment vessel were solved by the use of a large-capacity computer program. The solution algorithm used depends on the analytical method incorporated to evaluate the equations of motion for the system.

The results of the dynamic seismic analysis contain values for maximum translational accelerations, displacements, shears and moments, moments and rotations, as well as any response spectra and/or time histories desired at points throughout the steel containment vessel.

These resultant forces were then combined with the various loading conditions as described in paragraph 3.8.2.3 and in accordance with Subarticle NE-3131 of Section III of the ASME Code. These combined forces were used in the structural analysis of the various critical areas present within the steel containment vessel. By using a response spectra and/or time history, the cantilevered personnel locks, as well as other appurtenances, were dynamically analyzed.

For analytical purposes, each lock is assumed to be a beam cantilevered from the main body of the containment vessel. It is further assumed to vibrate in three independent directions as described in the following:

- A. Case I: Lock vibration in the meridional plane of the vessel due to vertical earthquake. This condition imposes a moment on the shell in the meridional plane of the vessel.
- B. Case II: Lock vibration in the circumferential plane of the vessel due to the combined effects of vessel translation and angular oscillation resulting from an applied horizontal earthquake acting perpendicular to the plane of the lock. This condition imposes a moment on the shell in the circumferential plane of the vessel.



- C. Case III: Lock vibration radial to the vessel due to an applied horizontal earthquake acting in the plane of the lock. This condition imposes a radial load on the shell.

In order to determine the seismic accelerations acting on the lock, a 1 degree-of-freedom system is assumed. After its natural periods of vibration are calculated for the longitudinal, circumferential, and radial directions of the containment vessel, the lock accelerations are determined from the floor response spectrum curves which are developed by the seismic analysis of the containment itself using the time-history technique. Equivalent dynamic loads of vibration are obtained by multiplying the accelerations by the mass of the lock. By applying these accelerations at the center of gravity of the lock, forces, moments, and shears transmitted to the shell are determined.

The resulting stress intensities due to the addition of seismic loads to the various loading conditions for the steel containment vessel and its appurtenances were kept in accordance with the stress intensity limits as specified in Subarticle NE-3131 of Section III of the ASME Code.

**3.8.2.4.6.1 Computer Program Utilized in the Seismic Dynamic Analysis.** The seismic dynamic analysis was performed using a large-capacity computer. The program is capable of generating the required mass and stiffness matrices which are required to represent the distributed mass and stiffness of the actual structure.

The structure was modeled by the use of any or all types of the following finite elements:

- Three-dimensional beam element.
- Triangular and quadrilateral plate and thin shell elements.
- Triangular and quadrilateral axisymmetric elements.
- Boundary elements as required.

The program provides for the solution of the resulting equations of motion and yields the desired number of eigenvalues and eigenvectors as required. The program can then be optioned to provide the solution of a reduced, if desired, set of uncoupled equations for response to a specified form of excitation. The excitation used can be either symmetric or asymmetric.

The program provides as output the geometry and topology of the constructed dynamic mathematical model as well as all pertinent information required in its description. The resulting eigenvalues (frequencies of vibration), the associated eigenvectors (modes of vibration) which can be normalized, and participation factors are provided. In the performance of the response analysis, the output includes the modal and/or system generalized forces, displacements, velocities, accelerations, and forces. This resulting output can be requested at either the member level, the joint level, or both.

**3.8.2.4.7 Computer Programs Used by Chicago Bridge and Iron Company (CB&I) for the Structural and Seismic Analysis of the Containment**

**3.8.2.4.7.1 CB&I Program 405 - Ring Analysis.<sup>(6)</sup>**

A. Description

This is a program used for the analysis of a ring with a constant moment of inertia and modulus of elasticity. The loads are in the plane of the ring. The mathematics are based upon the Hardy-Cross Column Analysis for rings. The loads can be moments, tangential, or radial to the ring. The printouts are coefficients at incremental distances around the ring. The printout titles for the output are as follows:

X = angle and degrees as measured from reference axes.

V = a radial shear with force units acting in a radial direction through the ring.

T = an axial thrust in the ring with units of force.

M/R = a coefficient with units of force when multiplied by the radius to the centroid equals a moment.

EI/RR = a coefficient which when multiplied by the radius<sup>2</sup> is equal to the rotation of the ring at the point.

REI/RR = a coefficient when multiplied by the radius equals the radial deflection of the point.

CEI/RRR = a coefficient when multiplied by the radius<sup>3</sup> equals the tangential deflection of the point.

B. Validation

The program was verified and document traceability is available at CB&I.

C. Extent of Application

The program is used to analyze a ring with constant moment of inertia and modulus of elasticity.

**3.8.2.4.7.2    CB&I Program 601 - Stresses at Specific Points.**

A.    Description

This program is based on the mathematics of Program 405. In addition, the coefficients have been multiplied by the proper radius. Consequently, the thrust and moment only have to be divided by the area and section modulus respectively to find the stresses at specific points.

B.    Validation

The program was verified and document traceability is available at CB&I.

C.    Extent of Application

This program is used in conjunction with the CB&I Program 405 to find the stresses at specific points.

**3.8.2.4.7.3    CB&I Program 655 - Shear Transfer from the Ring to the Shell.<sup>(7)</sup>**

A.    Description

This program is supplementary to CB&I Programs 405 and 601 and is applied to transfer the shear in the ring into the shell between the rings. The influence of the loads on any ring is not evaluated beyond the adjacent rings.

B.    Validation

The program was verified and document traceability is available at CB&I.

C.    Extent of Application

The program is used in conjunction with the CB&I Program 405 to transfer the shear in the ring into the shell between the rings.

**3.8.2.4.7.4    CB&I Program 7-81 N - Shell Stress at Discontinuities.<sup>(5)</sup>**

A.    Description

This shells of revolution program based on the ASME paper, "Analysis of Shells of Revolution Subjected to Symmetrical and Nonsymmetrical Loads," by A. Kalnins,<sup>(5)</sup> is a standard computer program in the industry. The program computes the stresses and displacements in thin-walled, elastic shells of revolution when they are subjected to static edge loads, surface loads, or arbitrary temperature distribution over the surface of the shell. The geometry of the shell must be symmetrical; however, the shape of the median may be arbitrary. The shell wall

## HNP-2-FSAR-3

may consist of four layers of different orthotropic materials, and the thickness and elastic property of each layer may vary along the median.

The program numerically integrates the eight ordinary first-order differential equations of the thin shell theory derived by H. Reissner.

The CB&I version of the shells of revolution program incorporated modifications on the method of input and the format of output.

### B. Validation

The results of the program were compared with those obtained by other shell programs, such as Seal and Cerl II, and were found to be in excellent agreement. Document traceability is available at CB&I.

### C. Extent of Application

The program is used in the analyses of the equipment hatch and personnel lock for the containment structure and for computing the shell stresses at discontinuities with the exception of nozzles.

## 3.8.2.4.7.5 **CB&I Program 6-20 - Local Stresses in Shells.**<sup>(4)</sup>

### A. Description

This program computes the local stresses in cylindrical and spherical shells due to a load or a combination of loads acting on a nozzle which penetrates the shell. The solution for local shell stresses is made using the dimensionless parameters (input) from the graphs in the Welding Research Council (WRC) Bulletin 107. When reinforcing is present, these parameters are found using the procedures of Biljaard as outlined in WRC 49 and 50.

Tests are performed in the cylinder and sphere subroutines to see if either an insert or pad plate or no reinforcing is present. Depending on the results of these tests, a particular set of denominators is computed for use in the stress calculations in the stress subroutine. When reinforcing is present, the program checks the stress at the edge of the reinforcing.

### B. Validation

The program was verified and document traceability is available at CB&I.

C. Extent of Application

The program is used to compute the local stresses in cylindrical and spherical shells due to a load or combination of loads acting on a nozzle which penetrates the shell.

**3.8.2.4.7.6     CB&I Program 860 - Rigid Attachment to Spherical Shell.<sup>(4)</sup>**

A. Description

This program computes shell stresses around a rigid attachment to a spherical shell due to any combination of loading - radial, shear, or moment. The program uses the nomenclature, the curves for coefficients, and the mathematics of the WRC Bulletin 107. Given the basic geometry of the attachment, the program computes the parameters as required from figures SR-2 and SR-3 and the shell stresses around the attachment.

If the width of reinforcing is  $< 1.65$  times the square root of the spherical radius times either the thickness of the insert or an equivalent thickness for pads, the stresses are also checked at the edge of the reinforcing. All induced moments at the nozzle-to-shell junction and the induced moment,  $M_x$ , at the edge of reinforcing are increased by 20% to satisfy WRC 49 and 50 by Biljaard. If the width of reinforcing is  $> 1.65$  times the square root of the spherical radius times either the insert thickness or equivalent thickness, only the stresses at the nozzle-to-shell junction are computed. None of the induced moments is increased.

B. Validation

This program was verified and document traceability is available at CB&I.

C. Extent of Application

This program is used to compute shell stresses around a rigid attachment to a spherical shell due to any combination of loading - radial, shear, or moment.

**3.8.2.4.7.7     CB&I Program 1737.** The torus support system was originally analyzed by CB&I Program 1737. The description, validation, and extent of application are included in supplement 3.8B.

**3.8.2.4.7.8     CB&I Program 7-78 - Drywell Primary Membrane Stress Analysis.<sup>(8)</sup>**

A. Description

The program computes the primary membrane stresses and compares, to the ASME Code, allowable stresses for different loading combinations. In addition, the

## HNP-2-FSAR-3

program computes compressive stresses and compares to allowable buckling stresses.

The program uses the general primary membrane stress equations for axisymmetrically loaded shell of revolution derived in chapter 14 of "Theory of Plates and Shells," by Timoshenko.<sup>(8)</sup>

The program computes the allowable compressive stress resultants based on "Biaxial Compression - Equal Unit Forces" and "Biaxial Compression - Unequal Unit Forces" of the WRC Bulletin 69.

### B. Validation

The program was verified and document traceability is available at CB&I.

### C. Extent of Application

The program is used to calculate the drywell primary membrane stresses for different loading combinations.

#### **3.8.2.4.7.9 CB&I Program 772 -Nozzle Reinforcing.<sup>(9)</sup>**

### A. Description

This is a program for checking nozzle reinforcing. It is designed essentially for containment vessels and adheres to area replacement criteria specified by ASME Code, Sections III and VIII.<sup>(9)</sup> The program does no design work, merely checking the adequacy of preselected reinforcing plate dimensions and weld sizes.

### B. Validation

The program by itself does not have the capability to analyze a structure. It merely checks the adequacy of reinforcing plate dimensions and weld sizes. Consequently, validation is not necessary.

### C. Extent of Application

The program is used to check the adequacy of plates used for nozzle reinforcing.

#### **3.8.2.4.7.10 CB&I Program 1027 - Stress Intensities.<sup>(4)</sup>**

### A. Description

This program determines the stress intensities in a sphere or cylinder at a maximum of 12 points around an externally loaded round or square attachment. Stresses resulting from external loads are superimposed on an initial pressure

## HNP-2-FSAR-3

stress situation. The program computes stresses at three levels of plate thicknesses: outside, inside, and centerline of plate; four points at the edge of attachment, at  $1/2\sqrt{Rt}$  from the edge of attachment, and at the edge of reinforcement.

The program determines three components for each stress intensity:

$\sigma_x$  = a normal stress parallel to the vessel's longitudinal axis.

$\sigma_\phi$  = a normal stress in a circumferential direction.

T = a shear stress.

The program has an option whereby the penetration load is considered reversible or nonreversible in direction. Under the reversible option, only the data associated with the most severe loading situation is printed.

Most of the analyses and notation used in the program are taken directly from WRC Bulletin 107 of December 1968.<sup>(4)</sup> Use of the program required complete familiarity with this publication.

The program contains extrapolations of the curves for cylinders in WRC Bulletin 107 for  $\gamma$  up to 570.

### B. Validation

The program was verified and document traceability is available at CB&I.

### C. Extent of Application

The program is used to analyze stress intensities in a sphere or cylinder around an externally loaded round or square attachment.

#### **3.8.2.4.7.11 CB&I Program 1017 - Modal Analysis of Structures.**<sup>(10)(11)</sup>

##### A. Description

##### Modal Analysis of Structures Using the Eigenvalue Technique

The purpose of the program is three-fold:

- To calculate the mass and stiffness matrices associated with the structural model.
- To determine the undamped natural periods of the model.

## HNP-2-FSAR-3

- To calculate the maximum modal responses of the structure, i.e., deflections, shears, and moments.

The stiffness and mass matrices may be required in order to perform a dynamic analysis of the structure. The maximum modal responses may be used to perform a spectral analysis.

The program has the following options:

- Vertical translation.
- Torsional modes.
- Soil-structure interaction.
- Liquid sloshing.
- Direct introduction of stiffness and mass matrices.

### B. Validation

The program was verified and document traceability is available at CB&I.

### C. Extent of Application

The program is used to calculate the mass and stiffness matrices, undamped natural periods and maximum modal responses.

### **3.8.2.4.7.12 CB&I Program 1044 - Seismic Analysis of Vessel Appendages.<sup>(12)</sup>**

#### A. Description

Appendages to a vessel may not significantly contribute structurally to the dynamic responses of a model of a vessel. However, appendages can affect the vessel locally by vibrating differently from the model of the vessel at the point of attachment.

The response spectrum method of analysis is not a strictly adequate way of obtaining the maximum appendage accelerations since it does not include the possible consequences of near resonance between the vessel model and the appendage model.

This paper describes the method used to evaluate the maximum elastic differential accelerations between an independently vibrating appendage model and an elastic-beam vessel model at the appendage elevation due to known excitations of the elastic beam model.



## HNP-2-FSAR-3

The method involves two distinct steps. Firstly, the necessary time-absolute acceleration records are computed at appendage elevations due to model excitations. Secondly, the maximum differential accelerations between each appendage model and the vessel model at the appendage elevation are obtained.

The time-absolute acceleration records at the appendage elevation are computed by use of a step-by-step matrix analysis procedure. The equations of motion for the vessel model are of the form:

$$[M]\{\ddot{u}\} + (AT/\pi)[K]\{\dot{u}\} + [K]\{u\} = [M_g]\{\ddot{u}_g\}$$

where:

[M] = mass matrix, order n x n, obtained from a modal analysis.

[K] = stiffness matrix, order n x n, obtained from a modal analysis.

A = portion of first mode critical damping for the model.

T = first mode period of the model.

[M<sub>g</sub>] = a diagonal matrix, order n x n, with diagonal elements corresponding to elements of the mass matrix excited by translational accelerations.

{ $\ddot{u}$ } = n x 1 matrix of relative accelerations between the model base and the n degrees of freedom.

{ $\dot{u}$ } = n x 1 matrix of velocities corresponding to { $\ddot{u}$ }.

{u} = n x 1 matrix of displacements corresponding to { $\ddot{u}$ }.

{ $\ddot{u}_g$ } = n x 1 matrix of translation base acceleration.

n = degrees-of-freedom of vessel model.

By taking a small time increment (smaller than the smallest period obtained from the modal analysis) and letting accelerations vary linearly within the selected increment, the equations of motion can be integrated for the quantities { $\ddot{u}$ }, { $\dot{u}$ }, and {u} over the selected time increments.<sup>(6)</sup> The values obtained are superimposed upon the values of these quantities existing at the beginning of the time increment. This process is repeated for the duration of the excitation. The time-absolute acceleration records for each translational degree-of-freedom are the sums of { $\ddot{u}$ } and { $\ddot{u}_g$ } taken throughout the history of the excitation.

## HNP-2-FSAR-3

The second step is similar to the first step. The equation of motion ( $n = 1$ ) is written for the appendage as a single degree-of-freedom elastic model using the time-absolute acceleration record obtained in step 1 at the appendage elevation as the excitation. This equation is solved in the same manner used in step 1. The maximum absolute value of  $\{\ddot{u}\}$  obtained is the quantity desired. It is the maximum differential acceleration between the appendage model and the vessel model due to a known excitation of the vessel model.

For any appendage, this two-step procedure should be executed three times. This is required to evaluate normal, tangential, and vertical appendage accelerations with respect to a vessel cross-section.

### B. Validation

The program was verified and document traceability is available at CB&I.

### C. Extent of Application

The program is used to evaluate the maximum elastic differential accelerations between an independently vibrating appendage model and an elastic beam vessel model due to excitations of the elastic beam model.

### 3.8.2.4.7.13 **CB&I Program 119 - Bolted Flange Design.**<sup>(9)</sup>

#### A. Description

This program is used for the design of bolted flanges. The program checks the flange design based on Appendix II of ASME Code, Section VIII.<sup>(9)</sup> Bolt and flange stresses are computed for both the boltup and design conditions. If the bolt and gasket are not overstressed, the computer automatically calculates the required flange thickness or checks any supplied thickness. The minimum gasket width required to prevent crushing and the maximum pressure that the flange is capable of resisting under the design conditions are automatically calculated.

#### B. Validation

The program was verified and document traceability is available at CB&I.

#### C. Extent of Application

This program is used for the design of bolted flanges in accordance with the requirements of Appendix II of Section VIII of the ASME Code.

**3.8.2.4.7.14 CB&I Program 9-48 - Nozzle Analysis Program - All Loads Mechanical (NAPALM).<sup>(9)</sup>**

A. Description

The basis for the program NAPALM is to analyze nozzles for mechanical loads and find the maximum stress intensity and location. The program analyzes at specified locations from the point of application of the mechanical loads. At each location the maximum stress intensity is calculated for both the inside and outside surfaces of the nozzle. The program includes an input option which results in the analysis to proceed for the sign and magnitude only, or it analyzes, with the magnitude of the loads constant, and varies the sign (plus or minus) for all combinations of loads. The program also uses an option for longitudinal pressure stress. With this option, the program considers this stress to exist and analyzes with it, or the program does not consider this stress and analyzes without it, or the program analyzes with and without this stress. This is to take into account the maximum stress condition, since due to the matching pipe configuration this stress may or may not exist.

The program also includes an option to input additional loads at the thermal sleeve junction to the nozzle. With this option at any location beyond the thermal sleeve junction toward the vessel, the additional loads are applied. These loads are added with their sign and magnitude to the mechanical loads applied elsewhere on the nozzle.

The program gives the largest value or maximum stress intensity for both the inside and outside surfaces and also its location angularly with respect to the axis of the nozzle. Also the principal stresses are printed out, and the stresses resulting from bending, axial load, shear loads, and torsion, as well as the value of the loads which caused this maximum stressed condition.

B. Validation

The program was verified and document traceability is available at CB&I.

C. Extent of Application

This program is used to analyze nozzles for mechanical loads and to compute the maximum stress intensity. The program also identifies the location of the maximum stress intensity.

**3.8.2.4.7.15 CB&I Program 10-06 - Rotation of Suppression Chamber Nozzle Loads.<sup>(4)</sup>**

A. Description

This program rotates nozzle loads from a global coordinate system to a nozzle coordinate system per WRC Bulletin 107.<sup>(4)</sup> This program has been written for the torus-shaped suppression chambers.

## HNP-2-FSAR-3

The input loads may be applied at the shell or at the end of a pipe connected to the shell. The pipe may be inside or outside of the torus. However, the pipe must lie in the vertical plane containing the penetration point and a radius of the cylindrical segment. Output loads are applied at the shell.

### B. Validation

The program was verified and document traceability is available at CB&I.

### C. Extent of Application

The program is used to rotate nozzle loads from a global coordinate system to a nozzle coordinate system for the torus-shaped suppression chambers.

### **3.8.2.4.7.16 CB&I Program 1342 - Three-Dimensional Frame.**

#### A. Description

This is a three-dimensional-frame program to provide analysis capabilities for determining deflections, rotations, and member reactions on general space frames.

The program handles the following:

- Any support combination.
- Any member end condition.
- Distributed and concentrated member loads at any angle.
- Joint loads.
- Any number of loading conditions.
- Thermal stresses.
- Joint displacements.
- Shear deformations.
- Members that can carry only tension or compression.
- Rectangular or cylindrical coordinate input.
- Plotting option for geometry check.

## HNP-2-FSAR-3

The input coordinate system is similar to the "Stress" coordinate system and uses the global and local coordinate systems. The joint coordinates are input in the global system, and joint loads and restraints are input in this system.

Member properties and member loads are input in the local system. Conversion from the global to the local coordinate system is accomplished in the same manner as in the "Stress" program. The output consists of joint reactions and displacements which are in the global coordinate system and member end loads which are in the local coordinate system.

The units are not as flexible as the units used in the "Stress" program in that all loads must be in terms of kips and all dimensions must be in the terms of feet.

### B. Validation

The program was verified and document traceability is available at CB&I.

### C. Extent of Application

The program is used to provide analysis capabilities for determining deflections, rotations, and member reactions on general space frames.

### 3.8.2.5 Structural Acceptance Criteria

The fundamental acceptance criteria for the containment is the successful completion of the structural integrity bare-vessel test at 125% of design pressure.

The design and analysis methods, as well as the type of construction and construction materials, are chosen to allow assessment of the structure's capability throughout its service life. Additionally, surveillance testing provides further assurances of the structure's continuing ability to meet its design functions.

The actual and allowable stresses at critical sections of the containment are listed in table 3.8-2 for different loading combinations.

The low values of the resultant stresses identified for the first item of table 3.8-2, sheet 1, are obtained from primary principal membrane stresses and are due to the low operating internal pressure which is < 2 psi as identified in paragraph 3.8.2.3.1(H).

When shear stress components are zero, then:

$$\sigma_t = \sigma_1 = \sigma_\phi$$

$$\sigma_\ell = \sigma_2 = \sigma_x$$

$$\sigma_r = \sigma_3 = 0$$

Stress intensity,  $S_m$ , is the largest absolute value of:

$$S_{12} = |\sigma_1 - \sigma_2| = |\sigma_\phi - \sigma_x|$$

$$S_{23} = |\sigma_2 - \sigma_3| = \sigma_x$$

$$S_{31} = |\sigma_3 - \sigma_1| = \sigma_\phi$$

where:

$\sigma_t, \sigma_\ell, \sigma_r$  = stress components in the tangential, longitudinal, and radial directions.

$\sigma_1, \sigma_2, \sigma_3$  = principal stresses derived from  $\sigma_t, \sigma_\ell$ , and  $\sigma_r$ .

$\sigma_\phi, \sigma_x$  = principal primary membrane stresses in the circumferential and meridional directions.

$S_{ij}$  = stress difference in the i and j directions.

$S_m$  = stress intensity.

The above method of computing stress intensity conforms to subsection NE-3215 of Section III of the ASME Boiler and Pressure Vessel Code. Table 3.8-2 was revised to show the stress intensities.

Figure 3.8-9 identifies the different levels at which stress computations were made and includes the thicknesses of the shell at those levels.

The calculated and allowable stresses at local areas of the containment, such as the personnel lock, are shown in table 3.8-3.

### **3.8.2.6 Design Loading Combination Stress Limits**

The stress limits for different loading combinations are listed in table 3.8-4. A primary membrane stress limit of  $0.9 S_y$  (specified minimum yield stress at appropriate temperature) has been used for DBE loading combinations to restrict the stresses within yield. For jet load impingement loadings on the shell backed up by bioshield concrete, an elastoplastic finite element analysis was performed to show that the computed strain is within the code allowables.

The compressive stress resultants were compared to the allowables obtained according to the paragraphs titled "Biaxial Compression - Equal Unit Forces" and "Biaxial Compression - Unequal Unit Forces" of the WRC Bulletin 69. The allowables used are found by assuming that the sphere reacts as a cylinder with a radius equal to the radius of the sphere. There are three cases of loading considered. The allowables for these three cases are:

HNP-2-FSAR-3

- Uniaxial compressive stress resultant.


$$N_{ALL} = 1.8 \times 10^6 \frac{t^2}{R}$$

- Biaxial equal compressive stress resultants.

$$N_{ALL} = 0.9 \times 10^6 \frac{t^2}{R}$$

- Biaxial unequal compressive stress resultants.

This case is treated as the summation of an uniaxial condition with the biaxial condition with equal stress resultants. (See sketch.)



where:

$N_{ALL}$  = allowable compressive stress resultant.

$t$  = thickness of the shell.

$R$  = radius of the equivalent cylinder.

$N_{\theta}$  = circumferential membrane stress resultant.

$N_{\phi}$  = meridional membrane stress resultant.

### 3.8.2.7 Materials, Quality Control, and Special Construction Techniques

The pressure parts and attachments to pressure parts of the containment vessel, penetrations, and appurtenances meet the requirements of Section NE-2000 of Section III of the ASME Code and were fabricated from the following materials:

A. Plate

- SA 36.
- SA 516, Grade 70.

## HNP-2-FSAR-3

- SA 240, Type 304.
  - SA 537, Grade A.
- B. Pipe
- SA 333, Grade 6.
  - SA 312, Type 304.
- C. Forgings
- SA 350, Grade LF2.
  - SA 105, Grade II.
  - SA 182, Type 304.
  - SA 479, Type 304.
- D. Bolting and Nuts
- SA 320, Grade L43.
  - SA 193, Grade B7.
  - SA 194, Grade 7.
- E. Fittings
- A 234, Grade WPB.

The nonpressure parts of the containment were fabricated from the following materials:

- A 36.
- A 514, Grade F (T-1).
- A 53, Grade B.
- A 106, Grade B.
- A 283, Grade C.
- A 516, Grade 70.
- SA 105, Grade II.



## HNP-2-FSAR-3

- SB 443, Alloy 625.

The provisions of USNRC Generic Letter 89-09 were implemented for modification of the bellows assemblies for penetrations X-8 and X-9A. The material used to fabricate the replacement bellows assemblies conforms to the requirements of SB-443, Alloy 625.

The pressure parts and attachments to the pressure parts of the containment vessel, with the exception of the austenitic steel materials, meet the longitudinal Charpy V-notch impact test requirements of Section NE-2300, with minimum impact values not less than those specified in Appendix I of the ASME Code, Section III. The impact specimens were tested at 0°F.

The quality assurance provisions of Section NA-4000 of Section III of the ASME Code were followed in all phases of procurement, shop fabrication, and field installation of the containment.

The following surfaces were sandblasted in accordance with Specification SSPC-SP5 and were coated with the inorganic zinc primer Dimetcote 6 to a dry film thickness between 3.0-mils minimum and 5.0-mils maximum:

- Interior surface of the suppression pool.
- Interior and exterior surfaces of the vent lines, vent header, and downcomers within the suppression pool.
- Exterior surface of the vent-header supports.
- All other appurtenances and attachments within the suppression pool, with the exception of stainless steel surfaces.

The inorganic zinc surfaces below the waterline in the suppression pool were later coated, as required, with a DBA qualified, 100% solids epoxy installed by underwater application.

The surfaces listed below have been sandblasted in accordance with Specification SSPC-SP10 and were primed with the inorganic zinc Dimetcote 6 to a dry film thickness of 2.0-mils minimum and 4.0-mils maximum followed by a topcoat of the organic coating Ameron 90 to a dry film thickness of 3.0-mils minimum and 5.0-mils maximum.

- All exposed drywell interior surfaces above el 114 ft 6 in.
- Jet deflectors of the vent openings.
- Exterior surfaces of the drywell above the water seal support bracket at el 201 ft 4 in.
- Interior surfaces of the equipment hatches.
- All other appurtenances and attachments within the drywell, including both exposed surfaces of the reactor pressure vessel support pedestal shells.

The above protective coating operation has been carried out in full compliance with the quality assurance requirements for protective coatings applied to water-cooled nuclear power plants described in Regulatory Guide 1.54 (June 1973) except that American National Standards Institute (ANSI) N45.2-1971 was not used.

The design, furnishing and fabrication, delivery and unloading, erection, and code stamping were performed by CB&I using proven methods, tools, and equipment generally used by this type of industry.

### **3.8.2.8 Testing and Inservice Surveillance Requirements**

This subsection describes the inspection and tests that are provided for the various systems or components of the primary containment as they apply during construction or plant operation.

#### **3.8.2.8.1 Objectives**

The objectives of these tests and inservice surveillance requirements are to ensure that:

- Leakage through the primary reactor containment and systems and components penetrating primary containment does not exceed allowable leakage rates specified in 10 CFR 50, Subsection 50.54, Appendix J, and the Technical Specifications.
- Periodic surveillance of primary reactor containment penetrations and isolation valves is performed so that proper maintenance and repairs can be made during the service life of the primary containment.

#### **3.8.2.8.2 Leakage Testing To Verify Primary Containment Integrity**

Fabrication procedures, nondestructive testing, and sample coupon tests were made in accordance with the ASME Code for Boilers and Pressure Vessels, Section III, Subsection NE, 1971 edition, including 1971 Summer Addenda. The integrity of the primary containment system was verified by a pneumatic test of the drywell and suppression chamber at 1.25 times their design pressure of 56 psig in accordance with Code requirements. An initial leakage test, performed in accordance with 10 CFR 50, Appendix J,<sup>(13)</sup> has also been successfully completed. These tests were completed upon erection of the primary containment.

The preoperational and periodic leakage tests of the primary containment and systems and components penetrating primary containment are performed in accordance with Appendix J to 10 CFR 50.<sup>(13)</sup> The integrated leak rate test (ILRT) is performed using the methods presented in BN-TOP-1 or ANSI/ANS-56.8-1994.<sup>(14)</sup> The testing methods, frequency, and acceptance criteria are specified in the Technical Specifications and are summarized briefly below. The terminology is consistent with reference 13.

**3.8.2.8.2.1 Integrated Leak Rate Test (Type A Tests).**

A. Objective

The objective is to confirm that the maximum allowable leak rate of 1.2 weight percent of the contained air per 24 h at peak calculated (test) pressure is not exceeded.

B. Test Methods

Both a reduced pressure test and a peak calculated pressure test were conducted prior to unit operation. **TRM table T7.0-1** provides a list of the type A tested items.

1. For the containment ILRT (type A) program, the test requires that data be collected at least hourly during type A testing. The time when containment conditions stabilize is monitored with the stipulation that the time period required for stabilization before the test is initiated is at least 4 h.
2. Systems which may communicate with the containment atmosphere under LOCA conditions are as follows:
  - Service air system.
  - H<sub>2</sub> and O<sub>2</sub> analyzer system.
  - Demineralized water system.
  - Nitrogen inerting system.
  - Purge and inerting system.
  - Fission products monitoring system.
  - Neutron monitoring system (NMS).
  - Main steam lines.
  - High-pressure coolant injection (HPCI) steam lines.
  - Reactor core isolation cooling (RCIC) steam lines.

The above systems are drained and vented to the atmosphere in accordance with 10 CFR 50, Appendix J.

In addition to the above systems, the drywell pneumatic system is depressurized and vented to ensure that no leakage of pressurized air into the containment occurs during the type A test. Also, the reactor pressure

HNP-2-FSAR-3

vessel is vented allowing nuclear boiler system components to be subjected to containment atmosphere pressure as well as the water head created by maintaining the reactor water level at the normal operating level during the test.

3. The following is a tabulation of those systems in the containment which were not vented and drained during the type A test. The letters on the right side of the table refer to criteria paraphrased from 10 CFR 50, Appendix J, which are included after the table.

| <u>System</u>                                          | <u>Criteria for Not Draining and Venting</u> |
|--------------------------------------------------------|----------------------------------------------|
| • Nuclear boiler system (RPV and feedwater lines)      | d                                            |
| • Reactor recirculation system (RRS)                   | d                                            |
| • CRD insert and withdraw lines                        | b                                            |
| • Standby liquid control system (SLCS)                 | a                                            |
| • HPCI system (torus suction)                          | d                                            |
| • RCIC system (torus suction)                          | d                                            |
| • Radwaste system                                      | b, e                                         |
| • Reactor water cleanup (RWC) system                   | a, f                                         |
| • Core spray (CS) system                               | c                                            |
| • RHR system                                           | c                                            |
| • Reactor building closed cooling water (RBCCW) system | b, g                                         |
| • Chilled-water system                                 | b, g                                         |
| • Steam valve sealing system                           | a                                            |

Criteria:

- a. The system is part of the reactor coolant boundary and does not open to the containment atmosphere normally or during a LOCA

## HNP-2-FSAR-3

and therefore is not drained. However, it is subjected to  $P_a$  as described in B.2 above.

- b. The system is not part of the reactor coolant boundary and does not communicate with the containment atmosphere normally or during a LOCA.
- c. The system is filled with water and is operating under post-LOCA conditions.
- d. The system is required to maintain the plant in a safe condition during the test and therefore is not drained. However, it is subjected to  $P_a$  as described in B.2 above.
- e. Radwaste system primary containment penetrations are discharge lines from submersible sump pumps. Each radwaste sump pump suction is sealed from the primary containment atmosphere by water in the sump during both normal and LOCA conditions.

The containment isolation valves for each radwaste pump discharge line are normally closed and are provided with a primary containment isolation signal. Isolation valve leakage is monitored by air testing as part of the type C leakage test program. The valves are also subject to  $P_a$  through the sump during the type A test.

Radwaste sump pump discharge piping is ASME III, Class 3, from the pump discharge to the containment penetration, where it is qualified ASME III, Class 2, to, and including, the outboard isolation valve. Piping from the pump discharges to, and including, the outboard isolation valves is also Seismic Category I.

- f. The RWC piping within the primary containment is Seismic Category I, Quality Group A piping and is part of the reactor coolant boundary normally and post-LOCA. The RWC piping is connected to the nuclear boiler system through suction connections on the recirculation loop and the bottom head drain on the RPV. The lines are normally full of coolant and remain full post-LOCA, even if the postulated break occurs in the recirculation loop with the RWC connection, because of the interface with the RPV bottom head drain.

RWC isolation valves are also tested with air as part of the type C leakage test program.

- g. The RBCCW and chilled-water systems within the primary containment meet the criteria of GDC 57 for closed systems within the primary containment and meet BTP6.2-3 with the exception of

quality group classification of the piping. **TRM table T7.0-1** compares the design requirements of the Quality Group D RBCCW and chilled-water piping to the design requirements of comparable Quality Group B piping.

As closed systems, the RBCCW and chilled-water piping do not communicate with the primary containment atmosphere, normally or post-LOCA, and therefore are not vented or drained during the type A test.

Isolation valve leakage is monitored in the type C test program.

4. The supplemental test for the ILRT type A test was calibrated to leakage type test similar to the test described in ANSI 45.4 - 1972, Appendix C. The verification test was performed after the reduced pressure test and after the peak pressure test.

A controlled leakage rate based on the ILRT result is imposed upon the containment by using the verification test portion of the integrated leak rate measurement system. The verification test portion of the measuring system allows a calibrated leak to be placed on the containment through the utilization of a bleedoff throttle valve. A flowmeter is installed downstream of the throttle valve to monitor the leak rate. The verification tests are run for a minimum of 5 h, during which the flowmeter data is taken hourly.

During the verification test, the containment leakage measuring equipment measures a composite of the imposed leakage rate and the actual leakage rate. During the test, the leakage rate is calculated by subtracting the imposed leakage rate from the composite leak rate. The acceptance criteria for the test are as follows:

$$(L_i + L_{tm} + 0.25L_t) > L_{vm} > (L_i + L_{tm} - 0.25L_t)$$

where:

$L_{tm}$  = containment leakage rate calculated during the ILRT at the same containment pressure at which the verification test is run.

$L_t$  = maximum allowable leakage rate for the ILRT at the same pressure as the verification test.

$L_{vm}$  = containment leakage rate calculated during the verification test.

$L_i$  = leakage rate imposed on the containment using the flowmeter.

5. The limiting conditions for operation and the surveillance requirements required for ILRT type A are included in the Technical Specifications.

### C. Acceptance Criteria

To provide some margin against normal leakage deterioration which may occur during the period between leak rate tests, the allowable operational leak rate is derived by multiplying the maximum allowable test leak rate by 0.75. Specific acceptance criteria are provided in the Technical Specifications.

#### **3.8.2.8.2.2 Leak Tests of Penetrations and Isolation Valves (Type B and C Tests).**

Containment isolation valves (except for main steam isolation valves) and primary containment components which seal or penetrate the pressure-containing boundary are periodically tested at the peak calculated pressure. Test frequencies are established per 10 CFR 50, Appendix J, Option B as implemented by the Primary Containment Leakage Rate Testing Program.

The combined leakage rate of components subject to type B and C (except for main steam isolation valves) does not exceed 0.6 times the maximum allowable leakage rate. An additional restriction is placed on the personnel airlock which does not exceed a leakage rate of 0.05 times the maximum allowable.

The main steam isolation valves (MSIVs) are also tested independently at a pressure of 28.8 psig and with an allowable leakage of 100 sf<sup>3</sup>/h per valve, but not to exceed a total maximum pathway leakage of 250 sf<sup>3</sup>/h through all four main steam lines.

All penetrations, seals, and isolation valves affected by these tests are listed in **TRM table T7.0-1**. Specific testing and acceptance criteria are provided per the Primary Containment Leakage Rate Testing Program.

Additional information regarding the containment local leak rate (types B and C) test program is provided in paragraph 3.8.2.8.2.2.1.

**3.8.2.8.2.2.1 Containment Local Leak Rate (Type B and C).** Figures 3.8-16 through 3.8-23 provide diagrams of the typical type C test arrangement used. **TRM table T7.0-1** lists the specific reference figures which depict the orientation of each test boundary. The isolation valves listed in **TRM table T7.0-1** are tested with the test volume water filled, then pressurized with air or nitrogen, since the volume would remain water filled post-LOCA.

The personnel airlock barrel is tested at  $P_a$  per 10 CFR 50, Appendix J. The barrel test is performed by pressurizing between the inner and outer doors and verifies the overall pressure integrity of the barrel. A 10-psig pressure test is performed on the airlock door seals at the frequency specified by 10 CFR 50, Appendix J, to verify that the seal leakage rate is less than detectable.

**3.8.2.8.2.3 Drywell-to-Pressure Suppression Chamber Bypass Area Tests.** At the frequency specified by Technical Specifications, a leak rate test is performed to verify that significant leakage flow paths do not exist between the drywell and pressure suppression chamber. The existence of such leakage paths would result, in the event of a primary system

rupture, in blowdown steam passing directly to the suppression chamber free-air space without being condensed in the suppression pool. Since the design pressure of the containment is predicated on the experimentally verified assumption that all the blowdown steam is condensed in the suppression pool, the existence of bypass paths could possibly result in the containment design pressure being exceeded.

A. Objective

The objective of bypass area leak testing is to detect flow paths between the drywell and suppression chamber whose capacity is equal to or greater than the capacity of a 1-in.-diameter orifice.

The smallest pipe that is a part of the vent system is 1-in. pipe, whose failure could result in a drywell-to-suppression chamber leakage path. There are 12 of these 3/4-in., schedule 80 lines which serve as drain lines for the vent headers and vacuum breaker valves.

B. Test Method

To conduct the drywell-to-suppression chamber bypass area leak rate test, the drywell pressure is increased by ~ 1 psi with respect to the suppression chamber pressure and held constant. The 2-psig scram setpoint is not exceeded. The subsequent suppression chamber pressure transient (if any) is monitored with a manometer capable of detecting a small pressure increase. If the drywell pressure cannot be increased by 1 psi over the suppression chamber pressure, it would be because a significant leak path exists; in this case, the leakage source is identified and eliminated before primary system pressurization.

Drywell-Suppression Chamber Testing Program

The drywell-to-suppression chamber bypass area test is performed with all vacuum breakers between the suppression chamber and drywell lined up in their normal operating condition.

A pressure decay test is performed by increasing the drywell pressure by > 1 psig higher than the suppression chamber pressure. The pressure decay is monitored by using a manometer over a 10-min period.

Boundary Conditions for Drywell Testing Program

During the test period, there is no operation of the following equipment:

- RHR system in either the containment spray or pool cooling mode.
- RCIC system.
- HPCI system.



- Relief valves.

The objective of these restrictions is to prevent temperature variations in either the pool or suppression chamber airspace during the test. There are no energy dumps to the pool near the end of the refueling outage and a constant temperature situation is expected to exist in the suppression chamber at the time of the test.

C. Acceptance Criteria

With a differential pressure > 1 psi, the rate of change of the suppression chamber pressure must not exceed 0.25 in. of water per minute as measured over a 10-min period. In the event the rate of change exceeds this value, then the source of leakage will be identified and eliminated before power operation. Figure 3.8-24 shows the drywell and suppression chamber pressure transients assuming a 1-in. orifice leakage path to exist and assuming the drywell pressure was increased 1.25 psi in a 5-min period. Figure 3.8-25 shows the associated pressure differential between the drywell and suppression chamber. It can be seen that there is a 20-min period during which the differential would be greater than 1 psi; thus, there would be ample time to conduct a 10-min test.

### 3.8.2.8.3 Inspection and Testing Features

The following features of plant design were provided to allow testing and inspection in accordance with the above criteria and objectives.

**3.8.2.8.3.1 Penetrations and Seals.** Pipe penetrations, which must accommodate thermal movement, are provided with expansion bellows such as the penetration shown in figure 3.8-2. By use of the pressure test tap, a gas (nitrogen or other as required for leak detection) can be injected into the annulus, and by soap film, pressure decay, or other means, leakage can be detected and measured during shutdown without pressurizing the entire primary containment system. The test tap is plugged during normal operation to prevent leakage through the test tap in the event of a leak within the penetration.

Electrical penetrations are also provided with double seals and are also separately testable. The test taps and seals are located so that the tests of the electrical penetrations can be conducted without entering or pressurizing the drywell or suppression chamber.

All containment closures, which are fitted with resilient seals or gaskets, are separately testable. The covers on flanged closures, such as the equipment access hatch cover, the drywell head, and the access manholes, and personnel airlock doors are provided with double seals without pressurizing the entire containment system. Details of the containment airlock design which permits pressure testing are shown on figure 3.8-26.

**3.8.2.8.3.2 Isolation Valves.**

- A. The test capabilities incorporated into the primary containment system to permit leak detection testing of containment isolation valves are separated into two categories.

The first category consists of those pipe lines which open into the containment and are not connected to the reactor vessel. In lines that contain two power-operated isolation valves in series, a test tap is provided between the valves which permits leakage monitoring of the first valve when the containment is pressurized. The test tap can also be used to pressurize between the valves to permit leakage testing of both valves simultaneously.

The second category consists of those pipe lines which are connected to the reactor vessel. In lines that contain two power-operated valves in series, a test tap is provided between the valves which permits leakage monitoring of the first valve when the reactor vessel is pressurized. The test tap can also be used to pressurize between the valves to permit leakage testing of both valves simultaneously when the reactor vessel is not pressurized. In lines that contain one inboard check valve and one outboard power-operated valve, a test tap is provided opposite the containment side of the outboard valve. Leakage through the inboard check valve can be monitored through the test tap by opening the outboard valve when the reactor is pressurized. Leakage through the outboard valve can be monitored by opening the inboard check valve when the reactor is pressurized.

- B. A test connection is located between the two series check valves in each of the reactor feedwater lines. This test connection is used to leak test the outboard check valve with the inboard gate valve closed.

Another test connection is located on the reactor side of the inboard check valve between the inboard check valve and gate valve. This test connection is used to test the inboard check valve with the inboard gate valve closed.

- C. A test connection is provided between the two valves in the reactor building to torus vacuum relief lines. With the inner air-operated valve held shut, leakage past the outer check valve is measured. Each of the two parallel lines would be tested individually. Thus, if the plant were in operation during the tests, the vacuum-breaking capability is still effective.

**3.8.2.8.3.3 Drywell-to-Suppression Pool Vacuum Breaker Tests and Inspections.** The drywell-to-suppression pool vacuum breakers are tested for operability monthly, using the redundant position indication installed on each valve. Each valve is cycled from both the main control room and the local panel. The indicating lights are monitored at each station as the valve cycles.

The vacuum breakers are visually inspected and leak tested by the method described in paragraph 3.8.2.8.2.3 at each refueling outage. The opening differential pressure for each valve is also checked at each refueling outage by measuring the force required to open the disc. This force would result from a 0.1-psid  $\Delta P$  existing across the valve.

Operators are installed on the vacuum breakers to provide exercising capabilities. However, the valves self-actuate when the setpoint differential pressure exists across the disc and pop open in  $< 1$  s. Therefore, an operational test for the determination of opening time is not feasible.

### **3.8.3 CONTAINMENT INTERNAL STRUCTURES**

The containment internal structures are all Seismic Category I, consisting of:

- RPV pedestal.
- Reactor shield wall.
- Recirculation pump supports.
- Other structures.

#### **3.8.3.1 Description of Internal Structures**

##### **A. RPV Pedestal**

The pedestal consists of two concentric steel shells 18 ft 3 in. and 26 ft 3 in. in diameter with concrete fill in between the shells to provide mass and stability. The concrete strength is not considered in design. Stiffeners are provided at different locations to distribute the load uniformly over larger areas of the shell. The pedestal supports the RPV, reactor shield wall, intermediate platforms, CRD platform, pipe-whip restraints, pump restraints, pipe hangers, and snubbers. The bottom of the pedestal is anchored to the base slab by means of ninety-two 3-in.-diameter A-193 B7 anchor bolts which transfer the loads to the foundation. The reactor shield wall columns are directly welded to the top of the pedestal. Provisions are made at the top of the inner shell to inspect the reactor vessel bolting rings. The details of RPV pedestal are shown in drawing nos. H-25004 and H-25005.

##### **B. Reactor Shield Wall**

The reactor shield wall consists of 12 buildup steel columns with 3/8-in.-thick steel liner plate welded on both sides of the column flanges. A 1 3/4-in.-thick liner plate is provided on the outside flange of the core area for radiation shielding. Intermediate ring beams are provided at various levels to accommodate the restraints. The reactor shield wall is rigidly connected at the base to RPV pedestal

## HNP-2-FSAR-3

and laterally supported at el 188 ft 1/2 in. by a star truss. The star truss transfers seismic and other forces from the reactor vessel and the shield wall to the drywell shield concrete through the eight lugs in the drywell. The flat development of the reactor shield is shown in figure 3.8-27.

### C. Recirculation Pump Supports

Recirculation pumps and motors are hung from platforms at el 127 ft 9 in. and el 148 ft 3 1/2 in. The snubbers for the pumps are attached to the RPV pedestal.

### D. Other Structures

#### 1. Inservice Inspection Platforms

Two major platforms at el 127 ft 9 in. and el 148 ft 3 1/2 in. are provided inside the drywell. The lower platform spans between the containment and the RPV pedestal and the upper platform spans between the containment and the reactor shield wall. Heavy steel I-beams and builtup box girders are used to carry pipe restraint and other loads. The beams are braced laterally to minimize torsion and to provide overall stability. Lubrite pads are provided at the drywell end of the beams for thermal movements. The other end of the beams are welded either to the pedestal at el 127 ft 9 in. or to the ring girder at el 148 ft 3 1/2 in. Typical connection details are shown in figure 3.8-28.

Other platforms are provided at various locations for inservice inspection access. The general arrangement of the platforms is shown in figure 3.8-28.

The inspection platforms provide access to inspect pipe welds, nozzle welds, and vessel welds in addition to providing working area for normal maintenance.

#### 2. Inservice Inspection Doors

Inservice inspection doors provided in the reactor shield wall are used for inservice inspection of the nozzle welds at the outside face of the RPV. The doors are of heavy steel plates, up to 4 1/2-in.-thick, with 6 7/8 in. to 8-in. type 277M concrete fill, manufactured by Reactor Experiments, Inc. The door frames are tied to the reactor shield wall. The total thickness of doors varies from 13 3/8 in. to 15 in.

Typical arrangement of the door for the 28-in.-diameter recirculation line is shown on drawing no. H-29000.

#### 3. Pipe Whip Restraints and Barrier Plates

Pipe whip restraints are provided inside the containment to protect it from pipe whip due to a high energy pipe break. A typical pipe whip restraint is a

steel bracket with wire ropes wrapped around the pipe and is shown on drawing no. H-29026.

Where pipe whip restraint installation is not possible due to limited space restrictions, barrier plates are provided to protect the containment integrity from pipe whip. The barrier plates in the cylindrical portion of the drywell are shown on drawing no. S-28345.

4. Drywell Concrete Floor at el 114 ft 6 in.

The reinforced concrete slab in the drywell at el 114 ft 6 in. provides a convenient level working area and supports the equipment.

5. Refueling Water Seal Assembly

The water seal assembly shown on drawing no. S-27793 is provided in the drywell cylinder at el 203 ft 4 1/2 in. to form a leaktight barrier for retaining and supporting the water above this level during refueling operation.

6. Miscellaneous Components

Miscellaneous components such as jet deflectors, monorails, spray headers and their supports are shown in figure 3.8-29.

### **3.8.3.2 Applicable Codes, Standards, and Specifications**

The following regulations, codes, standards, regulatory guides, and specifications apply to the original design of the containment internal structures:

A. Regulations

- Title 10 Code of Federal Regulations Part 50, "Licensing of Production and Utilization Facilities."
- Title 29 Code of Federal Regulations Part 1910, "Occupational Safety and Health Standards."

B. Codes and Standard Specifications

- American Concrete Institute (ACI), "Building Code Requirements for Reinforced Concrete" (ACI 318-63).
- ACI, "Specifications for Structural Concrete for Buildings" (ACI 301-66).
- American Institute of Steel Construction (AISC), "Specification for the Design, Fabrication, and Erection of Structural Steel for Buildings," 7th Edition.

## HNP-2-FSAR-3

- AWS, "Structural Welding Code" (AWS D1.1-72).
- C. General Design Criteria, Regulatory Guides, Industry Standards, and Topical Reports
- 10 CFR 50, Appendix A - General Design Criteria for Nuclear Power Plants.
  - GDCs 2, 3, 4, and 16.
  - NRC Regulatory Guides.
    - Regulatory Guide 1.15, "Testing Reinforcing Bars for Category I Concrete Structures" (December 1972).
    - Regulatory Guide 1.29, "Seismic Design Classification" (August 1973).
    - Regulatory Guide 1.46 "Protection against Pipe Whip Inside Containment" (May 1973).
    - Regulatory Guide 1.55, "Concrete Placement in Category I Structures" (June 1973).
  - Industry Standards.

Nationally recognized industry standards, such as those published by the ASTM, are used whenever possible to describe material properties, testing procedures, fabrication methods, and construction methods.
  - Bechtel Topical Reports.

BN-TOP-2, "Design for Pipe Break Effects," Revision 2, May 1974.

For new modifications and analysis of modifications installed after the plant was put into operation, later editions of the following codes will be used:

- AISC - "Manual of Steel Construction."
- ACI - "Building Code Requirements for Reinforced Concrete" (ACI 318).
- ACI - "Specifications for Structural Concrete for Buildings" (ACI 301).
- American Welding Society (AWS) - "Structural Welding Code" (AWS D1.1).

For analysis or modification of original plant designs, a later edition of the codes listed above may be used; however, the applicable sections of the original plant design codes must be reviewed. Differences between the original design codes and a later edition of these codes should be documented. Wherever a code change that is applicable to the design has occurred,

a later edition of the code may be used if the change results in a more conservative design than the original design code, or the change results in an acceptable decrease in conservatism based upon a better knowledge or understanding of the condition by the code committee because of tests or experience. If the code change results in a less conservative design and this change is based upon a change in material quality or quality of installation, then the section from the original code edition will be used.

To account for changes in steel member properties and dimensions over the years, this information will be obtained from the AISC Code edition used for the original design.

### **3.8.3.2.1 Structural Specifications**

Structural specifications are prepared to cover the areas related to design and construction of the plant structures. These specifications are prepared by Bechtel and Southern Company Services, Inc., specifically for these structures. The specifications emphasize important points of the industry standards for these structures and reduce options such as would otherwise be permitted by the industry standards. Unless specifically noted otherwise, these specifications do not deviate from the applicable industry standards and as such need not be included in the safety analysis report. These specifications cover the following areas:

- Furnishing and delivery of concrete.
- Purchasing, forming, placing, and curing of concrete.
- Furnishing, detailing, fabricating, delivery, and placing of reinforcing steel.
- Furnishing, delivery, and erection of structural steel.

### **3.8.3.3 Loads and Loading Combinations**

The internal structures are designed for all credible conditions of loadings, including normal loads, seismic loads, and loads resulting from a LOCA.

Critical loading combinations are those caused by a postulated earthquake or by a pipe rupture within the containment. In addition to the loads listed below, the internal structures inside the torus were designed for hydrodynamic loads due to LOCA and safety relief valve discharge. The hydrodynamic loads and load combinations considered are summarized in supplement 3.8B.

#### **3.8.3.3.1 Loads**

The following loads are considered: dead loads, live loads, earthquake loads, pipe-rupture loads, thermal loads, pressure loads due to LOCA, hydrostatic loads, and impact loads.

## HNP-2-FSAR-3

### A. Dead Loads (D)

Structural dead loads consist of the weight of platforms, all permanent equipment, major piping, and electrical ducts.

### B. Live Loads (L)

Live loads consist of design floor loads, laydown loads, equipment live loads, and fuel handling equipment loads.

Live loads considered in design are:

- |    |                                                                 |                                                |
|----|-----------------------------------------------------------------|------------------------------------------------|
| 1. | Floor at el 114 ft 6 in.                                        | 200 lb/ft <sup>2</sup>                         |
| 2. | Platforms and floors at el 127 ft 9 in. and el 148 ft 3 1/2 in. | 150 lb/ft <sup>2</sup> plus 30-kip moving load |
| 3. | Catwalk inside torus                                            | 75 lb/ft <sup>2</sup>                          |
| 4. | Inservice inspection platforms                                  | 100 lb/ft <sup>2</sup>                         |

Weight of water used to fill the drywell from el 203 ft 4 in. to el 227 ft during refueling was considered a live load for the refueling water seal assembly design.

### C. Earthquake Loads (E, E<sup>1</sup>)

The OBE loads, E, and DBE loads, E<sup>1</sup>, derived from the seismic analysis in section 3.7 are used in design.

### D. Pipe Rupture Loads (Y<sub>r</sub>, Y<sub>j</sub>, Y<sub>m</sub>)

Y<sub>r</sub> = Equivalent static load on the structure generated by the reaction on the broken high-energy pipe during the postulated break, including an appropriate dynamic load factor to account for the dynamic nature of the load.

Y<sub>j</sub> = Jet impingement equivalent static load on a structure generated by the postulated break, including an appropriate dynamic load factor to account for the dynamic nature of the load.

Y<sub>m</sub> = Missile-impact equivalent static load on a structure generated by or during the postulated break, as from pipe whipping, including an appropriate dynamic load factor to account for the dynamic nature of the load.

### E. Thermal Loads (T<sub>o</sub>, T<sub>a</sub>)

T<sub>o</sub> = Forces on structure or equipment due to thermal expansion of pipes or components under operating condition.



$T_a$  = Forces on structure or equipment due to LOCA, including  $T_o$ .

F. Pressure Loads due to LOCA ( $P_a$ )

A LOCA results in an increased pressure of the surrounding area. This pressure load  $P_a$  does not include the jet forces resulting from rupture of pipes.

G. Pipe Reaction Loads

$R_o$  = Pipe reactions during normal operating or shutdown conditions based on the most critical transient or steady-state condition.

$R_a$  = Pipe reactions under thermal conditions generated by the postulated break and including  $R_o$ .

**3.8.3.3.2 Loading Combinations**

The three different loading combinations considered for the design of internal structures were: normal operation, refueling, and LOCA.

A. Normal Operation

The loading combinations for normal operating condition are:

$$D + L + E + T_o + R_o$$

$$D + L + E^1 + T_o + R_o$$

B. Refueling

During refueling operation, the drywell cylinder is filled with water up to el 228 ft 0 in. The water seal assembly is subjected to hydrostatic load during this period. The loading combinations for this condition are:

$$D + L + E$$

$$D + L + E^1$$

C. LOCA

The loading combinations used for the postulated LOCA are:

$$D + L + E + Y_r + Y_j + Y_m + T_a + P_a + R_a$$

$$D + L + E^1 + Y_r + Y_j + Y_m + T_a + P_a + R_a$$

#### **3.8.3.4 Design and Analysis Procedures**

The internal structures are designed to provide structural supporting elements for the nuclear steam supply system (NSSS) as well as required shielding. Basic supporting components are of structural steel. All design aspects are integrated with the design criteria of the NSSS supplier and include thermal and dynamic effects evident during earthquakes. The elastic working stress design method was used in Seismic Category I steel structures design.

Design of internal structures evolves around four basic systems:

- Recirculation.
- Main steam.
- Feedwater.
- Engineered safeguards.

##### **3.8.3.4.1 RPV Pedestal**

The RPV pedestal is designed as a freestanding structure fixed at the base. Basically, the design of the RPV pedestal is divided into four sections:

- General shell design.
- Shell stiffening.
- Pedestal top section.
- Penetrations.

The pedestal shells are analyzed for all combinations of loading described in paragraph 3.8.3.3.2.

In areas of major attachments, the shell is locally reinforced with a stiffener system to prevent local buckling of the shell plates and to distribute the loads over large areas of the pedestal.

The top section of the pedestal is designed to transmit the reactor vessel and the reactor shield wall column loads to the inner and outer shells.

The pedestal shell is reinforced in the areas of major penetrations. The analysis and design of the pedestal are based on conventional methods found in standard textbooks and handbooks used in the engineering profession.

#### **3.8.3.4.2 Reactor Shield Wall**

The reactor shield is designed without considering the concrete for structural strength. Concrete is used as filler material for shielding. The forces considered were: seismic forces, pipe loads, pipe restraints, platform loads, jet loads, and uniform internal pressure generated due to pipe break in the annulus formed by the reactor shield and RPV.

For seismic design, reactor shield was modeled as a lumped mass spring system coupled with the reactor building, drywell, RPV, and RPV pedestal. A space frame model consisting of columns and ring girders at various elevations is used for the stress program CE-309 to check the stresses in individual members for different combinations of loading that the shield is subjected to.

#### **3.8.3.4.3 Recirculation Pump Supports**

The design and analysis procedures are based on conventional methods found in standard textbooks and handbooks used in the engineering profession.

#### **3.8.3.4.4 Other Structures**

##### **A. Inservice Inspection Platforms**

Inservice inspection platforms are designed for applicable loads and loading combinations using conventional methods found in standard textbooks used in the engineering profession.

##### **B. Inservice Inspection Doors**

Inservice inspection doors are provided with door frames which transfer loads to the reactor shield wall. These doors are designed for jet forces due to a postulated complete circumferential break of the RPV nozzle combined with pressure differential acting on the inside door face. To prevent the doors from becoming missiles due to these forces, they are secured by bolting to the door frame. Door frames are secured to the reactor shield wall by welded connections. The jet force on the outside face of a door due to a pipe break in the vicinity is also considered in the design. The design and analysis procedures are based on conventional methods found in standard textbooks and handbooks used in the engineering profession.

##### **C. Pipe-Whip Restraints and Barrier Plates**

The postulated pipe break criteria and locations are identified in section 3.6. The pipe-whip restraints design includes the dynamic effects as described in Bechtel Topical Report BN-TOP-2, Rev 2. Barrier plates are provided to protect the containment from pipe whip. The ballistic research formula is used in the barrier plate design.

D. Drywell Concrete Floor at el 114 ft 6 in.

The drywell concrete floor at el 114 ft 6 in. is designed for applicable loads and loading combinations using conventional methods found in standard textbooks used in the engineering profession.

E. Refueling Water Seal Assembly

Refueling water seal assembly is designed for the hydrostatic load, bellows load, and seismic loads using conventional methods found in standard textbooks and handbooks used in the engineering profession.

F. Miscellaneous Components

Miscellaneous components such as jet deflectors, weld pads, spray headers and their supports, access ladders, handrails, and monorails are designed for applicable loads and load combinations using conventional methods found in standard textbooks and handbooks used in the engineering profession.

**3.8.3.4.5 Computer Programs Used in the Analysis**

A. CE 3O9 Structural Engineering Systems Solver (STRESS)<sup>(15)</sup>

1. Description

STRESS is a programming system for the solution of structural engineering problems. The system is capable of executing the linear, elastic, static analyses of two- and three-dimensional framed structures of the following types:

- Plane truss.
- Plane frame.
- Plane grid.
- Space truss.
- Space frame.

The programming system was originally developed at Massachusetts Institute of Technology in 1964<sup>(15)</sup> and is now in the public domain.

2. Validation

The program has been verified by the ICES STRUDL II program. A sample problem of space-frame analysis was run using the CE 309 program and the commercially available versions (Version 1 and Version 2) of the ICES STRUDL II program. The results from these runs were found to be identical. Document traceability is available at Bechtel.

3. Extent of Application

The program is used to obtain the member forces and displacements by stiffness method.

**3.8.3.5 Structural Acceptance Criteria**

The limiting values of stress and gross deformations are established by the following criteria:

- To maintain the structural integrity when subjected to the worst load combinations.
- To prevent structural deformations from displacing the equipment to the extent that the equipment suffers a loss of function.

The allowable stresses for different loading combinations described in paragraph 3.8.3.3.2 are shown in table 3.8-8.

A summary of actual and allowable stresses for different loading combinations of the inner and outer rings of the pedestal are shown in table 3.8-9. Table 3.8-10 shows the summary of stress levels at different elevations for reactor shield.

Structural deformations were found not to be a controlling criterion in the design of the internal structures.

**3.8.3.6 Materials, Quality Control, and Special Construction Techniques**

The basic materials used in the construction of the internal structures are found in table 3.8-11.

The internal structures are built of reinforced concrete and structural steel, using proven methods common to heavy industrial construction. All concrete work is done in accordance with ACI 318-63, "Building Code Requirement for Reinforced Concrete," and ACI 301-66, "Specifications for Structural Concrete for Buildings."

Mill test reports are obtained for all steel used with the exceptions of handrails, stairs, and ladders. Detailing, fabrication, and erection of the structural and miscellaneous steel are in accordance with the Manual of Steel Construction, 1969 edition. Welding is done in accordance with AWS D1.0-69, "Code for Welding in Building Construction."

No special techniques were employed in the construction of internal structures.

The effects of various amounts of radiation on the internal structures were considered in the design. Provisions were made to maintain a constant temperature in order to prevent any appreciable loss of structural strength.

### **3.8.3.7 Testing and Inservice Surveillance Requirements**

The internal structures are not directly related to the functioning of the containment concept. Therefore, no testing or surveillance is required.

### **3.8.4 OTHER SEISMIC CATEGORY I STRUCTURES**

Seismic Category I structures other than the containment and the internal structures are listed below:

- Reactor building.
- Diesel generator building.
- Control building.
- Intake structure.
- Lower portion of the RPV support pedestal.
- Main stack.
- Other outdoor Seismic Category I structures.

The relative locations of the intake structure, plant structures, main stack, cooling towers, and other buildings are shown on drawing no. E-10173.

#### **3.8.4.1 Description of Structures**

##### **A. Reactor Building**

The reactor building encloses the reactor, primary containment, auxiliary cooling systems, refueling and spent-fuel storage pools, and spent-fuel cask pit. The reactor building provides secondary containment for the reactor and primary containment for auxiliary systems. Primary containment for the reactor consists of the drywell and the pressure suppression chamber discussed in subsection 3.8.2. The reactor building is basically a reinforced concrete structure with structural steel framing, consisting of the following major structural components:

## HNP-2-FSAR-3

- Reinforced concrete foundation mat.
- Reinforced concrete floors supported by structural steel framing.
- Reinforced concrete or concrete block interior walls.
- Stainless-steel-lined reinforced concrete spent-fuel pool and spent-fuel cask pit, reactor well, steam dryer-separator storage pool, and fuel transfer canal.
- HPCI room integral with reactor building.
- Reinforced concrete exterior walls up to refueling floor level.
- Exterior walls above the refueling floor consisting of structural steel columns and prefabricated concrete panels.
- Reinforced concrete slab on metal roof deck system supported by steel framing.

Drawing nos. H-26096 and H-26098 through H-26105 show various plans and sections of the reactor building. The principal features of the new- and spent-fuel handling, storage, and shipment facilities are shown in drawing nos. H-26102 through H-26105.

Fuel-handling facilities are served by a 125-ton overhead crane capable of handling heavy loads, such as the spent-fuel cask concrete plugs, dryer, separator, and drywell and reactor vessel heads. A fuel-handling refueling platform runs on rails mounted on the operating floor.

Mechanical antiderailing devices mounted on the wheel assemblies of the overhead crane bridge and trolley prevent the crane from being dislodged from its rails due to horizontal motion during an earthquake. The vertical acceleration due to an earthquake is not large enough to overcome the crane's downward load due to gravity.

The spent-fuel pool and the spent-fuel cask pit walls and base slab are of 6-ft-thick reinforced concrete. The inside face of the walls and base slab are lined with 1/4-in.-thick stainless-steel liner plate to provide leaktightness. The prestressed concrete wall panels around the fuel-handling area of the operating floor protect the spent-fuel pool from the environment.

The diagonal corner rooms in the basement which house the RHR and CS system are designed for the hydrostatic load resulting from flooding due to torus leak. The diagonal rooms are separated from the torus by 2-ft-thick concrete walls for the entire height of the torus room. Each construction joint is provided with a water stop to prevent leakage of water. The maximum height of flooding of the torus room has been calculated assuming design basis accident (DBA) torus water

## HNP-2-FSAR-3

volume. All pipe penetrations below this level in the diagonal walls are sealed by stainless steel bellows. Entry into the diagonal rooms is from the floor above the torus room at el 130 ft msl; hence, flood protection barriers are not required to be broken for entry.

The HNP-2 reactor building is separated from the turbine building, radwaste building, control building, and the HNP-1 reactor building by a 3-in. gap. Refueling floors of both units are freely accessible from each other when both units are commissioned. Provisions are made to use the same overhead crane and refueling platform.

### B. Diesel Generator Building

This reinforced concrete building, housing the diesel generators essential to safe plant shutdown upon loss-of-offsite power (LOSP), is a one-story box-type structure separated from all other buildings. Reinforced concrete interior walls are provided to physically separate the diesel generators from each other. Drawing no. H-12320 shows the general configuration of the building.

### C. Control Building

The control building houses the control room and associated auxiliaries and is shared by both HNP-1 and HNP-2. The building is a reinforced-concrete structure with steel frame structure above el 164 ft, consisting of the following major structural components:

- Reinforced concrete foundation mat.
- Reinforced concrete floors with reinforced concrete beam and girder framing.
- Reinforced concrete or concrete block interior walls and reinforced concrete columns.
- Reinforced concrete (poured or prefabricated) exterior walls.
- Reinforced concrete slab on metal roof deck system supported by steel framing.

Drawing nos. H-12405, H-12406, H12627, H-12629, H-12631, H16249, H-22250, H-40429, and H-40430 show the general layout of the building. The control building is separated from the turbine and reactor buildings by a gap of 3 in.

### D. Intake Structure

The intake structure constructed for HNP-1 is a reinforced concrete structure and is shared by HNP-2. Drawing no. H-12192 shows the intake structure and the equipment layout. The equipment provided is coarse trash racks with cleaners,



traveling screens, stop logs, service water, residual heat removal service water (RHRSW), and screen wash pumps. Table 3.8-12 lists the water velocity across the inlet screens at conditions of normal- and low-water river flow and for normal pumping rates and for pumping rates with all pumps running.

E. Lower Portion of RPV Support Pedestal

The lower portion of the RPV support pedestal is located outside the drywell and is a continuation of the concentric shells within the drywell. The lower portion of the pedestal is designed to transmit the loads developed for the pedestal and drywell to the foundation. Details of the lower portion of the pedestal are shown on drawing nos. H-25004 and H-25005.

F. Main Stack

The elevated gas release stack built at the site for HNP-1 is also used for HNP-2. This is a reinforced concrete structure 120-m high above ground level (el 119 ft 6 in.). The foundation is a reinforced concrete mat, octagonal in plan, supported by steel H piles. Drawing no. H-15650 shows the plans and elevations for the main stack.

G. Other Outdoor Seismic Category I Structures

The liquid nitrogen storage tank (chapter 9), the protective wall around the condensate storage tank (subsection 9.2.6), and the diesel generator fuel oil storage tanks (subsection 9.5.4) are designed to Seismic Category I requirements.

**3.8.4.2 Applicable Codes, Standards, and Specifications**

*The following codes, standards, specifications, design criteria, NRC Regulatory Guides, and industry standard practices apply to the original design and construction of all Seismic Category I structures other than the containment and internal structures:*

|                       |                                                                                                                                             |
|-----------------------|---------------------------------------------------------------------------------------------------------------------------------------------|
| <i>AISC</i>           | <i>Manual of Steel Construction</i>                                                                                                         |
| <i>ACI 318-63</i>     | <i>Building Code Requirements for Reinforced Concrete</i>                                                                                   |
| <i>AWS D.1.0-69</i>   | <i>Welding in Building Construction</i>                                                                                                     |
| <i>NCIG-01 Rev. 2</i> | <i>Nuclear Construction Issues Group (NCIG) Specifications for Visual Weld Acceptance Criteria for Structural Welding at Nuclear Plants</i> |
| <i>AWS D.2.0-69</i>   | <i>Specifications for Welded Highway and Railway Structures</i>                                                                             |
| <i>ANSI N45.2.5</i>   | <i>Supplementary Quality Assurance Requirements</i>                                                                                         |

## HNP-2-FSAR-3

*for Installation, Inspections, and Testing of Structural Concrete and Structural Steel During the Construction Phase of Nuclear Power Plants*

|                                                                                         |                                                                                                                                    |
|-----------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------|
| ASME                                                                                    | <i>Boiler and Pressure Vessel Code, Section III, "Nuclear Power Plant Components," 1971 Edition, including 1973 Winter Addenda</i> |
| <i>American Association of State Highway Officials (AASHO)</i>                          | <i>Standard Specifications for Highway Bridges</i>                                                                                 |
| SSBC                                                                                    | <i>Southern Standard Building Code, 1969 Edition</i>                                                                               |
| CMAA                                                                                    | <i>Specifications for Electric Overhead Traveling Crane No. 70, 1970 Edition</i>                                                   |
| ICBO                                                                                    | <i>Uniform Building Code, 1970 Edition</i>                                                                                         |
| NRC Regulatory Guides                                                                   | <i>Compliance is discussed in appendix A.</i>                                                                                      |
| <i>Regulatory Guide 1.10</i>                                                            | <i>Mechanical (Cadmium) Splices in Reinforcing Concrete Structures, (January 1973)</i>                                             |
| <i>Regulatory Guide 1.29</i>                                                            | <i>Seismic Design Classification, (August 1973)</i>                                                                                |
| <i>Regulatory Guide 1.54</i>                                                            | <i>Quality Assurance requirements for Protective Coatings Applied to Water-Cooled Nuclear Power Plants, (June 1973)</i>            |
| <i>Regulatory Guide 1.55</i>                                                            | <i>Concrete Placement in Category I Structures, (June 1973)</i>                                                                    |
| <i>Regulatory Guide 1.59</i>                                                            | <i>Design Basis Floods for Nuclear Power Plants, (August 1973)</i>                                                                 |
| <i>Regulatory Guide 1.64</i>                                                            | <i>Quality Assurance Program Requirements for the Design of Nuclear Power Plants, (October 1973)</i>                               |
| <i>Regulatory Guide 1.69</i>                                                            | <i>Concrete Radiation Shields for Nuclear Power Plants, (December 1973)</i>                                                        |
| <i>Regulatory Guide 1.76</i>                                                            | <i>Design Basis Tornado for Nuclear Power Plants, (April 1974)</i>                                                                 |
| <i>General Design Criteria of 10 CFR 50</i>                                             |                                                                                                                                    |
| <i>US Army Corps of Engineers Regulations with Respect to Dredging and Construction</i> |                                                                                                                                    |

## HNP-2-FSAR-3

*American Society of Civil Engineers Paper 3269 for Wind Design Requirements* <sup>(20)</sup>

*American Iron and Steel Institute Specification for the Design of Light Gauge Cold-Formed Structural Members, 1968 Code of Federal Regulations, Title 29, Chapter XVII, Occupational Safety and Health Standards*

For new modifications and analysis of modifications installed after the plant was put into operation, later editions of the following codes will be used:

- AISC - Manual of Steel Construction.
- ACI - Building Code Requirements for Reinforced Concrete (ACI 318).
- AWS - Welding in Building Construction (AWS D1.0).
- AWS - Specifications for Welded Highway and Railway Structures (AWS D2.0).
- AWS - Structural Welding Code (AWS D1.1).
- Southern Standard Building Code.
- Uniform Building Code.
- American Iron and Steel Institute Specification for the Design of Light-Gage Cold-Formed Steel Structural Members.

For analysis or modification of original plant designs, a later edition of the codes listed above may be used, however; the applicable sections of the original plant design codes must be reviewed. Differences between the original design codes and a later edition of these codes should be documented. Wherever a code change that is applicable to the design has occurred, a later edition of the code may be used if the change results in a more conservative design than the original design code, or the change results in an acceptable decrease in conservatism based upon a better knowledge or understanding of the condition by the code committee because of tests or experience. If the code change results in a less conservative design and this change is based upon a change in material quality or quality of installation, then the section from the original code edition will be used.

To account for changes in steel member properties and dimensions over the years, this information will be obtained from the AISC Code edition used for the original design.

### 3.8.4.3 Loads and Loading Combinations

All Seismic Category I structures are designed for all credible conditions of loadings, including normal loads, loads resulting from a pipe rupture where applicable, and loads due to adverse environmental conditions.

#### 3.8.4.3.1 Loads

The following loads are considered in the design:

A. Dead Loads (D)

Structural dead loads consist of the weight of framing, roof, floors, walls, partitions, platforms, hangers, cable trays, pipes with fluid, and equipment dead loads as specified on the drawings supplied by the manufacturers of the equipment installed within the structure.

B. Live Loads (L)

Live loads consist of design floor loads, pool and tank liquid weights, and equipment live loads as specified on the drawings supplied by the manufacturers of the equipment installed within the structure. The live loads used in design are shown on table 3.8-13.

C. Earthquake Loads (E, E<sup>1</sup>)

The OBE loads E and DBE loads E<sup>1</sup> derived from the seismic analysis in section 3.7 are used in design.

D. Pressure Loads Due to LOCA (P<sub>a</sub>)

A LOCA results in an increased pressure of the surrounding area. This pressure load P<sub>a</sub> does not include the jet forces resulting from rupture of pipes.

E. Thermal Loads (T<sub>o</sub>, T<sub>a</sub>)

T<sub>o</sub> = Thermal effects and loads during normal operating or shutdown conditions, based on the most critical transient or steady-state condition.

T<sub>a</sub> = Thermal loads under thermal conditions generated by the postulated break, including T.

F. Wind and Tornado Loads (W) and (W<sub>t</sub>)

The wind loadings and tornado loadings (W) and (W<sub>t</sub>) are discussed in section 3.3.

All Seismic Category I structures listed in subsection 3.8.4 are designed to withstand the effects of the wind and tornado loadings and to provide protection against tornado missiles for all Seismic Category I systems and components within the structures.

The structures are analyzed for tornado loadings not coincident with the DBE.

G. Pipe Reaction Loads ( $R_o$ ,  $R_a$ )

$R_o$  = Pipe reactions during normal operating or shutdown conditions, based on the most critical transient or steady-state condition.

$R_a$  = Pipe reactions under thermal conditions generated by the postulated break, including  $R_o$ .

H. Pipe Rupture Loads ( $Y_r$ ,  $Y_j$ ,  $Y_m$ )

$Y_r$  = Equivalent static load on the structure generated by the reaction on the broken high-energy pipe during the postulated break, including an appropriate dynamic load factor to account for the dynamic nature of the load.

$Y_j$  = Jet impingement equivalent static load on a structure generated by the postulated break, including an appropriate dynamic load factor to account for the dynamic nature of the load.

$Y_m$  = Missile-impact equivalent static load on a structure generated by or during the postulated break, as from pipe whipping, including an appropriate dynamic load factor to account for the dynamic nature of the load.

I. Impact Loads (I)

Crane impact loads as per AISC are considered in the design of crane girders and their supports.

**3.8.4.3.2 Loading Combinations**

The following loading combinations are used for all Seismic Category I structures listed in subsection 3.8.4:

$$D + L + T_o + R_o + E$$

$$D + L + I + E$$

$$D + L + T_o + R_o + W$$

$$D + L + T_o + R_o + E^1$$

$$D + L + T_o + R_o + W_t$$

$$D + L + T_a + 1.5P_a + R_a^{(a)}$$

$$D + L + 1.25E + 1.25P_a + T_a + R_a + Y_r + Y_j + Y_m^{(a)}$$

$$D + L + E^1 + P_a + T_a + R_a + Y_r + Y_j + Y_m$$

**3.8.4.3.2.1 Additional Load Combination Based on Document B.**<sup>(16)</sup> The load combinations and acceptance criteria for Seismic Category I steel and concrete structures are in agreement with Document (B).<sup>(16)</sup> The load combinations and acceptance criteria used to check for conformance to Document (B) are found in table 3.8-14.

The load factors for the equations for Seismic Category I structures outside containment provided in paragraphs 3.8.4.3 and 3.8.4.5 were revised to agree with those in Document (B).

#### **3.8.4.4 Design and Analysis Procedures**

##### **3.8.4.4.1 Biological Shield (Drywell Shield)**

For the analysis of the biological shield which constitutes the interior wall of the reactor building, a three-dimensional finite element analysis is made. The CE 779 computer program described in the manual "SAP - A General Structural Analysis Program" by E. L. Wilson is used to perform this analysis. The model is made up of a combination of 5-ft-6-in.-thick shell elements and three-dimensional solid elements. The solid elements are used primarily to model the structure in the vicinity of the fuel pool and at lower elevations where the thickness of the shield is much > 6 ft. The triangular shell elements are used for transitions in the size of the grid and where required by geometry. The distribution of forces around the major penetrations for the equipment and personnel hatches is determined by deleting the shell elements in these regions. Furthermore, the effects of the large penetrations around the pipe chase are also considered by deleting the appropriate elements in this area. The openings in the shield for the fuel pool and dryer-separator pool plugs are also considered. The floor slabs at each elevation are assumed to offer only lateral restraint to the model. Rotational or vertical restraints are not considered at any slab level. The model is assumed to be completely fixed at el 114 ft 6 in. Necessary modifications are made to the lateral restraints in the vicinity of the pools to ensure that the loads from the pool are carried by the shield. The input for the analysis was prepared on the General Electric 635 computer. The output provides moments and forces in both the vertical and hoop directions for the shell elements and all six stresses at the center and on one face of the solid elements.

The axisymmetric elements of CE 316-4, which considers cracked section in concrete, were used to perform the thermal analysis. For the axisymmetric analysis, the model is assumed to

---

a. These loading combinations are used to evaluate the effects of high-energy pipe breaks.

be completely fixed at el 101 ft 10 in. A 70°F linear temperature gradient is assumed across each section. The results of the thermal analysis are used to determine the additional tensile reinforcement required for the shield due to temperature effects. Loadings used for different combinations in the three-dimensional finite element analysis were applied to this model as uniform ring load and the results were compared to those obtained from CE 779.

The reactor building seismic loads derived in section 3.7, attributable to the biological shield in proportion to the stiffness of the various members, were computed.

The critical values of moments and shears from the above analysis were used for reinforcing design and to check the adequacy of the thickness of the shield.

#### **3.8.4.4.2 Other Seismic Category I Structures**

The analysis procedures for other Seismic Category I structures are based on conventional methods. The elastic working stress design method was used in Seismic Category I steel structures.

The computer programs used in the analysis are described in paragraphs 3.8.4.4.3, 3.8.4.4.4, and 3.8.4.4.5.

#### **3.8.4.4.3 Computer Programs Used for Biological Shield Analysis**

##### **3.8.4.4.3.1 CE 779 Structural Analysis Program (SAP).<sup>(17)</sup>**

###### **A. Description**

The program performs the static and dynamic analyses of linear, elastic, and three-dimensional structures using the finite element method. The finite element library contains truss and beam elements, plane and solid elements, plate and shell elements, axisymmetric (torus) elements, and special boundary (spring) elements.

Element stresses and displacements are solved for either applied loads or temperature distributions. Concentrated loads, pressures, or gravity loads may be applied. Temperature distributions are assigned as an appropriate uniform temperature change in each element. Prestressing may be simulated by using artificial temperature changes on rod elements.

Dynamic response routines are available for solving arbitrary dynamic loads or seismic excitations using either modal superposition or direct integration. The program can also perform response spectrum and time-history analyses.

B. Validation

The solutions to test problems have been demonstrated to be essentially identical to the results obtained using the ASKA program, which was developed by Prof. A. J. Argyris (Institut für Statik und Dynamik, Stuttgart) and to the Chan and Fermin program. The test problem solutions have also been compared to, and found to be in agreement with, the solutions of the programs from the ASME Library of Benchmark Computer Problems and Solutions. Document traceability is available at Bechtel.

C. Extent of Application

The program is used in the structural analysis of the containment shell at the region of the equipment hatch opening.

**3.8.4.4.3.2 CE 316-4 Finite Element Stress Analysis.**

A. Description

The program performs the static analyses of plane or axisymmetric structures using the finite element method in which a structure is idealized as an assemblage of finite elements. The finite elements are of either triangular or quadrilateral shape, connected at their corner (nodal) points. The applied loads may be concentrated, uniformly distributed, or inertial, or may be temperature distributions. At boundaries, displacements may be forced.

The program develops the force-displacement relationship (element stiffness matrix) for each individual element from its geometry and material properties. The element relationships are then assembled into an overall structure force-displacement relationship (structure stiffness matrix). Equilibrium equations are developed for each degree of freedom at each nodal point in terms of the structure force-displacement relationship, the unknown nodal point displacements by a modified Gaussian elimination scheme. Once the nodal point displacements are known, element stresses are calculated.

B. Assumptions

The stress and the strain are assumed to be constant within each element.

C. Validation

The program was verified by manual calculations. Document traceability is available at Bechtel.



D. Extent of Application

The program is used to compute stresses in the containment structure due to gravity, pressure, and thermal loads.

**3.8.4.4.4 Computer Program Used for Other Seismic Category I Structures**

**3.8.4.4.4.1 CE-309 Structural Engineering Systems Solver.<sup>(14)</sup>**

A. Description

STRESS is a programming system for the solution of structural engineering problems. The system is capable of executing the linear, elastic, static analyses of two- and three-dimensional framed structures of the following types:

- Plane truss.
- Plane frame.
- Plane grid.
- Space truss.
- Space frame.

The programming system was originally developed at the Massachusetts Institute of Technology in 1964 and is now in the public domain.

B. Validation

The program was verified by the ICES STRUDL II program. A sample problem of space frame analysis was run using the CE 309 program and the commercially available versions (Version 1 and Version 2) of the ICES STRUDL II program. The results from these runs were found to be identical. Document traceability is available at Bechtel.

C. Extent of Application

The program is used to obtain the flexibility matrices of the Seismic Category I structures. The flexibility matrices are used in the dynamic analyses of the structures.

### 3.8.4.4.5 Computer Programs Used for Seismic Analysis

#### 3.8.4.4.5.1 SAP 1.9 Structural Analysis Program.<sup>(17)</sup>

##### A. Description

This program performs the static and dynamic analysis of linear elastic three-dimensional structures using the finite element method. Modeling can be done by a combination of the following:

- Three-dimensional truss and beam elements.
- Triangular membrane.
- Plate and shell elements.
- Three-dimensional isoperimetric hexahedron (brick) elements.
- Quadrilateral orthotropic shell elements.
- Sixteen-node thick shell elements.
- Special boundary elements.
- Three-dimensional curved beam elements.
- Triangular quadrilateral axisymmetric solid quadrilateral plane stress and plane strain elements.

The element stresses and displacements are solved due either to applied loads or temperature distributions. Concentrated loads, pressures, or gravity loads can also be applied. Available dynamic response routines are solved for arbitrary dynamic loads or seismic excitations using either modal superposition or direct integration. The program also does response spectrum analysis.

##### B. Validation

The solutions to test problems were demonstrated to be essentially identical to the results obtained using the ASKA program, which was developed by Prof. A. J. Argyris (Institut for Statik und Dynamik, Stuttgart) and to the Chan and Fermin program. The test problem solutions have also been compared to, and found to be in agreement with, the solutions of the programs from the ASME Library of Benchmark Computer Problems and Solutions. Document traceability is available at Bechtel.

C. Extent of Application

The program is used in the structural analysis of the containment shell at the region of the equipment hatch opening.

**3.8.4.4.5.2 CE 917 Modal Dynamic Analysis.**

A. Description

The program computes the reduced-stiffness matrix from the basic geometry input for plane-frame or truss models, or accepts the reduced-stiffness matrix for any structure as input. It calculates mode shapes, frequencies, participation factors, and modal damping values for a lumped-mass model. The special features of the program are:

1. It can accept either diagonal or full-mass matrices.
2. It generates output tape for input to CE 918, CE 920, and CE 931.
3. It can be used for horizontal or vertical earthquake with minimal input changes.

B. Validation

The solutions to the program were demonstrated to be substantially identical to the results obtained by manual calculations. Document traceability is available at Bechtel.

C. Extent of Application

The program is used to obtain the mode shapes and natural frequencies of Seismic Category I structures.

**3.8.4.4.5.3 CE 918 Response Spectrum Analysis.**

A. Description

This program is supplemental to the modal dynamic analysis program (CE 917). It computes the modal response of general plane-frame or truss models. Response spectrum technique is used, and output is expressed in terms of displacements, accelerations, support reactions, member forces and moments, and spring forces.

B. Validation

The solutions to the program were demonstrated to be substantially identical to the results obtained by manual calculations. Document traceability is available at Bechtel.

C. Extent of Application

The program is used to compute and plot the response spectra for the seismic analyses of Seismic Category I structures.

**3.8.4.4.5.4 CE 920 Time-History Analysis of Structures.**

A. Description

The program performs the earthquake response time-history analysis of lumped-mass models using mode superposition. Program input consists of frequencies, mode shapes, modal damping, and the base acceleration time history.

B. Validation

The solutions to the program were demonstrated to be substantially identical to the results obtained by manual calculations. Document traceability is available at Bechtel.

C. Extent of Application

The program is used to generate the time histories at Seismic Category I equipment locations in the structures.

**3.8.4.4.5.5 CE 921 Response Spectrum Calculations.**

A. Description

The program calculates response acceleration, velocity, and displacement spectra for a specified acceleration time history. It can produce printed plots of the calculated response spectra.

B. Validation

The solutions to the program were demonstrated to be substantially identical to the results obtained by manual calculations. Document traceability is available at Bechtel.

C. Extent of Application

The program is used to generate acceleration, velocity, and displacement spectra at Seismic Category I equipment locations and to print plots of these response spectra.

**3.8.4.4.5.6 CE 931 Composite Damping for Soil-Structure Systems.**

A. Description

This program calculates the composite modal damping, modal participation factors, and mode shapes for lumped soil-structure systems, in which the structures are represented by their fixed-base normal modes.

B. Validation

The solutions to the program were demonstrated to be substantially identical to the results obtained by manual calculations. Document traceability is available at Bechtel.

C. Extent of Application

The program is used to calculate the composite modal damping, modal participation factors, and mode shapes for lumped soil-structure systems.

**3.8.4.5 Structural Acceptance Criteria**

The limiting values of stress and gross deformations are established by the following criteria:

- To maintain the structural integrity when subjected to the worst loading combinations.
- To prevent structural deformations from displacing the equipment to the extent that it suffers a loss of function.

The allowable stresses for different loading combinations described in paragraph 3.8.4.3.2 are found in table 3.8-15.

Structural deformations were found not to be a controlling criterion in the design of Seismic Category I structures other than the containment and the internal structures.

#### **3.8.4.6 Materials, Quality Control, and Special Construction Techniques**

The Seismic Category I structures listed in subsection 3.8.4 are built of reinforced concrete and structural steel, using proven methods common to heavy industrial construction. No special construction techniques were employed in the construction of these structures.

The materials used in construction conform to all the referenced governing codes and standards that were in force on the date the contract for the material was signed (April 1, 1969) unless otherwise noted.

The basic materials used in the construction of the Seismic Category I structures are found in table 3.8-16.

Materials and their quality control requirements are described in the following paragraphs. After the construction phase of the unit was completed, several of these requirements had to be modified to allow for the use of smaller quantities of material, while maintaining the quality. The differences in the present quality control requirements and those used during construction are noted.

##### **3.8.4.6.1 Reinforced Concrete**

###### **A. Concrete**

All concrete work is done in accordance with ACI 318-63, "Building Code Requirements for Reinforced Concrete," and ACI 301-66, "Specifications for Structural Concrete for Buildings," except as otherwise stated herein or in the appropriate job specifications or design drawings.

The concrete is a dense, durable mixture of sound coarse aggregates, fine aggregates, cement, and water. In some areas, fly ash is substituted for portions of cement used in the concrete. Admixtures are added to improve the quality and workability of the plastic concrete during placement and to retard the set of concrete. The sizes of aggregates, water-reducing additives, and slumps are selected to maintain low limits on shrinkage and creep.

Concrete radiation shields were constructed in accordance with the requirements of Regulatory Guide 1.69 (December 1973).

###### **B. Aggregates**

Aggregates comply with ASTM C 33, "Specifications for Concrete Aggregates." Acceptability of the aggregates is based on the initial tests listed in table 3.8-17.

Certain user tests, as indicated in table 3.8-17, were performed during construction on the aggregates used in every 500 tons of concrete produced. Presently, the user tests on the aggregates are performed within 6 months prior to a job.

## HNP-2-FSAR-3

In addition, a daily inspection/control program is carried out during construction to ascertain the consistency in the potentially variable characteristics such as gradation and organic content.

### C. Cement

Cement is either Type I, general use cement with no special properties, or Type II, low-alkali cement, in accordance with ASTM C 150-74, "Specification for Portland Cement," and is tested to comply with the requirements of ASTM C 114, "Chemical Analysis of Hydraulic Cement." Presently, Type II cement is only required when potentially reactive aggregates are used; however, during construction and Type II cement was used. The inspection and testing of cement, in addition to the initial tests performed by the cement manufacturer, are indicated in table 3.8-18.

During construction user tests were performed on the cement used in every 2800 tons of concrete produced. Presently, a certified mill test report is supplied stating compliance with ASTM C 150 for the cement used.

### D. Fly Ash

Fly ash conforms to ASTM C 618-68T Class F, "Fly Ash and Raw or Calcined Natural Pozzolans for Use in Portland Cement Concrete," and is tested to comply with the requirements of ASTM C 311-68, "Sampling and Testing Fly Ash for Use as an Admixture in Portland Cement Concrete."

The producer is required initially to test and then submit data on each lot of fly ash furnished. User tests, as indicated in table 3.8-19, are performed for each 200-300 tons of concrete produced. In addition, periodic tests in accordance with ASTM C 109-64 are performed during construction to check the environmental effects of storage on fly ash.

Fly ash was not used in concrete used for walls, floors, and ceilings of background-sensitive areas, such as, instrument calibration stations, counting rooms, radiochemical laboratory, etc.

### E. Water

During construction, water used in mixing concrete was free from injurious amounts of acid, alkali, organic matters, and other deleterious substances as determined by AASHTO-T-26.

Presently, mixing water used for concrete is fresh, clean, and drinkable, except that undrinkable water may be used if it produces mortar cubes having 7- and 28-day strengths  $\geq 90\%$  of the strength of similar specimens made with water from a municipal supply, and will not cause a change in the setting time of Portland Cement of  $> 25\%$ . The strength comparison shall be made on mortars (identical except for the mixing water) prepared and tested in accordance with "Method of Test for Compressive Strength Hydraulic Cement Mortars," ASTM C 109.

F. Admixtures

The selected water-reducing agent Pozzolith 80, manufactured by the Master Builders Company, possesses a shrinkage-reduction effect similar to the types prescribed by ASTM C 494, "Specifications for Chemical Admixtures for Concrete."

An air-entraining agent, MBVR, which conforms to ASTM C 260, manufactured by the Master Builders Company, is added to the concrete mix to increase workability.

Admixtures containing chlorides are not used.

G. Concrete Mix Design

Concrete mixes are designed in accordance with ACI 613-54, "Recommended Practice for Selecting Proportions for Concrete," using materials qualified and accepted for this work. Only concrete mixes meeting the design requirements specified for the structures are used.

Presently, concrete mixes are proportioned according to ACI 211.1, "Recommended Practice for Selecting Proportions for Normal and Heavyweight Concrete."

Trial mixes are tested in accordance with the applicable ASTM specifications as indicated below:

| <u>ASTM</u> | <u>Test</u>                                                  |
|-------------|--------------------------------------------------------------|
| C 39        | Compressive strength of molded-concrete cylinders            |
| C 144       | Slump of Portland Cement concrete                            |
| C 192       | Making and curing concrete test specimens in the laboratory  |
| C 231       | Air content of freshly mixed concrete by the pressure method |
| C 173       | Air content by the volumetric method                         |

H. Concrete Testing

During construction, concrete is sampled and tested to ascertain conformance to the specifications. Concrete samples are taken from the mix in accordance with ASTM C 172, "Method of Sampling Fresh Concrete."

During construction, six cylinders, three sets of two cylinders each, were prepared from each sampling and cured in accordance with ASTM C 31, "Making and Curing Concrete Compressive and Flexural Strength Test Specimens in the Field." Presently, only two sets of cylinders are prepared.

The tests consist of the following:

- Determination of air content in accordance with ASTM C 231 or C 173.



## HNP-2-FSAR-3

- Slump test in accordance with ASTM C 143.
- Compressive strength test in accordance with ASTM C 39.
- Determination of temperature.

The frequency and extent of these tests are as follows:

- One complete test for each 50 yd<sup>3</sup> or less mixed at the batch plant.
- One complete test for each 50 yd<sup>3</sup> discharged from the trucks when ready mixed trucks were used.

In addition, all concrete discharged from the truck is visually examined by an experienced inspector during the course of discharge from the truck, and samples are obtained and tested whenever the concrete appears to have excessive slump.

The locations at which the sampled concrete is placed are marked.

### I. Concrete Placement

All concrete for the base slab, drywell shield wall, and all other walls exceeding 2 1/2 ft in thickness has a placing temperature of not < 45°F nor more than 80°F. The concrete had a temperature of at least 55°F when placed for sections 0 to 12 in. and 50°F for sections 12 to 30 in.

If it is necessary to keep the temperature of the concrete from exceeding the above maximums, approved measures for reducing the temperature of the concrete are employed, such as:

- Cooling the mixing water.
- Cooling the aggregates by spraying with water.
- Shading the materials and facilities from direct rays of the sun.
- Insulating water-supply lines.
- Introducing flaked ice into the mix.
- Painting mixers, bins, and other appropriate storage and transporting facilities white.
- Working only at night.

In general, all procedures for hot weather concreting are in accordance with ACI 605-59.

## HNP-2-FSAR-3

During cold weather, concrete is not placed when the mean daily atmospheric temperature is below 40°F, or if it might be subject to freezing temperatures before final set has occurred. Whenever the outdoor temperature is below 40°F, the following procedures are implemented:

1. Prior to placing concrete, sufficient canvas and framework, or other type of housing are provided to maintain all concrete surfaces at least at their respective placement temperatures for not < 3 days. Concrete is protected from freezing for at least 7 days and kept wet during this period.
2. Salt or other chemicals for the prevention of freezing are not used and, when necessary, the concrete material was heated before mixing to maintain the required placement temperatures. Mixing water was not heated to more than 150°F and aggregates to more than 180°F.
3. No frozen materials were used in the concrete irrespective of whether or not the placement temperature criteria can be met.
4. Before concrete is placed, all ice, snow, and frost was completely removed from the surfaces which were in contact with the new concrete, and the temperature of these surfaces was raised within 10°F of the temperature of the concrete to be placed.

In general, all procedures for cold weather concreting are in accordance with ACI 306-66.

### J. Bonding of Concrete Between Lifts

Horizontal construction joints are prepared for receiving the next lift by either wet sandblasting, by cutting with an air-water jet, or by bush hammering.

When wet sandblasting is employed, it is continued until all laitance, coatings, stains, and other foreign materials are removed. The surface of the concrete is washed thoroughly to remove all loose materials.

When air-water jet cutting is used, it is performed after initial set has taken place but before the concrete has taken its final set. The surface is cut with a high-pressure air-water jet to remove all laitance and to expose clean, sound aggregates, but not to undercut the edges of the larger particles of the aggregates. After cutting, the surface is washed and rinsed as long as there is any trace of cloudiness of the wash water. When it is necessary to remove accumulated laitance, coatings, stains, and other foreign materials, wet sandblasting is used before placing the next lift, to supplement air-water jet cutting.

The horizontal surface is wet immediately before the concrete is placed.

Surface-set retardant compounds are not used.

### **3.8.4.6.2 Reinforcing Steel**

All reinforcing steel conforms to ASTM A 615-68, "Deformed Billet-Steel Bars for Concrete Reinforcement," Grade 60.

Mill test reports are obtained from the reinforcing steel supplier for each heat of steel to ensure that the physical and chemical properties of the steel are in compliance with the ASTM specifications. In addition, during construction user tests consisting of tension and bend tests, in accordance with ASTM A 615-68, were performed to supplement the standard mill tests. One tension test and one bend test were required for each 50 tons of each bar size from each heat of steel, with the exception that bend tests are not performed on No. 14 and No. 18 bars.

Bars No. 11 and smaller are generally lap spliced in accordance with ACI 318-63. Bars No. 14 and No. 18 are Cadweld spliced exclusively.

Splicing reinforcing bars by welding is not done.

Procedures for splicing reinforcing bars using the Cadweld process are defined in supplement 3.8C.

### **3.8.4.6.3 Structural and Miscellaneous Steel**

All structural and miscellaneous steel conforms to the following ASTM specifications:

- Rolled shapes, bars, and plates A 36-70a
- High-strength bolts A 325-7I or A-490-71
- Stainless steel A 240, Type 304

Mill test reports are obtained for all materials used with the exceptions of handrails, toe plates, kickplates, stairs, and ladders.

Detailing, fabrication, and erection of the structural and miscellaneous steel are in accordance with the Manual of Steel Construction, 1969 Edition.

Welding is done in accordance with AWS D 1.0-69, "Code for Welding in Building Construction."

NCIG-01 Rev. 2, "Visual Weld Acceptance Criteria For Structural Welding At Nuclear Plants," may be used in addition to AWS D1.0-69.

### **3.8.4.7 Testing and Inservice Surveillance Requirements**

No structural preoperational testing of the Seismic Category I structures is planned. During the life of the plant, periodic inspections of the structures are made to employ visual inspection for apparent structural deterioration such as large cracks and excessive deflection of structural

members. All seam and plug welds in the spent-fuel pool liner plate were vacuum-box tested upon completion of the welding. Where vacuum-box testing was not possible, liquid penetrant testing was performed.

The spent-fuel pool has a system that provides for leakage to be detected at any time in the life of the plant. This system consists of troughs under the liner plate which lead to a collection system where leakage can be observed.

### **3.8.5 FOUNDATIONS AND CONCRETE SUPPORTS**

The foundations for all Seismic Category I structures, other than Seismic Category I outdoor tank foundations, are supported by undisturbed Altamaha or Duplin formation with a static-bearing capacity in excess of 15,000 lb/ft<sup>2</sup>. Seismic Category I outdoor tank foundations rest on fill compacted to 95% of the relative maximum dry density as determined by the Modified Proctor test. Each of the Seismic Category I structures is constructed on an individual mat foundation. A 3-in. gap is provided between the individual buildings to eliminate the possibility of interaction and impact between buildings during an earthquake.

#### **3.8.5.1 Description of Foundations and Supports**

##### **A. Primary Containment**

The drywell and suppression chamber are supported by the reactor building foundation mat. Drawing no. H-25000 shows the outline of the primary containment resting on the foundation slab. A description of the reactor building foundation mat is given in paragraph 3.8.5.1.

##### **B. Reactor Building**

The reactor building foundation is a 149-ft<sup>2</sup>-reinforced concrete mat, 27-ft 2-in. thick at the middle drywell and reactor vessel support area and 12-ft 4-in. thick at other sections, bearing directly on the Duplin formation.

Drawing no. E-10173 shows the relative positions of the two reactor building foundations and other Seismic Category I structures' foundations. Suppression chamber seismic ties and support columns, RCIC turbine and pump, reactor vessel support pedestal, and the end walls are anchored to the base mat. Figure 3.8-30 shows the reactor building foundation mat general arrangement plan at el 87 ft and 101 ft 10 in.

Figure 3.8-31 shows typical details of end-wall anchorage to the base slab, reinforcing details for the transition zone between el 87 ft and 93 ft 2 in., general reinforcing for the base mat, and details of reinforcing directly under the reactor vessel pedestal.

## HNP-2-FSAR-3

### C. Diesel Generator Building

The diesel generator building foundation, which is common to both HNP-1 and HNP-2, shown on drawing no. H-12320, is a reinforced concrete rectangular mat 196 ft times 103 ft 6 in., with the bottom of the mat at el 125 ft. The static foundation pressure below the structure is < 3 ksf. The relative position of the mat, with respect to the other structures, is shown on drawing no. E-10173.

### D. Control Building

The control building foundation mat, which is common to both HNP-1 and HNP-2, shown on drawing nos. H-12405, H-12406, H-12627, H-12629, H-12631, H-16249, H-22250, H-40429, and H-40430 is a reinforced concrete rectangular mat 160 ft times 103 ft, with the bottom of the mat at el 105 ft. The foundation mat is separated from the HNP-1 and HNP-2 turbine building mats which are also found at the same elevation by a gap of 3 in. The average static foundation pressure below the structure is 6 ksf. The relative location of the mat with respect to the other structures is shown on drawing no. E-10173.

### E. Intake Structure

The intake structure, which serves both HNP-1 and HNP-2, shown on drawing no. H-26099, is built on a reinforced concrete, rectangular mat 103 ft times 53 ft, with the bottom of the mat at el 52 ft. The average static foundation pressure is 5 ksf.

### F. Lower RPV Pedestal

The lower pedestal is anchored to the reactor building foundation mat at el 101 ft 10 in. by ninety-two 3-in.-diameter anchor bolts as shown in figure 3.8-32.

### G. Main Stack

The main stack foundation is an 11-ft-thick octagonal reinforced concrete slab bearing on H-bearing piles which transfer the loads to the Duplin formation.

- Plan dimensions - octagon with 36-ft inscribed radius.
- Yard, el 119 ft 6 in.
- Top of cap, el 108 ft 6 in.
- Bottom of cap, el 97 ft 6 in.
- Pile cutoff, el 98 ft 3 in.
- 164-14BP73 100-ton piles at 4- to 6-ft spacing in 5 rings with radii of 6 ft, 16 ft, 20 ft, 30 ft, and 34 ft, piles driven to el 20 ft.

## HNP-2-FSAR-3

- Loads on pile foundation of 114,000 kip-ft moment, 21,500 kips vertical load at pile cap.
- A shear of 800 kips is supported by the piles and pile cap.

Figure 3.8-33 shows the details of pile tip and vertical wall anchorage to the base slab. Drawing no. E-10173 shows the relative position of the main stack foundation to the other Seismic Category I structures.

### H. Seismic Category I Outdoor Tank Foundations

There are two Seismic Category I outdoor tank foundations:

- Condensate storage tank foundation.
- Liquid nitrogen storage tank foundation.

The foundations of these tanks are 3-ft-thick reinforced concrete slabs bearing on fill compacted to 95% of the relative maximum dry density as determined by the Modified Proctor test.

The tank foundations are physically separated from each other and from other buildings as shown on drawing no. E-10173.

### **3.8.5.2 Applicable Codes, Standards, and Specifications**

*The following codes, standards, and specifications apply to the original design and construction of the foundations and concrete supports for all Seismic Category I structures.*

|                       |                                                                                                                                                         |
|-----------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|
| <i>ACI 318-63</i>     | <i>Building Code Requirements for Reinforced Concrete</i>                                                                                               |
| <i>ACI 307</i>        | <i>Specifications for the Design and Construction of Reinforced Concrete Chimneys</i>                                                                   |
| <i>AISC</i>           | <i>Manual of Steel Construction</i>                                                                                                                     |
| <i>AWS D.12.0</i>     | <i>Seventh Edition AWS D.12.0 Recommended Practice for Welding Reinforcing Steel, Metal Inserts and Connections in Reinforced Concrete Construction</i> |
| <i>AWS D.1.0-69</i>   | <i>Welding in Building Construction</i>                                                                                                                 |
| <i>NCIG-01 Rev. 2</i> | <i>Nuclear Construction Issues Group (NCIG) Specifications for Visual Weld Acceptance Criteria For Structural Welding At Nuclear Plants</i>             |

## HNP-2-FSAR-3

|                              |                                                                                                          |
|------------------------------|----------------------------------------------------------------------------------------------------------|
| <i>SBCC</i>                  | <i>Southern Standard Building Code, 1969 Edition</i>                                                     |
| <i>ICBO</i>                  | <i>Uniform Building Code, 1970 Edition</i>                                                               |
| <i>CFR</i>                   | <i>Title 29 Code of Federal Regulations, Chapter XVII, Occupational Safety and Health Standards</i>      |
| <i>CFR</i>                   | <i>Title 10 Code of Federal Regulations Part 50, Licensing of Production and Utilization Facilities</i>  |
| <i>NRC Regulatory Guides</i> | <i>Compliance is discussed in Appendix A.</i>                                                            |
| <i>Regulatory Guide 1.10</i> | <i>Mechanical (Cadmold) Splices in Reinforcing Bars of Category I Concrete Structures (January 1973)</i> |
| <i>Regulatory Guide 1.15</i> | <i>Testing of Reinforcing Bars for Category I Concrete Structures (December 1972)</i>                    |
| <i>Regulatory Guide 1.55</i> | <i>Concrete Placement in Category I Structures (June 1973)</i>                                           |
| <i>Regulatory Guide 1.59</i> | <i>Design Basis Floods for Nuclear Power Plants (August 1973)</i>                                        |
| <i>Regulatory Guide 1.64</i> | <i>Quality Assurance Program Requirements for the Design of Nuclear Power (October 1973)</i>             |

*Material specifications which were used to produce the concrete or the Seismic Category I foundations and concrete supports are given in paragraph 3.8.4.6.*

For new modifications and analysis of modifications installed after the plant was put into operation, later editions of the following codes will be used:

- AISC - Manual of Steel Construction.
- ACI - Building Code Requirements for Reinforced Concrete (ACI 318).
- ACI - Specifications for the Design and Construction of Reinforced Concrete Chimneys (ACI 307).
- AWS - Welding in Building Construction (D1.0).
- AWS - Recommended Practice for Welding Reinforcing Steel, Metal Inserts, and Connections in Reinforced Concrete Construction (AWS D12.0).
- AWS - Structural Welding Code (AWS D1.1).

- Southern Standard Building Code.
- Uniform Building Code.

For analysis or modification of original plant designs, a later edition of the codes listed above may be used; however, the applicable sections of the original plant design codes must be reviewed. Differences between the original design codes and a later edition of these codes should be documented. Whenever a code change that is applicable to the design has occurred, a later edition of the code may be used if the change results in a more conservative design than the original design code, or the change results in an acceptable decrease in conservatism based upon a better knowledge or understanding of the condition because of tests or experience by the code committee. If the code change results in a less conservative design and this change is based upon a change in material quality or quality of installation, then the section from the original code edition will be used. To account for changes in steel member properties and dimensions over the years, this information will be obtained from the AISC Code edition used for the original design.

### **3.8.5.3 Loads and Loading Combinations**

Foundation loads and loading combinations for all Seismic Category I structures are discussed in paragraphs 3.8.3.3 and 3.8.4.3.

### **3.8.5.4 Design and Analysis Procedures**

#### **3.8.5.4.1 Reactor Building Foundation**

The analysis and design of the reactor building foundation mat was based on conventional one-way slab fixed at the periphery of the middle 27-ft 2-in.-thick section and simply supported at the diagonal and exterior walls subjected to uniform soil pressure. The soil material under the reactor building foundation mat has been assumed to be homogeneous, isotropic, elastic, and of uniform thickness.

#### **3.8.5.4.2 Reactor Vessel Pedestal Foundation**

The pedestal is assumed to be a short vertical cantilever beam fixed at the base. To attain fixity, the anchor bolts are prestressed for the normal operating OBE loads.

The structural response is assumed to be linear and elastic for all loading combinations.

It is assumed that friction or bond between the concrete and the lower drywell shell plates does not contribute to resisting the loads.

The embedded portion of the anchor bolt is coated with asphaltum and wrapped with tape and hence no bond is assumed to exist between the coated surface and the concrete.



Since the shear planes in the concrete overlap between the anchor bolts, the available shear area between the rows of bolts is neglected in design.

The inside and outside rings of the pedestal are full-butt welded to a circular base plate projecting sufficiently on either side to accommodate the stiffener attachments as shown in figure 3.8-32.

Sixty-four 3-in.-diameter A193 B7 anchor bolts are provided for the outer ring and 28 for the inner ring. The length of embedments for these anchor bolts are 10 ft 0 in. for the outer ring and 7 ft 0 in. for the inner ring. The lower ends of the anchor bolts are attached to 3-in.-thick embedded plates by a double bolting system.

The loads are transmitted to the foundation by bearing between the base plate and concrete and by uplift in the anchor bolts. To maintain fixity at the base of the pedestal, the anchor bolts are prestressed to normal OBE loads. The values of the torque and strain applied to obtain the prestressing required are indicated in figure 3.8-32.

For all combinations of loading, except construction, the lower pedestal is embedded in concrete and hence the horizontal shear force is transmitted directly by bearing on the concrete in the embedded zone.

For the construction condition, the anchor bolts transmit the horizontal shear force to the concrete as individual bolt loads not exceeding those permitted by the Uniform Building Code, 1970 Edition, table 26-1.

The loads for various loading combinations are distributed to the outer and inner rings of the pedestal according to the geometrical and structural properties of both rings. The base plate, stiffener plates, anchor bolts, embedded bearing plates, and connections are designed for these loads.

Figure 3.8-32 shows the number, size, and location of the anchor bolts for the outer and inner rings. The base plate detail, stiffener arrangement, embedded plate thickness and size, construction details, and requirements, along with the actual loads for different loading combinations, are also shown in figure 3.8-32.

#### **3.8.5.4.3 Other Structures**

The seismic techniques for analysis and design of the foundations for all other Seismic Category I structures are the conventional methods which involve simplifying assumptions such as are found in the theory of concrete structures. Stresses resulting from local moments, torques, concentrated reactions, and uniform loadings are computed by these methods. The soil under these buildings has been assumed to be homogeneous, isotropic, elastic, and of uniform thickness.

### **3.8.5.5 Structural Acceptance Criteria**

The foundations of all Seismic Category I structures are designed to meet the same structural acceptance criteria as the structures themselves. These criteria are discussed in paragraphs 3.8.2.5, 3.8.3.5, and 3.8.4.5.

The allowable bearing pressure of 15,000 lb/ft<sup>2</sup> for all Seismic Category I structures recommended by the Law Engineering Testing Company was not exceeded for the most extreme loading combination.

The foundations of the individual structures are assumed to settle uniformly and independently and the estimated settlements for different buildings are discussed in supplement 2A.

All Seismic Category I structures rest on individual rigid mat foundations. In general, the sands which support the plant structures are dense and incompressible. The buildings are not structurally connected to each other and therefore settle independently. The estimated settlements of the individual plant structures are discussed in supplement 2A, section 2A.5.

The diesel generator building, intake structure, and main stack are physically separated by considerable distances and are on independent foundation mats as shown on drawing no. E-10173. The relative displacements between these buildings do not affect the safety objective.

The reactor building and the control building are physically separated by a 3-in. gap extending all the way through the foundation. Most of the total settlement occurs during construction. The maximum predicted post-construction settlement for the reactor building is in the range of 0.5 in., while it has been negligible for the control buildings, and hence their relative maximum displacement does not impair the integrity of these structures.

The horizontal forces were assumed to be resisted by sliding friction, and a minimum factor of safety against sliding for the most severe loading combination was well above 1.50.

The effects of overturning and floatation of all the structures were investigated, and a minimum factor of safety of 1.50 was maintained for the most critical loading combination.

### **3.8.5.6 Materials, Quality Control, and Special Construction Techniques**

The foundations and equipment supports are built of reinforced concrete, using proven methods for heavy industrial construction. The description of the materials and the quality control procedures, as well as special construction techniques for foundations, are the same as those discussed in paragraphs 3.8.2.6, 3.8.3.6, and 3.8.4.6.

### **3.8.5.7 Testing and Inservice Surveillance Requirements**

Testing and inservice surveillance are not required and are not planned for foundations of structures or supports. A discussion of the test program which serves as the basis for the soils investigation and foundation evaluation is found in chapter 2.

### **3.8.6 RESPONSES TO UNITED STATES NUCLEAR REGULATORY COMMISSION (USNRC) INSPECTION AND ENFORCEMENT (IE) BULLETINS (HNP-1 AND HNP-2)**

This section provides a summary of the responses to the following two USNRC IE Bulletins:

- USNRC IE Bulletin 80-11, "Masonry Wall Design."
- USNRC IE Bulletin 79-02, "Pipe Support Base Plate Design Using Concrete Expansion Anchor Bolts."

#### **3.8.6.1 Summary of Responses to USNRC IE Bulletin 80-11, "Masonry Wall Design"**

##### **3.8.6.1.1 Introduction**

For HNP-1 and HNP-2, masonry wall design was reevaluated in accordance with the requirements of IE Bulletin 80-11, "Masonry Wall Design," May 8, 1980.

##### **3.8.6.1.2 Reevaluation Approach**

Concrete masonry walls were reevaluated by considering the relative potential for wall failure based on wall configuration, loading magnitudes, and span lengths. Detailed reevaluations were performed for the worst-case walls. A relatively large number of the lesser case walls were also reevaluated in detail to ensure the structural adequacy of each wall and to ensure that a large enough sample was selected to include all walls requiring a detailed reevaluation. The remainder of the lesser case walls in each priority were reevaluated by comparison with the worst-case walls. This ensured that the most critical walls were considered for prompt, detailed reevaluation.

Attachments to concrete masonry walls were identified during the plant walkdowns. The weight of each component attached to a wall was determined and proportioned to its supports on the wall. All pipes and conduits were assumed full for purposes of the analysis. Conservative weights were supplied for all pieces of equipment to ensure that future minor changes in equipment would not increase the load on the walls and to provide an additional safety factor for the analysis.

### HNP-2-FSAR-3

No major piping systems were found to be attached to any concrete masonry walls, and all systems that were attached were sufficiently rigid to ensure that the attachments would all experience the same acceleration as the wall. Therefore, the load due to each attachment multiplied by the acceleration of the wall was assumed to equal the inertial loads from that attachment.

The attachment inertial loads were combined directly with the wall inertial loads using the absolute sum method. In addition, moments obtained by multiplying the inertial load of each piece of equipment by the distance from the center of gravity of the reinforcing to the center of gravity of the equipment were also applied to the wall. Because most major loads on the walls came from individual pieces of equipment such as panelboards and pull boxes rather than from piping or conduit systems, the method used to account for equipment weights is conservative in the design of the wall.

Seismic analyses were performed using the floor response spectra for the floor location above the wall, and 3% and 5% dampings were used for the OBE and DBE, respectively, for both cracked and uncracked sections.

Consistent with the original design of the plant and with the FSAR, horizontal earthquake loads were applied in only one direction at a time.

For a horizontal earthquake acting perpendicular to a given wall, the wall was checked for all stresses due to the inertial load of the wall itself, inertial loads due to attached equipment, and static moments from attached equipment. These loads were all combined by the direct sum method. In addition, out-of-plane drift effects were included.

For a horizontal earthquake acting parallel to the wall, in-plane drift effects and equipment inertial loads were considered for the overall evaluation of the wall.

For a vertical earthquake, the inertial load moments due to attached equipment were applied to the wall. None of the walls are load bearing; therefore, the only other load considered was the inertial load of the wall itself due to a horizontal earthquake acting perpendicular to the wall.

For each of the conditions listed above, the wall was checked to ensure local load transfer from all attachments to the wall.

Analyses were performed using horizontal wall strips modeled as simply supported beams and/or finite element models, depending on the degree of complexity required to ensure the structural adequacy of the walls. Allowable wall stresses were based on the reevaluation criteria given in supplement 3.8C of this report. Supplement 3.8C also provides justification for the selected design criteria.

### **3.8.6.1.3 Function, Configuration, Type, and Strength of Materials, and Construction Practices for Masonry Block Walls**

**3.8.6.1.3.1 Function of Walls.** Concrete masonry walls located in Class 1 buildings are all internal nonload bearing walls intended for use as partition walls, fire walls, and shield walls. None are intended or required to resist impact or pressurization loads such as tornados, missiles, pipe break, pipe whip, or jet impingement. A secondary function of these walls is to provide at least partial support for relatively light equipment and components such as small diameter piping, conduit, instrument lines, instrumentation, and electrical boxes.

**3.8.6.1.3.2 Wall Configurations.** Concrete masonry walls subject to reevaluation are single-wythe units constructed of normal-weight concrete blocks with nominal widths of 8 or 12 in. Horizontal joints are reinforced with extra-heavy single-wythe reinforcing trusses. Vertical reinforcing and cell fill are accomplished in two ways: some walls have every cell filled with concrete and No. 5 reinforcing bars spaced at 1 ft 4 in., while the rest of the walls have cell concrete and No. 6 reinforcing bars spaced at 2 ft 3 in. maximum. (Presently, the use of nonshrink grout is allowed in place of concrete for cell fill.) Vertical, reinforced concrete columns are strategically located along the walls to reduce the effective span length of the walls. All walls are recessed 1 in. into the supporting floor, with No. 4 reinforcing dowels projected into walls from the supporting floor at a spacing of 1 ft 4 in.

Masonry walls are anchored to structural concrete walls or columns with one or two dovetail stone anchors at each horizontal joint. In cases where dovetail anchor slots were not provided in the concrete, the masonry walls were anchored to the concrete with 3/16-in.-diameter wire ties attached to a structural shape which is in turn anchored to the concrete with 3/8-in.-diameter expansion bolts.

Each wall is set to within a minimum of 1/2 in. below the bottom of the concrete floor slab above, except for walls with suspended ceilings on both sides which extend one block course above the suspended ceiling. The gap between the masonry wall and the concrete slab is filled with insulating material.

The arrangement and location of concrete masonry walls in Class 1 buildings are shown on drawing nos. H-12320, H-12626 through H-12629, H-12631, H-12632, H-15851, H-15852, H-15854, H-16027, H-16029, H-16030, H-16249, H-22250, H-26098 through H-26105, H-40429, and H-40430. Figures 3.8-34 through 3.8-37 provide single-line wall sketches showing relative location and numbering scheme of the concrete masonry walls in the control building. Figures 3.8-38 through 3.8-45 show examples of wall surveillance sketches.

**3.8.6.1.3.3 Type and Strength of Materials.** A discussion is presented below for each of the primary materials used in the construction of concrete masonry walls at HNP.

## HNP-2-FSAR-3

### Concrete Blocks

These are hollow concrete masonry units made from Portland cement and normal weight aggregates for hollow load bearing units conforming to ASTM C 90-70, Grade N, Type I. Exposed surfaces are specified to have a fine- to medium-coarse texture and uniform color throughout. All units are specified to be free of cracks, chips, or other imperfections that could impair the strength or permanence of the constructed walls.

### Reinforcement

Horizontal wall reinforcement is extra-heavy (3/16-in. diameter) Durowall single-Wythe trusses manufactured from cold-drawn steel wire, conforming to ASTM A 82. The reinforcement is galvanized and side rods are deformed. Vertical wall reinforcing consists of deformed No. 5 and No. 6 bars, Grade 60, meeting the requirements of ASTM A 615-68. Dowels are No. 4 deformed bars.

### Grout

Grout used to fill the masonry cells during construction was nonshrink grout having a minimum compressive strength of 4000 psi at 28 days. The mix proportions are specified as 1-part Portland Cement, 1-part concrete sand, sufficient grams per sack of cement of an aluminum powder required to cause initial and sustained expansion, and ~ 5 gal of water per sack of cement. The maximum aggregate size is No. 4 (1/2 in.), and the nominal slump is 0 in. Premixed, nonshrink grout may be used for concrete masonry unit fill material and must have a 4000-psi compressive strength in accordance with ASTM C 109. One set of grout cubes shall be cured and tested once per lot or at least once per month.

### Mortar

Masonry mortar during construction was standard class mortar consisting of 1-part Portland Cement, 1/4-part hydrated lime, and 3-parts mortar sand with only sufficient quantities of water to produce the required workability. (Presently, the mortar type used shall be specified by the designer in accordance with ASTM C 270.)

### Mortar Sand

Mortar sand is specified to conform to ASTM C 144, except that all sand is required to pass a No. 8 sieve and not < 97% is to be retained on No. 100 sieve.

### Hydrated Lime

Hydrated lime for masonry mortar is specified to conform to ASTM C 207, Type S.

### Aluminum Powder

Aluminum powder for nonshrink grout is specified to be commercial grade conforming to ASTM D 962, Type I, Class B.

#### Dovetail Stone Anchors

These are specified to be 3/16-in. times 10 1/4-in. times 24-in. long, formed from carbon steel and hot-dip galvanized, Hohmann, and Barnard, Inc. No. 304, or equal.

**3.8.6.1.3.4 Reinforcement Details.** Wall reinforcement details are discussed in paragraph 3.8.6.1.3.2. Also, typical block wall details, including reinforcing, are shown in figures 3.8.6-46 through 3.8.6-49.

**3.8.6.1.3.5 Construction Practices.** Detailed concrete specifications were prepared to govern all concrete work at HNP, including concrete masonry. Civil concrete inspectors were assigned to inspect the construction of concrete masonry walls to ensure that the walls were constructed in accordance with the drawings and specifications.

As a matter of general practice, during construction, approval was obtained from the architect/engineer for deviations from the requirements of the drawings and/or specifications.

Concrete blocks were filled on a course-by-course basis, and a wooden tamping rod was used ensure that all voids in the blocks were filled. Also, when the top course of block was laid, it was formed to the existing overhead floor and the blocks were poured full of grout. Detailed erection specifications for concrete masonry walls, reinforcing, and grout were prepared and properly implemented with appropriate inspections.

#### **3.8.6.1.4 Discussion of Results and Conclusions**

The concrete masonry walls in Class 1 buildings at the HNP were reevaluated in accordance with the requirements of IE Bulletin 80-11, "Masonry Wall Design."

The objective of the reevaluations was to verify that the masonry walls would perform their intended function under all postulated loads without endangering safety-related components or systems either attached to the walls or in proximity to the walls.

The status of the reevaluation for each wall is shown in table 3.8-20. Out of 166 walls surveyed, 5 were shown to be concrete walls and 53 were determined to have no safety-related equipment or systems attached to or in proximity to the walls. In these instances, no further analysis was required. In addition, six walls which had safety-related equipment in proximity were supported on both sides by a structural steel frame designed to protect the equipment during a seismic event; no further analysis was required for these walls. The remaining walls were analyzed for the as-built condition for all loads and load combinations utilizing a conservative approach based on a horizontal beam strip. A number of the worst-case walls were then modeled for STRUDL-DYNAL and had a finite element analysis run of the as-built condition, taking into account all loads and load combinations. A total of 10 walls was identified where calculated stresses exceeded allowable stresses. The results of the analysis showed that the effective horizontal span length of the wall should be reduced. Therefore, a point somewhere within the middle one-third of the span of the wall was chosen, considering

## HNP-2-FSAR-3

obstructions and installation problems, and one or more structural steel columns were erected to provide additional support for the wall. The column(s) were designed to withstand the applied loads and were used to brace the wall. The wall was then remodeled for STRUDL-DYNAL, including the steel column, and a finite element analysis was performed again for all postulated loads and load combinations. Resulting moments and shears for the masonry wall and support column were checked against allowables. In addition, bolts, plates, and welds for the support column were checked for worst-case loads. Wall number C130-14 A and B had an angle brace attached to the ceiling in addition to the structural steel column on each side of the wall to provide lateral shear support and reduce a local overstress condition to within allowables. Following the analysis using the modified models, each wall was determined to satisfy all stress allowables.

A total of eight walls has been modified by this method to bring calculated stresses to within design allowables under all postulated loading conditions. The remaining two walls where calculated stresses exceeded design allowables have been removed.

Two of the walls in the HNP-1 reactor building, located in the southeast corner at the personnel elevator on el 130 ft 0 in., have safety-related equipment in proximity and were included in the reevaluations.

In accordance with the criteria addressing interstory drift, the floor displacements resulting from the original building seismic analysis were used to determine the interstory wall strains. It was determined that the calculated masonry wall strains are less than the allowable strains presented in the reevaluation criteria. Therefore, no significant wall cracking is induced by interstory drift effects.

Local load transfer from attachments to the walls is accomplished by either bolting through the wall to a plate on the other side of the wall or by anchoring bolts directly into the wall. For single-Wythe walls, there are four postulated failure modes:

- Failure of the masonry mortar resulting in a single block pullout.
- Shear failure of the masonry around the plate.
- Shear cone failure around an individual bolt.
- Local crushing of the masonry under the bolt under the action of shear loads on the bolt.

Every piece of equipment attached to a concrete masonry wall was analyzed for each of these failure modes using conservative loads and spectral accelerations. Allowable loads at local attachments were based on code allowables for shear and bearing. Therefore, local stresses due to vertical and horizontal forces and moments were considered, and determined not to create an overstress condition when compared with code allowables.

Based on a review of the original seismic analysis of the masonry walls in Class 1 buildings at the HNP, the conservative reevaluations performed in accordance with the requirements of USNRC IE Bulletin 80-11, and the review of construction practices for masonry walls, it is



concluded that the concrete masonry walls at the plant perform their intended function during all postulated loading. For those walls showing stresses above design allowables during seismic loadings, fixes were implemented to reduce the stresses to within the design allowables.

#### **3.8.6.1.5 Computer Program - BLOCK WALLS**

Supplement 3.8C provides the description of the computer program BLOCK WALLS in sufficient detail to establish the applicability and validation of the program, with solutions checked against other solutions of classical problems.

#### **3.8.6.2 Summary of Responses to IE Bulletin 79-02, "Pipe Support Base Plate Designs Using Concrete Expansion Anchor Bolts"**

##### **3.8.6.2.1 Introduction**

For HNP-2, the pipe support base plate design was reevaluated in accordance with the requirements of IE Bulletin 79-02 (March 8, 1979), Revision 1 (June 21, 1979), Supplement No. 1 to Revision 1 (August 20, 1979), and Revision 2 (November 8, 1979).

##### **3.8.6.2.2 Background**

Concrete expansion anchors employed in nuclear power plant construction to provide a means to quickly and economically attach pipe support systems to the vertical and horizontal surfaces of concrete structures for years were installed with reliance on the skill of the craftspersons employed for such tasks, i.e., pipefitters and millwrights. However, instances have occurred where these anchors failed in service, raising questions regarding the degree of reliance to be placed on the safety factors assigned to the particular design.

Beginning in late February 1979, Georgia Power Company (GPC) notified Bechtel that several pipe supports provided for the reactor feedwater system piping housed within the turbine building had failed. The piping had fallen from its supported location to the turbine building floor, a distance of ~ 18 in. The cause of failure was determined to be the improper installation of the support system concrete expansion anchors. Due to this situation, GPC requested Bechtel to develop a program of expansion anchor testing to ensure public safety and plant reliability.

In March 1979, the USNRC issued IE Bulletin 79-02 which required nuclear plant owners to examine their construction and engineering records to verify pipe support base plate rigidity (an assumption used in expansion anchor loading calculations) and satisfactory expansion anchor selection and installation.

The USNRC agreed that a written review of the as-built conditions was sufficient as long as supporting documentation was available. However, when such documentation was not available, a suitable testing program would be required to prove the existence of the assumed safety factors in the design.

For the HNP, it was necessary to develop a suitable testing program to respond to IE Bulletin 79-02, as well as Revision 1, Supplement 1 to Revision 1, and Revision 2 of the Bulletin.

### **3.8.6.2.3 Discussion of Concrete Expansion Anchor Testing and Replacement Program**

In order to ensure public safety, those systems essential to safe plant shutdown and/or accident mitigation were the subject of the anchor testing and inspection program. As an owner/operator of numerous central generating stations employing concrete expansion anchors, GPC agreed that plant reliability was not a consideration and, therefore, systems nonessential to safety were eliminated from the test program.

Discussions between Bergen-Paterson Pipesupport Corporation (the pipe-support designer and fabricator), Bechtel, and GPC revealed that little, if any, documentary evidence existed in support of the pipe-support base plate rigidity assumption. A review of construction as-built records and an inspection of the physical plant revealed that expansion anchor substitutions had been made, in many cases without supporting documentation. In addition, GPC construction quality control had not employed an anchor installation inspection program that was sufficiently documented to verify correct anchor installation techniques.

In light of the above, a base plate design verification program was initiated, employing Bergen-Paterson in the development of base plate loads, and Bechtel in the determination of base plate rigid/flexible conditions. An anchor testing program was also developed and implemented to verify proper expansion anchor installation.

A description of the above actions follows in the form of responses to specific attributes of IE Bulletin 79-02.

**3.8.6.2.3.1 Base Plate Flexibility and Design Criteria.** As part of the original design, Bechtel provided Seismic Category I piping analyses and forwarded supported system design loads to Bergen-Paterson. Bergen-Paterson supplied design and fabrication of the pipe-support systems and shipped the support assemblies to the plant site for installation by the piping contractor, M. W. Kellogg.

Because flexibility of the base plate was not specifically taken into account in determining the concrete anchor bolt loads during the original design phase, GPC initiated a program to take base plate flexibility into account and reassess the concrete anchor bolt load. Bergen-Paterson was employed to develop design loads (through dimensional forces and moments) at the centroid of each attachment to the pipe-support base plates. Bechtel utilized this data to determine the adequacy of the as-found base plate anchor systems. This determination was accomplished through analyses based on an empirical-analytic technique (developed by

### HNP-2-FSAR-3

Bechtel) which takes into account design parameters such as flexibility of the base plates and concrete anchors stiffness (based on actual load-displacement curves furnished by the anchor bolt manufacturer). This method was verified with appropriate finite element solutions.

A computer program for the empirical-analytic technique was implemented for determining the bolt loads for routine applications. The program requires plate dimensions, number of bolts, bolt size, bolt spacing, bolt stiffness, the applied forces, and the allowable bolt shear and tension loads as inputs. The allowable loads for given bolt are determined based on the concrete edge distance, bolt spacing, embedment length, shear cone overlapping, manufacturer's ultimate capacity, and a design safety factor. Supplement 3.8D provides criteria for determining expansion anchor bolt loads in pipe support base plates.

The program computes the bolt forces and calculates shear-tension interaction value based on the allowable loads. The following interaction equation is considered adequate:

$$\left[ \frac{\text{Design Tension}}{\text{Allowable Tension}} \right]^2 + \left[ \frac{\text{Design Shear}}{\text{Allowable Shear}} \right]^2 \leq 1$$

An interaction value > 1 indicates bolt inadequacy (safety factor less than required).

For special cases where the design of the support does not lend itself to this method, standard engineering analytical techniques with conservative assumptions were employed.

If any bolt on a base plate failed in the analysis, one or more of the following actions were taken.

- A. The base plate was reanalyzed assuming the failed bolts(s) carry zero load.
- B. The base plate was reanalyzed assuming bolt replacement.
- C. When feasible, additional expansion anchors were added, and the base plate was reanalyzed.
- D. Larger and/or thicker plates were substituted and reanalyzed.
- E. The existing base plates were stiffened to redistribute the loads to other concrete anchors and reanalyzed.
- F. Additional braces were added to the support to distribute the loading and were reanalyzed.
- G. In those instances where repair/corrective actions resulted in relocation of a piping support, Bechtel analyzed the effect of such modification on the piping system.
- H. Corrective action based on existing field conditions was proposed.

**3.8.6.2.3.2 Safety Factors for Expansion Anchors.** A minimum safety factor of 4.0 between the bolt design load and the bolt ultimate capacity was verified to exist for wedge-type anchors, and a minimum safety factor of 5.0 was maintained for the self-drilling shell-type anchors. It should be noted that in light of the experienced failure rate for shell-type anchors, support devices were modified as necessary to eliminate reliance on shell-type anchors employed in tensile load configurations.

However, for factored loadings (which include accident/extreme environmental loads), a safety factor of 3.0 could have been used commensurate with the provisions of Section B.7.2 of the "Proposed Addition to Code Requirements for Nuclear Safety Related Concrete Structures," (ACI 349-76), August 1978. Also based on the HNP program of 100% verification of acceptable anchor bolts, it would have been justifiable to reduce the safety factor to 2.0.

For snubbers and anchors, DBE (safe shutdown earthquake) loads were included directly for determining design bolt loads. For rigid hangers and restraints, OBE loads were used in determining bolt design loads in the actual calculation of shear-tension interactions. Since the interaction values typically have an additional margin which can accommodate increased loading, and since seismic loads on rigid supports comprise only a part of the entire design load, the bulletin factors of safety are, in general, satisfied for DBE (safe shutdown earthquake) loadings.

**3.8.6.2.3.3 Cyclic Loads.** In the original design of the piping system, Bechtel considered deadweight, thermal seismic, and dynamic operating loads, where applicable, in the generation of the static equivalent pipe support design loads.

The safety factors used for concrete expansion anchors were not increased for those portions of the support load which are cyclic in nature. The use of the same safety factor for cyclic and static loads is based on the FFTF tests.<sup>(18)</sup> The test results indicate:

- A. The expansion anchors successfully withstood 2 million cycles of long-term fatigue loading at a maximum intensity of 0.20 of the static ultimate capacity. When the maximum load intensity was steadily increased beyond the aforementioned value and cycled for 2000 times at each load step, the observed failure load was about the same as the static ultimate capacity.
- B. The dynamic load capacity of the expansion anchors, under simulated seismic loading, was about the same as their corresponding static ultimate capacities.
- C. Preload is not a requirement for the anchor bolts to function in a dynamic loading environment.

**3.8.6.2.3.4 Expansion Anchor Testing Program.** Due to insufficient documentation of the existing installations, an expansion anchor testing program was developed and implemented.

## HNP-2-FSAR-3

The expansion anchor testing program was conducted in accordance with written procedures HNP-2-11004, "Surveillance Procedure for Identifying Anchors Used For Hangers in Safety Systems," and HNP-2-11005, "Inspection and Testing Procedure for Concrete Expansion Anchors."

The following system piping was included in the test program:

- A. All large bore ( $> 2 \frac{1}{2}$ -in.-nominal diameter) piping systems required to function and/or support the function of systems to mitigate the consequences of the DBA discussed in chapter 15.
- B. Computer analyzed piping system  $\leq 1\frac{1}{2}$ -in.-nominal diameter, in safety-related systems.
- C. If  $< 2 \frac{1}{2}$ -in.-diameter pipe was supported using an engineered field procedure, i.e., the "cookbook method," the support systems were not included in this program, unless that portion of pipe was originally analyzed with the main piping system. In that case,  $< 2 \frac{1}{2}$ -in.-diameter pipe supports were inspected from the main pipe to the first anchor on the smaller line.

The specific systems or portions of systems for HNP-2 which had 100% expansion anchor testing or replacement are as follows:

- Primary steam drainage (computer analyzed portion).
- SLCS (pump suction and discharge piping up to containment penetration, Seismic Category I portion).
- Process radiation monitoring (PRM) system (containment penetration to first anchor after second isolation valve) HNP-2 only.
- HPCI system (containment isolation portion).
- RCIC system (containment isolation portion).
- H<sub>2</sub> and O<sub>2</sub> analyzer system (containment isolation portion).
- Drywell pneumatic system (containment isolation portion).
- Diesel oil system (oil piping from day tank to diesel, starting air and cylinder jacket cooling water).
- N<sub>2</sub> inerting system (containment isolation portion).

Since 100% testing of wedge-type expansion anchors and replacement of self-drilling type anchors with wedge type was performed on the above listed systems, it is felt that the supports employing expansion anchors subject to higher

## HNP-2-FSAR-3

concern with regard to system operability have been covered by the program. (NOTE: Small pipe inside the containment relies on welded supports for operability.)

Other supports outside the containment supported by "cookbook" methods have conservatisms inherent to this method of pipe supporting and since no major items which would affect system operability were identified during the testing or replacement of those small pipe supports which were covered by this program, plant safety is not considered to be in jeopardy.

- D. All the anchors not required to take tension loading through their support systems were not included in this program.
- E. Containment penetrations smaller than 2 1/2-in. piping installed with motor- or air-operated isolation valves (a heavy concentration of weight) and supported using standard cookbook methods; these support systems were included in this program up to the first anchor beyond the second isolation valve.

Piping and instrument diagrams, isometric drawings for the large bore and small bore piping, and, if necessary, physical piping drawings, were yellow-lined to identify the piping and systems which were to be subjected to the anchor test program. The program included the following systems:

|      |                                                                                                            |
|------|------------------------------------------------------------------------------------------------------------|
| 2B21 | Nuclear boiler system                                                                                      |
| 2C11 | Control rod drive system (Seismic Category I portion only)                                                 |
| 2C41 | SLCS (complete pump suction and discharge piping up to containment penetration Seismic Category I portion) |
| 2D11 | PRM system (from containment penetration to first anchor beyond second isolation valves)                   |
| 2E11 | RHR system                                                                                                 |
| 2E11 | RHRSW system (including intake structure)                                                                  |
| 2E21 | CS system                                                                                                  |
| 2E41 | HPCI system                                                                                                |
| 2E51 | RCIC system                                                                                                |
| 2G11 | Radwaste system (from containment penetration to first anchor beyond second isolation valves)              |

### HNP-2-FSAR-3

|      |                                                                                                                                                                                  |
|------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 2G31 | RWC (containment isolation portion and connection to feedwater F039)                                                                                                             |
| 2G41 | Fuel pool cooling system (RHR connection only)                                                                                                                                   |
| 2G51 | Torus drainage and purification system (Seismic Category I portion only)                                                                                                         |
| 2N11 | Main steam (MSIVs to first anchor beyond turbine stop valves and branches 2 1/2 in. and larger to first isolation valve)                                                         |
| 2N21 | Feedwater system (portion bounded by hangers and/or supports 2N21-RFW-H10, H8, H9, H6, H11, H12, H13, and R5)                                                                    |
| 2P11 | Condensate supply system (Seismic Category I portion only)                                                                                                                       |
| 2P21 | Demineralized water supply system (containment isolation portion only)                                                                                                           |
| 2P33 | H <sub>2</sub> and O <sub>2</sub> analyzer system (containment isolation portion only)                                                                                           |
| 2P41 | Service water system (reactor building, diesel building, and intake structure)                                                                                                   |
| 2P42 | RBCCW system (containment isolation portion only)                                                                                                                                |
| 2P51 | Service air system (containment isolation portion only)                                                                                                                          |
| 2P52 | Instrument air system (containment isolation portion only)                                                                                                                       |
| 2P64 | Chilled water system (containment isolation portion only)                                                                                                                        |
| 2P70 | Drywell pneumatic system (containment isolation portion only)                                                                                                                    |
| 2R43 | Diesel oil system (oil piping from day tank to diesel, starting air and cylinder jacket cooling water)                                                                           |
| 2T46 | Standby gas treatment system                                                                                                                                                     |
| 2T48 | Drywell-to-torus $\Delta P$ (containment isolation portion only)<br>Containment purge and inerting system<br>N <sub>2</sub> inerting system (containment isolation portion only) |

All systems within the primary containment which employ concrete expansion anchors for pipe support attachments

The initial step in this program was to identify the supports which employed anchor bolts and to verify the type of anchors used in these supports. This was accomplished by walking down the systems and noting the attachment to the building as being welded or employing wedge- or shell-type anchors. After identification of supports and anchor type, testing was started.

## HNP-2-FSAR-3

Wedge anchors were subjected to the following tests:

- Ultrasonic verification of bolt length.
- Determination of anchor bolt diameter using a Go-No-Go gauge.
- Verification of bolt preload using a calibrated torque wrench. Verification of proper installation of bolts was made using torque values based on manufacturer's data.

Shell-type anchors were tested by first removing the bolt from the shell, verifying its diameter, and verifying that a wedge could be seen inside the shell. The shell length was verified by measuring from the shoulder of the shell to the wedge and adding the standard wedge dimension to it. This would approximate the length of the shell for comparison to vendor data. Thread engagement was checked by reinserting the bolt without rotation until the bolt was seated against the starting thread of the shell. The distance from the underside of the bolt head to the surface of the plate was measured and recorded as thread engagement.

Prior to applying a torque wrench for load verification, the anchor shell was checked to be certain that it was not against the plate. If it was determined to not be against the plate, the bolt was reinserted and torqued to the specified value. The bolt was then removed to determine if any movement of the shell occurred.

In cases where the shell appeared to be seated against the plate prior to the reinsertion of the bolt, an attempt was made to shim the plate away from the wall. The bolt was then inserted and torqued.

Shell-type anchors subjected to the torque test were considered acceptable if no visible slippage was detected. If slippage did occur, an attempt was made to reseal and retest the shell.

Data collected for anchors was recorded and forwarded to design engineers for evaluation.

Failure rates experienced were such that the testing program included the total anchor population in lieu of a statistical sample. Ultimately in the interest of economics and safety, a management decision was made to simply remove and replace the self-drilling anchors (2500 anchors) with the more easily installed and tested wedge-style stud anchors. The new wedge-type anchors were installed per IE Bulletin 79-02. The existing wedge-type anchors were evaluated for design requirements per IE Bulletin 79-02, and corrective action was recommended as required.

**3.8.6.2.3.5 Expansion Anchor Bolts in Concrete Block Walls**. A walkdown inspection of HNP-1 and HNP-2 was performed to determine the extent that expansion anchor bolts were used in concrete block walls to attach piping supports within the scope of IE Bulletin 79-02.



No supports were identified for the safety-related systems which were inspected.

**3.8.6.2.3.6 Structural Shapes Attached Directly to Walls**. The scope of the testing and replacement programs for HNP-2 included all supports relying on expansion anchor bolts for support of the piping covered in the program, whether utilizing base plates or structural shapes attached directly to walls. It should be noted that structural shapes were generally not attached directly to the building walls. Only a few cases were identified during the program and these were given the same consideration as the other supports.

**3.8.6.2.3.7 Inaccessible Anchor Bolt Testing**. This paragraph is not applicable to HNP-2.

**3.8.6.2.3.8 Inspection Documentation**. Inspection documentation for the HNP-2 testing and replacement program is available at the site.

### **3.8.7 SEISMIC EVALUATION OF RADWASTE FACILITIES BUILDINGS (HNP-1 AND HNP-2)**

The following radwaste facilities were analyzed and evaluated in accordance with the Branch Technical Position<sup>(19)</sup> ETSB-11-1, Rev 1, Section V, and the USNRC Regulatory Guide 1.143 and found to be acceptable:

- Radwaste building (HNP-1).
- Radwaste addition building (HNP-1).
- Radwaste building (HNP-2).
- Waste gas treatment building (common to both units).
- Off-gas recombiner building (HNP-1).

#### **3.8.7.1 Seismic Model**

In order to seismically analyze each of the radwaste system structures, a simplified model fixed at the base was used. The mass points were located at elevated slab locations, and the weight of each mass consists of the weight of the slab plus half the weight of walls below and above the slab. Twenty-five percent of the live load on the slab was also included. The model did not consider structure-soil interaction, structure-structure interaction, or lateral torsional coupling.

### **3.8.7.2 Modal Analysis**

A modal analysis was performed on each of the radwaste system buildings to establish the natural frequencies and associated mode of vibrations using Bechtel computer program CE 917.

### **3.8.7.3 Response Spectrum Technique**

The response spectrum technique was used to determine the response of the structures to the earthquake. Using the design spectra presented in the USNRC Regulatory Guide 1.60 and a scale factor of 0.08, the spectral acceleration associated with each of the natural frequencies was determined. A building damping value of 4% was used based on the USNRC Regulatory Guide 1.61. The structural response, including the deflection, acceleration, shear and moment, for each mode were then evaluated. Because there were no closely spaced modes, the total response of the structure was taken as the square root of the sum of the squares of the individual modal responses. The computation of this portion of the analysis was accomplished by Bechtel computer program CE 918. Only a horizontal ground motion was considered.

### **3.8.7.4 Time-History Analysis**

In order to determine appropriate seismic loads for the design of equipment and piping systems attached to the structure, a time-history analysis was performed.

Input motion was defined at the foundation of each building by using a Bechtel standard synthetic time-history scaled to 0.08g (OBE). A building damping value of 4% was used. Both the input ground motion and the damping value are consistent with the USNRC Regulatory Guides 1.60 and 1.61. The response spectrum curves were computed for 0.5, 1, 2, 3, 4, and 5% damping at each mass point for all the buildings in the radwaste systems. The floor spectrum curves cover a frequency range for 0.1 Hz to 33 Hz. Two sets of curves, one for the east-west direction, and one for the north-south direction, were plotted for each elevation above the base. The computation and plotting of the response spectra was accomplished by use of Bechtel computer programs CE 920 and CE 921.

### **3.8.7.5 Computer Programs**

Description, validation, and extent of application for computer programs CE 917, CE 918, CE 920, and CE 921 are included in paragraph 3.8.4.4.3.

### **3.8.7.6 Structural Evaluation**

Using results from the seismic analysis of the radwaste facilities, structural evaluations were made, considering seismic forces. Structural evaluation included:

- Overturning.

## HNP-2-FSAR-3

- Combined flexural and axial stress at base of building.
- Shearing stress at base of building combined with torsional shear stresses.
- Local bending of interior and exterior walls.

### **3.8.7.7 Seismic Evaluation of Charcoal Adsorbers (HNP-1 and HNP-2)**

Using applicable floor response spectra of the waste gas treatment building, seismic evaluations were made for the charcoal adsorber vessels. Seismic response spectra curves were developed from 0.08g (OBE) lateral fixed-base time-history analysis, using Bechtel synthetic horizontal time history as the input ground motion.

Seismic evaluation of the charcoal adsorber vessels has shown that the design is adequate to withstand seismic accelerations, using the static analysis methods.

**DOCUMENTS INCORPORATED BY REFERENCE INTO THE FSAR**

***Technical Requirements Manual Table T7.0-1, Primary Containment Penetrations.***

REFERENCES

1. "Structural Evaluation of Pressure Suppression System for E. I. Hatch Nuclear Plant-Unit 2, Mark I Containment," Docket No. 50-366, July 1977, Bechtel.
2. "Mark I Containment Short-Term Program Safety Evaluation Report," NUREG-0408, Nuclear Regulatory Commission, December 1977.
3. Zick, L. P., "Circumferential Stresses in Pressure Vessel Shells of Revolution," Journal of Engineering for Industry, May 1963.
4. Wichman, K. R., Hopper, A. G., and Mershon, J. L., "Local Stresses in Spherical and Cylindrical Shells Due to External Loadings," Welding Research Council Bulletin 107, August 1965, revised December 1968.
5. Kalnins, A., "Analysis of Shells of Revolution Subjected to Symmetrical and Nonsymmetrical Loads," presented at the Summer Conference of the Applied Mechanics Division, Boulder, Colorado, June 9-11, 1964, of the American Society of Mechanical Engineers.
6. Grinter, L. E., Theory of Modern Steel Structures, McMillan Company, New York, 1949.
7. NAST-TN 129.
8. Timoshenko, S. P. and Woinowsky-Krieger, S., Theory of Plates and Shells, McGraw-Hill Book Company, New York, 1959.
9. ASME Boiler and Pressure Vessel Code, Sections III and VIII.
10. Blume, Newmark, and Corning, Design of Multistory Reinforced Concrete Buildings for Earthquake Motions, Portland Cement Association, 1961.
11. Hurty and Rubinstein, Dynamics of Structures, Prentice Hall, 1964.
12. Wilson, E. and Clough, R. W., Symposium on the Use of Computers in Civil Engineering, Paper 45, Lisbon, October 1-5, 1962.
13. 10 CFR 50, Appendix J, "Reactor Containment Leakage Testing for Water Cooled Power Reactors," February 14, 1973.

HNP-2-FSAR-3

14. BN-TOP-1, "Testing Criteria for Integrated Leakage Rate Testing of Primary Containment Structures for Nuclear Power Plants," Revision 1, November 1, 1972, Bechtel.
15. Fenjes, S. J., Logchar, R. D., and Mauch, S. P., Stress Reference Manual, M.I.T. Press, Cambridge, Mass., 1964.
16. Document (B), Structural Engineering Branch Directorate of Licensing, Structural Design Criteria for Evaluating the Effects of High-Energy Pipe Breaks on Category I Structures Outside the Containment, June 1973.
17. "A Refined Quadrilateral Element for Analysis of Plate Bending," Proceedings of the (second) Conference of Matrix Methods in Structural Mechanics, Wright-Patterson AFB, Ohio, 1968.
18. Drilled-In Expansion Bolts Under Static and Alternating Loads, Report No. BR-5853-C-4, Bechtel, January 1975.
19. "Design Guidelines for Radioactive Waste Management System Installation in Light-Water Cooled Nuclear Power Reactor Plants," Branch Technical Position ETSB No. 11-1, Revision 1.
20. American Society of Civil Engineers Paper 3269, "Wind Forces on Structures," Transactions Vol. 126, Part II, 1961.
21. "Plant Unique Analysis Report for E. I. Hatch Nuclear Plant Unit 2 Mark I Containment Long-Term Program, "Revision 1, Docket No. 50-366, Bechtel, September 1983.
22. "ASME Section III Component Replacements (Generic Letter 89-09)," USNRC, May 8, 1989.

HNP-2-FSAR-3

**TABLE 3.8-2 (SHEET 1 OF 11)**  
**SUMMARY OF CONTAINMENT STRESSES**

Location: Drywell Cylinder

| <u>Loading Condition</u>                                                                     | <u>Primary Principal Membrane Stresses</u>    |                                                       | <u>Stress Intensity (psi <math>S_m</math>)</u> | <u>Allowable Stress (psi)</u> |
|----------------------------------------------------------------------------------------------|-----------------------------------------------|-------------------------------------------------------|------------------------------------------------|-------------------------------|
|                                                                                              | <u>Meridional (psi <math>\sigma_x</math>)</u> | <u>Circumferential (psi <math>\sigma_\phi</math>)</u> |                                                |                               |
| Operating (interior pressure) <span style="float:right">OBE }<br/>DBE }</span>               | 380                                           | 548                                                   | 548                                            | 17,500                        |
|                                                                                              | 598                                           | 548                                                   | 598                                            | 32,670                        |
| Operating (exterior pressure) <span style="float:right">OBE }<br/>DBE }</span>               | -1481                                         | -548                                                  | 1481                                           | 17,500                        |
|                                                                                              | -1698                                         | -548                                                  | 1698                                           | 32,670                        |
| Refueling <span style="float:right">OBE }<br/>DBE }</span>                                   | -2222                                         | 0                                                     | 2222                                           | 17,500                        |
|                                                                                              | -2549                                         | 0                                                     | 2549                                           | 34,200                        |
| Accident (interior pressure) <sup>(a)</sup> <span style="float:right">OBE }<br/>DBE }</span> | 7671                                          | 15,335                                                | 15,335                                         | 17,500                        |
|                                                                                              | 7878                                          | 15,335                                                | 15,335                                         | 29,930                        |
| Accident (exterior pressure) <sup>(a)</sup> <span style="float:right">OBE }<br/>DBE }</span> | -1378                                         | -548                                                  | 1378                                           | 17,500                        |
|                                                                                              | -1585                                         | -548                                                  | 1585                                           | 32,670                        |
| Flooded OBE                                                                                  | 468                                           | 14,479                                                | 14,479                                         | 24,200                        |

HNP-2-FSAR-3

**TABLE 3.8-2 (SHEET 2 OF 11)**

Location: Section 1 - Upper Knuckle Section el 168.12 ft

| <u>Loading Condition</u>                                                                     | <u>Primary Principal Membrane Stresses</u>    |                                                       | <u>Stress Intensity (psi <math>S_m</math>)</u> | <u>Allowable Stress (psi)</u> |
|----------------------------------------------------------------------------------------------|-----------------------------------------------|-------------------------------------------------------|------------------------------------------------|-------------------------------|
|                                                                                              | <u>Meridional (psi <math>\sigma_x</math>)</u> | <u>Circumferential (psi <math>\sigma_\phi</math>)</u> |                                                |                               |
| Operating (interior pressure) <span style="float:right">OBE }<br/>DBE }</span>               | 115                                           | 385                                                   | 385                                            | 17,500                        |
|                                                                                              | 180                                           | 487                                                   | 487                                            | 32,670                        |
| Operating (exterior pressure) <span style="float:right">OBE }<br/>DBE }</span>               | -447                                          | -899                                                  | 899                                            | 17,500                        |
|                                                                                              | -513                                          | -1000                                                 | 1000                                           | 32,670                        |
| Refueling <span style="float:right">OBE }<br/>DBE }</span>                                   | -672                                          | -1035                                                 | 1035                                           | 17,500                        |
|                                                                                              | -771                                          | -1188                                                 | 1188                                           | 34,200                        |
| Accident (interior pressure) <sup>(a)</sup> <span style="float:right">OBE }<br/>DBE }</span> | 2319                                          | 9429                                                  | 9429                                           | 17,500                        |
|                                                                                              | 2382                                          | 9525                                                  | 9525                                           | 29,930                        |
| Accident (exterior pressure) <sup>(a)</sup> <span style="float:right">OBE }<br/>DBE }</span> | -416                                          | -851                                                  | 851                                            | 17,500                        |
|                                                                                              | -479                                          | -947                                                  | 947                                            | 32,670                        |
| Flooded OBE                                                                                  | 141                                           | 4595                                                  | 4595                                           | 34,200                        |
| Flooded - filling OBE                                                                        | -482                                          | -778                                                  | 778                                            | 34,200                        |
| Construction stage <span style="float:right">OBE }<br/>DBE }</span>                          | -356                                          | -550                                                  | 550                                            | 17,500                        |
|                                                                                              | -443                                          | -685                                                  | 685                                            | 34,200                        |
| Construction stage - wind                                                                    | -185                                          | -285                                                  | 285                                            | 34,200                        |
| Final testing (interior pressure) <span style="float:right">OBE }<br/>DBE }</span>           | 2319                                          | 9429                                                  | 9429                                           | 17,500                        |
|                                                                                              | 2382                                          | 9525                                                  | 9525                                           | 32,670                        |
| Final testing (exterior pressure) <span style="float:right">OBE }<br/>DBE }</span>           | -416                                          | -851                                                  | 851                                            | 17,500                        |
|                                                                                              | -479                                          | -947                                                  | 947                                            | 32,670                        |

HNP-2-FSAR-3

**TABLE 3.8-2 (SHEET 3 OF 11)**

Location: Section 2 - Middle Knuckle Section el 164.91 ft

| <u>Loading Condition</u>                                                                     | <u>Primary Principal Membrane Stresses</u>    |                                                       | <u>Stress Intensity (psi <math>S_m</math>)</u> | <u>Allowable Stress (psi)</u> |
|----------------------------------------------------------------------------------------------|-----------------------------------------------|-------------------------------------------------------|------------------------------------------------|-------------------------------|
|                                                                                              | <u>Meridional (psi <math>\sigma_x</math>)</u> | <u>Circumferential (psi <math>\sigma_\phi</math>)</u> |                                                |                               |
| Operating (interior pressure) <span style="float:right">OBE }<br/>DBE }</span>               | 154                                           | 798                                                   | 798                                            | 17,500                        |
|                                                                                              | 250                                           | 1164                                                  | 1164                                           | 32,670                        |
| Operating (exterior pressure) <span style="float:right">OBE }<br/>DBE }</span>               | -529                                          | -2242                                                 | 2242                                           | 18,500                        |
|                                                                                              | -625                                          | -2608                                                 | 2608                                           | 32,670                        |
| Refueling <span style="float:right">OBE }<br/>DBE }</span>                                   | -711                                          | -2966                                                 | 2966                                           | 17,500                        |
|                                                                                              | -905                                          | -3475                                                 | 3475                                           | 34,200                        |
| Accident (interior pressure) <sup>(a)</sup> <span style="float:right">OBE }<br/>DBE }</span> | 2903                                          | 16,946                                                | 16,946                                         | 17,500                        |
|                                                                                              | 2995                                          | 17,298                                                | 17,298                                         | 29,930                        |
| Accident (exterior pressure) <sup>(a)</sup> <span style="float:right">OBE }<br/>DBE }</span> | -494                                          | -2108                                                 | 2108                                           | 17,500                        |
|                                                                                              | -586                                          | -2460                                                 | 2460                                           | 32,670                        |
| Flooded OBE                                                                                  | 657                                           | 10,671                                                | 10,671                                         | 34,200                        |
| Flooded - filling OBE                                                                        | -788                                          | -3034                                                 | 3034                                           | 34,200                        |
| Construction stage <span style="float:right">OBE }<br/>DBE }</span>                          | -416                                          | -1602                                                 | 1602                                           | 17,500                        |
|                                                                                              | -518                                          | -1996                                                 | 1996                                           | 34,200                        |
| Construction stage - wind                                                                    | -213                                          | -819                                                  | 819                                            | 34,200                        |
| Final testing (interior pressure) <span style="float:right">OBE }<br/>DBE }</span>           | 2903                                          | 16,946                                                | 16,946                                         | 17,500                        |
|                                                                                              | 2995                                          | 17,298                                                | 17,298                                         | 32,670                        |
| Final testing (exterior pressure) <span style="float:right">OBE }<br/>DBE }</span>           | -494                                          | -2108                                                 | 2108                                           | 17,500                        |
|                                                                                              | -586                                          | -2460                                                 | 2460                                           | 32,670                        |



HNP-2-FSAR-3

**TABLE 3.8-2 (SHEET 4 OF 11)**

Location: Section 3 - Lower Knuckle Section el 163.50 ft

| <u>Loading Condition</u>                    | <u>Primary Principal Membrane Stresses</u>    |                                                       | <u>Stress Intensity (psi <math>S_m</math>)</u> | <u>Allowable Stress (psi)</u> |
|---------------------------------------------|-----------------------------------------------|-------------------------------------------------------|------------------------------------------------|-------------------------------|
|                                             | <u>Meridional (psi <math>\sigma_x</math>)</u> | <u>Circumferential (psi <math>\sigma_\phi</math>)</u> |                                                |                               |
| Operating (interior pressure)               | OBE                                           | 218                                                   | 684                                            | 17,500                        |
|                                             | DBE                                           | 320                                                   | 909                                            | 32,670                        |
| Operating (exterior pressure)               | OBE                                           | -707                                                  | 1763                                           | 17,500                        |
|                                             | DBE                                           | -809                                                  | 1988                                           | 32,670                        |
| Refueling                                   | OBE                                           | -993                                                  | 2193                                           | 17,500                        |
|                                             | DBE                                           | -1142                                                 | 2521                                           | 34,200                        |
| Accident (interior pressure) <sup>(a)</sup> | OBE                                           | 4093                                                  | 14,690                                         | 17,500                        |
|                                             | DBE                                           | 4190                                                  | 14,905                                         | 29,930                        |
| Accident (exterior pressure) <sup>(a)</sup> | OBE                                           | -663                                                  | 1667                                           | 17,500                        |
|                                             | DBE                                           | -761                                                  | 1882                                           | 32,670                        |
| Flooded                                     | OBE                                           | 807                                                   | 9095                                           | 34,200                        |
| Flooded - filling                           | OBE                                           | 502                                                   | 1126                                           | 34,200                        |
| Construction stage                          | OBE                                           | -513                                                  | 1133                                           | 17,500                        |
|                                             | DBE                                           | -641                                                  | 1413                                           | 34,200                        |
| Construction stage - wind                   |                                               | -265                                                  | 584                                            | 34,200                        |
| Final testing (interior pressure)           | OBE                                           | 4093                                                  | 14,690                                         | 17,500                        |
|                                             | DBE                                           | 4190                                                  | 14,905                                         | 32,670                        |
| Final testing (exterior pressure)           | OBE                                           | -663                                                  | 1667                                           | 17,500                        |
|                                             | DBE                                           | -761                                                  | 1882                                           | 32,670                        |

HNP-2-FSAR-3

**TABLE 3.8-2 (SHEET 5 OF 11)**

Location: Section 4 - Sphere - Knuckle Transition el 162.67 ft

| <u>Loading Condition</u>                                                                     | <u>Primary Principal Membrane Stresses</u>    |                                                       | <u>Stress Intensity (psi <math>S_m</math>)</u> | <u>Allowable Stress (psi)</u> |
|----------------------------------------------------------------------------------------------|-----------------------------------------------|-------------------------------------------------------|------------------------------------------------|-------------------------------|
|                                                                                              | <u>Meridional (psi <math>\sigma_x</math>)</u> | <u>Circumferential (psi <math>\sigma_\phi</math>)</u> |                                                |                               |
| Operating (interior pressure) <span style="float:right">OBE }<br/>DBE }</span>               | -1027                                         | 1720                                                  | 2747                                           | 17,500                        |
|                                                                                              | -1254                                         | 1948                                                  | 3202                                           | 42,345                        |
| Operating (exterior pressure) <span style="float:right">OBE }<br/>DBE }</span>               | -1720                                         | 1027                                                  | 2747                                           | 17,500                        |
|                                                                                              | -1948                                         | 1254                                                  | 3202                                           | 42,345                        |
| Refueling <span style="float:right">OBE }<br/>DBE }</span>                                   | -2313                                         | 2313                                                  | 4626                                           | 17,500                        |
|                                                                                              | -2643                                         | 2643                                                  | 5286                                           | 45,000                        |
| Accident (interior pressure) <sup>(a)</sup> <span style="float:right">OBE }<br/>DBE }</span> | 8429                                          | 10,984                                                | 10,984                                         | 17,200                        |
|                                                                                              | 8112                                          | 21,202                                                | 11,202                                         | 35,370                        |
| Accident (exterior pressure) <sup>(a)</sup> <span style="float:right">OBE }<br/>DBE }</span> | -1624                                         | 931                                                   | 2555                                           | 17,500                        |
|                                                                                              | -1842                                         | 1148                                                  | 2990                                           | 42,345                        |
| Flooded OBE                                                                                  | -1820                                         | 11,526                                                | 13,346                                         | 45,000                        |
| Flooded - filling OBE                                                                        | -2311                                         | 2474                                                  | 4785                                           | 45,000                        |
| Construction stage <span style="float:right">OBE }<br/>DBE }</span>                          | -1196                                         | 1196                                                  | 2392                                           | 17,500                        |
|                                                                                              | -1467                                         | 1467                                                  | 2934                                           | 45,000                        |
| Construction stage - wind                                                                    | -657                                          | 657                                                   | 1314                                           | 45,000                        |
| Final testing (interior pressure) <span style="float:right">OBE }<br/>DBE }</span>           | 8429                                          | 10,984                                                | 10,984                                         | 17,500                        |
|                                                                                              | 8112                                          | 11,202                                                | 11,202                                         | 42,345                        |
| Final testing (exterior pressure) <span style="float:right">OBE }<br/>DBE }</span>           | -1624                                         | 931                                                   | 2555                                           | 17,500                        |
|                                                                                              | -1842                                         | 1148                                                  | 2990                                           | 42,345                        |

HNP-2-FSAR-3

**TABLE 3.8-2 (SHEET 6 OF 11)**

Location: Section 5 - Upper Drywell Beam Seats el 148.29 ft

| <u>Loading Condition</u>                                                                     | <u>Primary Principal Membrane Stresses</u>    |                                                       | <u>Stress Intensity (psi <math>S_m</math>)</u> | <u>Allowable Stress (psi)</u> |
|----------------------------------------------------------------------------------------------|-----------------------------------------------|-------------------------------------------------------|------------------------------------------------|-------------------------------|
|                                                                                              | <u>Meridional (psi <math>\sigma_x</math>)</u> | <u>Circumferential (psi <math>\sigma_\phi</math>)</u> |                                                |                               |
| Operating (interior pressure) <span style="float:right">OBE }<br/>DBE }</span>               | -951                                          | 1644                                                  | 2595                                           | 17,500                        |
|                                                                                              | -1131                                         | 1824                                                  | 2955                                           | 42,345                        |
| Operating (exterior pressure) <span style="float:right">OBE }<br/>DBE }</span>               | -1644                                         | 951                                                   | 2595                                           | 17,500                        |
|                                                                                              | -1824                                         | 1131                                                  | 2955                                           | 42,345                        |
| Refueling <span style="float:right">OBE }<br/>DBE }</span>                                   | -1759                                         | 1759                                                  | 3518                                           | 17,500                        |
|                                                                                              | -1988                                         | 1988                                                  | 3976                                           | 45,000                        |
| Accident (interior pressure) <sup>(a)</sup> <span style="float:right">OBE }<br/>DBE }</span> | 8455                                          | 10,958                                                | 10,958                                         | 17,200                        |
|                                                                                              | 8281                                          | 11,132                                                | 11,132                                         | 35,370                        |
| Accident (exterior pressure) <sup>(a)</sup> <span style="float:right">OBE }<br/>DBE }</span> | -1598                                         | 905                                                   | 2503                                           | 17,500                        |
|                                                                                              | -1772                                         | 1079                                                  | 2851                                           | 42,345                        |
| Flooded OBE                                                                                  | -1484                                         | 13,270                                                | 14,754                                         | 45,000                        |
| Flooded - filling OBE                                                                        | -1725                                         | 3975                                                  | 5700                                           | 45,000                        |
| Construction stage <span style="float:right">OBE }<br/>DBE }</span>                          | -749                                          | 749                                                   | 1498                                           | 17,500                        |
|                                                                                              | -897                                          | 897                                                   | 1794                                           | 45,000                        |
| Construction stage - wind                                                                    | -464                                          | 464                                                   | 928                                            | 45,000                        |
| Final testing (interior pressure) <span style="float:right">OBE }<br/>DBE }</span>           | 8455                                          | 10,958                                                | 10,985                                         | 17,500                        |
|                                                                                              | 8281                                          | 11,132                                                | 11,132                                         | 42,345                        |
| Final testing (exterior pressure) <span style="float:right">OBE }<br/>DBE }</span>           | -1598                                         | 905                                                   | 2503                                           | 17,500                        |
|                                                                                              | -1772                                         | 1079                                                  | 2851                                           | 42,345                        |

HNP-2-FSAR-3

**TABLE 3.8-2 (SHEET 7 OF 11)**

Location: Section 6 - Drywell Bottom Head Intersection el 128.34 ft

| <u>Loading Condition</u>                                                                     | <u>Primary Principal Membrane Stresses</u>    |                                                       | <u>Stress Intensity (psi <math>S_m</math>)</u> | <u>Allowable Stress (psi)</u> |
|----------------------------------------------------------------------------------------------|-----------------------------------------------|-------------------------------------------------------|------------------------------------------------|-------------------------------|
|                                                                                              | <u>Meridional (psi <math>\sigma_x</math>)</u> | <u>Circumferential (psi <math>\sigma_\phi</math>)</u> |                                                |                               |
| Operating (interior pressure) <span style="float:right">OBE }<br/>DBE }</span>               | -2061                                         | 2755                                                  | 4816                                           | 17,500                        |
|                                                                                              | -2390                                         | 3084                                                  | 5474                                           | 42,345                        |
| Operating (exterior pressure) <span style="float:right">OBE }<br/>DBE }</span>               | -2755                                         | 2061                                                  | 4816                                           | 17,500                        |
|                                                                                              | -3084                                         | 2390                                                  | 5474                                           | 42,345                        |
| Refueling <span style="float:right">OBE }<br/>DBE }</span>                                   | -2873                                         | 2873                                                  | 5746                                           | 17,500                        |
|                                                                                              | -3251                                         | 3251                                                  | 6502                                           | 45,000                        |
| Accident (interior pressure) <sup>(a)</sup> <span style="float:right">OBE }<br/>DBE }</span> | 7345                                          | 12,068                                                | 12,068                                         | 17,200                        |
|                                                                                              | 7021                                          | 12,392                                                | 12,392                                         | 35,370                        |
| Accident (exterior pressure) <sup>(a)</sup> <span style="float:right">OBE }<br/>DBE }</span> | -2708                                         | 2015                                                  | 4723                                           | 17,500                        |
|                                                                                              | -3032                                         | 2339                                                  | 5371                                           | 42,345                        |
| Flooded OBE                                                                                  | -3231                                         | 18,137                                                | 21,368                                         | 45,000                        |
| Flooded - filling OBE                                                                        | -3474                                         | 8796                                                  | 12,270                                         | 45,000                        |
| Construction stage <span style="float:right">OBE }<br/>DBE }</span>                          | -1316                                         | 1316                                                  | 2632                                           | 17,500                        |
|                                                                                              | -1559                                         | 1559                                                  | 3118                                           | 45,000                        |
| Construction stage - wind                                                                    | -852                                          | 852                                                   | 1704                                           | 45,000                        |
| Final testing (interior pressure) <span style="float:right">OBE }<br/>DBE }</span>           | 7344                                          | 12,069                                                | 12,069                                         | 17,500                        |
|                                                                                              | 7020                                          | 12,393                                                | 12,393                                         | 42,345                        |
| Final testing (exterior pressure) <span style="float:right">OBE }<br/>DBE }</span>           | -2709                                         | 2016                                                  | 4725                                           | 17,500                        |
|                                                                                              | -3033                                         | 2340                                                  | 5373                                           | 42,345                        |

HNP-2-FSAR-3

**TABLE 3.8-2 (SHEET 8 OF 11)**

Location: Section 7 - Lower Drywell Beam Seats el 127.75 ft

| <u>Loading Condition</u>                                                                     | <u>Primary Principal Membrane Stresses</u>    |                                                       | <u>Stress Intensity (psi <math>S_m</math>)</u> | <u>Allowable Stress (psi)</u> |
|----------------------------------------------------------------------------------------------|-----------------------------------------------|-------------------------------------------------------|------------------------------------------------|-------------------------------|
|                                                                                              | <u>Meridional (psi <math>\sigma_x</math>)</u> | <u>Circumferential (psi <math>\sigma_\phi</math>)</u> |                                                |                               |
| Operating (interior pressure) <span style="float:right">OBE }<br/>DBE }</span>               | -1579                                         | 2099                                                  | 3678                                           | 16,200                        |
|                                                                                              | -1831                                         | 2351                                                  | 4182                                           | 38,970                        |
| Operating (exterior pressure) <span style="float:right">OBE }<br/>DBE }</span>               | -2099                                         | 1579                                                  | 3678                                           | 26,200                        |
|                                                                                              | -2351                                         | 1831                                                  | 4182                                           | 38,970                        |
| Refueling <span style="float:right">OBE }<br/>DBE }</span>                                   | -2191                                         | 2191                                                  | 4382                                           | 16,200                        |
|                                                                                              | -2481                                         | 2481                                                  | 4962                                           | 41,400                        |
| Accident (interior pressure) <sup>(a)</sup> <span style="float:right">OBE }<br/>DBE }</span> | 5476                                          | 9084                                                  | 9084                                           | 15,900                        |
|                                                                                              | 5228                                          | 9332                                                  | 9332                                           | 32,600                        |
| Accident (exterior pressure) <sup>(a)</sup> <span style="float:right">OBE }<br/>DBE }</span> | -2064                                         | 1544                                                  | 3608                                           | 16,200                        |
|                                                                                              | -2312                                         | 1792                                                  | 4104                                           | 38,970                        |
| Flooded OBE                                                                                  | -2491                                         | 13,671                                                | 16,162                                         | 41,400                        |
| Flooded - filling OBE                                                                        | -2675                                         | 6731                                                  | 9406                                           | 41,400                        |
| Construction stage <span style="float:right">OBE }<br/>DBE }</span>                          | -1041                                         | 1041                                                  | 2082                                           | 16,200                        |
|                                                                                              | -1230                                         | 1230                                                  | 2460                                           | 41,400                        |
| Construction stage - wind                                                                    | -679                                          | 679                                                   | 1358                                           | 41,400                        |
| Final testing (interior pressure) <span style="float:right">OBE }<br/>DBE }</span>           | 5475                                          | 9085                                                  | 9085                                           | 16,200                        |
|                                                                                              | 5227                                          | 9333                                                  | 9333                                           | 38,970                        |
| Final testing (exterior pressure) <span style="float:right">OBE }<br/>DBE }</span>           | -2065                                         | 1545                                                  | 3610                                           | 16,200                        |
|                                                                                              | -2313                                         | 1793                                                  | 4106                                           | 38,970                        |

HNP-2-FSAR-3

**TABLE 3.8-2 (SHEET 9 OF 11)**

Location: Section 8 - Drywell Ventline Intersection el 118.92 ft

| <u>Loading Condition</u>                    | <u>Primary Principal Membrane Stresses</u>    |                                                       | <u>Stress Intensity (psi <math>S_m</math>)</u> | <u>Allowable Stress (psi)</u> |        |
|---------------------------------------------|-----------------------------------------------|-------------------------------------------------------|------------------------------------------------|-------------------------------|--------|
|                                             | <u>Meridional (psi <math>\sigma_x</math>)</u> | <u>Circumferential (psi <math>\sigma_\phi</math>)</u> |                                                |                               |        |
| Operating (interior pressure)               | OBE                                           | -3188                                                 | 3708                                           | 6896                          | 16,200 |
|                                             | DBE                                           | -3706                                                 | 4226                                           | 7932                          | 38,970 |
| Operating (exterior pressure)               | OBE                                           | -3708                                                 | 3188                                           | 6896                          | 16,200 |
|                                             | DBE                                           | -4226                                                 | 3706                                           | 7932                          | 38,970 |
| Refueling                                   | OBE                                           | -3939                                                 | 3939                                           | 7878                          | 16,200 |
|                                             | DBE                                           | -4509                                                 | 4509                                           | 9018                          | 41,400 |
| Accident (interior pressure) <sup>(a)</sup> | OBE                                           | 3881                                                  | 10,679                                         | 10,679                        | 15,900 |
|                                             | DBE                                           | 3369                                                  | 11,191                                         | 11,191                        | 32,600 |
| Accident (exterior pressure) <sup>(a)</sup> | OBE                                           | -3659                                                 | 3139                                           | 6798                          | 16,200 |
|                                             | DBE                                           | -4171                                                 | 3651                                           | 7822                          | 38,970 |
| Flooded OBE                                 |                                               | -5327                                                 | 17,547                                         | 22,874                        | 41,400 |
| Flooded - filling OBE                       |                                               | -5585                                                 | 10,637                                         | 16,222                        | 41,400 |
| Construction stage                          | OBE                                           | -2091                                                 | 2091                                           | 4182                          | 16,200 |
|                                             | DBE                                           | -2454                                                 | 2454                                           | 4908                          | 41,400 |
| Construction stage - wind                   |                                               | -1398                                                 | 1398                                           | 2796                          | 41,400 |
| Final testing (interior pressure)           | OBE                                           | 3876                                                  | 10,684                                         | 10,684                        | 16,200 |
|                                             | DBE                                           | 3363                                                  | 11,197                                         | 11,197                        | 38,970 |
| Final testing (exterior pressure)           | OBE                                           | -3664                                                 | 3144                                           | 6808                          | 16,200 |
|                                             | DBE                                           | -4177                                                 | 3657                                           | 7834                          | 38,970 |

HNP-2-FSAR-3

**TABLE 3.8-2 (SHEET 10 OF 11)**

Location: Section 9 - Bottom Head Embedment el 113.17 ft

| <u>Loading Condition</u>                                                                     | <u>Primary Principal Membrane Stresses</u>    |                                                       | <u>Stress Intensity (psi <math>S_m</math>)</u> | <u>Allowable Stress (psi)</u> |
|----------------------------------------------------------------------------------------------|-----------------------------------------------|-------------------------------------------------------|------------------------------------------------|-------------------------------|
|                                                                                              | <u>Meridional (psi <math>\sigma_x</math>)</u> | <u>Circumferential (psi <math>\sigma_\phi</math>)</u> |                                                |                               |
| Operating (interior pressure) <span style="float:right">OBE }<br/>DBE }</span>               | -5923                                         | 6443                                                  | 12,366                                         | 16,200                        |
|                                                                                              | -6953                                         | 7473                                                  | 14,426                                         | 38,970                        |
| Operating (exterior pressure) <span style="float:right">OBE }<br/>DBE }</span>               | -6443                                         | 5923                                                  | 12,366                                         | 16,200                        |
|                                                                                              | -7473                                         | 6953                                                  | 14,426                                         | 38,970                        |
| Refueling <span style="float:right">OBE }<br/>DBE }</span>                                   | -6973                                         | 6973                                                  | 13,946                                         | 16,200                        |
|                                                                                              | -8089                                         | 8089                                                  | 16,178                                         | 41,400                        |
| Accident (interior pressure) <sup>(a)</sup> <span style="float:right">OBE }<br/>DBE }</span> | 1177                                          | 13,383                                                | 13,383                                         | 15,900                        |
|                                                                                              | 155                                           | 14,405                                                | 14,405                                         | 32,600                        |
| Accident (exterior pressure) <sup>(a)</sup> <span style="float:right">OBE }<br/>DBE }</span> | -6363                                         | 5843                                                  | 12,206                                         | 16,200                        |
|                                                                                              | -7385                                         | 6865                                                  | 14,250                                         | 38,970                        |
| Flooded OBE                                                                                  | -11,362                                       | 24,102                                                | 35,464                                         | 41,400                        |
| Flooded - filling OBE                                                                        | -11,775                                       | 17,475                                                | 29,250                                         | 41,400                        |
| Construction stage <span style="float:right">OBE }<br/>DBE }</span>                          | -4014                                         | 4014                                                  | 8028                                           | 16,200                        |
|                                                                                              | -4837                                         | 4837                                                  | 9674                                           | 41,400                        |
| Construction stage - wind                                                                    | -2489                                         | 2489                                                  | 4978                                           | 41,400                        |
| Final testing (interior pressure) <span style="float:right">OBE }<br/>DBE }</span>           | 1157                                          | 13,403                                                | 13,403                                         | 16,200                        |
|                                                                                              | 133                                           | 14,427                                                | 14,427                                         | 38,970                        |
| Final testing (interior pressure) <span style="float:right">OBE }<br/>DBE }</span>           | 6383                                          | 5863                                                  | 12,246                                         | 16,200                        |
|                                                                                              | -7407                                         | 6887                                                  | 14,294                                         | 38,970                        |

HNP-2-FSAR-3

**TABLE 3.8-2 (SHEET 11 OF 11)**

Location: Suppression Chamber Shell


| <u>Loading Condition</u>    | Shell Stresses                      |                                  |                                     |                                  | <u>Allowable Stress (psi)</u> |
|-----------------------------|-------------------------------------|----------------------------------|-------------------------------------|----------------------------------|-------------------------------|
|                             | Top Half                            |                                  | Bottom Half                         |                                  |                               |
|                             | <u>Circumferential Stress (psi)</u> | <u>Longitudinal Stress (psi)</u> | <u>Circumferential Stress (psi)</u> | <u>Longitudinal Stress (psi)</u> |                               |
| Operating OBE               | 624                                 | 3906                             | 2347                                | 4623                             | 17,500                        |
| Operating DBE               | 624                                 | 5174                             | 2526                                | 5929                             | 34,200                        |
| Accident OBE <sup>(a)</sup> | 17,474                              | 12,095                           | 17,444                              | 11,944                           | 17,500                        |
| Accident DBE <sup>(a)</sup> | 17,474                              | 12,823                           | 17,633                              | 12,736                           | 29,970                        |
| Flooded OBE                 | 28,718                              | 19,055                           | 28,453                              | 18,724                           | 34,200                        |

a. Does not include jet impingement loadings.



**TABLE 3.8-3 (SHEET 1 OF 6)**

**SUMMARY OF STRESSES AT PERSONNEL LOCK AREA**




Membrane Stresses at Lock to Insert - OBE Vessel Empty

| <u>Type of Stress</u>   | <u>A</u> | <u>B</u> | <u>C</u> | <u>D</u> |
|-------------------------|----------|----------|----------|----------|
| Radial (psi)            | 17,559   | 17,517   | 17,380   | 17,696   |
| Tangential (psi)        | 17,518   | 17,506   | 17,469   | 17,555   |
| Maximum surface (psi)   | 17,559   | 17,517   | 17,469   | 17,696   |
| Allowable surface (psi) | 26,250   | 26,250   | 26,250   | 26,250   |

Membrane Stresses at Insert to Shell - OBE Vessel Empty

| <u>Type of Stress</u>   | <u>A</u> | <u>B</u> | <u>C</u> | <u>D</u> |
|-------------------------|----------|----------|----------|----------|
| Radial (psi)            | 17,615   | 17,545   | 17,330   | 18,150   |
| Tangential (psi)        | 17,540   | 17,520   | 17,465   | 17,595   |
| Maximum surface (psi)   | 17,615   | 17,545   | 17,465   | 18,150   |
| Allowable surface (psi) | 19,250   | 19,250   | 19,250   | 19,250   |

**TABLE 3.8-3 (SHEET 2 OF 6)**




Membrane Stresses at Lock to Insert - DBE Vessel Empty

| <u>Type of Stress</u>   | <u>A</u> | <u>B</u> | <u>C</u> | <u>D</u> |
|-------------------------|----------|----------|----------|----------|
| Radial (psi)            | 17,601   | 17,531   | 17,422   | 17,710   |
| Tangential (psi)        | 17,532   | 17,512   | 17,483   | 17,561   |
| Maximum surface (psi)   | 17,601   | 17,531   | 17,483   | 17,710   |
| Allowable surface (psi) | 26,250   | 26,250   | 26,250   | 26,250   |

Membrane Stresses at Insert to Shell - DBE Vessel Empty

| <u>Type of Stress</u>   | <u>A</u> | <u>B</u> | <u>C</u> | <u>D</u> |
|-------------------------|----------|----------|----------|----------|
| Radial (psi)            | 17,690   | 17,580   | 17,405   | 17,865   |
| Tangential (psi)        | 17,565   | 17,535   | 17,360   | 17,610   |
| Maximum surface (psi)   | 17,690   | 17,580   | 17,405   | 17,865   |
| Allowable surface (psi) | 19,250   | 19,250   | 19,250   | 19,250   |

**TABLE 3.8-3 (SHEET 3 OF 6)**




Membrane Stresses at Lock to Insert - OBE Vessel Flooded

| <u>Type of Stress</u>   | <u>A</u> | <u>B</u> | <u>C</u> | <u>D</u> |
|-------------------------|----------|----------|----------|----------|
| Radial (psi)            | 17,574   | 17,524   | 17,396   | 17,702   |
| Tangential (psi)        | 17,519   | 17,509   | 17,470   | 17,558   |
| Maximum Surface (psi)   | 17,574   | 17,524   | 17,470   | 17,702   |
| Allowable surface (psi) | 26,250   | 26,250   | 26,250   | 26,250   |

Membrane Stresses at Insert to Shell - OBE Vessel Flooded

| <u>Type of Stress</u>   | <u>A</u> | <u>B</u> | <u>C</u> | <u>D</u> |
|-------------------------|----------|----------|----------|----------|
| Radial (psi)            | 17,640   | 17,560   | 17,360   | 17,840   |
| Tangential (psi)        | 17,545   | 17,525   | 17,470   | 17,850   |
| Maximum surface (psi)   | 17,640   | 17,560   | 17,470   | 17,850   |
| Allowable surface (psi) | 19,250   | 19,250   | 19,250   | 19,250   |

TABLE 3.8-3 (SHEET 4 OF 6)




Surface Stresses at Lock to Insert - OBE Vessel Empty

| Type of Stress          | <u>A<sub>0</sub></u> | <u>A<sub>i</sub></u> | <u>B<sub>0</sub></u> | <u>B<sub>i</sub></u> | <u>C<sub>0</sub></u> | <u>C<sub>i</sub></u> | <u>D<sub>0</sub></u> | <u>D<sub>i</sub></u> |
|-------------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|
| Radial (psi)            | 26,481               | 26,383               | 26,293               | 26,259               | 25,695               | 26,791               | 27,079               | 25,831               |
| Tangential (psi)        | 26,318               | 26,282               | 26,264               | 26,252               | 26,091               | 26,411               | 26,491               | 26,123               |
| Maximum surface (psi)   | 26,481               | 26,363               | 26,293               | 26,259               | 26,091               | 26,791               | 27,079               | 26,123               |
| Allowable surface (psi) | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               |

Surface Stresses at Insert to Shell - OBE Vessel Empty

| Type of Stress          | <u>A<sub>0</sub></u> | <u>A<sub>i</sub></u> | <u>B<sub>0</sub></u> | <u>B<sub>i</sub></u> | <u>C<sub>0</sub></u> | <u>C<sub>i</sub></u> | <u>D<sub>0</sub></u> | <u>D<sub>i</sub></u> |
|-------------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|
| Radial (psi)            | 17,905               | 17,675               | 17,655               | 17,675               | 16,875               | 18,135               | 18,685               | 17,105               |
| Tangential (psi)        | 17,630               | 17,550               | 17,560               | 17,520               | 17,343               | 17,687               | 17,847               | 17,413               |
| Maximum surface (psi)   | 17,905               | 17,675               | 17,655               | 17,675               | 17,343               | 18,135               | 18,685               | 17,413               |
| Allowable surface (psi) | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               |

**TABLE 3.8-3 (SHEET 5 OF 6)**




Surface Stresses at Lock to Insert - DBE Vessel Empty

| Type of Stress          | <u>A<sub>0</sub></u> | <u>A<sub>i</sub></u> | <u>B<sub>0</sub></u> | <u>B<sub>i</sub></u> | <u>C<sub>0</sub></u> | <u>C<sub>i</sub></u> | <u>D<sub>0</sub></u> | <u>D<sub>i</sub></u> |
|-------------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|
| Radial (psi)            | 26,642               | 26,440               | 26,332               | 26,270               | 25,856               | 26,868               | 27,118               | 25,842               |
| Tangential (psi)        | 26,367               | 26,303               | 26,277               | 26,253               | 26,140               | 26,432               | 26,504               | 26,124               |
| Maximum surface (psi)   | 26,642               | 26,440               | 26,332               | 26,270               | 26,140               | 26,868               | 27,118               | 26,124               |
| Allowable surface (psi) | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               |

Surface Stresses at Insert to Shell - DBE Vessel Empty

| Type of Stress          | <u>A<sub>0</sub></u> | <u>A<sub>i</sub></u> | <u>B<sub>0</sub></u> | <u>B<sub>i</sub></u> | <u>C<sub>0</sub></u> | <u>C<sub>i</sub></u> | <u>D<sub>0</sub></u> | <u>D<sub>i</sub></u> |
|-------------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|
| Radial (psi)            | 18,185               | 17,850               | 17,785               | 17,625               | 17,155               | 18,265               | 18,815               | 17,165               |
| Tangential (psi)        | 17,710               | 17,580               | 17,600               | 17,530               | 17,423               | 17,717               | 17,887               | 17,393               |
| Maximum surface (psi)   | 18,185               | 17,805               | 17,785               | 17,625               | 17,423               | 18,265               | 18,815               | 17,393               |
| Allowable surface (psi) | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               |

TABLE 3.8-3 (SHEET 6 OF 6)



Surface Stresses at Lock to Insert - OBE Vessel Flooded


| Type of Stress          | <u>A<sub>0</sub></u> | <u>A<sub>i</sub></u> | <u>B<sub>0</sub></u> | <u>B<sub>i</sub></u> | <u>C<sub>0</sub></u> | <u>C<sub>i</sub></u> | <u>D<sub>0</sub></u> | <u>D<sub>i</sub></u> |
|-------------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|
| Radial (psi)            | 26,535               | 26,387               | 26,185               | 26,267               | 25,753               | 26,539               | 27,097               | 25,837               |
| Tangential (psi)        | 26,335               | 26,289               | 26,271               | 26,253               | 26,109               | 26,419               | 26,497               | 26,123               |
| Maximum surface (psi)   | 26,535               | 26,387               | 26,271               | 26,267               | 26,109               | 26,539               | 27,097               | 26,123               |
| Allowable surface (psi) | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               |

Surface Stresses at Insert to Shell - OBE Vessel Flooded

| Type of Stress          | <u>A<sub>0</sub></u> | <u>A<sub>i</sub></u> | <u>B<sub>0</sub></u> | <u>B<sub>i</sub></u> | <u>C<sub>0</sub></u> | <u>C<sub>i</sub></u> | <u>D<sub>0</sub></u> | <u>D<sub>i</sub></u> |
|-------------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|
| Radial (psi)            | 18,000               | 17,720               | 17,710               | 17,590               | 16,980               | 18,120               | 18,730               | 17,190               |
| Tangential (psi)        | 17,654               | 17,565               | 17,575               | 17,525               | 17,369               | 17,703               | 17,861               | 17,439               |
| Maximum surface (psi)   | 18,000               | 17,720               | 17,710               | 17,590               | 17,369               | 18,120               | 18,730               | 17,439               |
| Allowable surface (psi) | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               | 52,500               |

**TABLE 3.8-4**  
**SUMMARY OF STRESS LIMITS**

| <u>Critical Section</u> | <u>Applicable Code</u> | <u>Type of Stress</u> | <u>Operating Condition</u> |            | <u>Accident, Initial, and Final Testing Conditions<sup>(a)</sup></u> |            | <u>Flooded Condition OBE</u> |
|-------------------------|------------------------|-----------------------|----------------------------|------------|----------------------------------------------------------------------|------------|------------------------------|
|                         |                        |                       | <u>OBE</u>                 | <u>DBE</u> | <u>OBE</u>                                                           | <u>DBE</u> |                              |
| A                       | ASME III-MC            | Membrane              | Sm                         | 0.9 Sy     | Sm                                                                   | 0.9 Sy     | 0.9 Sy                       |
| B                       | ASME III-MC            | Membrane              | Sm                         | 0.9 Sy     | Sm                                                                   | 0.9 Sy     | 0.9 Sy                       |
| C                       | ASME III-MC            | Membrane              | Sm                         | 0.9 Sy     | Sm                                                                   | 0.9 Sy     | 0.9 Sy                       |
| D                       | ASME III-MC            | Membrane              | Sm                         | 0.9 Sy     | Sm                                                                   | 0.9 Sy     | 0.9 Sy                       |



a. Does not include jet impingement loadings.

TABLE 3.8-8

## ALLOWABLE STRESSES FOR DIFFERENT LOADING COMBINATIONS

| <u>Loading Combinations</u>                                                                                                                                        | <u>Allowable Stresses</u>                                                                                                                                                                                                                                                                                                                                     |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| $D + L + E + T_o + R_o$<br>$D + L + E$<br>$D + L + E + Y_r + T_a + P_a + R_a$<br>(for pedestal only)<br>$D + L + E + Y_j + T_a + P_a + R_a$<br>(for pedestal only) | Normal code allowable stresses (AISC for structural steel, ACI for reinforced concrete). The customary increase in allowable stresses, when earthquake loads are considered, is not permitted.                                                                                                                                                                |
| $D + L + E^1$<br>$D + L + E + Y_r + Y_j + Y_m + T_a + P_a + R_a$                                                                                                   | Stresses do not exceed: 150% of AISC allowables for structural steel, 90% of yield stress for reinforcing bars, 85% of ultimate stress for concrete.                                                                                                                                                                                                          |
| $D + L + E^1 + T_o + R_o$<br>$D + L + E^1 + Y_r + Y_j + Y_m + T_a + P_a + R_a$                                                                                     | No functional failure is permitted. Usually stresses are not allowed to exceed the yield point of the material for steel and the ultimate strength for concrete. If these limits are exceeded, energy absorption is determined and compared to the energy input from the earthquake. The design is such that energy absorption capacity exceeds energy input. |



HNP-2-FSAR-3

**TABLE 3.8-9 (SHEET 1 OF 2)**  
**SUMMARY OF STRESSES ON PEDESTAL RINGS**

Location: Intersection of the Inner Ring and the Drywell el 107 ft 2 5/32 in.

| Loading Case            | Outer Ring         |                     |                    |                        | Inner Ring         |                     |                    |                        |
|-------------------------|--------------------|---------------------|--------------------|------------------------|--------------------|---------------------|--------------------|------------------------|
|                         | Axial Stress (ksi) | Moment Stress (ksi) | Total Stress (ksi) | Allowable Stress (ksi) | Axial Stress (ksi) | Moment Stress (ksi) | Total Stress (ksi) | Allowable Stress (ksi) |
| Normal operating OBE    | 6.01               | 8.85                | 14.86              | 22.80                  | 6.01               | 6.23                | 12.24              | 22.80                  |
| Normal operating DBE    | 6.64               | 16.67               | 23.31              | 34.20                  | 6.64               | 11.73               | 18.37              | 34.20                  |
| Refueling OBE           | 6.18               | 8.85                | 15.03              | 22.80                  | 6.18               | 6.23                | 12.41              | 22.80                  |
| Refueling DBE           | 6.81               | 16.67               | 23.48              | 34.20                  | 6.81               | 11.73               | 18.54              | 34.20                  |
| Accident OBE, vert jet  | 6.44               | 10.21               | 16.65              | 22.80                  | 6.44               | 7.18                | 13.62              | 22.80                  |
| Accident OBE, horiz jet | 6.01               | 11.33               | 17.34              | 22.80                  | 6.01               | 7.97                | 13.98              | 22.80                  |
| Accident DBE, vert jet  | 7.07               | 18.03               | 25.10              | 34.20                  | 7.07               | 12.68               | 19.75              | 34.20                  |
| Accident DBE, horiz jet | 6.64               | 19.15               | 25.79              | 34.20                  | 6.64               | 13.47               | 20.11              | 34.20                  |

Location: el 116 ft 3 in.

|                         |      |       |       |       |      |       |       |       |
|-------------------------|------|-------|-------|-------|------|-------|-------|-------|
| Normal operating OBE    | 6.01 | 7.27  | 13.28 | 22.80 | 6.01 | 5.11  | 11.12 | 22.80 |
| Normal operating DBE    | 6.64 | 13.82 | 20.46 | 34.20 | 6.64 | 9.72  | 16.36 | 34.20 |
| Refueling OBE           | 6.18 | 7.27  | 13.45 | 22.80 | 6.18 | 5.11  | 11.29 | 22.80 |
| Refueling DBE           | 6.81 | 13.82 | 20.63 | 34.20 | 6.81 | 9.72  | 16.53 | 34.20 |
| Accident OBE, vert jet  | 6.44 | 8.63  | 15.07 | 22.80 | 6.44 | 6.07  | 12.51 | 22.80 |
| Accident OBE, horiz jet | 6.01 | 9.01  | 15.02 | 22.80 | 6.01 | 6.34  | 12.35 | 22.80 |
| Accident DBE, vert jet  | 7.07 | 15.18 | 22.25 | 34.20 | 7.07 | 10.67 | 17.74 | 34.20 |
| Accident DBE, horiz jet | 6.64 | 15.57 | 22.21 | 34.20 | 6.64 | 10.95 | 17.59 | 34.20 |

HNP-2-FSAR-3

**TABLE 3.8-9 (SHEET 2 OF 2)**

Location: el 125 ft 11 in.

| Loading Case            | Outer Ring         |                     |                    |                        | Inner Ring         |                     |                    |                        |
|-------------------------|--------------------|---------------------|--------------------|------------------------|--------------------|---------------------|--------------------|------------------------|
|                         | Axial Stress (ksi) | Moment Stress (ksi) | Total Stress (ksi) | Allowable Stress (ksi) | Axial Stress (ksi) | Moment Stress (ksi) | Total Stress (ksi) | Allowable Stress (ksi) |
| Normal operating OBE    | 4.93               | 5.63                | 10.56              | 22.80                  | 4.93               | 3.96                | 8.89               | 22.80                  |
| Normal operating DBE    | 5.46               | 10.84               | 16.30              | 34.20                  | 5.46               | 7.62                | 13.08              | 34.20                  |
| Refueling OBE           | 5.10               | 5.63                | 10.73              | 22.80                  | 5.10               | 3.96                | 9.06               | 22.80                  |
| Refueling DBE           | 5.63               | 10.84               | 16.47              | 34.20                  | 5.63               | 7.62                | 13.25              | 34.20                  |
| Accident OBE, vert jet  | 5.19               | 6.95                | 12.14              | 22.80                  | 5.19               | 4.88                | 10.07              | 22.80                  |
| Accident OBE, horiz jet | 4.93               | 6.57                | 11.50              | 22.80                  | 4.93               | 4.62                | 9.55               | 22.80                  |
| Accident DBE, vert jet  | 5.72               | 12.15               | 17.87              | 34.20                  | 5.72               | 8.55                | 14.27              | 34.20                  |
| Accident DBE, horiz jet | 5.46               | 11.78               | 17.24              | 34.20                  | 5.46               | 8.29                | 13.75              | 34.20                  |

Location: el 132 ft 2 in.

|                         |      |       |       |       |      |      |       |       |
|-------------------------|------|-------|-------|-------|------|------|-------|-------|
| Normal operating OBE    | 4.30 | 4.83  | 9.13  | 22.80 | 4.30 | 3.40 | 7.70  | 22.80 |
| Normal Operating DBE    | 4.83 | 9.42  | 14.25 | 34.20 | 4.83 | 6.62 | 11.45 | 34.20 |
| Refueling OBE           | 4.30 | 4.83  | 9.13  | 22.80 | 4.30 | 3.40 | 7.70  | 22.80 |
| Refueling DBE           | 4.83 | 9.41  | 14.24 | 34.20 | 4.83 | 6.62 | 11.45 | 34.20 |
| Accident OBE, vert jet  | 4.56 | 5.95  | 10.51 | 22.80 | 4.56 | 4.18 | 8.74  | 22.80 |
| Accident OBE, horiz jet | 4.30 | 5.26  | 9.56  | 22.80 | 4.30 | 3.70 | 8.00  | 22.80 |
| Accident DBE, vert jet  | 5.08 | 12.84 | 17.92 | 34.20 | 5.08 | 9.03 | 14.11 | 34.20 |
| Accident DBE, horiz jet | 4.83 | 9.85  | 14.68 | 34.20 | 4.83 | 6.92 | 11.75 | 34.20 |

TABLE 3.8-10

## SUMMARY OF STRESS LIMITS ON REACTOR SHIELD

| <u>Location (el)</u> | <u>Actual Factor as Per<br/>AISC Section 1.6 for<br/>Combined Stresses<br/>Using Critical Load<br/>Combination</u> | <u>Allowable Factor<br/>as Per AISC<br/>Section 1.6 for<br/>Combined Stresses</u> |
|----------------------|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------|
| 148 ft 3 1/2 in.     | 0.58                                                                                                               | 1.0                                                                               |
| 151 ft 9 in.         | 0.59                                                                                                               | 1.0                                                                               |
| 156 ft 1 9/16 in.    | 0.78                                                                                                               | 1.0                                                                               |
| 162 ft 1 in.         | 0.65                                                                                                               | 1.0                                                                               |
| 168 ft 6 in.         | 0.73                                                                                                               | 1.0                                                                               |
| 178 ft 11 in.        | 0.73                                                                                                               | 1.0                                                                               |
| 188 ft 1/2 in.       | 0.69                                                                                                               | 1.0                                                                               |

**TABLE 3.8-11****BASIC MATERIALS FOR CONSTRUCTION OF INTERNAL STRUCTURES**

|                                       |                             |                                |
|---------------------------------------|-----------------------------|--------------------------------|
| 1. Concrete                           |                             | $f'c = 4000$ psi               |
| 2. Reinforcing steel                  |                             |                                |
| Deformed bars                         | ASTM A 615 Grade 60         | $f_y = 60,000$ psi             |
| 3. Structural and miscellaneous steel |                             |                                |
| Rolled shapes, bars, and plates       | ASTM A 36                   | $f_y = 36,000$ psi             |
|                                       | ASTM A 441                  | $f_y = 42,000$ to $50,000$ psi |
|                                       | ASTM A 516 Grade 70         | $f_y = 38,000$ psi             |
| High-strength bolts                   | ASTM A 325<br>ASTM A 193-B7 |                                |
| Nuts for the pedestal                 | ASTM A 194 Grade 7          |                                |
| Washers for the pedestal              | ASTM A 516 Grade 70         |                                |

**TABLE 3.8-12**  
**WATER VELOCITY AT INTAKE STRUCTURE**

|                             | el 71.5 ft<br><u>Normal Water (ft/s)</u> | el 61.7 ft<br><u>Low Water (ft/s)</u> |
|-----------------------------|------------------------------------------|---------------------------------------|
| Velocity at inlet           |                                          |                                       |
| Normal pumping requirement  | 0.40                                     | 1.08                                  |
| All pumps operating         | 0.78                                     | 2.12                                  |
| Velocity through screens    |                                          |                                       |
| Normal pumping requirements | 0.91                                     | 2.82                                  |
| All pumps operating         | 1.79                                     | 5.55                                  |

TABLE 3.8-13 (SHEET 1 OF 2)

## LIVE LOADS ON STRUCTURES

|                                                            | <u>Beams and<br/>Slabs</u>                    | <u>Girders and<br/>Columns</u> |
|------------------------------------------------------------|-----------------------------------------------|--------------------------------|
| <u>General</u>                                             |                                               |                                |
| Roof (minimum)                                             | 20 lb/ft <sup>2</sup>                         | 20 lb/ft <sup>2</sup>          |
| Offices                                                    | 50 lb/ft <sup>2</sup>                         | 40 lb/ft <sup>2</sup>          |
| Stairways and walkways                                     | 100 lb/ft <sup>2</sup>                        | 80 lb/ft <sup>2</sup>          |
| Assembly rooms                                             | 100 lb/ft <sup>2</sup>                        | 80 lb/ft <sup>2</sup>          |
| Concentrated loads <sup>(a)</sup>                          | 4000 lb                                       | 4000 lb                        |
| <u>Reactor Building (excluding drywell and torus area)</u> |                                               |                                |
| Floor at el 130 ft                                         |                                               |                                |
| General                                                    | 600 lb/ft <sup>2</sup>                        | 600 lb/ft <sup>2</sup>         |
| In corners                                                 | 250 lb/ft <sup>2</sup>                        | 200 lb/ft <sup>2</sup>         |
| Near equipment hatches                                     | 1000 lb/ft <sup>2</sup>                       | 1000 lb/ft <sup>2</sup>        |
| Near railroad airlock                                      | Cooper E72 locomotive wheel loads             |                                |
| Floor at el 158 ft, el 185 ft, and el 205 ft               | 200 lb/ft <sup>2</sup>                        | 200 lb/ft <sup>2</sup>         |
| Floor at el 228 ft                                         |                                               |                                |
| General                                                    | 1000 lb/ft <sup>2</sup>                       | 800 lb/ft <sup>2</sup>         |
| Cask areas                                                 | 250,000 lb<br>(6-ft diameter)                 | 250,000 lb<br>(6-ft diameter)  |
| New-fuel storage area                                      | 600 lb/ft <sup>2</sup>                        | 600 lb/ft <sup>2</sup>         |
| Spent-fuel pool and dryer separator<br>storage pool        | Water plus<br>equipment stored                | Water plus<br>equipment stored |
| <u>Torus Area</u>                                          |                                               |                                |
| Floor el 87 ft                                             | 150 lb/ft <sup>2</sup> or torus<br>water load |                                |
| <u>Intake Structure</u>                                    |                                               |                                |
| Valve pit slab                                             | 200 lb/ft <sup>2</sup>                        | 200 lb/ft <sup>2</sup>         |
| Pump room slab                                             | 200 lb/ft <sup>2</sup>                        | 200 lb/ft <sup>2</sup>         |
| Grating floor                                              | 100 lb/ft <sup>2</sup>                        | 100 lb/ft <sup>2</sup>         |
| Base slab                                                  | 75 lb/ft <sup>2</sup>                         |                                |

**TABLE 3.8-13 (SHEET 2 OF 2)**

|                                  | <u>Beams and<br/>Slabs</u> | <u>Girders and<br/>Columns</u> |
|----------------------------------|----------------------------|--------------------------------|
| <u>Control Building</u>          |                            |                                |
| Base slab                        | 250 lb/ft <sup>2</sup>     |                                |
| All floors                       | 350 lb/ft <sup>2</sup>     | 350 lb/ft <sup>2</sup>         |
| Laydown area                     | 1000 lb/ft <sup>2</sup>    | 1000 lb/ft <sup>2</sup>        |
| <u>Diesel Generator Building</u> |                            |                                |
| Base slab                        | 200 lb/ft <sup>3</sup>     |                                |

Crane Loads

Crane and elevator loads are considered live loads. A 25% impact increase to live load is used for traveling-crane support girders and columns. A 100% impact increase to live load is used for elevator supports.

a. For design of floor elements only. Applied at the point of maximum moment or shear. It is not cumulative and not carried to columns.

**TABLE 3.8-14**

**LOADING COMBINATION AND ACCEPTANCE CRITERIA**

| <u>Loading Combination</u>                                | <u>Acceptance Criteria</u>                                                                                                                                                                                                                                                                                                                                    |
|-----------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| $D + L + T_a + 1.5 P_a + R_a$                             | Stresses do not exceed 150% of AISC allowables for structural steel, 90% of yield stress for reinforcing bars, 85% of ultimate stress for concrete.                                                                                                                                                                                                           |
| $D + L + 1.25 E + 1.25 P_a + T_a + R_a + Y_r + Y_j + Y_m$ | No functional failure is permitted. Usually stresses are not allowed to exceed the yield point of the material for steel and the ultimate strength for concrete. If these limits are exceeded, energy adsorption is determined and compared to the energy input from the earthquake. The design is such that energy adsorption capacity exceeds energy input. |

where:

D, L, E,  $P_a$ ,  $T_a$ ,  $R_a$ ,  $Y_r$ ,  $Y_j$ , and  $Y_m$  are defined in paragraph 3.8.3.3.



TABLE 3.8-15

## ALLOWABLE STRESSES FOR DIFFERENT LOADING COMBINATIONS

| <u>Loading Combination</u>                                    | <u>Acceptance Stresses</u>                                                                                                                                                                                                                                                                                                                                                                                                                                |
|---------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| $D + L + T_o + R_o + E$                                       | Normal allowable code stresses (AISC for structural steel, ACI for reinforced concrete). The customary increase in allowable stresses, when earthquake loads are considered, is not permitted.                                                                                                                                                                                                                                                            |
| $D + L + I + E$                                               |                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
| $D + L + C + E$                                               |                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
| $D + L + T_o + R_o + W$                                       | Normal code allowable stresses.                                                                                                                                                                                                                                                                                                                                                                                                                           |
| $D + L + T_a + 1.5P_a + R_a^{(a)}$                            | Stresses do not exceed: 150% of AISC allowables for structural steel, 90% of yield for reinforcing bars, 85% of ultimate stress for concrete.                                                                                                                                                                                                                                                                                                             |
| $D + L + T_o + R_o + E^1$                                     | Stresses are limited to the minimum yield point as a general case. However, in a few cases when missile loads are included, stresses may exceed yield point. In such cases, an analysis, using the limit-design approach, is made to determine the energy absorption capacity which should be such that it exceeds the energy input. The resulting distortion is limited to ensure no loss of function and an adequate factor of safety against collapse. |
| $D + L + T_o + R_o + W_t$                                     |                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
| $D + L + 1.25E + 1.25P_a + T_a + R_a + Y_r + Y_j + Y_m^{(a)}$ |                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
| $D + L + E^1 + P_a + T_a + R_a + Y_r + Y_j + Y_m$             |                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
|                                                               |                                                                                                                                                                                                                                                                                                                                                                                                                                                           |

a. These loading combinations and structural acceptance criteria were used to evaluate the effects of high-energy pipe breaks.

**TABLE 3.8-16**

**BASIC CONSTRUCTION MATERIALS FOR SEISMIC CATEGORY I STRUCTURES**

|                                       |                                      |     |                                                     |
|---------------------------------------|--------------------------------------|-----|-----------------------------------------------------|
| 1. Concrete                           | $f'c = 4000$ psi<br>(all structures) | and | 5000 psi (certain areas<br>of refueling floor only) |
| 2. Reinforcing steel                  |                                      |     |                                                     |
| Deformed bars                         | ASTM A 615, Grade 60                 |     | $f_y = 60,000$ psi                                  |
| 3. Structural and miscellaneous steel |                                      |     |                                                     |
| Rolled shapes, bars, and plates       | ASTM A 36                            |     | $f_y = 36,000$ psi                                  |
| High-strength bolts                   | ASTM A 325 or A 490                  |     |                                                     |
| Stainless steel                       | ASTM A 240, Type 304                 |     |                                                     |

**TABLE 3.8-17****AGGREGATE TESTS**

| <u>ASTM No.</u> | <u>Title</u>                                        | <u>Results to Be Achieved</u> | <u>Initial Test</u> | <u>User's Test</u> | <u>Daily Test</u> |
|-----------------|-----------------------------------------------------|-------------------------------|---------------------|--------------------|-------------------|
| C-33            | Gradation                                           | To conform with specification | X                   |                    | X                 |
| C-40            | Organic impurities                                  | To conform with specification | X                   |                    |                   |
| C-87            | Mortar-making properties                            | To conform with specification | X                   |                    |                   |
| C-88            | Soundness                                           | To conform with specification | X                   |                    |                   |
| C-117           | Material finer than No. 200 sieve                   | Design mix calculations       | X                   | X                  |                   |
| C-127           | Specific gravity and absorption (coarse aggregates) | Design mix calculations       | X                   | X                  |                   |
| C-128           | Specific gravity and absorption (fine aggregates)   | Design mix calculations       | X                   | X                  |                   |
| C-131           | Los Angeles abrasion                                | To conform with specification | X                   |                    |                   |
| C-136           | Sieve analysis                                      | To conform with specification | X                   |                    |                   |
| C-142           | Clay lumps                                          | To conform with specification | X                   |                    |                   |
| C-227           | Potential reactivity (mortar bar)                   | To conform with specification | X                   |                    |                   |
| C-289           | Potential reactivity (chemical)                     | To conform with specification | X                   |                    |                   |
| C-295           | Petrographic                                        | To conform with specification | X                   |                    |                   |

**TABLE 3.8-18**  
**CEMENT TESTS**

| <u>ASTM<br/>No.</u> | <u>Type of Test</u>                | <u>Initial<br/>Test</u> | <u>User's<br/>Test</u> | <u>Daily<br/>Test</u> |
|---------------------|------------------------------------|-------------------------|------------------------|-----------------------|
| C-109               | Compressive strength               | X                       | X                      |                       |
| C-114               | Chemical analysis                  | X                       | X                      |                       |
| C-115               | Fineness-turbidimeter              | X                       | X                      |                       |
| C-151               | Autoclave expansion<br>(soundness) | X                       | X                      |                       |
| C-185               | Air content                        | X                       | X                      |                       |
| C-266               | Time of setting Gilmore            | X                       | X                      |                       |

HNP-2-FSAR-3

**TABLE 3.8-19**

**FLY ASH TESTS**

| <u>ASTM<br/>No.</u> | <u>Type of Test</u>                | <u>Initial<br/>Test</u> | <u>User's<br/>Test</u> |
|---------------------|------------------------------------|-------------------------|------------------------|
| C-114               | Chemical analysis loss on ignition | X                       | X                      |
| C-185               | Air entrainment of mortar          | X                       | X                      |
| C-188               | Specific gravity                   | X                       | X                      |
| C-204               | Fineness                           | X                       | X                      |
| C-311               | Sampling and tests                 | X                       | X                      |

TABLE 3.8-20 (SHEET 1 OF 13)

## MASONRY WALL REEVALUATION RESULTS

| <u>Wall No.</u> <sup>(a)</sup> | <u>Safety-Related Equipment</u> <sup>(b)</sup> | <u>Wall Analysis</u> <sup>(c)</sup> |
|--------------------------------|------------------------------------------------|-------------------------------------|
| C112-1A<br>-1B                 | Yes                                            | MR                                  |
| C112-2A<br>-2B                 | Yes                                            | SA                                  |
| C112-3A<br>-3B                 | No                                             | Not required                        |
| C112-4A<br>-4B                 | Yes                                            | SA                                  |
| C112-5A<br>-5B                 | Yes                                            | SA                                  |
| C112-6A<br>-6C                 | Yes                                            | SA                                  |
| C112-6B<br>-6D                 | No                                             | Not required                        |
| C112-7A<br>-7C                 | No                                             | Not required                        |
| C112-7B<br>-7D                 | No                                             | Not required                        |
| C112-8A<br>-8C                 | No                                             | Not required                        |
| C112-8B<br>-8D                 | No                                             | Not required                        |
| C112-9A<br>-9C                 | No                                             | Not required                        |
| C112-9B<br>-9D                 | No                                             | Not required                        |

**TABLE 3.8-20 (SHEET 2 OF 13)**

| <u>Wall No.</u> <sup>(a)</sup> | <u>Safety-Related<br/>Equipment</u> <sup>(b)</sup> | <u>Wall Analysis</u> <sup>(c)</sup> |
|--------------------------------|----------------------------------------------------|-------------------------------------|
| C112-10A<br>-10C               | Yes                                                | SA                                  |
| C112-10B<br>-10D               | Yes                                                | SA                                  |
| C112-11A<br>-11B               | Yes                                                | SA                                  |
| C112-12A<br>-12B               | Yes                                                | SA                                  |
| C112-13A<br>-13B               | No                                                 | Not required                        |
| C112-14A<br>-14B               | Yes                                                | SA                                  |
| C112-15A<br>-15B               | Yes                                                | SA                                  |
| C112-16A<br>-16B               | Yes                                                | SA                                  |
| C112-17A<br>-17B               | Yes                                                | SA                                  |
| C112-18A<br>-18B               | Yes                                                | SA                                  |
| C112-19A<br>-19B               | Yes                                                | SA                                  |
| C112-20A<br>-20B               | Yes                                                | SA                                  |
| C112-21A<br>-21D               | Yes                                                | SA                                  |
| C112-21B<br>-21E               | Yes                                                | SA                                  |

**TABLE 3.8-20 (SHEET 3 OF 13)**

| <u>Wall No.</u> <sup>(a)</sup> | <u>Safety-Related Equipment</u> <sup>(b)</sup> | <u>Wall Analysis</u> <sup>(c)</sup> |
|--------------------------------|------------------------------------------------|-------------------------------------|
| C112-21C<br>-21F               | Yes                                            | SA                                  |
| C112-22A<br>-22B               | Yes                                            | SA                                  |
| C112-23A<br>-23B               | Yes                                            | SA                                  |
| C112-24A<br>-24B               | Yes                                            | SA                                  |
| C112-25A<br>-25B               | Yes                                            | SA                                  |
| C112-25C<br>-25D               | Yes                                            | SA                                  |
| C112-26A<br>-26B               | Yes                                            | SA                                  |
| C112-27A<br>-27B               | Yes                                            | SA                                  |
| C112-28A<br>-28B               | Yes                                            | SA                                  |
| C112-29A<br>-29B               | Yes                                            | SA                                  |
| C112-30A<br>-30B               | Concrete walls                                 | Not required                        |
| C112-31A<br>-31B               | Concrete walls                                 | Not required                        |
| C112-32A<br>-32B               | Concrete walls                                 | Not required                        |
| C112-33A<br>-33B               | Concrete walls                                 | Not required                        |



**TABLE 3.8-20 (SHEET 4 OF 13)**

| <u>Wall No.</u> <sup>(a)</sup> | <u>Safety-Related Equipment</u> <sup>(b)</sup> | <u>Wall Analysis</u> <sup>(c)</sup> |
|--------------------------------|------------------------------------------------|-------------------------------------|
| C112-34A<br>-34B               | Yes                                            | SA                                  |
| C130-1A<br>-1B                 | Yes                                            | MR                                  |
| C130-2A<br>-2B                 | Yes                                            | MR                                  |
| C130-3A<br>-3B                 | Yes                                            | MR                                  |
| C130-4A<br>-4B                 | No                                             | Not required                        |
| C130-5A<br>-5B                 | Yes                                            | SA                                  |
| C130-6A<br>-6B                 | Yes                                            | SA                                  |
| C130-7A<br>-7B                 | Yes                                            | MR                                  |
| C130-8A<br>-8B                 | Yes                                            | SA                                  |
| C130-9A<br>-9B                 | Yes                                            | SA                                  |
| C130-10A<br>-10B               | Yes                                            | SA                                  |
| C130-11A<br>-11B               | Yes                                            | SA                                  |
| C130-12A<br>-12B               | Yes                                            | SA                                  |
| C130-13A<br>-13B               | Yes                                            | SA                                  |

**TABLE 3.8-20 (SHEET 5 OF 13)**

| <u>Wall No.</u> <sup>(a)</sup> | <u>Safety-Related Equipment</u> <sup>(b)</sup> | <u>Wall Analysis</u> <sup>(c)</sup> |
|--------------------------------|------------------------------------------------|-------------------------------------|
| C130-14A<br>-14B               | Yes                                            | MR                                  |
| C130-15A<br>-15B               | Yes                                            | SA                                  |
| C130-16A<br>-16B               | Yes                                            | SA                                  |
| C130-17A<br>-17B               | Yes                                            | SA                                  |
| C130-17C<br>-17D               | Yes                                            | SA                                  |
| C130-18A<br>-18B               | No                                             | Not required                        |
| C130-18C                       | No                                             | Not required                        |
| C130-19A<br>-19B               | No                                             | Not required                        |
| C130-20A<br>-20B               | Yes                                            | SA                                  |
| C130-20C<br>-20D               | Yes                                            | SA                                  |
| C130-21A<br>-21B               | Yes                                            | SA                                  |
| C130-21C<br>-21D               | Yes                                            | SA                                  |
| C130-22A<br>-22B               | Yes                                            | SA                                  |
| C130-23A<br>-23B               | No                                             | Not required                        |

**TABLE 3.8-20 (SHEET 6 OF 13)**

| <u>Wall No.</u> <sup>(a)</sup> | <u>Safety-Related<br/>Equipment</u> <sup>(b)</sup> | <u>Wall Analysis</u> <sup>(c)</sup> |
|--------------------------------|----------------------------------------------------|-------------------------------------|
| C130-24A<br>-24B               | No                                                 | Not required                        |
| C130-25A<br>-25B               | No                                                 | Not required                        |
| C130-25C<br>-25D               | No                                                 | Not required                        |
| C130-26A<br>-26B               | No                                                 | Not required                        |
| C130-27A<br>-27B               | No                                                 | Not required                        |
| C130-28A<br>-28B               | No                                                 | Not required                        |
| C130-29A<br>-29B               | No                                                 | Not required                        |
| C130-30A<br>-30B               | No                                                 | Not required                        |
| C130-31A<br>-31B               | No                                                 | Not required                        |
| C130-32A<br>-32B               | No                                                 | Not required                        |
| C130-33A<br>-33B               | No                                                 | Not required                        |
| C130-34A<br>-34B               | No                                                 | Not required                        |
| C130-35A<br>-35B               | Yes                                                | SA                                  |
| C130-36A<br>-36B               | No                                                 | Not required                        |

**TABLE 3.8-20 (SHEET 7 OF 13)**

| <u>Wall No.</u> <sup>(a)</sup> | <u>Safety-Related Equipment</u> <sup>(b)</sup> | <u>Wall Analysis</u> <sup>(c)</sup> |
|--------------------------------|------------------------------------------------|-------------------------------------|
| C130-37A<br>-37B               | No                                             | Not required                        |
| C130-38A<br>-38B               | No                                             | Not required                        |
| C130-39A<br>-39B               | Yes                                            | MR                                  |
| C130-39C<br>-39D               | Yes                                            | MR                                  |
| C130-40A<br>-40B               | Yes                                            | SA                                  |
| C130-41A<br>-41B               | Yes                                            | MR                                  |
| C130-42A<br>-42B               | No                                             | Not required                        |
| C130-43A<br>-43B               | No                                             | Not required                        |
| C130-44A<br>-44B               | Yes                                            | SA                                  |
| C130-44C<br>-44D               | Yes                                            | SA                                  |
| C130-45A<br>-45B               | Yes                                            | SA                                  |
| C130-46A<br>-46B               | Yes                                            | SA                                  |
| C130-47A<br>-47B               | Yes                                            | SA                                  |
| C130-47C<br>-47D               | Yes                                            | SA                                  |

**TABLE 3.8-20 (SHEET 8 OF 13)**

| <u>Wall No.</u> <sup>(a)</sup> | <u>Safety-Related Equipment</u> <sup>(b)</sup> | <u>Wall Analysis</u> <sup>(c)</sup> |
|--------------------------------|------------------------------------------------|-------------------------------------|
| C130-47E<br>-47F               | Yes                                            | SA                                  |
| C130-48A<br>-48B               | Yes                                            | SA                                  |
| C130-48C<br>-48D               | Yes                                            | SA                                  |
| C130-49A<br>-49B               | No                                             | Not required                        |
| C130-49C<br>-49D               | No                                             | Not required                        |
| C130-49E<br>-49F               | No                                             | Not required                        |
| C130-50A<br>-50B               | Yes                                            | SA                                  |
| C130-51A<br>-51B               | Yes                                            | SA                                  |
| C130-52A<br>-52B               | Yes                                            | SA                                  |
| C130-53A<br>-53B               | Yes                                            | SA                                  |
| C130-54A<br>-54B               | Yes                                            | SA                                  |
| C130-55A<br>-55B               | Yes                                            | SA                                  |
| C130-56A<br>-56B               | Yes                                            | SA                                  |
| C130-57A<br>-57B               | Yes                                            | SA                                  |

**TABLE 3.8-20 (SHEET 9 OF 13)**

| <u>Wall No.</u> <sup>(a)</sup> | <u>Safety-Related<br/>Equipment</u> <sup>(b)</sup> | <u>Wall Analysis</u> <sup>(c)</sup> |
|--------------------------------|----------------------------------------------------|-------------------------------------|
| C130-58A<br>-58B               | Yes                                                | SA                                  |
| C130-59A<br>-59B               | Yes                                                | SA                                  |
| C130-60A<br>-60B               | Yes                                                | SA                                  |
| C130-61A<br>-61B               | Yes                                                | SA                                  |
| C130-62A<br>-62B               | Yes                                                | SA                                  |
| C130-63A<br>-63B               | Yes                                                | SA                                  |
| C130-64A<br>-64B               | Yes                                                | SA                                  |
| C130-65A<br>-65B               | Yes                                                | SA                                  |
| C130-38C<br>-38D               | No                                                 | Not required                        |
| C147-1A<br>-1B                 | Yes                                                | SA                                  |
| C147-1C<br>-1D                 | Yes                                                | SA                                  |
| C147-2A<br>-2B                 | Yes                                                | SA                                  |
| C147-3A<br>-3B                 | Yes                                                | SA                                  |
| C147-4A<br>-4B                 | Yes                                                | SA                                  |

HNP-2-FSAR-3

**TABLE 3.8-20 (SHEET 10 OF 13)**

| <u>Wall No.</u> <sup>(a)</sup> | <u>Safety-Related Equipment</u> <sup>(b)</sup> | <u>Wall Analysis</u> <sup>(c)</sup> |
|--------------------------------|------------------------------------------------|-------------------------------------|
| C147-5A<br>-5B                 | No                                             | Not required                        |
| C147-6A<br>-6B                 | Yes                                            | SA                                  |
| C147-7A<br>-7B                 | No                                             | Not required                        |
| C147-8A<br>-8B                 | No                                             | Not required                        |
| C147-9A<br>-9B                 | Yes                                            | SA                                  |
| C147-10A<br>-10B               | Yes                                            | SA                                  |
| C147-10C<br>-10D               | Yes                                            | SA                                  |
| C164-1A<br>-1B                 | Yes                                            | SA                                  |
| C164-2A<br>-2B                 | Yes                                            | SA                                  |
| C164-3A<br>-3B                 | Yes                                            | SA                                  |
| C164-4A<br>-4B                 | Yes                                            | MR                                  |
| C164-5A<br>-5B                 | Yes                                            | SA                                  |
| C164-6A<br>-6B                 | No                                             | Not required                        |
| C164-7A<br>-7B                 | Yes                                            | SA                                  |

HNP-2-FSAR-3

**TABLE 3.8-20 (SHEET 11 OF 13)**

| <u>Wall No.</u> <sup>(a)</sup> | <u>Safety-Related Equipment</u> <sup>(b)</sup> | <u>Wall Analysis</u> <sup>(c)</sup> |
|--------------------------------|------------------------------------------------|-------------------------------------|
| C164-8A<br>-8B                 | No                                             | Not required                        |
| C164-9A<br>-9B                 | Yes                                            | SA                                  |
| C164-10A<br>-10B               | No                                             | Not required                        |
| C164-11A<br>-11B               | Yes                                            | SA                                  |
| C164-12A<br>-12B               | Yes                                            | SA                                  |
| C164-13A<br>-13B               | Yes                                            | SA                                  |
| C180-1A<br>-1B                 | No                                             | Not required                        |
| C180-2A<br>-2B                 | No                                             | Not required                        |
| C180-3A<br>-3B                 | No                                             | Not required                        |
| C180-4A<br>-4B                 | No                                             | Not required                        |
| R130-1A<br>-1B                 | Yes <sup>(a)</sup>                             | Not required                        |
| R130-2A<br>-2B                 | Yes <sup>(a)</sup>                             | Not required                        |
| R130-3A<br>-3B                 | Yes                                            | SA                                  |
| R130-4A<br>-4B                 | Yes                                            | SA                                  |



HNP-2-FSAR-3

**TABLE 3.8-20 (SHEET 12 OF 13)**

| <u>Wall No.</u> <sup>(a)</sup> | <u>Safety-Related Equipment</u> <sup>(b)</sup> | <u>Wall Analysis</u> <sup>(c)</sup> |
|--------------------------------|------------------------------------------------|-------------------------------------|
| R158-1A<br>-1B                 | Yes <sup>(a)</sup>                             | Not required                        |
| R158-2A<br>-2B                 | Yes <sup>(a)</sup>                             | Not required                        |
| R158-3A<br>-3B                 | Yes <sup>(a)</sup>                             | Not required                        |
| R158-4A<br>-4B                 | Yes <sup>(a)</sup>                             | Not required                        |
| R158-5A<br>-5B                 | No                                             | Not required                        |
| R158-6A<br>-6B                 | No                                             | Not required                        |
| R185-1A<br>-1B                 | No                                             | Not required                        |
| R185-2A<br>-2B                 | No                                             | Not required                        |
| R185-3A<br>-3B                 | No                                             | Not required                        |
| R185-4A<br>-4B                 | Concrete wall                                  | Not required                        |
| R203-1A<br>-1B                 | No                                             | Not required                        |
| R203-2A<br>-2B                 | No                                             | Not required                        |
| R203-3A<br>-3B                 | No                                             | Not required                        |
| S108-2A<br>-2B                 | Yes                                            | SA                                  |

HNP-2-FSAR-3

**TABLE 3.8-20 (SHEET 13 OF 13)**

---


a. Wall numbering system: Example: C112-20A.

C is used to denote control building; R denotes reactor building; and S denotes main stack.


112 indicates the floor elevation supporting the wall. 20 indicates the consecutive wall number, and A indicates the particular side of the wall in question.

b. Yes - Safety-related equipment is attached to or in proximity to wall. No - No safety-related equipment is attached to or in proximity to wall.


c. SA - Stresses are within design allowables. MR - Modification required due to one or more stresses above design allowables. Necessary modifications were completed.




DRYWELL HEAD PERSONNEL ACCESS HATCH



CRD REMOVAL HATCH




□ □ ETHYLENE PROPYLENE GASKET-ENDLESS (OR) O RINGS




BOLT HOLES

TYPICAL TESTABLE DOUBLE SEAL



TYP. 10'-0" DIA. EQUIPMENT DOOR ASS'Y



TYPICAL SUPPRESSION CHAMBER MANHOLE ENTRANCE

PERSONNEL AND EQUIPMENT ACCESS LOCKS

ACAD 2030801


REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

PERSONNEL AND EQUIPMENT  
ACCESS LOCKS FOR DRYWELL  
AND SUPPRESSION CHAMBER

FIGURE 3.8-1



"A", "B", & "C" = FIELD WELDS



ACAD 20308021


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

PIPE PENETRATIONS - TYPE 1  
ACCOMMODATE THERMAL MOVEMENTS

FIGURE 3.8-2 (SHEET 1 OF 4)



ACAD 20308021


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

PIPE PENETRATIONS – TYPE 1A  
(MAIN STEAM LINE ONLY)  
ACCOMMODATE THERMAL MOVEMENTS

FIGURE 3.8-2 (SHEET 2 OF 4)



"A", "B", & "C" = FIELD WELDS

CLAMSHELL - DESIGN BELLOWS ASSEMBLIES FOR PENETRATION X-8.

ACAD 20308023


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

PIPE PENETRATIONS - TYPE 1B  
ACCOMMODATE THERMAL MOVEMENTS

FIGURE 3.8-2 (SHEET 3 OF 4)



"A", "B", & "C" = FIELD WELDS

CLAMSHELL BELLOWS ASSEMBLIES DETAILS FOR PENETRATION X - 9A

ACAD 20308024


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

PIPE PENETRATIONS - TYPE 1C  
ACCOMMODATE THERMAL MOVEMENTS

FIGURE 3.8-2 (SHEET 4 OF 4)



ACAD 2030803

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

PIPE PENETRATIONS - TYPE 2.1 -  
THERMAL MOVEMENT RELATIVELY SMALL  
(SMALL BORE PIPING ONLY)

FIGURE 3.8-3





ACAD 2030804


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

PIPE PENETRATIONS – TYPE 2.2 –  
THERMAL MOVEMENTS RELATIVELY SMALL

FIGURE 3.8-4



ACAD 2030805


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TYPICAL INSTRUMENT PENETRATION

FIGURE 3.8-5



ELECTRICAL PENETRATION ASSEMBLY STRUCTURAL COMPONENTS

ACAD 2030806

REV 19 7/01


EF DWG SX-25401 REV A



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TYPICAL ELECTRICAL PENETRATION  
STRUCTURAL COMPONENTS

FIGURE 3.8-6



INSTALLED ELECTRICAL PENETRATION ASSEMBLY

ACAD 2030807

REV 19 7/01


EF DWG SX-25401 REV A



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TYPICAL ELECTRICAL PENETRATION  
ASSEMBLY DETAIL

FIGURE 3.8-7



TYPICAL TRAVERSING IN-CORE PROBE  
PENETRATION

ACAD 2030808


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TRAVERSING INCORE PROBE  
PENETRATION

FIGURE 3.8-8



**DRYWELL BASIC GEOMETRY**  
**SHELL THICKNESS & STRESS LOCATIONS**  
 SECTIONAL ELEVATION

ACAD 2030809

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

CONTAINMENT GEOMETRY  
 SHELL THICKNESS AND STRESS  
 LOCATIONS

FIGURE 3.8-9

APPLICABLE TO VALVES: 2E21-F015A, B



FORCES CAUSED BY THE APPLICATION OF LEAKAGE TEST PRESSURE UNDER THE VALVE DISC ACT AGAINST THE SEATING FORCE CREATED BY THE STEM ACTING ON THE DISC. FORCES DUE TO CONTAINMENT PRESSURE ACT ON TOP OF THE DISC AND ARE ADDITIVE TO THE SEATING FORCES OF THE STEM AGAINST THE DISC AND TEND TO SEAT THE VALVE MORE TIGHTLY.

ACAD 203810

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

GLOBE VALVE

FIGURE 3.8-10

APPLICABLE TO VALVES: 2B21-F022A, B, C, D



FORCES DUE TO THE LEAKAGE TEST PRESSURE ACT AGAINST THE SEATING FORCES OF THE VALVE. AS THE VALVE IS DESIGNED TO USE UPSTREAM PRESSURE TO PROVIDE A TIGHT SEAT, PRESSURE FORCES FROM THE CONTAINMENT DIRECTION WILL TEND TO SEAT THE VALVE.

ACAD 2030811

REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2


MAIN STEAM ISOLATION  
GLOBE VALVE

FIGURE 3.8-11



**APPLICABLE TO VALVES:**

2T48-F114  
2T48-F116  
2T48-F118A, B  
2T48-F322  
2T48-F327



THE SUBJECT VALVES ARE OF THE UNBALANCED FLOW TO OPEN DESIGN; THEREFORE, WITH AN OBSERVED PRESSURE DROP IN THE REVERSE FLOW DIRECTION, AN ADDITIONAL SEATING LOAD WILL BE EXPERIENCED DUE TO THE HIGHER PRESSURE AT THE OUTLET OF THE VALVE BEING REGISTERED ON TOP OF THE VALVE PLUG, THUS SUPPLYING A FORCE IN THE DOWNWARD DIRECTION. THEREFORE, PRIMARY CONTAINMENT PRESSURE WILL TEND TO SEAT THE VALVE MORE TIGHTLY, WHEREAS TEST PRESSURE APPLIED ON THE SIDE OPPOSITE CONTAINMENT ACTS AGAINST THE SEATING FORCES.

ACAD 2030812

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

CONTROL VALVE

FIGURE 3.8-12

**APPLICABLE TO VALVES:**

- 2T48-F307**
- 2T48-F309**
- 2T48-F310**
- 2T48-F311**
- 2T48-F318**
- 2T48-F319**



ACAD 2030813

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

BUTTERFLY VALVE

FIGURE 3.8-13

APPLICABLE TO VALVES: 2E11-F065, A, B, C, D



ACAD 2030814

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

BUTTERFLY VALVE

FIGURE 3.8-14

APPLICABLE TO VALVES: 2E41-F051  
2E51-F003  
2E21-F019A, B



RESILIENT SEAT  
THE SAME SEATING  
CHARACTERISTICS  
EXIST WHEN PRESSURIZED  
FROM EITHER DIRECTION.

ACAD 2030815


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

BUTTERFLY VALVE

FIGURE 3.8-15



**A/S** - AIR OR NITROGEN SUPPLY  
**F1** - DUAL SCALE FLOWMETER  
**PI** - PRESSURE GAGE ABSOLUTE

ACAD 2030816


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TYPICAL TYPE C TEST  
 ARRANGEMENT

FIGURE 3.8-16



ACAD 2030817


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

2P51 SERVICE AIR SYSTEM

FIGURE 3.8-17



ACAD 2030818


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

2P64 CHILLED WATER SYSTEM

FIGURE 3.8-18



ACAD 2030819

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

2T48 NITROGEN INERTING SYSTEM

FIGURE 3.8-19





ACAD 2030820


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

2P21 DEMINERALIZED WATER SYSTEM

FIGURE 3.8-20



ACAD 2030821


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

ILRT CONNECTION

FIGURE 3.8-21



ACAD 2030822



REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

FIRE PROTECTION

FIGURE 3.8-22



ACAD 2030823


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TORUS TO DRYWELL  
 $\Delta P$

FIGURE 3.8-23



ACAD 2030824


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

DRYWELL/SUPPRESSION CHAMBER LEAK  
TEST CONTAINMENT PRESSURE RESPONSE  
WITH LEAK EQUIVALENT TO 1-in. DIAMETER  
ORIFICE

FIGURE 3.8-24



ACAD 2030825


REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

DRYWELL SUPPRESSION CHAMBER LEAK  
TEST CONTAINMENT DIFFERENTIAL  
RESPONSE WITH LEAKAGE EQUIVALENT TO  
1-in. DIAMETER ORIFICE


FIGURE 3.8-25




**PLAN VIEW**  
 Tie Downs Omitted



**DETAIL F**



**PLAN VIEW**  
 (Tie Downs In Assembled Position)



**SECTION D-D**


ACAD 2030826

REV 19 7/01

**SOUTHERN NUCLEAR OPERATING COMPANY**  
**EDWIN I. HATCH NUCLEAR PLANT**  
**UNIT 2**  
 Energy to Serve Your World®


DETAILS OF CONTAINMENT AIRLOCK

FIGURE 3.8-26




REACTOR SHIELD ~

FLAT DEVELOPMENT



TYP RING GIRDER DETAIL  
(SECTION 'A-A')



ACAD 2030827

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

FLAT DEVELOPMENT OF  
REACTOR SHIELD

FIGURE 3.8-27





ACAD 2030828

DRYWELL INTERNAL STRUCTURES

ACAD 2030828


REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

DRYWELL INTERNAL STRUCTURES


FIGURE 3.8-28



DRYWELL JET DEFLECTION



VIEW AA





TYP. SECT THRU C BEAM SEAT




SECTION AA  
(TYP @ EACH HANGER LOCATION)

LOWER SPRAY HEADER SUPPORT

MISCELLANEOUS  
INTERNAL - STRUCTURAL  
COMPONENTS



SECTION AA



VIEW BB


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

MISCELLANEOUS INTERNAL  
STRUCTURAL COMPONENTS

FIGURE 3.8-29



REACTOR BUILDING FOUNDATION PLAN

ACAD 2030830


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

REACTOR BUILDING FOUNDATION  
PLAN AND SECTION

FIGURE 3.8-30



REACTOR BUILDING FOUNDATION SECTION

ACAD 2030831

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

SECTION OF REACTOR BUILDING  
FOUNDATION

FIGURE 3.8-31

SUMMARY OF LOADS AT BASE OF PEDESTAL  
EL 101'-11 1/2"

| LOADING CASE            | VERTICAL LOAD          |                          | OVER-TURNING MOMENT (FT-K) | HORIZ. SHEAR (K) | MAX BOLT LOAD (K) |          | MAX CONC BEARING (PSI) |          |
|-------------------------|------------------------|--------------------------|----------------------------|------------------|-------------------|----------|------------------------|----------|
|                         | WITH SEISMIC ACTING UP | WITH SEISMIC ACTING DOWN |                            |                  | OUTS RING         | INS RING | OUTS RING              | INS RING |
| OPERATING- OBE          | 10994                  | 18448                    | 104371                     | 1949             | 79                | 56       | 861                    | 881      |
| OPERATING- DBE          | 9326                   | 20116                    | 136245                     | 2615             | 150               | 147      | 1034                   | 1043     |
| REFUELING- OBE          | 12077                  | 19795                    | 104371                     | 1949             | 69                | 40       | 892                    | 917      |
| REFUELING- DBE          | 10352                  | 21520                    | 136245                     | 2615             | 140               | 132      | 1066                   | 1081     |
| ACCIDENT HORIZ JET- OBE | 10928                  | 18334                    | 137628                     | 2889             | 137               | 126      | 1000                   | 1000     |
| ACCIDENT VERT. JET- OBE | 9988                   | 19274                    | 104371                     | 1949             | 88                | 71       | 1880                   | 903      |
| ACCIDENT HORIZ JET- DBE | 9272                   | 19990                    | 168962                     | 3555             | 206               | 216      | 1171                   | 1160     |
| ACCIDENT VERT. JET- DBE | 8832                   | 20930                    | 136245                     | 2615             | 159               | 162      | 1053                   | 1065     |
| FLOODED OBE             | 8829                   | 21587                    | 135278                     | 3026             | 152               | 152      | 1064                   | 1079     |



PLAN VIEW

| PRE-TENSIONING VALUES |            |              |
|-----------------------|------------|--------------|
|                       | STRAIN     | TORQUE       |
| OUTS. BOLTS           | 0.0747 IN  | 2789 FT LB   |
| INS. BOLTS            | 0.0412 IN. | 2053 FT. LB. |

PEDESTAL ANCHOR BOLTS

ACAD 2030832


REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

RPV PEDESTAL FOUNDATION  
ANCHOR BOLTS


FIGURE 3.8-32



MAIN STACK FOUNDATION PLAN



SECTION A



PILE ANCHORAGE DETAIL

ACAD 2030833


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

MAIN STACK FOUNDATION  
PLAN AND SECTIONS

FIGURE 3.8-33



ACAD 2030834


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

MASONRY WALL SINGLE-LINE  
SKETCHES - CONTROL BUILDING

FIGURE 3.8-34



ACAD 2030835

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

MASONRY WALL SINGLE-LINE  
SKETCHES - CONTROL BUILDING

FIGURE 3.8-35





ACAD 2030836



REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

MASONRY WALL SINGLE-LINE  
SKETCHES - CONTROL BUILDING

FIGURE 3.8-36



ACAD 2030837


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

MASONRY WALL SINGLE-LINE  
SKETCHES – CONTROL BUILDING

FIGURE 3.8-37



NOTE: ALL CONDUIT THIS SKETCH IS  
 ALUM. UNLESS NOTE OTHERWISE.

ACAD 2030838


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

EXAMPLE OF WALL SURVEILLANCE  
 SKETCH

FIGURE 3.8-38



NOTE: ALL  $\nabla$  MADE OF SHEET METAL

ACAD 2030839


REV 19 #7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

MASONRY WALL NO. C-130-7A

FIGURE 3.8-39



DETAIL "C"



SECTION  
A-A

ACAD 2030840



REV 19 7/01

**SOUTHERN COMPANY**  
Energy to Serve Your World®

SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

DETAILS FOR MASONRY WALL  
NO. C-130-7A

FIGURE 3.8-40



SECTION A-A

ACAD 2030841


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

DETAILS FOR MASONRY WALL  
NO. C-130-7A

FIGURE 3.8-41



DETAIL "E"

STANDARD FIREDOOR HANGER

ACAD 2030842


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

DETAILS FOR MASONRY WALL  
WALL C-130-7A

FIGURE 3.8-42



ACAD 2030843

REV 19 7/01





SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

DETAILS FOR MASONRY WALL  
 WALL C-130-7A

FIGURE 3.8-43





ACAD 2030844


REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

DETAILS FOR MASONRY WALL  
WALL C-130-7A

FIGURE 3.8-44



DETAIL "H"  
MAGNETIC FIRE DOOR STOP



SECTION A-A

ACAD 2030845


REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

DETAILS FOR MASONRY WALL  
WALL C-130-7A

FIGURE 3.8-45



TYP. PLAN @ HORZ. BLOCK JOINT  
WHERE MASONRY BUTTS CONC. COL'S OF WALLS  
@ NO DOVETAIL SLOTS C-C  
 SC. 1/2" = 1'-0"





**NOTE "A"**  
 THE EXTENDED ENDS OF STONE ANCHORS THAT TERMINATE IN MASONRY CELLS THAT ARE NOT FILLED SOLID @ CONC, MUST BE SECURED TO THE WALL BY FILLING EACH CELL SOLID @ CONC WHERE REQUIRED.

TYP. PLAN @ HORZ BLK. JOINT WHERE  
MASONRY WALLS BUTT CONCRETE-  
DETAIL "B" (DOUBLE ANCHOR SLOT)

REV 19 7/01

## 2 TYPES OF CONCRETE BLOCK WALLS




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TYPICAL MASONRY WALL DETAILS

FIGURE 3.8-47



TYP. PLAN @ HORIZ. BLK. JOINT WHERE  
MASONRY WALLS BUTT CONCRETE -  
DETAIL "A" (SINGLE ANCHOR SLOT)  
 SC. 1/2" = 1'-0"


REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TYPICAL MASONRY WALL DETAILS

FIGURE 3.8-48



TYP. PRECAST CONC. LINTEL DETAIL A-A



TYP. ELEV. @ LINTEL WHERE  
OPENING BUTTS CONC.  
COLUMN - C-C  
 SC. 1" = 1'-0"

ACAD 2030849

REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TYPICAL MASONRY WALL DETAILS

FIGURE 3.8-49

**SUPPLEMENT 3.8A**

**MECHANICAL SPLICING OF REINFORCING BARS  
USING THE CADWELD PROCESS**

**3.8A.1 SCOPE**

Mechanical splicing of deformed reinforcing bars for full-tensile loading is accomplished with Cadweld connectors, and the procedure used is in accordance with Regulatory Guide 1.10, "Mechanical (Cadweld) Splices in Reinforcing Bars of Category I Concrete Structures," January 1973, except as noted in the Qualification of Operators and Joint Acceptance Standards. The average tensile strength of the Cadweld joints is greater than the minimum tensile strength for the particular grade of reinforcing steel as specified in the appropriate American Society of Testing Materials (ASTM) standard. The minimum tensile strength of the splices exceeds 125% of the minimum yield strength for each grade of reinforcing steel as specified in the appropriate ASTM standard.

**3.8A.2 PROCESS**

All splices are made by the Cadweld process (Erico Products, Inc.) using clamping devices, sleeves, charges, etc., as specified by the Cadweld instruction sheets for T series connections. The C series and C-16 series materials are not permitted.

**3.8A.3 QUALIFICATIONS OF OPERATORS**

Prior to the production splicing of reinforcing bars, each operator or crew, including the foreman or supervisor for that crew, prepares and tests a joint, in place of two joints required by Regulatory Guide 1.10, for each of the positions used in production work. These splices are made and tested in strict accordance with the specification, using the same ASTM grade and size of bar spliced in the production work. To qualify, the completed splices must meet the Joint Acceptance Standards for workmanship, visual quality, and minimum tensile strength. A list containing the names of qualified operators and their qualification test results is maintained at the jobsite. The qualified crew was not required to requalify in accordance with Regulatory Guide 1.10.

**3.8A.4 PROCEDURE**

All joints are made in strict accordance with the manufacturer's instruction as presented in Erico Products, Inc. Bulletin RB10M-670, "1970 Cadweld Rebar Splicing," plus the following additional requirements:

- A. A manufacturer's representative, experienced in Cadweld splicing of reinforcing bars, is present at the jobsite at the outset of the work to demonstrate the equipment and techniques used for making quality splices. He is also present for

### HNP-2-FSAR-3

at least the first 50 production splices to observe and verify that the equipment is being used correctly and that quality splices are being obtained.

- B. The splice sleeves, cartridges, asbestos wicking, ceramic inserts, and graphite parts are stored in a clean, dry area with adequate protection to prevent absorption of moisture.
- C. Each splice sleeve is visually examined immediately prior to use to ensure the absence of rust and other foreign material on the inner surface.
- D. The graphite molds are preheated with an oxyacetylene torch to 300°F minimum to drive off moisture immediately prior to use.
- E. Bar ends to be spliced are in good condition with full-size undamaged deformations. The bar ends are power brushed to remove all loose mill scale, rust, concrete, and other foreign material. Prior to power brushing, all water, grease, and paint are removed by heating the bar ends with an oxyacetylene or propane torch.
- F. A permanent line, marked 12 in. back from the end of each bar, serves as a reference point to confirm that the bar ends are properly centered in the splice sleeve.
- G. Immediately before the splice sleeve is placed into final position, the previously cleaned bar ends are preheated with an oxyacetylene or propane torch to ensure complete absence of moisture.
- H. Special attention is given to maintaining the alignment of sleeve and guide tube to ensure a proper fill.
- I. When the temperature is below freezing or the relative humidity is above 65%, the splice sleeve is externally preheated with an oxyacetylene or propane torch after all materials and equipment are in position.
- J. The reinforcing bar deformations which become engaged in the Cadweld splice are not ground, flame-cut, or altered in any way except for the longitudinal ribs which are ground to a diameter not less than the other bar deformations.
- K. An adequate escape route is provided for gases generated during the casting of horizontal splices. For splices in bars smaller than No. 11, this is done by inserting a hairpin piece of soft twisted wire at the top of the splice between the rebar and the sleeve.
- L. The packing material at the ends of the horizontal splices and at the top of the vertical splices is not hard packed. The material is firmly in place but loose enough to allow the escape of gases.



### **3.8A.5      ONSITE USER TESTS**

The onsite user test program for reinforcing steel splices is described below:

- A. Every operator is required to pass a qualification test.
- B. All splices are visually inspected. As indicated in section 3.8A.7 of this supplement, unsatisfactory splices are replaced.
- C. For each crew, after qualification, tests are made for each position as follows:

#### **Sister Splice Program**

The following tensile program is used:

- One out of the first lot of 10 production splices for each position, bar size, and grade of bar.
- One production splice and 3 "sister splices" from the next 90 splices for each position, bar size, and grade of bar.
- Three splices out of the next and subsequent lots of 100 splices for each position, bar size, and grade of bar; one-fourth of these splices from production splices and three-fourths from "sister splices."

A "sister splice" is defined as a 3-ft-long test bar spliced in sequence with, and in an otherwise identical manner as, the production splices.

### **3.8A.6      JOINT ACCEPTANCE STANDARDS**

The following criteria are used for judging the acceptability of Cadweld joints:

- A. Sound nonporous filler metal must be visible at both ends of the splice sleeve and at the tap hole in the center of the splice sleeve. Filler metal, which is usually recessed 1/4 in. from the end of the sleeve due to the packing material, is not considered as poor fill.
- B. Splices which contain slag or porous metal in the riser, tap hole, or at the ends of the sleeves (general porosity) are rejected. A single shrinkage bubble present below the riser is not detrimental and is distinguished from general porosity as described above.
- C. The Cadweld splices, both horizontal and vertical, may contain voids at either or both ends of the Cadweld splice sleeve. At the end of the Cadweld splice sleeves, the acceptable size void for a No. 18 splice does not exceed 3 in.<sup>2</sup> per end of splice sleeve. The area of the void is assumed to be the circumferential length as

## HNP-2-FSAR-3

measured at the inside face of the sleeve multiplied by the maximum depth of wire probe minus 3/16 in.

- D. The average tensile strength of the Cadweld joints is greater than the minimum tensile strength for the particular grade of reinforcing steel as specified in the appropriate ASTM standard. The minimum strength of the Cadweld joints must be greater than 125% of the specified minimum yield strength for the particular bar. If any of the tested specimens failed, two additional random splices of the same lot were tested, and if both passed the test, the lot was accepted. If one or both failed, the entire lot was rejected. This criterion is more conservative than the one described in Regulatory Guide 1.10.

### **3.8A.7    REPAIRS**

Joints which do not meet the quality acceptance standards of section 3.8A.6 are rejected and completely removed. The bars are then rejointed with a new splice.

## **SUPPLEMENT 3.8B**

### **PLANT-UNIQUE ANALYSIS OF MARK I CONTAINMENT SYSTEM**

#### **3.8B.1 INTRODUCTION**

The Hatch Nuclear Plant Unit 2 (HNP-2) containment system is one of the first-generation General Electric (GE) boiling water reactor (BWR) nuclear steam supply systems (NSSSs) housed in a containment structure designated as the Mark I containment system. The original design of the Mark I containment system considered postulated accident loads previously associated with containment design, which included pressure and temperature loads associated with a loss-of-coolant accident (LOCA), seismic loads, dead loads, jet-impingement loads, hydrostatic loads due to water in the suppression chamber, overload pressure test loads, and construction loads. However, since the establishment of the original design criteria, additional loading conditions have been identified that arise in the functioning of the pressure-suppression concept utilized in the Mark I containment system. These additional loads result from the dynamic effects of drywell air and steam being rapidly forced into the suppression pool (torus) during a postulated LOCA and from suppression pool response to safety relief valve (SRV) operation generally associated with plant transient operating conditions. Because these hydrodynamic loads were not considered in the original design of the Mark I containment system, the Nuclear Regulatory Commission (NRC) determined that a detailed reevaluation of the Mark I containment system was required.

A two-phase program was identified in the NRC in May 1975. The first-phase effort, called the Short-Term Program (STP), provided a rapid assessment of the adequacy of the containment to maintain its integrity under the most probable course of the postulated LOCA. Thus, the first phase demonstrated the acceptability of continued operation during the performance of the second phase, called the Long-Term Program (LTP). In the LTP, detailed testing and analytical work was performed to define the specific design loads against which the containment was assessed to establish conformance to established acceptance criteria.

The STP was completed in July 1977 following the docketed submittal by Georgia Power Company (GPC) to the NRC of the HNP-2 plant unique analysis report.<sup>(1)</sup> Reevaluation of the Mark I containment system (LTP) was completed in September 1983, following the docketed submittal by Georgia Power Company to the NRC of the HNP-2 Plant Unique Analysis Report (PUAR).<sup>(2)</sup>

#### **3.8B.2 PLANT UNIQUE ANALYSIS REPORT**

The Mark I containment system reevaluation results are detailed in the PUAR submitted to the NRC in September 1983 and revised in December 1989. (See Reference 2). Many of the analyses presented in Reference 2 assumed a 95°F initial suppression pool temperature. Reference 3 documents the acceptability of the Reference 2 analyses at higher initial pool temperature ( $\leq 110^\circ\text{F}$ ). The PUAR demonstrates that the configuration of the plant, including structural modifications and load mitigation devices, meets the NRC requirements for the Mark

## HNP-2-FSAR-3

I LTP as documented in the Mark I containment Long-Term Program Safety Evaluation Report, NUREG-0661.<sup>(4)</sup>

In summary the report provides the following:

- A review of the event sequences involving the Mark I containment system related phenomena for the postulated LOCA and safety relief valve (SRV) actuation conditions.
- A description of the major structural components of the HNP-2 containment system that were evaluated. The description includes both before and after status structural modifications.
- A review of the design criteria used, which includes both the design specification covering the fabrication and erection of the modifications and the structural acceptance criteria applying to the design analysis.
- A discussion of the system changes/additions made to the containment system to mitigate loads.
- A description of the loads and load combinations as applied in the HNP-2 analysis.
- A review of the computer programs used in the analysis.
- A summary of the analytical methods and models employed in evaluating each of the structural components.
- A summary of the analytical results for each structural component and a comparison with allowables, based on the structural acceptance criteria that demonstrate that the upgraded design-safety margins have been achieved.

### **3.8B.3 DESCRIPTION OF LTP MODIFICATIONS**

The components significantly affected by the postulated LOCA and SRV actuation events are the suppression chamber, vent system, torus internal structures, SRV piping and supports, and the torus-attached piping and supports. Detailed analysis of the components determined that structural modifications and system changes were required to establish the NRC design safety margins specified for the Mark I LTP. Table 3.8B-1 presents a summary of the LTP modifications to the HNP-2 containment system. The modifications are in addition to the STP changes summarized in Appendix A of the PUAR.<sup>(2)</sup>

### **3.8B.4 EXPANDED OPERATING DOMAIN OPERATION**

*A containment loads analysis was performed to demonstrate that ample margins for containment integrity remain for plant operation in the expanded operating domain (EOD) at the maximum core inlet*

subcooling condition which was 100% of original rated power (2436 MWt) and 87% flow with reduced feedwater temperature. This analysis<sup>(5)</sup> which evaluated the containment pressure and temperature response and the containment hydrodynamic loads for a postulated design basis LOCA, was based on the methodology developed for the Mark I Long-Term Containment Program and documented in the Mark I Containment Program Load Definition Report.<sup>(6)</sup> The results of this analysis showed that the peak containment pressure in the EOD with reduced feedwater temperature was 46.7 psig which was higher than the value reported in NEDO-24569<sup>(7)</sup> of 43.0 psig, but below the design value of 56 psig and within the design margins shown in the PUAR. The containment hydrodynamic loads with EOD conditions were also within the design margins shown in the PUAR. The results of analysis and evaluations for the effect of power uprates up to a licensed 100% RTP of 2804 MWt on containment loads including operation in the EOD are discussed in subsection 3.8B.5.

### **3.8B.5 POWER UPRATE OPERATION**

A containment loads analysis was performed for extended power uprate conditions to assure adequate margins existed for operation at 2763 MWt. The results, summarized in reference 9, were acceptable. The containment system performance analysis included short- and long-term pressure and temperature responses, LOCA containment dynamic loads, and SRV containment dynamic loads. The analyses included the EOD for a core power of 2763 MWt and final feedwater temperature operation. The effect on containment loads was subsequently evaluated in reference 10 to support operation at 2804 MWt and in references 11 and 12 for an increase in reactor operating pressure to 1060 psia. The evaluations indicate that containment loads increase slightly due to the operating pressure increase but remain acceptable. The evaluation for the pressure increase showed that the peak containment pressure in the EOD for a core power of 2804 MWt with reduced feedwater temperature (see section 6.2) is 50.1 psig, which is below the 56 psig design limit.

### **3.8B.6 OPERATION DURING PERIOD OF EXTENDED OPERATION**

An analysis of the cumulative fatigue usage factor (CFUF) for the torus shell was performed to account for the period of extended operation. (See subsection 18.1.1 for a definition of the term "period of extended operation.") This analysis demonstrated the need to track actual thermal and dynamic loading events to ensure the torus shell maintains an actual CFUF  $\leq$  1.0 through the period of extended operation. The most limiting event for the torus is the steam blowdown resulting from the lifting of one or more main steam safety relief valves. The component cyclic or transient limit program (subsection 18.2.12) performs tracking of operational events. The CFUF analysis is a time-limited aging analysis and is described in section 18.5

## HNP-2-FSAR-3

### REFERENCES

1. "Structural Evaluation of Pressure Suppression System for E. I. Hatch Nuclear Plant-Unit 2, Mark I Containment," Bechtel Power Corporation, Docket No. 50-366, July 1977.
2. "Plant Unique Analysis Report for E. I. Hatch Nuclear Plant-Unit 2, Mark I Containment Long-Term Program," Bechtel Power Corporation, Revision 2, Docket No. 50-366, December 1989.
3. "Elimination of the Suppression Pool Temperature Limit for Plant Hatch Units 1 and 2," EAS-19-0388, General Electric Company, March 1988.
4. "Safety Evaluation Report Mark I Containment Long-Term Program," NUREG-0661, U. S. Nuclear Regulatory Commission, July 1980.
5. "Limiting Reload Licensing Events for E. I. Hatch Nuclear Plant Unit 1 and Unit 2," EAS-65-1088, General Electric Company, October 1988.
6. "Mark I Containment Program Load Definition Report," Revision 2, NEDO-21888, General Electric Company, November 1981.
7. "Mark I Containment Program Plant Unique Load Definition: Unit 2," NEDO-24569, General Electric Company, September 1981.
8. "Power Uprate Safety Analysis Report for Edwin I. Hatch Plant Units 1 and 2," NEDC-32405P, General Electric Company, December 1994.
9. "Extended Power Uprate Safety Analysis Report for Edwin I. Hatch Plant Units 1 and 2," NEDC-32749P, General Electric Company, July 1997.
10. "Safety Analysis Report for Edwin I. Hatch Units 1 and 2 Thermal Power Optimization," NEDC-33085P, GE Nuclear Energy, December 2002.
11. "10-PSI Dome Pressure Increase Project Report for Edwin I. Hatch Units 1 and 2," GE-NE-0000-0003-0634-01, Revision 1, GE Nuclear Energy, July 2003.
12. RER 03-254, Reactor Operating Pressure Increase From 1050 psia to 1060 psia, Engineering Evaluation.

**TABLE 3.8B-1 (SHEET 1 OF 2)**

**LTP MODIFICATION SUMMARY**

| <u>Component Category</u> | <u>Modification Description</u>                                                                                                                                                                                                                                                                                                                                                                                                                              |
|---------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Torus                     | Addition of shell T-stiffeners<br><br>Addition of stiffeners to existing saddle supports                                                                                                                                                                                                                                                                                                                                                                     |
| Vent system               | Addition of vent header deflectors under vent header in the non-vent bays<br><br>Modification of existing downcomer ties<br><br>Addition of stiffener plates to downcomer-vent header intersection<br><br>Addition of stiffener plates to vent header intersection at vacuum breaker locations<br><br>Addition of stiffener plates to vent lines at the SRV line penetration locations<br><br>Addition of pipe braces to existing vacuum breaker drain lines |
| Internal structures       | Modification of catwalk inside torus<br><br>Modification of monorail inside torus                                                                                                                                                                                                                                                                                                                                                                            |
| SRV piping                | Addition of T-quencher discharge devices inside torus<br><br>Addition of vacuum breakers to low-low set (LLS) SRV discharge lines (SRVDLs)                                                                                                                                                                                                                                                                                                                   |
| SRV piping supports       | Addition of T-quencher supports<br><br>Support beams<br>Beam supports<br>Gusset plate reinforcing<br><br>SRV line M intermediate support<br><br>Addition/modification of SRVDL supports inside drywell                                                                                                                                                                                                                                                       |

HNP-2-FSAR-3

**TABLE 3.8B-1 (SHEET 2 OF 2)**

| <u>Component Category</u>                      | <u>Modification Description</u>                         |
|------------------------------------------------|---------------------------------------------------------|
| Torus attached piping and support inside torus | Addition of elbows to RHR test lines                    |
|                                                | Modification to return line restraints                  |
|                                                | Removal of spare piping - X227A                         |
| Suppression pool temperature monitoring        | Addition of thermowells and half couplings              |
| SRV logic change                               | Main steam isolation valve isolation logic level change |
|                                                | SRV LLS logic                                           |



**SUPPLEMENT 3.8C**

**DESIGN CRITERIA FOR REEVALUATION  
OF CONCRETE MASONRY WALLS**

**3.8C.1 GENERAL**

**3.8C.1.1 PURPOSE**

Provided in supplement 3.8C are the design requirements and criteria used to reevaluate the structural adequacy of concrete block walls as required by the Nuclear Regulatory Commission (NRC) I&E Bulletin 80-11, Masonry Wall Design (May 8, 1980).

**3.8C.1.2 SCOPE**

The reevaluation determined whether the concrete masonry walls would perform their intended function under all postulated loads and load combinations. Concrete masonry walls not supporting safety systems but whose collapse could result in the loss of required function of safety-related equipment or systems were evaluated in the same manner as walls that support safety systems. Verification of wall adequacy included support condition, global response of wall, and local transfer of load. Evaluation of anchor bolts and embedments was not considered to be within the scope of I&E Bulletin 80-11.

**3.8C.2 GOVERNING CODE**

The American Concrete Institute (ACI) Building Code Requirements for Concrete Masonry Structures (ACI 531-79) was used as the basis for structural reevaluation. Supplemental allowables for cases not directly covered in the governing code are specified in this supplement.

**3.8C.3 LOADS AND LOAD COMBINATIONS**

Loads and load combinations are as specified in the Final Safety Analysis Report (FSAR) for concrete design. Load factors consistent with FSAR requirements were applied to all loads in all postulated load combinations.

Masonry walls were designed to withstand dead loads, live loads and both operating basis earthquake (OBE) and design basis earthquake (DBE) loads. The walls are not subjected to other loads such as wind, tornadoes, missiles, pipe whips, jet impingement, or differential pressure. All walls are nonload bearing and are not included in the overall building shear wall system.

The walls are relied upon to act only as interior partition walls or to provide shielding. During normal operation or seismic events, the walls are not subjected to extreme thermal loads. The

walls were originally designed to provide a specified fire rating; therefore, it is assumed that the walls will not fail under thermal loads.

### **3.8C.4 DESIGN ALLOWABLES**

For walls subjected to normal unfactored dead loads, live loads, and OBE loads, the design allowables are as follows:

A. Masonry

Allowable values for tension, compression, shear, bond, and bearing stresses are those given in ACI 531-79.

B. Core Concrete Or Cell Grout

Values used for stress in core concrete were the same as allowables for concrete given in ACI 318. The allowable tension stress is given as  $2.5 \sqrt{f'_c}$ . This value is stated as having a safety factor of 3.

C. Reinforcing Steel

The allowable values for tension and compression stresses are those given in Section 10.2, ACI 531-79.

D. Seismic Loads

Consistent with FSAR guidelines, the 33% increase in allowable stresses for masonry and reinforcing steel due to OBE loads is not permitted.

E. Collar Joints

Multiple Wythe walls are assumed to act independently under earthquake loads.

Design allowables for load combinations that include factored loads and/or DBE loads are as follows:

A. Masonry

The allowable masonry stresses are 1.67 times the values given in A and B above.

## HNP-2-FSAR-3

### B. Reinforcing Steel

The allowable steel stresses are  $0.9 f_y$ , provided that lap splice lengths and embedment can develop a stress level equal to this value. To determine splice and anchorage requirements, allowable bond stresses may be increased by 1.67 in calculations.

The damping values used for uncracked sections are as follows:

- A. For OBE analysis, a 3% value of critical damping is used.
- B. For DBE analysis, a 5% value of critical damping is used.

The damping values used for cracked sections are as follows:

- A. For OBE analysis, a 3% value of critical damping is used.
- B. For DBE analysis, a 5% value of critical damping is used.

The extreme tensile fiber stress for use in determining the lower-bound uncracked moment capacity is  $6 \sqrt{f'_c}$  for core concrete or cell grout and 2.4 times the code allowable flexural tensile stress for masonry.

### **3.8C.5 ANALYSIS AND DESIGN**

#### **3.8C.5.1 GENERAL**

- A. The concrete masonry structures were analyzed according to working stress principles using factored loads.
- B. The walls were designed, in general, to span horizontally in accordance with the original design. Walls were also designed to span vertically or for two-way action on a case-by-case basis.
- C. Consistent with FSAR criteria, concrete columns, pilasters, and walls framing into the wall under consideration are taken as rigid supports under seismic loading.
- D. Section properties are based on actual masonry unit dimensions rather than on nominal sizes.

**3.8C.5.2 STRUCTURAL RESPONSE OF MASONRY WALLS****A. Equivalent Moment of Inertia**

To determine the out-of-plane frequencies of masonry walls, the uncracked behavior and capacities of the walls (step 1) and, if applicable, the cracked behavior and capacities of the wall (step 2) were considered.

**Step 1 - Uncracked Condition**

The equivalent moment of inertia of an uncracked wall is obtained from a transformed section consisting of the block, mortar, cell grout, and core concrete. Alternatively, the cell grout and core concrete (neglecting block and mortar on the tension side) may be used.

**Step 2 - Cracked Condition**

If the applied moment ( $M_a$ ) due to all loads in a load combination exceeds the uncracked-moment capacity, the wall is considered to be cracked. In this event, the equivalent moments of inertia are computed as follows:

$$I_e = \left( \frac{M_{cr}}{M_a} \right)^3 (I_t) + \left[ 1 - \left( \frac{M_{cr}}{M_a} \right)^3 \right] I_{cr}$$

$$M_{cr} = f_r \left( \frac{I_t}{y} \right)$$

where:

$I_e$  = equivalent moment of inertia.

$M_{cr}$  = uncracked-moment capacity.

$M_a$  = applied maximum moment on the wall.

$I_t$  = moment of inertia of the transformed section.

$I_{cr}$  = moment of inertia of the cracked section.

$f_r$  = modulus of rupture (2.4 times the allowable flexural tensile stress for masonry).

$y$  = distance of neutral plane from tension face.

## HNP-2-FSAR-3

If the use of  $I_e$  results in an applied moment  $M_a$  which is less than  $M_{cr}$ , then the wall is verified for  $M_{cr}$ .

### B. Modes of Vibration

A parametric study concluded that, under all boundary conditions and aspect ratios tested, the first mode of vibration accounted for over 99% of the total moment and displacement of the walls. The effect of the first 3 modes was considered in the analysis, and was assumed to contribute ~ 100% of the total moment and displacement.

### C. Frequency Variations

Uncertainties in structural frequencies of the masonry walls because of variations in structural properties and mass were taken into account. Significant variables include mass, boundary conditions, modulus of elasticity, extent of cracking, vertical load, in-plane and out-of-plane loads, and two-way action. Because of these uncertainties, the effect of variations was considered. It is considered conservative to use the lower-bound frequency if it is on the higher-frequency side of the response spectrum peak; however, if the lower-bound frequency is on the lower side of the peak, the peak acceleration is used if a more detailed analysis was not performed.

### D. Selection of Appropriate Response Spectra

The seismic acceleration at each frequency is the greater number from the response spectra of the floor above or the floor below the wall for all walls except simple cantilevers. The response spectra for the lower floor was used for cantilever walls.

Since portions of the control building are shared by both HNP-1 and HNP-2, the response spectra for HNP-2 were used for initial analyses since the accelerations are greater at each frequency in the HNP-2 spectra. However, if more detailed analyses were required, the response spectra used in the original design were used.

## 3.8C.5.3 STRUCTURAL STRENGTH OF MASONRY WALLS

### A. Boundary Conditions

The walls were designed as either one-way or two-way spans with either free, simply supported, or fixed edges. A simple support was assumed when the joint was capable of shear transfer under all loading conditions. Fixed support conditions were assumed when the joint was capable of flexural tensile stress transfer to the support under all loading conditions.

B. Application of Concentrated Out-of-Plane Loads

One-Way Bending

Out-of-plane loads are applied as point loads on a beam strip equal in width to two times the wall thickness. Local moments are determined by using beam theory and taking into account both in-plane and out-of-plane loads.

Two-Way Bending

On a case-by-case basis, two-way action may be considered. For these cases, conservative analysis techniques are employed with all out-of-plane loads and openings being considered in the seismic analysis.

C. Interstory Drift Effects

Interstory drift effects are derived from the original dynamic analysis. Adequacy of the walls with regard to in-plane drift effects are based on a strain criteria that are based on experimental and analytical results for walls cyclically loaded to failure. The strain criteria apply for all confined nonstructural walls. A nonstructural wall is defined as follows:

1. A nonstructural wall does not carry a significant part of the story shear or moment.
2. A nonstructural wall does not significantly modify the behavior of adjacent structural elements.

In other words, the behavior of the structure must be substantially the same whether such walls are present or not.

A conservative value to use for acceptable levels of strain for confined masonry is 0.001 in./in. For a wall 17 ft in height, the allowable story drift is 0.204 in.

D. Stress Calculations

All stress calculations are performed by conventional methods prescribed by the Working Stress Design Method.

E. Analytical Techniques

In general, classical design techniques were used in the evaluation. Refined methods utilizing computer analyses or dynamic analyses were also used on a case-by-case basis.

### **3.8C.6 JUSTIFICATION OF SELECTED ITEMS IN DESIGN CRITERIA**

#### **3.8C.6.1 PURPOSE**

The purpose of this subsection is to justify and elaborate on certain selected items contained within the criteria. It is not an attempt to present all the background information that was analyzed in an effort to arrive at a consistent, structurally sound criteria for the reevaluation of existing concrete masonry walls, but is instead a summary of items upon which certain portions of the criteria are based.

#### **3.8C.6.2 DAMPING**

Accelerations at the boundaries of the wall were computed without taking the walls into account. Since the walls are nonstructural, nonload-bearing elements, their presence has no effect on the overall response of the structure. Therefore, the evaluation method for the walls is similar to that used for equipment qualification, and damping values realistic for concrete block walls in general were used. Test data and industry consensus indicates that 3% and 5% damping (for operating basis earthquake (OBE) and design basis earthquake (DBE), respectively) are reasonable for the uncracked case and that 4% and 7% are reasonable for the cracked case. Although the higher damping values are reasonable and conservative for the cracked case, 3% and 5% damping were used for both the cracked and uncracked condition since these spectra were already available. The difficulties and uncertainties involved in obtaining response spectra for higher damping values outweigh the benefits obtained by using the resulting lower spectral accelerations in the analysis.

#### **3.8C.6.3 IN-PLANE ACCEPTANCE CRITERIA**

In-plane effects may be imposed on masonry walls by the relative displacement between floors during seismic events. However, nonstructural walls are not considered to carry a part of the associated story shear; and any portion which they might carry, determined by their stiffness, is extremely difficult to define. In addition, since the experimental evidence demonstrates that the apparent in-plane strength of masonry walls depends heavily upon the in-plane stress boundary conditions, load or stress on the walls is not a reasonable basis for acceptance criteria.

However, examination of the test data indicates that the gross shear strain of a wall is a reliable indicator for predicting the onset of significant cracking. A significant crack is considered to be a crack in the central portion of the wall extending at least 10% of the wall's width or height. Cracking along the interface between a block wall and adjacent concrete members does not limit the integrity of the wall unless it affects boundary conditions for out-of-plane analysis, and was not considered when examining available test data.

Because of the absence of test data that examined the behavior of masonry walls subjected to simultaneous in-plane and out-of-plane behavior, no general acceptance criteria for the coupled condition were established. Instead, the criteria for in-plane effects are conservative so that a reasonable margin remains for out-of-plane loading. However, boundary condition

requirements, as specified in the acceptance criteria, must be met before that boundary condition may be assumed for out-of-plane loading, even with the existence of a crack along the interface of the wall and adjacent concrete members.

Test data indicate that for confined masonry (supported on the bottom and two sides) significant cracking is initiated at strains in excess of  $\sim 0.001$  in./in. Reinforcing and grout have no effect on this value. The data also show that this strain level is not sensitive to the magnitude of the initially applied vertical load. Since all masonry walls at Plant Hatch meet the criteria for confined walls, the question of shear strain allowables for unconfined walls was not addressed.

For width to height ratios of 0.5 to 2.5, an excellent correlation has been found between a nonlinear analysis of an equivalent diagonal strut and available test data in predicting the onset of significant cracking. Dividing the predicted strain level (using the equivalent strut method) by two, gives a value for allowable strain of  $\sim 0.001$  in./in. Available test data indicate that this value provides a sufficient margin for out-of-plane loading.

#### **3.8C.6.4 OUT-OF-PLANE DRIFT EFFECT**

The internal wall moments due to deflections caused by out-of-plane interstory drift were determined for each wall height, location, and orientation and compared to the ultimate allowable moment for each wall. In all cases, calculated moments were found to be less than allowables.

#### **3.8C.6.5 ALLOWABLE STRESSES**

Most available test data were analyzed to obtain reasonable allowable stresses for masonry, grout, and reinforcing for different loadings and types of stress. For areas where no test data were available to back up chosen values, conservative engineering judgment was used.

Using test data results utilizing materials, height-to-thickness ratios, and loadings appropriate for the walls under consideration, values presented in the criteria for axial compression have a safety factor of 3 for 93% of all walls tested. A 1.67 increase for DBE still leaves a safety factor of 1.8 for 93% of all walls tested. Assuming that masonry can develop 85% of its specified compressive strength at any section,<sup>(a)</sup> the value given for flexural compression has a safety factor of 2.6 at the worst-case extreme fiber of the unit.

Values for bearing stress allowables were based on test data used in determining values in the American Concrete Institute code. These values are less than allowed by the ATC-3-06 provision.

---

a. This is an assumption practiced for many years.



Comparison of results from recent extensive tests evaluating the shear strength of concrete block walls, with values for shear stress allowables presented in the acceptance criteria, yields the following safety factors:

|                  |             |
|------------------|-------------|
| Unfactored loads | 2.0 to 3.0  |
| Factored loads   | 1.2 to 1.76 |

Ductility associated with walls subjected to stress levels in the range of factored loads near maximum permissible levels provides an added safety factor.

Allowable reinforcing stresses in reinforced concrete masonry walls are the same as for reinforced concrete and have the same safety factors.

All multiple-Wythe walls are designed as single-Wythe walls. That is, the allowable tension and shear stresses for collar joints are assumed to be zero.

### **3.8C.7 COMPUTER REEVALUATION OF REINFORCED CONCRETE MASONRY WALLS**

#### **3.8C.7.1 INTRODUCTION**

The fortran computer code BLOCK WALLS was developed to analyze block walls for axial load and flexural effects due to external and/or seismic loading. The block wall was analyzed as a simplified three-degree-of-freedom beam model. The modal analysis technique was used in conjunction with the response spectrum method to obtain the seismic response of the wall model. An iterative method was used to determine the actual stress and section properties (effective moment of inertia) of a wall section. Convergence criteria were established to verify that the assumed section condition results in the same inertial loading for two successive iterations.

The working stress method for concrete analysis was used for stress calculations. Finally, the calculated stresses were checked against the established allowables.

##### **3.8C.7.1.1 Determination of Section State (Cracked Versus Uncracked) - Iteration Procedure**

- A. For the first iteration, the wall was assumed to be uncracked.
- B. As a result of A above and based on the calculated inertial forces, the section was checked for cracking.
- C. If cracked conditions existed, an effective moment of inertia was determined using the following American Concrete Institute (ACI) formula:

$$I_e = \left(\frac{M_{cr}}{M_a}\right)^3 (I_t) + \left[1 - \left(\frac{M_{cr}}{M_a}\right)^3\right] I_{cr}$$

$$M_{cr} = f_r \left(\frac{I_t}{y}\right)$$

where:


- $M_{cr}$  = uncracked-moment capacity.
- $M_a$  = applied maximum moment on the wall.
- $I_t$  = moment of inertia of the transformed section.
- $I_{cr}$  = moment of inertia of the cracked section.
- $f_r$  = modulus of rupture.
- $y$  = distance of neutral plane from tension face.

- D. A new iteration was initiated to recompute the frequencies, mode shapes, and modal participation factors.
- E. The procedure was repeated until convergence was achieved.

### 3.8C.7.1.2 Seismic Analysis

The wall was represented by a three-degree-of-freedom simplified beam model. A response spectrum analysis was performed yielding the inertial loading to be imposed on the system.

The four types of end conditions allowed for the beam model that was used to perform the analysis are shown schematically below:



### 3.8C.7.1.3 Stress and Deflection Calculations

The stress calculations were performed for the final configuration of the section using working stress methods. Based on inertial loads, applied external loads, and the computed section stiffness, the beam model deflection was determined.


### 3.8C.7.1.4 Governing Codes

- ACI 531-79 and commentary.
- Uniform Building Code, 1970 edition.
- Other codes as specified.

## 3.8C.7.2 ANALYTICAL PROCEDURE

### 3.8C.7.2.1 Block-Wall Stress Calculation

The governing equations for block-wall stress calculations were developed using a working stress approach.



The section properties were calculated based on a transformed section with the block material as a base. The standard concrete analysis equilibrium concept is as follows:

$$\Sigma \text{ FORCES} = 0 \text{ or tension} = \text{compression}$$

$$\Sigma \text{ Moment} = M = \text{section internal moment}$$

The following equations for stress calculation for bending were obtained:

Case A - Uncracked section

$$\begin{aligned} f_{MB} &= (M/I_{UCR}) \times Y_{CU} \\ f_{ST} &= NSM \times (M/I_{UCR}) \times (Y_{TU}-DS) \\ f_{SC} &= NSM \times (M/I_{UCR}) \times (Y_{CU}-DP) \end{aligned}$$

Case B - Cracked section

$$\begin{aligned} f_{MB} &= (M/I_{CR}) \times Y_{CCR} \\ f_{ST} &= NSM \times (M/I_{CR}) \times (Y_{TCR}-DS) \\ f_{SC} &= NSM \times (M/I_{CR}) \times (Y_{CCR}-DP) \end{aligned}$$

For both Case A and Case B, the axial compression stresses were calculated and interaction was checked.

$$(f_{MA}/F_{MA}) + (f_{MB}/F_{MB}) \leq 1.0$$

For axial tension, it was assumed that only the reinforcing steel carries the tension.

The definitions of the variables used in the above equations are:

- M = bending moment.
- F<sub>MB</sub> = allowable masonry compressive stress due to bending.

### HNP-2-FSAR-3

- FMA = allowable masonry compressive stress due to axial force.  
fMB = masonry compressive stress due to bending.  
fMA = masonry compressive stress due to axial force.  
IUCR = uncracked moment of inertia.  
ICR = cracked moment of inertia.  
YCU = distance to extreme fiber in compression (uncracked).  
YTU = distance to extreme fiber in tension (uncracked).  
YCCR = distance to extreme fiber in compression (cracked).  
YTCR = distance to extreme fiber in tension (cracked).  
AC = transformed compressive area of section.  
NSM = modular ratio for steel.

#### 3.8C.7.2.2 Eigenvalue Solution and Response Calculation

The following two matrices were determined based upon boundary conditions and structural properties:

$$\begin{aligned}\text{Flexibility matrix} &= [\mathbf{F}] \\ \text{Mass matrix} &= [\mathbf{M}]\end{aligned}$$

Calculate transformation matrix

$$[I M^* I] = [I M I^{-1/2}]$$

Using Gauss elimination technique with column pivoting, calculate the structural stiffness matrix:

$$[\mathbf{k}] = [\mathbf{F}^{-1}]$$

Calculate transformed stiffness matrix  $[\bar{\mathbf{k}}]$  such that:

$$[\bar{\mathbf{k}}] = [I M^* I][\mathbf{k}][I M^* I]^T$$

## HNP-2-FSAR-3

Tridiagonalize  $[\bar{k}]$  using Householder's method, and evaluate the characteristic value equation:

$$[\bar{k}](\Phi_i) + W_i^2(\Phi_i) = 0$$

Calculate eigenvalues using Sturm sequence on the tridiagonal matrix.

Calculate eigenvectors using Wilkinson's method on the tridiagonal matrix.

( $W_i$ ) are the eigenvalues for the untransformed stiffness matrix  $[k]$ . Calculate the frequencies:

$$f_i = W_i / 2\pi$$

Eigenvectors  $\{\Phi_i\}$  must be transformed into the vectors  $\{\Phi_i\}$  of the untransformed matrix:

$$\{\Phi_i\} = [M^{-1}]\{\Phi_i\}$$

Compute modal participation factors:

$$(R_i) = \sum_j^n 1[\Phi_{ij}]^T [M_{ij}]$$

The modal values of the inertia forces  $\{P\}_i$  at the dynamic degrees of freedom for the  $i^{\text{th}}$  mode were given by:

$$\{P\}_i = (R_i)(a_i)[M]\{\Phi_i\}$$

$R_i$  = participation factor for the  $i^{\text{th}}$  mode.


$a_i$  = acceleration for the  $i^{\text{th}}$  mode.

$\{\Phi_i\}$  = mode shape for the  $i^{\text{th}}$  mode.


Using the calculated inertial loads and the seismic moments, the shear and corresponding deflection were calculated using the "square root of the sum of the squares" (SRSS) method since the modes were not closely spaced.

3.8C.7.3 COMPUTER PROGRAM

3.8C.7.3.1 Flow Chart of the Block Wall Program



### HNP-2-FSAR-3



#### 3.8C.7.3.2 Hand Calculation for Computer Verification

Two core masonry units were assumed to be 44% solid by volume with running bond. Nominal thickness is 12 in., with two 5 vertical reinforcing bars at 16-in. spacing. Exact dimensions were:

11 5/8 in. x 7 5/8 in. x 15 5/8 in.,  
 $t_s = 1.25$  in.,  $t_w = 1.12$  in.



HNP-2-FSAR-3

A. Uncracked Section Properties

Transform all materials to block material:

$$n_1 = \frac{\text{steel } E_s}{\text{block } E_m} = \frac{29 \times 10^6}{1 \times 10^6} = 29$$

$$n_2 = \frac{\text{grout } E_c}{\text{block } E_m} = \frac{1.4 \times 10^6}{1.0 \times 10^6} = 1.4$$

Tensile steel area

$$A_s = 0.31 \text{ in.}^2$$

Tension steel cover


$$D_s = 3.375 \text{ in.}$$

Thickness of the wall


$$H = 11.625 \text{ in.}$$

Effective width of beam

$$b_{\text{eff}} = 15.625 \text{ in.}$$



Assumed Section




Transformed Section

$$\text{Uncracked moment of inertia} = I_t = 1096.2 \text{ in.}^4$$

HNP-2-FSAR-3

B. Cracked Section Properties



Cracked moment of inertia =  $I_{cr} = 326.7 \text{ in.}^4$

C. Calculation of Effective Area (Axial and Shear)


Reference ACI Code 531-79.

$$\text{AXIAL} = 2(1.12 + 6.1325 + 1.12) 1.25 + (9.125 \times 1.12) 3 + (6.1325 \times 9.125) \times 1.4 + 2 \times (6.1325 + 1.12) = 144.4 \text{ in.}^2$$

D. Calculation of Shear Area

Reference ACI Code 531-79.

$$\text{ASHEAR} = (11.625 - 3.875) 1.12 \times 3 + 2 \times (6.1325 + 1.12) + 1.4 (11.625 - 3.875 - 1.25) 6.1325 = 26.04 + 15.33 + 55.8 = 97.2 \text{ in.}^2$$



NOTE:

The above calculations are for uniform inertia loadings.

## HNP-2-FSAR-3

### E. Dynamic Inertia Loading

For a 12-in. wall grouted at 16 in. on center, the average weight of a completed wall is 111 lb/ft<sup>2</sup>.

$$\text{Weight/unit length} = \frac{111 \times 16}{144} = 12.3 \text{ lb/in.}$$

$$f = \frac{\pi}{2(L)^2} \sqrt{\frac{EIg}{A\gamma}} = \frac{\pi}{2(240)^2}$$

$$\sqrt{\frac{1.6 \times 10^4 \times 1096.2 \times 386.4}{12.3}} = 5.98 \text{ Hz}$$

$$\text{Acceleration} = 0.28 \text{ g}$$

$$\begin{aligned} \text{Inertia loading intensity } W_i &= \text{acceleration times weight/unit length} \\ &= 0.28 \times 0.0123 \end{aligned}$$

$$\text{Seismic moment} = \frac{(0.28 \times 0.0123)(240)^2}{8} = 24.79 \text{ in. - kips}$$

### F. Determination of Maximum Bending Stress

$$\text{Tension} = \frac{29 \times 24.79 \times (7.846 - 2.62)}{326.75} = 11.5 \text{ ksi}$$

$$\text{Compression} = \frac{(24.79 \times 2.528)}{326.75} = 0.192 \text{ ksi}$$

## HNP-2-FSAR-3

### 3.8C.7.3.3 Computer Calculation

```
****BLOCK WALLS PROGRAM****  
**** VERSION 6 2/12/81
```

```
*****  
* *  
* UNITS KIPS INCHES *  
* *  
*****
```

```
INPUT PROBLEM TITLE (UP TO 10 CHARACTERS)  
>EXAMPLE
```

```
DEFINE INITIAL CONDITION OF SECTION
```

```
IF NO EXTERNAL LOAD APPLIED TYPE 0  
IF EXTERNAL LOAD IS APPLIED TYPE 1  
>0
```

```
INPUT SECTIONS PROPERTIES AS,ASP,DS,DP,H,L,BEFF,HEIGHT IN.  
>.31,,2.62,,12.,240.,15.6,240.
```

```
INPUT IUCR,ICR,YCU,YTU,YCCR,YTCR,AAXIAL,ASHEAR,AC  
WHERE: IUCR=UNCRACKED INERTIA  
ICR=CRACKED INERTIA  
YCU=DIST. TO EXTREME FIBER IN COMP.(UNCRACKED)  
YTU=DIST. TO EXTREME FIBER IN TENSION (UNCRACKED)  
YCCR=DIST. TO EXTREME FIBER IN COMP.(CRACKED)  
YTCR=DIST. TO EXTREME FIBER IN TENSION(CRACKED)  
AAXIAL=EFFECTIVE AXIAL AREA  
ASHEAR=EFFECTIVE SHEAR AREA  
AC=TRANSFORMED COMPRESSIVE AREA OF SECTION  
>1096.22,326.74.4.84,5.535.2.528,7.846,144.4,97.2,34.8
```

### HNP-2-FSAR-3

INPUT YOUNG MODULUS , AVERAGE WT. PER UNIT LENGTH AND MODULAR RATIOS  
>1400.,.0123.29.,1.4

INPUT COMP.STRENGTH OF MASONRY , COMP. STRENGTH OF GROUT  
AND YIELD STRENGTH OF REINFORCING STEEL  
>1.,1.8,40.

DEFAULT ALLOWABLE STRESSES ARE ACI 531-79\*\*  
IF ACCEPTABLE TYPE 0  
IF UNACCEPTABLE TYPE 1  
>0

CHECK IF SEISMIC LOADING IS TO BE CONSIDERED  
  
IF OBE SEISMIC CONSIDERATION IS REQUIRED TYPE 1  
IF SSE SEISMIC CONSIDERATION IS REQUIRED TYPE 2  
IF SEISMIC CONSIDERATION IS NOT REQUIRED TYPE 0  
>2

INPUT FLOOR RESPONSE SPECTRUM  
SPECTRUM INPUT IS A 2-D ARRAY DEFINING FREQUENCY INCPS VS ACCELERATION IN 6  
TYPE \*N\* NUMBER OF POINT USED TO DESCRIBE THE CURVE ?  
>8

INPUT 8 SET OF FREQUENCY VS ACCELERATIONS ENTRIES EACH ON A NEW LINE  
>.2,.12  
>1.2,.36  
>2.,2.45  
>2.6,2.45  
>2.8,.75  
>3.5,.75  
>5.99,.28  
>1000.,.28

INPUT ADDITIONAL WEIGHTS AT MASS PTS. 1.2.3  
>0.,0.,0.<sup>2</sup>

# HNP-2-FSAR-3

BOUNDARY CONDITIONS ASSUMED FOR SIMPLIFIED BEAM MODEL

S.S BOTH ENDS TYPE 1  
S.S ONE END FIXED THE OTHER TYPE 2  
BOTH ENDS FIXED TYPE 3  
SIMPLE CANTILEVER TYPE 4

1

\*\*\*\*\*

\*\*\*\* DATA FROM INTERNAL STORAGE\*\*\*\*

\*\*\*\*BLOCK WALLS PROGRAM\*\*\*\*  
\*\*\*\* VERSION 6 2/12/81

\*\*\*\*\*  
\* \*  
\* UNITS KIPS INCHES \*  
\* \*  
\*\*\*\*\*

\*\*\*\* PROB. TITLE: EXAMPLE \*\*\*\*

AS= .31  
H= 12.0

ASP= .00  
L=240.0

\*\*\*\* SECTION PROPERTIES \*\*\*\*  
DS= 2.62 DP= .00  
B= 15.6 D= 7.8

# HNP-2-FSAR-3

\*\*\*INPUT FOR STRESS CALCULATION\*\*\*

IUCR=UNCRACKED INERTIA= 1096.22  
ICR=CRACKED INERTIA\*= 326.74  
YCU=DIST. TO EXTREME FIBER IN COMP.(UNCRACKED)= 4.840  
YTU=DIST. TO EXTREME FIBER IN TENSION(UNCRACKED)= 5.535  
YCCR=DIST. TO EXTREME FIBER IN COMP.(CRACKED)= 2.528  
YTCR=DIST. TO EXTREME FIBER IN TENSION(CRACKED)= 7.846  
AAXIAL=EFFECTIVE AXIAL AREA= 144.40  
ASHEAR=EFFECTIVE SHEAR AREA= 97.20  
AC=TRANSFORMED COMPRESSIVE AREA OF SECTION= 34.80

\*\*\*\* MATERIAL PROPERTIES \*\*\*\*

YOUNG MODULUS= 1400.00  
AVERAGE WT. PER UNIT LENGTH= .01230000  
MODULAR RATIOS= 29.0 1.4  
COMPRESSIVE STRENGTH OF MASONRY= 1.0  
COMPRESSIVE STRENGTH OF GROUT= 1.8  
YIELD OF REINFORCING STEEL= 40.0

\*\* SSE SEISMIC CONSIDERATION FOR THIS PROBLEM \*\*

FLOOR RESPONSE SPECTRUM DEFINITION

| F       | G    |
|---------|------|
| .20     | .12  |
| 1.20    | .36  |
| 2.00    | 2.45 |
| 2.60    | 2.45 |
| 2.80    | .75  |
| 3.50    | .75  |
| 5.99    | .28  |
| 1000.00 | .28  |

ADDITIONAL WEIGHTS AT MASS PTS. ARE:

ADDU1= .000 ADDU2= .000 ADDU3= .000

HNP-2-FSAR-3

\*\*BEAM MODEL IS S.S AT BOTH ENDS\*\*

\*\*\* FREQUENCIES ARE \*\*\*      5.989      23.790      50.511

\*\*\*MODAL PARTICIPATION FACTORS ARE\*\*\*      .07      .00      .01

\*\*\*ACCELERATIONS ARE \*\*\*      .280      .280      .280

\*\*\*SEISMIC MOMENT=              25.9KIPS.IN

\*\*\*\*\*RESULTS OF ANALYSIS\*\*\*\*\*

|                                     |             |             |           |
|-------------------------------------|-------------|-------------|-----------|
| MASONRY COMPRESSIVE BENDING STRESS= | .2007KSI    | ALLOWABLE = | .825KSI   |
| MASONRY AXIAL COMPRESSIVE STRESS=   | .0000KSI    | ALLOWABLE = | .394KSI   |
| TENSILE STEEL STRESS=               | 12.0305KSI  | ALLOWABLE = | 36.000KSI |
| COMPRESSIVE STEEL STRESS=           | .0000 KSI   | ALLOWABLE = | 36.000KSI |
| MASONRY SHEAR STRESS=               | .0031KSI    | ALLOWABLE = | .058KSI   |
| MAXIMUM DEFLECTION =                | .093572 IN. |             |           |

DO YOU WANT TO RUN BLOCK WALL AGAIN      YES TYPE 1      NO TYPE 0  
>0



**3.8C.7.3.4 Comparison Between Hand Calculation and Computer Calculation**

|                                                 | <u>BLOCK WALL Program</u> | <u>Hand Calculation</u> |
|-------------------------------------------------|---------------------------|-------------------------|
| Natural frequencies (Hz)                        | 5.99, 23.79, 50.51        | 5.98                    |
| Seismic accelerations (g)                       | 0.28, 0.28, 0.28          | 0.28                    |
| Seismic moment (in.-kips) <sup>(a)</sup>        | 25.9                      | 24.79                   |
| Masonry compressive stress (psi) <sup>(a)</sup> | 201                       | 192                     |
| Reinforcing steel stress (psi) <sup>(a)</sup>   | 12,030                    | 11,500                  |

---

a. The program calculates a higher value because of the inclusion of the second and third modes.

**SUPPLEMENT 3.8D**

**DETERMINATION OF EXPANSION ANCHOR BOLT LOADS IN  
PIPE SUPPORT BASE PLATES**

**3.8D.1 SUMMARY**

This report describes a method for determining the anchor bolt loads in steel base plates supporting Seismic Category I piping systems. The anchors in question are of the expansion type. The loads are applied to the base plate through some type of attachment, usually concentric with the base plate, and could comprise of moments and forces in three directions. A review of the typical base plates used in supporting the subject piping systems indicates that the majority of them have either a four-, six-, or eight-bolt connection. The plate thicknesses usually vary from 1/2 in. to 1 1/2 in. and are not generally stiffened. The present formulation will, therefore, be devoted to base plate anchorage systems with aforementioned physical characteristics.

From an analytical standpoint the load distribution in a base plate anchorage system is fairly complex, and it is necessary, therefore, that certain simplifying assumptions be made to arrive at conservative yet practical solutions. However, such assumptions should take into consideration the following parameters, which might affect the load distribution in the anchorage system.

- Flexibility of the base plate: consideration of bending effects.
- Bolt stiffness: based on available load displacement data.
- Prying action.

For expansion anchor bolts, prying action will not be critical for the following reasons:

- Where the anchorage system capacity is governed by the concrete shear cone, the prying action would result in an application of an external compressive load on the cone and would not therefore affect the anchorage capacity.
- Where the bolt pullout determines the anchorage capacity, the additional load carried by the bolt due to the prying action will be self-limiting. With the bolt stiffness decreasing with increasing load, at higher loads the bolt extension will be such that the corners of the base plate will lift off, and the prying action will be relieved. This has been found to occur when the bolt stiffnesses in the finite element analysis were varied from a high to a low value to correspond typically to the initial stiffness and the stiffness beyond the allowable design load.

### **3.8D.2 METHOD OF ANALYSIS FOR ANCHOR BOLT LOADS**

In general, the finite element method of analysis may be used to analyze the base plates under consideration. However, such an approach will be both time consuming and expensive considering the number of base plates involved. A quasi-analytical approach has been formulated taking into account the base plate flexibility and the bolt stiffness. The results of the quasi-analytical method have been verified with appropriate finite element solutions and have shown good correlation for the typical cases studied.

#### **3.8D.2.1 INTRODUCTION**

The purpose of this study was to develop an analytical method for determining tension loads on expansion anchors used as anchors for pipe support base plates. Finite element analysis<sup>(1)</sup> served as a data base for developing less expensive and less time consuming analytical methods. The method that is presented as a result of this study uses plate flexibility and bolt stiffness as the primary parameters. This method will be computerized for four-, six-, and eight-bolt patterns.

#### **3.8D.2.2 ANALYSIS**


In the quasi-analytical model presented here, the plate is primarily treated as a beam on elastic springs. Base plates with three different bolt configurations were considered.

#### **3.8D.2.3 ASSUMPTIONS**

- Symmetrical bolt patterns.
- Centroidal loading.
- Attachment dimensions small compared to the plate dimensions.
- Units for all variables.  
force = kips  
length = in.

### 3.8D.3 FOUR-BOLT PATTERN: MOMENT- AND TENSION-LOADING CASES

Given a plate with a four-bolt pattern and a moment about one axis: This plate will be modeled as a beam.



$$T(X) = C(X) = M$$


where:

T = total tension (kips).

C = resultant of compressive stress block (kips).


The beam will be idealized as being supported at the location of the compressive force resultant. Therefore, if the compression centroid can be located, X becomes known, and T can be calculated.

HNP-2-FSAR-3



$$T \cdot (X) = M$$

For a four-bolt pattern loaded centroidally:



conceptually,  $L = \text{function}(t, d, K_B)$

where:

$L$  = distance from edge of attachment to the center of compression (in.).

$t$  = plate thickness (in.).

$D$  = distance from edge of attachment to the edge of the plate (in.).

$K_B$  = bolt stiffness (kips/in.).

## HNP-2-FSAR-3

Based on a number of finite element analysis results (i.e., varying T, d, and  $K_B$ ), the following empirical relationship was derived:

$$L = 3.5 \left[ \left( \frac{t}{d} \right)^{2/3} \left( \frac{44}{K_B} \right)^{1/3} \right] (d) \quad (1)$$

where:

$$L \leq d$$

Once L is calculated, total tension (T) and bolt load ( $F_T$ ) can be found:

$$T = \frac{M}{\frac{S}{2} + \frac{b}{2} + L} \quad (2)$$

$$F_T = \frac{T}{2} = \frac{M}{S + b + 2L} \quad \text{For centrically loaded four-bolt patterns only.} \quad (3)$$

This method can be extrapolated for use with combined loading cases.

For biaxial bending:


$$\text{Critical } F_T = \frac{M_x}{S_x + b_x + 2L_x} + \frac{M_y}{S_y + b_y + 2L_y} \quad (4)$$

For combined bending and tension:


$$\text{Critical } F_T = \frac{M}{S + b + 2L} + \frac{T}{4} \quad (5)$$

Since L varies with t, d, and  $K_B$ , the method for finding L can be used for many plate and bolt patterns. Once L is known, the plate can be modeled as a beam on springs. The beam can be solved by various methods, and the total tension force for any row of bolts can be calculated. This will be demonstrated for six- and eight-bolt patterns in the following details.

**3.8D.4 EIGHT-BOLT PATTERN: MOMENT-LOADING CASE**



Beam model:



$K_B$  = bolt stiffness

$$I = \frac{Wt^3}{12}$$

## HNP-2-FSAR-3

The reactions for this indeterminate beam model can be solved using the principle of virtual work. The following equations were derived for eight-bolt patterns:

$$Z = \frac{b}{2} + L$$

where: L is determined from equation 1.

$$EI = 2417 Wt^3 \text{ (kips-in.}^2\text{)}$$

Redundants are taken at C:

$$-EI\delta_{CO} = \frac{EIM(K_1 + K_2)}{S^2 K_1 K_2} \left[ Z + \left( \frac{K_1}{K_1 + K_2} \right) S \right] - \frac{M Z S}{3} \quad (6)$$

where:  $\delta_{CO}$  = deflection at C due only to M:

$$EI\delta_{CC} = \frac{EI}{S^2 K_1 K_2} \left[ K_1 S^2 + 2K_1 Z S + (K_1 + K_2) Z^2 \right] \frac{Z^2}{3} [Z + S] \quad (7)$$

where:  $\delta_{CC}$  = deflection due to a 1<sup>K</sup> - force applied at C:

$$\text{Reaction at C} = R_C = -\frac{EI\delta_{CO}}{EI\delta_{CC}} \quad (8)$$

$$\therefore R_A = \frac{[M - Z(R_C)]}{S}$$

$$R_B = R_C - R_A$$

As the plate gets wider and Z becomes small compared to Y, the two middle bolts cannot be lumped together as one support with  $K_2 = 2K_B$ .  $K_2$  will be something less than  $2K_B$ . The following expression for  $K_2$  yielded results that were in good agreement with finite element method results:

$$K_2 = 2K_B \left( \frac{Z}{Y} \right)^2 \leq 2K_B \quad (9)$$

For plate sizes generally used in pipe supports, this width effect will have negligible effect on row A; i.e., the stiffnesses of the three bolts can still be lumped together in the beam model.



### HNP-2-FSAR-3

The reactions in the beam model are now known. The reaction at any one support is the total tension in that row of bolts. To distribute the load to the bolts:

$$\text{For row B from symmetry, tension per bolt} = F_{Td} = F_{Te} = \frac{R_B}{2} \quad (10)$$

For row A, the relative stiffness of the plate and the bolts and the bolt distance from the attachment will affect the load distribution between the middle and corner bolts. Evidently, the bolt closest to the attachment will carry more load, and, if the attachment size is small, the bolt-to-attachment distance may be substituted by the distance of the bolt to the center line of the plate. Thus, tension in the middle bolt b:

$$F_{Tb} = \alpha \left[ \frac{\left( \frac{K_B}{EI} \right)}{\left( \frac{\ell_1^3}{L_M} + \frac{2}{L_C} \right)} \right] (R_A) \quad (11)$$

where:

$L_M$  = distance from plate center to bolt b.

$L_C$  = distance from plate center to bolts a and c.

$\ell_1$  =  $S + Z$ .

$\alpha$  = constant.

Based on several finite element method analyses, the following expression of  $F_{Tb}$  was derived:

$$F_{Tb} = \lambda(R_A) = \frac{2}{3} \left[ \frac{\left( \frac{K_B}{EI} \right)}{\left( \frac{\ell_1^3}{L_M} + \frac{2}{L_C} \right)} \right]^{1/4} \left[ \frac{\left( \frac{K_B}{EI} \right)}{\left( \frac{\ell_1^3}{L_M} + \frac{2}{L_C} \right)} \right] (R_A) \quad (12)$$

with the limits  $0.333 < \lambda < 1.0$  corresponding to very rigid and very flexible plates.


Tension in the corner bolts is given by:

$$F_{Tc} = F_{Ta} = \frac{R_A - F_{Tb}}{2} \quad (13)$$

$$F_{Tf} = F_{Tg} - F_{Th} = 0 \quad (14)$$

For biaxial bending, the resultant bolt forces will be determined by superposition.

**3.8D.5 SIX-BOLT PATTERN: MOMENT-LOADING CASE**



The six-bolt pattern can be solved by using a combination of the equations for four-bolt and eight-bolt patterns.

For moment about the X-X axis:

- A. Use equations 1 and 2 to solve for total tension.
- B. Use the eight-bolt distribution equations, 12 and 13, for solving the bolt loads with

$$l_1 = \frac{S_x}{2} + Z \text{ and } EI = 2417 B_y t^3$$

For moment about the Y-Y axis:

- A. Use equations 6, 7, and 8 to solve for reactions with

$$K_2 = 2K_B \left( \frac{Z}{Y} \right)^2; S = S_y; Y = \frac{S_x}{2} \text{ and}$$

$$EI = 2417 B_x t^3$$


- B. Divide the reactions corresponding to each bolt row by two to obtain individual bolt loads.

**3.8D.6 SIX- AND EIGHT-BOLT PATTERNS: TENSION-LOADING CASES**

Unlike the four-bolt pattern, for the six- and eight-bolt cases the centrally applied tension cannot be distributed equally to all the bolts due to the interplay of bolt and plate stiffnesses and to the relative distances of the bolts from the point of application of the load.

Based on the moment case, it will be assumed that the parametric variable affecting the load distribution will be of the same form as in the moment case. The constant 8/9 for the distribution factors,  $DFM_x$  and  $DFM_y$  was obtained from finite element analysis results.

**3.8D.6.1 EIGHT-BOLT PATTERNS: TENSION-LOADING CASE**



T = tension load.

$F_T$  = load per bolt.

Calculate:

$$EI_1 = 2417 B_x t^3$$

$$EI_2 = 2417 B_y t^3$$

HNP-2-FSAR-3

$$K_X = \frac{EI_1}{2S_Y}$$

$$K_Y = \frac{EI_2}{2S_X}$$

$$T_X = \left[ \frac{K_X}{K_X + K_Y} \right] T; \quad T_Y = T - T_X$$

$$L_C = \left[ (S_X)^2 + (S_Y)^2 \right]^{1/2}$$

$$DFM_X = \frac{8}{9} \left[ \frac{K_B (2S_Y)^3}{EI_1} \right]^{1/4} \left[ \frac{\frac{1}{S_Y}}{\frac{1}{S_Y} + \frac{2}{L_C}} \right]; \quad \frac{4}{7} \leq DFM_X \leq 1.00$$

$$DFM_Y = \frac{8}{9} \left[ \frac{K_B (2S_X)^3}{EI_2} \right]^{1/4} \left[ \frac{\frac{1}{S_X}}{\frac{1}{S_X} + \frac{2}{L_C}} \right]; \quad \frac{4}{7} \leq DFM_Y \leq 1.00$$

NOTE:

For plate stiffness varying from infinitely rigid to extremely flexible,

$$\frac{4}{8} \leq DFM \leq 1$$

Since a rigid plate does not exist, 4/7 was used as a limit.

$$F_{Tb} = F_{Tg} = [DFM_Y] \left[ \frac{T_Y}{2} \right]$$

$$F_{Td} = F_{Te} = [DFM_X] \left[ \frac{T_X}{2} \right]$$

$$F_{Ta} = F_{Tc} = F_{Tf} = F_{Th} = \frac{T - 2(F_{Tb} + F_{Td})}{4}$$

If, by above equations,  $F_{Td} < F_{Ta}$  or  $F_{Tb} < F_{Ta}$ , set  $F_{Td} = F_{Ta}$  or  $F_{Tb} = F_{Ta}$  as limiting values for rectangular plates.

**3.8D.6.2 SIX-BOLT PATTERN: TENSION-LOADING CASE**


$$EI_1 = 2417 B_x t^3$$

$$EI_2 = 2417 B_y t^3$$

$$K_x = \frac{EI_1}{2S_y}$$

$$K_y = \frac{EI_2}{S_x}$$

$$T_y = \left[ \frac{K_y}{K_x + K_y} \right] T$$



$$DFM_y = \left[ \frac{8K_B (S_y)^3}{9EI_2} \right]^{1/4} \left[ \frac{1}{\frac{S_y}{S_x} + \frac{1}{L_c}} \right]; \geq \frac{4}{7} \text{ and } \leq 1.00$$

where:

$$L_c = \left[ \frac{S_x^2}{2} + \frac{S_y^2}{1} \right]^{1/2}$$

$$F_{Tb} = F_{Te} [DFM_y] \left[ \frac{T_y}{2} \right]$$

$$F_{Ta} = F_{Tc} = F_{Td} = F_{Tf} = \left[ \frac{T - 2(F_{Tb})}{4} \right]$$

Based on the above equation, if  $F_{Ta} (= F_{Tc} = F_{Td} = F_{Tf}) > F_{Tb} (= F_{Te})$ , as may be the case where:


$S_x \geq 2S_y$ , then

$$F_{Ta} = F_{Tc} = F_{Td} = F_{Tf} = F_{Tb} = F_{Te} = \frac{T}{6}$$

**3.8D.6.3 COMPARISON OF RESULTS**

Finite Element Method Versus Bechtel Model Sketches of Base Plates Analyzed


A. Four-Bolt Pattern



| <u>Plate</u> | <u>t<sup>(a)</sup></u> | <u>K<sub>B</sub></u> | <u>Loading</u>                                                |
|--------------|------------------------|----------------------|---------------------------------------------------------------|
| 1            | 1/2 in.                | 44                   | M <sub>X</sub> = 18 kips-in.                                  |
| 2            | 1/2 in.                | 44                   | M <sub>X</sub> = 18 kips-in.,<br>M <sub>Y</sub> = 36 kips-in. |
| 3            | 1/2 in.                | 44                   | M <sub>X</sub> = 18 kips-in.,<br>F <sub>Z</sub> = 4 kips-in.  |
| 4            | 3/4 in.                | 44                   | M <sub>X</sub> = 18 kips-in.                                  |
| 5            | 3/4 in.                | 150                  | M <sub>X</sub> = 18 kips-in.                                  |
| 6            | 3/4 in.                | 300                  | M <sub>X</sub> = 18 kips-in.                                  |

a. K<sub>B</sub> = bolt stiffness (kips/in.); t = plate thickness.

HNP-2-FSAR-3




| Plate <sup>(a)</sup> | t       | $K_B$ | Loading                                           |
|----------------------|---------|-------|---------------------------------------------------|
| 7                    | 3/8 in. | 44    | $M_Y = 247.5$ kips-in.                            |
| 8                    | 2 in.   | 44    | $M_Y = 247.5$ kips-in.                            |
| 9                    | 1/2 in. | 44    | $M_Y = 247.5$ kips-in.,<br>$M_X = 247.5$ kips-in. |

a. From Teledyne Engineering Report.<sup>(2)</sup>

HNP-2-FSAR-3

B. Six-Bolt Pattern




| <u>Plate</u> | <u>t</u> | <u>K<sub>B</sub></u> | <u>S<sub>X</sub></u> | <u>S<sub>Y</sub></u> | <u>B<sub>X</sub></u> | <u>B<sub>Y</sub></u> | <u>Loading</u>               |
|--------------|----------|----------------------|----------------------|----------------------|----------------------|----------------------|------------------------------|
| 1            | 1/2 in.  | 44                   | 12                   | 8                    | 16                   | 20                   | M <sub>X</sub> = 36 kips-in. |
| 2            | 1 in.    | 440                  | 12                   | 8                    | 16                   | 20                   | M <sub>X</sub> = 36 kips-in. |
| 3            | 1 in.    | 44                   | 22.5                 | 4                    | 25.5                 | 12                   | F <sub>Z</sub> = 10 kips     |
| 4            | 2 in.    | 44                   | 22.5                 | 4                    | 25.5                 | 12                   | F <sub>Z</sub> = 10 kips     |
| 5            | 3/4 in.  | 44                   | 12                   | 6                    | 16                   | 16                   | F <sub>Z</sub> = 10 kips     |
| 6            | 1 in.    | 44                   | 12                   | 6                    | 16                   | 16                   | F <sub>Z</sub> = 9 kips      |



HNP-2-FSAR-3

C. Eight-Bolt Pattern



| Plate | t         | $K_B$ | $S_X$ | $S_Y$ | $B_X$ | $B_Y$ | b | Loading              |
|-------|-----------|-------|-------|-------|-------|-------|---|----------------------|
| 1     | 1 1/4 in. | 44    | 12    | 12    | 28    | 28    | 6 | $M_X = 10$ kips-in.  |
| 2     | 1 1/4 in. | 440   | 12    | 12    | 28    | 28    | 6 | $M_X = 180$ kips-in. |
| 3     | 1 in.     | 300   | 8     | 8     | 20    | 20    | 4 | $M_X = 90$ kips-in.  |
| 4     | 1 1/4 in. | 150   | 12    | 12    | 28    | 28    | 6 | $F_Z = 16$ kips      |
| 5     | 1 1/4 in. | 44    | 12    | 12    | 28    | 28    | 6 | $F_Z = 18$ kips      |
| 6     | 1 in.     | 44    | 6     | 10    | 16    | 24    |   | $F_Z = 10$ kips      |

**3.8D.6.4 TABULATED RESULTS**

A. Four-Bolt Pattern

| <u>Load per Bolt (kips)</u>  |                       |                                 |                           |
|------------------------------|-----------------------|---------------------------------|---------------------------|
| <u>Analysis Method Plate</u> | <u>Finite Element</u> | <u>Bechtel Analytical Model</u> | <u>Percent Difference</u> |
| A (1)                        | 0.75                  | 0.75                            | 0                         |
| A (2)                        | 2.08                  | 2.25                            | +8.2                      |
| A (3)                        | 1.71                  | 1.75                            | +2.3                      |
| A (4)                        | 0.64                  | 0.68                            | +6.3                      |
| A (5)                        | 0.75                  | 0.78                            | +4.0                      |
| A (6)                        | 0.78                  | 0.84                            | +7.7                      |
| A (7)                        | 9.12                  | 9.19                            | +0.8                      |
| A (8)                        | 6.12                  | 6.45                            | +5.4                      |
| A (9)                        | 16.61                 | 18.17                           | +9.4                      |

B. Six-Bolt Pattern

| <u>Analysis Method Plate</u> | <u>Tensile Load Per Bolt (kips)</u> |               |                                 |               | <u>Percent Difference</u> |               |
|------------------------------|-------------------------------------|---------------|---------------------------------|---------------|---------------------------|---------------|
|                              | <u>Bolts a and c</u>                | <u>Bolt b</u> | <u>Bolts a and c</u>            | <u>Bolt b</u> | <u>Bolts a and c</u>      | <u>Bolt b</u> |
|                              | <u>Finite Element</u>               |               | <u>Bechtel Analytical Model</u> |               |                           |               |
| B (1)                        | 0.65                                | 1.84          | 0.64                            | 1.72          | -1.5                      | -6.5          |
| B (2)                        | 0.61                                | 1.96          | 0.72                            | 1.86          | +18.0                     | -5.1          |
| B (3)                        | 1.68                                | 1.64          | 1.67                            | 1.67          | -0.7                      | +1.5          |
| B (4)                        | 1.67                                | 1.66          | 1.67                            | 1.67          | 0                         | +0.2          |
| B (5)                        | 1.55                                | 1.89          | 1.67                            | 1.67          | -7.2                      | +13.5         |
| B (6)                        | 1.45                                | 1.59          | 1.5                             | 1.5           | +3.2                      | -6.1          |

HNP-2-FSAR-3

C. Eight-Bolt Pattern

| Tensile Load per Bolt (kips) |                       |        |        |                                 |        |        |                           |               |               |
|------------------------------|-----------------------|--------|--------|---------------------------------|--------|--------|---------------------------|---------------|---------------|
| Analysis Method<br>Plate     | Bolt a                | Bolt b | Bolt d | Bolt a                          | Bolt b | Bolt d | <u>Percent Difference</u> |               |               |
|                              | <u>Finite Element</u> |        |        | <u>Bechtel Analytical Model</u> |        |        | Bolt <u>a</u>             | Bolt <u>b</u> | Bolt <u>d</u> |
| C (1)                        | 1.89                  | 2.64   | 0.75   | 1.94                            | 2.70   | 0.92   | +2.69                     | +2.3          | +17.0         |
| C (2)                        | 1.55                  | 5.26   | 1.46   | 1.58                            | 5.14   | 1.47   | +1.9                      | -2.3          | +0.7          |
| C (3)                        | 1.22                  | 3.32   | 0.88   | 1.32                            | 3.23   | 0.85   | +8.2                      | -2.6          | -3.0          |
| C (4)                        | 1.08                  | 2.92   | 1.46   | 1.08                            | 2.92   | 1.46   | 0                         | 0             | 0             |
| C (5)                        | 0.83                  | 1.17   | 0.59   | 0.86                            | 1.14   | 0.57   | +3.6                      | -2.6          | -3.5          |
| C (6)                        | 0.99                  | 1.95   | 1.06   | 0.96                            | 2.04   | 1.01   | -3.1                      | +4.4          | +5.2          |

## HNP-2-FSAR-3

### REFERENCES

1. "ANSYS" Engineering Analysis System, developed by Swanson Analysis System, Inc.
2. Diluna, L. J. and Flaherty, J. A., "An Assessment of the Effect of Plate Flexibility on the Design of Moment-Resistant Base Plates," Teledyne Engineering Services (submitted to American Society of Mechanical Engineers for publication).

### **3.9 MECHANICAL SYSTEMS AND COMPONENTS**

#### **3.9.1 DYNAMIC SYSTEM ANALYSIS AND TESTING**

##### **3.9.1.1 Vibration Operational Test Program**

The Hatch Nuclear Plant-Unit 2 (HNP-2) design is in conformance with Sections NB-3622, NC-3622.3, and ND-3611 of the American Society of Mechanical Engineers (ASME) Code, Section III, which requires that the piping be arranged and supported with consideration of vibration and that the designer is responsible by design and observation under startup or initial operating conditions to ensure that vibration of piping systems is within acceptable levels.

The test program is designed through observation to identify any excessive vibration anywhere on a given piping system, not just at selected points. Piping systems are monitored to verify that the piping and piping restraints will withstand dynamic effects due to normal operation; flow-induced, steady-state vibration; and anticipated transients. Also, piping vibrations are monitored to ensure that they are within acceptable limits. If an observed displacement is judged to be excessive anywhere in the system during preoperational testing or during normal operation, the displacement will be measured and corrective action taken for Class 1, 2, and 3 systems. The test program is standard practice and is a continuing program of observation and inspection to identify past or present cases of excessive vibration.

Vibration and transient response for main steam, recirculation, and feedwater piping inside the drywell is measured by the instrumentation used to measure thermal expansion in these systems. Other Class 1, 2, or 3 piping systems throughout the plant are the subject of construction acceptance testing, startup testing, or surveillance during normal operation or shutdown as dictated by accessibility considerations.

Acceptance criteria for piping system vibration include:

##### **A. Flow-Induced, Steady-State Vibration**

The measured range of displacements for the main steam, recirculation, and feedwater lines is reported to the system designer or a stress analyst for evaluation and resolution.

An evaluation of flow-induced, steady-state vibration in other piping systems shall be made as dictated by visual observation.

##### **B. Transient Response**

Data acquisition in support of the anticipated, rapid, short duration plant transients, such as turbine stop valve closure or main steam relief valve operation, is returned to the piping designer to allow verification of the conservatism of the piping analysis. Other transients which may occur during plant testing and operation are

## HNP-2-FSAR-3

evaluated as dictated by observation of piping systems during the transient or by visual inspection of the piping system following the transient.

If any vibration is determined to be greater than that expected in the piping design analysis for a given piping system, resultant stresses will be calculated. These stresses will be appropriately combined with the stresses caused by dead weight, earthquake, and pressure and compared to the allowable primary stresses. If the allowable code stresses are exceeded, restraints will be installed to eliminate the displacements or reduce them to acceptable levels. If during the test the piping systems restraints are determined to be inadequate or damaged, corrective restraints will be installed and the test program for identifying excessive vibration by inspection and observation will continue in order to verify that the vibration has been reduced to an acceptable level.

The transients specifically noted in paragraph 3.9.1.1.1 below are considered to be reasonable checks of system responses to reasonably severe transients. Absolute worst condition transients for which these Class 1, 2, and 3 systems were designed and analyzed are noted in the System Design Specifications. All other system transients were reviewed and determined to be insignificant. In any event, Georgia Power Company (GPC) observed and inspected Class 1, 2, and 3 system responses to all transients experienced during the preoperational test program and up to March 22, 1997, as a matter of course. Since March 22, 1997, Southern Nuclear Operating Company, as the exclusive operating licensee, has observed and inspected Class 1, 2, and 3 system responses to all transients experienced during operation.

All piping supports were installed and adjusted to proper specifications prior to testing. For any of these components whose modification may have a significant effect on a system, the magnitude of that effect was evaluated by the designer or a stress analyst and, if necessary, that portion of the system was monitored for effects of vibration or transient response during a similar event.

Any displacement which is judged to be significant will be analyzed for resultant stresses and corrections will be made, if necessary, for all systems.

### 3.9.1.1.1 ASME Class 1 and 2 Components

Valves, piping, and supports associated with the following components are visually checked for excessive vibration:

| <u>Component</u>                                        | <u>Quantity</u> |
|---------------------------------------------------------|-----------------|
| High-pressure coolant injection (HPCI) pump and turbine | 1               |
| Reactor core isolation cooling (RCIC) pump and turbine  | 1               |
| Recirculating pumps                                     | 2               |
| Residual heat removal (RHR) and core spray (CS) pumps   | 6               |

## HNP-2-FSAR-3

The specific conditions for which vibrations are checked are as follows:

- Design flowrate.
- Minimum flowrate (shutoff flow), as feasible.
- Maximum flowrate (runout flow), as feasible.
- Startup.
- Shutdown.
- Other specific transient or operating conditions (discussed below) which might be expected to produce abnormal vibration or pressure pulsations.

### A. Restart Testing Following Recirculation Piping Replacement

A restart test program was performed following fuel cycle 4 after replacement of the recirculation piping due to intergranular stress corrosion cracking. The restart test program verified that system performance is satisfactory for safe operation of the station at all expected operating conditions. During the restart program, calibration of the affected systems, based on the new recirculation system configuration, was Pre-Operational and Startup Specification and Data Sheet. Plant-specific restart procedures were conducted or verified to be correct; and piping expansion and vibration were monitored to confirm design values as specified in the Recirculation completed, and a detailed schedule of testing was followed.

#### 1. Heatup from Ambient to Rated Temperature and Pressure

Following satisfactory installation of the replacement recirculation pipe, special instruments were installed in the drywell at preselected locations on the recirculation, RHR, and the reactor water cleanup (RWC) piping to monitor piping vibration, expansion and strain. In the main control room (MCR), signal taps were installed to monitor selected process signals. The following tests were conducted during this phase of the restart program:

- a. Reactor vessel process temperatures were monitored during heatup to determine that specified temperature limits were not exceeded (STI-16).
- b. System expansion (STI-17) checks were made during heatup to verify freedom of motion of major recirculation system equipment and piping.
- c. Strain measurements were taken at rated temperature and pressure to confirm design values.

## HNP-2-FSAR-3

- d. Nuclear instrumentation was monitored to verify proper operation following cable replacement after the outage.
  - e. Safety relief valves (STI-26) were tested to verify proper discharge and that no blockage exists in the safety relief valve discharge lines.
2. From Rated Temperature to 100% Power

Reactor power was increased to 100% in a controlled fashion with two major testing plateaus:

- Along the 75% rod line.
- Along the 100% rod line.

The following tests were conducted:

- a. Vibration measurements (STI-33) were performed to determine the vibration characteristics of the recirculation piping, RHR, and RWC piping as reactor power was increased.
- b. Control system stability (STI-23, 29) was demonstrated for both the feedwater and recirculation system controllers.
- c. The 75% and 100% load lines were reverified, and new jet pump baseline data were obtained.
- d. The jet pumps were calibrated (STI-35), based upon the current jet pump riser flow distribution and current recirculation pipe design.
- e. Recirculation pump trips (STI-30) were conducted to verify that vibration and system performance are within design values.
- f. A cavitation search (STI-30) was conducted to verify that the low feedwater flow interlock is still adequate to prevent jet pump and recirculation pump cavitation.
- g. The recirculation pump high-speed stops were reset, based upon the current recirculation system configuration.

An analysis of the recirculation system has been completed to determine the potential for damage due to water hammer. Since the recirculation system is filled with water and is self-venting by configuration, the problem area of most concern is the potential for damage due to pressure waves caused by rapid changes in flow velocity.

The recirculation system minimum valve closure time of 30 s is much too slow to cause water hammer. If instantaneous seizure of the recirculation pump should



## HNP-2-FSAR-3

occur, stoppage of the impeller does not result in a large instantaneous change in flow velocity as would be required for water hammer effects to occur. This is because a large open flow area still exists through the pump impeller when it is stopped.

When the pump seizes, it changes from a device which aids the flow of water to a device which impedes its flow. Two pressure waves which modify the flow are sent out from the pump. The wave that travels up the suction pipe is a compression wave, while the wave traveling down the discharge pipe is a rarefaction wave. Evaluation of the pressure waves, using equations of the form  $\Delta P = C\Delta V$ , results in a wave strength of < 200 psi. That is, the pressure in the suction pipe is < 200 psi above normal operating pressure, while the pressure in the discharge pipe is < 200 psi below normal operating pressure. This change in pressure is within the design capability of the piping system.

Since there is no further energy input to the system after the pump seizes, any conceivable combination of pressure wave reinforcement in the piping system caused by reflections from valves, elbow, orifices, etc., cannot exceed the strength of the original wave from which they were subdivided.

The water hammer effect in the recirculation system is, therefore, negligible.

### B. For Main Steam System

Flow-induced vibrations have been measured on earlier plants (Dresden 2), where the conditions were generally similar, but where the piping configurations did not closely resemble those of HNP-2. During the startup of HNP-2, the instrumentation which exists for determining expansion and movement of the steam lines was used wherever possible to augment further the data on flow-induced vibrations.

#### 1. Description of Mathematical Model and Analytical Technique

The mathematical model of the main steam line is constructed to simulate the physical dynamic characteristics of the piping system. The model consisted of lumped masses at discrete points connected by weightless elements. The elements were assigned cross-sectional and elastic properties identical to those of the pipe section which the element represented. Each lumped mass point included the mass of the piping and insulation in its vicinity. The masses of valves were lumped independently because of the increased local weight concentrations these items represented.

The main steam piping is subjected to two transient conditions that produce dynamic loads acting on it. These two conditions are turbine stop valve closure and relief valve lifting.

a. Safety Relief Valve

The safety relief valves discharge through an enclosed piping system which carries the steam to the suppression pool. Under the conditions of steady-state flow, the forces associated with flow acting on the piping system are self-equilibrated and do not create bending moments in the piping system. These safety relief valves do not cause large steady forces acting on the system as do the more common safety relief valves discharging through an elbow directly to the atmosphere. The safety relief valves discharging into an enclosed piping system do create momentary imbalanced forces acting on the piping system during the first few milliseconds following safety relief valve lift. These loads are caused by the following:

- 1.) A movement by change of force exerted on the discharge piping during the first few milliseconds when the safety relief valve has started to open and prior to the time steady-state flow has been established.
- 2.) A fluid transient load will be exerted on the safety relief valves and respective piping during the first few milliseconds when the valve is opening and prior to the time steady-state flow has been established. (With steady-state flow, the dynamic flow reaction forces will be self-equilibrated in the safety relief valve discharge piping).
- 3.) Forces are produced on the discharge piping system immediately after the relief valve lifts, due to fluid momentum changes at each elbow.
- 4.) These forces vary with time and with position along the discharge pipe because the flowrate through the relief valve is a function of time.

b. Turbine Stop Valve Closure

Prior to turbine stop valve closure, saturated steam flows through each main steam line at nuclear-boiler-rated pressure and mass-flowrate. Flow stops at the upstream side of the valve at the instant stop valve closure is achieved. However, flow of steam into the main steam line from the reactor vessel continues until the fluid compression wave produced by the stop valve closure reaches the vessel nozzle. Repeated reflections of this wave at the vessel end of the main steam line and at the turbine stop valve end produce time-varying, segmented forces at each elbow in the main steam line and are calculated by the TSMOOD computer program. The dynamic analysis of the main steam and relief valve piping system for turbine stop valve closure is performed using the time-history analysis by direct integration method

## HNP-2-FSAR-3

on the SAP4 (structural analysis program) computer program. No test data are available to compare with the results of the analysis.

A conservative dynamic analysis has been made for both of these transients to determine stress levels, rather than by actual test measurements. The moments from these loads were combined individually with earthquake moments by the square-root-of-the-sum-of-the-squares method. These combined moments will then be added to deadweight moments to determine bending stresses. The bending stresses plus the longitudinal pressure stresses will be shown to be  $< 2.25 S_m$ , in accordance with the principles and methods of ASME, Section III. A further justification for the use of the square-root-of-the-sum-of-the-squares method and for the load combinations with respect to the ASME Code, Section III criteria is provided below.

### 2. Square-Root-of-the-Sum-of-the-Squares Method

The square-root-of-the-sum-of-the-squares method is used when combining the operating basis earthquake (OBE) loads with the operational transients (turbine stop valve closure and safety relief valve blowdown loads.) The use of this method is justified by the fact that earthquake excitation is a random process with amplitudes increasing to a peak and then decaying, and the fact that the amplitude of the operational transients (turbine stop valve closure and safety relief valve blowdown) loads also rise to a peak and then decay. Therefore, considering that the dynamic responses of such loads possess varying frequencies, amplitudes, and random-phase relationship with respect to each other, the square-root-of-the-sum-of-the-squares method is adequate for calculating the design loads. The only piping system for which this method of load combination was used was the main steam system.

### 3. Load Combination

The combination of the OBE + operational transients (such as turbine stop valve closure and relief valve opening loads) is considered an emergency condition and evaluated against emergency acceptance criteria of the ASME Code, Section III, Equation 9 ( $2.25 S_m$ ).

The upset condition was not selected for the following reasons:

- a. The OBE loading as characterized has an encounter probability of  $< 10^{-2}$  per reactor year; thus, it is an emergency condition on the probability scale. This justifies evaluation of the consequences of an OBE event (including the operational transient which is assumed to result from the OBE) against the emergency condition criteria.
- b. The turbine stop valve closure and the safety relief valve discharge loads are operative only during a very small portion of the seismic cycle; thus, there is a reduced probability of the effects combining adversely.

## HNP-2-FSAR-3

The number of maximum stress cycles due to the event combination of OBE + operational transients are too small to be used as a design condition (five maximum cycles per OBE for the event [OBE + relief valve] and three maximum cycles per OBE for the [OBE + turbine stop valve] event).

- c. It is more reasonable to use the emergency stress limit (table 3.9-1) rather than the upset.

The probability of the combined load is conditional on the probability of the individual event, and it is reasonable to use only a probable value for the combined load.

- d. The shakedown and fatigue effects of these loads are adequately considered in the ASME Code by the applications of these loads in the appropriate ASME Code equations. There is thus no doubt in the fact that these loads are considered in assessing the forces, moments, accelerations, fatigue, and stresses throughout the piping system components.

Review of the analysis work done on main steam piping on HNP-2 shows that the loading combination of the OBE and operational transients was tested as an upset condition using ASME equations 12-14. The associated stresses were below the upset intensity limit. However, with regard to this situation, OBE and operational transients should continue to be treated as an emergency condition.

The load combinations summarized in table 3.9-2 show the different event and load combinations assumed for the analysis of the main steam piping system.

### C. For Other Systems

Specific attention was directed toward evaluating possible vibration problems during the performance of the following transients:

#### 1. RHR System

Taking suction from the reactor, start the RHR pumps with the RHR system in the normal lineup. With the RHR pump running, open and close the reactor injection valves. Minimum flow bypass valves will open automatically. Stop the RHR pumps.

#### 2. CS System

Taking suction from the condensate storage tank (CST), start the CS pumps with the CS system in the normal lineup. With the CS pumps running, open

## HNP-2-FSAR-3

and close the reactor injection valves. Minimum flow bypass valves will open automatically. Stop the CS pumps.

### 3. HPCI System

Taking suction from the CST, start the turbine-driven HPCI pump with the HPCI system in the normal lineup. With the HPCI pump running, open and close the reactor injection valves. Minimum flow bypass valve will open automatically. Stop the HPCI pump.

### 4. RCIC System

Taking suction from the CST, start the turbine-driven RCIC pump with the RCIC system in the normal lineup. With the RCIC pump running, open and close the reactor injection valves. Minimum flow bypass valves will open automatically. Stop the RCIC pump.

Any observed displacement of piping which is judged to be significant was measured and the resultant stresses calculated. The resultant stresses were combined with the stresses caused by dead weight, earthquake, and pressure and compared to the allowable primary stresses. If the allowable code stresses were exceeded, restraints were installed to eliminate the displacements or reduce them to acceptable levels.

#### **3.9.1.1.2 ASME Class 3 Components**

Valves, piping, and supports associated with a given system were visually checked for excessive vibration during the normal course of the preoperational test program. Any displacement observed then or thereafter during normal operation which was judged to be significant was analyzed for resultant stresses and corrections made, if necessary, as noted above for Class 1 and 2 systems.

#### **3.9.1.2 Dynamic Testing Procedures**

A description of the tests or analyses used in the design of safety-related mechanical equipment (pumps, valves, and heat exchangers) to withstand seismic loadings is given in supplement 3.7A, and sections 3.7A.2 and 3.7A.3.

Most of this mechanical equipment is physically isolated from the effects of the faulted plant condition; therefore, it will see negligible accident loadings. For equipment which is not isolated from the effects of the faulted plant condition, the following design criteria have been established:

- A. Piping and components not designed to withstand the dynamic effects of pipe whip must be part of the redundant, physically separated subsystems so that single failure of one subsystem does not affect the operability of the redundant subsystem.

- B. Where systems are subjected to potential vibratory loadings due to the dynamic effects of fluid momentum changes (water hammer), the following measures have been taken to avoid the causes of such changes:
1. Motor-operated valves (MOVs) in the emergency core cooling system (ECCS) are not capable of closing or opening at speeds greater than 6 in./s. Catastrophic failure is improbable for MOVs.
  2. ECCS and feedwater pumps are not capable of fast starts under normal operating conditions because the lines are filled with fluid. Seizure of the prime mover (motor or turbine) is considered a single failure in the ECCS and renders the complete subsystem inoperative. Pressures and fluid velocities in the ECCS are such that a water hammer stemming from pump motor seizure can be tolerated within the ASME Code faulted limits.
  3. Air and steam voids that may develop in a stagnant system due to leakage are prevented in the RHR and CS systems by providing pump discharge check valves and automatic water charging on the pump discharge piping. The HPCI (and RCIC) pump lines do not need a charging system because the CST provides the same function. The pump suction piping of the HPCI and RCIC systems is pressurized by the CST and the suction piping of the RHR and CS systems are pressurized by the static head in the suppression pool. The HPCI and RCIC systems discharge to the feedwater line from the pump. Thus, the water in the discharge piping cannot leak into the higher pressure feedwater line.

Although system vents are located at the piping high points, air pockets, resulting from poor or inadequate system drainage, filling, and venting during and after maintenance or prior to startup, could result in severe water hammer. To preclude this, procedural control is recognized as the only available means to assure proper system venting.

### **3.9.1.3 Dynamic System Analysis Methods for Reactor Internals**

#### **3.9.1.3.1 Forcing Functions and Dynamic Response of Reactor Internals**

The major reactor internal components within the vessel are subjected to extensive testing, coupled with dynamic system analyses, to describe properly the resulting flow-induced vibration phenomena incurred from normal reactor operation and from anticipated operational occurrences. (Refer to section 4.2.)

In general, the vibration forcing functions for operational flow transients and steady-state conditions are not predetermined by detailed analysis. Special analyses of the response signals measured from reactor internals of similar designs are performed to predict amplitude and modal contributions, and parameter studies useful for extrapolating the results from the tests of internals and components of similar designs are performed. This vibration prediction

## HNP-2-FSAR-3

method is appropriate where standard hydrodynamic theory cannot be applied due to complexity of the structure and flow conditions. Elements of the vibration prediction method are outlined as follows:

- A. Dynamic analyses of major components and subassemblies are performed to identify natural vibration modes and frequencies. The analysis models used for Seismic Category I structures are similar to those outlined in section 3.7A.2, Seismic System Analysis.
- B. Data from previous plant vibration measurements are assembled and examined to identify predominant vibration response modes of major components. In general, response modes are similar, but response amplitudes vary among boiling water reactors (BWRs) of differing sizes and design.
- C. Parameters are identified which are expected to influence vibration response amplitudes among the several reference plants. These include hydraulic parameters such as velocity and steam flowrates, and structural parameters such as natural frequency and significant dimensions.
- D. Correlation functions of the variable parameters are developed which, multiplied by response amplitudes, tend to minimize the statistical variability between plants. A correlation function is obtained for each major component and response mode.
- E. Predicted vibration amplitudes for components of the prototype plant are obtained from these correlation functions, based on applicable values of the parameters for the prototype plant. The predicted amplitude for each dominant response mode is stated in terms of a range, taking into account the degree of statistical variability in each of the correlations. The predicted mode and frequency are obtained from the dynamic analyses of paragraph A.

The dynamic modal analysis also forms the basis for interpretation of the prototype plant preoperational and initial startup test results (paragraph 3.9.1.3.2). Modal stresses are calculated and relationships are obtained between sensor response amplitudes and peak component stresses for each of the lower normal modes. The allowable amplitude in each mode is that which produces a peak stress amplitude of  $\pm 10,000$  psi.

### **3.9.1.3.2 Preoperational Flow-Induced Vibration Testing of Reactor Internals**

HNP-2 reactor internals were tested in accordance with provisions of Regulatory Guide 1.20, Revision 2, for nonprototype Category I plants. The inspection of reactor internals was conducted following cold preoperational functional testing of the reactor system in significant flow modes. The inspection was conducted prior to fuel loading and reactor criticality. This inspection was practical to conduct, having been performed three times previously on the Browns Ferry-Unit 1, Fitzpatrick, and Duane Arnold prototype BWRs in response to provisions of Regulatory Guide 1.20.

## HNP-2-FSAR-3

Flow testing included operation of the recirculation system at flows up to 100% of rated volumetric flow. The results of vibration measurements in prototype plants show that the flow condition produces vibration responses in core-support structures which are greater than those at normal operating conditions and are thus conservative for testing. The test duration of 63 h included both normal and unbalanced recirculation system operation to subject major components to a minimum of  $10^6$  cycles at their lowest dominant response frequencies and at maximum response amplitudes.

After completion of flow testing, the vessel and shroud heads were removed and the vessel drained. Access to the lower plenum was provided by opening a manhole in the shroud support plate. Reactor internal structures and components, including those in the lower plenum region, were given a close visual inspection to detect possible wear, cracking, loosening of bolts, and the presence of debris and loose parts. The inspection covered all components which were examined in the prototype reactor, including the following categories:

- Peripheral control rod drive and incore guide tubes, housing, and their lower joints.
- Incore guide tube stabilizer connections and stabilizer bars. Plenum region for evidence of loose and/or failed parts.
- Inside surfaces of the jet pump adapter to shroud support welds and jet pump diffuser to jet pump adapter welds.
- Liquid control and delta pressure line and bracket welds.
- The shroud-to-shroud support weld.
- Jet pump instrument lines and brackets.
- Jet pump annulus for evidence of loose parts.
- Jet pump beams, beam bolts, wedges, and locator screws.
- Jet pump riser braces and welds.
- Shroud head and shroud bolt lug welds.
- Shroud and shroud head flange locating pins for evidence of deleterious motion marks other than those caused from normal installation.
- Core support plate bolt keepers.
- Steam separators and standpipes, and shroud head bolt support ring brackets and supports.
- Feedwater sparger and attachments.



- CS lines, brackets, and CS spargers.

Reactor internals for HNP-2 are substantially the same as the internals design configurations which have been tested in prototype BWR 4 plants. Results of the prototype tests are presented in reference 3. This report also contains additional information on the confirmatory inspection program.

#### **3.9.1.4 Correlations of Reactor Internals Vibration Tests With the Analytical Results**

Prior to initiation of the instrumented vibration test program for the prototype plant, extensive dynamic analyses of the reactor and internals are performed. The results of these analyses are used to generate the allowable vibration levels during the vibration test. The vibration data obtained during the test are always analyzed in detail. The results of the data analysis, vibration amplitudes, natural frequencies, and mode shapes are then compared to those obtained from the theoretical analysis.

Such comparisons provide the analysts with added insight into the dynamic behavior of the reactor internals. The additional knowledge gained is used in the generation of dynamic models for seismic and loss-of-coolant accident (LOCA) analyses for HNP-2. The models used for HNP-2 are the same as those used for the vibration analysis of the prototype plant. A comparison of predicted internals response characteristics for HNP-2 and Cooper is provided below.

## HNP-2-FSAR-3

### COMPARISON OF PREDICTED INTERNALS RESPONSE

| <u>Component and Mode</u>  | <u>Predicted Amplitude</u> |             |                               |                                | <u>Measured Amplitude</u> |
|----------------------------|----------------------------|-------------|-------------------------------|--------------------------------|---------------------------|
|                            | <u>HNP-2</u>               |             | <u>Cooper<sup>(a)</sup></u>   |                                |                           |
|                            | <u>Low</u>                 | <u>High</u> | <u>Low</u>                    | <u>High</u>                    |                           |
| Shroud/ separator assembly | 0                          | 43 mils     | 0                             | 39 mils                        | 8 mils                    |
| Jet pump (tangential)      | 0.5 mils                   | 2.8 mils    | 0.5 mils<br>(19 micro-strain) | 2.7 mils<br>(112 micro-strain) | 20 micro-strain           |
| Jet pump (radial)          | 0.4 mils                   | 4.0 mils    | 0.3 mils                      | 3.2 mils                       | 4 mils                    |

The vibration test data are supplemented by data from forced oscillation tests of reactor internal components to provide the analysts with additional information concerning the dynamic behavior of the reactor internals.

#### **3.9.1.5 Analysis Methods Under LOCA Loadings**

In order to ensure that no significant dynamic amplification of load occurs as a result of the oscillatory nature of the blowdown forces, a comparison was made of the periods of the applied forces and the natural periods of the core support structures being acted upon by the applied forces. These periods were determined from a comprehensive dynamic model of the reactor pressure vessel (RPV) and internals with 27 degrees of freedom as shown on figure 3.9-1. The maximum values of the differential pressures resulting from a steam line break are provided in table 4.2-20.

Only motion in the vertical direction was considered here; therefore, each structural member (between two mass points) can have only an axial load. Besides the real masses of the RPV and core support structures, account was made for the water inside the RPV.

The time-varying pressures are applied to the dynamic model of the reactor internals described above. Except for the nature and locations of the forcing functions and the dynamic model, the dynamic analysis method is identical to that described for seismic analysis.

The reactor internals for HNP-2 were designed and analyzed in accordance with applicable regulatory requirements, considering the postulated simultaneous occurrence of LOCA and design basis earthquake (DBE) events. Square-root-of-the-sum-of-the-squares of peak

a. Cooper is a 218-in. BWR 4 that has been operated at full power. Cooper is similar to HNP-2 except that the rated recirculation flow for Cooper is 6% lower.

## HNP-2-FSAR-3

magnitude or absolute-sum-of-peak magnitude are used to combine response-time histories of two or more dynamic loads. The square-root-of-the-sum-of-the-squares method is applied where responses have random time phasing, response amplitudes vary in time, and the frequencies of responses are comparable. In general, the use of the square-root-of-the-sum-of-the-squares method to combine the peak-dynamic, response-time histories of different events can be justified under circumstances where there is a reasonably high probability of not exceeding the square-root-of-the-sum-of-the-squares method value. As the number of loads being combined increases, the probability of their peak values combining absolutely decreases.

Due to the low stresses calculated from the HNP-2 internals, the absolute-sum method was used to combine the DBE stresses and LOCA differential pressure stresses. The design loading combinations are described in table 3.9-4.

For piping, the LOCA loads which were considered on HNP-2 were pressure changes in the systems affected and transient wave or pressure forces transmitted from a broken pipe through the vessel and into unbroken piping systems where integrity is required to prevent LOCA escalation. Evaluation of these loads indicated the following:

- A. Pressure changes were no greater than the peak pressure already considered in non-LOCA evaluations.
- B. Transient wave forces transmitted through the vessel into unbroken piping systems are insignificant for the BWR.

Therefore, for piping design and analysis, the DBE load represented the only significant primary loading to be considered for the combined loading of DBE + LOCA. (See table 3.9-5.) Thus, the LOCA loading for the unbroken systems was conservatively taken to be the peak transient pressure obtained from non-LOCA evaluations, and this load was combined with the DBE plus system deadweight to obtain the total design loading combination for piping systems. As an example, this form of load combination is shown in table 3.9-6 for the recirculation system piping. The results of the snubber evaluations are tabulated in table 3.9-7.

The Class 1 components within the reactor coolant pressure boundary (RCPB) have been designed to withstand the effects of the postulated high-energy line breaks inside the primary containment postulated in section 3.6. The LOCA loads were jet impingement, differential pressure, jet thrust reactions, and pipe whip. These Class 1 components are classified Seismic Category I and, therefore, are also designed to withstand the effects of the DBE.

HNP-2 is designed so that a seismic event will not induce sufficient stresses in the piping systems to cause a pipe break in a Seismic Category I system. Therefore, the combination of LOCA + DBE is not a design basis for HNP-2. However, as an independent study, the combination of LOCA + DBE loads for the Class 1 components in the RCPB was evaluated. The LOCA loads described above were added directly to the DBE loads and compared to allowables except for the broken pipe, as discussed below. A summary of the evaluation is presented below.

For the unbroken reactor coolant piping, LOCA loads, such as jet impingement loads and differential pressure loads across the outside pipe wall, were evaluated according to Equation 9

of Subsection NB-3650 of ASME Section III. These loads, when added directly to the DBE loads, were found to be below the faulted condition limits of the piping components. The load combinations are provided in table 3.9-8. For pipe supports, the combined loads due to deadweight, DBE, and LOCA were within the manufacturer's faulted condition allowables, and shock suppressor loads were within emergency allowables. For RPV nozzles, the combined loads due to thermal expansion, deadweight, DBE, and LOCA were within the manufacturer's allowables.

For the broken reactor coolant piping, the pipe was not evaluated except for the adequacy of its whip restraints because the seismic stresses were insignificant when added to the LOCA stresses. Therefore, the design of the whip restraints, as presented in section 3.6, is considered adequate.

### **3.9.1.6 Analytical Methods for ASME Code Class 1 Components**

The analytical methods used to evaluate stresses for ASME Code Class 1 components are in conformance with Sections NB-3200 through NB-3600, and Appendix F of ASME Boiler and Pressure Vessel (B&PV) Code, Section III. As permitted by NB-3630(d) of the 1975 Summer Addenda to the ASME Code, Section III, Class 1 piping 1 in. in diameter and smaller may be alternatively analyzed according to the rules of NC-3600.

Both elastic and inelastic stress analysis techniques are used in the design of the core support and reactor internal structures to show that the stress limits, specified in tables 4.2-12 through 4.2-14, are not exceeded. When an inelastic stress analysis was performed on these components, the elastic (linear) system analysis was checked to see if it required modification. The procedure is to perform a linear analysis with the stiffness of the inelastic component reduced to the stiffness value corresponding to the inelastic displacement value. A nonlinear dynamic analysis was performed in lieu of a linear analysis if the natural frequencies of the system with reduced stiffness deviated significantly from that of the unreduced system.

Use of inelastic methods of analysis for other components is not anticipated at this time. These methods, however, may be used in those cases where it is deemed desirable and appropriate to permit significant (local) inelastic response. In these cases, if any, the system or subsystem analysis performed to establish loads which act on components and component supports is modified to include the inelastic strain compatibility in the local regions of the components and component supports at which significant (local) inelastic response is permitted.

When an elastic system analysis is employed to establish the loads which act on components and supports, elastic stress-analysis methods are also used in the design calculations to evaluate the effects of the loads on the components and supports. In particular, inelastic methods such as plastic instability and limit analysis methods, as defined in Section III of the ASME Code, Appendix F, are not used in conjunction with an elastic system analysis (except for core support and reactor internals).

Table 3.9-6 provides the load conditions for the recirculation piping system (Class 1 pipe).

### 3.9.1.7 Fatigue Monitoring of ASME Code, Section III Class 1 Piping

To account for the increase in operating life as a result of the renewed license, the cumulative fatigue usage factor (CFUF) for Class 1 piping is monitored. Bounding locations in the feedwater piping, primary steam condensate drainage, and the main steam piping are monitored (subsection 18.2.12) to ensure the CFUF for the Class 1 piping will not exceed 1.0 during operation of the plant.

## 3.9.2 ASME CODE CLASS 2 AND 3 COMPONENTS

For HNP-2, this refers to either ASME Code Class 2 and 3 components (table 3.9-9) or similar non-RCPB safety-related, pressure-retaining components designed to earlier codes. (For safety-related mechanical components not covered by the ASME Code, see table 3.9-10.)

### 3.9.2.1 Plant Conditions and Design Loading Combinations

ASME Code Class 2 and 3 components of fluid systems were constructed in accordance with Section III of the ASME B&PV Code. Some components (piping, pumps, and valves) ordered prior to July 1971 were designed to other industry codes (tables 3.2-1 and 3.2-2) when the effective ASME Section III was not applicable. The specific quality group classification for each principal component is provided in table 3.2-1.

Torus-attached piping (TAP) and safety relief valve discharge line (SRVDL) piping were designed and constructed per the NRC requirement for the Mark I Long-Term Program (LTP) as documented in the "Mark I Containment Long-Term Program Safety Evaluation Report," NUREG-0661.<sup>(6)</sup> Modifications made to SRVDL, TAP, and their supports due to hydrodynamic loads identified during the LTP are presented in supplement 3.8B.

Tables 3.9-4 and 3.9-11 through 3.9-28 list the design-loading combinations for the major components of each safety-related system.

Load combinations for ASME Code Class 2 and 3 piping are as follows:

#### A. Primary Stress

##### 1. Normal Conditions

The following combination of loads and stress limits is considered in satisfying the requirements of NC-3652.1 and ND-3652.2 of ASME Section III.

- Design pressure and deadweight  $\leq S_h$

## HNP-2-FSAR-3

### 2. Upset Conditions

The following combinations of loads and stress limits are considered in satisfying the requirements of equation (9) of NC-3652.2 and ND-3652.2 of ASME Section III:

- Maximum pressure + deadweight + OBE  $\leq 1.2 S_h$
- Maximum pressure + deadweight + relief valve opening or fast valve closure as applicable.<sup>(a)</sup>  $\leq 1.2 S_h$

### 3. Emergency Conditions

The following combination of loads and stress limits is considered in satisfying the requirements of equation (9) of NC-3652.2 and ND-3652.2 of ASME Section III:

- Maximum pressure + deadweight + OBE + fast valve closure and/or relief valve opening as applicable.<sup>(a)</sup>  $\leq S_y$   
or  
 $\leq 1.8 S_h$

### 4. Faulted Conditions

The following combination of loads and stress limits is considered in satisfying the requirements of equation (9) of NC-3652.2 and ND-3652.2 of ASME Section III:

- Maximum pressure + deadweight + DBE + fast valve closure and/or relief valve opening as applicable.<sup>(a)</sup>  $\leq 2.4 S_h$

### B. Secondary Stress

Either of the following loading combinations may be used to satisfy the requirements of NC-3652.3 and ND-3652.3 of ASME Section III:

---

a. Fast valve closure in this case is applicable only to the Class 2 portion of the main steam and the Class 3 main steam relief valve discharge piping. Relief valve opening is applicable only to main steam relief valve discharge piping and to the steam piping to the RHR heat exchanger.

## HNP-2-FSAR-3

- Thermal expansion and OBE anchor displacement stresses<sup>(a)(b)</sup>  $\leq [1.25 S_c + 0.25 S_h]$
- Design pressure + weight + maximum range of thermal expansion and OBE anchor displacement stresses<sup>(a)</sup>  $\leq 1.25 (S_c + S_h)$

The allowable stress limits for ASME Class 2 and 3 piping assumes that the total number of full-temperature cycles to which this piping will be exposed is < 7000 for the life of the plant.

### 3.9.2.2 Design Loading Combinations

The combinations of design loadings are categorized with respect to plant conditions identified as normal, upset, emergency, or faulted and are shown in tables 3.9-4 and 3.9-11 through 3.9-28 for the major components, and paragraph 3.9.2.1 for piping. For nuclear steam supply system (NSSS) design, the methods used for the various load combinations are shown in these tables. Tables 3.9-4 and 3.9-11 through 3.9-28, along with the text of sections 3.9 and 5.2, contain the required information to demonstrate conformance with criteria for ASME Class 1, 2, and 3 components or their pre-1971 code equivalents. The tables in section 3.9, when taken together with the loading combination table 3.9-29, provide the necessary information on loading combinations, design criteria, and results to demonstrate the conformance of Bechtel equipment with code requirements. The various types of loadings (design mechanical loadings, emergency condition loads, etc.) are combined by absolute sum.

Design criteria and the specific manner of combining loads for normal, upset, emergency, and faulted conditions for supports of all ASME Class 1, 2, and 3 active and inactive components and piping are now provided. Specific design criteria used for supports for active pumps and valves for both General Electric- and Bechtel-supplied equipment are presented.

Design criteria and the manner of combining loads for supports of ASME Class 1, 2 and 3 active and inactive components are provided below and in table 3.9-3.

#### A. Supports on Bechtel-Supplied Piping

Standard piping supports used on Nuclear Class 1 piping are designed in accordance with NB-3674 of the 1971 ASME Code, Section III, which further references American National Standards Institute (ANSI) B31.7, 1969, Divisions 1-720 and 1-721. Class 2 and 3 standard piping supports are designed in accordance with ASME Section III, Subsection NC-3674, with references to

---

a. Anchor displacements due to OBE may be deleted if considered with primary stresses in equation 9 of NC-3652.2 and ND-3652.2 or if not a design condition.

b. This formula contains a time-limited aging analysis based upon an assumed number of thermal cycles. The thermal cycles assumed for HNP are adequate to account for the period of extended operation during the renewed license term. (See sections 18.1 and 18.5.)

## HNP-2-FSAR-3

ANSI B31.1.0, 1967, paragraphs 120 and 121. Because the loading conditions for normal, upset, emergency, and faulted conditions are not included in these codes, the design of nonstandard linear-type supports has used the procedures of Appendix XVII-2000 of the 1974 ASME Section III. The loading combinations under the various plant conditions are presented in table 3.9-3.

Shear lugs used to hold clamps on Class 1 piping are analyzed with the Class 1 piping.

Plate and shell-type supports on Nuclear Class 1 piping are limited to the anchors and restraints at the flued heads. The effects of these supports are considered with the flued head Class 1 analyses. The supports are designed for pipe rupture loads in accordance with appendix F.

Plate and shell-type supports on Nuclear Class 2 and 3 piping are designed to the loading combinations and stress allowables provided in table 3.9-3.

In addition to the stress limits provided in table 3.9-3, a standard specified deflection of 1/16 in. is allowed under the worst combination of loadings. If deflections exceed this limit, the validity of the analysis is reviewed by a stress engineer. The deflection of whip restraints is discussed in subsection 3.6.5. The design of supplementary steel is in accordance with the American Institute of Steel Construction with the additional requirements on deflection under the worst combination of loadings.

### B. Supports on Bechtel-Supplied Equipment

Vendor-supplied equipment supports purchased by Bechtel are designed in accordance with the applicable ASME Code to which the equipment is designed. The design limits specified for pumps and tanks are such as to limit the material to no gross deformation as well as to limit the deflection to assure operability.

### C. Supports on GE-Supplied Piping and Equipment

Supports for GE-supplied components have been designed to various criteria depending on the application and previous experience with the particular equipment to be supported. With the exception of the supports for the jet pump instrumentation penetration seal and the RPV, supports for GE-supplied ASME Class 1, 2, and 3 components have been designed using one of the following approaches.

1. The Direct Addition of the Maximum Forces Resulting from Seismic Loading, Dead Loads, and Operating Loads (Fluid Flow Reaction, Thermal Expansion, Equipment Nozzle Loading from Connecting Piping, etc.) in the Weakest or Worst Direction to Establish Anchoring Requirements



## HNP-2-FSAR-3

Components for which supports were designed in this manner are:

- RHR pumps
- SLC pumps
- RHR heat exchangers
- HPCI pump
- CS pumps
- RCIC pump

The design criterion was that the stress remain within the allowable values for the holddown or anchor bolts. The results are as follows:

|                     | <u>Calculated<br/>Stress (psi)</u> | <u>Allowable<br/>Stress (psi)</u> |
|---------------------|------------------------------------|-----------------------------------|
| RHR pumps           | 2335                               | 25,000 <sup>(a)</sup>             |
| RHR heat exchangers | 8400                               | 37,800                            |
| CS pumps            | 1842                               | 25,000 <sup>(a)</sup>             |
| SLC pumps (shear)   | 5960                               | 16,500 <sup>(a)</sup>             |
| SLC pumps (tensile) | 3730                               | 16,500 <sup>(a)</sup>             |
| HPCI pump (shear)   | 3917                               | 20,000 <sup>(a)</sup>             |
| HPCI pump (tensile) | 6154                               | 7000 <sup>(a)</sup>               |
| RCIC pump           | 5070                               | 32,400 <sup>(a)</sup>             |

2. Treated as Extensions of the Piping Systems of Which They Form an Integral Part and Designed in Accordance with the Rules Governing Supports Associated with the Codes Specifying the Design Requirements for the Piping Systems

The GE-supplied piping systems are the main steam piping from the RPV through the second main steam isolation valve (MSIV) and the original recirculation system piping which have both been designed, fabricated, and supported in accordance with the 1971 Edition of Section III of the ASME B&PV Code. Components for which supports were designed in this manner are main steam safety relief valves, MSIVs, recirculation pumps, recirculation pump suction valves, and recirculation pump discharge valves.

<sup>a</sup>. Allowable value from ASME Code, Section VIII.

## HNP-2-FSAR-3

Recirculation system piping, which was replaced in 1984, was designed in accordance with the 1980 Edition of the ASME Code, Section III, Class 1 with Addenda through Winter 1981. The materials, testing, and fabrication were in accordance with the ASME Code, Section III, 1980 Edition with Addenda through Winter 1980.

As noted, two GE-supplied components do not fall into these categories. The following procedures were used to design those supports:

a. Jet Pump Instrumentation Seal

The design criteria used are those specified in Section III of the ASME B&PV Code, Subsection NB, considering pressure (A), pipe reaction (B), seismic (C), and thermal (D) loadings. The following loading combinations are considered:

- Normal and upset -  $A + B + 1/2C + D$
- Faulted -  $A + B + C$

b. Reactor Pressure Vessel Support Skirt

The structural integrity of the reactor vessel support skirt has been assured by the preparation of a stress report as required by Paragraph N-142, Section III, of the ASME Code. This report demonstrates that the support skirt has met all applicable ASME Code stress limits. Requested details of these calculations may be found in this report which is on file with the authorized inspector at the plant site.

D. For Bechtel Equipment

Valves are supported by the piping system of which they are a part. The stresses at the pipe valve junctions are held within the same limits as all other points in the piping system. The supports for Bechtel-provided active pumps are checked against the appropriate allowables by the pump manufacturer. Loads resulting from the connecting piping are considered in the analysis.

E. For GE Equipment

The recirculation piping suspension system was supplied by GE and provides supports for active components. Recirculation pump discharge valves were designed prior to the issue of any definitive standard to which either the analysis methods or the resultant stress levels could be judged. However, these active valves were treated as extensions of the piping systems of which they form an integral part and designed in accordance with the rules governing supports associated with the codes specifying the design requirements for the piping systems. The replaced recirculation system piping is designed in accordance with the 1980 Edition of Section III of the ASME B&PV Code, with Addenda through

## HNP-2-FSAR-3

Winter 1981. The materials, testing, and fabrication were in accordance with the ASME Code, Section III, 1980 Edition with Addenda through Winter 1980.

Three types of component supports have been used to support the recirculation system piping such as hangers, struts, and snubbers which are designed, fabricated, and assembled so that they cannot become disengaged by the movement of the support pipe or equipment while performing its function during the various operating conditions of the plant. The design load on each of these component supports is identified as follows:

1. Hangers

The design load on hangers is the load caused by deadweight. The hangers are calibrated to ensure that they support the design load at both their hot and cold load settings. Hangers provide a specified down travel and up travel in excess of the specified thermal movement.

2. Struts

The design load on struts includes those caused by deadweight, thermal expansion, primary seismic loads (OBE, DBE, and system anchor displacements, etc.).

3. Snubbers

The design load on snubbers includes those loads caused by seismic forces (OBE and DBE), system anchor displacements, etc.

The analyses that are used for the design of these components supports to ensure that all such supports will not deform to the extent that would impair the pressure-retaining integrity of the supported components under normal, upset, emergency, and faulted plant conditions, can essentially be divided into three parts, as given below:

- a. Piping Analysis to Determine Design Loads on Component Supports

The piping analysis is performed with GE SAP4 program. SAP4 is a general structural analysis program for static and dynamic analysis of linear elastic complex structures. The finite element displacement method is used to solve for the displacements and loads and computes the stresses of each element of the structure. The loads resulting from thermal expansion, deadweight, primary seismic loading (OBE and DBE), and system anchor displacements are first determined individually and then combined under normal, upset, emergency, and faulted plant conditions to determine the design load on the respective component support. Piping supports are then designed by the load rating method, and the load combinations for the various plant operating conditions correspond to those used to design the supported pipe. Design

## HNP-2-FSAR-3

transient cyclic data are not applicable to piping supports as no fatigue evaluation is necessary to meet the code requirements.

The recirculation pipe replacement, RHR piping between the connections to the recirculation loop suction and discharge and the head fittings, and the portion of RWC piping between the connection to the RHR suction and the penetration, were analyzed using the General Electric PISYS-05 computer program. PISYS performs static and dynamic analyses of piping systems. The analysis modules of PISYS were taken directly from the SAP4G program.

b. Selection from Vendor Data

After determining the design load by piping analysis, component supports are selected from the vendor data that indicate loads are equal to or below the load rating of the components.

c. Analysis and/or Tests to Demonstrate Acceptability

Finally, the vendor performs analyses and/or tests to demonstrate acceptability for his load rating data on component supports.

### 3.9.2.3 Design Stress Limits

For safety-related ASME Code Class 1, 2, and 3 components, the design stress limits are listed in tables 3.9-4 and 3.9-11 through 3.9-28 and paragraph 3.9.2.1. Inelastic methods as permitted by ASME Code, Section III for Class 1 components (also appendix F) were not used for these components. For Code Class 1 components, the normal, upset, and emergency conditions used in the analysis are as follows:

#### Conditions

Normal and Upset Conditions:

- RPV boltup and unbolt.<sup>(a)</sup>
- Startup (100°F/h heatup rate).<sup>(b)</sup>
- Natural circulation startup.
- Daily reduction to 75% power.<sup>(a)</sup>

a. Applied to RPV only.

b. Bulk average vessel coolant temperature change in any 1-h period.

## HNP-2-FSAR-3

- Weekly reduction to 50% power.<sup>(a)</sup>
- Control rod pattern change.<sup>(a)</sup>
- Loss of feedwater heaters:
  - Turbine trip with 100% steam bypass.
  - Partial feedwater heater bypass.
- Scram.
  - Turbine-generator trip, feedwater on, isolation valves stay open.
  - Loss of ac power, natural circulation restart.
  - Other scrams.
- Reduction to 0% power, hot standby, shutdown (100°F/h cooldown rate).<sup>(b)</sup>

### Emergency Conditions:

- Scram.
  - Loss of feedwater pumps, isolation valves closed (100°F/h).<sup>(b)</sup>
  - Single safety relief valve blowdown (177°F/10 min and 100°F/h cooldown rate).<sup>(b)</sup>
  - Automatic blowdown.
  - Reactor overpressure with delayed scram, feedwater stays on, isolation valves stay open.
- Improper start of cold RRS loop.
- Improper startup with recirculation system pumps off and drain shut off followed by turbine roll and increase to rated power.
- Faulted condition.
- Pipe rupture and blowdown.

---

a. Applied to RPV only.

b. Bulk average vessel coolant temperature change in any 1-h period.

### 3.9.2.4 Analytical and Empirical Methods for Design of Pumps and Valves

A combination of analysis, component testing, and operating experience is employed in the design of pumps and valves. Design criteria and the manner in which loads are combined for ASME Class 2 and 3 pumps and valves are provided below.

All components meet the specific requirements of the ASME Code to which they were designed. Except for Class 2 and 3 valves, Seismic Category I components have been analyzed for OBE loads combined with any identified concurrent operating transients by the absolute sum, and stresses were held within the upset stress allowable. Class 2 and 3 valves have not been analyzed for an equivalent OBE loading condition because they are shown to withstand a more severe DBE equivalent loading.

An evaluation of the direct combination of all LOCA + DBE loads for the Class 1 components in the RCPB was performed and is summarized in paragraph 3.9.1.5.

#### A. Analytical Methods

All Bechtel-supplied ASME Nuclear Class 2 or 3 active valves are designed in accordance with ANSI B16.5. Valves with extended structures which could affect pressure integrity are analyzed for a minimum of 3.0-g vertical and horizontal loading in combination with normal operating loads. These extended structures are also modeled into the piping stress analysis, and the piping stresses are held within ASME Code allowables for the loading combinations identified in paragraph 3.9.2.1.

The only Bechtel-supplied Nuclear Class 2 or 3 active pumps are the residual heat removal service water (RHRSW) and plant service water (PSW) pumps whose loading combinations are addressed in appendix A in the conformance to Regulatory Guide 1.48. Tables 3.9-30 through 3.9-32 summarize the loading combinations and the design criteria for these pumps.

A more detailed description of design criteria and the manner of combining loads for the RHR and CS pumps classified as ASME Class 2 active pumps is listed below.

Closure bolting is calculated by using Rules for Bolted Flange Connections, ASME Section VIII, Appendix II, and allowable working stresses in accordance with ASME Section VIII. The bolting loads include design pressure and temperature, design gasket load, static mass forces, nozzle loads, and seismic acceleration. The nozzle loads used are the DBE values using the worst combination of loads in the three axes of each nozzle.

Wall thickness is calculated in accordance with the rules of ASME Section VIII, Part UG, with stress limits from ASME Section VIII. Furthermore, Bijlaard analyses, using the ASME Section VIII stress limits, are performed on pressure-retaining, nozzle-shell intersections considering the loads, design pressure and temperature, static mass forces, nozzle loads, and seismic

## HNP-2-FSAR-3

acceleration. The nozzle loads used are the DBE values using the worst combination of loads in the three axes of each nozzle.

Four sets of calculations are performed:

- OBE seismic acceleration with maximum nozzle moments.
- OBE seismic acceleration with maximum nozzle forces.
- DBE seismic acceleration with maximum nozzle moments.
- DBE seismic acceleration with maximum nozzle forces.

The only GE-supplied ASME Class 2 or 3 active valves are the control rod hydraulic system valves. Design calculations and certifications are provided by the valve vendors to demonstrate that the seismic capability of the body-to-bonnet bolts, yoke (as operator support), and operator bolts are sufficient to withstand the seismic forces applied to the mass center of the operator. The calculations combine the stresses in the valve components due to seismic loads (horizontal and vertical acting simultaneously) and the stresses due to other live and dead loads along with the operating loads. These combined loads do not exceed 1.5 times the ASME Code allowable stresses. The valve will not fail to function during application of these forces. Calculations are also submitted to demonstrate compliance with Paragraphs 452.1a and 453.1 of the ASME Nuclear Pump and Valve Code.

### B. Component Testing

Active mechanical equipment classified as Seismic Category I is shown capable of performing its function during the life of the plant under postulated plant conditions. Equipment with operating condition functional requirements includes active pumps and valves in fluid systems such as the RHR system, CS system, and the isolation systems.<sup>(a)</sup>

Operability is ensured by satisfying the requirements of the following programs. Continued operability is ensured by periodic testing.

### C. Pumps

All active pumps are qualified for operability by first being subjected to rigid tests both prior to installation in the plant and after installation in the plant. The in-shop tests include hydrostatic tests of pressure-retaining parts to 1.5 times the design

---

a. Active equipment must perform a mechanical motion during the course of accomplishing a safety function.

### HNP-2-FSAR-3

pressure times the ratio of material allowable stress at room temperature to the allowable stress value at the design temperature; seal leakage tests; and performance tests, while the pump is operated with flow, to determine total developed head, minimum and maximum head, net positive suction head requirements, and other pump/motor parameters. After the pump is installed in the plant, it undergoes the cold hydro tests, functional tests, and the required periodic inservice inspection and operation. These tests demonstrate reliability of the pump for the design life of the plant.

In addition to these tests, the safety-related active pumps were analyzed for operability during a seismic condition by ensuring that the pump will not be damaged during the seismic event, and the pump will continue operating despite the addition of the seismic loads.

Performing these analyses with the conservative loads stated and with the restrictive stress limits of tables 3.9-15, 3.9-18, 3.9-20, 3.9-22, 3.9-24, and 3.9-26 as allowables ensures that critical parts of the pump will not be damaged during the seismic condition and that the reliability of the pump for post-seismic condition operation is not expected to be impaired by the seismic event.

The second criterion necessary to ensure operability is that the pump functions throughout the seismic event. The pump/motor rotor combination is designed to rotate at a constant speed under all conditions unless the rotor becomes completely seized, i.e., with no rotation. Motors are designed to withstand short periods of severe overload. Typically, the rotor can be seized 5 full seconds before a circuit breaker trips to prevent damage to the motor. However, the high rotary inertia in the operating pump rotor, and the nature of the random, short duration loading characteristics of the seismic event, will prevent the rotor from becoming seized. In actuality, the seismic loadings will cause only a slight increase, if any, in the torque (motor current) necessary to drive the pump at the constant design speed. Therefore, the pump will not shut down during the event and will operate at the design speed despite the seismic loads.

From the previous arguments, the safety-related pump/motor assemblies will not be damaged and will continue operating under seismic loadings; therefore, they will perform their intended functions. These proposed requirements take into account the complex characteristics of the pump and are sufficient to demonstrate and ensure the seismic operability of the active pumps.

The functional ability of active pumps after a seismic condition is ensured since only normal operating loads and steady-state nozzle loads exist. Since it is demonstrated that the pumps would not be damaged during the faulted condition, the post-seismic condition operating loads will be no worse than the normal plant operating limits. This is ensured by requiring that the imposed nozzle loads (steady-state loads) for normal conditions and post-seismic conditions are limited by the magnitudes of the normal condition nozzle loads. The post-seismic condition ability of the pumps to function under these applied loads is proven during the normal operating plant conditions for active pumps.



HNP-2-FSAR-3

D. Design Criteria (NSSS Design)

1. Pumps

The ASME Code allowable stresses and design calculated stresses for specific components of the various pumps are tabulated below. This tabulation shows that the design values are well within the allowable elastic limits for the materials used, thus ensuring no geometric or dimensional deformation as a result of exposure to the worst case postulated loading environment. Functional capability is, therefore, preserved for the design conditions with substantial margins.

RHR and CS Systems:

| <u>Pressure<br/>Boundary Components</u> | <u>Stresses (psi)</u> |           |                  |
|-----------------------------------------|-----------------------|-----------|------------------|
|                                         | <u>RHR</u>            | <u>CS</u> | <u>Allowable</u> |
| Suction shell                           | 6095                  | 3366      | 17500            |
| Discharge Nozzle                        | 15900                 | 11995     | 17500            |
| Suction nozzle                          | 13813                 | 9480      | 17500            |
| Nozzle head bolts                       | 22307                 | 15423     | 25000            |
| Torispherical head of shell             | 10148                 | 3179      | 17500            |
| Stuffing box                            | 2200                  | 2200      | 15000            |
| Discharge head plate                    | 7877                  | 1818      | 15000            |
| Outer column flange                     | 10334                 | 10162     | 17500            |
| Mounting bolts                          | 2335                  | 1842      | 25000            |

SLC Pump - Allowable and Calculated Stresses:

| <u>Pressure<br/>Boundary Components</u> | <u>Stresses (psi)</u> |                  |
|-----------------------------------------|-----------------------|------------------|
|                                         | <u>Calculated</u>     | <u>Allowable</u> |
| Fluid Cylinder                          | 3640                  | 17500            |
| Cylinder head extensions                | 5280                  | 17500            |
| Stuffing box                            | 10690                 | 30000            |
| Stuffing box studs                      | 16770                 | 25000            |
| Cylinder head studs                     | 17720                 | 25000            |
| Cylinder head covers                    | 1788                  | 15000            |
| Gland                                   | 3910                  | 75000            |

| <u>Nonpressure<br/>Boundary Components</u> | <u>Stresses (psi)</u> |                  |
|--------------------------------------------|-----------------------|------------------|
|                                            | <u>Calculated</u>     | <u>Allowable</u> |
| Motor holddown bolting (shear)             | 1720                  | 10000            |

### HNP-2-FSAR-3

|                                  |      |       |
|----------------------------------|------|-------|
| Motor holddown bolting (tensile) | 1230 | 16500 |
| Motor foot, integral (shear)     | 115  | 4400  |
| Pump holddown bolting (shear)    | 5960 | 16500 |
| Pump holddown bolting (tensile)  | 3730 | 16500 |

Pump analysis denotes minimum metal thickness of the fluid chamber, cylinder walls, cylinder covers, and allowable stress of bolting materials. Hydrostatic test of the assembled unit was conducted at 1.5 times the design pressure. A performance test was performed on each pump assembly as proof that the unit meets specification requirements. Preoperational testing was performed prior to the startup phase of the power test program to verify and document that equipment and system combined meet the design requirements.

#### HPCI Pump - Allowable and Calculated Stresses:

| <u>Pressure</u><br><u>Boundary Components</u> | <u>Stresses (psi)</u> |                  |
|-----------------------------------------------|-----------------------|------------------|
|                                               | <u>Calculated</u>     | <u>Allowable</u> |
| Closure bolting (main)                        | 19950                 | 20000            |
| Closure bolting (booster)                     | 17400                 | 20000            |
| Casing wall thickness (main)                  | 12050                 | 14000            |
| Casing wall thickness (booster)               | 3650                  | 14000            |

| <u>Nonpressure</u><br><u>Boundary Components</u> | <u>Stresses (psi)</u> |                  |
|--------------------------------------------------|-----------------------|------------------|
|                                                  | <u>Calculated</u>     | <u>Allowable</u> |
| Pump bolts (tensile) booster                     | 664                   | 7000             |
| Pump bolts (tensile) main                        | 996                   | 7000             |
| Dowel pins (shear) booster                       | 4990                  | 20000            |
| Dowel pins (shear) main                          | 7485                  | 20000            |
| Anchor bolt (tensile)                            | 6154                  | 7000             |
| Anchor bolt (shear)                              | 3917                  | 20000            |

**NOTE:** Eight anchor bolts carry the stresses for both units mounted on a common baseplate.

Pump analysis also denotes minimum metal thickness of pump case and the allowable stress of bolting materials. Hydrostatic test of the assembled unit was conducted at 1.5 times the design pressure. A performance test was performed on pump for proof that the unit satisfied specification requirements by measurements of developed head flow, and vibration. Preoperational testing will be performed prior to startup phase of the power test program to verify and document that equipment and system combined meet design requirements.

#### RCIC Pump - Allowable and Calculated Stresses:

HNP-2-FSAR-3

| <u>Pressure<br/>Boundary Components</u> | <u>Stresses (psi)</u> |                  |
|-----------------------------------------|-----------------------|------------------|
|                                         | <u>Calculated</u>     | <u>Allowable</u> |
| Barrel                                  | 9200                  | 17500            |
| Suction nozzle                          | 5348                  | 17500            |
| Discharge nozzle                        | 5348                  | 17500            |
| End cover bolting                       | 22600                 | 25000            |

| <u>Nonpressure<br/>Boundary Components</u> | <u>Stresses (psi)</u> |                  |
|--------------------------------------------|-----------------------|------------------|
|                                            | <u>Calculated</u>     | <u>Allowable</u> |
| Pump holddown bolting                      | 5070                  | 32400            |
| Pump taper pin                             | 9820                  | 21000            |
| Bearing housing pin                        | 1390                  | 21000            |

Pump analysis also denotes minimum metal thickness of barrel, end covers, and nozzle walls, and the allowable stress of bolting materials. Hydrostatic test of the assembled unit was done at 1.5 times the design pressure. Performance test was performed on pump for proof that the unit satisfied specification requirements by measurements of developed head, flow, and vibration. Preoperational testing was performed prior to startup phase of the power test program to verify and document that equipment and system combined meet design requirements.

E. Design Criteria for HPCI and RCIC Turbines and Bechtel-Supplied Components

1. HPCI and RCIC Turbines

Calculated stress levels were summarized in comparison with ASME Code allowable stress levels. Maximum values are tabulated as follows:

|                  | <u>Allowable Percentage</u> |             |
|------------------|-----------------------------|-------------|
|                  | <u>HPCI</u>                 | <u>RCIC</u> |
| Pressure casting | 64                          | 86          |
| Pressure bolting | 92                          | 80          |
| Structural       | 49                          | 44          |

Shaft deflections under operating loads, including seismic, are < 0.015 in. for the HPCI turbine and 0.005 in. for the RCIC turbine. These deflections are substantially less than the internal clearance (0.1875 in.) between the turbine rotor and stationary parts.

The design margins noted above provide for sufficient component dimensional stability to assure their required functional capabilities.

## 2. For Bechtel-Supplied Components

Both active and inactive pumps and valves used in a safety-related system are designed to the applicable sections of the ASME Code, Section III, and other recognized standards. The manufacturers are also required to comply with specific requirements in the design specification concerning earthquake loadings, environment conditions, and operating transients. The most severe loading condition for each component then becomes a design condition. (See table 3.9-29.) Since the ASME Code does not address operability, pumps or valves required to perform a motion to provide their safety function are so designated in the design specification and manufacturers are required to demonstrate this by testing detailed analysis or a combination of both. If testing is not practical, a detailed stress and deflection analysis is performed. Stresses are maintained below yield so that no permanent deformation occurs, and deflections are minimized so that the potential for binding or misalignment is eliminated.

Where functional capability of a piping system is required, stress levels do not exceed yield unless the effect of permanent deformation is evaluated. It is reasoned that by eliminating permanent deformation, the component will not only maintain its pressure integrity but also retain its dimensional stability. For these systems, the use of ASME Code Case 1606 and Appendix F of the ASME Code Section III is avoided.

### F. Valves

Safety-related active valves must perform their mechanical motion in times of an accident. Assurance must be supplied that these valves will operate during a seismic event. Qualification tests accompanied by analyses were conducted for all active valves. Active valves in the RCPB and other Seismic Category I systems are listed in tables 3.9-33 and 3.9-34.

The safety-related valves are subjected to a series of stringent tests prior to service and during the plant life. Prior to installation, the following tests are performed--shell hydrostatic test to the ASME Code, Section III, requirements, back seat and main seat leakage tests, disc hydrostatic test, functional tests to verify that the valve will open and close within the specified time limits when subjected to the design differential pressure and operability qualification of valve actuators.

Cold hydro qualification tests, hot functional qualification tests, and periodic inservice operation are performed in-situ to verify and ensure the functional ability of the valve. These tests and appropriate maintenance ensure operability of the valve for the design life of the plant. The valves are designed using either the standard or the alternate design rules of ASME Code, Section III. On all active valves, an analysis of the extended structure is also performed for static equivalent seismic loads applied at the center of gravity of the extended structure. These valves are required to have a lowest natural frequency of vibration  $\geq$  to 20 Hz. The

## HNP-2-FSAR-3

natural frequency has been determined by analysis of a three lumped mass cantilever beam model of the valve. This model also enables calculation of some higher mode frequencies. The maximum stress limits allowed in these analyses show structural integrity.

Valves which are safety related but can be classified as not having an overhanging structure, such as check valves and safety relief valves, are considered separately.

Due to the particular simple characteristics of the check valves, they will be qualified as follows:

- In-shop hydrostatic test.
- In-shop seat leakage test.
- Periodic in-situ valve exercising and inspection to assure the functional capability of the valve.

The safety relief valves are qualified by the following procedures. These valves are subjected to tests and stress analyses including the seismic loads, in-shop hydrostatic seat leakage, and performance tests. In addition to these tests, periodic in-situ valve inspection, as applicable, and periodic valve removal, refurbishment, performance testing, and reinstallation are performed to ensure the functional capability of the valve.

During a seismic event, it is allowed that the seismic accelerations imposed upon the valve may cause it to open momentarily and discharge under system conditions which otherwise would not result in valve opening. This is of no real safety or other consequence.

Using the methods described, all the safety-related valves in the systems are qualified for operability during a seismic event. These methods proposed conservatively simulate the seismic event and ensure that the active valves will perform their safety-related function when necessary.

### 1. MSIV

To assure that deformation of the valve body does not interfere with functional capability of the MSIV, the piping reaction loads are design limited. The axial, binding, and torsional pipe loads are separately limited to  $2 S_m$  at 500°F (41,000 psi) in the attached schedule 80 pipes.

Assuming these piping loads to be applied, the MSIV is designed in accordance with ASME B&PV Vessel Code, Section III, Class I requirements. This code limits the outer fiber stress in critical regions of the body to  $1.5 S_m$  at 500°F (29,100 psi). Thus, the body of the valve is assumed to remain elastic and assures only small deformation and operability.

## HNP-2-FSAR-3

The complete analysis of the piping and valve as a system under the worst faulted condition of the piping system causes a stress in the adjoining piping of 3289 psi or 0.14  $S_m$ . The combination of loads are those given in table 3.9-8. For this piping, the applied load stress in the critical crotch region of the valve body is 1438 psi or 0.07  $S_m$  which is well below the yield point of 1.5  $S_m$ .

With respect to the functional capability of the bonnet, body flange, and associated bolting, the piping-induced loads, due to dynamic motion, are limited by design to 1.5-g horizontal and 0.6-g vertical applied at the greater center of mass. These components are designed to remain below 1.5  $S_m$ , and they are elastic under the worst faulted loading condition of the piping as described in table 3.9-8.

Under these conditions, the maximum calculated stress in studs is 45,000 psi or 65% of allowable. Calculated required thickness of the bonnet is 4.34 in. Actual thickness of bonnet is 6.33 in. or 46% greater than required. The body flange was evaluated for stress and was determined to have a maximum stress of 29,977 psi or 83% of allowable.

All the above components were analyzed by using the code method of converting moments and forces from design acceleration loads to equivalent pressure. These calculations assume that piping-induced dynamic loads are at the design limit of 1.5-g horizontal and 0.6-g vertical.

The valve actuator assembly was analyzed for design accelerations. The induced loads were resolved into a single-load vector and applied at the actuator center of gravity. Each actuator component was evaluated and stress determined. The maximum stress calculated was 33,400 psi or 80% of allowable which is 90% of yield strength. Steamline system, calculated-acceleration values were 0.64-g horizontal and 0.12-g vertical. These values are 43% and 20% of design accelerations, respectively. Finally, static deflection tests completed on this configuration determined that the valve remained operable up to a load equivalent of 4.3 g applied perpendicular to the actuator centerline before the closure speed was effected. The valve continued to operate as the load was increased to 5.7 g. The functional capability of the operator, stem and guidance system has been demonstrated to be over 3.3 times the loads applied as calculated by the piping analysis reported in table 3.9-14.

Two of the four MSIVs are mounted at 35 degrees from the main steam pipe vertical centerline. The effects of this rotation on the pipe centerline are to decrease the seismic effect on the valve top works. This occurs due to the difference of the horizontal and vertical components. Also, the valve closing time will not be affected by this rotation since the closing force is reduced by < 1%. The variable-flow hydraulic control valves will automatically compensate for this extremely small loss of driving force.

The analysis and tests reported above assures functional capability of the MSIV to close under the worst-faulted conditions of the piping system. To assure that the disc and stationary seat of the valve seal to prevent long-term low-volume leakage, the long-term piping-applied loads (table 3.9-14) on the valve are limited to  $0.75 S_m$  in the connecting pipe. The analysis of the piping system has shown that after the dynamic loads have ceased, the actual piping stress is  $0.18 S_m$ .

## 2. Recirculation Valves

The recirculation gate valves are analyzed in accordance with the requirements of the ASME Code, Section III, for Class I valves. The code requires that the secondary stress level in the valve critical crotch area due to the individual effects of axial, bending and torsion shall be  $1.5 S_m$  or less at  $500^\circ\text{F}$  for the valve body material. This requirement assures the adequacy of the valve body to safely transmit forces and moments imposed by the connecting pipe and guarantees that the valve body material will remain within the elastic range while exposed to the worst combination of pipe reaction loads.

The pressure integrity of the valve assembly involves, not only the valve body, but also the body-to-bonnet pressure boundary bolting. This pressure boundary bolting must meet ASME Code and ANSI B 31.7 requirements. These requirements are met by calculating a minimum bolting area using the actual flange dimensions and the flange design pressure,  $P_{FD}$ . The term  $P_{FD}$  includes the seismic loading components as well as valve design pressure. Thus calculated, the minimum required bolting area is  $37.53 \text{ in.}^2$  for the suction valve and  $44.41 \text{ in.}^2$  for the discharge valve. The actual bolting area in both cases is  $55.86 \text{ in.}^2$  which is 49% greater than required for this suction valve and 26% greater than required for the discharge valve. These margins, above already conservative bolting areas, assure the pressure integrity of the body-to-bonnet pressure boundary bolting.

Pressure integrity as described in the preceding discussion is all that is required of the suction valve. Only the discharge valve is required to operate in a LOCA condition. The required operation of the discharge valve is closure. There are three areas to be considered for discharge valve operation--the valve body, the stem, and the actuator. The valve body must not deform as a result of the loading environment so that the gates can move properly to the seating position. As previously mentioned, the design criteria of  $1.5 S_m$  maintains the body within the elastic range and precludes deformation. Thus, evaluation of the valve body determines that it will not interfere with valve operability.

Consideration of the stem requires that it must have free movement through the packing to lower the gates to the seating position. Calculations to evaluate stem buckling prove that the stem will not buckle (deflect) under a direct summation of operator thrust and vertical seismic loads. Stem

deflection was found to occur; however, due to horizontal seismic loading on the valve extended mass. The valve extended mass consists of the actuator, yoke, and stem assembly. Actuator deflection was determined by assuming that the mass of the entire assembly acts on the actuator horizontal centerline. Then, a linear deflection distribution along the stem was assumed for conservatism, and the stem deflection at the top of the packing box was determined. This deflection is only 40% of the packing box and stem-machining tolerance when using design seismic loadings.

With the seismic loadings as determined by the stress analysis using the loading combination presented in table 3.9-16, the stem deflection at the packing box is 16% of the machining tolerance. Therefore, it is assured that there will be no interference between the stem and the packing box to hamper valve operability.

Lastly, valve operability is ultimately dependent on the performance of the actuator. The suction valve actuator used is manufactured by Limitorque and has been generically qualified to Institute of Electrical and Electronics Engineers (IEEE) 382-1972 which specifically calls for IEEE 344-1971 and IEEE 323-1971, thus proving its operability by test. The suction valve actuator is not required to be qualified under 10 CFR 50.49. The test, which lasted 30 days, was conducted by the Franklin Institute Research Laboratory in September 1972. The actuator is qualified to 5.8 g at 35 Hz which is in excess of the expected seismic loadings provided in table 3.9-16. The discharge valve is qualified to IEEE 382-1972, IEEE 344-1975, and IEEE 323-1974; and is qualified to be operable to 340°F with an external pressure of 105 psig, the saturated pressure of steam at that temperature.

The three areas for consideration of valve operability have been evaluated, and the closure of the discharge valve in a LOCA condition is assured.

### 3. Main Steam Safety Relief Valves

The main steam safety relief valves are designed in accordance with the requirements of the ASME Code, Section III, for Class 1 components. The Code requires that the stress levels in the critical crotch area of the valve due to axial, bending, and torsional effects shall be  $\leq 1.5 S_m$  of the valve body material at 500°F. This criterion assures the adequacy of the valve body for safely transmitting the forces and moments imposed by the connecting pipe since it assures that the valve body material will remain within the elastic limit and maintain its pressure integrity. The maximum stress level in the valve body is 10,406 psi or 0.54  $S_m$ , which is only 38% of the permitted elastic design load limit of 1.5  $S_m$ . Operability of the main steam safety relief valves under both normal conditions has been demonstrated by bench tests. Since the valve design consists of components that are not deflection limited and reaction during valve operation comprises the major portion of worst-case loading, it is concluded that the valve will remain operable under the worst-case loading.



## HNP-2-FSAR-3

### G. Vital Pump and Valve Appurtenances

All appurtenances vital to the operation of active pumps and valves have been qualified by testing, analysis, or a combination of both.

The operability of certain appurtenances has been qualified by the equipment vendors through dynamic testing programs described below. Results of representative analyses for those components not qualified by testing are provided in tables 3.9-4, 3.9-11 through 3.9-28, and 3.9-35 through 3.9-64. Where analyses are performed, it is verified that deflections produced by seismic loadings do not limit the operability of the component.

#### 1. Qualification Test of National Acme Company Snap-Lock Electric Switch D 2400X-2

A seismic qualification test program of National Acme snap-lock electric switch D 2400X-2 was conducted by Fisher Controls Company and reported in document 1529 dated November 2, 1972. Testing was conducted with the switch assembly fastened to a metal plate which in turn was attached to a shaker table. All tests were conducted with the switch in an operating condition. The following is a summary of the test procedure and results:

##### a. Test Procedure

Conduct a continuous frequency sweep for each of the 3 axes, from 5 to 60 Hz at an acceleration level of 1.0 g in not < 31 s.

If the resonant frequency is < 33 Hz, conduct a 4 g, 1-min dwell at the resonant frequency and at 10 and 33 Hz.

If the resonant frequency is > 33 Hz, conduct a 4 g, 1-min dwell at 10, 17, 25, and 33 Hz and at the resonant frequency if it is < 60 Hz.

##### b. Test Results

The snap-lock electric switch performed satisfactorily with no malfunctions noted and meets or exceeds the specifications outlined in the test procedure.

#### 2. Qualification Testing of Valve Motor Operators

An ongoing program of seismic and environmental testing dating back to 1968 was undertaken by Limatorque Corporation on their valve motor operators.

A seismic qualification test program was conducted by Lockheed Electronics Company for Limatorque Corporation, and the results are included in reports

## HNP-2-FSAR-3

issued by Limatorque on January 2, 1969 (Engineering Order 600198), and June 2, 1972 (Engineering Order 600374).

The 1969 report includes results of a test in which the valve operator was subjected to an exploratory scan of 5 Hz to 35 Hz. No critical resonant frequencies were observed during this scan. The unit was also subjected to a 5.3-g load at 35 Hz in each of 3 different axes a total of 2 min on, 1 min off, 3 times per axis. The unit was operated electrically to both the fully open and fully closed positions. All torque and limit switches functioned properly.

In the 1972 report, the unit was subjected to 2 exploratory scans over the frequency range of 5 to 60 Hz. These scans indicated no resonances except at 44 Hz in the Y axis, 46 Hz in the Z axis, and 39 Hz in the X axis. Two 1-min dwells were performed at the resonant frequency at a nominal input of 3 to 5.8 g with the first minute of vibration followed by 1 min of rest.

The results of these tests showed no loss of operability either during or after the loads were applied.

### a. Excess Flow Check Valves

The excess flow check valves supplied by Marotta Scientific Controls, Inc., were put through a seismic qualification test program at American Environments Company, Inc., and the results are reported in Marotta's seismic test report dated October 8, 1975 (Code 99657).

The valves were subjected to a biaxial continuous-sine-sweep test over the frequency range of 1 to 35 Hz. The continuous-sine-sweep test was performed simultaneously in each of two mutually perpendicular axes (including the vertical) at an angle of 45 degrees from the horizontal axis. The input excitation level was 1-g peak horizontal and 1-g peak vertical.

The valves were tested in three operating conditions during the seismic loading: valve open (inlet pressurized to 1100 psig with the outlet blank), valve closed (inlet pressurized to 1100 psig with the outlet open to the atmosphere), and valve closing excess flow (inlet pressurized to 1100 psig with outlet blocked then quickly opened to the atmosphere).

The results of the tests indicated that no physical damage or seat leakage occurred as a result of the seismic loading.

### b. Solenoid Valves

The Y-pattern solenoid valves supplied by Target Rock Corporation (used in the RHR system) have been qualified by an extensive environmental and seismic test program conducted by East-West Technology Corporation.

## HNP-2-FSAR-3

The seismic test procedure consisted of exploratory scans from 1 to 33 Hz at 0.2 g to determine whether any resonant frequencies existed. These scans revealed resonances at 16.5, 20, and 26.5 Hz in the major horizontal axis, 9, 17.5, and 26.5 Hz in the minor horizontal axis, and 21 Hz in the vertical axis.

Resonance dwells were then performed at 3 g and 4.5 g at each of the resonance frequencies with the valve being operated during and after the load applications.

The results of these tests, recorded in Target Rock Corporation Report 1500, dated October 22, 1974, show no loss of operability either during or after seismic load application.

The above descriptions demonstrate a prudent operability assurance program for active pumps and valves that is a reasonable balance between testing and analytical methods.

The solenoid air valve assembly (together with the supporting brackets) used for controlling power actuation of the main steam safety relief valves was dynamically tested to demonstrate that no resonant frequency exists below 33 Hz, and the assembly does not suffer any damage when subjected to vibration input at 33 Hz of 3.0-g vertical and 4.5-g horizontal accelerations.

Recirculation suction valves operators were qualified by testing to IEEE 382-1972 (IEEE Trial-Use Guide for Type Test of Class 1 Electric Valve Operators for Nuclear Power Generating Stations) and to IEEE 344-1971 (Trial-Use Guide for Seismic Qualification of Class 1 Electric Equipment for Nuclear Power Generating Stations) by Limitorque Corporation in September 1972. The suction valve actuator is not required to be qualified under 10 CFR 50.49. (See detail on their Franklin Institute Test Report Number F-C3441.) The discharge valve operators are qualified to IEEE 382-1972 and IEEE 344-1975.

### **3.9.2.5 Design and Installation Criteria, Pressure-Relieving Devices**

Nuclear Class 2 and 3 system components, other than the main steam relief valve piping, are protected from overpressure by the installation of pressure-relieving devices in accordance with ASME Code, Section III, Class 2 or 3. The design of pressure-relieving devices can be generally grouped in two categories, open discharge, and closed discharge.

#### **A. Open Discharge**

An open discharge is characterized by a relief valve discharge elbow open to the atmosphere.

The design of relief valve stations includes the considerations of both local stresses at the header-to-relief valve-inlet piping junction and the stresses in the relief valve-inlet piping and header.

Forces and moments on the piping resulting from thrust developed by full opening of the relief valve are considered in the stress analysis. The reaction forces are calculated in accordance with ASME Code Case 1569 using a dynamic load factor of 2. A static analysis of the piping system is performed by applying the calculated force at the pipe discharge exit. The resulting stresses at all points in the piping system are combined with other loading as described in paragraph 3.9.2.1, and the total piping stresses are maintained within ASME Code allowables.

In lieu of the above procedure, a time-history dynamic calculation may be used.

B. Closed Discharge

Nuclear Class 2 and 3 relief valve discharge piping systems > 2 in. in diameter with long discharge piping runs or with discharges submerged in water are analyzed by using RVDFT. This program is based on finite different solutions by the methods of characteristics. The computed transient pressure, velocity and density are then used to calculate loads on the piping system. These loads will be employed to obtain the dynamic effect on the piping system using a dynamic time-history analysis. The resulting stresses are combined with other loadings as described in paragraph 3.9.2.1, and the total stresses are maintained within ASME Code allowables.

Two-in. and under closed discharge piping systems are analyzed by considering pressure and momentum effects at each change in flow direction. A dynamic time-history analysis is performed using conservative forces, and the combined stresses are held within ASME Code allowables.

**3.9.2.6 Stress Levels for Seismic Category I Components**

Stress analysis was used to determine structural adequacy of pressure components under the operating conditions of normal, upset, emergency, or faulted as applicable.

Significant discontinuities were considered such as nozzles, flanges, etc. In addition to the design calculations required by the ASME Code, stress analysis was performed by methods outlined in the ASME Code appendices or by other methods by reference to analogous codes or other published literature.

Tables 3.9-4 and 3.9-11 through 3.9-28 give calculated stress levels, or maximum allowable loadings at significant areas of consideration for the major components of GE supply. Stress levels for major Seismic Category I components that are not supplied by GE are presented in tables 3.9-36 through 3.9-64. Stress levels for Holtec spent-fuel storage racks are presented in table 3.9-27 (sheet 3 of 3).

Stress levels for safety-related Seismic Category I piping systems above 2 in. in diameter are provided in HNP-2 stress calculations which were reviewed and revised (if necessary) as part of the overall pipe stress reanalysis effort for NRC Inspection and Enforcement Bulletin (IEB) 79-14.

### **3.9.2.7 Field Run Piping Systems**

Except for a few cases where space was limited during construction, all 2-in. and under piping, regardless of nuclear or seismic class, was field run.

Seismic Category I piping systems are delineated in subsection 3.2.1 and in addition all 2-in. and under branch lines from these systems are also classified Seismic Category I to the first valve or other Seismic Category I component. The piping is seismically restrained and analyzed to the first anchor beyond the valve.

A design guide for use by field personnel was written to establish simplified procedures for designing and installing 2-in. and under piping. The design guide specified minimum support lengths to keep seismic response frequencies over 20 Hz and to support weight loads. The guide specified minimum offset lengths on pipe runs so that thermal expansion stresses did not exceed code allowables. Standard pipe support designs were also established to ensure adequate support design. The as-built isometrics were then sent to the engineering office for review. Where the limits of an equivalent dynamic analysis were exceeded, a dynamic analysis was performed.

The necessary changes in routing or restraints were indicated on the isometrics which were returned to the field for implementation. The revised drawing was then returned to the engineering office for approval. Once the field obtained an approved drawing, a surveillance was conducted to ensure that the as-built condition and the drawing agreed.

### **3.9.2.8 Inspection and Testing**

Inservice testing of ASME Code Class 1, 2, and 3 pumps and valves shall be performed in accordance with ASME Code Section XI and applicable Addenda as required by 10 CFR 50.55a(g), except where the NRC granted specific written relief pursuant to 10 CFR 50.55a(g)(6)(i). The preservice program is presented in subsection 5.2.8, and the inservice program is provided under separate cover.

### **3.9.2.9 Computer Programs**

#### **A. GE**

The SAP computer program used for the main steam piping analysis is described in Appendix 5A of the 238 GESSAR.

## HNP-2-FSAR-3

The PISYS-05 computer program used for the replaced recirculation piping performs static and dynamic analyses of piping systems. The analysis modules of PISYS were taken directly from the SAP4G program. The SAMIS computer program was used in the dynamic analysis of the hydraulic control units control rod drive (CRD) and in the analysis of the RPV support skirt and stabilizer. This program is described in Appendix 5A of the 238 GESSAR.

The MASS computer program was the principal computer program used in the design of the core structure for HNP-2. The MASS program can be described as an elemental or lumped-parameter approach (even though distributed properties are considered) for the analysis of redundant structures. The modeling of a complex structure is possible due to the variety of elements contained in MASS such as three-dimensional straight, curved, and segmented beams, tubes, and special connectors. The inputs to MASS are mechanical loadings (including maneuver), thermal gradients, and deflections. The inputs of MASS are stresses, loads, and deflections. MASS has been used in the design of the top guide, core support, shroud and shroud head, steam dryer, and CS lines chiefly as a tool for predicting load distributions and deflections with a structure. Other uses of MASS are not known since MASS has been available for use throughout the division. The MASS program has been design reviewed in accordance with Nuclear Regulatory Commission, Standard Review Plan 3.9.1 guidelines, using the standard BWRSD design control procedure for verification of computer codes used in design analysis.

### B. Bechtel

The following computer programs have been used in the analysis of Seismic Category I piping:

#### 1. ME-632/ME-101

##### a. Description

###### Purpose

The stresses and loads in piping systems due to restrained expansion, deadweight, seismic movement, and earthquake are calculated using the ME-632 computer program.

###### Method of Analysis

The stiffness method of finite element analysis has been used in this program. In this method, the displacement of the joints of a given structure are considered to be the basic unknowns. The dynamic analysis is by the modal synthesis method. The modal synthesis, in principle, exploits known maximum accelerations produced in a single degree-of-freedom model of certain frequency. The programs principal assumptions are:

## HNP-2-FSAR-3

- Linearly elastic structure.
- Response spectrum input for seismic analysis; force time-history input for time-history analysis.
- Lumped mass model satisfactorily replaces the structure.
- Modal synthesis is applicable for seismic analysis.
- Rotational inertias of the masses have negligible effect.

### b. Extent of Application

The program was used for the above purpose on all piping lines which require seismic, thermal, weight, or time-history analysis.

### c. Design Control Measures

The following is a comparison of the ME-632 program results with the results of the previously approved Engineering Data System computer program.

#### Example:

The two piping systems chosen for stress checks were:

- Core Spray Piping System - Monticello Nuclear Generating Plant-Unit 1
- Lines 48223-18-HE, 50056-10-HE, 50057-10-HE-SMUD Rancho Seco-Unit 1

These two test cases were chosen because independent piping stress analyses performed by Engineering Data Systems under contract to Bechtel were available for comparison purposes. The engineering data systems analysis of the CS piping system consisted of both dead weight and thermal loading, while the SMUD Rancho Seco piping system was an earthquake response spectrum analysis.

The ME-632 piping stress analyses were performed in the period September 18-29, 1972, on the PICC Honeywell 635 computer. A relocatable binary deck of the program is stored on tape no. 8312 and will be retained indefinitely for documentation purposes.

The following stress analyses were performed using the ME-632 piping stress analysis computer program:

## HNP-2-FSAR-3

Monticello Nuclear Power Plant  
Core Spray Piping System, Unit 1

Deadweight, thermal  
with anchor movements

SMUD Rancho Seco, Unit 1  
(Lines 48223-18-HE,  
50056-10-HE, 50057-10-HE)

Earthquake

The resulting forces, moments, deflections, and stresses were compared with independent analyses performed on the same piping systems using the same loadings. A comparison of results showed that differences in the output quantities were < 5% based upon the corresponding maximum value.

Based upon these results, the ME-632 program may be used with confidence to analyze piping systems per the ASME, Section III, Nuclear Piping Code.

The purpose and method of analysis of ME101 is essentially the same as ME-632.



## HNP-2-FSAR-3

### 2. ME-660/ME-661/ME-662

#### a. Description

##### Purpose

The purpose of the ME-660, -661, -662 program was to determine the temperature and stress distribution within a body as a function of time when subjected to thermal and/or mechanical loads. The program is valid for axisymmetric or plane structures and would typically be used for gross or local discontinuity analysis as described in paragraphs NB-3213.2 and NB-3213.3 of the ASME Code, Section III.

##### Method of Analysis

The program consists of three parts each of which can be used separately. The first part, ME-660, calculates steady-state or transient temperature distributions due to temperature or heat flux inputs. The method used is the finite element technique coupled with a step-by-step time integration procedure. The program adopts a stepwise description of environmental temperatures and heat-transfer coefficients if they are time dependent. Transient temperature distributions are calculated from the specified initial temperature and the step function heat inputs. ME-660 is for plane and axisymmetrical structures.

The second part of the program, ME-661, is built on the displacement method of the matrix theory of structures which calculates the displacements and stresses within the solids with orthotropic, temperature-dependent, nonlinear material properties. ME-661 is also for plane and axisymmetrical structures.

The third part of the program, ME-662, calculates the steady state or transient temperature distribution due to temperature or heat flux inputs. The output of this program gives the code required parameters, i.e.,  $\Delta t_1$ ,  $\Delta t_2$ ,  $T_a$ , and  $T_b$ , where:  $\Delta t_1$  is the linear thermal gradient,  $\Delta t_2$  is the nonlinear thermal gradient, and  $T_a$  and  $T_b$  are the average temperature on side a and b of a gross discontinuity. ME-662 is for straight pipe only.

#### b. Extent of Application

The program was used to calculate  $\Delta T_1$ ,  $\Delta T_2$ , and  $|T_a - T_b|$  terms for the analysis of ASME Nuclear Class 1 piping systems.

## HNP-2-FSAR-3

### c. Design Control Measures

The program has been verified by solving a problem and comparing the results to the solution of an identical problem obtained by hand calculation. The results were almost identical.

### 3. ME-913

#### a. Description

##### Purpose

ME-913 program consists of numerical calculations of stress intensity levels for Class 1 nuclear power piping components to validate their design adequacy.

##### Method of Analysis

The program determines the stress intensity levels of Class 1 nuclear power piping components for equations 9 through 14 of Subarticle NB-3650, Analysis of Piping Components, Section III, ASME B&PV Code. The method is described in detail in that subarticle.

Prior to running this program, the user analyzes the piping system using flexibility analysis program ME-632 and heat transfer program ME-662. The inputs to this program are the following:

- Piping configuration.
- Piping and piping component properties.
- Moment reactions due to:
  - Thermal expansion loads
  - Weight loads
  - Earthquake loads
- The thermal response of the piping system due to the specified transients:  $\Delta T_1$ ,  $\Delta T_2$ ,  $T_a$ , and  $T_b$  values for the selected points in the system.

## HNP-2-FSAR-3

### b. Extent of Application

The ME-913 program was used to calculate stress intensity levels and fatigue usage factors for all Bechtel-supplied ASME Nuclear Class 1 piping.

### c. Design Control Measures

Stress analyses were performed using ME-913 code compliance computer program for the following examples:

- Sample Analysis of a Class 1 piping system prepared by the working group on piping of the ASME B&PV Code
- Analysis of main feedwater piping inside containment for Grand Gulf-Units 1 and 2 of Mississippi Power and Light Company

The resulting stresses were compared with the results from working group calculations and hand computations performed on the same piping systems using same loadings. A comparison of results showed that the differences in the output quantities were very conservative based on the corresponding maximum value. Judging from these results, the ME-913 program may be used with confidence to analyze Nuclear Class 1 piping systems per ASME Section III.

## 4. TRHEAT

### a. Description

TRHEAT, which was developed by the Nuclear Service Corporation of Campbell, California, is a digital computer program which determines the temperature response of a pipe due to a temperature transient in the contained fluid. The fluid temperature transient may be described as a step change from an initial to a final temperature, a ramp change terminating in a constant temperature plateau, or a series of time versus temperature points. TRHEAT results include the equivalent linear and nonlinear pipe wall temperature gradients and the discontinuity temperature differences required for calculations of piping stresses in accordance with the requirements for Class 1 piping specified in the ASME B&PV Code, Section III, Nuclear Power Plant Components.

The method of analysis used is a closed-form solution to the basic heat transfer partial differential equation.

## HNP-2-FSAR-3

### b. Extent of Application

The TRHEAT program was used to calculate  $\Delta T_1$ ,  $\Delta T_2$ , and  $|T_a - T_b|$  terms for the analysis of ASME Nuclear Class 1 piping systems.

### c. Design Control Measures

TRHEAT has been verified by the originator of the program, Nuclear Services Corporation.

## 5. SAP

### a. Description

The SAP is a finite element computer program that is used to perform linear, elastic analyses of three-dimensional structural systems. The program is capable of performing static analyses, modal extractions, and dynamic response analyses on structures composed of any combination of a variety of modeling elements.

### b. Extent of Application

The SAP was used to analyze the main steam piping for the effects of turbine stop valve closure and relief valve lifting as described in paragraph 3.9.1.1. This analysis was done by GE.

### c. Design Control Measures

The program has been in existence many years and has been used for many applications in industry.

## 6. RVDFT

### a. Description

The program was developed to analyze the effects of transient flows resulting from actuation of relief valves in closed discharge systems.

The analysis considers the steam flow, the flow of the air originally in the pipe, and the water slug at the submerged end. The method of characteristic was adopted for the analysis of the resulting unsteady pipe flows. The steam and air are treated as ideal gases while the water is dealt with as a compressible liquid (conventional hydraulic transients approach). The analysis uses a unique procedure for modeling the motion of the air and water interface during the transient. The computer code RVDFT was developed to predict pressure, velocity and density changes with time along the pipe. The computed flow

## HNP-2-FSAR-3

results are used to predict piping loads (dynamic forcing functions used for the structural design of the discharge pipe). The analysis is applicable to Mark I, Mark II, and Mark III containments as well as PWR quencher tanks.

b. Extent of Application

The program was used in the analysis of the main steam safety relief valve piping in the suppression chamber and the RHR relief valve piping.

c. Design Control Measures

A comparison of the program solution and actual test results taken at Quad Cities-Unit 2 was made. There is good agreement between the pressure measurements and the values predicted by the program.

C. S. Levy, Inc.

1. ANSYS

a. Description

ANSYS, Revision 3, which was developed by the Swanson Analysis Systems, Inc., is a general purpose computer program that can be used to solve several classes of engineering analysis problems. Analysis capabilities include static and dynamic; elastic, plastic, creep, and swelling; small and large deflections; steady-state and transient heat transfer and fluid flow. The matrix displacement method of analysis based on finite element idealization is used in the code. The ANSYS program has the capability of analyzing two- and three-dimensional frame structures, piping systems, two-dimensional plane and axisymmetric solids, three-dimensional solids, flat plates, and three-dimensional shells and nonlinear problems, including interfaces and cables.

Loading on the structure may be forces, displacements, pressures, temperatures, or response spectra. Loadings may be time functions for linear and nonlinear dynamic analysis. The ANSYS program uses the wave front direct solution method for the system of simultaneous linear equations developed by the matrix displacement method.

b. Extent of Application

The ANSYS code was used in the seismic analysis performed to evaluate the use of 80-mil fuel assembly channels. The seismic analysis methodology employed used the conservative response spectrum method with the ANSYS code.

c. Design Control Measures

The ANSYS code is a publicly available code which is appropriate for this application. An independent verification was performed to confirm that the assumptions and method of analysis are reasonable and that the results are consistent with a previous independent analysis method.

D. Zentech, Inc.

1. Description

ZENPIPE is a computer program that may be used to evaluate the static and dynamic performance of piping systems under various loading conditions. The program is marketed and supported by Zentech, Inc.

ZENPIPE utilizes the stiffness method to simultaneously analyze complex piping systems for any combination of multiple thermal, pressure, uniform support displacement, and concentrated force/moment loadings. A weight analysis may also be performed. Any of these static load combinations can be intermixed with a shock loading which may be determined by response spectrum analysis, response history by mode superposition, or response history by direct integration. Stresses for each loading or loading combination are calculated in accordance with the specified code and may be checked for code compliance at the user's option. ZENPIPE generates a full code compliance report for the ANSI Code B31.1, as well as the ASME Code, Section III, Division 1, Class 2 and 3.

2. Extent of Application

ZENPIPE has been used for thermal and weight, seismic analysis on ASME Class 2 and 3, and ANSI B31.1 piping in both nuclear and balance-of-plant systems.

3. Design Control Measures

The ZENPIPE computer code has been tested against the piping benchmark problems (dynamic analysis uniform support motion response spectrum method) in NUREG/CR-1677, BNL-NUREG-51267, Vol. I. The computer program was used to model seven piping systems for spectrum analysis. Mode shapes, response displacements, and support loads were reviewed, and the outputs obtained from the program were compared to those listed in NUREG/CR-1677, BNL-NUREG-51267, Vol. I. Resulting stress and code compliance was checked against hand calculations and other widely used piping software. Overall, ZENPIPE performed as expected. The accuracy it yields is within an acceptable range for engineering calculation, and this is suitable for Quality Class Category 1 calculations.

E. SST Systems, Inc.

The following computer programs were used in the analysis of Seismic Category I piping:

- CAEPIPE.
- PS+CAEPIPE.

1. CAEPIPE

a. Description

CAEPIPE is a PC-based piping stress analysis program for the nuclear, power, and petroleum industries. The software was developed and is distributed by SST Systems, Inc. Static and dynamic analyses (calculations of loads, pipe forces, displacements, mode shapes, etc.) may be performed. The piping system can be subjected to multiple load cases of different types such as thermal and seismic loads and checked for code compliance (ANSI, ASME, etc.)

b. Extent of Application

The software is classified as a Computer Software for Safety-Related Application. This program has been used for thermal and weight, seismic analysis on ASME Class 2 and 3, and ANSI B31.1 piping in both nuclear and balance-of-plant systems.

c. Design Control Measures

The CAEPIPE computer program has been benchmarked against the three test problems in NUREG/CR-1677, BNL-NUREG-51267, Vol. I, applicable to the capabilities of the program. All outputs were comparable. Based on this review, CAEPIPE is acceptable for Quality Class Category 1 calculations. It has also been benchmarked against other computer programs (e.g., ADLPIPE, TPIPE, NUPIPE, and WESTDYN), and it produced equally acceptable results.

2. PS+CAEPIPE

a. Description

PS+CAEPIPE is a group of interrelated computer programs for performing linear elastic analysis of three-dimensional piping systems subject to a variety of loading conditions. Nuclear and conventional power generation piping systems may be investigated for compliance with piping codes and with other constraints on system response. The

## HNP-2-FSAR-3

software was developed by DST Computer Services and SST Systems, Inc.

PS+CAEPIPE includes the PIPESTRESS software. PIPESTRESS has advanced static and dynamic analysis capabilities including detailed uniform and multi-level response spectrum analyses, time history and fatigue calculations, and multiple load cases and load combinations. Stresses due to internal pressure are calculated according to the code. PIPESTRESS solves static problems by constructing a linear finite element model of the piping system using the load-deflection relationships based on the displacement method. Dynamic analysis calculates bound solutions or time history solutions for dynamic loads, which may be described by response spectra or time history data. The dynamic analysis methods used by PIPESTRESS are Modal Extraction, Single or Multi-level Response Analysis, Multi-modal/Multi-level Response Analysis, Generalized Response Analysis, Selective Time History Analysis, Left-Out-Force Method, and Primary and Secondary Terms involved in Multi-level Response Analysis. Thermal transient analysis can be performed using a finite difference approximation to find thermal gradients in the pipe walls, thereby determining the maximum value during the transient analysis of the various stress terms. Fluid properties are calculated as functions of instantaneous transient fluid temperatures and pressures.

### b. Extent of Application

The software is classified as a Computer Software for Safety-Related Application. This program has been used for thermal and weight, seismic analysis on ASME Class 2 and 3, and ANSI B31.1 piping in both nuclear and balance-of-plant systems.

### c. Design Control Measures

PS+CAEPIPE was benchmarked against all seven test problems in NUREG/CR-1677, BNL-NUREG-51267, Vol. I, and against the entire set of test problems in NUREG/CR-1677, BNL-NUREG-51267, Vol. II. These permitted the verification of the analysis methods implemented in PIPESTRESS. The program was verified under a nuclear quality assurance program established in accordance with 10 CFR 50, Appendix B, and 10 CFR 21. The verification was directed by personnel competent in the design of ASME Section III, Nuclear Power Plant Components, Class 1, 2, and 3 nuclear power plant piping under ASME nuclear quality assurance procedures. The program performs calculations in accordance with the requirements and intention of Subarticles NC/ND-3600 of ASME, Section III. PIPESTRESS has been used to analyze piping for more than 100 nuclear power plants, and for numerous conventional power plants, chemical plants, oil refineries, and other process plants.



### 3.9.3 COMPONENTS NOT COVERED BY ASME CODE

#### 3.9.3.1 General

Safety-related mechanical components not covered by the ASME B&PV Code are identified in table 3.9-10. The design codes for each principal component are identified and qualification methods for such equipment are summarized herein. This subsection specifically addresses the details of the mechanical design and analytical procedures for the design of the fuel; the methods and procedures used to determine the operability of the CRD and control rod insertability under LOCA and seismic loadings; mechanical design and loading criteria for HPCI and RCIC turbines; and applicable standards, codes, and testing for heating, ventilation, and air-conditioning (HVAC) equipment.

#### 3.9.3.2 Fuel Mechanical Design and Analytical Procedures

The fuel bundle performance history is specified by the design reference fuel cycle as defined in subsection 4.2.1. Performance of individual fuel rods is then determined from the fuel-bundle performance history coupled with the exposure-dependent design, local and axial power, and exposure-peaking factors. The most limiting fuel rods within the peak performance fuel bundle, with respect to power and exposure combination, are then analyzed to determine thermal and mechanical performance characteristics.

The performance of all fuel rods satisfies the requirements identified in paragraph 4.2.1.1. Satisfaction of these requirements for all fuel rods is demonstrated by analysis of the performance of the most limiting fuel rods with respect to power and exposure level identified in the design reference fuel cycle.

Thermal design analyses performed include, but are not limited to, the determination of clad and fuel temperatures, clad and fuel thermal expansion, fuel irradiation swelling, fuel fission gas generation and release as a function of time. Employing these thermal analysis results, the mechanical design analyses are then performed to determine the most limiting clad stress and/or strain due to such loadings as:

- Internal fuel rod pressure from gaseous fission product release to the fuel-rod plenum plus initial fill gas.
- Differential fuel-clad expansions.
- External coolant pressure.
- Flow-induced rod vibrations.

Finally, the limiting combinations of cladding stress in the categories summarized in subsection 4.2.1 are identified and compared to the cladding design stress limits. All stresses are below the defined limits.

### **3.9.3.3 Control Rod Drive Operability and Control Rod Insertability Under LOCA and Seismic Loadings**

In the event of a significant seismic disturbance and/or LOCA, only the rapid insertion mode (scram) is essential. Descriptions of the CRD and the CRD system operation during scram are covered in subsection 4.2.3.

The hydraulic nature of the CRDs and their location relative to the reactor vessel provides scram operability of the control rods during seismic events is assured by the generous control rod-to-channel and control rod-to-guide tube clearances. However, LOCA produces larger than normal pressure differentials across the reactor vessel internals, thus tending to reduce these clearances. These pressure differentials are considered in determining the insertability of the control rods.

The highest pressure differentials across the RPV internals occur as a result of a postulated steam line break. To ensure adequate rod-to-guide-tube clearance, the guide tube must be capable of resisting the external to internal pressure difference without collapse. In addition, any increase of friction force due to channel bulging is shown to be small compared to the total addressed in subsections 4.2.2 and 4.2.3.

### **3.9.3.4 HPCI and RCIC Turbines**

The turbine mechanical design and loading criteria are given in tables 3.9-23 and 3.9-25.

### **3.9.3.5 HVAC Equipment (Safety-Related)**

Table 3.9-35 presents a list of safety-related HVAC equipment, the applicable standards and codes to which they are designed, and test report numbers and/or procedure numbers for the equipment.

## **3.9.4 POWER UPRATES**

Evaluations to support increases in power output including extended power uprate, thermal power optimization uprate, and the reactor operating pressure increase to 1060 psia, are summarized in references 8, 9, 10, and 11. The results of the evaluations indicate that the piping and components within the scope of section 3.9 are within acceptable limits for operation at 100% RTP of 2804 MWt.

## HNP-2-FSAR-3

### REFERENCES

1. Quinn, E. P., "Vibration of Fuel Rods in Parallel Flow," USAEC Report GEAP-4059, General Electric, Atomic Power Equipment Department, July 1962.
2. Quinn, E. P., "Vibration of SEFOR Fuel Rods in Parallel Flow," USAEC Report GEAP-4966, Atomic Power Equipment Department, September 1965.
3. "Assessment of Reactor Internals Vibration in BWR 4 and BWR 5 Plants," NEDE 24057-P and NEDO 24057, November 1977.
4. "Edwin I. Hatch Nuclear Plant Unit 2, Evaluation of 80-mil Fuel Assembly Channels," SLI-8305, March 1983.
5. "80-mil Channel Change for Hatch-2 Cycle-4," GE Letter, L. M. Quintana (GE) to K. G. Turnage (SCS), May 18, 1983.
6. "Safety Evaluation Report Mark I Containment Long-Term Program," NUREG-0661, U.S. Nuclear Regulatory Commission, July 1980.
7. "Recirculation Piping Loop A, Section XI Replacement Certified Design Report," GE Nuclear Energy Design Report 25A5746, June 30, 1995.
8. "Extended Power Uprate Safety Analysis Report for Edwin I. Hatch Units 1 and 2," NEDC-32749P, GE Nuclear Energy, July 1997.
9. "Safety Analysis Report for Edwin I. Hatch Units 1 and 2 Thermal Power Optimization," NEDC-33085P, GE Nuclear Energy, December 2002.
10. "10-PSI Dome Pressure Increase Project Report for Edwin I. Hatch Units 1 and 2," GE-NE-0000-0003-0634-01, Revision 1, GE Nuclear Energy, July 2003.
11. RER 03-254, Reactor Operating Pressure Increase From 1050 psia to 1060 psia, Engineering Evaluation.

**TABLE 3.9-1**  
**EVENT LOAD COMBINATION CRITERIA**

| <u>Event or<br/>Load Combination</u> | <u>Event Category</u> | <u>Criteria</u> |
|--------------------------------------|-----------------------|-----------------|
| Normal operation                     | Normal                | Normal          |
| Operational transients               | Upset                 | Upset           |
| OBE                                  | Emergency             | Upset           |
| OBE + normal operation               | Emergency             | Upset           |
| OBE + operational transients         | Emergency             | Emergency       |
| DBE + operational transients         | Faulted               | Faulted         |

**TABLE 3.9-2 (SHEET 1 OF 2)**  
**MAIN STEAM LINE PIPING SYSTEM (CLASS 1 PIPE)**

| <u>Condition</u>       | <u>Load Combination</u>                                                                                              | <u>Criteria</u>                                                                                                                       |
|------------------------|----------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------|
| Design                 | P + W + OBE                                                                                                          | Eq 9A < 1.5 S <sub>m</sub>                                                                                                            |
| Normal<br>and<br>Upset | For dynamic loads,<br>individually considering:<br>OBE, TSV, RV with other<br>ASME Section III<br>Code-defined loads | Eq 9B < 1.8 S <sub>m</sub><br>Eq 10 < 3.0 S <sub>m</sub><br>Eq 12 < 3.0 S <sub>m</sub><br>Eq 13 < 3.0 S <sub>m</sub><br>Eq 14 U < 1.0 |
| Emergency              | $P_e + W + [(OBE)^2 + (TSV)^2]^{1/2}$<br>$P_e + W + [(OBE)^2 + (RV)^2]^{1/2}$                                        | Eq 9C < 2.25 S <sub>m</sub>                                                                                                           |
| Faulted                | $P_e + W + [(DBE)^2 + (TSV)^2]^{1/2}$<br>$P_e + W + [(DBE)^2 + (RV)^2]^{1/2}$                                        | Eq 9D < 3.0 S <sub>m</sub>                                                                                                            |

LEGEND

- P = stresses due to design pressure.  
P<sub>e</sub> = stresses due to peak pressure.  
W = stresses due to weight pressure.  
RV = stresses due to safety relief valve opening.  
TSV = stresses due to turbine stop valve closure.

HNP-2-FSAR-3

**TABLE 3.9-2 (SHEET 2 OF 2)**

| Criteria Per ASME<br><u>Section III NB-3600</u> | Node<br><u>No.</u> | Main<br>Steam<br><u>Line</u> | <u>Maximum Stress Intensities (psi)</u>          |                                      |                                                               |
|-------------------------------------------------|--------------------|------------------------------|--------------------------------------------------|--------------------------------------|---------------------------------------------------------------|
|                                                 |                    |                              | <u>Power<br/>Uprate<br/>Stress<sup>(b)</sup></u> | <u>Code<br/>Allowable<br/>Stress</u> | <u>Ratio:<br/>Power Uprate<br/>to Allowable<sup>(a)</sup></u> |
| Equation 9: Design                              | 21                 | D                            | 11,942                                           | 26,550                               | 0.45                                                          |
| Normal/Upset                                    | 210                | B                            | 16,554                                           | 31,860                               | 0.52                                                          |
| Emergency                                       | 210                | B                            | 16,516                                           | 39,825                               | 0.41                                                          |
| Faulted                                         | 21                 | D                            | 17,435                                           | 53,100                               | 0.33                                                          |
| Equation 10                                     | 49F                | C<br>HPCI                    | 57,560                                           | 53,100                               | 1.08                                                          |
| Equation 12                                     | 49F                | C<br>HPCI                    | 42,882                                           | 53,100                               | 0.81                                                          |
| Equation 13                                     | 21                 | D                            | 32,311                                           | 53,100                               | 0.61                                                          |
| Equation 14 (Fatigue)                           | 17                 | D                            | CUF = 0.28                                       | CUF < 1.0                            |                                                               |

a. Since equation 10 is not satisfied, the piping is qualified by meeting equations 12 and 13, and the maximum stress for equation 13 for any node occurs at node point 21 on line D.

b. Values reflect extended power uprate evaluation. Thermal power optimization evaluations indicate no impact and 10-psi reactor operating pressure increase evaluation indicates there are only minor increases in stresses which remain within available margins.

TABLE 3.9-3 (SHEET 1 OF 4)

## LOADING COMBINATIONS UNDER VARIOUS PLANT CONDITIONS

## NONSTANDARD LINEAR-TYPE SUPPORTS

| <u>Load Combinations</u>                                                                     | <u>Allowable Stress<br/>In Accordance With<br/>Appendix XVII-2000</u> |
|----------------------------------------------------------------------------------------------|-----------------------------------------------------------------------|
| I. Design, Normal, Upset                                                                     |                                                                       |
| Hydro weight + hydro pressure <sup>(a)</sup>                                                 | 0.66 F <sub>y</sub> bending                                           |
| Deadweight + thermal + secondary OBE +<br>primary OBE + design pressure <sup>(a)</sup> + RVO | 0.4 F <sub>y</sub> shear                                              |
| Deadweight + thermal + RVC + design pressure <sup>(a)</sup>                                  | 0.6 F <sub>y</sub> tensile                                            |
| Deadweight + thermal + FV + design pressure <sup>(a)</sup>                                   |                                                                       |
| II. Emergency <sup>(c)(1)</sup>                                                              |                                                                       |
| Deadweight + design pressure <sup>(a)</sup> + primary OBE + RVC                              | 1.33 (0.66 F <sub>y</sub> ) bending                                   |
| Deadweight + design pressure <sup>(a)</sup> + primary OBE + FV                               | 1.33 (0.4 F <sub>y</sub> ) shear                                      |
|                                                                                              | 1.33 (0.6 F <sub>y</sub> ) tensile                                    |
| III. Faulted                                                                                 |                                                                       |
| Deadweight + design pressure <sup>(a)</sup> + primary DBE + RVC<br>or RVO + FV               | 1.2 F <sub>y</sub> but < 0.7 Su                                       |
| Pipe rupture for whip restraints in contact with pipe <sup>(b)</sup>                         | 1.2 F <sub>y</sub> but < 0.7 Su                                       |
| Pipe rupture for whip restraints not in contact with pipe                                    | BN-TOP-2, Rev 2                                                       |

**TABLE 3.9-3 (SHEET 2 OF 4)**

- 
- a. Pressure included only for checking stresses in the pipe wall.
  - b. The faulted condition of pipe rupture for whip restraints normally in contact with the pipe is evaluated independently of all other loading combinations. The loads used in these calculations are based on the ultimate strength of the pipe. Whip restraints not normally in contact with the pipe are discussed separately in subsection 3.6.5 and supplement 15A.
  - c. See paragraph 3.9.1.1.1. This load combination was used only for the turbine stop and safety relief valves. During the long-term blowdown following the establishment of steady-state flow for a closed relief valve discharge system, the reactions on the discharge piping, relief valve, and inlet piping are balanced, and no stresses are introduced as a result of relief valve blowdown. The time duration for the stresses induced during the transient preceding steady-state flow is ~ 200 ms. After this period of time, the motions are damped out.

It may be argued that an earthquake could cause a plant trip and consequential relief valve actuation. However, the probability of the maximum stresses from these transients (in a time sense) occurring at the same location, at the same instant in time and in place, is extremely low.

Furthermore, the number of cycles (3-10) during which both are occurring is more extremely low.

NOTES:

1. The rigid restraints for the main steam and the relief valve discharge lines are designed with adequate margin in the design stress so that the normal stress allowables can be met, using the emergency condition loading combination.

The snubbers used on the main steam and the relief valve discharge lines are designed with adequate margin in the design stress so that normal stress allowables can be met, using loading combination I of the faulted condition loading combinations.

LEGEND

- RVO - dynamic effects associated with an open relief valve discharge
- FV - dynamic effects associated with fast valve closure
- RVC - dynamic effects associated with a closed relief valve discharge



**TABLE 3.9-3 (SHEET 3 OF 4)**

## PLATE- AND SHELL-TYPE SUPPORTS

| <u>Load Combinations</u>                                                                  | <u>Allowable Stress</u>                 |
|-------------------------------------------------------------------------------------------|-----------------------------------------|
| I. Design, Normal, Upset                                                                  |                                         |
| Hydro weight + hydro pressure <sup>(a)</sup>                                              |                                         |
| Deadweight + thermal + FV + design pressure <sup>(a)</sup>                                | $S_h$ general membrane                  |
| Deadweight + thermal + primary OBE + secondary OBE + design pressure <sup>(a)</sup> + RVO | 1.5 $S_h$ general membrane plus bending |
| II. Emergency <sup>(c)(1)</sup>                                                           |                                         |
| Deadweight + design pressure <sup>(a)</sup> + primary OBE + RVC or FV                     | 1.2 $S_h$ general membrane              |
|                                                                                           | 1.8 $S_h$ general membrane plus bending |
| III. Faulted                                                                              |                                         |
| Deadweight + design pressure <sup>(a)</sup> + primary DBE + RVO or RVC + FV               | 1.2 $F_y^{(b)}$ but $< 0.7 S_u$         |
| Pipe rupture for whip restraints normally in contact with pipe                            | 1.2 $F_y^{(b)}$ but $< 0.7 S_u$         |
| Pipe rupture for whip restraints not normally in contact with pipe                        | BN-TOP-2, Rev 2                         |

**TABLE 3.9-3 (SHEET 4 OF 4)**

- 
- a. Pressure needs to be included only for checking stresses in the pipe wall.
  - b.  $F_y$  is the minimum yield stress of the component at the operating temperature. Normally, supports are designed elastically. If  $1.2 F_y$  is used, the effects of plastic deformation on the elastic analysis are considered.
  - c. See paragraph 3.9.1.1.1. This load combination was used only for the turbine stop and safety relief valves. During the long-term blowdown following the establishment of steady-state flow for a closed relief valve discharge system, the reactions on the discharge piping, relief valve, and inlet piping are balanced, and no stresses are introduced as a result of relief valve blowdown. The time duration for the stresses induced during the transient preceding steady-state flow is ~ 200 ms. After this period of time, the motions are damped out.

It may be argued that an earthquake could cause a plant trip and consequential relief valve actuation. However, the probability of the maximum stresses from these transients (in a time sense) occurring at the same location, at the same instant in time and in place, is extremely low.

Furthermore, the number of cycles (3-10) during which both are occurring is likewise extremely low.

#### NOTES

1. The rigid restraints for the main steam line are designed with adequate margin in the design stress so that the normal stress allowables can be met, using the emergency condition loading combination.

The snubbers used on the main steam line and the relief valve discharge lines are designed with adequate margin in the design stress so that normal stress allowables can be met, using loading combination I of the faulted-condition loading combinations.

#### LEGEND

- RVO - dynamic effects associated with an open relief valve discharge  
FV - dynamic effects associated with fast valve closure  
RVC - dynamic effects associated with a closed relief valve discharge

**TABLE 3.9-4 (SHEET 1 OF 9)**  
**RPV INTERNALS AND ASSOCIATED EQUIPMENT**

| <u>Criteria</u>                                                                                                                                                      | <u>Loading</u> <sup>(a)/(h)</sup>                                                              | <u>Primary Stress Type</u>    | <u>Allowable Stress (psi)</u> | <u>Calculated Stress (psi)</u> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------|-------------------------------|-------------------------------|--------------------------------|
| <u>Top Guide - Highest Stressed Beam</u>                                                                                                                             |                                                                                                |                               |                               |                                |
| <u>Primary stress limit</u> - The allowable primary membrane stress plus bending stress is based on ASME B&PV Code, Section III, for Type 304 stainless-steel plate. |                                                                                                |                               |                               |                                |
| For normal and upset condition stress intensity:                                                                                                                     | Normal and upset conditions:                                                                   |                               |                               |                                |
| $S_A = 1.5 S_m = 1.5 \times 16,925 \text{ psi} = 25,388 \text{ psi}$                                                                                                 | Normal $\Delta P$<br>Weight of structure<br>OBE, vertical and horizontal                       | General membrane plus bending | 25,388                        | 15,258                         |
|                                                                                                                                                                      | Upset $\Delta P$ due to loss-of-feedwater heaters<br>Weight of structure                       | General membrane plus bending | 25,388                        | 3426                           |
| For emergency condition:                                                                                                                                             | Emergency condition:                                                                           |                               |                               |                                |
| $S_{limit} = 1.5 S_A = 1.5 \times 25,388 = 38,081 \text{ psi}$                                                                                                       | Emergency $\Delta P$ due to ADS actuation <sup>(b)</sup><br>Weight of structure                | General membrane plus bending | 38,081                        | 3908                           |
| For faulted condition:                                                                                                                                               | Faulted condition:                                                                             |                               |                               |                                |
| $S_{limit} = 2 S_A = 2 \times 25,388 = 50,775 \text{ psi}$                                                                                                           | LOCA $\Delta P$ due to steam line break<br>Weight of structure<br>DBE, horizontal and vertical | General membrane plus bending | 50,775                        | 25,215                         |

HNP-2-FSAR-3

**TABLE 3.9-4 (SHEET 2 OF 9)**

| <u>Criteria</u>                                                                                                          | <u>Loading</u> <sup>(a)(h)</sup>                                                               | <u>Primary Stress Type</u> | <u>Allowable Stress (psi)</u> | <u>Calculated Stress (psi)</u> |
|--------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------|----------------------------|-------------------------------|--------------------------------|
| <u>Top Guide Beam End Connections</u>                                                                                    |                                                                                                |                            |                               |                                |
| <u>Primary stress limit</u> - ASME B&PV Code, Section III, defines material stress limit for Type 304 stainless steel.   |                                                                                                |                            |                               |                                |
| For normal and upset condition stress intensity:<br>$S_A = 0.6 S_m = 0.6 \times 16,925 \text{ psi} = 10,155 \text{ psi}$ | Normal and upset conditions:                                                                   |                            |                               |                                |
|                                                                                                                          | Normal $\Delta P$<br>Weight of structure<br>OBE, horizontal and vertical                       | Pure shear                 | 10,155                        | 6744                           |
|                                                                                                                          | Upset $\Delta P$ due to loss-of-feedwater heaters<br>Weight of structure                       | Pure shear                 | 10,155                        | 1275                           |
| For emergency condition:<br>$S_{limit} = 1.5 S_A = 1.5 \times 10,155 \text{ psi} = 15,232 \text{ psi}$                   | Emergency condition:                                                                           |                            |                               |                                |
|                                                                                                                          | Emergency $\Delta P$ due to ADS actuation <sup>(b)</sup><br>Weight of structure                | Pure shear                 | 15,232                        | 1454                           |
| For faulted condition:<br>$S_{limit} = 2 S_A = 2 \times 10,155 \text{ psi} = 20,310 \text{ psi}$                         | Faulted condition:                                                                             |                            |                               |                                |
|                                                                                                                          | LOCA $\Delta P$ due to steam line break<br>Weight of structure<br>DBE, horizontal and vertical | Pure shear                 | 20,310                        | 11,291                         |

HNP-2-FSAR-3

**TABLE 3.9-4 (SHEET 3 OF 9)**

| <u>Criteria</u>                                                                                                                                                      | <u>Loading</u> <sup>(a)(h)</sup>                                                               | <u>Primary Stress Type</u>    | <u>Allowable Stress (psi)</u> | <u>Calculated Stress (psi)</u> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------|-------------------------------|-------------------------------|--------------------------------|
| <u>Top Guide Aligners</u>                                                                                                                                            |                                                                                                |                               |                               |                                |
| <u>Primary stress limit</u> - The allowable primary membrane stress plus bending stress is based on ASME B&PV Code, Section III, for Type 304 stainless-steel plate. |                                                                                                |                               |                               |                                |
| For normal and upset condition stress intensity:                                                                                                                     | Normal and upset conditions:                                                                   |                               |                               |                                |
| $S_A = 1.5 S_m = 1.5 \times 16,925 \text{ psi} = 25,388 \text{ psi}$                                                                                                 | Normal $\Delta P$<br>Weight of structure<br>OBE, horizontal and vertical                       | General membrane plus bending | 25,388                        | (c)                            |
|                                                                                                                                                                      | Upset $\Delta P$ due to loss- of-feedwater heaters<br>Weight of structure                      | General membrane plus bending | 25,388                        | (c)                            |
| For emergency condition:                                                                                                                                             | Emergency condition:                                                                           |                               |                               |                                |
| $S_{limit} = 1.5 S_A = 1.5 \times 25,388 = 38,081 \text{ psi}$                                                                                                       | Emergency $\Delta P$ due to ADS actuation <sup>(b)</sup><br>Weight of structure                | General membrane plus bending | 38,081                        | (c)                            |
| For faulted condition:                                                                                                                                               | Faulted condition:                                                                             |                               |                               |                                |
| $S_{limit} = 2 S_A = 2 \times 25,388 = 50,775 \text{ psi}$                                                                                                           | LOCA $\Delta P$ due to steam line break<br>Weight of structure<br>DBE, horizontal and vertical | General membrane plus bending | 50,775                        | (c)                            |

HNP-2-FSAR-3

**TABLE 3.9-4 (SHEET 4 OF 9)**

| <u>Criteria</u>                                                                                                                                                      | <u>Loading</u> <sup>(a)(h)</sup>                                                               | <u>Primary Stress Type</u>    | <u>Allowable Stress (psi)</u> | <u>Calculated Stress (psi)</u> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------|-------------------------------|-------------------------------|--------------------------------|
| <u>Core Support</u>                                                                                                                                                  |                                                                                                |                               |                               |                                |
|                                                                                                                                                                      | Normal and upset conditions:                                                                   |                               |                               |                                |
| <u>Primary stress limit</u> - The allowable primary membrane stress plus bending stress is based on ASME B&PV Code, Section III, for Type 304 stainless-steel plate. | Normal $\Delta P$<br>Weight of structure<br>OBE, horizontal and vertical                       | General membrane plus bending | 25,388                        | 18,650                         |
|                                                                                                                                                                      | Upset $\Delta P$ due to loss-of-feedwater heaters<br>Weight of structure                       | General membrane plus bending | 25,388                        | 10,902                         |
| For allowable stresses, see Top Guide, Longest Beam.                                                                                                                 |                                                                                                |                               |                               |                                |
|                                                                                                                                                                      | Emergency condition:                                                                           |                               |                               |                                |
|                                                                                                                                                                      | Emergency $\Delta P$ due to ADS actuation <sup>(b)</sup><br>Weight of structure                | General membrane plus bending | 30,081                        | 10,921                         |
|                                                                                                                                                                      | Faulted condition:                                                                             |                               |                               |                                |
|                                                                                                                                                                      | LOCA $\Delta P$ due to steam line break<br>Weight of structure<br>DBE, horizontal and vertical | General membrane plus bending | 50,775                        | 24,937                         |

HNP-2-FSAR-3

**TABLE 3.9-4 (SHEET 5 OF 9)**

| <u>Criteria</u>                                                                                                                                                                                             | <u>Loading</u> <sup>(a)(h)</sup>                                                                                                                                                         | <u>Primary Stress Type</u> | <u>Allowable Stress (psi)</u> | <u>Calculated Stress (psi)</u> |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------|-------------------------------|--------------------------------|
| <u>Core Support Aligners</u>                                                                                                                                                                                |                                                                                                                                                                                          |                            |                               |                                |
| <p><u>Primary stress limit</u> - ASME B&amp;PV Code, Section III, defines material stress limit for Type 304 stainless steel.</p> <p>For allowable shear stresses, see Top Guide Beam, End Connections.</p> | Normal and upset conditions:                                                                                                                                                             |                            |                               |                                |
|                                                                                                                                                                                                             | <p>Normal <math>\Delta P</math><br/>Weight of structure<br/>OBE, horizontal and vertical</p> <p>Upset <math>\Delta P</math> due to loss-of-feedwater heaters<br/>Weight of structure</p> | Pure shear                 | 10,155                        | (d)                            |
|                                                                                                                                                                                                             | Emergency condition:                                                                                                                                                                     |                            |                               |                                |
|                                                                                                                                                                                                             | <p>Emergency <math>\Delta P</math> due to ADS actuation<sup>(b)</sup><br/>Weight of structure</p>                                                                                        | Pure shear                 | 15,232                        | (d)                            |
|                                                                                                                                                                                                             | Faulted condition:                                                                                                                                                                       |                            |                               |                                |
|                                                                                                                                                                                                             | <p>LOCA <math>\Delta P</math> due to steam line break<br/>Weight of structure<br/>DBE, horizontal and vertical</p>                                                                       | Pure shear                 | 20,310                        | 2000                           |

HNP-2-FSAR-3

**TABLE 3.9-4 (SHEET 6 OF 9)**

| <u>Criteria</u>                                                                                                                            | <u>Loading</u> <sup>(e)(h)</sup>                                                                                                                                                                                                                                                         | <u>Primary Stress Type</u>                                                                                                        | <u>Allowable Stress (psi)</u> | <u>Calculated Stress (psi)</u> |
|--------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------|-------------------------------|--------------------------------|
| <u>CRD Housing</u>                                                                                                                         |                                                                                                                                                                                                                                                                                          |                                                                                                                                   |                               |                                |
| For normal and upset condition:                                                                                                            | Normal and upset condition loads:                                                                                                                                                                                                                                                        |                                                                                                                                   |                               |                                |
|                                                                                                                                            | Design pressure<br>Stuck rod scram loads<br>OBE, with housing lateral support installed                                                                                                                                                                                                  | Maximum membrane stress intensity occurs in tube-to-tube weld near center of housing for normal, upset, and emergency conditions. | $S_m = 16,660$                | 13,150                         |
| <u>Primary stress limit</u> - The allowable primary membrane stress is based on ASME B&PV Code, Section III, for Type 304 stainless steel. |                                                                                                                                                                                                                                                                                          |                                                                                                                                   |                               |                                |
| For emergency condition:                                                                                                                   | Emergency condition loads:                                                                                                                                                                                                                                                               |                                                                                                                                   |                               |                                |
| $S_{limit} = 1.2 S_m$ in accordance with ASME Section III.                                                                                 | Design pressure<br>Stuck rod scram loads<br>DBE, with housing lateral; lateral support installed<br><br>OBE 0.8-g horizontal (statically applied)<br>OBE 0.2-g vertical (statically applied)<br><br>OBE 1.6-g horizontal (statically applied)<br>OBE 0.4-g vertical (statically applied) |                                                                                                                                   | $1.2 S_m = 20,000$            | 13,150                         |



HNP-2-FSAR-3

**TABLE 3.9-4 (SHEET 7 OF 9)**

| <u>Criteria</u>                                                                                                                                                      | <u>Loading</u> <sup>(e)(h)</sup>                                                                                                           | <u>Primary Stress Type</u>                                              | <u>Allowable Stress (psi)</u> | <u>Calculated Stress (psi)</u> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------|-------------------------------|--------------------------------|
| <u>CRD</u>                                                                                                                                                           |                                                                                                                                            |                                                                         |                               |                                |
| <u>Primary stress limit</u> - The allowable primary membrane stress plus bending is based on ASME B&PV Code, Section III.                                            |                                                                                                                                            |                                                                         |                               |                                |
| For normal and upset conditions:                                                                                                                                     | Normal and upset condition loads:                                                                                                          |                                                                         |                               |                                |
| $S_m = 1.5 \times 17,238 = 25,860$ psi                                                                                                                               | Maximum hydraulic pressure from CRD supply pump <sup>(f)</sup>                                                                             | Maximum stress intensity occurs at point on Y-Y axis of indicator tube. | 25,860                        | 20,790                         |
| <u>CRD Guide Tube</u>                                                                                                                                                |                                                                                                                                            |                                                                         |                               |                                |
| <u>Primary stress limit</u> - The allowable primary membrane stress plus bending stress is based on ASME B&PV Code, Section III for Type 304 stainless-steel tubing. |                                                                                                                                            |                                                                         |                               |                                |
| For normal and upset condition:                                                                                                                                      | Normal condition:                                                                                                                          |                                                                         |                               |                                |
| $S_m = 16,925$ psi                                                                                                                                                   | Since calculated stresses for faulted condition are less than normal condition allowables, normal condition is satisfied and not reported. |                                                                         |                               |                                |

HNP-2-FSAR-3

**TABLE 3.9-4 (SHEET 8 OF 9)**

| Criteria                                                                                                                                   | Loading <sup>(e)(h)</sup>                                                                                                                                                                                                                                      | Primary Stress Type                                                                    | Allowable Stress (psi) | Calculated Stress (psi) |
|--------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------|------------------------|-------------------------|
| <u>CRD Guide Tube</u> (continued)                                                                                                          |                                                                                                                                                                                                                                                                |                                                                                        |                        |                         |
| For faulted condition:                                                                                                                     |                                                                                                                                                                                                                                                                |                                                                                        |                        |                         |
| $S_{limit} = 1.5 S_m = 1.5 \times 16,295 = 25,400$ psi                                                                                     | Faulted condition loads:<br><br>Deadweight<br>Pressure drop across guide tube due to failure of steam line<br>Crossflow loading<br>Seismic loading<br><br>DBE 1.2-g horizontal (statically applied)<br>DBE 0.14-g vertical <sup>(g)</sup> (statically applied) | Maximum bending stress under faulted loading condition occurs at center of guide tube. | 25,400                 | 6061                    |
| <u>Incore housing</u>                                                                                                                      |                                                                                                                                                                                                                                                                |                                                                                        |                        |                         |
| <u>Primary stress limit</u> - The allowable primary membrane stress is based on ASME B&PV Code, Section III, for Type 304 stainless steel. |                                                                                                                                                                                                                                                                |                                                                                        |                        |                         |
| For normal and upset condition:                                                                                                            |                                                                                                                                                                                                                                                                |                                                                                        |                        |                         |
| $S_m = 16,660$ psi at 575°F                                                                                                                | Since emergency condition stresses are less than normal condition limits, normal condition is satisfied and not reported.                                                                                                                                      |                                                                                        |                        |                         |
| For emergency condition:                                                                                                                   |                                                                                                                                                                                                                                                                |                                                                                        |                        |                         |
| $S_{limit} = 1.2 S_m = 1.2 \times 16,660 = 20,000$ psi                                                                                     | Emergency condition load:<br><br>Design pressure DBE<br><br>DBE 1.6-g horizontal (statically applied)<br>DBE 0.4-g vertical (statically applied)                                                                                                               | Maximum membrane stress intensity occurs at outer surface of vessel penetration.       | 20,000                 | 15,290                  |

HNP-2-FSAR-3

**TABLE 3.9-4 (SHEET 9 OF 9)**

- 
- a. The horizontal load is based on the results of the dynamic seismic analysis of the building for 0.08-g OBE and 0.15-g DBE free-shield ground motion. The vertical load is based on 0.1-g OBE and 0.2-g DBE times the component weight statically applied. The load combination method used was the absolute sum of the individual loads.
  - b. Automatic depressurization system.
  - c. Twenty-four wedges, which will resist the horizontal seismic top-guide shear load, are installed in the annulus between the top guide and the shroud. Therefore, there is no load on the top-guide aligners.
  - d. The friction force between core support and core support flange due to the preload of the studs is greater than the shear load induced by the specified earthquake.
  - e. These loads were directly combined.
  - f. Accident conditions do not increase this loading. Earthquake loads are negligible. Direct addition of all other loads is less than the hydraulic pressure load, and other loads are not additive to the hydraulic pressure load.
  - g. 0.14-g vertical = 70.5 psi and is considered negligible.
  - h. The analyses were performed assuming 100-mil-thick fuel assembly channels. The effect on seismic loads due to a design change from 100-mil to 80-mil-thick channels is negligible.<sup>(4)</sup>

HNP-2-FSAR-3

**TABLE 3.9-5**

**HNP-2 LOAD COMBINATIONS (SEISMIC + LOCA)**

| <u>Component</u>                       | <u>Loads Combined</u>                                              | <u>Method of Combination</u> <sup>(a)</sup>                                      | <u>FSAR<br/>Analysis Reference</u>     | <u>Remarks</u>                                                                                                                                           |
|----------------------------------------|--------------------------------------------------------------------|----------------------------------------------------------------------------------|----------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------|
| RPV shell                              | Seismic, mechanical, thermal, and transient (NPC + DBE + DSL)      | Direct addition                                                                  | Section 3.9                            | Meets Article 4, Section III, ASME Code for all loads; also meets ASME Section III, N-417.11.                                                            |
| RPV nozzles                            | Seismic, mechanical, thermal, and transient (NPC + DBE + DSL)      | Direct addition                                                                  | Section 3.9                            | Meets Section III, ASME Code, N-450; also meets ASME Section III, N-417.11.                                                                              |
| RPV skirt and stabilizers              | Annulus pressurization. (See FSAR supplement 6A.)                  | Direct addition                                                                  | Supplement 6A                          | DBE added by SRSS due to very low probability of combining with specific break location. (Not original design basis.) Elastic stress limit not exceeded. |
| RPV internals                          | Seismic, deadweight, LOCA (steam line break $P_e + W + DBE$ )      | Direct addition                                                                  | Table 3.9-4                            | SRSS load combination justified (dynamic loads).                                                                                                         |
| Class 1 piping (unbroken)              | Seismic, deadweight, LOCA ( $P_o + W + DBE$ ) or (NPC + DBE + DSL) | Direct addition except for RV and TSV operation                                  | Tables 3.9-2, 3.9-6. Paragraph 3.9.1.5 | Meets ASME Code, Section III, NB-3656.                                                                                                                   |
| Class 1 valves (pipe mounted)          | Same as for Class 1 piping                                         | Same as for Class 1 piping. Piping reaction loads are design limited for valves. | Tables 3.9-14 and 3.9-16. Section 3.9  | Relief valves meet ASME NPVC, 1968. MSIV meets ASME Section III, 1971 (winter addenda); recirculation valves meet Article 4 of NPVC, 1968.               |
| Class 1 pumps (inactive) recirculation | Same as for Class 1 piping                                         | Same as for Class 1 piping. Piping reaction loads are design limited for pumps.  | Table 3.9-15. Paragraph 3.9.2.2        | Meets Section VIII, NPVC.                                                                                                                                |

a. Dynamic loads are combined by SRSS when three or more result in cyclic dynamic responses, for DBE + LOCA, or for any two loads for which it can be demonstrated that the SRSS value has at least an 84% nonexceedence probability (NEP).

HNP-2-FSAR-3

**TABLE 3.9-6**

**RECIRCULATION PIPING SYSTEM (CLASS 1 PIPE)<sup>(a)</sup>**

| <u>Condition</u> | <u>Load Combination</u> | <u>Criteria</u>                                                    | <u>Limit (psi)</u> | <u>Load (psi)</u> | <u>Stress Ratio</u> | <u>Location</u>                  |
|------------------|-------------------------|--------------------------------------------------------------------|--------------------|-------------------|---------------------|----------------------------------|
| Design           | $P_D + W + OBE_1$       | $\leq 1.5 S_m$                                                     | 25,875             | 25,067            | 0.969               | Loop A, node 181, hanger lugs    |
| Normal and upset | TE, $P_o$ , NO, OT, OBE | Eq 10 $\leq 3.0 S_m$<br>if Eq 10 exceeds<br>Eq 12 $\leq 3.0 S_m$   | 51,750             | 39,838            | 0.77                | Loop A, node 220, reducer        |
|                  |                         | Eq 13 $\leq 3.0 S_m$                                               | 51,750             | 49,724            | 0.961               | Loop A, node 500, RHR supply tee |
|                  |                         | $U \leq 1.0^{(b)}$                                                 | -                  | -                 | 0.05 <sup>(b)</sup> |                                  |
| Upset            | $P_o + W + OBE_1$       | The lesser of<br>Eq 9 $\leq 1.8 S_m$<br>and<br>Eq 9 $\leq 1.5 S_y$ | 29,223             | 25,691            | 0.879               | Loop A, node 181, hanger lugs    |
| Faulted          | $P_o + W + DBE_1$       | The lesser of<br>Eq 9 $\leq 3.0 S_m$<br>and<br>Eq 9 $\leq 2.0 S_y$ | 38,964             | 26,060            | 0.669               | Loop A, node 181, hanger lugs    |

LEGEND

- I = inertia
- NO = normal operating loads
- OT = operating transient loads
- P = design pressure stresses
- $P_o$  = operating pressure stresses
- TE = thermal expansion stresses

a. The HNP-2 recirculation piping was evaluated for the effects of power uprate and shown to satisfy the applicable Code requirements. Reference 7 provides a summary of the results. Effect of extended power uprate, thermal power optimization uprate, and 10-psi reactor operating pressure increase on results summarized in reference 7 is insignificant.

b. Usage factor.

**TABLE 3.9-7**  
**SNUBBER EVALUATION FOR LOCA AND DBE**

| <u>Snubber Description</u> <sup>(b)</sup> | <u>DBE Load (kips)</u> | <u>LOCA Load<sup>(a)</sup> (kips)</u> | <u>Loop A</u>                                             |                              |              |
|-------------------------------------------|------------------------|---------------------------------------|-----------------------------------------------------------|------------------------------|--------------|
|                                           |                        |                                       | <u><math>\sqrt{(\text{LOCA}^2 + \text{DBE}^2)}</math></u> | <u>Faulted Rating (kips)</u> | <u>Ratio</u> |
| SA1                                       | 6.2                    | 3.5                                   | 7.1                                                       | 75                           | 0.09         |
| SA2                                       | 31.4                   | 1.6                                   | 31.4                                                      | 75                           | 0.42         |
| SA3                                       | 30.2                   | 3.5                                   | 30.4                                                      | 75                           | 0.41         |
| SA4                                       | 26.0                   | 3.2                                   | 26.2                                                      | 75                           | 0.35         |
| SA5                                       | 23.1                   | 1.1                                   | 23.1                                                      | 75                           | 0.31         |
| SA6                                       | 7.8                    | 1.1                                   | 7.9                                                       | 75                           | 0.11         |
| SA14                                      | 8.5                    | 3.6                                   | 9.2                                                       | 45                           | 0.21         |
| SA19                                      | 19.3                   | 17.2                                  | 25.9                                                      | 30                           | 0.86         |
| SA20                                      | 20.2                   | 15.5                                  | 25.5                                                      | 30                           | 0.85         |
| SA21                                      | 20.7                   | 3.0                                   | 20.9                                                      | 30                           | 0.70         |
| SA22                                      | 12.5                   | 0.0                                   | 12.5                                                      | 30                           | 0.42         |
|                                           |                        |                                       | <u>Loop B</u>                                             |                              |              |
| SB1                                       | 7.0                    | 3.4                                   | 7.8                                                       | 75                           | 0.10         |
| SB2                                       | 40.6                   | 6.4                                   | 41.1                                                      | 75                           | 0.55         |
| SB3                                       | 39.1                   | 4.7                                   | 39.4                                                      | 75                           | 0.53         |
| SB4                                       | 32.1                   | 3.2                                   | 32.3                                                      | 75                           | 0.43         |
| SB5                                       | 28.9                   | 2.4                                   | 29.0                                                      | 75                           | 0.39         |
| SB6                                       | 7.9                    | 1.4                                   | 8.0                                                       | 75                           | 0.11         |
| SB12                                      | 17.3                   | 7.8                                   | 19.0                                                      | 30                           | 0.63         |
| SB14                                      | 8.9                    | 4.2                                   | 9.8                                                       | 45                           | 0.22         |
| SB19                                      | 17.2                   | 15.7                                  | 23.3                                                      | 30                           | 0.78         |

a. Jet impingement only.

b. Snubbers SA7, SA8, SA12, SA13, SA17, SB7, SB8, SB13, SB17, SB20, SB21, and SB22 were deleted from the recirculation piping system during the snubber reduction program.

TABLE 3.9-8 (SHEET 1 OF 2)

LOAD COMBINATIONS FOR LOCA<sup>(a)</sup> + DBE FOR CLASS 1 RCPB COMPONENTS

| <u>Component</u>                                                  | <u>Plant Condition</u>                                                    | <u>Combination Loading<sup>(a)</sup></u> | <u>Stress Limit</u>                    | <u>ASME Section III Reference</u> |
|-------------------------------------------------------------------|---------------------------------------------------------------------------|------------------------------------------|----------------------------------------|-----------------------------------|
| Class 1 piping (See note 1.)                                      | Normal and upset                                                          | NPC or UPC + OBE                         | 1.5 S <sub>m</sub> (primary)           | NB-3652                           |
|                                                                   |                                                                           |                                          | 3 S <sub>m</sub> (primary + secondary) | NB-3653<br>NB-3654                |
|                                                                   | Emergency                                                                 | EPC (weight + maximum pressure)          | 2.25 S <sub>m</sub> (primary)          | NB-3655                           |
|                                                                   | Faulted                                                                   | NPC (weight + pressure + DBE)            | 3 S <sub>m</sub> (primary)             | NB-3656 (See Note 4.)             |
| Class 1 valves (inactive) by standard or alternative design rules | Normal and upset                                                          | NPC or UPC                               | S <sub>m</sub> (primary)               | NB-3500                           |
|                                                                   |                                                                           |                                          | 3 S <sub>m</sub> (primary + secondary) |                                   |
|                                                                   | Emergency                                                                 | EPC                                      | S <sub>m</sub> (primary)               | NB-3500                           |
|                                                                   | 3 S <sub>m</sub> (primary + secondary)                                    |                                          |                                        |                                   |
| Faulted                                                           | NPC (weight + stem thrust + maximum service pressure + DBE (See Note 2.)) | S <sub>m</sub> (primary)                 | NB-3524 (See Note 2.)                  |                                   |
| Class 1 valves (active) by analysis                               | Normal and upset                                                          | NPC or UPC                               | U.F. < 1                               | NB-3222.4                         |
|                                                                   | Emergency                                                                 | EPC                                      | U.F. < 1                               | NB-3224                           |
|                                                                   | Faulted                                                                   | NA (See Note 3.)                         | NA (See Note 3.)                       | NA (See Note 3.)                  |

HNP-2-FSAR-3

**TABLE 3.9-8 (SHEET 2 OF 2)**

| <u>Component</u>                                                | <u>Plant Condition</u> | <u>Combination Loading<sup>(a)</sup></u>                                  | <u>Stress Limit</u>                                                    | <u>ASME Section III Reference</u> |
|-----------------------------------------------------------------|------------------------|---------------------------------------------------------------------------|------------------------------------------------------------------------|-----------------------------------|
| Class 1 valves (active) by standard or alternative design rules | Normal and upset       | NPC or UPC                                                                | S <sub>m</sub> (primary)<br><br>3 S <sub>m</sub> (primary + secondary) | NB-3500                           |
|                                                                 | Emergency              | EPC                                                                       | S <sub>m</sub> (primary)<br><br>3 S <sub>m</sub> (primary + secondary) | NB-3500                           |
|                                                                 | Faulted                | NPC (weight + stem thrust + maximum service pressure) + DBE (See Note 2.) | S <sub>m</sub> (primary)                                               | NB-3524 (See Note 2.)             |

NOTES:

1. Bechtel analyzed General Electric-supplied main steam and the original recirculation systems for jet impingement and differential pressure.
2. Reference Note 3 of table 3.9-29. LOCA effects are evaluated for the piping; because the valve body is thicker, the piping stress is considered limiting.
3. Design by analysis per NB-3200 is used for fatigue evaluation only.
4. General Electric evaluated the replacement recirculation piping for Bechtel-supplied jet impingement loads.

LEGEND

- NPC - normal plant condition  
 UPC - upset plant condition  
 EPC - emergency plant condition  
 NA - not applicable

a. LOCA - jet impingement and differential pressure across components.



TABLE 3.9-9 (SHEET 1 OF 4)

## ASME CODE CLASS 2 AND 3 COMPONENTS

|                                                            | <u>Code Class</u> | <u>Design Pressure (psi)</u> | <u>Design Temperature (°F)</u> | <u>Active</u> |
|------------------------------------------------------------|-------------------|------------------------------|--------------------------------|---------------|
| <u>Reactor system</u>                                      |                   |                              |                                |               |
| Power range detector pressure containment parts            | 2                 | 1250                         | 600                            | NO            |
| <u>Nuclear boiler system</u>                               |                   |                              |                                |               |
| Vessels, air accumulators                                  | 2                 | 180                          | 340                            | NO            |
| Piping, relief valve discharge                             | 3                 | 500                          | 470                            | NO            |
| <u>CRD hydraulic system</u>                                |                   |                              |                                |               |
| Valves, scram discharge volume lines                       | 2                 | 1250                         | 280                            | YES           |
| Valves, insert and withdraw lines                          | 2                 | 1750                         | 575                            | NO            |
| Piping, scram discharge volume lines                       | 2                 | 1250                         | 280                            | NO            |
| Piping, insert and withdraw lines                          | 2                 | 1750                         | 575                            | NO            |
| <u>Standby liquid control system (SLCS)</u>                |                   |                              |                                |               |
| SLC tank                                                   | 2                 | ATM <sup>(a)</sup>           | < 250                          | NO            |
| Pump                                                       | 2                 | 1400                         | 150                            | NO            |
| Valves beyond isolation valves                             | 2                 | 1400                         | 150                            | NO            |
| Piping beyond isolation valves                             | 2                 | 1400                         | 150                            | NO            |
| <u>Neutron monitoring system</u>                           |                   |                              |                                |               |
| Piping, TIP <sup>(b)</sup> (reactor pressure, containment) | 2                 | 100                          | 340                            | NO            |
| Valves, isolation TIP <sup>(b)</sup> system                | 2                 | 100                          | 340                            | NO            |

TABLE 3.9-9 (SHEET 2 OF 4)

|                                                             | <u>Code Class</u> | <u>Design Pressure (psi)</u> | <u>Design Temperature (°F)</u> | <u>Active</u> |
|-------------------------------------------------------------|-------------------|------------------------------|--------------------------------|---------------|
| <u>RHR system</u>                                           |                   |                              |                                |               |
| Heat exchangers, primary side                               | 3                 | 450                          | 470                            | NO            |
| Heat exchangers, secondary side                             | Section VIII      | 450                          | 470                            | NO            |
| Piping, beyond outermost isolation valves                   | 2                 | 450                          | 358                            | NO            |
| Pumps                                                       | 2                 | 500                          | 40 to 360                      | YES           |
| Valves, beyond isolation valves                             | 2                 | 300                          | BW <sup>(c)</sup><br>ANSI      | YES           |
| <u>CS</u>                                                   |                   |                              |                                |               |
| Piping, beyond outermost isolation valves to pump discharge | 2                 | 460                          | 225                            | NO            |
| Pumps                                                       | 2                 | 500                          | 40 to 212                      | YES           |
| Valves, beyond outermost isolation valves to pump discharge | 2                 | 460                          | 225                            | YES           |
| <u>HPCI</u>                                                 |                   |                              |                                |               |
| Piping beyond outermost isolation valve                     | { Steam           | 2                            | 1250                           | 575 } NO      |
|                                                             | { Water           | 2                            | 1330                           |               |
| Pump                                                        | 2                 | 1500                         | 40 to 140                      | YES           |
| Valves (other)                                              | { Steam           | 2                            | 1250                           | 575 } YES     |
|                                                             | { Water           | 2                            | 1330                           |               |
| <u>RCIC system</u>                                          |                   |                              |                                |               |
| Piping beyond outermost isolation valve                     | { Steam           | 2                            | 1250                           | 575 } NO      |
|                                                             | { Water           | 2                            | 1300                           |               |
| Pumps                                                       | 2                 | 1500                         | 40 to 140                      | YES           |
| Valves (other)                                              | { Steam           | 2                            | 1250                           | 575 } YES     |
|                                                             | { Water           | 2                            | 1300                           |               |
| <u>Radwaste system</u>                                      |                   |                              |                                |               |
| Valves, containment isolation                               | 2                 | 150                          | 212                            | YES           |

TABLE 3.9-9 (SHEET 3 OF 4)

|                                                    | <u>Code Class</u> | <u>Design Pressure (psi)</u> | <u>Design Temperature (°F)</u> | <u>Active</u> |
|----------------------------------------------------|-------------------|------------------------------|--------------------------------|---------------|
| <u>RWC system</u>                                  |                   |                              |                                |               |
| Filter-demineralizer unit                          | 3                 | 1400                         | 150                            | NO            |
| Piping, beyond outermost isolation valves          | 3                 | 1300                         | 575                            | NO            |
| Pumps                                              | 3                 | 1400                         | 575                            | YES           |
| Valves (other)                                     | 3                 | 1300                         | 575                            | YES           |
| Heat exchangers (regenerative)                     | 3                 | 1400                         | 575                            | NO            |
| Heat exchangers (nonregenerative)                  | 3                 | { 1400 tube<br>150 shell }   | { 575 tube<br>370 shell }      | NO            |
| <u>Fuel pool cooling and cleanup (FPCC) system</u> |                   |                              |                                |               |
| Vessels, filter-demineralizers                     | 3                 | 150                          | 150                            | NO            |
| Vessels (other)                                    | 3                 | 150                          | 150                            | NO            |
| Heat exchangers                                    | 3                 | 150                          | 150                            | NO            |
| Piping                                             | 3                 | 150                          | 150                            | NO            |
| Pumps                                              | 3                 | 150                          | 150                            | NO            |
| Valves                                             | 3                 | 150                          | 150                            | NO            |
| <u>RHRSW system</u>                                |                   |                              |                                |               |
| Piping                                             | 3                 | 525                          | 125                            | NO            |
| Pumps                                              | 3                 | 595                          | 125                            | YES           |
| Valves                                             | 3                 | 525                          | 125                            | YES           |
| <u>PSW system</u>                                  |                   |                              |                                |               |
| Pumps                                              | 3                 | 180                          | 125                            | YES           |
| Piping to the reactor building                     | 3                 | 180                          | 125                            | NO            |
| Valves to the reactor building                     | 3                 | 180                          | 125                            | YES           |
| Piping in the reactor building                     | 3                 | 185                          | 125                            | NO            |
| Valves in the reactor building                     | 3                 | 185                          | 125                            | YES           |

HNP-2-FSAR-3

**TABLE 3.9-9 (SHEET 4 OF 4)**

|                                            | <u>Code Class</u> | <u>Design Pressure (psi)</u> | <u>Design Temperature (°F)</u> | <u>Active</u> |
|--------------------------------------------|-------------------|------------------------------|--------------------------------|---------------|
| <u>Drywell pneumatic system</u>            |                   |                              |                                |               |
| Piping and valves                          | 2                 | 150                          | 353/150                        | NO            |
| <u>Diesel generator system</u>             |                   |                              |                                |               |
| Day tanks                                  | 3                 | atmospheric pressure         | 105                            | NO            |
| Piping for diesel service water system     | 3                 | 180                          | 125                            | NO            |
| Valves for diesel service water system     | 3                 | 180                          | 125                            | YES           |
| Pumps, fuel oil system                     | 3                 | 15                           | 70                             | YES           |
| <u>Primary containment</u>                 | MC                | 56                           | 340                            | NO            |
| <u>Standby gas treatment system (SGTS)</u> |                   |                              |                                |               |
| Filter train housing                       | 2                 | +2 to -2                     | 150                            | NO            |
| Valves                                     | 2                 | 150                          | 150                            | YES           |
| Piping                                     | 2 and 3           | 150                          | 150                            | NO            |
| Fans                                       | -                 | +2 to -2                     | 150                            | YES           |

- a. Atmosphere, standard.  
b. Traversing incore probe.  
c. Bingham Willamette Company.

TABLE 3.9-10 (SHEET 1 OF 2)

**SAFETY-RELATED MECHANICAL COMPONENTS  
NOT COVERED BY ASME CODE**

| <u>Principal Components</u>                             | <u>FSAR Location</u> <sup>(a)</sup> | <u>Design Code</u>                  | <u>Qualification Method</u>                           |
|---------------------------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------------------------|
| <u>Reactor system</u>                                   |                                     |                                     |                                                       |
| CRD housing supports                                    | 4.5                                 | AISC                                | Analytical                                            |
| Reactor internal structures, engineered safety features | 4.2.2                               | NA                                  | Analytical and empirical                              |
| Control rods                                            | 4.2.3.1                             | NA                                  | Prototype tests                                       |
| CRD system                                              | 4.2.3.2                             | NA                                  | Analytical and prototype tests                        |
| Core support structures                                 | 4.2.2                               | NA                                  | Analytical                                            |
| RPV stabilizer                                          | 5.4.6.3.3.2                         | AISC                                | Analytical                                            |
| Fuel assemblies                                         | 4.2.1                               | NA                                  | Analytical, prototype tests, and operating experience |
| <u>Recirculation system</u>                             |                                     |                                     |                                                       |
| Pipe restraints, recirculation line                     | 3.9.2.1 - 3.9.2.2                   | AISC                                | Analytical and tests                                  |
| <u>CRDH system</u>                                      |                                     |                                     |                                                       |
| Hydraulic control unit                                  | 4.2.3.2                             | ASME<br>ANSI                        | Analytical and prototype tests                        |
| <u>SLCS</u>                                             |                                     |                                     |                                                       |
| Atmospheric storage tank                                | 6.3                                 | API-620<br>API-650                  | Seismic analyses                                      |
| <u>HPCI system</u>                                      |                                     |                                     |                                                       |
| Turbine                                                 | 6.3                                 | ASME<br>Section VIII <sup>(a)</sup> | Analytical                                            |
| <u>RCIC system</u>                                      |                                     |                                     |                                                       |
| Turbine                                                 | 6.3                                 | ASME<br>Section VIII <sup>(a)</sup> | Analytical                                            |

**TABLE 3.9-10 (SHEET 2 OF 2)**

| <u>Principal Components</u>                   | <u>FSAR Location</u> <sup>(a)</sup> | <u>Design Code</u>                                              | <u>Qualification Method</u>       |
|-----------------------------------------------|-------------------------------------|-----------------------------------------------------------------|-----------------------------------|
| <u>RHRSW system</u>                           |                                     |                                                                 |                                   |
| Mechanical draft cooling towers               | 9.2.7                               | AISC<br>ACI <sup>(c)</sup>                                      | Analytical                        |
| <u>Diesel generator systems</u>               |                                     |                                                                 |                                   |
| Diesel generators                             | 9.5                                 | DEMA<br>ANSI<br>IEEE<br>NEMA <sup>(d)</sup>                     | Analytical                        |
| <u>SGTS</u>                                   |                                     |                                                                 |                                   |
| Filters, exhaust fans, drivers                | 6.2.4                               | AMCA<br>SMACNA <sup>(e)</sup><br>ORNL <sup>(f)</sup><br>NSIC-65 | Analytical and<br>prototype tests |
| Housing, valves, piping                       | table 3.2-1                         | ASME III-2                                                      | Seismic calculations              |
| <u>Reactor building ventilation</u>           |                                     |                                                                 |                                   |
| All components with safety functions          | 9.4.2                               | AMCA<br>SMACNA <sup>(e)</sup>                                   | Analytical                        |
| <u>Emergency equipment area cooling units</u> | 9.4                                 | AMCA<br>SMACNA <sup>(e)</sup>                                   | Analytical                        |

- a. ASME Code, Section VIII, used as a design guide.  
 b. Location of summary of stress and dynamic calculations or experimental testing.  
 c. American Concrete Institute.  
 d. National Electric Manufacturers' Association.  
 e. Sheet Metal and Air Conditioning Contractors National Association.  
 f. Oak Ridge National Laboratory.

TABLE 3.9-11

## FUEL ASSEMBLY WITH 100-mil CHANNELS

|                               | <u>Horizontal Seismic Loadings</u>         |                               |                                               |                                            |                               |                                               |
|-------------------------------|--------------------------------------------|-------------------------------|-----------------------------------------------|--------------------------------------------|-------------------------------|-----------------------------------------------|
|                               | OBE                                        |                               |                                               | DBE                                        |                               |                                               |
|                               | <u>80-mil<br/>Calculated<sup>(b)</sup></u> | <u>100-mil<br/>Calculated</u> | <u>Seismic<br/>Design Basis<sup>(a)</sup></u> | <u>80-mil<br/>Calculated<sup>(b)</sup></u> | <u>100-mil<br/>Calculated</u> | <u>Seismic<br/>Design Basis<sup>(a)</sup></u> |
| Shear at top of fuel (lb)     | 335                                        | 300                           | 446                                           | 630                                        | 563                           | 892                                           |
| Shear at bottom of fuel (lb)  | 350                                        | 279                           | 436                                           | 660                                        | 523                           | 871                                           |
| Maximum fuel moment (lb-in.)  | 19,200                                     | 13,800                        | 21,600                                        | 35,800                                     | 25,900                        | 43,200                                        |
| Maximum fuel acceleration (g) |                                            | 0.834                         | 1.5                                           |                                            | 1.56                          | 3.0                                           |

a. The seismic design basis loading allowances were determined after considering normal loads for the OBE case and accident loads for the DBE case. Design basis loadings are the same for 80-mil and 100-mil channels.

b. See reference 4.

**TABLE 3.9-12 (SHEET 1 OF 2)**

**RPV SUPPORT EQUIPMENT**

| <u>Criteria</u>                                                                                                                                                                                                      | <u>Loading</u>                                               | <u>Location</u>     | <u>Allowable Stress (psi)</u> | <u>Calculated Stress (psi)</u> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------|---------------------|-------------------------------|--------------------------------|
| <u>RPV stabilizer</u>                                                                                                                                                                                                |                                                              |                     |                               |                                |
| Primary stress limit:                                                                                                                                                                                                |                                                              |                     |                               |                                |
| AISC specification for the construction, fabrication, and erection of structural steel for buildings. For normal and upset conditions, AISC allowable stresses, but without the usual increase for earthquake loads. | Upset condition: <sup>(b)</sup><br>Spring preload<br>OBE     | Rod                 | 84,000                        | $f_t = 78,200^{(a)}$           |
|                                                                                                                                                                                                                      |                                                              | Bracket             | 22,000                        | $f_b = 20,900$                 |
|                                                                                                                                                                                                                      |                                                              |                     | 14,000                        | $f_v = 13,220$                 |
| For emergency conditions, 1.5 x AISC allowable stresses.                                                                                                                                                             | Emergency condition: <sup>(b)</sup><br>Spring preload<br>DBE | Bracket             | 33,000                        | $f_b = 24,500$                 |
|                                                                                                                                                                                                                      |                                                              |                     | 21,000                        | $f_v = 15,510$                 |
| For faulted conditions, material yield strength.                                                                                                                                                                     | Faulted condition: <sup>(b)</sup><br>Spring preload<br>DBE   | Bracket             | 36,000                        | $f_b = 26,100$                 |
|                                                                                                                                                                                                                      |                                                              |                     | 21,500                        | $f_v = 16,510$                 |
|                                                                                                                                                                                                                      |                                                              | Jet reactor load    |                               |                                |
| <u>CRD housing support</u>                                                                                                                                                                                           |                                                              |                     |                               |                                |
| Primary stress limit:                                                                                                                                                                                                |                                                              |                     |                               |                                |
| AISC specification for the design, fabrication, and erection of structural steel for buildings.                                                                                                                      | Faulted condition: <sup>(c)</sup><br>loads                   | Beams (top cord)    | 33,000                        | $f_a = 12,200$                 |
|                                                                                                                                                                                                                      |                                                              |                     | 33,000                        | $f_b = 16,500$                 |
|                                                                                                                                                                                                                      | Deadweight<br>Impact force from failure<br>of CRD housing    | Beams (bottom cord) | 33,000                        | $f_a = 10,300$                 |
|                                                                                                                                                                                                                      |                                                              |                     | 33,000                        | $f_b = 11,700$                 |



HNP-2-FSAR-3

**TABLE 3.9-12 (SHEET 2 OF 2)**

| <u>Criteria</u>                         | <u>Loading</u>                                                                                     | <u>Location</u> | <u>Allowable Stress (psi)</u> | <u>Calculated Stress (psi)</u> |
|-----------------------------------------|----------------------------------------------------------------------------------------------------|-----------------|-------------------------------|--------------------------------|
| For normal and upset conditions:        | (Deadweights and earthquake loads are very small as compared to jet force and are not considered.) | Grid structure  | 41,500                        | $f_b = 40,700$                 |
| $F_a = 0.60 F_y$ (tension)              |                                                                                                    |                 | 27,500                        | $f_v = 11,100$                 |
| $F_b = 0.60 F_y$ (bending)              |                                                                                                    |                 |                               |                                |
| $F_v = 0.40 F_y$ (shear)                |                                                                                                    |                 |                               |                                |
| For faulted conditions:                 |                                                                                                    |                 |                               |                                |
| $F_a \text{ limit} = 1.5 F_a$ (tension) |                                                                                                    |                 |                               |                                |
| $F_b \text{ limit} = 1.5 F_b$ (bending) |                                                                                                    |                 |                               |                                |
| $F_v \text{ limit} = 1.5 F_v$ (shear)   |                                                                                                    |                 |                               |                                |
| $F_y =$ material yield strength         |                                                                                                    |                 |                               |                                |

- 
- a. The ratio maximum stress limit is highest for upset loading conditions.
  - b. These loads were directly combined.
  - c. The only loading condition considered was faulted which assumes the instantaneous circumferential separation of a CRD housing.

TABLE 3.9-13 (SHEET 1 OF 5)

MAIN STEAM RELIEF VALVES (TARGET ROCK)

| <u>Topic</u>                          | <u>Method of Analysis</u>                                                                                                                                 | <u>Target Rock 7567F Analysis</u>                                                                    | <u>Allowable Value</u> | <u>Calculated</u>                                                                                                                               |
|---------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------|------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------|
| Body inlet and outlet flange stresses | $S_H = \frac{fM_O}{Lg_1^2B} + \frac{PB}{4g_0}$ $S_R = \frac{(4te/3 + 1) M_O}{Lt^2B}$ $S_T = \frac{\gamma M_O}{t^2B} - ZS_R$ <p>where:</p>                 | $S_H < 1.5 S_m$<br>$S_R < 1.5 S_m$<br>$S_T < 1.5 S_m$<br>Material: A 105 Gr II<br>$S_m = 19,400$ psi | 1.5 $S_m = 29,100$ psi | Inlet:<br>$S_H = 22,220$ psi<br>$S_R = 9953$ psi<br>$S_T = 21,905$ psi<br>Outlet:<br>$S_H = 6850$ psi<br>$S_R = 9629$ psi<br>$S_T = 26,251$ psi |
| Inlet stud area requirements          | Total cross-sectional area shall not exceed the greater of:<br>$A_{m_1} = \frac{W_{m_1}}{S_b} \text{ (or)}$ $A_{m_2} = \frac{W_{m_2}}{S_a}$ <p>where:</p> | $A_{m_1} = \frac{W_{m_1}}{S_b}$ $A_{m_2} = \frac{W_{m_2}}{S_a}$ Material: SA 192 Gr B7               | $A_{m_1} (> A_{m_2})$  | $A_m$ (actual) = 13.85 in. (required minimum)                                                                                                   |
|                                       | $A_{m_1}$ = total required bolt (stud) area for operating condition<br>$A_{m_2}$ = total required bolt (stud) area for gasket seating                     |                                                                                                      |                        |                                                                                                                                                 |

HNP-2-FSAR-3

TABLE 3.9-13 (SHEET 2 OF 5)

| <u>Topic</u>        | <u>Method of Analysis</u>                                                          | <u>Target Rock 7567F Analysis</u>                                                   | <u>Allowable Value</u>                                                                 | <u>Calculated</u>                                                           |
|---------------------|------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------|-----------------------------------------------------------------------------|
| Body wall thickness | Valve wall thickness criterion:                                                    | Section at inlet:                                                                   | $t_m 1 - 1 = 0.670$ in.                                                                | $t_a 1 - 1 = 1.125$ in.                                                     |
|                     | $t_{min} < t_a$                                                                    | $t_m 1 - 1 < t_a 1 - 1$                                                             |                                                                                        |                                                                             |
|                     | where:                                                                             |                                                                                     |                                                                                        |                                                                             |
|                     | $t_{min}$ = minimum calculated thickness requirement including corrosion allowance | Section at middle of body:<br>$t_m 2 - 2 < t_a 2 - 2$                               | $t_m 2 - 2 = 0.670$ in.<br>Actual thickness is > t at the section under consideration. | $t_a 2 - 2 = 0.859$ in.                                                     |
|                     | $t_a$ = actual wall thickness                                                      | Material SA 105                                                                     |                                                                                        |                                                                             |
|                     | (Note: This $t_{min}$ is $t_m$ per notation of codes.)                             |                                                                                     |                                                                                        |                                                                             |
|                     | Cyclic Rating:                                                                     |                                                                                     |                                                                                        |                                                                             |
|                     | Thermal                                                                            |                                                                                     |                                                                                        |                                                                             |
|                     | $I_t = \sum \frac{Nri}{Ni}$                                                        | $I_t = \sum \frac{Nri}{Ni}$ (i = 1, 2, & 3)                                         | $I_t$ (max) < 1                                                                        | $I_t = (0.33)$<br>( $I_t$ maximum)                                          |
|                     | Fatigue                                                                            |                                                                                     |                                                                                        |                                                                             |
|                     | $Na \geq 2,000$ cycles, as based on $Sa$ , where $Sa$ is defined as the larger of: | $Na \geq 2000$ cycles as based on $Sp$ where<br>$Sp$ (calculated) = $Sa$<br>(codes) | $Na \geq 2000$ cycles                                                                  | $Na$ (based on $Sp_2$ )<br>$1.8 \times 10^5$ cycles:<br>satisfies criterion |
|                     | $S_{p_1} = \left(\frac{2}{3}\right)Qp + \frac{Peb}{2} + Q_{T_2} + 1.3Q_{T_1}$      |                                                                                     |                                                                                        |                                                                             |
|                     | or                                                                                 | (Use same notation as codes.)                                                       |                                                                                        |                                                                             |
|                     | $S_{p_2} = 0.4Qp + \frac{K}{2}(Peb + 2Q_T)$                                        |                                                                                     |                                                                                        |                                                                             |

HNP-2-FSAR-3

TABLE 3.9-13 (SHEET 3 OF 5)

| <u>Topic</u>                    | <u>Method of Analysis</u>                                                                                                | <u>Target Rock 7567F Analysis</u>                                          | <u>Allowable Value</u>          | <u>Calculated</u>                                  |
|---------------------------------|--------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------|---------------------------------|----------------------------------------------------|
| Body wall thickness (continued) | Sp <sub>1</sub> = fatigue stress intensity at inside surface of crotch (psi)                                             |                                                                            |                                 |                                                    |
|                                 | Sp <sub>2</sub> = fatigue stress intensity at outside surface of crotch (psi)                                            |                                                                            |                                 |                                                    |
| Bonnet flange (body side)       | $S_R = \frac{6(M_p + M_s)}{t^2(\pi C - \eta D)}$                                                                         | S <sub>H</sub> < 1.5 S <sub>m</sub>                                        | 1.5 S <sub>m</sub> = 29,100 psi | S <sub>H</sub> = 0.44 (allowable)                  |
|                                 | $S_R = \left[ \frac{Q}{\pi B_1 t} + P \right] \pm \frac{6M_S}{\pi B_1 T}$                                                | S <sub>R</sub> < 1.5 S <sub>m</sub><br>S <sub>T</sub> < 1.5 S <sub>m</sub> |                                 | S <sub>R</sub> = 0.33 (allowable)                  |
|                                 | $S_T = \left[ \frac{Q}{\pi B_1 t} + P \right]^Z \pm \left[ \frac{Et\theta_B}{B_1} + \frac{1.8M}{\pi B_1 t^2} \right]$    |                                                                            |                                 | S <sub>T</sub> = 0.55 (allowable)                  |
|                                 | $S_{H_1} = \frac{PB_1}{4g_1} + \frac{6M_H}{\pi B_1 g_1^2}$                                                               | Material: A105 Gr II                                                       |                                 |                                                    |
|                                 | $S_{H_2} = \left[ \frac{Q}{\pi B_1 t} + P \right]^{-(Z+\gamma)} + \frac{Et\theta_B}{B_1}$                                | S <sub>m</sub> = 19,400 psi                                                |                                 |                                                    |
| Bonnet flange (bonnet side)     | Using table X of reference 3.9-22, superscribe Cases 2 and 3                                                             | S <sub>R</sub> < 1.5 S <sub>m</sub><br>S <sub>T</sub> < 1.5 S <sub>m</sub> | 1.5 S <sub>m</sub> = 29,100 psi | S <sub>R</sub> = S <sub>T</sub> = 0.85 (allowable) |
|                                 | $S_R = S_T = \frac{-3W}{2\pi m t^2} \left[ m + (m+1)\log \frac{a}{r_0} - (m-1)\frac{r_0^2}{4a^2} \right]$                |                                                                            |                                 |                                                    |
|                                 | $S_R = S_T = \frac{-3W}{2\pi m t^2} \left[ \frac{1}{2}(m-1) + (m+1)\log \frac{a}{r_0} - (m-1)\frac{r_0^2}{2a^2} \right]$ |                                                                            |                                 |                                                    |
|                                 | Material: A 105 Gr III S <sub>m</sub> = 19,400                                                                           |                                                                            |                                 |                                                    |

HNP-2-FSAR-3

TABLE 3.9-13 (SHEET 4 OF 5)

| <u>Topic</u>                       | <u>Method of Analysis</u>                                                                                                                                                                                                                                                                          | <u>Target Rock 7567F Analysis</u>                                                                                                 | <u>Allowable Value</u> | <u>Calculated</u>                                                                        |
|------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------|------------------------|------------------------------------------------------------------------------------------|
| Bonnet stud area requirements      | <p>Total cross-sectional area shall exceed:</p> $A_m = \frac{W_m}{S_b}$ <p>where:</p> <p><math>A_m</math> = total required bolt (stud) area for operating condition</p>                                                                                                                            | $A_m = \frac{W_m}{S_b}$ <p>Material: SA 193 Gr 37</p>                                                                             | $A_m = 9.839$          | $A_m$ (actual = 10.272)<br>(required minimum)                                            |
| Pilot valve housing wall thickness | <p>Using Table XIII, Case 35 of reference 3.9-22 considering the circumferential stress, <math>S_2</math> (governing stress) setting equal to <math>S_m</math></p> $S_2 = P \frac{b^2 + a^2}{b^2 - a^2}$ <p>where:</p> <p>P = design pressure<br/>a = inside diameter<br/>b = outside diameter</p> | $T_m < T_a$                                                                                                                       | $T_m = 0.119$ in.      | $T_a = 3.75 T_m$                                                                         |
| Pilot valve housing flange         | $S_H = \frac{fM_O}{Lg_1^2B}$ $S_R = \frac{(4te/3 + 1)M_O}{Lt^2B}$ $S_T = \frac{\gamma M_O}{t^2B} - ZS_R$                                                                                                                                                                                           | $S_H < 1.5 S_m$<br><br>$S_R < 1.5 S_m$<br><br>$S_T = 1.55 S_m$ <p>Material:<br/>A 105 Gr II<br/><math>S_m = 19,400</math> psi</p> | $1.5 S_m = 27,300$ psi | $S_H = 0.33$ (allowable)<br><br>$S_R = 0.20$ (allowable)<br><br>$S_T = 0.17$ (allowable) |

HNP-2-FSAR-3

TABLE 3.9-13 (SHEET 5 OF 5)

| <u>Topic</u>                           | <u>Method of Analysis</u>                                                                                                                                                                                                                                                                | <u>Target Rock 7567F Analysis</u>              | <u>Allowable Value</u> | <u>Calculated</u>              |
|----------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------|------------------------|--------------------------------|
| Pilot valve housing flange (continued) | where:<br>$S_A$ = longitudinal hub wall stress (psi)<br>$S_H$ = radial flange stress (psi)<br>$S_T$ = tangential flange stress (psi)                                                                                                                                                     |                                                |                        |                                |
| Pilot valve body flange stress         | Using Table X, Case 2 of reference 3.9-22<br><br>$S_R = S_T = \frac{-3W}{2\pi mt^2} \left[ m + (m+1)\log\frac{a}{r_0} - (m-1)\frac{r_0^2}{4a^2} \right]$ where:<br>$W$ = applied load<br>$m$ = reciprocal of Poisson's ratio<br>$a$ = radius of flange<br>$r_0$ = radius of applied load | $S_R = S_T < S_m$<br><br>Material: A 105 Gr II | $S_m = 19,400$ psi     | $S_R = S_T = 0.33$ (allowable) |
| Main disc stress                       | Using reference 3.9-22<br><br>$S_{\max} = \frac{\beta W a^2}{t_0^2}$ where:<br>$\beta$ = 1.63<br>$W$ = applied load<br>$a$ = radius of disc<br>$t_0$ = thickness at center                                                                                                               | $S_{\max} < S_m$                               | $S_m = 13,600$ psi     | $S_{\max} = 0.68$ (allowable)  |

HNP-2-FSAR-3

**TABLE 3.9-14 (SHEET 1 OF 14)**

**MAIN STEAM ISOLATION VALVES**

| <u>Criteria</u>                   | <u>Method of Analysis</u>                                                                                                                                                                                                                                                                                                                                                     | Allowable Stress or Minimum Thickness (in.) | Calculated Stress or Actual Thickness (in.) |
|-----------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------|---------------------------------------------|
|                                   | All references are made to ASME B&PV Code, Section III, Nuclear Power Plant Components, 1971 Edition, as addended by Summer 1971, Winter 1971, unless otherwise specified. Reference Reference the same code for explanation of the symbols used.                                                                                                                             |                                             |                                             |
| Body minimum wall thickness       | Reference paragraph NB-3543, Nonstandard Pressure-Rated Valve, Table NB-3542-1.<br><br>For design condition of 1250 psig and 575°F, the primary service rating = 495 based on a core diameter of 21.83 in. $t_m = 1.48$ in. (including a corrosion allowance of 0.12 in.).                                                                                                    | 1.48                                        | 1.79                                        |
| Body shape rule                   | Reference paragraph NB-3544, Body Shape Rules.                                                                                                                                                                                                                                                                                                                                |                                             |                                             |
| Radius of crotch                  | Reference paragraph NB-3544.1(a), Radius of Crotch.<br><br>criterion $r_2 \leq 0.3 t_m$ as $r_2 = 0.88$ in., $t_m = 1.48$ in. $\rightarrow 0.88 \geq 0.3 \times 1.480 = 0.4044$ criterion satisfied.                                                                                                                                                                          |                                             |                                             |
| Corner radii on internal surfaces | Reference paragraph NB-3544.1(b), Corner Radii on Internal Surfaces.<br><br>criterion $r_4 < r_2$ ; $r_4 = 0.62$ in., $r_2 = 0.88$ in. $\rightarrow 0.62 < 0.88$ criterion satisfied.                                                                                                                                                                                         |                                             |                                             |
| Out of roundness                  | Reference paragraph NB-3544.5, Out of Roundness, Figure NB-3545.1-2.<br><br>criterion $\frac{b}{t_b} + \frac{3}{4} \left( \frac{3b^2 - 2ab - a^2}{t_b^2} \right) + 1 \leq 1.5 \frac{S_m}{P_s}$<br><br>where:<br><br>$a = 6.87$ in., $b = 11.67$ in., $t_b = 3.21$ in., $S_m = 19,400$ psi at 500°F for ASME SA 216 WCB<br>$\rightarrow 19.27 \leq 21.56$ criterion satisfied. |                                             |                                             |
| Longitudinal curvature            | Reference paragraph NB-3544.6, Longitudinal Curvature.<br><br>criterion $\frac{1}{r_{long}} + \frac{1}{r_{lat}} \geq \frac{4}{3d_m}$ where: $r_{long} = 37.63$ in., $r_{lat} = 11.67$ in., $d_m = 21.83$ in.<br>$\rightarrow 0.11 \geq 0.06$ criterion satisfied                                                                                                              |                                             |                                             |

HNP-2-FSAR-3

**TABLE 3.9-14 (SHEET 2 OF 14)**

| <u>Criteria</u>                                        | <u>Method of Analysis</u>                                                                                                                                                                                                                                                                                  | Allowable Stress or Minimum Thickness (in.) | Calculated Stress or Actual Thickness (in.) |
|--------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------|---------------------------------------------|
| Flat wall limitation                                   | Reference paragraph NB-3544.7, Flat Wall Limitation.<br><br>criterion $\frac{d}{t} \leq \frac{3 d_m}{2 t_m}$ where: $d_m = 21.83$ in., $t_m = 1.48$ in., $d = 32.75$ in., $t = 3.70$ in.<br>$\rightarrow 8.85 \leq 22.13$ criterion satisfied.                                                             |                                             |                                             |
| Minimum wall at weld end                               | Reference paragraph NB-3544.8, Minimum Wall at Weld End.<br><br>Actual thickness at 1 x 1 in. (i.e., 1.48 in.) measured alone. The run direction is 2.05 in.                                                                                                                                               | 1.48                                        | 2.05                                        |
| Primary crotch stress due to internal pressure         | Reference paragraph NB-3545.1.<br><br>criterion $P_m = \left( \frac{A_p}{A_m} + 0.5 \right) P_s < S_m$<br><br>where: $A_p = 404.53$ in. <sup>2</sup> , $A_m = 77.59$ in. <sup>2</sup> , $P_s = 1350$ psig, $P_m = 7713$ psi, $S_m = 19,400$ psi<br>$\rightarrow S_m > P_m$ criterion satisfied.            | 19,400                                      | 7713                                        |
| Valve body secondary stress                            | Reference paragraph NB-3545.2.                                                                                                                                                                                                                                                                             |                                             |                                             |
| Primary plus secondary stress due to internal pressure | Reference paragraphs NB-3545.2(a)(1), NB-3545.2(a)(2).<br><br>$Q_p = C_p \left( \frac{r_i}{t_e} + 0.5 \right) P_s$<br><br>where: $C_p = 3$ , $r_i = 9.1$ in., $P_s = 1350$ psi, $t_e = 2.58$ , $Q_p = 16,310$ psi<br>for wye-type valve $Q'_p = C_a Q_p$ where: $C_a = 1.33 \rightarrow Q'_p = 21,692$ psi |                                             |                                             |
| Secondary stress due to pipe reaction <sup>(1)</sup>   | Reference paragraphs NB-3545.2(b) and NB-3524; Figures NB-3545.2-3, NB-3545.2-5, and NB-3545.2-6.                                                                                                                                                                                                          |                                             |                                             |
| Direct or axial load effect                            | $P_{ed} = \frac{F_d S}{G_d}$<br><br>where: $S = 41,000$ , $F_d = 27$ in. <sup>2</sup> , $G_d = 144$ in. <sup>2</sup> $\rightarrow P_{ed} = 7688$ psi                                                                                                                                                       | 29,100                                      | 7688<br>1162 <sup>(3)</sup>                 |



HNP-2-FSAR-3

TABLE 3.9-14 (SHEET 3 OF 14)

| Criteria                                  | Method of Analysis                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  | Allowable Stress or Minimum Thickness (in.) | Calculated Stress or Actual Thickness (in.) |
|-------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------|---------------------------------------------|
| Bending load effect                       | $P_{eb} = C_b \frac{F_b S}{G_b}$ <p>where: <math>S = 41,000</math>, <math>F_b = 295 \text{ in.}^3</math>, i.d. = 21.83 in., <math>r_i = 9.10</math>, <math>t_e = 2.58</math>, <math>\bar{r} = 10.39 \text{ in.}</math></p> $\frac{t_e}{\bar{r}} = 0.25 > 0.19 \rightarrow C_b = 1$ $G_b = \frac{I}{r_i + t_e}$ <p>where: <math>I = 7889 \text{ in.}^4</math>, <math>r_i = 9.10 \text{ in.}</math>, <math>t_e = 2.58 \text{ in.} \rightarrow G_b = 675 \text{ in.}^3</math></p> $\rightarrow P_{eb} = 1 \times \frac{295 \times (41,000)}{675} = 17,919 \text{ psi}$ | 29,100                                      | 17,919<br>1437 <sup>(3)</sup>               |
| Torsion load effect                       | <p>Reference paragraphs NB-3545.2(b)(1), NB-3545.2(b)(6)(c).</p> $P_{et} = 2 \frac{F_b S}{G_t}$ <p>where: <math>F_b = 295 \text{ in.}^3</math>, <math>S = 41,000 \text{ psi}</math></p> $G_t = C_t \bar{A} \bar{t}$ <p>where: <math>C_t = 1.75</math>, <math>\bar{A} = 345 \text{ in.}^2</math>, <math>\bar{t} = 2.26 \text{ in.} \rightarrow G_t = 1364 \text{ in.}^3</math></p> $\rightarrow P_{et} = 17,734 \text{ psi}$                                                                                                                                         | 29,100                                      | 17,734<br>160 <sup>(3)</sup>                |
| Thermal secondary stress at crotch region | <p>Reference paragraph NB-3545.2(c); Figures NB-3545.2(c)-2, NB-3545.2(c)(2), NB-3545.2(c)-3, NB-3545.2(c)-3, and NB-3545.2(c)-4.</p> $Q_T = Q_{T_1} + Q_{T_2}$ <p>where: <math>T_{e_1} = 4.20 \text{ in.}</math>, <math>Q_{T_1} = 2100</math></p> $Q_{T_2} = C_6 C_2 \Delta T_2$ <p>where: <math>C_2 = 0.53</math>, <math>C_6 = 220</math>, and <math>\Delta T_2 = 5^\circ\text{F} \rightarrow Q_{T_2} = 583 \text{ psi}</math></p>                                                                                                                                |                                             |                                             |

HNP-2-FSAR-3

TABLE 3.9-14 (SHEET 4 OF 14)

| Criteria                                    | Method of Analysis                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              | Allowable Stress or Minimum Thickness (in.) | Calculated Stress or Actual Thickness (in.) |
|---------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------|---------------------------------------------|
| Normal duty valve fatigue requirements      | <p>criterion <math>S_N = Q'_p + P_{ed} + 2Q_{T_2} \leq 3 S_m</math></p> <p>where: <math>Q'_p = 21,692</math> , <math>P_{ed} = 7688</math>, <math>Q_{T_2} = 583</math></p> <p>→ <math>30,546 \leq 58,200</math> criterion satisfied.</p> <p>Reference paragraphs NB-3545.3, NB-3545.3(a), and NB-3545.3a; Figure 1-9-1.</p> <p>criterion <math>N_a \geq 2000</math> cycles</p> $S_{p_1} = \frac{2}{3} Q'_p + \frac{P_{eb}}{2} + Q_{T_3} + 1.3 Q_{T_1}, \quad S_{p_2} = 0.4 Q'_p + \frac{K}{2} (P_{eb} + 2Q_{T_3})$ <p>where: <math>Q'_p = 21,692</math> , <math>P_{eb} = 17,919</math>, <math>K = 2</math>, <math>Q_{T_1} = 2100</math>, <math>Q_{T_3} = 682</math> psi</p> <p>→ <math>S_{p_1} = 26,822</math> , <math>S_{p_2} = 27,938</math> , <math>S_a =</math> to larger of <math>S_{p_1}</math> and <math>S_{p_2}</math> → <math>S_a = 27,938</math></p> <p>→ <math>N_a = 25,000 \geq 2000</math> criterion satisfied.</p> | 58,200                                      | 30,546                                      |
| Cyclic loading requirements at valve crotch | <p>Reference paragraph NB-3550.</p> <p>For the largest temperature change range</p> <p>criterion <math>Q'_p + P_{ed} + C_6 C_2 C_4 \Delta T_{f \max} \leq 3 S_m</math></p> <p>where: <math>Q'_p = 21,692</math> psi, <math>P_{ed} = 7688</math>, <math>C_6 = 220</math> at <math>\Delta T_{f \max}</math> of <math>342^\circ\text{F}</math>, <math>C_2 = 0.52</math>, <math>C_4 = 0.23</math>, <math>S_m = 19,400</math></p> <p>→ <math>38,379 \leq 58,200</math> criterion satisfied.</p> <p>Thermal transients not excluded by Code: criterion <math>\sum \frac{N_{ri}}{N_i} &lt; 1</math></p> <p>Calculate the fatigue usage factor (<math>I_f</math>) as follows: <math>C_3 = 0.61</math></p> $S_{n \max} = Q'_p + P_{eb} + C_6 C_3 C_4 \Delta T_{f \max} \rightarrow S_{n \max} = 50,167 \text{ psi}$                                                                                                                      | 58,200                                      | 38,379                                      |

HNP-2-FSAR-3

**TABLE 3.9-14 (SHEET 5 OF 14)**

| Criteria                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | Method of Analysis                                                                                                              | Allowable Stress or Minimum Thickness (in.) | Calculated Stress or Actual Thickness (in.) |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------|---------------------------------------------|
| <p>Since <math>S_{n \max} &lt; 3 S_m</math> (<math>= 58,200</math>), the following equation is used:</p> $S_i = \frac{4}{3} Q'_p + P_{eb} + C_6(C_3 C_4 + C_5) \Delta T_{fi}$ <p>for <math>\Delta T_{fi} = 342^\circ\text{F}</math>, <math>N_{ri} = 8</math>, <math>S_i = 140,162</math> psi, <math>N_i = 1500</math>, <math>N_{ri} / N_i = 0.005</math></p> <p><math>\Delta T_{fi} = 122^\circ\text{F}</math>, <math>N_{ri} = 10</math>, <math>S_i = 80,131</math> psi, <math>N_i = 8000</math>, <math>N_{ri} / N_i = 0.001</math></p> <p><math>\Delta T_{fi} = 90^\circ\text{F}</math>, <math>N_{ri} = 120</math>, <math>S_i = 71,400</math> psi, <math>N_i = 15,000</math>, <math>N_{ri} / N_i = 0.008</math></p> <p>where: <math>I_t = \sum \frac{N_{ri}}{N_i} = 0.014 &lt; 1</math> criterion satisfied.</p> | Reference paragraph NB-3546.3, Table I-1.1, Roark, 4th Edition, pp 220 and 222.                                                 |                                             |                                             |
| Disk design calculation                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           | Disk design conditions, $P_s = 1350$ psi at $500^\circ\text{F}$ , $S_m = 20,800$ psi at $500^\circ\text{F}$                     |                                             |                                             |
| Case No. 13: $S = \frac{3W}{4\pi t^2(a^2 - b^2)} \left[ a^4(3m+1) + b^4(m-1) - 4m a^2 b^2 - 4(m+1)a^2 b^2 \ln(a/b) \right]$                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       | where: $W = 1350$ psi, $m = 10/3$ , $t = 4.63$ in., $a = 9.25$ in., $b = 2.28$ in., $\rightarrow S_t = 11,261$ psi              |                                             |                                             |
| Case No. 14: $S = \frac{3W}{2\pi m t^2} \left[ \frac{2a^2(m+1)}{a^2 - b^2} \ln\left(\frac{a}{b}\right) + (m-1) \right]$                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           | where: $W = 60,134$ lb <sub>f</sub> , $t = 4.63$ in., $m = 10/3$ , $a = 9.25$ in., $b = 2.28$ in., $\rightarrow S_t = 6130$ psi |                                             |                                             |
| $S_t = S_{t \text{ Case No. 13}} + S_{t \text{ Case No. 14}} = 17,391 \leq 20,800$                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |                                                                                                                                 | 20,800                                      | 17,391                                      |
| Case No. 21: $S_r = \frac{3W}{4t^2} \left[ \frac{4a^4(m+1)\ln\left(\frac{a}{b}\right) - a^4(m+3) + b^4(m-1) + 4a^2 b^2}{a^2(m+1) + b^2(m-1)} \right]$                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             | where: $W = 1350$ , $m = 10/3$ , $t = 1.80$ in., $a = 9.25$ , $b = 7.75$ in. $\rightarrow S_r = 3102$ psi                       |                                             |                                             |

HNP-2-FSAR-3

**TABLE 3.9-14 (SHEET 6 OF 14)**

| Criteria              | Method of Analysis                                                                                                                      | Allowable Stress or Minimum Thickness (in.) | Calculated Stress or Actual Thickness (in.) |
|-----------------------|-----------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------|---------------------------------------------|
| Case No. 22:          | $S_r = \frac{3W}{2\pi t^2} \left[ \frac{2a^2 (m+1) \ln\left(\frac{a}{b}\right) + a^2 (m-1) - b^2 (m-1)}{a^2 (m+1) + b^2 (m-1)} \right]$ |                                             |                                             |
|                       | where: $W = 288,993$ , $m = 10/3$ , $t = 1.80$ , $a = 9.25$ , $b = 7.75 \rightarrow S_r = 15,885$ psi                                   |                                             |                                             |
|                       | Total Stress = $S_{r_{21}} + S_{r_{22}} = 18,987$ psi, allowable stress 20,800 psi                                                      | 20,800                                      | 18,987                                      |
|                       | $S_{\text{shear}}$ at inner edge disk                                                                                                   |                                             |                                             |
|                       | $S_{\text{shear}} = \frac{F}{A}$ where: $F = 60,134$ lb, $A = 64.9$ in. <sup>2</sup> $\rightarrow S_{\text{shear}} = 927$ psi           | 12,480                                      | 927                                         |
|                       | $S_{\text{shear}}$ at seat bore                                                                                                         |                                             |                                             |
|                       | $S_{\text{shear}} = \frac{F}{A}$ where: $F = 397,142$ lb, $A = 79$ in. <sup>2</sup> $\rightarrow S_{\text{shear}} = 5027$ psi           | 12,480                                      | 5027                                        |
|                       | Allowable shear stress = $0.6 \times$ allowable stress = $0.6 \times 20,800 = 12,480$ psi                                               |                                             |                                             |
|                       | Hub Tensile Stress                                                                                                                      |                                             |                                             |
|                       | $S = \frac{F}{A}$ where: $F = 281,566$ lb, $A = 44.6$ in. <sup>2</sup> $\rightarrow S = 6313$ psi                                       |                                             |                                             |
|                       | Allowable stress = 20,800 psi                                                                                                           | 20,800                                      | 6313                                        |
| Stem disk calculation | Reference Roark, 4th Edition, p 216, Table I-1.1.                                                                                       |                                             |                                             |
|                       | Design condition, $P_s = 1350$ psi at 500°F, allowable stress = 20,800 psi                                                              |                                             |                                             |
| Tensile and shear     | Case No. 1: $S_r = S_t = \frac{3W_p}{8\pi m t^2} (3m+1)$                                                                                |                                             |                                             |
|                       | where: $W_p = P \times A = 26,085$ lb, $m = 10/3$ , $t = 1.39$ in. $\rightarrow S_t = 5319$ psi                                         |                                             |                                             |

HNP-2-FSAR-3

TABLE 3.9-14 (SHEET 7 OF 14)

| Criteria                  | Method of Analysis                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  | Allowable Stress or Minimum Thickness (in.) | Calculated Stress or Actual Thickness (in.) |
|---------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------|---------------------------------------------|
|                           | <p>Case No. 3: <math>S_r = S_t = \frac{3W}{2\pi mt^2} \left[ \frac{1}{2}(m-1) + (m+1) \ln \left( \frac{a}{r_o} \right) - (m-1) \frac{r_o^2}{2a^2} \right]</math></p> <p>where: <math>W = 38,500</math>, <math>t = 1.39</math>, <math>a = 2.48</math>, <math>r_o = 1.31</math> in., <math>m = 10/3 \rightarrow S_t = 10,285</math> psi</p> <p><math>S = S_{t \text{ Case 1}} + S_{t \text{ Case 3}} = 15,604</math> psi</p>                                                                                                                                                                                                                                                                                                          |                                             |                                             |
|                           | <p>Shear stress above seat</p> <p><math>S_{\text{shear}} = \frac{F_s}{A}</math> where: <math>F_s = 64,585</math> lb<sub>f</sub>, <math>A = 16.51</math> in.<sup>2</sup> <math>\rightarrow S_{\text{shear}} = 3910</math> psi</p> <p>Allowable stress = <math>0.6 S_m = 12,480</math></p>                                                                                                                                                                                                                                                                                                                                                                                                                                            |                                             |                                             |
| Thread strength           | <p>1 7/8 - 12 UN - 2 Thread<br/>Reference Federal Thread Standard Part No. 1, page 5, (1957 Edition).</p> <p>Thread Shear Area</p> <p><math>AS_n = \pi n L_e D_{s \text{ min}} \left[ \frac{1}{2n} + 0.57735 (D_{s \text{ min}} - E_{n \text{ max}}) \right]</math></p> <p>where: <math>n = 12</math> threads/in., <math>D_{s \text{ min}} = 1.8618</math> in., <math>E_{n \text{ max}} = 1.8287</math> in., <math>L_e = 1.00</math> in.</p> <p><math>\rightarrow AS_n = 4.26</math> in.<sup>2</sup></p> <p><math>\rightarrow</math> Shear stress = <math>\frac{F}{AS_n} = 6593</math> psi, where: <math>F = 28,085</math> lb, <math>AS_n = 4.26</math> in.<sup>2</sup></p> <p>Allowable stress = <math>0.6 S_m = 12,480</math></p> |                                             |                                             |
| Piston design calculation | Design condition, $P_s = 1350$ psi at 500°F, $S_m = 19,400$ psi, ultimate tensile stress = 70,000                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |                                             |                                             |
| Thread strength           | <p>Thread Shear Area</p> <p><math>AS_s = \pi n L_e K_{n \text{ max}} \left[ \frac{1}{2n} + 0.57735 (E_{s \text{ min}} - K_{n \text{ max}}) \right]</math></p> <p>where: <math>K_{n \text{ max}} = 8.5147</math>, <math>L_e = 1.95</math> in. <math>\rightarrow AS_s = 35.24</math> in.<sup>2</sup>, <math>E_{s \text{ min}} = 8.5527</math>, <math>n = 8</math></p>                                                                                                                                                                                                                                                                                                                                                                 |                                             |                                             |

HNP-2-FSAR-3

**TABLE 3.9-14 (SHEET 8 OF 14)**

| Criteria                                 | Method of Analysis                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 | Allowable Stress or Minimum Thickness (in.) | Calculated Stress or Actual Thickness (in.) |
|------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------|---------------------------------------------|
| Hoop stress                              | <p>Actual shear stress = <math>\frac{F}{AS_s}</math> where: <math>F = 271,574</math> lb, <math>AS_s = 35.24</math> in.<sup>2</sup> → <math>S_a = 7707</math> psi</p> <p>Allowable stress = <math>0.6 S_n = 11,640</math></p>                                                                                                                                                                                                                                                                                                                                                                                                                                                       | 11,640                                      | 7707                                        |
| Hoop stress                              | <p>Reference Roark, 4th Edition, p 308, Case No. 34.</p> <p><math>S = P \left( \frac{2b^2}{b^2 - a^2} \right)</math> where: <math>b = 8.68</math> in., <math>P = 19,400</math> psi, <math>a = 7.55</math> in.</p> <p><math>S = 11,092</math> psi</p> <p>where: <math>11,092 \leq 19,400</math> condition acceptable</p>                                                                                                                                                                                                                                                                                                                                                            | 19,400                                      | 11,092                                      |
| Tensile stress at thread relief          | <p><math>S_m = \frac{F}{\Delta A_t}</math> where: <math>F = 283,132</math> lb, <math>\Delta A_t = A_1 - A_2 = 21.39</math> in.<sup>2</sup>, <math>S_m = 19,400</math> lb</p> <p><math>S_m = \frac{283,132}{21.39} \rightarrow S_m = 13,237</math> psi</p> <p>→ <math>13,237 &lt; 19,400</math> condition acceptable</p>                                                                                                                                                                                                                                                                                                                                                            | 19,400                                      | 13,237                                      |
| Bonnet design calculation <sup>(2)</sup> | <p>Reference paragraph NB-3647.1(a), paragraph UG-34(K)(2) of ASME Section VIII, Division 1, 1971 Edition.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                                             |                                             |
| Minimum thickness <sup>(2)</sup>         | <p><math>P_{fd} = P + P_{eg}</math>; <math>P_{eg} = \frac{16M}{\pi G^3} + \frac{4F}{\pi G^2}</math></p> <p><math>M = 455,937</math> } in.-lb, <math>F = 38,500</math> lb, <math>G = 19.25</math> in. → <math>P_{eg} = 458</math> psi, <math>P_{fd} = 1808</math> psi<br/> <math>M = 189,729^{(4)}</math> }</p> <p><math>t = d \sqrt{\frac{CP}{S} + \frac{1.78 W hg}{S_d^3}}</math> <math>M =</math> (combined seismic coefficient) (moment arm) (operator weight)</p> <p>where: <math>C = 0.3</math>, <math>P = 1808</math> psi, <math>S = 19,400</math> psi, <math>hg = 2.375</math> in., <math>W = 748,666</math> lb, <math>d = 19.25</math> in. → <math>t = 4.34</math> in.</p> |                                             |                                             |

HNP-2-FSAR-3

**TABLE 3.9-14 (SHEET 9 OF 14)**

| Criteria                                       | Method of Analysis                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        | Allowable Stress or Minimum Thickness (in.) | Calculated Stress or Actual Thickness (in.) |
|------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------|---------------------------------------------|
| Reinforcement <sup>(2)</sup>                   | <p>Reference paragraph UG-39(a)(2) of ASME Section VIII, Division 1, 1971 Edition (to account for opening for stem in the bonnet).</p> $t = \sqrt{2} \left( d \sqrt{\frac{CP}{S} + \frac{1.78 W hg}{S_d^3}} \right)$ <p>→ t = 6.21 in., t = 6.21 + 0.12 = 6.33 in. (corrosion allowance = 0.120 in.)</p>                                                                                                                                                                                                                                                                                                                                                                                                                  | 6.33                                        | 6.62                                        |
| Bonnet studs design calculation <sup>(2)</sup> | <p>Reference paragraph 3232.1 and Article E-1000.</p> <p>Bolt used 20 pieces of 1 3/8-UNC bolts.</p> <p>Total bolt area = 24.6 in.<sup>2</sup></p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |                                             |                                             |
| Normal operation <sup>(2)</sup>                | <p>Pressure stress at operating condition</p> $S_1 = \frac{W_{m1}}{A_b} = 29,642 \text{ lb/in.}^2 \text{ where: } W_{m1} = 729,201 \text{ lb, } A_b = 24.6 \text{ in.}^2$ <p>Gasket load at ambient condition with no internal pressure</p> $S_2 = \frac{W_{m2}}{A_b} = 3430 \text{ lb/in.}^2 \text{ where: } W_{m2} = 84,320 \text{ lb}_f, A_b = 24.6 \text{ in.}^2$ <p>Maximum tensile stress = 29,642 lb/in.<sup>2</sup></p> <p>Thermal stress is assumed negligible, because the coefficient of thermal expansion of bonnet plate and stud is the same.</p> <p>Standard preload = 45,000 psi.</p> <p>Higher stress condition = the standard preload.</p> <p>Allowable stress is 69,400 psi. Condition acceptable.</p> | 69,400                                      | 45,000                                      |
| Body flange design calculation <sup>(2)</sup>  | <p>Reference paragraph NB-3647.1 and ASME Section VIII, Division 1 of ASME B&amp;PV Code, 1971 Edition</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |                                             |                                             |

HNP-2-FSAR-3

**TABLE 3.9-14 (SHEET 10 OF 14)**

| <u>Criteria</u>                                    | <u>Method of Analysis</u>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | Allowable Stress or Minimum Thickness (in.) | Calculated Stress or Actual Thickness (in.) |
|----------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------|---------------------------------------------|
| Total flange moment under operating conditions     | $M_O = M_D + M_G + M_T$ $M_D = H_D h_D, H_D = 0.785 B^2 P, h_D = R + 0.591$ <p>where: <math>B = 18.5</math> in., <math>P = 1808</math> psi <math>\rightarrow H_D = 485,749</math> lb<sub>f</sub>, <math>h_D = 1.69</math> in., <math>M_D = 820,915</math> in.-lb</p> $M_G = H_G h_G, H_G = W - H, h_G = \frac{C - G}{2}$ <p>where: <math>W</math> is the higher of <math>W_{m_1}</math> and <math>W_{m_2}</math></p> $W_{m_1} = 0.785 G^2 P + (2b \times 3.14 G m P)$ $W_{m_2} = 3.14 G b y$ <p>where: <math>G = 19.25</math> in., <math>b = 0.31</math> in., <math>m = 3</math>, <math>y = 4500 \rightarrow W_{m_1} = 729,201</math> lb, <math>W_{m_2} = 84,320</math> lb</p> $H_G = 203,269$ lb, $h_G = 2.375$ in. $\rightarrow M_G = 480,389$ in.-lb $M_T = H_T h_T, H_T = H - H_D, h_T = \frac{R + g_1 + h_G}{2}$ <p>where: <math>H = 525,932</math>, <math>H_D = 485,749</math>, <math>R = 0.62</math> in., <math>g_1 = 2.13</math> in., <math>h_G = 2.38</math> in.</p> $\rightarrow H_T = 40,183$ lb, $h_T = 2.57$ in., $M_T = 103,270$ in.-lb <sub>f</sub> $M_O = 1,404,574$ in.-lb where: $M_D = 820,915$ in.-lb, $M_G = 480,389$ in.-lb,<br>$M_T = 103,270$ in.-lb |                                             |                                             |
| Total flange moment under gasket seating condition | $M_O = W \frac{(C - G)}{2}, W = \frac{(A_m + A_b)}{2} s_a$ <p>where: <math>C = 24</math> in., <math>A_b = 24.8</math> in.<sup>2</sup>, <math>G = 19.25</math> in., <math>A_m = 21.01</math> in.<sup>2</sup>, <math>s_a = 40,000</math> psi at 100°F</p> $\rightarrow W = 912,200$ lb $\rightarrow M_O = 2,166,475$ lb/in.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |                                             |                                             |



HNP-2-FSAR-3

**TABLE 3.9-14 (SHEET 11 OF 14)**

| <u>Criteria</u>                        | <u>Method of Analysis</u>                                                         | Allowable Stress or Minimum Thickness (in.) | Calculated Stress or Actual Thickness (in.) |
|----------------------------------------|-----------------------------------------------------------------------------------|---------------------------------------------|---------------------------------------------|
| Longitudinal hub stress <sup>(2)</sup> | Reference Paragraph NB-3647.1(c).                                                 |                                             |                                             |
|                                        | $S_H = \frac{fM_0}{L_{g1}^2 B} + \frac{PB}{4g_0}$                                 |                                             |                                             |
|                                        | at operating condition $S_H = 22,015$ psi                                         | 29,100                                      | 22,015 (14,481) <sup>(4)</sup>              |
|                                        | at atmospheric condition $S_H = 29,977$ psi                                       | 34,950                                      | 29,977 (21,572) <sup>(4)</sup>              |
| Radial stress <sup>(2)</sup>           | Reference UA-51(1), Equation (7) of Section VIII of ASME B&PV Code, 1971 Edition. |                                             |                                             |
|                                        | $S_R = \frac{(1.33t_e + 1)M_0}{Lt^2B}$                                            |                                             |                                             |
|                                        | at operating condition $S_R = 6605$ psi                                           | 29,100                                      | 6605 (5708) <sup>(4)</sup>                  |
|                                        | at atmospheric condition $S_R = 10,188$ psi                                       | 34,950                                      | 10,188 (9,318) <sup>(4)</sup>               |
| Tangential stress <sup>(2)</sup>       | Reference UA-51(1), Equation (8) of Section VIII of ASME B&PV Code, 1971 Edition  |                                             |                                             |
|                                        | $S_T = \frac{(YM_0)}{t^2B} - ZS_R$                                                |                                             |                                             |
|                                        | where: $Y = 5.0$ , $t = 4.25$ in., $Z = 2.60$ , $B = 18.50$ in.                   |                                             |                                             |
|                                        | at operating condition $S_T = 3844$ psi                                           | 29,100                                      | 3844 (4067) <sup>(4)</sup>                  |
|                                        | at atmospheric condition $S_T = 5928$ psi                                         | 34,950                                      | 5928 (6640) <sup>(4)</sup>                  |
| Flange stress criteria <sup>(2)</sup>  | Reference paragraph UA-52 of Section VIII of ASME B&PV Code, 1971 Edition.        |                                             |                                             |

HNP-2-FSAR-3

**TABLE 3.9-14 (SHEET 12 OF 14)**

| <u>Criteria</u>          | <u>Method of Analysis</u>                                              | Allowable Stress or Minimum Thickness (in.) | Calculated Stress or Actual Thickness (in.) |
|--------------------------|------------------------------------------------------------------------|---------------------------------------------|---------------------------------------------|
| criteria                 | $\frac{S_H + S_R}{2} < S_m ; \frac{S_H + S_T}{2} < S_m$                |                                             |                                             |
| at operating condition   | $\frac{S_H + S_R}{2} = 14,310 \text{ psi}$                             | 19,400                                      | 14,310 (10,096) <sup>(4)</sup>              |
|                          | $\frac{S_H + S_T}{2} = 12,930 \text{ psi}$                             | 19,400                                      | 12,930 (9,276) <sup>(4)</sup>               |
| at atmospheric condition | $\frac{S_H + S_R}{2} = 20,083 \text{ psi}$                             | 23,300                                      | 20,080 (15,445) <sup>(4)</sup>              |
|                          | $\frac{S_H + S_T}{2} = 17,953 \text{ psi}$                             | 23,300                                      | 17,953 (14,106) <sup>(4)</sup>              |
| Stem calculation         |                                                                        |                                             |                                             |
| Back-seated stress       | $S = \frac{F}{A}$                                                      |                                             |                                             |
|                          | where: F = 9616 lb net upward force                                    |                                             |                                             |
|                          | A = 2.268 in. <sup>2</sup> , smallest cross-sectional area on the stem |                                             |                                             |
|                          | S = 4240 psi < 26,700 psi                                              | 26,700                                      | 4240                                        |
| Valve close stem stress  | $S = \frac{F}{A}$                                                      |                                             |                                             |
|                          | where: F = 38,500 lb net down force                                    |                                             |                                             |
|                          | A = 2.268 in. <sup>2</sup> , smallest cross-sectional area on the stem |                                             |                                             |
|                          | S = 16,975 psi < 26,700 psi                                            | 26,700                                      | 16,975                                      |
| Disk entering seat       | $S = \frac{F}{A}$                                                      |                                             |                                             |

HNP-2-FSAR-3

**TABLE 3.9-14 (SHEET 13 OF 14)**

| <u>Criteria</u>      | <u>Method of Analysis</u>                                                                                                                                    | Allowable<br>Stress or<br>Minimum<br>Thickness<br>(in.)                                          | Calculated<br>Stress or<br>Actual<br>Thickness<br>(in.) |
|----------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------|---------------------------------------------------------|
| Stem thread strength | where: $F = 26,085$ disk load<br>$A = 2.268 \text{ in.}^2$ , smallest cross-sectional area on the stem<br>$S = 11,501 \text{ psi} < 26,700 \text{ psi}$      | 26,700                                                                                           | 11,501                                                  |
|                      | Reference Federal Thread Standard.<br>Stem Thread Mating with Disk<br>Thread 1.875 in. - 12 UN - 2 Thread                                                    | $A_{S_1} = \pi n L_e K_{n \max} \left[ \frac{1}{2n} + 0.57735 (E_{s \min} - K_{n \max}) \right]$ | 16,020                                                  |
|                      | where: $n = 12$ , $E_{s \min} = 1.8131$ , $L_e = 1.25 \text{ in.}$ , $K_{n \max} = 1.8030 \text{ in.}$ $A_{S_1} = 4.04 \text{ in.}^2$                        |                                                                                                  |                                                         |
|                      | $\tau = \frac{F}{A_{S_1}}$ where: $F = 38,500 \text{ lb}_f$ , $A_{S_1} = 4.04 \text{ in.}^2 \rightarrow \tau_{sd} = 9540 \text{ psi}$                        |                                                                                                  |                                                         |
|                      | Stem Thread Mating with Air Pneumatic Cylinder<br>Thread 2 in. - 12 UN - 2                                                                                   |                                                                                                  |                                                         |
|                      | $A_{S_2} = \pi n L_e K_{n \max} \left[ \frac{1}{2n} + 0.57735 (E_{s \min} - K_{n \max}) \right]$                                                             |                                                                                                  |                                                         |
|                      | where: $n = 12$ , $E_{s \min} = 1.9380 \text{ in.}$ , $L_e = 1.14 \text{ in.}$ , $K_{n \max} = 1.928 \text{ in.}$ $\rightarrow A_{S_2} = 3.93 \text{ in.}^2$ |                                                                                                  |                                                         |
|                      | $\tau = \frac{F}{A_{S_2}}$ where: $F = 31,400 \text{ lb}_f$ , $A_{S_2} = 3.93 \text{ in.}^2 \rightarrow \tau = 7990 \text{ psi}$                             | 16,020                                                                                           | 7990                                                    |

**TABLE 3.9-14 (SHEET 14 OF 14)****NOTES:**

1. Secondary stresses due to pipe reaction are limited in the adjoining pipe by specification to  $2 S_m$  at faulted conditions [peak pressure, thermal, deadweight, DBE, relief valve lift, and TSV closure].

$$(S)_{\text{torsion}} = \frac{M_A}{2 Z_{\text{pipe}}}$$

$$(S)_{\text{bending}} = \frac{\sqrt{M_B^2 + M_C^2}}{Z_{\text{pipe}}}$$

$$(S)_{\text{axial}} = \frac{F_A + P_A}{A_{\text{pipe}}}$$

where:  $M_{A,B,C}$  are moments due to

$$\left[ \text{peak pressure} + \text{thermal} + \text{deadweight} + \sqrt{\text{DBE}^2 + R/V_{\text{lift}} \text{ or } \text{TSV}_{\text{closure}}^2} \right]_{A,B,C}$$

$F_A$  and  $P_A$  are axial loads due to pipe reaction and peak pressure. The piping stress report includes those calculations to assure that the stresses are within the acceptable limit (table 3.9-14).

2. Calculations relating to the body flange, bonnet, and bolting design include the effects of the DBE plus valve actuation forces as converted per code (NB-3647) to an effective pressure. Stresses are then calculated to assure conformance to stress limits.
3. Calculated values based on maximum actual stress (S) determined from pipe system analysis.
4. Calculated values based on the maximum actual accelerations determined from pipe system analysis.

**TABLE 3.9-15 (SHEET 1 OF 3)**

**RECIRCULATION PUMPS**

| <u>Criteria</u>                                                                 | <u>Method of Analysis</u>                                                                                                                                                                              | <u>Analytical Results</u> | <u>Allowable Stress<br/>or<br/>Actual Thickness</u>             |
|---------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------|-----------------------------------------------------------------|
| <u>Casing minimum wall thickness</u>                                            | $t = \frac{PR}{SE - 0.6P} + C$                                                                                                                                                                         | t = 2.75 in.              | S <sub>allow</sub> = 15,114 psi                                 |
| Loads:                                                                          | where:                                                                                                                                                                                                 |                           | t <sub>act</sub> = 3.00 in.                                     |
| Normal and upset condition                                                      | t = minimum required thickness (in.)<br>P = design pressure (psig)<br>R = maximum internal radius (in.)<br>S = allowable working stress (psi)<br>E = joint efficiency<br>C = corrosion allowance (in.) |                           |                                                                 |
| Design pressure and temperature                                                 |                                                                                                                                                                                                        |                           |                                                                 |
| Primary membrane stress limit:                                                  |                                                                                                                                                                                                        |                           |                                                                 |
| Allowable working stress per ASME Section III, Class C                          |                                                                                                                                                                                                        |                           |                                                                 |
| <u>Casing cover minimum thickness</u>                                           | $S_s = \frac{F}{A}$                                                                                                                                                                                    | S <sub>s</sub> = 3370 psi | S <sub>allow</sub> = 8740 psi                                   |
| Loads:                                                                          | F = force<br>A = area at shear point                                                                                                                                                                   |                           | t <sub>act</sub> = 3.5 in.                                      |
| Normal and upset condition                                                      |                                                                                                                                                                                                        |                           |                                                                 |
| Design pressure and temperature                                                 |                                                                                                                                                                                                        |                           |                                                                 |
| Primary bending and shear stress limit:                                         |                                                                                                                                                                                                        |                           |                                                                 |
| 1.5 S <sub>m</sub> per ASME Code for Pumps and Valves for Nuclear Power Class I | $S_b = \frac{Kqa^2}{h^2}$<br>q = pressure load<br>a = radius of OD<br>b = radius of ID<br>h = plate thickness                                                                                          | S <sub>b</sub> = 5950 psi | S <sub>allow</sub> = 15,075 psi<br><br>t <sub>act</sub> = 7 in. |

HNP-2-FSAR-3

**TABLE 3.9-15 (SHEET 2 OF 3)**

| <u>Criteria</u>                                                                  | <u>Method of Analysis</u>                                                                                                                                                                                                                    | <u>Analytical Results</u>                                                                                                                                      | <u>Allowable Stress<br/>or<br/>Actual Thickness</u>            |
|----------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------|
| <u>Seal cover</u>                                                                |                                                                                                                                                                                                                                              |                                                                                                                                                                |                                                                |
| Loads:                                                                           |                                                                                                                                                                                                                                              |                                                                                                                                                                |                                                                |
| Normal and upset condition                                                       | Flange thickness shall be calculated in accordance with ASME Section VIII, Paragraph UG 34, Unstayed Flat Heads and Covers.                                                                                                                  | t = 2.59 in.                                                                                                                                                   | t <sub>act</sub> = 2.625 in.                                   |
| Design pressure and temperature<br>Design gasket load                            |                                                                                                                                                                                                                                              |                                                                                                                                                                |                                                                |
| <u>Seal chamber minimum wall thickness</u>                                       | $t = \frac{PR}{SE - 0.6P} + C$                                                                                                                                                                                                               | t = 0.741 in.                                                                                                                                                  | S <sub>allow</sub> = 15,075 psi                                |
| Loads:                                                                           | where:                                                                                                                                                                                                                                       |                                                                                                                                                                | t <sub>act</sub> = 1.375 in.                                   |
| Normal and upset condition                                                       | t = minimum required thickness (in.)<br>P = design pressure (psig)<br>R = maximum internal radius (in.)<br>S = allowable working stress (psi)<br>E = joint efficiency<br>C = corrosion allowance (in.)                                       |                                                                                                                                                                |                                                                |
| Design pressure and temperature<br>Piping reactions during normal operation      |                                                                                                                                                                                                                                              |                                                                                                                                                                |                                                                |
| Combined Stress Limit:                                                           |                                                                                                                                                                                                                                              |                                                                                                                                                                |                                                                |
| 1.5 S <sub>m</sub> per ASME Code for Pumps and Valves for Nuclear Power Class 1. |                                                                                                                                                                                                                                              |                                                                                                                                                                |                                                                |
| <u>Mounting bracket combined stress</u>                                          | Bracket vertical loads are determined by summing the equipment, fluid weights, and vertical seismic forces. Bracket horizontal loads are determined by applying the specified seismic force at mass center of pump-motor assembly (flooded). | Combined stress (shear plus tensile)<br><br>Lug #1 S <sub>C</sub> = 6506 psi<br><br>Lug #2 S <sub>C</sub> = 7976 psi<br><br>Lug #3 S <sub>C</sub> = 10,762 psi | S <sub>m</sub> = 15,150 psi<br><br>S <sub>y</sub> = 30,000 psi |
| Loads:                                                                           |                                                                                                                                                                                                                                              |                                                                                                                                                                |                                                                |
| Flooded weight                                                                   |                                                                                                                                                                                                                                              |                                                                                                                                                                |                                                                |
| DBE horizontal seismic force = 1.5 g                                             |                                                                                                                                                                                                                                              |                                                                                                                                                                |                                                                |
| DBE vertical seismic force = 0.144 g                                             |                                                                                                                                                                                                                                              |                                                                                                                                                                |                                                                |

HNP-2-FSAR-3

**TABLE 3.9-15 (SHEET 3 OF 3)**

| <u>Criteria</u>                                                                                                                                                                                                                             | <u>Method of Analysis</u>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             | <u>Analytical Results</u>                                                                                                                                                                                                                                            | <u>Allowable Stress<br/>or<br/>Actual Thickness</u>                                                                                                      |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>Combined stress limit:</p> <p>Yield stress</p>                                                                                                                                                                                           | <p>Horizontal and vertical loads are applied simultaneously to determine tensile, shear, and bending stresses in the brackets. Tensile, shear, and bending stresses are combined to determine maximum combined stresses.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          |                                                                                                                                                                                                                                                                      |                                                                                                                                                          |
| <p><u>Stresses due to the seismic loads</u></p> <p>Loads:</p> <p>Operation pressure and temperature<br/>DBE horizontal seismic force = 1.5 g<br/>DBE vertical seismic force = 0.144 g</p> <p>Combined stress limit:</p> <p>Yield stress</p> | <p>The flooded pump-motor assembly is analyzed as a free body supported by constant support hangers from the pump brackets. Horizontal and vertical seismic forces are applied at mass center of assembly, and equilibrium reactions are determined for the motor and pump brackets. Loads, shear, and moment diagrams are constructed using live loads, dead loads, and calculated snubber reactions. Combined bending, tension, and shear stresses are determined for each major component of the assembly including motor support barrel, bolting, and pump casing. The maximum combined tensile stress in the cover bolting is calculated using tensile stresses determined from loading diagram plus tensile stress from operating pressure.</p> | <p>Motor bolt tensile stress:</p> <p><math>S_{act} = 7500 \text{ psi}</math></p> <p>Pump cover bolt tensile stress:</p> <p><math>S_{act} = 19,000 \text{ psi}</math></p> <p>Motor support barrel combined stress:</p> <p><math>S_{act} = 1546 \text{ psi}</math></p> | <p><math>S_{allow} = 11,200 \text{ psi}</math></p> <p><math>S_{allow} = 32,000 \text{ psi}</math></p> <p><math>S_{allow} = 22,400 \text{ psi}</math></p> |

**TABLE 3.9-16 (SHEET 1 OF 8)**

**STRUCTURAL AND MECHANICAL LOADING CRITERIA**

Reactor Recirculation Gate Valve (28-in. Discharge)

The discharge valve is designed to accommodate loads transmitted by the piping system so that the maximum stress in the pipe, at the point of attachment to the valve, is 25,000 psi. The discharge valve and operator are designed to accommodate static seismic loadings of 1.5-g and 2.65-g horizontal, respectively, and 0.8-g and 1.0-g vertical, respectively, acting at the operator's center of mass.

The valve and operator were analyzed as a system using the loading combination of deadweight, peak pressure, and the absolute value of the DBE loading as an algebraic sum.

These calculated seismic loadings and stress are seen to be less than the design values in all cases. The following table establishes that the valve can accept the design piping and pressure loads.

| <u>Component Loads Design</u>         | <u>Design Procedure</u>                    | <u>Required Design Value</u>                           | <u>Actual Design Value</u> |
|---------------------------------------|--------------------------------------------|--------------------------------------------------------|----------------------------|
| <u>Body and bonnet</u>                |                                            |                                                        |                            |
| Loads:                                |                                            |                                                        |                            |
| Design pressure                       | System requirement                         | 1525 psi                                               | 1525 psi                   |
| Design temperature                    | System requirement                         | 575°F                                                  | 575°F                      |
| Peak pressure                         | System requirement                         | 1572 psi                                               | 1650 psi                   |
| Pressure rating (psi)                 | Used Tables 451.4 and 451.5 of NPVC        | $P_r = 799$ psi                                        | $P_r = 800$ psi            |
| Minimum wall thickness (in.)          | Used Table 452.1 of NPVC (dm = 22)         | $t_m \geq 2.114$ in.                                   | $t_m = 2.114$ min          |
| Primary membrane stress (psi)         | Used Paragraph 452.3 of NPVC               | $P_m \leq S_m (500^\circ\text{F}) = 19,600$ psi        | $P_m = 10,293$ psi         |
| Secondary stress due to pipe reaction | Used Paragraph 452.4b of NPVC (S = 25,000) | $P_e =$ greatest value of $P_{ed}$                     | $P_{ed} = 5580$ psi        |
|                                       |                                            | $P_{eb}$ and $P_{et} \leq 1.5 S_m (500^\circ\text{F})$ | $P_{eb} = 12,702$ psi      |
|                                       |                                            | $1.5 (19,600) = 29,400$ psi                            | $P_{et} = 12,277$ psi      |
|                                       |                                            |                                                        | $P_e = 12,702$ psi         |



HNP-2-FSAR-3

**TABLE 3.9-16 (SHEET 2 OF 8)**

| <u>Component Loads Design</u>                                                                | <u>Design Procedure</u>                                                                                                              | <u>Required Design Value</u>                                    | <u>Actual Design Value</u>                                |
|----------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------|-----------------------------------------------------------|
| Primary plus secondary stress due to internal pressure                                       | Used Paragraph 452.4a of NPVC.                                                                                                       | $S_n \leq 3 S_m (500^\circ\text{F}) = 58,800 \text{ psi}$       | $Q_p = 24,284 \text{ psi}$                                |
| Thermal secondary stress                                                                     | Used Paragraph 452.4c of NPVC.                                                                                                       | Same as above                                                   | $Q_T = 5591 \text{ psi}$                                  |
| Sum of primary plus secondary stress                                                         | Used Paragraph 452.4 of NPVC.                                                                                                        | Same as above                                                   | $S_n = 32,642 \text{ psi}$                                |
| Fatigue requirements                                                                         | Used Paragraph 452.5 of NPVC.                                                                                                        | $N_a \geq 2000 \text{ cycles}$                                  | $N_a \gg 10^5 \text{ cycles}$                             |
| Cyclic rating                                                                                | Used Paragraph 454 of NPVC.                                                                                                          | $I_t \leq 1$                                                    | $I_t = .004 \text{ (normal duty)}$                        |
| <u>Body-to-bonnet bolting</u>                                                                |                                                                                                                                      |                                                                 |                                                           |
| Loads:                                                                                       |                                                                                                                                      |                                                                 |                                                           |
| Design pressure and temperature, gasket loads, stem operational load, and seismic load (DBE) | USAS B31.7, Paragraph 1-704.5.1.<br>Used ASME Section VIII, 1968, Paragraphs UA-47 to UA-51, as required by Paragraph 453.1 of NPVC. |                                                                 |                                                           |
| 1.5-g horizontal (statically applied)                                                        |                                                                                                                                      |                                                                 |                                                           |
| 0.8-g vertical (statically applied)                                                          |                                                                                                                                      |                                                                 |                                                           |
| Bolt area                                                                                    | Same as above.                                                                                                                       | $A_b \geq 44.41 \text{ in.}^2$<br>$S_b \leq 28,800 \text{ psi}$ | $A_b = 55.86 \text{ in.}^2$<br>$S_b = 22,899 \text{ psi}$ |
| Body flange stresses                                                                         | USAS B31.7, Paragraph 1-704.5.1<br>Used ASME Section VIII, 1968, Paragraphs UA-47 to UA-51, as required by Paragraph 453.1 of NPVC.  |                                                                 |                                                           |

HNP-2-FSAR-3

**TABLE 3.9-16 (SHEET 3 OF 8)**

| <u>Component Loads Design</u> | <u>Design Procedure</u>                                                                                                                   | <u>Required Design Value</u>                                 | <u>Actual Design Value</u> |
|-------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------|----------------------------|
| Operating condition           | USAS B31.7, Paragraph 1-704.5.1<br>Used ASME Section VIII, 1968,<br>Paragraphs UA-47 to UA-51, as<br>required by Paragraph 453.1 of NPVC. | $S_H \leq 1.5 S_m (500^\circ\text{F}) = 29,400 \text{ psi}$  | $S_H = 26,021 \text{ psi}$ |
|                               |                                                                                                                                           | $S_R \leq 1.5 S_m (500^\circ\text{F}) = 29,400 \text{ psi}$  | $S_R = 8113 \text{ psi}$   |
|                               |                                                                                                                                           | $S_T \leq 1.5 S_m (500^\circ\text{F}) = 29,400 \text{ psi}$  | $S_T = 9019 \text{ psi}$   |
| Gasket seating condition      | USAS B31.7, Paragraph 1-704.5.1<br>Used ASME Section VIII, 1968,<br>Paragraphs UA-47 to UA-51, as<br>required by Paragraph 453.1 of NPVC. | $S_H \leq 1.5 S_m (100^\circ\text{F}) = 30,000 \text{ psi}$  | $S_H = 29,981 \text{ psi}$ |
|                               |                                                                                                                                           | $S_R \leq 1.5 S_m (100^\circ\text{F}) = 30,000 \text{ psi}$  | $S_R = 11,671 \text{ psi}$ |
|                               |                                                                                                                                           | $S_T \leq 1.5 S_m (100^\circ\text{F}) = 30,000 \text{ psi}$  | $S_T = 12,972 \text{ psi}$ |
| Bonnet flange                 |                                                                                                                                           |                                                              |                            |
| Operating condition           | Calculate bonnet flange thickness<br>according to rules of ASME Section VIII,<br>Art. UA-6, Figure UA-6c.                                 | $S_{\max} \leq S_m (500^\circ\text{F}) = 19,600 \text{ psi}$ | $S = 6232 \text{ psi}$     |
| <u>Stresses in Stem</u>       |                                                                                                                                           |                                                              |                            |
| Loads:                        |                                                                                                                                           |                                                              |                            |
| Operator thrust and torque    |                                                                                                                                           |                                                              |                            |
| Stem thrust stress            | Calculate stress due to operator thrust in<br>critical cross-section.                                                                     | $S_T \leq 0.8 S_m = 35,280 \text{ psi}$                      | $S_T = 28,512 \text{ psi}$ |
| Stem torque stress            | Calculate shear stress due to operator<br>torque in critical cross-section.                                                               | $S_S \leq 0.6 S_m = 26,460 \text{ psi}$                      | $S_S = 17,369 \text{ psi}$ |

HNP-2-FSAR-3

**TABLE 3.9-16 (SHEET 4 OF 8)**

| <u>Component Loads Design</u>    | <u>Design Procedure</u>                                                                        | <u>Required Design Value</u>                                     | <u>Actual Design Value</u>  |
|----------------------------------|------------------------------------------------------------------------------------------------|------------------------------------------------------------------|-----------------------------|
| <u>Disc Analysis</u>             |                                                                                                |                                                                  |                             |
| Loads:                           |                                                                                                |                                                                  |                             |
| Maximum differential pressure    |                                                                                                |                                                                  |                             |
| Maximum stress in disc           | Calculate maximum stress according to Table 10 of Roark's "Formula for Stress and Strain."     | $S_{\max} \leq 1.5 S_m (500^\circ\text{F}) = 28,500 \text{ psi}$ | Maximum stress = 22,885 psi |
| <u>Yoke and yoke connections</u> |                                                                                                |                                                                  |                             |
| Loads:                           |                                                                                                |                                                                  |                             |
| Stem operational load            | Calculate stresses in the yoke and yoke connections to acceptable structural analysis methods. |                                                                  |                             |
| Maximum stress in yoke           |                                                                                                | $S_{\max} \leq S_m = 19,400 \text{ psi}$                         | Maximum stress = 14,662 psi |

HNP-2-FSAR-3

**TABLE 3.9-16 (SHEET 5 OF 8)**

Reactor Recirculation Gate Valve (28-in. Suction)

The suction valve is designed to accommodate loads transmitted by the piping system so that the maximum stress in the pipe at the point of attachment to the valve is 25,000 psi. The suction valve and operator are designed to accommodate static seismic loadings of 1.5-g horizontal and 0.8-g vertical, acting at the operator's center of mass.

The valve and operator were analyzed as a system, using the loading combination of deadweight, peak pressure, and the absolute value of the DBE loading as an algebraic sum.

These calculated seismic loadings and stress are seen to be less than the design values in all cases. The following table establishes that the valve can accept the design piping and pressure loads.

| <u>Component Loads Design</u>         | <u>Design Procedure</u>                         | <u>Required Design Value</u>                           | <u>Actual Design Value</u>  |
|---------------------------------------|-------------------------------------------------|--------------------------------------------------------|-----------------------------|
| <u>Body and bonnet</u>                |                                                 |                                                        |                             |
| Loads:                                |                                                 |                                                        |                             |
| Design pressure                       | System requirement                              | 1275 psi                                               | 1275 psi                    |
| Design temperature                    | System requirement                              | 575°F                                                  | 575°F                       |
| Peak pressure                         | System requirement                              | 1362 psi                                               | 1400 psi                    |
| Pressure rating (psi)                 | Used Tables 451.4 and 451.5 of NPVC.            | $P_r = 668$ psi                                        | $P_r = 668$ psi             |
| Maximum wall thickness (in.)          | Used Table 452.1 of NPVC. (dm = 22)             | $t_m \geq 1.77$ in.                                    | $t_m = 1.77$ in.            |
| Primary membrane stress (psi)         | Used Paragraph 452.3 of NPVC.                   | $P_m \leq S_m (500^\circ\text{F}) = 19,600$ psi        | $P_m = 8606$ psi            |
| Secondary stress due to pipe reaction | Used Paragraph 452.4b of NPVC. (S = 25,000 psi) | $P_e =$ greatest value of $P_{ed}$                     | $P_{ed} = 5318$ psi         |
|                                       |                                                 | $P_{eb}$ and $P_{et} \leq 1.5 S_m (500^\circ\text{F})$ | $P_{eb} = 11,980$ psi       |
|                                       |                                                 | $1.5 (19,600) = 29,400$ psi                            | $P_{et} = 11,575$ psi       |
|                                       |                                                 |                                                        | $P_e = P_{eb} = 11,980$ psi |

HNP-2-FSAR-3

**TABLE 3.9-16 (SHEET 6 OF 8)**

| <u>Component Loads Design</u>                                                            | <u>Design Procedure</u>                                                                                                              | <u>Required Design Value</u>                                    | <u>Actual Design Value</u>                                |
|------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------|-----------------------------------------------------------|
| Primary plus secondary stress due to internal pressure                                   | Used Paragraph 452.4a of NPVC.                                                                                                       | $S_n \leq 3S_m (500^\circ\text{F}) = 58,800 \text{ psi}$        | $Q_p = 20,580 \text{ psi}$                                |
| Thermal secondary stress                                                                 | Used Paragraph 452.4c of NPVC.                                                                                                       | Same as above                                                   | $Q_T = 5704 \text{ psi}$                                  |
| Sum of primary plus secondary stress                                                     | Used Paragraph 452.4 of NPVC.                                                                                                        | Same as above                                                   | $S_n = 28,478 \text{ psi}$                                |
| Fatigue requirements                                                                     | Used Paragraph 452.5 of NPVC.                                                                                                        | $N_a \geq 2000 \text{ cycles}$                                  | $N_a \geq 7 \times 10^5 \text{ cycles}$                   |
| Cyclic rating                                                                            | Used Paragraph 454 of NPVC.                                                                                                          | $I_t \leq 1$                                                    | $I_t = 0.003 \text{ (normal duty)}$                       |
| <u>Body-to-bonnet bolting</u>                                                            |                                                                                                                                      |                                                                 |                                                           |
| Loads:                                                                                   |                                                                                                                                      |                                                                 |                                                           |
| Design pressure and temperature gasket loads, stem operational load, seismic load (DBE): | USAS B31.7, Paragraph 1-704.5.1.<br>Used ASME Section VIII, 1968, Paragraphs UA-47 to UA-51, as required by Paragraph 453.1 of NPVC. |                                                                 |                                                           |
| 1.5-g horizontal (statically applied)                                                    |                                                                                                                                      |                                                                 |                                                           |
| 0.8-g vertical (statically applied)                                                      |                                                                                                                                      |                                                                 |                                                           |
| Bolt area                                                                                | Same as above.                                                                                                                       | $A_b \geq 37.53 \text{ in.}^2$<br>$S_b \leq 28,800 \text{ psi}$ | $A_b = 55.86 \text{ in.}^2$<br>$S_b = 19,350 \text{ psi}$ |
| Body flange stresses                                                                     | USAS B31.7, Paragraph 1-704.5.1.<br>Used ASME Section VIII, 1968, Paragraphs UA-47 to UA-51, as required by Paragraph 453.1 of NPVC. |                                                                 |                                                           |

HNP-2-FSAR-3

**TABLE 3.9-16 (SHEET 7 OF 8)**

| <u>Component Loads Design</u> | <u>Design Procedure</u>                                                                                                                    | <u>Required Design Value</u>                           | <u>Actual Design Value</u> |
|-------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------|----------------------------|
| Operating condition           | USAS B31.7, Paragraph 1-704.5.1.<br>Used ASME Section VIII, 1968,<br>Paragraphs UA-47 to UA-51, as<br>required by Paragraph 453.1 of NPVC. | $S_H \leq 1.5 S_m (500^\circ F) = 29,400 \text{ psi}$  | $S_H = 23,456 \text{ psi}$ |
|                               |                                                                                                                                            | $S_R \leq 1.5 S_m (500^\circ F) = 29,400 \text{ psi}$  | $S_R = 6531 \text{ psi}$   |
|                               |                                                                                                                                            | $S_T \leq 1.5 S_m (500^\circ F) = 29,400 \text{ psi}$  | $S_T = 8703 \text{ psi}$   |
| Gasket seating condition      | USAS B31.7, Paragraph 1-704.5.1.<br>Used ASME Section VIII, 1968,<br>Paragraphs UA-47 to UA-51, as<br>required by Paragraph 453.1 of NPVC. | $S_H \leq 1.5 S_m (500^\circ F) = 30,000 \text{ psi}$  | $S_H = 28,945$             |
|                               |                                                                                                                                            | $S_R \leq 1.5 S_m (500^\circ F) = 30,000 \text{ psi}$  | $S_R = 10,253$             |
|                               |                                                                                                                                            | $S_T \leq 1.5 S_m (500^\circ F) = 30,000 \text{ psi}$  | $S_T = 13,619 \text{ psi}$ |
| Bonnet flange                 | USAS B31.7, Paragraph 1-704.5.1.<br>Used ASME Section VIII, 1968,<br>Paragraphs UA-47 to UA-51, as<br>required by Paragraph 453.1 of NPVC. |                                                        |                            |
| Operating condition           | Calculate bonnet flange thickness<br>according to rules of ASME Section VIII,<br>Art. UA-6, figure UA-6(c).                                | $S_{\max} \leq S_m (500^\circ F) = 19,600 \text{ psi}$ | $S = 5294 \text{ psi}$     |
| <u>Stresses in stem</u>       |                                                                                                                                            |                                                        |                            |
| Loads:                        |                                                                                                                                            |                                                        |                            |
| Operator thrust and torque    |                                                                                                                                            |                                                        |                            |
| Stem thrust stress            | Calculate stress due to operator thrust in<br>critical cross-section.                                                                      | $S_T \leq 0.8 S_m = 35,280 \text{ psi}$                | $S_T = 24,792 \text{ psi}$ |
| Stem torque stress            | Calculate shear stress due to operator<br>torque in critical cross-section.                                                                | $S_S \leq 0.6 S_m = 26,460 \text{ psi}$                | $S_S = 15,241 \text{ psi}$ |

HNP-2-FSAR-3

**TABLE 3.9-16 (SHEET 8 OF 8)**

| <u>Component Loads Design</u>    | <u>Design Procedure</u>                                                                       | <u>Required Design Value</u>                                     | <u>Actual Design Value</u>  |
|----------------------------------|-----------------------------------------------------------------------------------------------|------------------------------------------------------------------|-----------------------------|
| <u>Disc analysis</u>             |                                                                                               |                                                                  |                             |
| Loads:                           |                                                                                               |                                                                  |                             |
| Maximum differential pressure    |                                                                                               |                                                                  |                             |
| Maximum stress in disc           | Calculate maximum stress according to Table 10 of Roark's "Formula for Stress and Strain."    | $S_{\max} \leq 1.5 S_m (500^\circ\text{F}) = 28,500 \text{ psi}$ | Maximum stress = 19,418 psi |
| <u>Yoke and yoke connections</u> |                                                                                               |                                                                  |                             |
| Loads:                           |                                                                                               |                                                                  |                             |
| Stem operational load            |                                                                                               |                                                                  |                             |
| Maximum stress in yoke           | Calculate stresses in the yoke and yoke connections to acceptable structural analysis method. | $S_{\max} \leq S_m = 19,400 \text{ psi}$                         | Maximum stress = 14,662 psi |

LEGEND

NPVC = draft ASME Code for Pumps and Valves for Nuclear Power, 1978, including March 1970 Addendum.

**TABLE 3.9-17**

**HYDRAULIC CONTROL UNIT PIPING**

| <u>Criteria</u>                                                                                                                                  | <u>Loading</u>                                                                                                                                                                                                       | <u>Location</u>               | <u>Allowable Stress (psi)</u> | <u>Calculated Stress (psi)</u> |
|--------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------|-------------------------------|--------------------------------|
| For normal condition:<br>From ANSI B31.1, Code for Power Piping                                                                                  | Normal condition load<br><br>Maximum normal hydraulic system pump pressure                                                                                                                                           | 3/4-in. drive withdraw piping | $S_h = 15,000$                | 14,596                         |
| For normal condition:<br><br>$S_h = 15,000$ psi                                                                                                  |                                                                                                                                                                                                                      |                               |                               |                                |
| For upset and emergency condition:<br><br>When upset or emergency condition exists for < 1% of the time, the code allows 20% increase in stress. | Upset condition <sup>(a)</sup> load<br>Shutoff pump pressure<br>OBE (negligible load)                                                                                                                                | 3/4-in. drive withdraw piping | $1.2 S_h = 18,000$            | 17,056                         |
| $S_a = 1.2 S_h = 18,000$ psi                                                                                                                     | Emergency condition <sup>(a)</sup><br>Shutoff pump pressure<br>DBE (negligible load)<br><br>OBE: 1-g horizontal <sup>(b)</sup><br>(statically applied)<br>DBE: 2-g horizontal <sup>(b)</sup><br>(statically applied) | 3/4-in. drive withdraw piping | $1.2 S_h = 18,000$            | 17,162                         |

a. Vertical earthquake is not defined since only relatively short vertical piping runs are involved.  
b. These loads were directly combined.



**TABLE 3.9-18 (SHEET 1 OF 3)**

**SLC PUMP**

| <u>Criteria</u>                                                                                                                                                                 | <u>Method of Analysis</u>                                                                                        | <u>Allowable Stress (psi)</u> | <u>Calculated Stress (psi)</u> |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------|-------------------------------|--------------------------------|
| 1. <u>Closure bolting</u>                                                                                                                                                       | Bolting loads and stresses calculated per "Rules for Bolted Flange Connections," ASME Section VIII, Appendix II. | Stuffing box bolts = 25,000   | 18,150                         |
| Design condition <sup>(a)</sup> analyzed is operating condition and gasket seating condition resulting from:<br><br>Design pressure<br>Design temperature<br>Design gasket load |                                                                                                                  | Cylinder head bolts = 25,000  | 19,600                         |
| <u>Bolting stress limit</u>                                                                                                                                                     |                                                                                                                  |                               |                                |
| Allowable working stress per ASME Section VIII.                                                                                                                                 | Pressure area method maximum stress point on fluid cylinder.                                                     | 16,500                        | 9000                           |
| 2. <u>Wall thickness</u>                                                                                                                                                        |                                                                                                                  |                               |                                |
| Stress <sup>(a)</sup> is calculated at areas of thinnest wall section under operating conditions resulting from load combinations of design pressure and temperature.           |                                                                                                                  |                               |                                |
| <u>Stress limit</u>                                                                                                                                                             |                                                                                                                  |                               |                                |
| ASME Section VIII                                                                                                                                                               |                                                                                                                  |                               |                                |
| 3. <u>Motor mount bolts</u>                                                                                                                                                     | Seismic forces acting on motor subject bolts to tension and shear.                                               | Tension = 16,500              | 860                            |
| Design condition <sup>(a)</sup> to show bolting stressed by seismic loads are within the allowable limits.                                                                      |                                                                                                                  | Shear = 10,000                | 1220                           |

**TABLE 3.9-18 (SHEET 2 OF 3)**

| <u>Criteria</u>                                                                                                                                                                                                                                                          | <u>Method of Analysis</u>                                                                                             | <u>Allowable Stress (psi)</u>                                                     | <u>Calculated Stress (psi)</u>                                                                                                                                                                                                                                                                                                                                                             |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>Loads:</p> <p>Design basis earthquake 1.5-g horizontal, and 0.14-g vertical, plus deadweight.</p> <p><u>Stress limit</u></p> <p>0.9-yield tension and twice allowable shear per ASME Section VIII.</p>                                                                | <p>For the maximum moment due to pipe reaction, the maximum force shall not exceed the allowable.</p>                 |                                                                                   |                                                                                                                                                                                                                                                                                                                                                                                            |
| <p>4. <u>Nozzle Loads</u></p> <p>The design condition<sup>(a)</sup> analyzed is an uninterrupted operation during operating conditions resulting from design pressure, temperature, deadweight, thermal expansion, and OBE (horizontal = 0.75 g; vertical = 0.07 g).</p> | <p>Total nozzle stress with this criteria does not exceed stress limits. Mount bolts do not exceed stress limits.</p> | <p>Allowable Nozzle Forces and Moments, Force (lb),<br/><u>Moment (ft-lb)</u></p> | <p><u>Calculated Nozzle Forces and Moments</u></p>                                                                                                                                                                                                                                                                                                                                         |
|                                                                                                                                                                                                                                                                          |                                                                                                                       | <p><u>Suction</u></p> <p>M = 4.59 (711-F)<br/>not to exceed 1385 ft-lb</p>        | <p><u>Pump A</u></p> <p>F<sub>x</sub> = 58 lb    M<sub>x</sub> = 24 ft-lb<br/>F<sub>y</sub> = 64 lb    M<sub>y</sub> = 173 ft-lb<br/>F<sub>z</sub> = 131 lb    M<sub>z</sub> = 43 ft-lb</p> <p><u>Pump B</u></p> <p>F<sub>x</sub> = 55 lb    M<sub>x</sub> = 16 ft-lb<br/>F<sub>y</sub> = 24 lb    M<sub>y</sub> = 283 ft-lb<br/>F<sub>z</sub> = 164 lb    M<sub>z</sub> = 13 ft-lb</p>    |
|                                                                                                                                                                                                                                                                          |                                                                                                                       | <p><u>Discharge</u></p> <p>M = 2.3 (342-F)<br/>not to exceed 283 ft-lb</p>        | <p><u>Pump A</u></p> <p>F<sub>x</sub> = 196 lb    M<sub>x</sub> = 23 ft-lb<br/>F<sub>y</sub> = 216 lb    M<sub>y</sub> = 50 ft-lb<br/>F<sub>z</sub> = 66 lb    M<sub>z</sub> = 153 ft-lb</p> <p><u>Pump B</u></p> <p>F<sub>x</sub> = 228 lb    M<sub>x</sub> = 12 ft-lb<br/>F<sub>y</sub> = 163 lb    M<sub>y</sub> = 102 ft-lb<br/>F<sub>z</sub> = 129 lb    M<sub>z</sub> = 77 ft-lb</p> |

HNP-2-FSAR-3

**TABLE 3.9-18 (SHEET 3 OF 3)**

| <u>Criteria</u>                                                                                                                                                                                    | <u>Method of Analysis</u> | <u>Allowable Nozzle Forces and Moments,<br/>Force (lb), Moment (ft-lb)</u> | <u>Calculated Nozzle Forces<br/>and Moments</u>                                                                                                                         |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------|----------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| The design condition <sup>(a)</sup> analyzed is no functional failure resulting from design pressure, temperature, deadweight, thermal expansion, and DBE (horizontal = 1.5 g; vertical = 0.14 g). |                           | <u>Suction</u>                                                             | <u>Pump A</u><br>$F_x = 59 \text{ lb}$ $M_x = 27 \text{ ft-lb}$<br>$F_y = 68 \text{ lb}$ $M_y = 185 \text{ ft-lb}$<br>$F_z = 143 \text{ lb}$ $M_z = 45 \text{ ft-lb}$   |
|                                                                                                                                                                                                    |                           |                                                                            | <u>Pump B</u><br>$F_x = 83 \text{ lb}$ $M_x = 20 \text{ ft-lb}$<br>$F_y = 33 \text{ lb}$ $M_y = 292 \text{ ft-lb}$<br>$F_z = 176 \text{ lb}$ $M_z = 20 \text{ ft-lb}$   |
| <u>Stress limit</u><br><br>ASME Section VIII, for normal and upset condition; 1.5 of allowable stress for emergency. Mount bolts 0.9-yield for tension and twice allowable shear for emergency.    |                           | <u>Discharge</u>                                                           | <u>Pump A</u><br>$F_x = 198 \text{ lb}$ $M_x = 23 \text{ ft-lb}$<br>$F_y = 216 \text{ lb}$ $M_y = 50 \text{ ft-lb}$<br>$F_z = 66 \text{ lb}$ $M_z = 153 \text{ ft-lb}$  |
|                                                                                                                                                                                                    |                           |                                                                            | <u>Pump B</u><br>$F_x = 228 \text{ lb}$ $M_x = 12 \text{ ft-lb}$<br>$F_y = 163 \text{ lb}$ $M_y = 102 \text{ ft-lb}$<br>$F_z = 129 \text{ lb}$ $M_z = 77 \text{ ft-lb}$ |

a. These loads are combined directly.

**TABLE 3.9-19 (SHEET 1 OF 2)**

**SLC TANK**

| <u>Criteria</u>                                                           | <u>Method of Analysis</u>                                                                                                       | <u>Allowable Stress or Minimum Thickness Required (psi)</u> | <u>Calculated (psi)</u> |
|---------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|-------------------------|
| <u>Shell thickness</u>                                                    | Minimum thickness                                                                                                               | 3/16 in.                                                    | 0.015 in.               |
| Loads: normal and upset <sup>(a)</sup><br>Design pressure and temperature | $t = \frac{2.6D(H - 1)G \text{ in.}}{SE}$                                                                                       |                                                             |                         |
| Stress limit:<br>Allowable working stress per ASME Section VIII.          | D = nominal ID<br>H = tank height<br>G = specific gravity<br>S = allowable stress<br>E = joint efficiency<br><br>Not < 3/16 in. |                                                             |                         |
| <u>Shell stress:</u>                                                      | Loads will not produce excessive tensile or compressive (buckling) stresses.                                                    | <u>Tensile</u>                                              |                         |
| Loads: Emergency <sup>(a)</sup><br>OBE nozzle load                        |                                                                                                                                 | 10,000                                                      | 685                     |
| Stress limit:<br>ASME Section VIII,<br>compression 1/3 yield              |                                                                                                                                 | <u>Compressive</u><br><br>5190                              | 2190                    |

HNP-2-FSAR-3

**TABLE 3.9-19 (SHEET 2 OF 2)**

| <u>Criteria</u>                                                                                                                                                                                                                                                                                                                                                                                                                              | <u>Method of Analysis</u>                                                           | <u>Allowable Stress and Moments Force (lb), Moment (ft-lb)</u>                                                                                                                                                                                           | <u>Calculated Forces and Moments</u>                                                                                                                                                                                                              |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p><u>Allowable nozzle loads</u></p> <p>Application of forces and moments by attaching pipe on outlet nozzle under combined maximum thermal expansion, deadweight, and DBE loading reaction. Stress due to internal pressure shall not produce an equivalent bending and torsional stress in the nozzles or shell in excess of the allowable stress as defined by the ASME Boiler and Pressure Vessel Code, Section VIII. <sup>(a)</sup></p> | <p>Stresses will not be excessive if piping loads do not exceed the allowables.</p> | <p><math>F_C = 235 \text{ lb}</math>      <math>M_C = 366 \text{ in.-lb}</math><br/> <math>F_L = 235 \text{ lb}</math>      <math>M_L = 366 \text{ in.-lb}</math><br/> <math>F_R = 105 \text{ lb}</math>      <math>M_T = 1050 \text{ in.-lb}</math></p> | <p><math>F_X = 347 \text{ lb}</math>      <math>M_X = 106 \text{ ft-lb}</math><br/> <math>F_Y = 229 \text{ lb}</math>      <math>M_Y = 82 \text{ ft-lb}</math><br/> <math>F_Z = 435 \text{ lb}</math>      <math>M_Z = 8 \text{ ft-lb}</math></p> |

a. These loads were directly combined.

**TABLE 3.9-20 (SHEET 1 OF 3)**

**RHR PUMP**

| <u>Criteria</u>                                                                                                                                                                                                                                 | <u>Method of Analysis</u>                                                                                               | <u>Allowable Stress (psi)</u>                                                      | <u>Calculated Stress (psi)</u>     |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------|------------------------------------|
| <p>1. <u>Closure bolting</u><sup>(a)</sup></p> <p>The design condition analyzed considers the following loads:</p> <p>Design pressure and temperature</p> <p>Design gasket load</p>                                                             | <p>Bolting loads and stresses calculated per "Rules for Bolted Flange Connections," ASME Section VIII, Appendix II.</p> | <p>Maximum allowable stress = 25,000 using the OBE seismic acceleration values</p> | <p>Maximum calculated = 21,090</p> |
| <p>Seismic acceleration, nozzle forces, and/or moments, static mass forces. The seismic acceleration is applied in two directions:</p> <p>DBE (1.5-g horizontal)<br/>(0.14-g vertical)</p> <p>OBE (0.75-g horizontal)<br/>(0.07-g vertical)</p> |                                                                                                                         | <p>Maximum allowable stress = 94,500 using the DBE seismic acceleration values</p> | <p>Maximum calculated = 22,300</p> |
| <p>Bolting stress limit:</p> <p>Allowable working stress per ASME Section VIII</p>                                                                                                                                                              | <p>Per rules of Part UG, Section VIII</p>                                                                               | <p>Maximum allowable stress main pump = 17,500</p>                                 | <p>Maximum calculated = 11,360</p> |
| <p>2. <u>Wall thickness</u></p> <p>The design condition<sup>(a)</sup> analyzed considers the following loads:</p> <p>Design pressure and temperature</p> <p>Stress limit:</p> <p>ASME Section VIII</p>                                          |                                                                                                                         |                                                                                    |                                    |

**TABLE 3.9-20 (SHEET 2 OF 3)**

| Criteria                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           | Method of Analysis                               | Allowable Nozzle Forces and Moments, Force (lb), Moment (ft-lb)                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | Calculated Nozzle Forces and Moments |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------|
| <p>3. <u>Nozzle loads</u></p> <p>The design conditions<sup>(a)</sup> analyzed consider the following:</p> <p>Deadweight, thermal expansion, force and/or moment, and seismic acceleration applied in two directions:</p> <p>DBE (1.5-g horizontal)<br/>(0.14-g vertical)</p> <p>OBE (0.75-g horizontal)<br/>(0.07-g vertical)</p> <p>Stress limit:</p> <p>ASME Section VIII, primary local membrane stress<br/>1.5 of allowable stress when using OBE values<br/>1.8 of allowable stress when using DBE values</p> | <p>For maximum stresses due to maximum loads</p> | <p>The following expression relates allowable combination of forces and moments:</p> <div data-bbox="1062 532 1409 748" data-label="Figure"> </div> <p>where:</p> <p><math>F_i</math> = largest of three actual external orthogonal forces (<math>F_x</math>, <math>F_y</math>, and <math>F_z</math>) that may be imposed by the pipe.</p> <p><math>M_i</math> = largest of three actual external orthogonal moments (<math>M_x</math>, <math>M_y</math>, and <math>M_z</math>) permitted from the pipe when they are combined simultaneously for any condition.</p> <p><math>F_0</math> = allowable of <math>F_i</math> when all moments are zero.</p> <p><math>M_0</math> = allowable value of <math>M_i</math> when all forces are zero.</p> <p>The values of <math>F_0</math> and <math>M_0</math> are given below:</p> <p>Using the DBE seismic values:</p> <p>Suction: <math>F_0 = 10,610</math><br/><math>M_0 = 42,060</math></p> <p>Discharge: <math>F_0 = 11,050</math><br/><math>M_0 = 35,140</math></p> | <p>See following page.</p>           |

HNP-2-FSAR-3

**TABLE 3.9-20 (SHEET 3 OF 3)**

| <u>Criteria</u> | <u>Method of Analysis</u> | <u>Allowable Nozzle Forces and Moments, Force (lb), Moment (ft-lb)</u> | <u>Calculated Nozzle Forces and Moments</u>                        |
|-----------------|---------------------------|------------------------------------------------------------------------|--------------------------------------------------------------------|
|                 |                           |                                                                        | Using the DBE seismic values:                                      |
|                 |                           |                                                                        | <u>Pump A</u>                                                      |
|                 |                           |                                                                        | Suction: $F_i = 5915 \text{ lb}$<br>$M_i = 19,523 \text{ ft-lb}$   |
|                 |                           |                                                                        | Discharge: $F_i = 4540 \text{ lb}$<br>$M_i = 18,014 \text{ ft-lb}$ |
|                 |                           |                                                                        | <u>Pump B</u>                                                      |
|                 |                           |                                                                        | Suction: $F_i = 5001 \text{ lb}$<br>$M_i = 16,564 \text{ ft-lb}$   |
|                 |                           |                                                                        | Discharge: $F_i = 4540 \text{ lb}$<br>$M_i = 18,014 \text{ ft-lb}$ |
|                 |                           |                                                                        | <u>Pump C</u>                                                      |
|                 |                           |                                                                        | Suction: $F_i = 9005 \text{ lb}$<br>$M_i = 28,891 \text{ ft-lb}$   |
|                 |                           |                                                                        | Discharge: $F_i = 6496 \text{ lb}$<br>$M_i = 12,847 \text{ ft-lb}$ |
|                 |                           |                                                                        | <u>Pump D</u>                                                      |
|                 |                           |                                                                        | Suction: $F_i = 9174 \text{ lb}$<br>$M_i = 26,478 \text{ ft-lb}$   |
|                 |                           |                                                                        | Discharge: $F_i = 6496 \text{ lb}$<br>$M_i = 12,847 \text{ ft-lb}$ |

a. These loads were directly combined.



HNP-2-FSAR-3

**TABLE 3.9-21 (SHEET 1 OF 2)**

**RHR HEAT EXCHANGER**

| <u>Criteria</u>                                | <u>Method of Analysis</u>                                                                                       | <u>Minimum Thickness Required (in.)</u> | <u>Actual Thickness (in.)</u> |
|------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|-----------------------------------------|-------------------------------|
| 1. <u>Closure Bolting</u>                      | Bolting loads and stresses calculated per "Rules for Bolted Flange Connections" ASME Section VIII, Appendix II. |                                         |                               |
| Loads: Normal and upset <sup>(a)</sup>         |                                                                                                                 |                                         |                               |
| Design pressure and temperature                |                                                                                                                 |                                         |                               |
| Design gasket load                             |                                                                                                                 |                                         |                               |
| Bolting Stress Limit                           | Shell cover bolts                                                                                               | 1 1/4 (diameter)                        | 1 1/4                         |
| Allowable working stress per ASME Section VIII | Channel cover bolts                                                                                             | 1 1/4 (diameter)                        | 1 1/4                         |
| 2. <u>Wall Thickness</u>                       | Shell side ASME Section III, TEMA <sup>(b)</sup> Class C                                                        |                                         |                               |
| Loads: Normal and upset <sup>(a)</sup>         |                                                                                                                 |                                         |                               |
| Design pressure and temperature                | Tube side ASME Section VIII and TEMA <sup>(b)</sup> Class C                                                     |                                         |                               |
| Stress Limit                                   |                                                                                                                 |                                         |                               |
| ASME Section VIII                              | Shell                                                                                                           | 1.121                                   | 1.250                         |
|                                                | Shell cover                                                                                                     | 1.168                                   | 1.218                         |
|                                                | Channel ring                                                                                                    | 1.181                                   | 1.250                         |
|                                                | Tubes { 17 BWG                                                                                                  | 0.0492                                  | 0.052                         |
|                                                | { 18 BWG                                                                                                        | 0.0439                                  | 0.044                         |
|                                                | Channel cover                                                                                                   | 7.403                                   | 7.75                          |
|                                                | Tube sheet                                                                                                      | 6.047                                   | 6.0625                        |

HNP-2-FSAR-3

**TABLE 3.9-21 (SHEET 2 OF 2)**

| <u>Criteria</u>                                | <u>Method of Analysis</u>                                                                      | <u>Allowable Nozzle Forces and Moments, Force (lb) Moment (ft-lb)</u> | <u>Calculated Nozzle Forces and Moments</u> |
|------------------------------------------------|------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------|---------------------------------------------|
| 3. <u>Nozzle Loads</u>                         |                                                                                                |                                                                       |                                             |
| Design pressure and temperature <sup>(a)</sup> | Maximum moments due to pipe reaction and maximum forces shall not exceed the allowable limits. | See below.                                                            |                                             |
| Deadweight, thermal expansion and DBE:         | Primary stress < 1.8 of allowable per ASME Section VIII.                                       |                                                                       |                                             |
| 1.5-g horizontal (statically applied)          |                                                                                                |                                                                       |                                             |
| 0.5 g vertical (statically applied)            |                                                                                                |                                                                       |                                             |

Allowable limits  
Design basis

|                  | <u>N1</u>      | <u>N2</u>      | <u>N3</u>      | <u>N4</u>      |
|------------------|----------------|----------------|----------------|----------------|
| F <sub>x</sub> = | 29,400 lb      | 28,200 lb      | 45,800 lb      | 28,400 lb      |
| F <sub>y</sub> = | 28,400 lb      | 33,700 lb      | 47,500 lb      | 28,400 lb      |
| F <sub>z</sub> = | 28,400 lb      | 27,400 lb      | 45,800 lb      | 29,200 lb      |
| M <sub>x</sub> = | 460,000 lb-in. | 450,000 lb-in. | 746,000 lb-in. | 520,000 lb-in. |
| M <sub>y</sub> = | 520,000 lb-in. | 524,000 lb-in. | 885,000 lb-in. | 520,000 lb-in. |
| M <sub>z</sub> = | 520,000 lb-in. | 498,000 lb-in. | 746,000 lb-in. | 560,000 lb-in. |

|                  | <u>B001<br/>A&amp;B Inlet</u> | <u>B001<br/>A&amp;B Outlet</u> | <u>B001<br/>A&amp;B SW Inlet</u> | <u>B001<br/>A&amp;B SW Outlet</u> |
|------------------|-------------------------------|--------------------------------|----------------------------------|-----------------------------------|
| F <sub>x</sub> = | 2986 lb                       | 682 lb                         | 1984 lb                          | 4304 lb                           |
| F <sub>y</sub> = | 13,287 lb                     | 2898 lb                        | 4149 lb                          | 3766 lb                           |
| F <sub>z</sub> = | 9028 lb                       | 3213 lb                        | 2131 lb                          | 740 lb                            |
| M <sub>x</sub> = | 24,845 ft-lb                  | 17,214 ft-lb                   | 15,519 ft-lb                     | 6125 ft-lb                        |
| M <sub>y</sub> = | 10,079 ft-lb                  | 10,516 ft-lb                   | 8100 ft-lb                       | 11,223 ft-lb                      |
| M <sub>z</sub> = | 20,039 ft-lb                  | 2777 ft-lb                     | 5948 ft-lb                       | 8475 ft-lb                        |

- a. These loads are directly combined.  
b. Tubular Exchanger Manufacturers Association.

HNP-2-FSAR-3


**TABLE 3.9-22 (SHEET 1 OF 2)**

**CORE SPRAY PUMP**

| <u>Criteria</u>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         | <u>Method of Analysis</u>                                                                                               | <u>Allowable Stress (psi)</u>                                                                                                                                                 | <u>Calculated Stress (psi)</u>                                        |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------|
| <p>1. <u>Closure bolting</u></p> <p>The design condition<sup>(a)</sup> analyzed considers the following loads:</p> <p>Design pressure and temperature</p> <p>Design gasket load</p> <p>Seismic acceleration, nozzle forces, and/or moments, static mass forces. Seismic acceleration is applied in two directions:</p> <p style="padding-left: 40px;">DBE: (1.5-g horizontal)<br/>(0.14-g vertical)</p> <p style="padding-left: 40px;">OBE: (0.75-g horizontal)<br/>(0.07-g vertical)</p> <p>Bolting stress limit</p> <p style="padding-left: 40px;">Allowable working stress per ASME Section VIII</p> | <p>Bolting loads and stresses calculated per "Rules for Bolted Flange Connections," ASME Section VIII, Appendix II.</p> | <p>Maximum allowable stress = 25,000<br/>Using the OBE seismic acceleration values</p> <p>Maximum allowable stress = 94,500<br/>Using the DBE seismic acceleration values</p> | <p>Maximum calculated = 13,500</p> <p>Maximum calculated = 15,420</p> |
| <p>2. <u>Wall thickness</u></p> <p>The design condition<sup>(a)</sup> analyzed considers the following loads:</p> <p>Design pressure and temperature</p> <p>Stress limit</p> <p style="padding-left: 40px;">ASME Section VIII</p>                                                                                                                                                                                                                                                                                                                                                                       | <p>Per rules of ASME Section VIII, Part UG.</p>                                                                         | <p>Maximum allowable stress main pump = 17,500</p>                                                                                                                            | <p>Maximum calculated = 9230</p>                                      |

HNP-2-FSAR-3

**TABLE 3.9-22 (SHEET 2 OF 2)**

| Criteria                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | Method of Analysis                               | Allowable Nozzle Forces and Moments,<br>Force (lb) Moment (ft-lb)                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | Calculated Nozzle<br>Forces and Moments                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          |          |              |          |          |  |                |  |  |            |              |              |      |  |                |                |        |  |  |              |      |  |  |              |      |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|--------------|----------|----------|--|----------------|--|--|------------|--------------|--------------|------|--|----------------|----------------|--------|--|--|--------------|------|--|--|--------------|------|
| <p>3. <u>Nozzle loads</u></p> <p>The design conditions<sup>(a)</sup> analyzed consider the following:</p> <p>Deadweight, thermal expansion, force and/or moment, and seismic acceleration applied in two directions:</p> <p>DBE: (1.5-g horizontal)<br/>(0.14-g vertical)</p> <p>OBE: (0.75-g horizontal)<br/>(0.07-g vertical)</p> <p>Stress Limit</p> <p>ASME Section VIII, primary local membrane stress</p> <p>1.5 of allowable stress when using the OBE values</p> <p>1.8 of allowable stress when using the DBE values</p> | <p>For maximum stresses due to maximum loads</p> | <p>The following expression relates allowable combination of forces and moments:</p>  <p>where:</p> <p><math>F_i</math> = largest of three actual external orthogonal forces (<math>F_x</math>, <math>F_y</math>, and <math>F_z</math>) that may be imposed by the pipe.</p> <p><math>M_i</math> = largest of three actual external orthogonal moments (<math>M_x</math>, <math>M_y</math>, and <math>M_z</math>) permitted from the pipe when they are combined simultaneously for any condition.</p> <p><math>F_0</math> = allowable value of <math>F_i</math> when all moments are zero.</p> <p><math>M_0</math> = allowable value of <math>M_i</math> when all forces are zero.</p> | <p>The values of <math>F_0</math> and <math>M_0</math> are given below.</p> <p>Using the DBE seismic values:</p> <table border="0"> <tr> <td>Suction:</td> <td><math>F_0 = 6380</math></td> <td><u>A</u></td> <td><u>B</u></td> </tr> <tr> <td></td> <td><math>M_0 = 20,290</math></td> <td></td> <td></td> </tr> <tr> <td>Discharge:</td> <td><math>F_0 = 4460</math></td> <td><math>F_i = 4651</math></td> <td>4651</td> </tr> <tr> <td></td> <td><math>M_0 = 12,640</math></td> <td><math>M_i = 11,323</math></td> <td>11,323</td> </tr> <tr> <td></td> <td></td> <td><math>F_i = 4894</math></td> <td>3000</td> </tr> <tr> <td></td> <td></td> <td><math>M_i = 5191</math></td> <td>3100</td> </tr> </table> | Suction: | $F_0 = 6380$ | <u>A</u> | <u>B</u> |  | $M_0 = 20,290$ |  |  | Discharge: | $F_0 = 4460$ | $F_i = 4651$ | 4651 |  | $M_0 = 12,640$ | $M_i = 11,323$ | 11,323 |  |  | $F_i = 4894$ | 3000 |  |  | $M_i = 5191$ | 3100 |
| Suction:                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | $F_0 = 6380$                                     | <u>A</u>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | <u>B</u>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         |          |              |          |          |  |                |  |  |            |              |              |      |  |                |                |        |  |  |              |      |  |  |              |      |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | $M_0 = 20,290$                                   |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |          |              |          |          |  |                |  |  |            |              |              |      |  |                |                |        |  |  |              |      |  |  |              |      |
| Discharge:                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        | $F_0 = 4460$                                     | $F_i = 4651$                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               | 4651                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |          |              |          |          |  |                |  |  |            |              |              |      |  |                |                |        |  |  |              |      |  |  |              |      |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | $M_0 = 12,640$                                   | $M_i = 11,323$                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             | 11,323                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |          |              |          |          |  |                |  |  |            |              |              |      |  |                |                |        |  |  |              |      |  |  |              |      |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |                                                  | $F_i = 4894$                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               | 3000                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |          |              |          |          |  |                |  |  |            |              |              |      |  |                |                |        |  |  |              |      |  |  |              |      |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |                                                  | $M_i = 5191$                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               | 3100                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |          |              |          |          |  |                |  |  |            |              |              |      |  |                |                |        |  |  |              |      |  |  |              |      |

a. These loads were directly combined.

HNP-2-FSAR-3

**TABLE 3.9-23 (SHEET 1 OF 3)**

**HPCI TURBINE**

| <u>Criteria</u>                                                                                                                                                                                                           | <u>Method of Analysis</u>                                                                                        | <u>Allowable Stress (psi)</u>     | <u>Calculated Stress (psi)</u> |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------|-----------------------------------|--------------------------------|
| 1. <u>Closure bolting</u><br>Loads: Normal and upset <sup>(a)</sup><br>Design pressure and temperature<br>Design gasket load OBE <sup>(b)</sup><br>Bolting stress limit<br>Allowable working stress per ASME Section VIII | Bolting loads and stresses calculated per "Rules for Bolted Flange Connections," ASME Section VIII, Appendix II. | Maximum allowable stress = 20,000 | Maximum calculated = 18,290    |
| 2. <u>Casing wall thickness</u><br>Loads: Normal and upset <sup>(a)</sup><br>Design pressure and temperature<br>Design gasket load OBE <sup>(b)</sup><br>Stress limit<br>ASME Section VIII                                | Per rules of ASME Section VIII, Part UG.                                                                         | Maximum allowable stress = 14,000 | Maximum calculated = 8975      |

HNP-2-FSAR-3

**TABLE 3.9-23 (SHEET 2 OF 3)**

| <u>Criteria</u>                                       | <u>Method of Analysis</u>                                                                          | <u>Allowable Nozzle Forces and Moments Force (lb) Moment (ft-lb)</u>  | <u>Calculated Nozzle Forces and Moments</u>             |
|-------------------------------------------------------|----------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------|---------------------------------------------------------|
| 3. <u>Nozzle loads</u>                                |                                                                                                    |                                                                       |                                                         |
| Loads: normal <sup>(a)</sup>                          | For the resultant moment due to pipe reaction, the resultant force shall not exceed the allowable. | <u>Inlet</u><br>$F = (7570-M)/3$                                      | $F_R = 1405 \text{ lb}$<br>$M_R = 2933 \text{ ft-lb}$   |
|                                                       | Design analysis has demonstrated the acceptability of these values.                                | <u>Exhaust</u><br>$F = (9930-M)/3$                                    | $F_R = 2645 \text{ lb}$<br>$M_R = 11,768 \text{ ft-lb}$ |
| Deadweight and thermal expansion                      |                                                                                                    |                                                                       |                                                         |
| Loads: normal plus upset <sup>(a)</sup>               |                                                                                                    | <u>Inlet</u><br>$F = (20,000-M)/2.5$<br>but not to exceed 5000 lb     | $F_R = 1480 \text{ lb}$<br>$M_R = 5660 \text{ ft-lb}$   |
| Deadweight thermal expansion, and OBE <sup>(b)</sup>  |                                                                                                    | <u>Exhaust</u><br>$F = (20,000-M)/0.8$<br>but not to exceed 11,500 lb | $F_R = 2759 \text{ lb}$<br>$M_R = 12,162 \text{ ft-lb}$ |
| Loads: emergency <sup>(a)</sup>                       |                                                                                                    | <u>Inlet</u><br>$F = (30,000-M)/2.5$<br>but not to exceed 7500 lb     | $F_R = 2004 \text{ lb}$<br>$M_R = 6354 \text{ ft-lb}$   |
| Deadweight, thermal expansion, and DBE <sup>(a)</sup> |                                                                                                    | <u>Exhaust</u><br>$F = (30,000-M)/0.8$<br>but not to exceed 17,250 lb | $F_R = 3020 \text{ lb}$<br>$M_R = 12,558 \text{ ft-lb}$ |
| Stress limits                                         |                                                                                                    |                                                                       |                                                         |
|                                                       | Specified by vendor for normal; ASME Section VIII for upset; increased 20% for emergency.          |                                                                       |                                                         |

HNP-2-FSAR-3

**TABLE 3.9-23 (SHEET 3 OF 3)**

| <u>Criteria</u>                                                                                               | <u>Method of Analysis</u>                                                                                                                                                          | <u>Allowable Stress (psi)</u>                                                     | <u>Calculated Stress (psi)</u>                                                                                                                                         |
|---------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 4. <u>Turbine mounting bolts (turbine to base plate)</u>                                                      | Vertical and horizontal forces on mounting bolts and dowel pins calculated as the sum of seismic accelerations on the turbine and pipe reaction forces and moments of the nozzles. | 61,100                                                                            | 29,800                                                                                                                                                                 |
| Loads: normal and upset <sup>(a)</sup>                                                                        |                                                                                                                                                                                    |                                                                                   |                                                                                                                                                                        |
| OBE <sup>(b)</sup>                                                                                            |                                                                                                                                                                                    | Tensile and shear stress for bolting materials as specified in ASME Section VIII. | By meeting the nozzle load criteria of nozzle loads, the detailed seismic analysis indicates that mounting bolts and dowel pins satisfy allowable stress requirements. |
| Nozzle loads for OBE, dead weight, and thermal expansion                                                      |                                                                                                                                                                                    |                                                                                   |                                                                                                                                                                        |
| Loads: emergency <sup>(a)</sup>                                                                               |                                                                                                                                                                                    |                                                                                   |                                                                                                                                                                        |
| DBE <sup>(b)</sup>                                                                                            |                                                                                                                                                                                    |                                                                                   |                                                                                                                                                                        |
| Nozzle loads for DBE, dead weight, and thermal expansion                                                      |                                                                                                                                                                                    |                                                                                   |                                                                                                                                                                        |
| Stress limits                                                                                                 |                                                                                                                                                                                    |                                                                                   |                                                                                                                                                                        |
| ASME Section VIII allowables for normal and upset. For emergency 0.9-yield tension and twice allowable shear. |                                                                                                                                                                                    |                                                                                   |                                                                                                                                                                        |

a. These loads were directly combined.  
b. OBE = 0.75-g horizontal, 0.24-g vertical (statically applied).  
DBE = 1.5-g horizontal, 0.48-g vertical (statically applied).

**TABLE 3.9-24 (SHEET 1 OF 2)**

**HPCI PUMP**

| <u>Criteria</u>                                                                                                                                                                                                                                                                                                                                    | <u>Method of Analysis</u>                                                                                               | <u>Allowable Stress (psi)</u>                                                          | <u>Calculated Stress (psi)</u>                                                   |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------|----------------------------------------------------------------------------------|
| <p>1. <u>Closure bolting</u></p> <p>Design condition<sup>(a)</sup> analyzed is operating condition and gasket seating condition resulting from design pressure and temperature.</p> <p>Design gasket load resulting from design pressure plus gasket factor.</p> <p>Bolting stress limit</p> <p>Allowable working stress per ASME Section VIII</p> | <p>Bolting loads and stresses calculated per "Rules for Bolted Flange Connections," ASME Section VIII, Appendix II.</p> | <p>Maximum allowable stress</p> <p>main pump = 20,000</p> <p>booster pump = 20,000</p> | <p>Maximum calculated</p> <p>main pump = 19,950</p> <p>booster pump = 17,400</p> |
| <p>2. <u>Casing wall thickness</u></p> <p>Design condition<sup>(a)</sup> analyzed is stress due to pressure loading resulting from design pressure and temperature.</p> <p>Stress limit</p> <p>ASME Section VIII</p>                                                                                                                               | <p>Per rules of ASME Section VIII, Part UG, nozzle stress maximum case stress.</p>                                      | <p>Maximum allowable stress</p> <p>main pump = 14,000</p> <p>booster pump = 14,000</p> | <p>Maximum calculated</p> <p>main pump = 12,050</p> <p>booster pump = 3650</p>   |



HNP-2-FSAR-3

**TABLE 3.9-24 (SHEET 2 OF 2)**

| <u>Criteria</u>                                                                                                                                                                     | <u>Method of Analysis</u>                                                                              | <u>Allowable Nozzle Forces and Moments<br/>Force (lb) Moment (ft-lb)</u> | <u>Calculated Nozzle Forces and Moments</u>               |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------|-----------------------------------------------------------|
| 3. <u>Nozzle loads</u>                                                                                                                                                              |                                                                                                        |                                                                          |                                                           |
| Design condition <sup>(a)</sup> analyzed in uninterrupted operation during operating condition resulting from design pressure, temperature, deadweight, thermal expansion, and OBE: | For maximum resultant moment due to pipe reaction, maximum resultant force shall not exceed allowable. | Suction                                                                  | $F_R = 9265 \text{ lb}$<br>$M_R = 16,702 \text{ ft-lb}$   |
| (horizontal = 0.75 g)<br>(vertical = 0.07 g)                                                                                                                                        | Total nozzle stress with this criteria does not exceed stress limits.                                  | Discharge                                                                | $F_R = 2691 \text{ lb}$<br>$M_R = 13,898 \text{ ft-lb}$   |
| Design condition <sup>(a)</sup> analyzed is no functional failure resulting from design from design pressure, temperature, deadweight, thermal expansion, and DBE:                  |                                                                                                        | Suction                                                                  | $F_R = 11,600 \text{ lb}$<br>$M_R = 20,900 \text{ ft-lb}$ |
| (horizontal = 1.5 g)<br>(vertical = 0.14 g)                                                                                                                                         |                                                                                                        | Discharge                                                                | $F_R = 3850 \text{ lb}$<br>$M_R = 18,100 \text{ ft-lb}$   |
| Stress limit                                                                                                                                                                        |                                                                                                        |                                                                          |                                                           |
| ASME Section VIII, for normal and upset; 1.5 of allowable stress for emergency.                                                                                                     |                                                                                                        |                                                                          |                                                           |

a. These loads were directly combined.

**TABLE 3.9-25 (SHEET 1 OF 3)**

**RCIC TURBINE**

| <u>Criteria</u>                                                                                                                                                                                                                                                 | <u>Method of Analysis</u>                                                                                               | <u>Allowable Stress (psi)</u>            | <u>Calculated Stress (psi)</u>     |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------|------------------------------------------|------------------------------------|
| <p>1. <u>Closure bolting</u></p> <p>Loads: normal and upset<sup>(a)</sup></p> <p>    Design pressure and temperature</p> <p>    Design gasket load OBE<sup>(b)</sup></p> <p>Bolting stress limit:</p> <p>    Allowable working stress per ASME Section VIII</p> | <p>Bolting loads and stresses calculated per "Rules for Bolted Flange Connections," ASME Section VIII, Appendix II.</p> | <p>Maximum allowable stress = 25,000</p> | <p>Maximum calculated = 20,100</p> |
| <p>2. <u>Casing wall thickness</u></p> <p>Loads: normal and upset<sup>(a)</sup></p> <p>    Design pressure and temperature</p> <p>    OBE<sup>(b)</sup></p> <p>Stress limit:</p> <p>    ASME Section VIII</p>                                                   | <p>Per rules of ASME Section VIII, Part UG.</p>                                                                         | <p>Maximum allowable stress = 17,500</p> | <p>Maximum calculated = 12,700</p> |

HNP-2-FSAR-3

**TABLE 3.9-25 (SHEET 2 OF 3)**

| <u>Criteria</u>                                                               | <u>Method of Analysis</u>                                                                  | <u>Allowable Nozzles Forces and Moments</u><br><u>Force (lb) Moment (ft-lb)</u> | <u>Calculated Nozzle Forces and Moments</u>           |
|-------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------|-------------------------------------------------------|
| 3. <u>Nozzle loads</u>                                                        |                                                                                            |                                                                                 |                                                       |
| Loads: normal <sup>(a)</sup>                                                  | For resultant moment due to pipe reaction, resultant force shall not exceed the allowable. | <u>Inlet</u><br>$F = (2620-M)/3$                                                | $F_R = 765 \text{ lb}$<br>$M_R = 1730 \text{ ft-lb}$  |
| Deadweight and thermal expansion                                              | Detailed design analysis has demonstrated acceptability of these values.                   | <u>Exhaust</u><br>$F = (6000-M)/3$                                              | $F_R = 535 \text{ lb}$<br>$M_R = 4170 \text{ ft-lb}$  |
| Loads: normal plus upset <sup>(a)</sup>                                       |                                                                                            | <u>Inlet</u><br>$F = (3000-M)/2.5$                                              | $F_R = 1000 \text{ lb}$<br>$M_R = 2600 \text{ ft-lb}$ |
| Deadweight, thermal expansion, and OBE <sup>(b)</sup>                         |                                                                                            | <u>Exhaust</u><br>$F = 3(6000-M)$<br>but not to exceed 8370 lb                  | $F_R = 600 \text{ lb}$<br>$M_R = 5000 \text{ ft-lb}$  |
| Loads: emergency                                                              |                                                                                            | <u>Inlet</u><br>$F = (4500-M)/2.5$                                              | $F_R = 1090 \text{ lb}$<br>$M_R = 2780 \text{ ft-lb}$ |
| Deadweight, thermal expansion, and DBE <sup>(b)</sup>                         |                                                                                            | <u>Exhaust</u><br>$F = 3(9000-M)$<br>but not to exceed 12,555 lb                | $F_R = 925 \text{ lb}$<br>$M_R = 4860 \text{ ft-lb}$  |
| Stress limits:                                                                |                                                                                            |                                                                                 |                                                       |
| Specified by vendor for normal; ASME Section VIII for upset; increased by 20% |                                                                                            |                                                                                 |                                                       |

HNP-2-FSAR-3

**TABLE 3.9-25 (SHEET 3 OF 3)**

| <u>Criteria</u>                                                                                              | <u>Method of Analysis</u>                                                                                                                                              | <u>Allowable Stress (psi)</u>                                                                       | <u>Calculated Stress (psi)</u>                                                                                                                 |
|--------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------|
| 4. <u>Turbine mounting bolts (turbine to base plate)</u>                                                     | Vertical and horizontal forces on mounting bolts and dowel pins calculated as sum of seismic accelerations on turbine and pipe reaction forces and moments on nozzles. | 61,100                                                                                              | 26,800                                                                                                                                         |
| Loads: normal and upset <sup>(a)</sup>                                                                       |                                                                                                                                                                        | Tensile and shear stress for bolting materials as specified in ASME Section VIII.                   | By meeting nozzle load criteria, detailed seismic analysis indicates that mounting bolts and dowel pins satisfy allowable stress requirements. |
| OBE <sup>(c)</sup>                                                                                           |                                                                                                                                                                        |                                                                                                     |                                                                                                                                                |
| Nozzle loads for OBE, deadweight and thermal expansion                                                       |                                                                                                                                                                        |                                                                                                     |                                                                                                                                                |
| Loads: emergency                                                                                             |                                                                                                                                                                        | Tensile stress less than 0.9-yield and shear stress less than twice allowable of ASME Section VIII. |                                                                                                                                                |
| DBE <sup>(c)</sup>                                                                                           |                                                                                                                                                                        |                                                                                                     |                                                                                                                                                |
| Nozzle loads for DBE, deadweight and thermal expansion                                                       |                                                                                                                                                                        |                                                                                                     |                                                                                                                                                |
| Stress limits:                                                                                               |                                                                                                                                                                        |                                                                                                     |                                                                                                                                                |
| ASME Section VIII allowable for normal and upset. For emergency 0.9-yield tension and twice allowable shear. |                                                                                                                                                                        |                                                                                                     |                                                                                                                                                |

- a. These loads were directly combined.
- b. OBE = 0.75-g horizontal, 0.24-g vertical (statically applied).  
 DBE = 1.5-g horizontal, 0.48-g vertical (statically applied).
- c. OBE = 1.75-g horizontal, 0.24-g vertical (statically applied).  
 DBE = 1.5-g horizontal, 0.48-g vertical (statically applied).

HNP-2-FSAR-3

**TABLE 3.9-26 (SHEET 1 OF 2)**

**RCIC PUMP**

| <u>Criteria</u>                                                                                                                                                                                                                                                                                | <u>Method of Analysis</u>                                                                                               | <u>Allowable Stress (psi)</u>                          | <u>Calculated Stress (psi)</u>     |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------|------------------------------------|
| <p>1. <u>Closure bolting</u></p> <p>Design condition<sup>(a)</sup> analyzed is operating condition and gasket seating condition resulting from design pressure, temperature and design gasket load.</p> <p>Bolting stress limit:</p> <p>    Allowable working stress per ASME Section VIII</p> | <p>Bolting loads and stresses calculated per "Rules for Bolted Flange Connections," ASME Section VIII, Appendix II.</p> | <p>Maximum allowable stress = 25,000</p>               | <p>Maximum calculated = 22,600</p> |
| <p>2. <u>Casing wall thickness</u></p> <p>Design condition<sup>(a)</sup> analyzed is stress due to pressure loading resulting from design pressure and temperature.</p> <p>Stress limit:</p> <p>    Per ASME Section III</p>                                                                   | <p>Per rules of ASME Section VIII, Part UG, nozzle stress barrel.</p>                                                   | <p>Maximum allowable stress<br/>Main pump = 17,500</p> | <p>Maximum calculated = 9200</p>   |

HNP-2-FSAR-3

**TABLE 3.9-26 (SHEET 2 OF 2)**

| <u>Criteria</u>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             | <u>Method of Analysis</u>                                                                                                                                              | <u>Allowable Nozzle Forces and Moments</u><br><u>Force (lb) Moment (ft-lb)</u>                                                                              | <u>Calculated Nozzle Forces and Moments</u>                                                                                                                                                                                                                                                                                                 |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>3. <u>Nozzle loads</u></p> <p>Design condition<sup>(a)</sup> analyzed is uninterrupted operation during operating conditions resulting from design pressure, temperature, deadweight, thermal expansion, and OBE:</p> <p>(horizontal = 0.75 g)<br/>(vertical = 0.07 g)</p> <p>Design condition analyzed is no functional failure resulting from design pressure, temperature, deadweight, thermal expansion, and DBE:</p> <p>(horizontal = 1.5 g)<br/>(vertical = 0.14 g)</p> <p>Stress limit:</p> <p>ASME Section VIII for normal and upset; 1.5 of allowable stress for emergency.</p> | <p>For maximum moment due to pipe reaction, maximum force shall not exceed allowable.</p> <p>Total nozzle stress with this criteria does not exceed stress limits.</p> | <p>Suction</p> <p>F = 9400-2.50M</p> <p>Discharge</p> <p>F = 9400-4.33M</p> <p>Suction</p> <p>F = 19,000-2.42M</p> <p>Discharge</p> <p>F = 19,000-5.05M</p> | <p><math>F_R = 708 \text{ lb}</math><br/><math>M_R = 1050 \text{ ft-lb}</math></p> <p><math>F_R = 585 \text{ lb}</math><br/><math>M_R = 1970 \text{ ft-lb}</math></p> <p><math>F_R = 708 \text{ lb}</math><br/><math>M_R = 1050 \text{ ft-lb}</math></p> <p><math>F_R = 585 \text{ lb}</math><br/><math>M_R = 1970 \text{ ft-lb}</math></p> |

a. These loads were directly combined.

HNP-2-FSAR-3

TABLE 3.9-27 (SHEET 1 OF 3)

FUEL STORAGE RACKS

A. General Electric

| <u>Criteria</u>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | <u>Loading</u>                                            | <u>Location</u>                | <u>Allowable Stress (psi)</u>      | <u>Calculated Stress (psi)</u> |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|--------------------------------|------------------------------------|--------------------------------|
| New-fuel storage racks                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |                                                           |                                |                                    |                                |
| Stresses due to normal, upset, or emergency loading shall not cause racks to fail so as to result in a critical fuel array.                                                                                                                                                                                                                                                                                                                                                                       | Emergency condition                                       | Column                         | 16,000                             | 2950                           |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | Dead loads<br>Full fuel load in rack<br>DBE               | Base-to-column welds           | 11,000                             | 1100                           |
| Primary stress limit                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |                                                           |                                |                                    |                                |
| Paper Nos. 3341 and 3342, Proceedings of American Society of Civil Engineers, Structural Division, December 1962 (task committee on light-weight alloys).                                                                                                                                                                                                                                                                                                                                         |                                                           | Channel                        | 20,000                             | 3150                           |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |                                                           | Support channel-to-column weld | 6000                               | 2650                           |
| Spent-fuel storage racks                                                                                                                                                                                                                                                                                                                                                                                                                                                                          |                                                           |                                |                                    |                                |
| Stresses due to normal, upset, emergency, or faulted loading shall not cause racks to fail so as to result in a critical fuel array.                                                                                                                                                                                                                                                                                                                                                              | Loads:                                                    |                                |                                    |                                |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | Dead loads<br>Full fuel load in rack<br>DBE<br>Live loads |                                |                                    |                                |
| <u>Allowable Stresses</u>                                                                                                                                                                                                                                                                                                                                                                                                                                                                         |                                                           |                                |                                    |                                |
| Allowable stresses for each loading combination follow ASME Boiler and Pressure Vessel Code, Section III, Subsection NF, per "Operating Technical Position for Review and Acceptance of Spent Fuel Storage and Handling Applications." Only an elastic analysis was considered. The two controlling loading combination equations were found to be: D + L + OBE and D + L + SSE. D + L + T + SSE was also considered to check for elastic buckling per ASME Section III, Subsection NF. Allowable | <u>Stress Type</u>                                        | <u>D+L + OBE</u>               | <u>D+L + SEE</u>                   |                                |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | Tension (w/o pin hole)                                    | 0.6 Sy                         | Increased by<br>1.2 $\frac{Sy}{F}$ |                                |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | (w/pin hole)                                              | 0.45 Sy                        |                                    |                                |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | Shear                                                     | 0.4 Sy                         |                                    |                                |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | Bending Stress                                            | 0.66 Sy                        |                                    |                                |
| Bearing                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           | 0.9 Sy                                                    |                                |                                    |                                |

HNP-2-FSAR-3

**TABLE 3.9-27 (SHEET 2 OF 3)**

Allowable Stresses (continued)

stresses are given in Table 4-1 based on the following equations, and they are consistent with the requirements specified in Regulatory Guide 1.124.

NOTE: Sy and F are specified minimum yield strength and allowable tensile stress, respectively.

Emergency Condition B

Loading:

In addition to the loading conditions given on sheet 1 of 3, the racks were tested and analyzed to determine their capability to safely withstand the accidental, uncontrolled drop of the fuel grapple from its fully retracted position into the weakest portion of the rack.

Results of Analysis:

All criteria were met.

Analysis showed that the grapple would shear the welds in the area where the impact occurred. The longitudinal structural member bends but does not fail in shear. Grapple penetration into the rack is not sufficient to cause the vertical columns to deflect the fuel into a critical array. Static load testing showed that forces in excess of those resulting from a grapple drop are required to cause the columns to deflect to the extent that the criteria are violated.

| <u>Location/Type</u>                                            | <u>Comparison of Calculated Stress vs Allowables (psi)</u> |                                |                          |                                |
|-----------------------------------------------------------------|------------------------------------------------------------|--------------------------------|--------------------------|--------------------------------|
|                                                                 | <u>OBE Condition</u>                                       |                                | <u>SSE Condition</u>     |                                |
|                                                                 | <u>Calculated Stress</u>                                   | <u>Allowable<sup>(a)</sup></u> | <u>Calculated Stress</u> | <u>Allowable<sup>(a)</sup></u> |
| Tube wall shear                                                 | 6040                                                       | 11,000                         | 7400                     | 22,000                         |
| Tube wall compression                                           | 7180                                                       | 14,880                         | 8400                     | 29,760                         |
| Tube weld throat shear                                          | 8540                                                       | 11,000                         | 10,400                   | 22,000                         |
| Angle, weld throat shear                                        | 8540                                                       | 11,000                         | 10,400                   | 22,000                         |
| Casting wall shear                                              | 6240                                                       | 11,000                         | 9210                     | 22,000                         |
| Casting wall compression                                        | 11,600                                                     | 16,500                         | 12,500                   | 33,000                         |
| Casting base weld shear                                         | 4920                                                       | 11,000                         | 7250                     | 22,000                         |
| Support plate weld throat shear                                 | 3400                                                       | 11,000                         | 7250                     | 22,000                         |
| Closure plate compression                                       | 6570                                                       | 14,880                         | 7460                     | 29,760                         |
| Closure plate shear                                             | 6840                                                       | 11,000                         | 8450                     | 22,000                         |
| Closure plate weld shear                                        | 9120                                                       | 11,000                         | 11,300                   | 22,000                         |
| Corner tube local compressive - stress check for local buckling | --                                                         | --                             | 6900                     | 17,224                         |



HNP-2-FSAR-3

**TABLE 3.9-27 (SHEET 3 OF 3)**

B. Holtec

| <u>Criteria</u>                                                                                                                                                                                                   | <u>Loading</u>                                                                                              | <u>Location</u>         | <u>Allowable Stress (psi)</u> | <u>Calculated Stress (psi)</u> |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------|-------------------------|-------------------------------|--------------------------------|
| Spent-fuel storage racks:                                                                                                                                                                                         |                                                                                                             |                         |                               |                                |
| Stresses due to normal, upset, emergency, or faulted loading shall not cause racks to fail so as to result in a critical fuel array.                                                                              | Fully loaded<br>Half loaded (diagonally)<br>Half loaded (along long axis)<br>Half loaded (along short axis) |                         |                               |                                |
| Allowable stresses:                                                                                                                                                                                               |                                                                                                             |                         |                               |                                |
| Stress limits are derived from ASME Code, Section III, Appendix F, faulted values. Parameters and terminology are in accordance with the ASME Code. Calculated values were derived by nonlinear dynamic analysis. | Normal and Upset Conditions (Level A or Level B)<br>Level D Service Limits                                  | At column-to-base welds | 38,340                        | 12,450                         |

Comparison of Bounding Calculated Loads/Allowables at Impact Locations and at Welds

| <u>Location/Type</u>                 | <u>OBE Condition</u>     |                     | <u>DBE Condition</u>     |                       |
|--------------------------------------|--------------------------|---------------------|--------------------------|-----------------------|
|                                      | <u>Calculated Stress</u> | <u>Allowable</u>    | <u>Calculated Stress</u> | <u>Allowable</u>      |
| Fuel assembly/cell wall impact (lbf) | 210                      | 8272 <sup>(b)</sup> | 411                      | 8272 <sup>(b)</sup>   |
| Rack/baseplate weld (psi)            | 3967                     | 21,300              | 6934                     | 38,340                |
| Baseplate/pedestal weld (psi)        | 1492                     | 21,300              | 12,450                   | 38,340                |
| Cell/cell welds (psi)                |                          |                     | 2511 <sup>(c)</sup>      | 10,000 <sup>(d)</sup> |

- a. Allowable stresses are referenced in ASME Code, Section III, Subsection NF.
- b. Based on the limit load for a cell.
- c. Cell-to-cell weld stresses, including consideration of shear.
- d. Conservatively based on OBE allowable stresses.

TABLE 3.9-28

## RECIRCULATION PIPE AND PUMP RESTRAINTS

| <u>Component</u>    | <u>Loading</u>                 | <u>Locations</u>                       | <u>Design Limits</u>                                       | <u>Calculated Limits</u>           |
|---------------------|--------------------------------|----------------------------------------|------------------------------------------------------------|------------------------------------|
| Restraint frame     | Reaction force from pipe break | Multiple on recirculation piping       | 50% of uniform ultimate strain                             | < 50% of all restraints            |
| Stainless-steel bar | Reaction force from pipe break | Multiple on recirculation piping       | 50% of uniform ultimate strain                             | < 50% of all restraints            |
| Carbon-steel cable  | Reaction force from pipe break | Multiple on recirculation piping       | 90% of guaranteed minimum breaking strength                | < 90% of all cables                |
| Pump restraint      | Reaction force from pipe break | One on each pump                       | Primary membrane stress<br>$\sigma_T \leq 1.0 (\sigma_y)$  | $\sigma_T < 1.0 (\sigma_y)$        |
| Attachment welds    | Reaction force from pipe break | At piping and pump restraint locations | Weld shear stress<br>$\sigma_{SH} \leq 1.5 (\sigma_{AWS})$ | $\sigma_{SH} < 1.5 (\sigma_{AWS})$ |

NOTES:

$\sigma_y$  = Minimum yield strength by testing or from American Society of Testing Materials (ASTM) specifications.  
Uniform ultimate strain determined by testing or from ASTM specifications.

$\sigma_{AWS}$  = Allowable weld stress from American Welding Society Welding Code or AISC structural code.

HNP-2-FSAR-3

TABLE 3.9-29 (SHEET 1 OF 2)

DESIGN CRITERIA FOR ASME CLASS 2 AND 3 COMPONENTS<sup>(5)</sup>

| <u>Loading Condition</u> <sup>(1)</sup>                                                                                           | <u>Piping</u>                                               | <u>Valves</u>                                           | <u>Pumps</u>                                                                                                   | <u>Vessels</u>                                                                                                                 | <u>Mechanical Snubbers</u> | <u>Expansion Bellows</u>                                                                    |
|-----------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|---------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------|----------------------------|---------------------------------------------------------------------------------------------|
| Design                                                                                                                            |                                                             |                                                         |                                                                                                                |                                                                                                                                |                            |                                                                                             |
| Design pressure and temperature plus (expansion for bellows)                                                                      | See paragraph 3.9.2.1 (typical for all loading conditions). | ASME Section III, ANSI B16.5                            | ASME Section III, ASME Section VIII. Performance testing in accordance with the Hydraulic Institute procedures | ASME Section III; ASME Section VII, Division I                                                                                 | See Note 7, typical.       | ASME Section III                                                                            |
| Normal                                                                                                                            |                                                             |                                                         |                                                                                                                |                                                                                                                                |                            |                                                                                             |
| Operating pressure plus deadweight plus stem thrust for valves plus (nozzle loads for pumps and vessels)                          |                                                             | ASME Section III, ANSI B16.5                            | ASME Section III, ASME Section VIII Performance testing in accordance with the Hydraulic Institute procedures  | ASME Section III<br>ASME Section VIII                                                                                          | -                          | NA <sup>(4)</sup>                                                                           |
| Upset                                                                                                                             |                                                             |                                                         |                                                                                                                |                                                                                                                                |                            |                                                                                             |
| Operating pressure plus deadweight plus OBE plus (nozzle loads for pumps and vessels)                                             | -                                                           | NA <sup>(4)</sup>                                       | ASME Section III, ASME Section VIII stress allowable $S_n$ and $1.5 S_m$                                       | ASME Section III<br>ASME Section VIII, Division I tension $0.6 S_y$<br>shear $0.45 S_y$<br>bending $0.66 S_y$<br>(See Note 2.) | -                          | NA <sup>(4)</sup>                                                                           |
| Emergency                                                                                                                         |                                                             |                                                         |                                                                                                                |                                                                                                                                |                            |                                                                                             |
| Operating pressure plus deadweight                                                                                                | -                                                           | NA <sup>(4)</sup>                                       | NA                                                                                                             | NA                                                                                                                             | -                          | NA <sup>(4)</sup>                                                                           |
| Faulted                                                                                                                           |                                                             |                                                         |                                                                                                                |                                                                                                                                |                            |                                                                                             |
| Operating pressure plus deadweight plus DBE plus (stem thrust for valves) plus (nozzle loads for pumps and vessels) (See Note 8.) | -                                                           | Structure analysis $< S_y$ testing (See Notes 3 and 6.) | ASME Section III, stress $< 0.9 S_y$ testing (See Note 2.)                                                     | ASME Section III, ASME, Section VIII, Division 1 stress $< 0.9 S_y$ (See Note 2.)                                              | -                          | IEEE 344, 1971 stress $< 0.9 S_y$ or by fatigue life in accordance with ASME Paper 61-WA-18 |

## HNP-2-FSAR-3

**TABLE 3.9-29 (SHEET 2 OF 2)**

NOTES:

1. Loading conditions of design, normal, upset, emergency, and faulted are for reference.
2. Seismic loads for pumps and vessels are included only for those designated as Seismic Category I. See appendix A, Compliance with Regulatory Guide 1.48, for details on the RHR and PSW active pumps.
3. Valves designated as Seismic Category I with extended structures are modeled into the piping system analyses as eccentric masses; piping stresses are held within the ASME Code, Section III allowables, as specified in paragraph 3.9.2.1. In addition, a structural analysis is performed by the valve manufacturer in which a static 3-g loading is applied to the operator center of gravity. The 3-g loading is the maximum response that the valve would experience as installed in the piping system under a DBE. The valve assembly is shown not to amplify this response by maintaining natural frequencies in the rigid range. Operability is assured by a combination of analysis and testing. Structural analyses show that deflections are small so as not to cause binding, and motor-operator testing verifies that the motor cycles freely during a minimum acceleration of 3 g.
4. NA means that the particular loading condition was not analyzed for that component.
5. Piping reactions on Class 2 and 3 valves need not be evaluated, because wall thicknesses are at least 10% thicker than the pipe to which they are attached when designed in accordance with ANSI B16.5.
6. Yield stress is used as an allowable for evaluation of the most severe loading condition on the basis of eliminating permanent deformation, thus maintaining dimensional stability. Where active components must remain functional during the event, operability is demonstrated by testing or analysis, or a combination of both. Analyses verify that only elastic deformation occurs so that deflections are small; thus, operability is not impaired.
7. Mechanical snubbers purchased in accordance with ASME Code Section III, (NF) are designed by analysis and generically tested to confirm functional capability. DBE loads are directly combined with dynamic loads due to fast valve opening or closing, and the resulting load is designated as the normal load for the snubber.
8. For the Plant-Unique Analysis, the effects of simultaneous loads due to the DBE and the torus displacement LOCA loads were evaluated for external piping connected to the torus.

TABLE 3.9-30 (SHEET 1 OF 2)

RHRSW 14-in. PUMPS<sup>(a)</sup>

| <u>Location</u>      | <u>Load Conditions</u>     | <u>Criteria</u>                    | <u>Allowable Stress (psi)</u> | <u>Calculated Stress (psi)</u>                     |
|----------------------|----------------------------|------------------------------------|-------------------------------|----------------------------------------------------|
| Discharge head shell | Weight + OBE + nozzle load | Combined stress ( $\sigma < S_H$ ) | 12,600                        | Not calculated because DBE stress < OBE allowable. |
|                      | Weight + DBE + nozzle load | $\sigma < 0.9 S_Y$                 | 29,700                        | 2668                                               |
| Discharge head base  | Weight + OBE + nozzle load | $\sigma < S_H$                     | 13,700                        | 5269                                               |
|                      | Weight + DBE + nozzle load | $\sigma < 0.9 S_Y$                 | 27,000                        | 7281                                               |
| Sub base             | Weight + OBE + nozzle load | $\sigma < S_H$                     | 12,600                        | 4465                                               |
|                      | Weight + DBE + nozzle load | $\sigma < 0.9 S_Y$                 | 29,700                        | 6459                                               |
| Column pipe          | P + weight + OBE           | $\sigma < S_H$                     | 20,000                        | 4453                                               |
|                      | P + weight + DBE           | $\sigma < 0.9 S_Y$                 | 31,500                        | 5457                                               |
| Pipe hub             | P + weight + OBE           | $\sigma < 1.5 S_H$                 | 30,000                        | 14,723                                             |
|                      | P + weight + DBE           | $\sigma < 0.9 S_Y$                 | 31,500                        | 16,172                                             |
| Column flange        | P + weight + OBE           | $\sigma < 1.5 S_H$                 | 20,550                        | 9286                                               |
|                      | P + weight + DBE           | $\sigma < 0.9 S_Y$                 | 27,000                        | 12,287                                             |
| Lineshaft            | Torque + thrust + DBE      | $\sigma < 0.3 S_Y$ per ANSI B58.1  | 12,000                        | Not calculated because DBE stress < OBE allowable. |
|                      | Torque + thrust + DBE      | $\sigma < 0.9 S_Y$                 | 36,000                        | 10,414                                             |

TABLE 3.9-30 (SHEET 2 OF 2)

| <u>Location</u>  | <u>Load Conditions</u> | <u>Criteria</u>                   | <u>Allowable Stress (psi)</u>           | <u>Calculated Stress (psi)</u>                     |
|------------------|------------------------|-----------------------------------|-----------------------------------------|----------------------------------------------------|
| <u>Bolts</u>     |                        |                                   |                                         |                                                    |
| Motor to head    | OBE                    | $\sigma < S_H$                    | 35,500                                  | Not calculated because DBE stress < OBE allowable. |
|                  | DBE                    | $\sigma < 0.9 S_Y$                | 94,500                                  | 4353                                               |
| Head-to-sub base | OBE + nozzle load      | $\sigma < S_H$                    | 35,000                                  | 18,072                                             |
|                  | DBE + nozzle load      | $\sigma < 0.9 S_Y$                | 94,500                                  | 26,167                                             |
| Column flange    | OBE                    | $\sigma < 2 S_H$<br>per NB 3232.1 | 20,000                                  | 9863                                               |
|                  | DBE                    | $\sigma < 0.9 S_Y$                | 27,000                                  | 12,790                                             |
| Anchor bolts     | OBE + nozzle load      |                                   | Material not specified; stress is below | 5959                                               |
|                  | DBE + nozzle load      |                                   | allowables for common bolt materials.   | 8640                                               |

a. All allowables are in accordance with ASME B&PV Code, Section III, 1971 Edition, except as noted.

**TABLE 3.9-31 (SHEET 1 OF 2)**  
**STANDBY SERVICE WATER PUMP<sup>(a)</sup>**

| <u>Location</u>      | <u>Load Conditions</u> | <u>Criteria</u>                       | <u>Allowable Stress (psi)</u> | <u>Calculated Stress (psi)</u>                     |
|----------------------|------------------------|---------------------------------------|-------------------------------|----------------------------------------------------|
| Discharge head shell | P + weight + OBE       | Combined stress<br>( $\sigma < S_H$ ) | 15,000                        | Not calculated because DBE stress < OBE allowable. |
|                      | P + weight + DBE       | $\sigma < 0.9 S_Y$                    | 31,500                        | 1354                                               |
| Discharge head base  | P + weight + OBE       | $\sigma < S_H$                        | 13,700                        | Not calculated because DBE stress < OBE allowable. |
|                      | P + weight + DBE       | $\sigma < 0.9 S_Y$                    | 27,000                        | 9818                                               |
| Sub base             | OBE                    | $\sigma < S_H$                        | 12,600                        | Not calculated because DBE stress < OBE allowable. |
|                      | DBE                    | $\sigma < 0.9 S_Y$                    | 29,700                        | 7358                                               |
| Column pipe          | Weight + OBE           | $\sigma < S_H$                        | 15,000                        | Not calculated because DBE stress < OBE allowable. |
|                      | Weight + DBE           | $\sigma < 0.9 S_Y$                    | 31,500                        | 12,760                                             |
| Column flange        | P + weight + OBE       | $\sigma < 1.5 S_H$                    | 20,550                        | 10,562                                             |
|                      | P + weight + DBE       | $\sigma < 0.9 S_Y$                    | 27,000                        | 17,541                                             |
| Flange hub           | P + weight + OBE       | $\sigma < 1.5 S_H$                    | 22,500                        | 8597                                               |
|                      | P + weight + DBE       | $\sigma < 0.9 S_Y$                    | 31,500                        | 11,753                                             |

HNP-2-FSAR-3

**TABLE 3.9-31 (SHEET 2 OF 2)**

| <u>Location</u>  | <u>Load Conditions</u> | <u>Criteria</u>                      | <u>Allowable Stress (psi)</u>                            | <u>Calculated Stress (psi)</u>                     |
|------------------|------------------------|--------------------------------------|----------------------------------------------------------|----------------------------------------------------|
| Lineshaft        | Thrust + torque + OBE  | $\sigma < 0.3 S_Y$<br>per ANSI B58.1 | 12,000                                                   | Not calculated because DBE stress < OBE allowable. |
|                  | Thrust + torque + DBE  | $\sigma < 0.9 S_Y$                   | 36,000                                                   | 8206                                               |
| Top bowl         | P + weight + OBE       | $\sigma < S_H$                       | 13,700                                                   | Not calculated because DBE stress < OBE allowable. |
|                  | P + weight + DBE       | $\sigma < 0.9 S_Y$                   | 27,000                                                   | 6085                                               |
| <u>Bolts</u>     |                        |                                      |                                                          |                                                    |
| Motor to head    | OBE                    | $\sigma < S_H$                       | 35,000                                                   | Not calculated because DBE stress < OBE allowable. |
|                  | DBE                    | $\sigma < 0.9 S_Y$                   | 94,500                                                   | 1253                                               |
| Head to sub base | OBE                    | $\sigma < S_H$                       | 35,000                                                   | Not calculated because DBE stress < OBE allowable. |
|                  | DBE                    | $\sigma < 0.9 S_Y$                   | 94,500                                                   | 15,419                                             |
| Column flange    | OBE                    | $\sigma < S_H$                       | 35,000                                                   | 21,272                                             |
|                  | DBE                    | $\sigma < 0.9 S_Y$                   | 94,500                                                   | 31,648                                             |
| Anchor bolts     | OBE                    | $\sigma < S_H$                       | Material not specified;                                  | 6596                                               |
|                  | DBE                    | $\sigma < 0.9 S_Y$                   | stresses are below allowables for common bolt materials. | 11,209                                             |

a. All allowables are in accordance with ASME B&PV Code, Section III, 1971 Edition, except as noted.



HNP-2-FSAR-3

TABLE 3.9-32 (SHEET 1 OF 2)

PSW PUMPS<sup>(a)</sup>

| <u>Item</u>          | <u>Loading Combination</u> | <u>Criteria</u>                                   | <u>Allowable Stress (psi)</u> | <u>Calculated Stress (psi)</u>                     |
|----------------------|----------------------------|---------------------------------------------------|-------------------------------|----------------------------------------------------|
| Discharge head shell | Weight + OBE               | Combined stress<br>$\sigma < S_H$                 | 12,000                        | Not calculated since DBE stress < OBE allowable.   |
|                      | Weight + DBE               | $\sigma < 0.9 S_y$                                | 29,700                        | 580                                                |
| Discharge head base  | Weight + OBE               | $\sigma < S_H$                                    | 13,700                        | 10,986                                             |
|                      | Weight + DBE               | $\sigma < 0.9 S_y$                                | 27,000                        | 16,637                                             |
| Sub base             | Weight + OBE               | $\sigma < S_H$                                    | 12,600                        | 11,823                                             |
|                      | Weight + DBE               | $\sigma < 0.9 S_y$                                | 29,700                        | 18,164                                             |
| Column pipe          | P + weight + OBE           | $\sigma < S_H$                                    | 15,000                        | 4562                                               |
|                      | P + weight + DBE           | $\sigma < 0.9 S_y$                                | 31,500                        | 6549                                               |
| Pipe-hub stress      | P + weight + OBE           | $\sigma < 1.5 S_H$                                | 22,500                        | 10,792                                             |
|                      | P + weight + DBE           | $\sigma < 0.9 S_y$                                | 31,500                        | 12,997                                             |
| Column flange        | P + weight + OBE           | $\sigma < 1.5 S_H$                                | 20,550                        | 16,592                                             |
|                      | P + weight + DBE           | $\sigma < 0.9 S_y$                                | 27,000                        | 23,959                                             |
| Lineshaft            | Thrust + torque + OBE      | Combined shear stress < 0.30 $S_y$ per ANSI B58.1 | 12,000                        | Not calculated because DBE stress < OBE allowable. |
|                      | Thrust + torque + DBE      | $\sigma < 0.9 S_y$                                | 36,000                        | 11,069                                             |
| <u>Bolts</u>         |                            |                                                   |                               |                                                    |
| Motor-to-head        | OBE                        | $\sigma < S_H$                                    | 35,000                        | Not calculated because DBE stress < OBE allowable. |
|                      | DBE                        | $\sigma < 0.9 S_y$                                | 94,500                        | 3477                                               |

HNP-2-FSAR-3

**TABLE 3.9-32 (SHEET 2 OF 2)**

| <u>Item</u>      | <u>Loading Combination</u> | <u>Criteria</u>                         | <u>Allowable Stress (psi)</u>                                                    | <u>Calculated Stress (psi)</u> |
|------------------|----------------------------|-----------------------------------------|----------------------------------------------------------------------------------|--------------------------------|
| Head-to-sub base | OBE                        | $\sigma < S_H$                          | 35,000                                                                           | 17,155                         |
|                  | DBE                        | $\sigma < 0.9 S_y$                      | 94,500                                                                           | 26,255                         |
| Column flange    | OBE                        | $\sigma_{ave} < 2 S_H$<br>per NB-3232.1 | 20,000                                                                           | 15,577                         |
|                  | DBE                        | $\sigma < 0.9 S_y$                      | 27,000                                                                           | 22,398                         |
| Anchor bolts     | OBE                        | $\sigma < S_H$                          | Material not specified; stresses are below allowables for common bolt materials. | 8147                           |
|                  | DBE                        | $\sigma < 0.9 S_y$                      |                                                                                  | 17,812                         |

a. All allowables are in accordance with ASME B&PV Code, Section III, 1971 Edition, except as noted.

HNP-2-FSAR-3

TABLE 3.9-33 (SHEET 1 OF 16)

**ACTIVE VALVES IN RCPB AND OTHER SEISMIC CATEGORY I SYSTEMS  
(BECHTEL SUPPLIED)**

| <u>Valve No.</u>                                                                                                                                | <u>Service Description</u>                             | <u>Valve Type</u> | <u>Size Line (in.)</u> | <u>Actuator Type</u> | <u>Environmental Design Conditions</u> <sup>(a)</sup> |
|-------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------|-------------------|------------------------|----------------------|-------------------------------------------------------|
| RCPB (See drawing nos. H-26000, H-26001, H-26003, H-26014, H-26015, H-26018, H-26020, H-26021, H-26023, H-26024, H-26036, H-26037, and H-26189) |                                                        |                   |                        |                      |                                                       |
| 2B21-F010A,B                                                                                                                                    | Feedwater line inside containment                      | Check             | 18                     | None                 | A, F                                                  |
| 2B21-F016                                                                                                                                       | Steam line drain isolation valve inside containment    | Gate              | 3                      | Motor                | A, F <sup>(e)</sup>                                   |
| 2B21-F019                                                                                                                                       | Steam line drain isolation valve outside containment   | Gate              | 3                      | Motor                | A, F <sup>(e)</sup>                                   |
| 2B21-F024A-D                                                                                                                                    | Inboard MSIV air supply check valve                    | Check             | 1 1/2                  | None                 | C                                                     |
| 2B21-F029A-D                                                                                                                                    | Outboard MSIV air supply check valve                   | Check             | 1 1/2                  | None                 | C                                                     |
| 2B21-F036A-H, K,L,M                                                                                                                             | Main steam safety/relief air inlet check valve         | Check             | 1                      | None                 | C                                                     |
| 2B21-F037A-H, K,L,M                                                                                                                             | Main steam safety/relief discharge line vacuum breaker | Check             | 6                      | None                 | C                                                     |
| 2B21-F041                                                                                                                                       | Instrumentation line excess flow check valve           | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B21-F043A,B                                                                                                                                    | Instrumentation line excess flow check valve           | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B21-F045A,B                                                                                                                                    | Instrumentation line excess flow check valve           | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B21-F047A,B                                                                                                                                    | Instrumentation line excess flow check valve           | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B21-F049A,B                                                                                                                                    | Instrumentation line excess flow check valve           | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |

HNP-2-FSAR-3

TABLE 3.9-33 (SHEET 2 OF 16)

| <u>Valve No.</u>             | <u>Service Description</u>                         | <u>Valve Type</u> | <u>Size Line (in.)</u> | <u>Actuator Type</u> | <u>Environmental Design Conditions</u> <sup>(a)</sup> |
|------------------------------|----------------------------------------------------|-------------------|------------------------|----------------------|-------------------------------------------------------|
| RCPB (cont)                  |                                                    |                   |                        |                      |                                                       |
| 2B21-F051A-D                 | Instrumentation line excess flow check valve       | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B21-F053A-D                 | Instrumentation line excess flow check valve       | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B21-F055                    | Instrumentation line excess flow check valve       | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B21-F057                    | Instrumentation line excess flow check valve       | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B21-F059A-H,<br>L,M,N,P,R-U | Instrumentation line excess flow check valve       | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B21-F061                    | Instrumentation line excess flow check valve       | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B21-F070A-D                 | Instrumentation line excess flow check valve       | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B21-F071A-D                 | Instrumentation line excess flow check valve       | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B21-F072A-D                 | Instrumentation line excess flow check valve       | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B21-F073A-D                 | Instrumentation line excess flow check valve       | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B21-F076A,B                 | Feedwater line isolation valve outside containment | Check             | 18                     | Air                  | B, G <sup>(e)</sup>                                   |
| 2B21-F077A,B                 | Feedwater line isolation valve outside containment | Check             | 18                     | Air                  | B, G <sup>(e)</sup>                                   |
| 2B31-F003A,B                 | Instrumentation line excess flow check valve       | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |

HNP-2-FSAR-3

TABLE 3.9-33 (SHEET 3 OF 16)

| <u>Valve No.</u> | <u>Service Description</u>                              | <u>Valve Type</u> | <u>Size Line (in.)</u> | <u>Actuator Type</u> | <u>Environmental Design Conditions</u> <sup>(a)</sup> |
|------------------|---------------------------------------------------------|-------------------|------------------------|----------------------|-------------------------------------------------------|
| RCPB (cont)      |                                                         |                   |                        |                      |                                                       |
| 2B31-F004A,B     | Instrumentation line excess flow check valve            | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B31-F009A-D     | Instrumentation line excess flow check valve            | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B31-F010A-D     | Instrumentation line excess flow check valve            | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B31-F011A-D     | Instrumentation line excess flow check valve            | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B31-F012A-D     | Instrumentation line excess flow check valve            | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B31-F013A,B     | Recirculation pump seal supply line inside containment  | Check             | 3/4                    | None                 | C                                                     |
| 2B31-F017A,B     | Recirculation pump seal supply line outside containment | Check             | 3/4                    | None                 | C                                                     |
| 2B31-F019        | Recirculation sample line isolation inside containment  | Globe             | 1                      | Air                  | F <sup>(e)</sup>                                      |
| 2B31-F020        | Recirculation sample line isolation outside containment | Globe             | 1                      | Air                  | F <sup>(e)</sup>                                      |
| 2B31-F040A-D     | Instrumentation line excess flow check valve            | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2B31-F057A,B     | Instrumentation line excess flow check valve            | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2E11-F008        | RHR shutdown suction outside containment                | Gate              | 20                     | Motor                | A, F <sup>(e)</sup>                                   |
| 2E11-F009        | RHR shutdown suction inside containment                 | Gate              | 20                     | Motor                | A, F <sup>(e)</sup>                                   |
| 2E11-F015A,B     | RHR system LPCI line outside containment                | Gate              | 24                     | Motor                | A, F <sup>(e)</sup>                                   |

HNP-2-FSAR-3

**TABLE 3.9-33 (SHEET 4 OF 16)**

| <u>Valve No.</u>                                           | <u>Service Description</u>                               | <u>Valve Type</u> | <u>Size Line (in.)</u> | <u>Actuator Type</u> | <u>Environmental Design Conditions</u> <sup>(a)</sup> |
|------------------------------------------------------------|----------------------------------------------------------|-------------------|------------------------|----------------------|-------------------------------------------------------|
| <u>RCPB (cont)</u>                                         |                                                          |                   |                        |                      |                                                       |
| 2E11-F022                                                  | RHR vessel head spray inside containment <sup>(f)</sup>  |                   |                        |                      |                                                       |
| 2E11-F023                                                  | RHR vessel head spray outside containment <sup>(f)</sup> |                   |                        |                      |                                                       |
| 2E11-F050A,B                                               | RHR system LPCI check valve inside containment           | Check             | 24                     | None                 | A, F                                                  |
| 2E11-F122A,B                                               | Bypass for check valves 2E11-F050A,B                     | Globe             | 1                      | Air                  | B <sup>(b)(e)</sup>                                   |
| 2E21-F005A,B                                               | CS pump discharge outside containment                    | Gate              | 10                     | Motor                | A, F <sup>(e)</sup>                                   |
| 2E21-F006A,B                                               | CS pump discharge inside containment                     | Check             | 10                     | None                 | A, F                                                  |
| 2E21-F018A-C                                               | Instrumentation line excess flow check valve             | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2E21-F037A,B                                               | Bypass for check valves 2E21-F006A,B                     | Globe             | 1                      | Air                  | B <sup>(b)(e)</sup>                                   |
| 2E41-F002                                                  | HPCI steam line isolation inside containment             | Gate              | 10                     | Motor                | A, F <sup>(e)</sup>                                   |
| 2E41-F003                                                  | HPCI steam line isolation outside containment            | Gate              | 10                     | Motor                | A, F <sup>(e)</sup>                                   |
| <u>RCIC System (See drawing nos. H-26023 and H-26024.)</u> |                                                          |                   |                        |                      |                                                       |
| 2E41-F024A-D                                               | Instrumentation line excess flow check valve             | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2E51-F007                                                  | RCIC steam line isolation inside containment             | Gate              | 4                      | Motor                | A, F <sup>(e)</sup>                                   |
| 2E51-F008                                                  | RCIC steam line isolation outside containment            | Gate              | 4                      | Motor                | A, F <sup>(e)</sup>                                   |
| 2E51-F044A-D                                               | Instrumentation line excess flow check valve             | Excess flow check | 1                      | Self/solenoid reset  | E                                                     |
| 2E51-F001                                                  | Exhaust line isolation valve                             | Stop check        | 10                     | None                 | B, G                                                  |
| 2E51-F002                                                  | Exhaust drain isolation valve                            | Stop check        | 2                      | None                 | C                                                     |

HNP-2-FSAR-3

TABLE 3.9-33 (SHEET 5 OF 16)

| <u>Valve No.</u>   | <u>Service Description</u>              | <u>Valve Type</u> | <u>Size Line (in.)</u> | <u>Actuator Type</u> | <u>Environmental Design Conditions</u> <sup>(a)</sup> |
|--------------------|-----------------------------------------|-------------------|------------------------|----------------------|-------------------------------------------------------|
| <u>RCIC (cont)</u> |                                         |                   |                        |                      |                                                       |
| 2E51-F003          | Suction from suppression pool isolation | Butterfly         | 6                      | Air                  | C <sup>(c)(e)</sup>                                   |
| 2E51-F004          | Condensate pump discharge drain line    | Globe             | 1                      | Air                  | B <sup>(b)</sup>                                      |
| 2E51-F005          | Condensate pump discharge drain line    | Globe             | 1                      | Air                  | B <sup>(b)</sup>                                      |
| 2E51-F010          | Suction from CST isolation              | Gate              | 6                      | Motor                | B, G                                                  |
| 2E51-F011          | Suction from CST                        | Check             | 6                      | None                 | B, G                                                  |
| 2E51-F012          | RCIC pump discharge isolation           | Gate              | 4                      | Motor                | B, G                                                  |
| 2E51-F013          | RCIC pump discharge isolation           | Gate              | 4                      | Motor                | B, G <sup>(e)</sup>                                   |
| 2E51-F014          | RCIC pump discharge line                | Check             | 4                      | None                 | B, G                                                  |
| 2E51-F015          | Cooling water pressure regulator        | Pressure check    | 2                      | Process fluid        | B <sup>(b)</sup>                                      |
| 2E51-F017          | Pump suction relief valve               | Relief            | 1 1/2                  | Self                 | C                                                     |
| 2E51-F018          | Cooling water relief valve              | Relief            | 1 1/2                  | Self                 | C                                                     |
| 2E51-F019          | Minimum flow isolation                  | Globe             | 2                      | Motor                | C                                                     |
| 2E51-F021          | Minimum flow line                       | Check             | 2                      | None                 | C                                                     |
| 2E51-F025          | Drain line to main condenser            | Globe             | 1                      | Air                  | B <sup>(b)</sup>                                      |
| 2E51-F026          | Drain line to main condenser            | Globe             | 1                      | Air                  | B <sup>(b)</sup>                                      |
| 2E51-F028          | Vacuum pump discharge line              | Check             | 2                      | None                 | C                                                     |
| 2E51-F029          | Suction from suppression pool isolation | Gate              | 6                      | Motor                | B, G                                                  |
| 2E51-F030          | Suction from suppression pool           | Check             | 6                      | None                 | B, G                                                  |
| 2E51-F031          | Suction from suppression pool isolation | Gate              | 6                      | Motor                | B, G <sup>(e)</sup>                                   |
| 2E51-F040          | Turbine exhaust line                    | Check             | 10                     | None                 | B, G                                                  |

HNP-2-FSAR-3

TABLE 3.9-33 (SHEET 6 OF 16)

| <u>Valve No.</u>                                          | <u>Service Description</u>                 | <u>Valve Type</u> | <u>Size Line (in.)</u> | <u>Actuator Type</u> | <u>Environmental Design Conditions</u> <sup>(a)</sup> |
|-----------------------------------------------------------|--------------------------------------------|-------------------|------------------------|----------------------|-------------------------------------------------------|
| <u>RCIC (cont)</u>                                        |                                            |                   |                        |                      |                                                       |
| 2E51-F045                                                 | Turbine inlet isolation                    | Globe             | 4                      | Motor                | B, G                                                  |
| 2E51-F046                                                 | Cooling water isolation                    | Globe             | 2                      | Motor                | C                                                     |
| 2E51-F047                                                 | Condensate pump discharge                  | Check             | 2                      | None                 | C                                                     |
| 2E51-F102                                                 | Exhaust line vacuum breaker line           | Check             | 1 1/2                  | None                 | C                                                     |
| 2E51-F103                                                 | Exhaust line vacuum breaker line           | Check             | 1 1/2                  | None                 | C                                                     |
| 2E51-F104                                                 | Exhaust line vacuum breaker line isolation | Gate              | 1 1/2                  | Motor                | C <sup>(e)</sup>                                      |
| 2E51-F105                                                 | Exhaust line vacuum breaker line isolation | Gate              | 1 1/2                  | Motor                | C <sup>(e)</sup>                                      |
| <u>RWC System</u>                                         |                                            |                   |                        |                      |                                                       |
| 2G31-F001                                                 | RWC line isolation inside containment      | Gate              | 6                      | Motor                | A, F <sup>(e)</sup>                                   |
| 2G31-F004                                                 | RWC line isolation outside containment     | Gate              | 6                      | Motor                | A, F <sup>(e)</sup>                                   |
| <u>RHR System</u> (See drawing nos. H-26014 and H-26015.) |                                            |                   |                        |                      |                                                       |
| 2E11-F003A,B                                              | Heat exchanger discharge                   | Gate              | 16                     | Motor                | B, G <sup>(e)</sup>                                   |
| 2E11-F004A,-D                                             | Pump suction                               | Gate              | 24                     | Motor                | B, G <sup>(e)</sup>                                   |
| 2E11-F006A-D                                              | Pump suction                               | Gate              | 20                     | Motor                | B, G <sup>(e)</sup>                                   |
| 2E11-F007A,B                                              | Minimum flow line                          | Gate              | 4                      | Motor                | B, G <sup>(e)</sup>                                   |
| 2E11-F010                                                 | Crosstie line                              | Gate              | 20                     | Motor                | B, G                                                  |
| 2E11-F011A,B                                              | Minimum flow line                          | Gate              | 4                      | Motor                | B, G <sup>(e)</sup>                                   |
| 2E11-F016A,B                                              | Containment spray                          | Globe             | 16                     | Motor                | B, G <sup>(e)</sup>                                   |
| 2E11-F017A,B                                              | LPCI line                                  | Angle             | 24                     | Motor                | B, G <sup>(e)</sup>                                   |
| 2E11-F021A,B                                              | Containment spray                          | Gate              | 16                     | Motor                | B, G <sup>(e)</sup>                                   |



HNP-2-FSAR-3

TABLE 3.9-33 (SHEET 7 OF 16)

| <u>Valve No.</u>                              | <u>Service Description</u>               | <u>Valve Type</u> | <u>Size Line (in.)</u> | <u>Actuator Type</u> | <u>Environmental Design Conditions</u> <sup>(a)</sup> |
|-----------------------------------------------|------------------------------------------|-------------------|------------------------|----------------------|-------------------------------------------------------|
| <u>RHR System</u> (cont)                      |                                          |                   |                        |                      |                                                       |
| 2E11-F024A,B                                  | Test line                                | Globe             | 16                     | Motor                | B, G <sup>(e)</sup>                                   |
| 2E11-F026A,B                                  | Heat exchanger to RCIC                   | Gate              | 4                      | Motor                | B, G <sup>(e)(g)</sup>                                |
| 2E11-F027A,B                                  | Torus spray                              | Globe             | 16                     | Motor                | B, G <sup>(e)</sup>                                   |
| 2E11-F028A,B                                  | Torus spray                              | Gate              | 16                     | Motor                | B, G <sup>(e)</sup>                                   |
| 2E11-F040                                     | Discharge to radwaste system             | Globe             | 4                      | Motor                | B, G <sup>(e)</sup>                                   |
| 2E11-F041A-D                                  | Pressure sensing line isolation valve    | Globe             | 1                      | Air                  | B <sup>(b)</sup>                                      |
| 2E11-F047A,B                                  | Discharge to heat exchanger              | Gate              | 16                     | Motor                | B, G <sup>(e)</sup>                                   |
| 2E11-F048A,B                                  | Heat exchanger bypass                    | Globe             | 24                     | Motor                | B, G <sup>(e)</sup>                                   |
| 2E11-F049                                     | Discharge to radwaste                    | Gate              | 4                      | Motor                | B, G <sup>(e)</sup>                                   |
| 2E11-F053A,B                                  | Heat exchanger to RCIC                   | Globe             | 3                      | Air                  | B <sup>(b)(e)</sup>                                   |
| 2E11-F065A-D                                  | Pump suction                             | Butterfly         | 24                     | Air                  | B, G <sup>(e)</sup>                                   |
| 2E11-F073A,B                                  | Service water crosstie                   | Gate              | 10                     | Motor                | B, G <sup>(e)</sup>                                   |
| 2E11-F074A,B                                  | Service water in heat exchanger A to DRW | Globe             | 1                      | Solenoid             | B <sup>(b)(e)</sup>                                   |
| 2E11-F075A,B                                  | Service water crosstie                   | Gate              | 10                     | Motor                | B, G <sup>(e)</sup>                                   |
| 2E11-F079A,B                                  | Process sample line                      | Globe             | 3/4                    | Solenoid             | B <sup>(b)</sup>                                      |
| 2E11-F080A,B                                  | Process sample line                      | Globe             | 3/4                    | Solenoid             | B <sup>(b)</sup>                                      |
| <u>SBGT System</u> (See drawing no. H-26078.) |                                          |                   |                        |                      |                                                       |
| 2T46-F001A,B                                  | SGTS inlet isolation valve               | Butterfly         | 18                     | Air                  | C <sup>(d)(e)</sup>                                   |
| 2T46-F002A,B                                  | SGTS exhaust isolation valve             | Butterfly         | 18                     | Air                  | C <sup>(d)</sup>                                      |
| 2T46-F003A,B                                  | SGTS inlet isolation valve               | Butterfly         | 18                     | Air                  | C <sup>(d)</sup>                                      |

HNP-2-FSAR-3

**TABLE 3.9-33 (SHEET 8 OF 16)**

| <u>Valve No.</u>                                                         | <u>Service Description</u>                     | <u>Valve Type</u> | <u>Size Line (in.)</u> | <u>Actuator Type</u> | <u>Environmental Design Conditions</u> <sup>(a)</sup> |
|--------------------------------------------------------------------------|------------------------------------------------|-------------------|------------------------|----------------------|-------------------------------------------------------|
| <u>Primary Containment Purge System</u> (Reference drawing no. H-26084.) |                                                |                   |                        |                      |                                                       |
| 2T48-F307                                                                | Drywell purge inlet                            | Butterfly         | 18                     | Air                  | C <sup>(d)(e)</sup>                                   |
| 2T48-F308                                                                | Drywell purge inlet                            | Butterfly         | 18                     | Air                  | C <sup>(d)(e)</sup>                                   |
| 2T48-F309                                                                | Torus purge inlet                              | Butterfly         | 18                     | Air                  | C <sup>(d)(e)</sup>                                   |
| 2T48-F310                                                                | Torus isolation valve before vacuum breaker    | Butterfly         | 20                     | Air                  | C <sup>(d)(e)</sup>                                   |
| 2T48-F311                                                                | Torus isolation valve before vacuum breaker    | Butterfly         | 20                     | Air                  | C <sup>(d)(e)</sup>                                   |
| 2T48-F318                                                                | Torus purge valve                              | Butterfly         | 18                     | Air                  | C <sup>(d)(e)</sup>                                   |
| 2T48-F319                                                                | Drywell purge valve                            | Butterfly         | 18                     | Air                  | C <sup>(d)(e)</sup>                                   |
| 2T48-F320                                                                | Drywell purge valve                            | Butterfly         | 18                     | Air                  | C <sup>(d)(e)</sup>                                   |
| 2T48-F324                                                                | Torus purge inlet                              | Butterfly         | 18                     | Air                  | C <sup>(d)(e)</sup>                                   |
| 2T48-F326                                                                | Torus purge valve                              | Butterfly         | 18                     | Air                  | C <sup>(d)(e)</sup>                                   |
| 2T48-F328A,B                                                             | Torus to secondary containment vacuum breakers | Check             | 20                     | Air                  | D                                                     |
| 2T48-F332A,B                                                             | Torus vent valve                               | Globe             | 2                      | Diaphragm            | B <sup>(b)(e)</sup>                                   |
| 2T48-F333A,B                                                             | Torus vent valve                               | Globe             | 2                      | Diaphragm            | B <sup>(b)(e)</sup>                                   |
| 2T48-F335A,B                                                             | Drywell vent valve                             | Globe             | 2                      | Diaphragm            | B <sup>(b)(e)</sup>                                   |
| 2T48-F336A,B                                                             | Drywell vent valve                             | Globe             | 2                      | Diaphragm            | B <sup>(b)</sup>                                      |
| 2T48-F337A,B                                                             | Torus vent valve                               | Globe             | 2                      | Diaphragm            | B <sup>(b)</sup>                                      |
| 2T48-F338                                                                | Torus bypass                                   | Globe             | 2                      | Diaphragm            | B <sup>(b)(e)</sup>                                   |
| 2T48-F339                                                                | Torus bypass                                   | Globe             | 2                      | Diaphragm            | B <sup>(b)(e)</sup>                                   |
| 2T48-F340                                                                | Drywell bypass                                 | Globe             | 2                      | Diaphragm            | B <sup>(b)(e)</sup>                                   |
| 2T48-F341                                                                | Drywell bypass                                 | Globe             | 2                      | Diaphragm            | B <sup>(b)(e)</sup>                                   |

HNP-2-FSAR-3

TABLE 3.9-33 (SHEET 9 OF 16)

| <u>Valve No.</u>                                  | <u>Service Description</u>              | <u>Valve Type</u> | <u>Size Line (in.)</u> | <u>Actuator Type</u> | <u>Environmental Design Conditions</u> <sup>(a)</sup> |
|---------------------------------------------------|-----------------------------------------|-------------------|------------------------|----------------------|-------------------------------------------------------|
| <u>Primary Containment Purge System (cont)</u>    |                                         |                   |                        |                      |                                                       |
| 2T48-F342A-L                                      | Vacuum breaker solenoid valves          | Globe             | 1/2                    | Solenoid             | B <sup>(b)</sup>                                      |
| 2T48-F361A,B                                      | Instrument sensing line isolation valve | Globe             | 1                      | Air                  | B <sup>(b)</sup>                                      |
| 2T48-F362A,B                                      | Instrument sensing line isolation valve | Globe             | 1                      | Air                  | B <sup>(b)</sup>                                      |
| 2T48-F363A,B                                      | Instrument sensing line isolation valve | Globe             | 1                      | Air                  | B <sup>(b)</sup>                                      |
| 2T48-F364A,B                                      | Instrument sensing line isolation valve | Globe             | 1                      | Air                  | B <sup>(b)</sup>                                      |
| 2T48-F334A,B                                      | Drywell vent valve                      | Globe             | 2                      | Diaphragm            | B <sup>(b)(e)</sup>                                   |
| <u>H<sub>2</sub>O<sub>2</sub> Analyzer System</u> |                                         |                   |                        |                      |                                                       |
| 2P33-F002                                         | Inboard drywell sample A                | Globe             | 1                      | Air                  | B <sup>(b)(e)</sup>                                   |
| 2P33-F003                                         | Inboard drywell sample B                | Globe             | 1                      | Air                  | B <sup>(b)(e)</sup>                                   |
| 2P33-F004                                         | Inboard drywell return A                | Globe             | 1                      | Air                  | B <sup>(b)(e)</sup>                                   |
| 2P33-F005                                         | Inboard drywell return B                | Globe             | 1                      | Air                  | B <sup>(b)(e)</sup>                                   |
| 2P33-F006                                         | Inboard torus sample A                  | Globe             | 1                      | Air                  | B <sup>(b)(e)</sup>                                   |
| 2P33-F007                                         | Inboard torus sample B                  | Globe             | 1                      | Air                  | B <sup>(b)(e)</sup>                                   |
| 2P33-F010                                         | Outboard drywell sample A               | Globe             | 1                      | Air                  | B <sup>(b)(e)</sup>                                   |
| 2P33-F011                                         | Outboard drywell sample B               | Globe             | 1                      | Air                  | B <sup>(b)(e)</sup>                                   |
| 2P33-F012                                         | Outboard drywell return A               | Globe             | 1                      | Air                  | B <sup>(b)(e)</sup>                                   |
| 2P33-F013                                         | Outboard drywell return B               | Globe             | 1                      | Air                  | B <sup>(b)(e)</sup>                                   |
| 2P33-F014                                         | Outboard torus sample A                 | Globe             | 1                      | Air                  | B <sup>(b)(e)</sup>                                   |
| 2P33-F015                                         | Outboard torus sample B                 | Globe             | 1                      | Air                  | B <sup>(b)(e)</sup>                                   |

HNP-2-FSAR-3

**TABLE 3.9-33 (SHEET 10 OF 16)**

| <u>Valve No.</u>                                           | <u>Service Description</u>                 | <u>Valve Type</u> | <u>Size Line (in.)</u> | <u>Actuator Type</u> | <u>Environmental Design Conditions</u> <sup>(a)</sup> |
|------------------------------------------------------------|--------------------------------------------|-------------------|------------------------|----------------------|-------------------------------------------------------|
| <u>HPCI System</u> (See drawing nos. H-26020 and H-26021.) |                                            |                   |                        |                      |                                                       |
| 2E41-F001                                                  | HPCI turbine inlet isolation valve         | Gate              | 10                     | Motor                | B <sup>(b)(e)</sup>                                   |
| 2E41-F004                                                  | Pump suction from CST isolation            | Gate              | 16                     | Motor                | B <sup>(b)(e)</sup>                                   |
| 2E41-F006                                                  | Pump discharge to feedwater line isolation | Gate              | 14                     | Motor                | B <sup>(b)(e)</sup>                                   |
| 2E41-F007                                                  | Pump discharge to feedwater line isolation | Gate              | 14                     | Motor                | B, G <sup>(e)</sup>                                   |
| 2E41-F019                                                  | Pump suction from CST                      | Check             | 16                     | None                 | B, G                                                  |
| 2E41-F020                                                  | Pump suction relief valve                  | Relief            | 1                      | None                 | C                                                     |
| 2E41-F035                                                  | Cooling water pressure regulator           | Pressure check    | 2                      | Process fluid        | B <sup>(b)</sup>                                      |
| 2E41-F041                                                  | Suction from suppression pool isolation    | Gate              | 16                     | Motor                | B, G <sup>(e)</sup>                                   |
| 2E41-F042                                                  | Suction from suppression pool isolation    | Gate              | 16                     | Motor                | B, G <sup>(e)</sup>                                   |
| 2E41-F045                                                  | Suction from suppression pool              | Check             | 16                     | None                 | B, G                                                  |
| 2E41-F046                                                  | Minimum flow line                          | Check             | 4                      | None                 | B, G                                                  |
| 2E41-F048                                                  | Barometric condensate pump discharge line  | Check             | 2                      | None                 | C                                                     |
| 2E41-F049                                                  | HPCI turbine exhaust                       | Check             | 20                     | None                 | B, G                                                  |
| 2E41-F050                                                  | Cooling water relief valve                 | Relief            | 2                      | None                 | C <sup>(c)</sup>                                      |
| 2E41-F051                                                  | Suppression pool suction isolation         | Butterfly         | 16                     | Air                  | C <sup>(e)</sup>                                      |
| 2E41-F053                                                  | Exhaust drain pot drain isolation          | Globe             | 1                      | Solenoid             | B <sup>(b)(e)</sup>                                   |
| 2E41-F057                                                  | Oil cooler outlet                          | Check             | 2                      | None                 | C                                                     |
| 2E41-F059                                                  | Cooling water isolation valve              | Globe             | 2                      | Motor                | C <sup>(e)</sup>                                      |
| 2E41-F102                                                  | Exhaust line vacuum breaker line           | Check             | 2                      | None                 | C                                                     |

HNP-2-FSAR-3

**TABLE 3.9-33 (SHEET 11 OF 16)**

| <u>Valve No.</u>                                     | <u>Service Description</u>                 | <u>Valve Type</u> | <u>Size Line (in.)</u> | <u>Actuator Type</u> | <u>Environmental Design Conditions</u> <sup>(a)</sup> |
|------------------------------------------------------|--------------------------------------------|-------------------|------------------------|----------------------|-------------------------------------------------------|
| <u>HPCI System</u> (cont)                            |                                            |                   |                        |                      |                                                       |
| 2E41-F103                                            | Exhaust line vacuum breaker line           | Check             | 2                      | None                 | C                                                     |
| 2E41-F104                                            | Exhaust line vacuum breaker line isolation | Gate              | 2                      | Motor                | C <sup>(e)</sup>                                      |
| 2E41-F111                                            | Exhaust line vacuum breaker line isolation | Gate              | 2                      | Motor                | C <sup>(e)</sup>                                      |
| <u>CS System</u> (See drawing no. H-26018.)          |                                            |                   |                        |                      |                                                       |
| 2E21-F001A,B                                         | Pump suction line from torus               | Gate              | 20                     | Motor                | B, G <sup>(e)</sup>                                   |
| 2E21-F003A,B                                         | Pump discharge line                        | Check             | 12                     | None                 | B, G                                                  |
| 2E21-F004A,B                                         | Pump discharge line                        | Gate              | 10                     | Motor                | A, F <sup>(e)</sup>                                   |
| 2E21-F015A,B                                         | Test line                                  | Globe             | 10                     | Motor                | B, G <sup>(e)</sup>                                   |
| 2E21-F019A,B                                         | Pump suction line from torus               | Butterfly         | 20                     | Air                  | C <sup>(c)(e)</sup>                                   |
| 2E21-F031A,B                                         | Minimum flow bypass                        | Gate              | 3                      | Motor                | B, G <sup>(e)</sup>                                   |
| <u>Jockey Pump System</u> (See drawing no. H-26019.) |                                            |                   |                        |                      |                                                       |
| 2E11-F123A,B                                         | RHR fill line check valve                  | Check             | 2                      | None                 | C                                                     |
| 2E11-F124A,B                                         | RHR fill line isolation                    | Globe             | 2                      | None                 | C                                                     |
| 2E21-F039A,B                                         | CS fill line check valve                   | Check             | 1 1/2                  | None                 | C                                                     |
| 2E21-F040A,B                                         | CS fill line isolation                     | Globe             | 1 1/2                  | None                 | C                                                     |
| 2E21-F044A,B                                         | Discharge to CS test line isolation        | Stop check        | 1 1/2                  | None                 | C                                                     |
| 2E21-F050A,B                                         | Pump suction line                          | Check             | 2                      | None                 | C                                                     |
| 2E21-F052A,B                                         | Pump discharge line                        | Check             | 2                      | None                 | C                                                     |
| 2E21-F053A,B                                         | Pump discharge line                        | Check             | 2                      | None                 | C                                                     |

HNP-2-FSAR-3

**TABLE 3.9-33 (SHEET 12 OF 16)**

| <u>Valve No.</u>                                                   | <u>Service Description</u>            | <u>Valve Type</u> | <u>Size Line<br/>(in.)</u> | <u>Actuator<br/>Type</u> | <u>Environmental<br/>Design<br/>Conditions</u> <sup>(a)</sup> |
|--------------------------------------------------------------------|---------------------------------------|-------------------|----------------------------|--------------------------|---------------------------------------------------------------|
| <u>Jockey Pump System</u> (cont)                                   |                                       |                   |                            |                          |                                                               |
| 2E21-F056A,B                                                       | Pump suction line                     | Check             | 2                          | None                     | C                                                             |
| 2E21-F061A,B                                                       | Pump recirculation line               | Check             | 2                          | None                     | C                                                             |
| 2E21-F063A,B                                                       | Pump recirculation line               | Check             | 2                          | None                     | C                                                             |
| <u>FPCC System</u> (See drawing no. H-26039.)                      |                                       |                   |                            |                          |                                                               |
| 2G41-F017                                                          | RHR to fuel pool cooling isolation    | Gate              | 6                          | Handwheel                | B                                                             |
| 2G41-F034                                                          | RHR to fuel pool cooling isolation    | Gate              | 6                          | Handwheel                | B                                                             |
| 2G41-F038                                                          | Diffuser check valve                  | Check             | 6                          | None                     | B                                                             |
| 2G41-F039                                                          | Diffuser check valve                  | Check             | 6                          | None                     | B                                                             |
| <u>PSW System</u> (See drawing nos. H-21033, H-26050 and H-26051.) |                                       |                   |                            |                          |                                                               |
| 2P41-F035A,B                                                       | Inlet to HPCI pump room coolers       | Globe             | 2                          | Air                      | B <sup>(b)(e)</sup>                                           |
| 2P41-F036A,B                                                       | Inlet to RHR and CS pump room coolers | Globe             | 3                          | Air                      | B <sup>(b)(e)</sup>                                           |
| 2P41-F037A-D                                                       | Cooling water to RHR pumps            | Globe             | 1 1/2                      | Air                      | B <sup>(b)(e)</sup>                                           |
| 2P41-F039A,B                                                       | Inlet to RHR and CS pump room coolers | Globe             | 3                          | Air                      | B <sup>(b)(e)</sup>                                           |
| 2P41-F040A,B                                                       | Inlet to RCIC pump room coolers       | Globe             | 2                          | Air                      | B <sup>(b)(e)</sup>                                           |
| 2P41-F042A,B                                                       | Inlet to CRD pump room coolers        | Globe             | 3                          | Air                      | B <sup>(b)</sup>                                              |
| 2P41-F310                                                          | Dilution line                         | Butterfly         | 30                         | Motor                    | C <sup>(d)</sup>                                              |
| 2P41-F316A-D                                                       | Turbine building isolation            | Butterfly         | 30                         | Motor                    | C <sup>(d)</sup>                                              |
| 2P41-F320A-D                                                       | Minimum flow valve                    | Globe             | 3                          | Air                      | B <sup>(b)</sup>                                              |

HNP-2-FSAR-3

**TABLE 3.9-33 (SHEET 13 OF 16)**

| <u>Valve No.</u>                                                                            | <u>Service Description</u>              | <u>Valve Type</u> | <u>Size Line (in.)</u> | <u>Actuator Type</u> | <u>Environmental Design Conditions</u> <sup>(a)</sup> |
|---------------------------------------------------------------------------------------------|-----------------------------------------|-------------------|------------------------|----------------------|-------------------------------------------------------|
| <u>PSW System</u> (cont)                                                                    |                                         |                   |                        |                      |                                                       |
| 2P41-F334A,B                                                                                | Pump motor cooling water                | Globe             | 1                      | Process fluid        | B <sup>(b)</sup>                                      |
| 2P41-F339A,B                                                                                | Diesel generator cooler outlet          | Butterfly         | 6                      | Air                  | C <sup>(d)</sup>                                      |
| 2P41-F340                                                                                   | Diesel generator cooler outlet          | Butterfly         | 6                      | Air                  | C <sup>(d)</sup>                                      |
| <u>Reactor Building Closed Cooling Water System</u> (See drawing nos. H-26054 and H-26055.) |                                         |                   |                        |                      |                                                       |
| 2P42-F051                                                                                   | Isolation valve outside containment     | Gate              | 6                      | Motor                | B, G <sup>(e)</sup>                                   |
| 2P42-F052                                                                                   | Isolation valve outside containment     | Gate              | 6                      | Motor                | B, G <sup>(e)</sup>                                   |
| <u>RHR Service Water System</u> (See drawing no. H-21039.)                                  |                                         |                   |                        |                      |                                                       |
| 2E11-F068A,B                                                                                | Heat exchanger outlet control           | Globe             | 18                     | Motor                | B <sup>(b)(e)</sup>                                   |
| 2E11-F119A,B                                                                                | Crosstie line                           | Gate              | 18                     | Motor                | B <sup>(e)</sup>                                      |
| 2E11-F207A-D                                                                                | Minimum flow line                       | Globe             | 2                      | Air                  | B <sup>(b)</sup>                                      |
| <u>Drywell Pneumatic System</u> (See drawing nos. H-26066 and H-28023.)                     |                                         |                   |                        |                      |                                                       |
| 2P70-F001A,B                                                                                | Drywell pneumatic nitrogen backup valve | Globe             | 2                      | Air                  | B <sup>(b)(e)</sup>                                   |
| 2P70-F002                                                                                   | Drywell pneumatic isolation valve       | Globe             | 1                      | Air                  | B <sup>(b)(e)</sup>                                   |
| 2P70-F003                                                                                   | Drywell pneumatic isolation valve       | Globe             | 1                      | Air                  | B <sup>(b)(e)</sup>                                   |
| 2P70-F004                                                                                   | Drywell pneumatic isolation valve       | Globe             | 2                      | Air                  | B <sup>(b)(e)</sup>                                   |
| 2P70-F005                                                                                   | Drywell pneumatic isolation valve       | Globe             | 2                      | Air                  | B <sup>(b)(e)</sup>                                   |
| 2P70-F044                                                                                   | Drain from receiver 2P70-A001           | Solenoid          | 1/2                    | Electric             | B <sup>(b)</sup>                                      |

HNP-2-FSAR-3

**TABLE 3.9-33 (SHEET 14 OF 16)**

| <u>Valve No.</u>                                                                                         | <u>Service Description</u>                          | <u>Valve Type</u> | <u>Size Line (in.)</u> | <u>Actuator Type</u> | <u>Environmental Design Conditions</u> <sup>(a)</sup> |
|----------------------------------------------------------------------------------------------------------|-----------------------------------------------------|-------------------|------------------------|----------------------|-------------------------------------------------------|
| <u>Drywell Pneumatic System</u> (cont)                                                                   |                                                     |                   |                        |                      |                                                       |
| 2P70-F103A,B                                                                                             | Outlet from filters 2P70-D009A,B                    | Globe             | 1                      | Process fluid        | B <sup>(b)</sup>                                      |
| <u>Torus Drainage and Purification System</u> (See drawing no. H-26042.)                                 |                                                     |                   |                        |                      |                                                       |
| 2G51-F011                                                                                                | Condensate pump suction from torus                  | Gate              | 3                      | Air                  | B, G <sup>(e)</sup>                                   |
| 2G51-F012                                                                                                | Condensate pump suction from torus                  | Gate              | 3                      | Air                  | B, G <sup>(e)</sup>                                   |
| <u>Radwaste System</u> (See drawing nos. H-26026 through H-26032.)                                       |                                                     |                   |                        |                      |                                                       |
| 2G11-F003                                                                                                | Drywell floor drain sump first isolation valve      | Gate              | 3                      | Air                  | B <sup>(e)</sup>                                      |
| 2G11-F004                                                                                                | Drywell floor drain sump second isolation valve     | Gate              | 3                      | Air                  | B <sup>(e)</sup>                                      |
| 2G11-F019                                                                                                | Drywell equipment drain sump first isolation valve  | Gate              | 3                      | Air                  | B <sup>(e)</sup>                                      |
| 2G11-F020                                                                                                | Drywell equipment drain sump second isolation valve | Gate              | 3                      | Air                  | B <sup>(e)</sup>                                      |
| <u>Drywell Cooling and Chilled Water System</u>                                                          |                                                     |                   |                        |                      |                                                       |
| 2P64-F045                                                                                                | Chilled water line isolation                        | Globe             | 6                      | Motor                | B, G <sup>(e)</sup>                                   |
| 2P64-F047                                                                                                | Chilled water line isolation                        | Globe             | 6                      | Motor                | B, G <sup>(e)</sup>                                   |
| <u>Instrument Air System</u> (See drawing nos. H-21028, H-21077, H-26064, H-26070, H-26260 and H-26261.) |                                                     |                   |                        |                      |                                                       |
| 2P52-F565                                                                                                | Nitrogen backup to instrument air                   | Globe             | 2                      | Motor                | C                                                     |
| <u>Fission Product Monitoring System</u> (See drawing nos. H-16173 and H16274.)                          |                                                     |                   |                        |                      |                                                       |
| 2D11-F050                                                                                                | Fission product sample                              | Globe             | 1                      | Air                  | B <sup>(b)(e)</sup>                                   |



HNP-2-FSAR-3

**TABLE 3.9-33 (SHEET 15 OF 16)**

| <u>Valve No.</u>                                | <u>Service Description</u> | <u>Valve Type</u> | <u>Size Line<br/>(in.)</u> | <u>Actuator<br/>Type</u> | <u>Environmental<br/>Design<br/>Conditions</u> <sup>(a)</sup> |
|-------------------------------------------------|----------------------------|-------------------|----------------------------|--------------------------|---------------------------------------------------------------|
| <u>Fission Product Monitoring System</u> (cont) |                            |                   |                            |                          |                                                               |
| 2D11-F051                                       | Fission product sample     | Globe             | 1                          | Air                      | B <sup>(b)(e)</sup>                                           |
| 2D11-F052                                       | Fission product sample     | Globe             | 1                          | Air                      | B <sup>(b)(e)</sup>                                           |
| 2D11-F053                                       | Fission product sample     | Globe             | 1                          | Air                      | B <sup>(b)(e)</sup>                                           |

HNP-2-FSAR-3

**TABLE 3.9-33 (SHEET 16 OF 16)**

|                                                                                    | <u>A</u>            | <u>B</u>        | <u>C</u>        | <u>D</u>             | <u>E</u>        | <u>F</u>                                                           | <u>G</u> |
|------------------------------------------------------------------------------------|---------------------|-----------------|-----------------|----------------------|-----------------|--------------------------------------------------------------------|----------|
| Temperature (°F)                                                                   | 150                 | 40-104          | 150             | 100-340<br>(maximum) | 85-135          | 250 (340 for<br>10 min)                                            | 150      |
| Pressure (psig)                                                                    | 0-2                 | 0               | 0               | 0-62                 | 0               | 30 (56 for<br>10 min)                                              | 0        |
| Relative<br>humidity (%)                                                           | 40-90               | 20-90           | 95              | 100                  | 0-100           | 100                                                                | 90       |
| Atmosphere                                                                         | Air and<br>nitrogen | Air             | Air             | Air and<br>nitrogen  | Air             | Saturated<br>steam or mixed<br>saturated<br>steam plus<br>nitrogen | Air      |
| Integrated<br>radiation dose,<br>rads (except<br>when otherwise<br>shown in table) | $2 \times 10^8$     | $2 \times 10^8$ | $1 \times 10^7$ | $2 \times 10^7$      | $1 \times 10^7$ | ---                                                                | ---      |

- a. Environmental design conditions for active valves:
- b. Except integrated radiation dose is  $1.1 \times 10^6$  rads.
- c. Except integrated radiation dose is  $2 \times 10^7$  rads.
- d. Except integrated radiation dose is  $1 \times 10^6$  rads.
- e. Refer to Plant Hatch Central File for the Environmental Qualification of Electrical Equipment for the environmental design conditions of certain aspects of the equipment.
- f. Deactivated and locked in the closed (isolation) position.
- g. Power removed by opening breaker, valve in closed position.

HNP-2-FSAR-3

**TABLE 3.9-34 (SHEET 1 OF 2)**

**ACTIVE VALVES IN RCPB AND OTHER SEISMIC CATEGORY I SYSTEMS (GE SUPPLIED)**

| <u>MPL No.</u>                                                | <u>Type</u>                                                    | <u>Line Size (in.)</u> | <u>System Installed</u>                      | <u>Operator Actuator</u>                                                       | <u>Environmental Design Condition</u> | <u>Remarks</u>                                                      |
|---------------------------------------------------------------|----------------------------------------------------------------|------------------------|----------------------------------------------|--------------------------------------------------------------------------------|---------------------------------------|---------------------------------------------------------------------|
| B21-F013A,B<br>C,D,E,F,G,H,K,<br>L,M                          | Safety relief, 2-stage,<br>pilot-operated Target<br>Rock 7567F | 6                      | Nuclear boiler system<br>in main steam lines | Solenoid controlled air<br>valve and pneumatic<br>diaphragm operator           | (a)(d)                                | Solenoid valves qualified<br>by Target Rock to IEEE<br>Std 323-1974 |
| B21-F022A,B,C,D<br>(inboard)<br>B21-F028A,B,C,D<br>(outboard) | MSIV, Rockwell                                                 | 24                     | Nuclear boiler system<br>in main steam lines | Spring and pneumatic<br>cylinder-air-to open,<br>air and/or<br>spring-to-close | (b)(d)                                |                                                                     |
| B31-F031A,B                                                   | Block (discharge)                                              | 28                     | Recirculation system                         | Motor-operated<br>operator Limitorque                                          | (c)(d)                                | Operators from<br>Limitorque qualified to<br>IEEE Std 382-1972      |
| B31-F023A,B                                                   | Block (suction)                                                | 28                     |                                              |                                                                                |                                       |                                                                     |

a. Ambient Conditions - Valves are exposed to the following ambient conditions within a pressure-retaining enclosure:

|                       | <u>Normal</u> | <u>Emergency</u> |                 |                 |                 |                 |
|-----------------------|---------------|------------------|-----------------|-----------------|-----------------|-----------------|
|                       |               | <u>A</u>         | <u>B</u>        | <u>C</u>        | <u>D</u>        | <u>E</u>        |
| Temperature (°F)      | 150           | 340              | 340             | 320             | 250             | 200             |
| Pressure (psig)       | 0 to 2        | 65<br>(maximum)  | 45<br>(maximum) | 45<br>(maximum) | 25<br>(maximum) | 20<br>(maximum) |
| Relative humidity (%) | 100           | 100              | 100             | 100             | 100             | 100             |
| Duration              | Continuous    | < 60 s           | 3 h             | 3 h             | 24 h            | 100 days        |

(Total duration is the sum of the separate durations.)

HNP-2-FSAR-3

**TABLE 3.9-34 (SHEET 2 OF 2)**

Incident radiation: Continuous for design life  
 Gamma: 65 R/h  
 Gamma and neutron: 75 R/h

The valves are operable, within specification limits, during normal and emergency conditions A, B, C, D, and E, except that valves need not be operable in the power-actuated, pressure-relieving mode during exposure to emergency condition A but must survive exposure to emergency condition A without a detrimental effect. Variance in set pressure, during the automatic pressure-relieving mode of operation, due to ambient superimposed back pressure is permissible.

b. Valves operate as specified at the following ambient conditions within the pressure-retaining enclosure:

|                               | <u>Normal</u> | <u>Emergency</u> |                 |                 |                 |                 |
|-------------------------------|---------------|------------------|-----------------|-----------------|-----------------|-----------------|
|                               |               | <u>A</u>         | <u>B</u>        | <u>C</u>        | <u>D</u>        | <u>E</u>        |
| Temperature (°F)<br>(maximum) | 150           | 340              | 340             | 320             | 250             | 200             |
| Pressure (psig)               | 0 to 2        | 65<br>(maximum)  | 45<br>(maximum) | 45<br>(maximum) | 25<br>(maximum) | 20<br>(maximum) |
| Relative humidity (%)         | 100           | 100              | 100             | 100             | 100             | 100             |
| Duration                      | Continuous    | < 60 s           | 3 h             | 3 h             | 24 h            | 100 days        |

(Total duration is the sum of the separate durations.)

Incident radiation: Continuous for design life  
 Gamma: 15 R/h  
 Gamma and neutron: 25 R/h

The valves are capable of operation, within specified limits, except regarding variance in closing speed due to superimposed back pressure resulting from emergency ambient conditions during 1-h (total) exposure to emergency ambient conditions A and B, and remain closed during the continuance of emergency ambient conditions.

c. Valves are inaccessible for periods of up to 1 year and are designed to operate over the specified design life in an atmosphere of air or nitrogen at 150°F with 100% humidity. Valves are also designed to operate satisfactorily when exposed to a saturated steam atmosphere or mixture of nitrogen and steam under the following conditions:

- 340°F for 3 h at 100% humidity between -2 and 45 psig.
- 320°F for 4 1/2 h at 100% humidity between -2 and 20 psig.

d. Refer to Plant Hatch Central File for the Environmental Qualification of Electrical Equipment for the environmental design conditions of certain aspects of this equipment.

HNP-2-FSAR-3

**TABLE 3.9-35 (SHEET 1 OF 5)**

**DESIGN CRITERIA FOR HVAC COMPONENTS NOT COVERED BY ASME CODE**

| <u>System Components</u>  | <u>Controlling Standards<br/>and/or Codes</u>                                                                                                                                                                                                                                                                                                                                                                                           | <u>Test Report No.<br/>Test Procedure No.</u>                                                                                                                                                                                                                                                                             |
|---------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <u>SBG T system train</u> |                                                                                                                                                                                                                                                                                                                                                                                                                                         |                                                                                                                                                                                                                                                                                                                           |
| Exhaust fans and drivers  | Applicable seismic response curves per attachment to Specifications<br><br>American Society for Testing and Materials (ASTM) Standards D2862, A366, 1056, D2866, & D28<br><br>Air Moving and Conditioning Association Incorporated, Test Codes 300-67, & 210-67<br><br>IEEE Standard 323-71, Guide for Qualification of Class 1E Equipment for Nuclear Power Generating Stations<br><br>Military Specifications MIL-51079 and MIL-R6130 | Seismic calculations<br><br><br><br>Certified fan performance curves<br><br>Equipment not required for rulemaking, 10 CFR 50.49                                                                                                                                                                                           |
| Filter housing            | <br><br>ANSI B16.5 (1968), for steel pipe flanges and flanged fittings<br><br>ANSI B16.11 (1966), for forged-steel fittings, socket welded and threaded<br><br>ANSI N45.8, Testing of Nuclear Air Cleaning Systems                                                                                                                                                                                                                      | Seismic calculations<br><br>Inspection test documentation (filter media tests, etc.) per Farr Company Procedure QC-10<br><br>In-place leak test of HEPA filter banks per Farr Company Procedure L53460<br><br>In-place leak test of carbon bank per Farr Company Procedure L53577<br><br>Certified fan performance curves |
| Filter elements           | Underwriters' Laboratories Standard UL-900, Air Filter Units<br><br>NRC Health and Safety Information Bulletin, Issue 306, March 31, 1971                                                                                                                                                                                                                                                                                               | Seismic calculations<br><br>Inspection test documentation (filter media tests, etc.) per Farr Company Procedure QC-10                                                                                                                                                                                                     |

HNP-2-FSAR-3

**TABLE 3.9-35 (SHEET 2 OF 5)**

| <u>System Components</u>                                                   | <u>Controlling Standards<br/>and/or Codes</u>                                                                                                                                     | <u>Test Report No.<br/>Test Procedure No.</u>                             |
|----------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------|
| <u>SBGT system train (cont)</u>                                            | Military Specification MIL-F-51068C, Filter, Particulate, High Efficiency, and Fire Resistance                                                                                    | In-place leak test of HEPA filter banks per Farr Company Procedure L53460 |
|                                                                            | National Bureau of Standards (NBS) Bulletin A, Test Method for Air Filters, by A.S. Dill, 1966                                                                                    | In-place leak test of carbon bank per Farr Company Procedure L53577       |
|                                                                            | ASTM Standards, D2862, A366, 1056, D2866, D28                                                                                                                                     | Certified fan performance curves                                          |
|                                                                            | ANSI N101.1, 1972, Efficiency Testing of Air Cleaning Systems Containing Devices for Removal of Particles                                                                         |                                                                           |
|                                                                            | Technical, Unimpregnated                                                                                                                                                          |                                                                           |
|                                                                            | NRC Division of Reactor Development and Technology Standard RDTM16-IT, "Gas-Phase Adsorbents for Trapping Radio Active Iodine Compounds," including Amendment dated March 7, 1973 |                                                                           |
|                                                                            | ANSI N45.8, Testing of Nuclear Air Cleaning Systems                                                                                                                               |                                                                           |
| Instrumentation                                                            | IEEE 279 and IEEE 336                                                                                                                                                             | Seismic calculations                                                      |
| <u>RHR pump room cooling units<br/>and<br/>HPCI pump room cooling unit</u> |                                                                                                                                                                                   |                                                                           |
| Fan and driver                                                             |                                                                                                                                                                                   | Seismic Analysis Report, CVI A 905-9913                                   |
|                                                                            |                                                                                                                                                                                   | ARI calculations, CVI A 905-9927                                          |
|                                                                            | Air Moving and Conditioning Association Incorporated Test Code 300-67, 210-67                                                                                                     | Liquid penetrant test per CVI Procedure 38-1002                           |

HNP-2-FSAR-3

**TABLE 3.9-35 (SHEET 3 OF 5)**

| <u>System Components</u>                                                          | <u>Controlling Standards<br/>and/or Codes</u>                                                             | <u>Test Report No.<br/>Test Procedure No.</u>                                                                                                                                                                                            |
|-----------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <u>RHR pump room cooling units<br/>and<br/>HPCI pump room cooling unit</u> (cont) |                                                                                                           |                                                                                                                                                                                                                                          |
| Fan and driver (cont)                                                             | ASTM Standards                                                                                            | Hydrostatic coil test per CVI Procedure A 905-9903<br><br>Certified fan performance curves                                                                                                                                               |
| Plenum                                                                            | American Welding Society (AWS) Standard D1.0-69                                                           | Seismic Analysis Report, CVI A 905-9913<br><br>ARI calculations, CVI A 905-9927<br><br>Liquid penetrant test per CVI Procedure 38-1002<br><br>Hydrostatic coil test per CVI Procedure A 905-9903<br><br>Certified fan performance curves |
| <u>Battery room</u>                                                               |                                                                                                           |                                                                                                                                                                                                                                          |
| Emergency exhaust fan<br>and driver                                               | Air Moving and Conditioning Association Incorporated<br>Test Codes 300-67 and 210-67<br><br>ASTM Standard | Seismic Analysis Report, CVI A 905-9913<br><br>Seismic Calculations<br><br>Certified performance curves                                                                                                                                  |

HNP-2-FSAR-3

**TABLE 3.9-35 (SHEET 4 OF 5)**

| <u>System Components</u>                                     | <u>Controlling Standards<br/>and/or Codes</u>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       | <u>Test Report No.<br/>Test Procedure No.</u>                                                                                                                                                                                 |
|--------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <u>Control room environmental<br/>control (MCREC) system</u> |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                                                                                                                                                                                                                               |
| Fans                                                         | Air Moving and Conditioning Association                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             | Seismic calculations<br>Certified fan performance curves                                                                                                                                                                      |
| Filters (HEPA and charcoal)                                  | American Filter Institute Artificial dust weight test<br>(Section 1)<br><br>United States Army Edgewood Arsenal Instruction Manuals:<br>136-300-195A and 136-300-175A<br><br>Military Specification MIL-F-51068A, as amended and<br>modified to meet particular needs of national atomic energy<br>program per NRC Health and Safety Information Bulletin<br>Issue 212, June 25, 1965<br><br>American Society of Heating, Refrigerating and Air<br>Conditioning Engineers<br><br>Sheet Metal and Air Conditioning Contractors National<br>Association, Incorporated<br><br>NRC Bulletin 306<br><br>NBS Standard (dust spot)<br><br>Underwriters' Laboratories UL-900 and UL-586<br><br>ASTM D1056<br><br>NRC DP1075 | Seismic calculations<br><br>In-place leak test of HEPA filter banks per Farr Company<br>Procedure L41656<br><br>In-place leak test of carbon bed per Farr Company<br>Procedure L47634<br><br>Certified fan performance curves |
| Air-conditioning unit                                        | Associated Air Balance Council<br><br>Air Moving and Conditioning Association                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       | Seismic calculations<br><br>Leak test for cooling coils<br><br>Certified fan performance curves                                                                                                                               |



HNP-2-FSAR-3

**TABLE 3.9-35 (SHEET 5 OF 5)**

| <u>System Components</u>                | <u>Controlling Standards and/or Codes</u>                                 | <u>Test Report No. Test Procedure No.</u>                                 |
|-----------------------------------------|---------------------------------------------------------------------------|---------------------------------------------------------------------------|
| <u>(MCREC) system (cont)</u>            |                                                                           |                                                                           |
| Ductwork and insulation                 |                                                                           | Seismic calculations                                                      |
|                                         | Sheet Metal and Air Conditioning Contractors National Association         | Leak test for cooling coils                                               |
|                                         | National Building Code, Section 200                                       | In-place leak test of HEPA filter banks per Farr Company Procedure L41656 |
|                                         | Underwriters' Laboratories                                                | In-place leak test of carbon bed per Farr Company Procedure L47634        |
|                                         |                                                                           | Certified fan performance curves                                          |
| Controls and instrumentation            | National Electric Manufacturers Association                               | Seismic calculations                                                      |
|                                         | IEEE Standard                                                             | Leak test for cooling coils                                               |
| Refrigerant piping and condensing units | ANSI B31.5                                                                | Seismic calculations                                                      |
|                                         | American Society of Heating, Refrigerating and Air-Conditioning Engineers | Leak test for cooling coils                                               |
|                                         | ASME Section VIII, Division I                                             |                                                                           |

LEGEND

HEPA - high-efficiency particulate air.

HNP-2-FSAR-3

**TABLE 3.9-36 (SHEET 1 OF 5)**  
**CORE SPRAY 10-in. GATE VALVE**

1. Seismic analysis (NB-3524)

| <u>Valve Critical Sections</u> | <u>Method of Analysis</u>                                                                                               | <u>Limit</u>             | Minimum Required<br>( $G/f_n$ ) | Calculated<br>( $G_{sm}/f_n$ ) |
|--------------------------------|-------------------------------------------------------------------------------------------------------------------------|--------------------------|---------------------------------|--------------------------------|
| Motor/yoke bolting             | Calculate static acceleration ( $G_{sm}$ ) that will make sum of bending stress plus thrust stress at section = $S_m$ . | $G_{sm} > 3.0 \text{ g}$ | 3.0                             | 38.3                           |
| Yoke arm                       |                                                                                                                         |                          | 3.0                             | 9.46                           |
| Yoke/bonnet bolting            |                                                                                                                         |                          | 3.0                             | 12.75                          |
| Body neck                      |                                                                                                                         |                          | 3.0                             | 60.95                          |
| Natural frequency              | Three lumped-mass cantilever beam analyzed by matrix iteration method.                                                  | $f_n > 20$               | 20.0                            | 117.0                          |

HNP-2-FSAR-3

**TABLE 3.9-36 (SHEET 2 OF 5)**

2. Design of pressure-retaining parts

| <u>Stress Category</u>                                                                        | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u> | <u>Allowable Stress<br/>or Minimum<br/>Dimension Required</u> | <u>Calculated Stress<br/>or Actual Dimension</u> |
|-----------------------------------------------------------------------------------------------|--------------------------------------------------------------|---------------------------------------------------------------|--------------------------------------------------|
| Minimum wall thickness                                                                        | NB-3541                                                      |                                                               |                                                  |
| $t_m \leq t_e$                                                                                | NB-3542.1                                                    | $t_m = 0.772$ in.                                             | $t_e = 0.937$ in.                                |
| for $d'_m \geq 1.5 d_m$                                                                       | NB-3542.2                                                    | $1.5 d_m = 14.625$ in.                                        | $d'_m = 13.0$ in.                                |
| Radius of crotch                                                                              |                                                              |                                                               |                                                  |
| $r_2 \geq 0.3 t_m$                                                                            | $r_2 =$ NB-3544.1(a)                                         | $0.3 t_m = 0.2316$ in.                                        | $r_2 = 1.5$ in.                                  |
| $r_3 \geq \left\{ \begin{array}{l} 0.05t_m \\ 0.1h \end{array} \right\}$ whichever is greater |                                                              | $0.10 H = 0.0625$ in.                                         | $r_3 = 0.125$ in.                                |
| Body primary and secondary stress                                                             | NB-3545                                                      |                                                               |                                                  |
| $P_m = \left( \frac{A_f}{A_m} + 0.5 \right) P_s$                                              | NB-3545.1(a)(2)                                              |                                                               |                                                  |
| Inlet end                                                                                     | $S_m \geq P_m$ at 500°F                                      | $S_m = 19,400$ psi at 500°F                                   | $P_m = 8377$ psi                                 |
| Outlet end                                                                                    |                                                              | $S_m = 19,400$ psi at 500°F                                   | $P_m = 8377$ psi                                 |
| Disc and seat ring analysis                                                                   | NB-3546.2                                                    |                                                               |                                                  |
| $P_m \leq 1.0 S_m$                                                                            | Acceptable stress analysis method                            | $1.0 S_m = 19,400$ psi at 500°F                               | $P_m = 11,433$ psi                               |
| $S_{max} \leq 1.5 S_m$                                                                        |                                                              | $1.5 S_m = 29,100$ psi at 500°F                               | $S_{max} = 19,357$ psi                           |

HNP-2-FSAR-3

**TABLE 3.9-36 (SHEET 3 OF 5)**

3. Structural analysis for  
other valve parts (NB-3546.3)

| <u>Stress Category</u>    | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u> | <u>Allowable Stress<br/>or Design Value<br/>(psi)</u> | <u>Calculated Stress<br/>or Actual Value<br/>(psi)</u> |
|---------------------------|--------------------------------------------------------------|-------------------------------------------------------|--------------------------------------------------------|
| Stem thrust stress        | Calculate stress due to operator thrust                      | $S_m = 26,700$ at 500°F                               | $S_T = 10,904$                                         |
| Stem torque stress        | Calculate stress due to operator torque                      | $0.6 S_m = 16,020$ at 500°F                           | $S_S = 453$                                            |
| Gasket seating stress     | Acceptable stress analysis method                            | $1.5 S_m = 28,300$ at 500°F                           | $S = 9590$                                             |
| Bonnet                    | Calculate stress due to pressure                             | $S_m = 19,400$ at 500°F                               | $S = 13,410$                                           |
| Protective or thrust ring | Calculate stress due to pressure                             | $S_m = 44,100$ at 500°F                               | $S = 11,554$                                           |
| Eyebolt                   | Calculate stress due to pressure                             | $S_m = 7000$ at 500°F                                 | $S = 3097$                                             |

TABLE 3.9-36 (SHEET 4 OF 5)

4. Cyclic loading requirements

| <u>Stress Category</u>                                 | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u>    | <u>Allowable Stress<br/>or Minimum<br/>Dimension Required<br/>(psi)</u> | <u>Calculated Stress<br/>or Actual Dimension<br/>(psi)</u> |
|--------------------------------------------------------|-----------------------------------------------------------------|-------------------------------------------------------------------------|------------------------------------------------------------|
| Secondary stress due to pipe reaction                  | NB-3545.2(b)                                                    |                                                                         |                                                            |
| $P_{ed} = \frac{F_d S}{G_d}$                           | NB-3545.2(b)(1)<br>Figures NB-3545.2-2, 3<br>NB-3545.2(b)(1)    | $1.5 S_m = 29,100$ at 500°F                                             | $P_{ed} = 9440$                                            |
| $P_{eb} = C_b \frac{F_b S}{G_b}$                       | Figures NB-3545.2-4, 5<br>Figure NB-3545.2-6<br>NB-3545.2(b)(5) | $1.5 S_m = 29,100$ at 500°F                                             | $P_{eb} = 18,608$                                          |
| $P_{et} = 2 \frac{F_b S}{G_t}$                         | NB-3545.2(b)(1)<br>NB-3545.2(b)(6)(c)                           | $1.5 S_m = 29,100$ at 500°F                                             | $P_{et} = 17,721$                                          |
| Primary plus secondary stress due to internal pressure | NB-3545.2(a)(1)                                                 |                                                                         |                                                            |
| $Q_p = C_p \left( \frac{r_i}{t_e} + 0.5 \right) P_s$   | Figure NB-3545.1-1<br>Figure NB-3545.1(a)-1                     | No limit required                                                       | $Q_p = 27,630$                                             |
| Thermal secondary stress at inlet and outlet crotch    | NB-3545.2(c)                                                    |                                                                         |                                                            |
| $Q_{T_1}$                                              | Figures                                                         | No limit required                                                       | $Q_{T_1} = NA^{(a)}$                                       |
| $Q_{T_2}$                                              | NB-3545.2(c)-2, 3                                               | No limit required                                                       | $Q_{T_2} = 177$                                            |
| $Q_{T_3}$                                              | NB-3545.2(c)-4, 5                                               | No limit required                                                       | $Q_{T_3} = 271$                                            |

**TABLE 3.9-36 (SHEET 5 OF 5)**

4. Cyclic loading requirements (cont)

| <u>Stress Category</u>                                                | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u> | <u>Allowable Stress<br/>or Minimum<br/>Dimension Required<br/>(psi)</u> | <u>Calculated Stress<br/>or Actual Dimension<br/>(psi)</u>                                              |
|-----------------------------------------------------------------------|--------------------------------------------------------------|-------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|
| Valve body secondary stress criteria at crotch region                 | NB-3545.2                                                    |                                                                         |                                                                                                         |
| $S_n = Q_p + P_{ed} + 2Q_{T_2} \leq 3S_m$                             |                                                              | $3 S_m = 58,200$ at 500°F                                               | $S_n = 37,425$                                                                                          |
| Normal-duty valve fatigue requirements                                | NB-3545.3<br>NB-3550                                         |                                                                         |                                                                                                         |
| $S_{P_1} = \frac{2}{3} Q_p + \frac{P_{eb}}{2} + Q_{T_3} + 1.3Q_{T_1}$ | NB-3545.3(a)                                                 | No limit required                                                       | $S_{P_1} = 28,618$                                                                                      |
| $S_{P_2} = 0.4 Q_p + P_{eb} + 2Q_{T_3}$                               | NB-3545.3(a)                                                 | No limit required                                                       | $S_{P_2} = 30,201$<br>$S_A = 30,201$                                                                    |
| $N_a \geq 2000$ cycles                                                | $N_a =$ Figure I-9-1                                         | 2000 cycles                                                             | $N_a = 10,900$ cycles                                                                                   |
| Cyclic stress calculation                                             | NB-3554                                                      |                                                                         | The analysis complies with NB-3222.4(c). Therefore, fatigue analysis and usage factor are not required. |
| $Q_p + P_{ed} + C_6 C_2 C_4 \Delta T_{f(max)} \leq 3S_m$              | NB-3554(a)                                                   | $3 S_m = 58,200$ at 500°F                                               |                                                                                                         |
| $Q_p + P_{eb} + C_6 C_3 C_4 \Delta T_{f(max)} \leq 3S_m$              | NB-3554(b)                                                   | $3 S_m = 58,200$ at 500°F                                               |                                                                                                         |
| $S_i = \frac{4}{3} Q_p + P_{eb} + C_6 (C_3 C_4 + C_5) \Delta T_{fi}$  | $N_i =$ Figure I-9-1                                         | $\sum \frac{N_{ri}}{N_i} \leq 1.0$                                      | $\sum \frac{N_{ri}}{N_i} = NA$ (a)                                                                      |

a. NA - not applicable.

HNP-2-FSAR-3

TABLE 3.9-37 (SHEET 1 OF 5)

HPCI AND CORE SPRAY 10-in. GATE VALVE

1. Seismic analysis (NB-3524)

| <u>Valve Critical Sections</u> | <u>Method of Analysis</u>                                                                                               | <u>Limit</u>             | Minimum<br>Required<br>( $G/f_n$ ) | Calculated<br>( $G_{sm}/f_n$ ) |
|--------------------------------|-------------------------------------------------------------------------------------------------------------------------|--------------------------|------------------------------------|--------------------------------|
| Motor/yoke bolting             | Calculate static acceleration ( $G_{sm}$ ) that will make sum of bending stress plus thrust stress at section = $S_m$ . | $G_{sm} > 3.0 \text{ g}$ | 3.0                                | 97.7                           |
| Yoke arm                       |                                                                                                                         |                          | 3.0                                | 65.7                           |
| Yoke/bonnet bolting            |                                                                                                                         |                          | 3.0                                | 24.9                           |
| Body neck                      |                                                                                                                         |                          | 3.0                                | 169.6                          |
| Natural frequency              | Three lumped-mass cantilever beam analyzed by matrix iteration method.                                                  | $f_n > 20$               | 20.0                               | 141.0                          |

HNP-2-FSAR-3

**TABLE 3.9-37 (SHEET 2 OF 5)**

2. Design of pressure-retaining parts

| <u>Stress Category</u>                                                                        | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u> | <u>Allowable Stress<br/>or Minimum<br/>Dimension Required</u> | <u>Calculated Stress<br/>or Actual Dimension</u> |
|-----------------------------------------------------------------------------------------------|--------------------------------------------------------------|---------------------------------------------------------------|--------------------------------------------------|
| Minimum wall thickness                                                                        | NB-3541                                                      |                                                               |                                                  |
| $t_m \leq t_e$                                                                                | NB-3542.1                                                    | $t_m = 1.061$ in.                                             | $t_e = 1.84$ in.                                 |
| for $d'_m \geq 1.5 d_m$                                                                       | NB-3542.2                                                    | $1.5 d_m = 13.968$ in.                                        | $d'_m = 11.625$ in.                              |
| Radius of crotch                                                                              |                                                              |                                                               |                                                  |
| $r_2 \geq 0.3 t_m$                                                                            | $r_2 =$ NB-3544.1(a)                                         | $0.3 t_m = 0.3183$ in.                                        | $r_2 = 1.50$ in.                                 |
| $r_3 \geq \left\{ \begin{array}{l} 0.05t_m \\ 0.1h \end{array} \right\}$ whichever is greater |                                                              | $0.05 t_m = 0.0594$ in.                                       | $r_3 = 0.125$ in.                                |
| Body primary and secondary stress                                                             | NB-3545                                                      |                                                               |                                                  |
| $P_m = \left( \frac{A_f}{A_m} + 0.5 \right) P_s$                                              | NB-3545.1(a)(2)                                              |                                                               |                                                  |
| Inlet end                                                                                     | $S_m \geq P_m$ at 500°F                                      | $S_m = 19,400$ psi at 500°F                                   | $P_m = 8443$ psi                                 |
| Outlet end                                                                                    |                                                              | $S_m = 19,400$ psi at 500°F                                   | $P_m = 8443$ psi                                 |
| Disc and seat ring analysis                                                                   | NB-3546.2                                                    |                                                               |                                                  |
| $P_m \leq 1.0 S_m$                                                                            | Acceptable stress analysis method                            | $1.0 S_m = 19,400$ psi at 500°F                               | $P_m = 14,448$ psi<br>(due to thrust)            |
| $S_{max} \leq 1.5 S_m$                                                                        |                                                              | $1.5 S_m = 29,100$ psi at 500°F                               | $S_{max} = 16,443$ psi                           |



HNP-2-FSAR-3

**TABLE 3.9-37 (SHEET 3 OF 5)**

3. Structural analysis for  
other valve parts (NB-3546.3)

| <u>Stress Category</u>    | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u> | <u>Allowable Stress<br/>or Design Value<br/>(psi)</u> | <u>Calculated Stress<br/>or Actual Value<br/>(psi)</u> |
|---------------------------|--------------------------------------------------------------|-------------------------------------------------------|--------------------------------------------------------|
| Stem thrust stress        | Calculate stress due to operator thrust                      | $S_m = 26,700$ at 500°F                               | $S_T = 11,670$                                         |
| Stem torque stress        | Calculate stress due to operator torque                      | $0.6 S_m = 16,020$ at 500°F                           | $S_S = 533$                                            |
| Gasket seating stress     | Acceptable stress analysis method                            | $1.5 S_m = 28,300$ at 500°F                           | $S = 11,661$                                           |
| Bonnet                    | Calculate stress due to pressure                             | $S_m = 19,400$ at 500°F                               | $S = 13,263$                                           |
| Protective or thrust ring | Calculate stress due to pressure                             | $S_m = 26,700$ at 500°F                               | $S = 13,735$                                           |
| Eyebolt                   | Calculate stress due to pressure                             | $S_m = 7000$ at 500°F                                 | $S = 6073$                                             |

HNP-2-FSAR-3

**TABLE 3.9-37 (SHEET 4 OF 5)**

4. Cyclic loading requirements

| <u>Stress Category</u>                                 | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u>    | <u>Allowable Stress<br/>or Minimum<br/>Dimension Required<br/>(psi)</u> | <u>Calculated Stress<br/>or Actual Dimension<br/>(psi)</u> |
|--------------------------------------------------------|-----------------------------------------------------------------|-------------------------------------------------------------------------|------------------------------------------------------------|
| Secondary stress due to pipe reaction                  | NB-3545.2(b)                                                    |                                                                         |                                                            |
| $P_{ed} = \frac{F_d S}{G_d}$                           | NB-3545.2(b)(1)<br>Figures NB-3545.2-2, 3<br>NB-3545.2(b)(1)    | 1.5 S <sub>m</sub> = 29,100 at 500°F                                    | P <sub>ed</sub> = 10,084                                   |
| $P_{eb} = C_b \frac{F_b S}{G_b}$                       | Figures NB-3545.2-4, 5<br>Figure NB-3545.2-6<br>NB-3545.2(b)(5) | 1.5 S <sub>m</sub> = 29,100 at 500°F                                    | P <sub>eb</sub> = 21,282                                   |
| $P_{et} = 2 \frac{F_b S}{G_t}$                         | NB-3545.2(b)(1)<br>NB-3545.2(b)(6)(c)                           | 1.5 S <sub>m</sub> = 29,100 at 500°F                                    | P <sub>et</sub> = 21,289                                   |
| Primary plus secondary stress due to internal pressure | NB-3545.2(a)(1)                                                 |                                                                         |                                                            |
| $Q_p = C_p \left( \frac{r_i}{t_e} + 0.5 \right) P_s$   | Figure NB-3545.1-1<br>Figure NB-3545.1(a)-1                     | No limit required                                                       | Q <sub>p</sub> = 20,322                                    |
| Thermal secondary stress at inlet and outlet crotch    | NB-3545.2(c)                                                    |                                                                         |                                                            |
| Q <sub>T1</sub>                                        | Figures                                                         | No limit required                                                       | Q <sub>T1</sub> = NA <sup>(a)</sup>                        |
| Q <sub>T2</sub>                                        | NB-3545.2(c)-2, 3                                               | No limit required                                                       | Q <sub>T2</sub> = 177                                      |
| Q <sub>T3</sub>                                        | NB-3545.2(c)-4, 5                                               | No limit required                                                       | Q <sub>T3</sub> = 271                                      |

HNP-2-FSAR-3

**TABLE 3.9-37 (SHEET 5 OF 5)**

4. Cyclic loading requirements (cont)

| <u>Stress Category</u>                                               | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u> | <u>Allowable Stress<br/>or Minimum<br/>Dimension Required<br/>(psi)</u> | <u>Calculated Stress<br/>or Actual Dimension<br/>(psi)</u> |
|----------------------------------------------------------------------|--------------------------------------------------------------|-------------------------------------------------------------------------|------------------------------------------------------------|
| Valve body secondary stress criteria<br>at crotch region             | NB-3545.2                                                    |                                                                         |                                                            |
| $S_n = Q_p + P_{ed} + 2Q_{T_2} \leq 3S_m$                            |                                                              | $3 S_m = 58,200$ at 500°F                                               | $S_n = 30,718$                                             |
| Normal-duty valve fatigue<br>requirements                            | NB-3545.3<br>NB-3550                                         |                                                                         |                                                            |
| $S_{P_1} = \frac{2}{3}Q_p + \frac{P_{eb}}{2} + Q_{T_3} + 1.3Q_{T_1}$ | NB-3545.3(a)                                                 | No limit required                                                       | $S_{P_1} = 25,571$                                         |
| $S_{P_2} = 0.4 Q_P + P_{eb} + 2Q_{T_3}$                              | NB-3545.3(a)                                                 | No limit required                                                       | $S_{P_2} = 29,836$<br>$S_A = 29,836$                       |
| $N_a \geq 2000$ cycles                                               | $N_a =$ Figure I-9-1                                         | 2000 cycles                                                             | $N_a = 20,100$ cycles                                      |
| Cyclic stress calculation                                            | NB-3554                                                      |                                                                         |                                                            |
| $Q_P + P_{ed} + C_6 C_2 C_4 \Delta T_{f(max)} \leq 3S_m$             | NB-3554(a)                                                   | $3 S_m = 58,200$ at 500°F                                               | $S_{nc} = 40,736$                                          |
| $Q_P + P_{eb} + C_6 C_3 C_4 \Delta T_{f(max)} \leq 3S_m$             | NB-3554(b)                                                   | $3 S_m = 58,200$ at 500°F                                               | $S_{nmax} = 55,680$                                        |
| $S_i = \frac{4}{3}Q_p + P_{eb} + C_6(C_3 C_4 + C_5)\Delta T_{fi}$    | $N_i =$ Figure I-9-1                                         | $\sum \frac{N_{ri}}{N_i} \leq 1.0$                                      | $\sum \frac{N_{ri}}{N_i} = 0.2458$                         |

HNP-2-FSAR-3

**TABLE 3.9-38 (SHEET 1 OF 5)**  
**FEEDWATER 18-in. GATE VALVE**

1. Seismic analysis (NB-3524)

| <u>Valve Critical Sections</u> | <u>Method of Analysis</u>                                                                                               | <u>Limit</u>             | Minimum<br>Required<br>( $G/f_n$ ) | Calculated<br>( $G_{sm}/f_n$ ) |
|--------------------------------|-------------------------------------------------------------------------------------------------------------------------|--------------------------|------------------------------------|--------------------------------|
| Motor/yoke bolting             | Calculate static acceleration ( $G_{sm}$ ) that will make sum of bending stress plus thrust stress at section = $S_m$ . | $G_{sm} > 3.0 \text{ g}$ | 3.0                                | 5.851                          |
| Yoke arm                       |                                                                                                                         |                          | 3.0                                | 80.69                          |
| Yoke/bonnet bolting            |                                                                                                                         |                          | 3.0                                | 37.935                         |
| Body neck                      |                                                                                                                         |                          | 3.0                                | 90.839                         |
| Natural frequency              | Three lumped-mass cantilever beam analyzed by matrix iteration method.                                                  | $f_n > 20$               | 20.0                               | 36.0                           |

HNP-2-FSAR-3

**TABLE 3.9-38 (SHEET 2 OF 5)**

2. Design of pressure-retaining parts

| <u>Stress Category</u>                                                                          | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u> | <u>Allowable Stress<br/>or Minimum<br/>Dimension Required</u> | <u>Calculated Stress<br/>or Actual Dimension</u> |
|-------------------------------------------------------------------------------------------------|--------------------------------------------------------------|---------------------------------------------------------------|--------------------------------------------------|
| Minimum wall thickness                                                                          | NB-3541                                                      |                                                               |                                                  |
| $t_m \leq t_e$                                                                                  | NB-3542.1                                                    | $t_m = 1.739$ in.                                             | $t_e = 3.235$ in.                                |
| for $d'_m \geq 1.5 d_m$                                                                         | NB-3542.2                                                    | $1.5 d_m = 23.53$ in.                                         | $d'_m = 19.50$ in.                               |
| Radius of crotch                                                                                |                                                              |                                                               |                                                  |
| $r_2 \geq 0.3 t_m$                                                                              | $r_2 =$ NB-3544.1(a)                                         | $0.3 t_m = 0.5217$ in.                                        | $r_2 = 1.250$ in.                                |
| $r_3 \geq \left\{ \begin{array}{l} 0.05 t_m \\ 0.1 h \end{array} \right\}$ whichever is greater | Figure NB-5544.1(c)-1                                        | $0.05 t_m = 0.087$ in.<br>$0.01 h = 0.0871$                   | $r_3 = 0.187$ in.                                |
| Body primary and secondary stress                                                               | NB-3545                                                      |                                                               |                                                  |
| $P_m = \left( \frac{A_f}{A_m} + 0.5 \right) P_s$                                                | NB-3545.1(a)(2)                                              |                                                               |                                                  |
| Inlet end                                                                                       | $S_m \geq P_m$ at 500°F                                      | $S_m = 18,900$ psi at 500°F                                   | $P_m = 11,374$ psi                               |
| Outlet end                                                                                      |                                                              | $S_m = 18,900$ psi at 500°F                                   | $P_m = 11,374$ psi                               |
| Valve disc seat ring analysis                                                                   | NB-3546.2                                                    |                                                               |                                                  |
| $P_m \leq 1.0 S_m$                                                                              | Acceptable structural analysis method                        | $1.0 S_m = 18,900$ psi at 500°F                               | $P_m = 16,517$ psi                               |
| $S_{max} \leq 1.5 S_m$                                                                          |                                                              | $1.5 S_m = 28,350$ psi at 500°F                               | $S_{max} = 18,675$ psi                           |

HNP-2-FSAR-3

**TABLE 3.9-38 (SHEET 3 OF 5)**

3. Structural analysis for  
other valve parts (NB-3546.3)

| <u>Stress Category</u> | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u> | <u>Allowable Stress<br/>or Design Value<br/>(psi)</u> | <u>Calculated Stress<br/>or Actual Value<br/>(psi)</u> |
|------------------------|--------------------------------------------------------------|-------------------------------------------------------|--------------------------------------------------------|
| Stem thrust stress     | Calculate stress due to operator thrust                      | $S_m = 26,700$ at 500°F                               | $S_T = 20,300$                                         |
| Stem torque stress     | Calculate stress due to operator torque                      | $0.6 S_m = 16,020$ at 500°F                           | $S_S = 10,600$                                         |
| Gasket seating stress  | Acceptable stress analysis method                            | $1.5 S_m = 28,300$ at 500°F                           | $S = 13,500$                                           |
| Bonnet                 | Calculate stress due to pressure                             | $S_m = 16,200$ at 500°F                               | $S = 11,005$                                           |
| Protective ring        | Calculate stress due to pressure                             | $S_m = 44,100$ at 500°F                               | $S = 9030$                                             |
| Eyebolt                | Calculate stress due to pressure                             | $S_m = 7000$ at 500°F                                 | $S = 6821$                                             |

HNP-2-FSAR-3

**TABLE 3.9-38 (SHEET 4 OF 5)**

4. Cyclic loading requirements

| <u>Stress Category</u>                                 | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u>    | <u>Allowable Stress<br/>or Minimum<br/>Dimension Required<br/>(psi)</u> | <u>Calculated Stress<br/>or Actual Dimension<br/>(psi)</u> |
|--------------------------------------------------------|-----------------------------------------------------------------|-------------------------------------------------------------------------|------------------------------------------------------------|
| Secondary stress due to pipe reaction                  | NB-3545.2(b)                                                    |                                                                         |                                                            |
| $P_{ed} = \frac{F_d S}{G_d}$                           | NB-3545.2(b)(1)<br>Figures NB-3545.2-2, 3<br>NB-3545.2(b)(1)    | 1.5 S <sub>m</sub> = 29,100 at 500°F                                    | P <sub>ed</sub> = 4231                                     |
| $P_{eb} = C_b \frac{F_b S}{G_b}$                       | Figures NB-3545.2-4, 5<br>Figure NB-3545.2-6<br>NB-3545.2(b)(5) | 1.5 S <sub>m</sub> = 29,100 at 500°F                                    | P <sub>eb</sub> = 8605                                     |
| $P_{et} = 2 \frac{F_b S}{G_t}$                         | NB-3545.2(b)(1)<br>NB-3545.2(b)(6)(c)                           | 1.5 S <sub>m</sub> = 29,100 at 500°F                                    | P <sub>et</sub> = 8605                                     |
| Primary plus secondary stress due to internal pressure | NB-3545.2(a)(1)                                                 |                                                                         |                                                            |
| $Q_p = C_p \left( \frac{r_i}{t_e} + 0.5 \right) P_s$   | Figure NB-3545.1-1<br>Figure NB-3545.1(a)-1                     | No limit required                                                       | Q <sub>p</sub> = 10,838                                    |
| Thermal secondary stress at inlet and outlet crotch    | NB-3545.2(c)                                                    |                                                                         |                                                            |
| Q <sub>T1</sub>                                        | Figures                                                         | No limit required                                                       | Q <sub>T1</sub> = NA <sup>(a)</sup>                        |
| Q <sub>T2</sub>                                        | NB-3545.2(c)-2, 3                                               | No limit required                                                       | Q <sub>T2</sub> = 141.69                                   |
| Q <sub>T3</sub>                                        | NB-3545.2(c)-4, 5                                               | No limit required                                                       | Q <sub>T3</sub> = 163.73                                   |

**TABLE 3.9-38 (SHEET 5 OF 5)**

4. Cyclic loading requirements (cont)

| <u>Stress Category</u>                                               | <u>ASME Section III Reference Method of Analysis</u> | <u>Allowable Stress or Minimum Dimension Required (psi)</u> | <u>Calculated Stress or Actual Dimension (psi)</u> |
|----------------------------------------------------------------------|------------------------------------------------------|-------------------------------------------------------------|----------------------------------------------------|
| Valve body secondary stress criteria at crotch region                | NB-3545.2                                            |                                                             |                                                    |
| $S_n = Q_p + P_{ed} + 2Q_{T_2} \leq 3S_m$                            |                                                      | $3 S_m = 56,700$ at 500°F                                   | $S_n = 24,912$                                     |
| Normal-duty valve fatigue requirements                               | NB-3545.3<br>NB-3550                                 |                                                             |                                                    |
| $S_{P_1} = \frac{2}{3}Q_p + \frac{P_{eb}}{2} + Q_{T_3} + 1.3Q_{T_1}$ | NB-3545.3(a)                                         | No limit required                                           | $S_{P_1} = 19,690$                                 |
| $S_{P_2} = 0.4 Q_P + P_{eb} + 2Q_{T_3}$                              | NB-3545.3(a)                                         | No limit required                                           | $S_{P_2} = 17,090$                                 |
|                                                                      | S = Figure I-9-1                                     |                                                             | $S_A = 19,690$                                     |
| $N_a \geq 2000$ cycles                                               | $N_a =$ Figure I-9-1                                 | 2000 cycles                                                 | $N_a = 100,000$ cycles                             |
| Cyclic stress calculation                                            | NB-3554                                              |                                                             |                                                    |
| $Q_P + P_{ed} + C_6 C_2 C_4 \Delta T_{f(max)} \leq 3S_m$             | NB-3554(a)                                           | $3 S_m = 56,700$ at 500°F                                   | $S_{nc} = 24,629$                                  |
| $Q_P + P_{eb} + C_6 C_3 C_4 \Delta T_{f(max)} \leq 3S_m$             | NB-3554(b)                                           | $3 S_m = 56,700$ at 500°F                                   | $S_{n max} = 29,003$                               |
| $S_i = \frac{4}{3}Q_p + P_{eb} + C_6(C_3 C_4 + C_5)\Delta T_{fi}$    | $N_i =$ Figure I-9-1                                 | $\sum \frac{N_{ri}}{N_i} \leq 1.0$                          | $\sum \frac{N_{ri}}{N_i} = 0.8458$                 |

a. Not applicable.



HNP-2-FSAR-3

TABLE 3.9-39 (SHEET 1 OF 5)

RHR PUMP SUCTION 24-in. ANGLE VALVE

1. Seismic analysis (NB-3524)

| <u>Valve Critical Sections</u> | <u>Method of Analysis</u>                                                                                               | <u>Limit</u>             | Minimum Required<br>( $G/f_n$ ) | Calculated<br>( $G_{sm}/f_n$ ) |
|--------------------------------|-------------------------------------------------------------------------------------------------------------------------|--------------------------|---------------------------------|--------------------------------|
| Motor/yoke bolting             | Calculate static acceleration ( $G_{sm}$ ) that will make sum of bending stress plus thrust stress at section = $S_m$ . | $G_{sm} > 3.0 \text{ g}$ | 3.0                             | 41.0                           |
| Yoke arm                       |                                                                                                                         |                          | 3.0                             | Upper - 308.0<br>Lower - 47.4  |
| Yoke/bonnet bolting            |                                                                                                                         |                          | 3.0                             | 15.1                           |
| Body neck                      |                                                                                                                         |                          | 3.0                             | 30.0                           |
| Natural frequency              | Three lumped-mass cantilever beam analyzed by matrix iteration method.                                                  | $f_n > 20$               | 20.0                            | 28.0                           |

HNP-2-FSAR-3

**TABLE 3.9-39 (SHEET 2 OF 5)**

2. Design of pressure-retaining parts

| <u>Stress Category</u>                                                                        | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u> | <u>Allowable Stress<br/>or Minimum<br/>Dimension Required</u> | <u>Calculated Stress<br/>or Actual Dimension</u> |
|-----------------------------------------------------------------------------------------------|--------------------------------------------------------------|---------------------------------------------------------------|--------------------------------------------------|
| Minimum wall thickness                                                                        | NB-3541                                                      |                                                               |                                                  |
| $t_m \leq t_e$                                                                                | NB-3542.1                                                    | $t_m = 1.54$ in.                                              | $t_e = 2.375$ in.                                |
| for $d'_m \geq 1.5 d_m$                                                                       | NB-3542.2                                                    | $1.5 d_m = 31.875$ in.                                        | $d'_m = 22.252$ in.                              |
| Radius of crotch                                                                              |                                                              |                                                               |                                                  |
| $r_2 \geq 0.3 t_m$                                                                            | $r_2 =$ NB-3544.1(a)                                         | $0.3 t_m = 0.462$ in.                                         | $r_2 = 4.0$ in.                                  |
| $r_3 \geq \left\{ \begin{array}{l} 0.05t_m \\ 0.1h \end{array} \right\}$ whichever is greater |                                                              | $0.05 t_m = 0.077$ in.<br>$0.10 h = 0.1625$                   | $r_3 = 0.187$ in.                                |
| Body primary and secondary stress                                                             | NB-3545                                                      |                                                               |                                                  |
| $P_m = \left( \frac{A_f}{A_m} + 0.5 \right) P_s$                                              | NB-3545.1(a)(2)                                              |                                                               |                                                  |
| Inlet end                                                                                     | $S_m \geq P_m$ at 500°F                                      | $S_m = 18,900$ psi at 500°F                                   | $P_m = 9264$ psi                                 |
| Outlet end                                                                                    |                                                              | $S_m = 18,900$ psi at 500°F                                   | $P_m = 9264$ psi                                 |
| Valve disc seat ring analysis                                                                 | NB-3546.2                                                    |                                                               |                                                  |
| $P_m \leq 1.0 S_m$                                                                            | Acceptable structural analysis method                        | $1.0 S_m = 17,900$ psi at 500°F                               | $P_m = 7966$ psi                                 |
| $S_{max} \leq 1.5 S_m$                                                                        |                                                              | $1.5 S_m = 26,850$ psi at 500°F                               | $S_{max} = 16,010$ psi                           |

HNP-2-FSAR-3

**TABLE 3.9-39 (SHEET 3 OF 5)**

3. Structural analysis for  
other valve parts (NB-3546.3)

| <u>Stress Category</u>               | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u> | <u>Allowable Stress<br/>or Design Value<br/>(psi)</u> | <u>Calculated Stress<br/>or Actual Value<br/>(psi)</u> |
|--------------------------------------|--------------------------------------------------------------|-------------------------------------------------------|--------------------------------------------------------|
| Stem thrust stress                   | Calculate stress due to operator thrust                      | $S_m = 17,900$ at 500°F                               | $S_T = 17,900$                                         |
| Stem torque stress                   | Calculate stress due to operator torque                      | $0.6 S_m = 10,740$ at 500°F                           | $S_S = 7639$                                           |
| Gasket seating stress                | Acceptable stress analysis method                            | $1.5 S_m = 35,000$ at 500°F                           | $S = 8710$                                             |
| Bonnet stress at gasket bearing area | Calculate stress due to pressure                             | $S_m = 16,200$ at 500°F                               | $S = 10,874$                                           |
| Protective ring                      | Calculate stress due to pressure                             | $S_m = 44,100$ at 500°F                               | $S = 5914$                                             |
| Eyebolt                              | Calculate stress due to pressure                             | $S_m = 15,000$ at 500°F                               | $S = 11,692$                                           |

HNP-2-FSAR-3

**TABLE 3.9-39 (SHEET 4 OF 5)**

4. Cyclic loading requirements

| <u>Stress Category</u>                                 | <u>ASME Section III Reference Method of Analysis</u>            | <u>Allowable Stress or Minimum Dimension Required (psi)</u> | <u>Calculated Stress or Actual Dimension (psi)</u> |
|--------------------------------------------------------|-----------------------------------------------------------------|-------------------------------------------------------------|----------------------------------------------------|
| Secondary stress due to pipe reaction                  | NB-3545.2(b)                                                    |                                                             |                                                    |
| $P_{ed} = \frac{F_d S}{G_d}$                           | NB-3545.2(b)(1)<br>Figures NB-3545.2-2, 3<br>NB-3545.2(b)(1)    | $1.5 S_m = 28,350$ at 500°F                                 | $P_{ed} = 4275$                                    |
| $P_{eb} = C_b \frac{F_b S}{G_b}$                       | Figures NB-3545.2-4, 5<br>Figure NB-3545.2-6<br>NB-3545.2(b)(5) | $1.5 S_m = 28,350$ at 500°F                                 | $P_{eb} = 8105$                                    |
| $P_{et} = 2 \frac{F_b S}{G_t}$                         | NB-3545.2(b)(1)<br>NB-3545.2(b)(6)(c)                           | $1.5 S_m = 28,350$ at 500°F                                 | $P_{et} = 8601$                                    |
| Primary plus secondary stress due to internal pressure | NB-3545.2(a)(1)                                                 |                                                             |                                                    |
| $Q_p = C_p \left( \frac{r_i}{t_e} + 0.5 \right) P_s$   | Figure NB-3545.1-1<br>Figure NB-3545.1(a)-1                     | No limit required                                           | $Q_p = 22,568$                                     |
| Thermal secondary stress at inlet and outlet crotch    | NB-3545.2(c)                                                    |                                                             |                                                    |
| $Q_{T_1}$                                              | Figures                                                         | No limit required                                           | $Q_{T_1} = 1600$                                   |
| $Q_{T_2}$                                              | NB-3545.2(c)-2, 3                                               | No limit required                                           | $Q_{T_2} = 334$                                    |
| $Q_{T_3}$                                              | NB-3545.2(c)-4, 5                                               | No limit required                                           | $Q_{T_3} = 460$                                    |

HNP-2-FSAR-3

**TABLE 3.9-39 (SHEET 5 OF 5)**

4. Cyclic loading requirements (cont)

| <u>Stress Category</u>                                                | <u>ASME Section III Reference Method of Analysis</u> | <u>Allowable Stress or Minimum Dimension Required (psi)</u> | <u>Calculated Stress or Actual Dimension (psi)</u> |
|-----------------------------------------------------------------------|------------------------------------------------------|-------------------------------------------------------------|----------------------------------------------------|
| Valve body secondary stress criteria at crotch region                 | NB-3545.2                                            |                                                             |                                                    |
| $S_n = Q_p + P_{ed} + 2Q_{T_2} \leq 3S_m$                             |                                                      | $3 S_m = 56,700$ at 500°F                                   | $S_n = 27,510$                                     |
| Normal-duty valve fatigue requirements                                | NB-3545.3<br>NB-3550                                 |                                                             |                                                    |
| $S_{P_1} = \frac{2}{3} Q_p + \frac{P_{eb}}{2} + Q_{T_3} + 1.3Q_{T_1}$ | NB-3545.3(a)                                         | No limit required                                           | $S_{P_1} = 21,630$                                 |
| $S_{P_2} = 0.4 Q_p + P_{eb} + 2Q_{T_3}$                               | NB-3545.3(a)                                         | No limit required                                           | $S_{P_2} = 18,052$<br>$S_A = 21,638$               |
| $N_a \geq 2000$ cycles                                                | $N_a =$ Figure I-9-1                                 | 2000 cycles                                                 | $N_a = 70,000$ cycles                              |
| Cyclic stress calculation                                             | NB-3554                                              |                                                             |                                                    |
| $Q_p + P_{ed} + C_6 C_2 C_4 \Delta T_{f(max)} \leq 3S_m$              | NB-3554(a)                                           | $3 S_m = 56,500$ at 500°F                                   | $S_{nc} = 44,016$                                  |
| $Q_p + P_{eb} + C_6 C_3 C_4 \Delta T_{f(max)} \leq 3S_m$              | NB-3554(b)                                           | $3 S_m = 56,700$ at 500°F                                   | $S_{n max} = 54,327$                               |
| $S_i = \frac{4}{3} Q_p + P_{eb} + C_6 (C_3 C_4 + C_5) \Delta T_{fi}$  | $N_i =$ Figure I-9-1                                 | $\sum \frac{N_{ri}}{N_i} \leq 1.0$                          | $\sum \frac{N_{ri}}{N_i} = 0.4992$                 |

HNP-2-FSAR-3

TABLE 3.9-40 (SHEET 1 OF 5)

RHR PUMP SUCTION 24-in. GATE VALVE

1. Seismic analysis (NB-3524)

| <u>Valve Critical Sections</u> | <u>Method of Analysis</u>                                                                                               | <u>Limit</u>             | Minimum<br>Required<br>( $G/f_n$ ) | Calculated<br>( $G_{sm}/f_n$ ) |
|--------------------------------|-------------------------------------------------------------------------------------------------------------------------|--------------------------|------------------------------------|--------------------------------|
| Motor/yoke bolting             | Calculate static acceleration ( $G_{sm}$ ) that will make sum of bending stress plus thrust stress at section = $S_m$ . | $G_{sm} > 3.0 \text{ g}$ | 3.0                                | 4.53                           |
| Yoke arm                       |                                                                                                                         |                          | 3.0                                | 56.7                           |
| Motor yoke bolting             |                                                                                                                         |                          | 3.0                                | 8.7                            |
| Yoke/bonnet bolting            |                                                                                                                         |                          | 3.0                                | 18.4                           |
| Body neck                      |                                                                                                                         |                          | 3.0                                | 91.7                           |
| Natural frequency              | Three lumped-mass cantilever beam analyzed by matrix iteration method.                                                  | $f_n > 20$               | 20.0                               | 29.9                           |

HNP-2-FSAR-3

**TABLE 3.9-40 (SHEET 2 OF 5)**

2. Design of pressure-retaining parts

| <u>Stress Category</u>                                                                          | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u> | <u>Allowable Stress<br/>or Minimum<br/>Dimension Required</u> | <u>Calculated Stress<br/>or Actual Dimension</u> |
|-------------------------------------------------------------------------------------------------|--------------------------------------------------------------|---------------------------------------------------------------|--------------------------------------------------|
| Minimum wall thickness                                                                          | NB-3541                                                      |                                                               |                                                  |
| $t_m \leq t_e$                                                                                  | NB-3542.1                                                    | $t_m = 2.272$ in.                                             | $t_e = 3.157$ in.                                |
| for $d'_m \geq 1.5 d_m$                                                                         | NB-3542.2                                                    | $1.5 d_m = 31.4$ in.                                          | $d'_m = 26.625$ in.                              |
| Radius of crotch                                                                                |                                                              |                                                               |                                                  |
| $r_2 \geq 0.3 t_m$                                                                              | $r_2 =$ NB-3544.1(a)                                         | $0.3 t_m = 0.602$ in.                                         | $r_2 = 6.0$ in.                                  |
| $r_3 \geq \left\{ \begin{array}{l} 0.05 t_m \\ 0.1 h \end{array} \right\}$ whichever is greater |                                                              | $0.05 t_m = 0.1137$ in.<br>$0.10 h = 0.1888$                  | $r_3 = 0.25$ in.                                 |
| Body primary and secondary stress                                                               | NB-3545                                                      |                                                               |                                                  |
| $P_m = \left( \frac{A_f}{A_m} + 0.5 \right) P_s$                                                | NB-3545.1(a)(2)                                              |                                                               |                                                  |
| Inlet end                                                                                       | $S_m \geq P_m$ at 500°F                                      | $S_m = 19,400$ psi at 500°F                                   | $P_m = 9541$ psi                                 |
| Outlet end                                                                                      |                                                              | $S_m = 19,400$ psi at 500°F                                   | $P_m = 9541$ psi                                 |
| Valve disc seat ring analysis                                                                   | NB-3546.2                                                    |                                                               |                                                  |
| $P_m \leq 1.0 S_m$                                                                              | Acceptable structural analysis method                        | $1.0 S_m = 19,400$ psi at 500°F                               | $P_m = 16,332$ psi                               |
| $S_{max} \leq 1.5 S_m$                                                                          |                                                              | $1.5 S_m = 29,100$ psi at 500°F                               | $S_{max} = 13,478$ psi                           |

HNP-2-FSAR-3

**TABLE 3.9-40 (SHEET 3 OF 5)**

3. Structural analysis for  
other valve parts (NB-3546.3)

| <u>Stress Category</u> | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u> | <u>Allowable Stress<br/>or Design Value<br/>(psi)</u> | <u>Calculated Stress<br/>or Actual Value<br/>(psi)</u> |
|------------------------|--------------------------------------------------------------|-------------------------------------------------------|--------------------------------------------------------|
| Stem thrust stress     | Calculate stress due to operator thrust                      | $S_m = 26,700$ at 500°F                               | $S_T = 22,845$                                         |
| Stem torque stress     | Calculate stress due to operator torque                      | $0.6 S_m = 16,020$ at 500°F                           | $S_S = 825$                                            |
| Gasket seating stress  | Acceptable stress analysis method                            | $1.5 S_m = 28,300$ at 500°F                           | $S = 17,666$                                           |
| Bonnet                 | Calculate stress due to pressure                             | $S_m = 19,400$ at 500°F                               | $S = 3110$                                             |
| Protective ring        | Calculate stress due to pressure                             | $S_m = 26,700$ at 500°F                               | $S = 17,837$                                           |
| Eyebolt                | Calculate stress due to pressure                             | $S_m = 7000$ at 500°F                                 | $S = 6147$                                             |



HNP-2-FSAR-3

**TABLE 3.9-40 (SHEET 4 OF 5)**

4. Cyclic loading requirements

| <u>Stress Category</u>                                 | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u>    | <u>Allowable Stress<br/>or Minimum<br/>Dimension Required<br/>(psi)</u> | <u>Calculated Stress<br/>or Actual Dimension<br/>(psi)</u> |
|--------------------------------------------------------|-----------------------------------------------------------------|-------------------------------------------------------------------------|------------------------------------------------------------|
| Secondary stress due to pipe reaction                  | NB-3545.2(b)                                                    |                                                                         |                                                            |
| $P_{ed} = \frac{F_d S}{G_d}$                           | NB-3545.2(b)(1)<br>Figures NB-3545.2-2, 3<br>NB-3545.2(b)(1)    | 1.5 S <sub>m</sub> = 29,100 at 500°F                                    | P <sub>ed</sub> = 5553                                     |
| $P_{eb} = C_b \frac{F_b S}{G_b}$                       | Figures NB-3545.2-4, 5<br>Figure NB-3545.2-6<br>NB-3545.2(b)(5) | 1.5 S <sub>m</sub> = 29,100 at 500°F                                    | P <sub>eb</sub> = 12,124                                   |
| $P_{et} = 2 \frac{F_b S}{G_t}$                         | NB-3545.2(b)(1)<br>NB-3545.2(b)(6)(c)                           | 1.5 S <sub>m</sub> = 29,100 at 500°F                                    | P <sub>et</sub> = 12,144                                   |
| Primary plus secondary stress due to internal pressure | NB-3545.2(a)(1)                                                 |                                                                         |                                                            |
| $Q_p = C_p \left( \frac{r_i}{t_e} + 0.5 \right) P_s$   | Figure NB-3545.1-1<br>Figure NB-3545.1(a)-1                     | No limit required                                                       | Q <sub>p</sub> = 26,774                                    |
| Thermal secondary stress at inlet and outlet crotch    | NB-3545.2(c)                                                    |                                                                         |                                                            |
| Q <sub>T1</sub>                                        | Figures                                                         | No limit required                                                       | Q <sub>T1</sub> = 2650                                     |
| Q <sub>T2</sub>                                        | NB-3545.2(c)-2, 3                                               | No limit required                                                       | Q <sub>T2</sub> = 561                                      |
| Q <sub>T3</sub>                                        | NB-3545.2(c)-4, 5                                               | No limit required                                                       | Q <sub>T3</sub> = 822                                      |

**TABLE 3.9-40 (SHEET 5 OF 5)**

4. Cyclic loading requirements (cont)

| <u>Stress Category</u>                                               | <u>ASME Section III Reference Method of Analysis</u> | <u>Allowable Stress or Minimum Dimension Required (psi)</u> | <u>Calculated Stress or Actual Dimension (psi)</u> |
|----------------------------------------------------------------------|------------------------------------------------------|-------------------------------------------------------------|----------------------------------------------------|
| Valve body secondary stress criteria at crotch region                | NB-3545.2                                            |                                                             |                                                    |
| $S_n = Q_p + P_{ed} + 2Q_{T_2} \leq 3S_m$                            |                                                      | $3 S_m = 58,200$ at 500°F                                   | $S_n = 33,450$                                     |
| Normal-duty valve fatigue requirements                               | NB-3545.3<br>NB-3550                                 |                                                             |                                                    |
| $S_{P_1} = \frac{2}{3}Q_p + \frac{P_{eb}}{2} + Q_{T_3} + 1.3Q_{T_1}$ | NB-3545.3(a)                                         | No limit required                                           | $S_{P_1} = 28,178$                                 |
| $S_{P_2} = 0.4 Q_P + P_{eb} + 2Q_{T_3}$                              | NB-3545.3(a)                                         | No limit required                                           | $S_{P_2} = 24,478$                                 |
|                                                                      |                                                      |                                                             | $S_A = 28,178$                                     |
| $N_a \geq 2000$ cycles                                               | $N_a =$ Figure I-9-1                                 | 2000 cycles                                                 | $N_a = 30,000$ cycles                              |
| Cyclic stress calculation                                            | NB-3554                                              |                                                             |                                                    |
| $Q_P + P_{ed} + C_6C_2C_4\Delta T_{f(max)} \leq 3S_m$                | NB-3554(a)                                           | $3 S_m = 58,200$ at 500°F                                   | $S_{nc} = 44,199$                                  |
| $Q_P + P_{eb} + C_6C_3C_4\Delta T_{f(max)} \leq 3S_m$                | NB-3554(b)                                           | $3 S_m = 58,200$ at 500°F                                   | $S_{n max} = 56,293$                               |
| $S_i = \frac{4}{3}Q_p + P_{eb} + C_6(C_3C_4 + C_5)\Delta T_{fi}$     | $N_i =$ Figure I-9-1                                 | $\sum \frac{N_{ri}}{N_i} \leq 1.0$                          | $\sum \frac{N_{ri}}{N_i} = 0.3246$                 |

HNP-2-FSAR-3

**TABLE 3.9-41 (SHEET 1 OF 5)**

**RWC 6-in. GATE VALVE**

1. Seismic analysis (NB-3524)

| <u>Valve Critical Sections</u> | <u>Method of Analysis</u>                                                                                               | <u>Limit</u>             | Minimum Required<br>( $G/f_n$ ) | Calculated<br>( $G_{sm}/f_n$ ) |
|--------------------------------|-------------------------------------------------------------------------------------------------------------------------|--------------------------|---------------------------------|--------------------------------|
| Motor/yoke bolting             | Calculate static acceleration ( $G_{sm}$ ) that will make sum of bending stress plus thrust stress at section = $S_m$ . | $G_{sm} > 3.0 \text{ g}$ | 3.0                             | 93.5                           |
| Yoke arm                       |                                                                                                                         |                          | 3.0                             | 79.2                           |
| Yoke/bonnet bolting            |                                                                                                                         |                          | 3.0                             | 29.2                           |
| Body neck                      |                                                                                                                         |                          | 3.0                             | 92.9                           |
| Natural frequency              | Three lumped-mass cantilever beam analyzed by matrix iteration method.                                                  | $f_n > 20$               | 20.0                            | 18.97                          |

HNP-2-FSAR-3

**TABLE 3.9-41 (SHEET 2 OF 5)**

2. Design of pressure-retaining parts

| <u>Stress Category</u>                                                    | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u> | <u>Allowable Stress<br/>or Minimum<br/>Dimension Required</u> | <u>Calculated Stress<br/>or Actual Dimension</u> |
|---------------------------------------------------------------------------|--------------------------------------------------------------|---------------------------------------------------------------|--------------------------------------------------|
| Minimum wall thickness                                                    | NB-3541                                                      |                                                               |                                                  |
| $t_m \leq t_e$                                                            | NB-3542.1                                                    | $t_m = 0.71$ in.                                              | $t_e = 1.063$ in.                                |
| for $d'_m \geq 1.5 d_m$                                                   | NB-3542.2                                                    | $1.5 d_m = 8.625$ in.                                         | $d'_m = 7.75$ in.                                |
| Radius of crotch                                                          |                                                              |                                                               |                                                  |
| $r_2 \geq 0.3 t_m$                                                        | $r_2 =$ NB-3544.1(a)                                         | $0.3 t_m = 0.213$ in.                                         | $r_2 = 2.0$ in.                                  |
| $r_3 \geq \begin{cases} 0.05t_m \\ 0.1h \end{cases}$ whichever is greater |                                                              | $0.05 t_m = 0.05$ in.                                         | $r_3 = 0.125$ in.                                |
| Body primary and secondary stress                                         | NB-3545                                                      |                                                               |                                                  |
| $P_m = \left( \frac{A_f}{A_m} + 0.5 \right) P_s$                          | NB-3545.1(a)(2)                                              |                                                               |                                                  |
| Inlet end                                                                 | $S_m \geq P_m$ at 500°F                                      | $S_m = 19,600$ psi at 500°F                                   | $P_m = 4510$ psi                                 |
| Outlet end                                                                |                                                              | $S_m = 19,600$ psi at 500°F                                   | $P_m = 4510$ psi                                 |
| Valve disc seat ring analysis                                             | NB-3546.2                                                    |                                                               |                                                  |
| $P_m \leq 1.0 S_m$                                                        | Acceptable structural analysis method                        | $1.0 S_m = 19,600$ psi at 500°F                               | $P_m = 8489$ psi                                 |
| $S_{max} \leq 1.5 S_m$                                                    |                                                              | $1.5 S_m = 29,400$ psi at 500°F                               | $S_{max} = NA^{(a)}$                             |

HNP-2-FSAR-3

**TABLE 3.9-41 (SHEET 3 OF 5)**

3. Structural analysis for  
other valve parts (NB-3546.3)

| <u>Stress Category</u>     | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u> | <u>Allowable Stress<br/>or Design Value<br/>(psi)</u> | <u>Calculated Stress<br/>or Actual Value<br/>(psi)</u> |
|----------------------------|--------------------------------------------------------------|-------------------------------------------------------|--------------------------------------------------------|
| Stem thrust stress         | Calculate stress due to operator thrust                      | $S_m = 26,700$ at 500°F                               | $S_T = 5330$                                           |
| Stem torque stress         | Calculate stress due to operator torque                      | $0.6 S_m = 16,020$ at 500°F                           | $S_S = 255$                                            |
| Gasket seating stress      | Acceptable stress analysis method                            | $1.5 S_m = 28,300$ at 500°F                           | $S = 7525$                                             |
| Bonnet gasket bearing area | Calculate stress due to pressure                             | $S_m = 17,900$ at 500°F                               | $S = 2445$                                             |
| Protective ring            | Calculate stress due to pressure                             | $S_m = 26,700$ at 500°F                               | $S = 9549$                                             |
| Eyebolt                    | Calculate stress due to pressure                             | $S_m = 15,000$ at 500°F                               | $S = 6297$                                             |

**TABLE 3.9-41 (SHEET 4 OF 5)**

4. Cyclic loading requirements

| <u>Stress Category</u>                                 | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u>    | <u>Allowable Stress<br/>or Minimum<br/>Dimension Required<br/>(psi)</u> | <u>Calculated Stress<br/>or Actual Dimension<br/>(psi)</u> |
|--------------------------------------------------------|-----------------------------------------------------------------|-------------------------------------------------------------------------|------------------------------------------------------------|
| Secondary stress due to pipe reaction                  | NB-3545.2(b)                                                    |                                                                         |                                                            |
| $P_{ed} = \frac{F_d S}{G_d}$                           | NB-3545.2(b)(1)<br>Figures NB-3545.2-2, 3<br>NB-3545.2(b)(1)    | 1.5 S <sub>m</sub> = 29,400 at 500°F                                    | P <sub>ed</sub> = 4435                                     |
| $P_{eb} = C_b \frac{F_b S}{G_b}$                       | Figures NB-3545.2-4, 5<br>Figure NB-3545.2-6<br>NB-3545.2(b)(5) | 1.5 S <sub>m</sub> = 29,400 at 500°F                                    | P <sub>eb</sub> = 8445                                     |
| $P_{et} = 2 \frac{F_b S}{G_t}$                         | NB-3545.2(b)(1)<br>NB-3545.2(b)(6)(c)                           | 1.5 S <sub>m</sub> = 29,400 at 500°F                                    | P <sub>et</sub> = 9334                                     |
| Primary plus secondary stress due to internal pressure | NB-3545.2(a)(1)                                                 |                                                                         |                                                            |
| $Q_p = C_p \left( \frac{r_i}{t_e} + 0.5 \right) P_s$   | Figure NB-3545.1-1<br>Figure NB-3545.1(a)-1                     | No limit required                                                       | Q <sub>p</sub> = 14,887                                    |
| Thermal secondary stress at inlet and outlet crotch    | NB-3545.2(c)                                                    |                                                                         |                                                            |
| Q <sub>T1</sub>                                        | Figures                                                         | No limit required                                                       | Q <sub>T1</sub> = NA <sup>(a)</sup>                        |
| Q <sub>T2</sub>                                        | NB-3545.2(c)-2, 3                                               | No limit required                                                       | Q <sub>T2</sub> = 587                                      |
| Q <sub>T3</sub>                                        | NB-3545.2(c)-4, 5                                               | No limit required                                                       | Q <sub>T3</sub> = 979                                      |

HNP-2-FSAR-3

**TABLE 3.9-41 (SHEET 5 OF 5)**

4. Cyclic loading requirements (cont)

| <u>Stress Category</u>                                                | <u>ASME Section III Reference Method of Analysis</u> | <u>Allowable Stress or Minimum Dimension Required (psi)</u> | <u>Calculated Stress or Actual Dimension (psi)</u> |
|-----------------------------------------------------------------------|------------------------------------------------------|-------------------------------------------------------------|----------------------------------------------------|
| Valve body secondary stress criteria at crotch region                 | NB-3545.2                                            |                                                             |                                                    |
| $S_n = Q_p + P_{ed} + 2Q_{T_2} \leq 3S_m$                             |                                                      | $3 S_m = 58,800$ at 500°F                                   | $S_n = 20,497$                                     |
| Normal-duty valve fatigue requirements                                | NB-3545.3<br>NB-3550                                 |                                                             |                                                    |
| $S_{P_1} = \frac{2}{3} Q_p + \frac{P_{eb}}{2} + Q_{T_3} + 1.3Q_{T_1}$ | NB-3545.3(a)                                         | No limit required                                           | $S_{P_1} = 17,726$                                 |
| $S_{P_2} = 0.4 Q_p + P_{eb} + 2Q_{T_3}$                               | NB-3545.3(a)                                         | No limit required                                           | $S_{P_2} = 16,359$<br>$S_A = 17,726$               |
| $N_a \geq 2000$ cycles                                                | $N_a =$ Figure I-9-1                                 | 2000 cycles                                                 | $N_a = 300,000$ cycles                             |
| Cyclic stress calculation                                             | NB-3554                                              |                                                             |                                                    |
| $Q_p + P_{ed} + C_6 C_2 C_4 \Delta T_{f(max)} \leq 3S_m$              | NB-3554(a)                                           | $3 S_m = 58,800$ at 500°F                                   | $S_{nc} = 47,828$                                  |
| $Q_p + P_{eb} + C_6 C_3 C_4 \Delta T_{f(max)} \leq 3S_m$              | NB-3554(b)                                           | $3 S_m = 58,800$ at 500°F                                   | $S_{n max} = 70,843$                               |
| $S_i = \frac{4}{3} Q_p + P_{eb} + C_6 (C_3 C_4 + C_5) \Delta T_{fi}$  | $N_i =$ Figure I-9-1                                 | $\sum \frac{N_{ri}}{N_i} \leq 1.0$                          | $\sum \frac{N_{ri}}{N_i} = NA^{(a)}$               |

a. NA - not applicable.

HNP-2-FSAR-3

TABLE 3.9-42 (SHEET 1 OF 5)

RHR PUMP DISCHARGE 20-in. GATE VALVE

1. Seismic analysis (NB-3524)

| <u>Valve Critical Sections</u> | <u>Method of Analysis</u>                                                                                               | <u>Limit</u>             | Minimum Required<br>( $G/f_n$ ) | Calculated<br>( $G_{sm}/f_n$ ) |
|--------------------------------|-------------------------------------------------------------------------------------------------------------------------|--------------------------|---------------------------------|--------------------------------|
| Motor/yoke bolting             | Calculate static acceleration ( $G_{sm}$ ) that will make sum of bending stress plus thrust stress at section = $S_m$ . | $G_{sm} > 3.0 \text{ g}$ | 3.0                             | 48.5                           |
| Yoke arm                       |                                                                                                                         |                          | 3.0                             | 139.6                          |
| Yoke/bonnet bolting            |                                                                                                                         |                          | 3.0                             | 45.3                           |
| Body neck                      |                                                                                                                         |                          | 3.0                             | 145.4                          |
| Natural frequency              | Three lumped-mass cantilever beam analyzed by matrix iteration method.                                                  | $f_n > 20$               | 20.0                            | 44.8                           |



HNP-2-FSAR-3

**TABLE 3.9-42 (SHEET 2 OF 5)**

2. Design of pressure-retaining parts

| <u>Stress Category</u>                                                                          | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u> | <u>Allowable Stress<br/>or Minimum<br/>Dimension Required</u> | <u>Calculated Stress<br/>or Actual Dimension</u> |
|-------------------------------------------------------------------------------------------------|--------------------------------------------------------------|---------------------------------------------------------------|--------------------------------------------------|
| Minimum wall thickness                                                                          | NB-3541                                                      |                                                               |                                                  |
| $t_m \leq t_e$                                                                                  | NB-3542.1                                                    | $t_m = 1.898$ in.                                             | $t_e = 2.91$ in.                                 |
| for $d'_m \geq 1.5 d_m$                                                                         | NB-3542.2                                                    | $1.5 d_m = 26.06$ in.                                         | $d'_m = 22.5$ in.                                |
| Radius of crotch                                                                                |                                                              |                                                               |                                                  |
| $r_2 \geq 0.3 t_m$                                                                              | $r_2 =$ NB-3544.1(a)                                         | $0.3 t_m = 0.57$ in.                                          | $r_2 = 5.0$ in.                                  |
| $r_3 \geq \left\{ \begin{array}{l} 0.05 t_m \\ 0.1 h \end{array} \right\}$ whichever is greater |                                                              | $0.05 t_m = 0.095$ in.                                        |                                                  |
|                                                                                                 |                                                              | $0.1 h = 0.132$                                               | $r_3 = 0.25$ in.                                 |
| Body primary and secondary stress                                                               | NB-3545                                                      |                                                               |                                                  |
| $P_m = \left( \frac{A_f}{A_m} + 0.5 \right) P_s$                                                | NB-3545.1(a)(2)                                              |                                                               |                                                  |
| Inlet end                                                                                       | $S_m \geq P_m$ at 500°F                                      | $S_m = 18,900$ psi at 500°F                                   | $P_m = 8067$ psi                                 |
| Outlet end                                                                                      |                                                              | $S_m = 18,900$ psi at 500°F                                   | $P_m = 8067$ psi                                 |
| Valve disc seat ring analysis                                                                   | NB-3546.2                                                    |                                                               |                                                  |
| $P_m \leq 1.0 S_m$                                                                              | Acceptable structural analysis method                        | $1.0 S_m = 19,400$ psi at 500°F                               | $P_m = 9278$ psi                                 |
| $S_{max} \geq 1.5 S_m$                                                                          |                                                              | $1.5 S_m = 29,100$ psi at 500°F                               | $S_{max} = 12,712$                               |

HNP-2-FSAR-3

**TABLE 3.9-42 (SHEET 3 OF 5)**

3. Structural analysis for  
other valve parts(NB-3546.3)

| <u>Stress Category</u>   | <u>ASME Section III<br/>Reference<br/>Method of Analysis</u> | <u>Allowable Stress<br/>or Design Value<br/>(psi)</u> | <u>Calculated Stress<br/>or Actual Value<br/>(psi)</u> |
|--------------------------|--------------------------------------------------------------|-------------------------------------------------------|--------------------------------------------------------|
| Stem thrust stress       | Calculate stress due to operator thrust                      | $S_m = 26,700$ at 500°F                               | $S_T = 21,047$                                         |
| Stem torque stress       | Calculate stress due to operator torque                      | $0.6 S_m = 16,020$ at 500°F                           | $S_S = 887$                                            |
| Gasket seating stress    | Acceptable stress analysis method                            | $1.5 S_m = 28,700$ at 500°F                           | $S = 13,853$                                           |
| Bonnet                   | Calculate stress due to pressure (radial)                    | $1.5 S_m = 24,300$ at 500°F                           | $S = 17,258$                                           |
| Protective (thrust ring) | Calculate stress due to pressure                             | $S_m = 44,100$ at 500°F                               | $S = 16,761$                                           |
| Eyebolt                  | Calculate stress due to pressure                             | $S_m = 7000$ at 500°F                                 | $S = 5950$                                             |

**TABLE 3.9-42 (SHEET 4 OF 5)**

4. Cyclic loading requirements

| <u>Stress Category</u>                                 | <u>ASME Section III Reference Method of Analysis</u>            | <u>Allowable Stress or Minimum Dimension Required (psi)</u> | <u>Calculated Stress or Actual Dimension (psi)</u> |
|--------------------------------------------------------|-----------------------------------------------------------------|-------------------------------------------------------------|----------------------------------------------------|
| Secondary stress due to pipe reaction                  | NB-3545.2(b)                                                    |                                                             |                                                    |
| $P_{ed} = \frac{F_d S}{G_d}$                           | NB-3545.2(b)(1)<br>Figures NB-3545.2-2, 3<br>NB-3545.2(b)(1)    | $1.5 S_m = 28,350$ at 500°F                                 | $P_{ed} = 5640$                                    |
| $P_{eb} = C_b \frac{F_b S}{G_b}$                       | Figures NB-3545.2-4, 5<br>Figure NB-3545.2-6<br>NB-3545.2(b)(5) | $1.5 S_m = 28,350$ at 500°F                                 | $P_{eb} = 11,214$                                  |
| $P_{et} = 2 \frac{F_b S}{G_t}$                         | NB-3545.2(b)(1)<br>NB-3545.2(b)(6)(c)                           | $1.5 S_m = 28,350$ at 500°F                                 | $P_{et} = 11,211$                                  |
| Primary plus secondary stress due to internal pressure | NB-3545.2(a)(1)                                                 |                                                             |                                                    |
| $Q_p = C_p \left( \frac{r_i}{t_e} + 0.5 \right) P_s$   | Figure NB-3545.1-1<br>Figure NB-3545.1(a)-1                     | No limit required                                           | $Q_p = 24,028$                                     |
| Thermal secondary stress at inlet and outlet crotch    | NB-3545.2(c)                                                    |                                                             |                                                    |
| $Q_{T_1}$                                              | Figures                                                         | No limit required                                           | $Q_{T_1} = 2500$                                   |
| $Q_{T_2}$                                              | NB-3545.2(c)-2, 3                                               | No limit required                                           | $Q_{T_2} = 545$                                    |
| $Q_{T_3}$                                              | NB-3545.2(c)-4, 5                                               | No limit required                                           | $Q_{T_3} = 845$                                    |

**TABLE 3.9-42 (SHEET 5 OF 5)**

4. Cyclic loading requirements (cont)

| <u>Stress Category</u>                                               | <u>ASME Section III Reference Method of Analysis</u> | <u>Allowable Stress or Minimum Dimension Required (psi)</u> | <u>Calculated Stress or Actual Dimension (psi)</u> |
|----------------------------------------------------------------------|------------------------------------------------------|-------------------------------------------------------------|----------------------------------------------------|
| Valve body secondary stress criteria at crotch region                | NB-3545.2                                            |                                                             |                                                    |
| $S_n = Q_p + P_{ed} + 2Q_{T_2} \leq 3S_m$                            |                                                      | $3 S_m = 56,700$ at 500°F                                   | $S_n = 30,757$                                     |
| Normal-duty valve fatigue requirements                               | NB-3545.3<br>NB-3550                                 |                                                             |                                                    |
| $S_{P_1} = \frac{2}{3}Q_p + \frac{P_{eb}}{2} + Q_{T_3} + 1.3Q_{T_1}$ | NB-3545.3(a)                                         | No limit required                                           | $S_{P_1} = 25,720$                                 |
| $S_{P_2} = 0.4 Q_P + P_{eb} + 2Q_{T_3}$                              | NB-3545.3(a)                                         | No limit required                                           | $S_{P_2} = 22,514$<br>$S_A = 25,720$               |
| $N_a \geq 2000$ cycles                                               | $N_a =$ Figure I-9-1                                 | 2000 cycles                                                 | $N_a = 40,000$ cycles                              |
| Cyclic stress calculation                                            | NB-3554                                              |                                                             |                                                    |
| $Q_P + P_{ed} + C_6 C_2 C_4 \Delta T_{f(max)} \leq 3S_m$             | NB-3554(a)                                           | $3 S_m = 56,700$ at 500°F                                   | $S_{nc} = 43,410$                                  |
| $Q_P + P_{eb} + C_6 C_3 C_4 \Delta T_{f(max)} \leq 3S_m$             | NB-3554(b)                                           | $3 S_m = 56,700$ at 500°F                                   | $S_{n max} = 56,555$                               |
| $S_i = \frac{4}{3}Q_p + P_{eb} + C_6(C_3 C_4 + C_5)\Delta T_{fi}$    | $N_i =$ Figure I-9-1                                 | $\sum \frac{N_{ri}}{N_i} \leq 1.0$                          | $\sum \frac{N_{ri}}{N_i} = 0.295$                  |

TABLE 3.9-43

RCIC PIPING 4-in. GATE VALVE AND RHR HEAD SPRAY<sup>(a)</sup> 4-in. VALVEDesign of Pressure-Retaining Parts - (NB-3541)

| <u>Stress Category</u>                                      | <u>ASME Section III Reference</u> | <u>Minimum Dimension Required</u>                 | <u>Calculated or Actual Dimension</u> |
|-------------------------------------------------------------|-----------------------------------|---------------------------------------------------|---------------------------------------|
| Port wall thickness                                         |                                   |                                                   |                                       |
| $t_m$                                                       | NB-3542-1                         | Based on:<br>$d_m = 3.4375$ in.<br>$P_r = 900$ lb | $t_m = 0.46$ in.                      |
| Neck wall thickness                                         |                                   |                                                   |                                       |
| $t'_m \geq t_m$                                             | NB-3542.2                         | $t_m = 0.46$ in.                                  | $t'_m = 0.513$ in.                    |
| $d'_m \geq 1.5 d_m$                                         |                                   | $1.5 d_m = 5.156$ in.                             | $d'_m = 5.75$ in.                     |
| Minimum thickness of valve for nonstandard pressure ratings | NB-3543                           | NA <sup>(b)</sup>                                 | NA <sup>(b)</sup>                     |

a. RHR head spray is deactivated.

b. NA - not applicable.

TABLE 3.9-44

## MAIN STEAM DRAIN AND CRD RETURN PIPING 3-in. GATE VALVE

Design of Pressure-Retaining Parts - (NB-3541)

| <u>Stress Category</u>                                      | <u>ASME Section III Reference</u> | <u>Minimum Dimension Required</u>        | <u>Calculated or Actual Dimension</u> |
|-------------------------------------------------------------|-----------------------------------|------------------------------------------|---------------------------------------|
| Port wall thickness <sup>(a)</sup>                          | NB-3542-1                         | $t_m = \frac{13}{32}$ in. <sup>(b)</sup> | $t_m = \frac{13}{32}$ in.             |
| Neck wall thickness                                         |                                   |                                          |                                       |
| $t'_m \geq t_m$                                             | NB-3542.2                         | $t_m = \frac{13}{32}$ in.                | $t'_m = \frac{13}{32}$ in.            |
| $d'_m \geq 1.5 d_m$                                         | NA <sup>(c)</sup>                 |                                          |                                       |
| Minimum thickness of valve for nonstandard pressure ratings | NB-3543                           | NA <sup>(c)</sup>                        | NA <sup>(c)</sup>                     |

a. See ANSI B16.5.

b. Taken from ANSI B16.5.

c. NA - not applicable.

HNP-2-FSAR-3

**TABLE 3.9-45**  
**STANDBY SERVICE WATER 6-in. STRAINER**

Design of Pressure-Retaining Parts

| <u>Component Part Analyzed</u> | <u>Method of Analysis</u>                                                                  | <u>Allowable Stress or Minimum Thickness</u> |           | <u>Calculated Stress or Actual Thickness</u> |
|--------------------------------|--------------------------------------------------------------------------------------------|----------------------------------------------|-----------|----------------------------------------------|
| Shell                          | UG-27<br>ASME Code, Section VIII                                                           | Circumferential                              | 0.146 in. | 0.365 in.                                    |
|                                |                                                                                            | Longitudinal                                 | 0.104 in. | 0.365 in.                                    |
| Inlet and outlet nozzle flange | UA-49 to UA-52                                                                             | Longitudinal hub                             | 26,250    | 16,518                                       |
|                                |                                                                                            | Radial flange                                | 17,500    | 4964                                         |
|                                |                                                                                            | Tang flange                                  | 17,500    | 4099                                         |
| Inlet nozzle                   | Welding Council,<br>Bulletin 107, Johns and<br>Orange Paper (including<br>pressure stress) | $S_{max}(P_m)$                               | 12,000    | 6334                                         |
|                                |                                                                                            | $S_{max}(P_m + P_b)$                         | 18,000    | 10,970                                       |
| Outlet nozzle                  | Welding Council,<br>Bulletin 107, Johns and<br>Orange Paper (including<br>pressure stress) | $S_{max}(P_m)$                               | 12,000    | 5240                                         |
|                                |                                                                                            | $S_{max}(P_m + P_b)$                         | 18,000    | 11,727                                       |
| Support                        | Supported by nozzle<br>connected to piping                                                 | NA <sup>(a)</sup>                            |           | NA <sup>(a)</sup>                            |

a. NA - not applicable.

HNP-2-FSAR-3

**TABLE 3.9-46**  
**RHRSW 18-in. STRAINER**

Design of Pressure-Retaining Parts

| <u>Component Part Analyzed</u> | <u>Method of Analysis</u>                             |              | <u>Allowable Stress or Minimum Thickness</u> |           | <u>Calculated Stress or Actual Thickness</u> |
|--------------------------------|-------------------------------------------------------|--------------|----------------------------------------------|-----------|----------------------------------------------|
| Shell                          | ASME Code, Section VIII, UG-27                        |              | Circumferential                              | 0.748 in. | 1 1/4 in.                                    |
|                                |                                                       |              | Longitudinal                                 | 0.356 in. | 1 1/4 in.                                    |
| Inlet and outlet nozzle flange | UA-49 to UA-52                                        |              | Longitudinal hub                             | 26,250    | 14,285                                       |
|                                |                                                       |              | Radial flange                                | 17,500    | 3730                                         |
|                                |                                                       |              | Tangential flange                            | 17,500    | 3757                                         |
| Inlet nozzle                   | Welding Council, Bulletin 107, Johns and Orange Paper |              | $S_{max}(P_m)$                               | 17,500    | 12,550                                       |
|                                |                                                       |              | $S_{max}(P_m + P_b)$                         | 26,250    | 21,529                                       |
| Outlet nozzle                  | Welding 107, Johns and Orange Paper                   | < 1.0 S      | $S_{max}(P_m)$                               | 17,500    | 13,976                                       |
|                                |                                                       | < 1.5 S      | $S_{max}(P_m + P_b)$                         | 26,250    | 22,120                                       |
| Support bolts                  | Hand calculation                                      | < 0.9 $S_y$  | $\sigma_T$                                   | 29,970    | 19,823                                       |
|                                |                                                       | < 0.45 $S_y$ | $\tau$                                       | 14,985    | 6499                                         |
| Support base flange            | Hand calculation                                      | < 1.5 S      | $\sigma_x$                                   | 26,250    | 8687                                         |
|                                |                                                       | < 0.6 S      | $\tau$                                       | 10,500    | 1351                                         |
| Support weld                   | Hand calculation                                      | < 0.6 S      | $\tau$                                       | 10,500    | 4956                                         |
| Frequency                      |                                                       |              |                                              | > 20 Hz   | 30 Hz                                        |



HNP-2-FSAR-3

**TABLE 3.9-47**  
**STRESS SUMMARY OF PSW 30-in. STRAINER**

Design of Pressure-Retaining Parts

| <u>Component Part Analyzed</u> | <u>Method of Analysis</u>                  | <u>Allowable Stress or Minimum Thickness</u> | <u>Calculated Stress or Actual Thickness</u> |
|--------------------------------|--------------------------------------------|----------------------------------------------|----------------------------------------------|
| Shell                          | ASME Section III and Regulatory Guide 1.48 | 15,500 psi/0.05 in.                          | 1908 psi/0.625 in. <sup>(a)</sup>            |
| Outlet nozzle                  | Structural dynamic computer program        | 17,000 psi/0.0464 in.                        | 1576 psi/0.75 in. <sup>(a)</sup>             |
| Inlet nozzle                   | Structural dynamic computer program        | 17,000 psi/0.0464 in.                        | 1576 psi/0.75 in. <sup>(a)</sup>             |
| Base plate                     | ASME Section III, Appendix XVII-2214.3     | 28,500 psi                                   | 4000 psi <sup>(a)</sup>                      |
| Anchor bolts                   | ASME Section III, Appendix XVIII-2461.3    | 35,340 psi                                   | 21,842 psi (maximum)                         |
| Frequency                      |                                            | > 20 Hz                                      | 22.9 Hz                                      |

a. Actual stress due to external loads plus seismic load.

HNP-2-FSAR-3

**TABLE 3.9-48 (SHEET 1 OF 2)**

**RHR AND CORE SPRAY SYSTEMS JOCKEY PUMPS**

| <u>Component</u>            | <u>Normal Steady-State Load</u><br>(psi) |                  | <u>Normal + OBE</u><br>(psi) |                  | <u>Normal + OBE</u><br>(psi) |                  |
|-----------------------------|------------------------------------------|------------------|------------------------------|------------------|------------------------------|------------------|
|                             | <u>Actual</u>                            | <u>Allowable</u> | <u>Actual</u>                | <u>Allowable</u> | <u>Actual</u>                | <u>Allowable</u> |
| Pump holddown pump stress   |                                          |                  |                              |                  |                              |                  |
| shear                       | 232                                      | 10,000           | 1845                         | 10,000           | 2499                         | 16,200           |
| tensile                     | 3304                                     | 20,000           | 7562                         | 20,000           | 8370                         | 32,400           |
| Anchor bolt stress          |                                          |                  |                              |                  |                              |                  |
| shear                       | 373                                      | 10,000           | 2430                         | 10,000           | 3211                         | 16,200           |
| tensile                     | 1021                                     | 20,000           | 10,563                       | 20,000           | 14,317                       | 32,400           |
| Shaft stress                | 2363                                     | 17,500           | 2603                         | 17,500           | 2792                         | 30,000           |
| Support frame stress        | 80                                       | 23,760           | 1953                         | 23,760           | 2617                         | 32,400           |
| Thrust retainer bolt stress | 1232                                     | 20,000           | 1299                         | 20,000           | 1364                         | 32,400           |
| Pump frame bolt stress      |                                          |                  |                              |                  |                              |                  |
| shear                       | 1000                                     | 10,000           | 1897                         | 10,000           | 2184                         | 16,200           |
| tensile                     | 502                                      | 20,000           | 1528                         | 20,000           | 1834                         | 32,400           |
| Frame adapter flange stress | 12,387                                   | 26,250           | 13,127                       | 26,250           | 13,352                       | 52,500           |
| Adapter flange bolt stress  | 12,338                                   | 25,000           | 13,075                       | 25,000           | 13,299                       | 37,500           |
| Maximum nozzle stress       |                                          |                  |                              |                  |                              |                  |
| suction                     | 7977                                     | 17,500           | 11,966                       | 27,720           | 11,966                       | 27,720           |
| discharge                   | 6652                                     | 17,500           | 9771                         | 27,720           | 9771                         | 27,720           |
| Discharge flange stress     | 26,151                                   | 26,250           | 37,253                       | 52,500           | 37,253                       | 52,500           |
| Suction flange stress       | 23,388                                   | 26,250           | 32,534                       | 52,500           | 32,534                       | 52,500           |
| Frame-to-cover bolt stress  | 1400                                     | 20,000           | 4443                         | 20,000           | 5432                         | 32,400           |

HNP-2-FSAR-3

**TABLE 3.9-48 (SHEET 2 OF 2)**

| <u>Component</u>                     | <u>Normal Steady-State Load</u><br>(psi) |                  | <u>Normal + OBE</u><br>(psi) |                  | <u>Normal + OBE</u><br>(psi) |                  |
|--------------------------------------|------------------------------------------|------------------|------------------------------|------------------|------------------------------|------------------|
|                                      | <u>Actual</u>                            | <u>Allowable</u> | <u>Actual</u>                | <u>Allowable</u> | <u>Actual</u>                | <u>Allowable</u> |
| Pump bearing loads                   |                                          |                  |                              |                  |                              |                  |
| outboard                             | 208                                      | 3440             | 286                          | 3440             | 335                          | 3440             |
| inboard                              | 1169                                     | 5750             | 1618                         | 5750             | 1813                         | 5750             |
| Impeller key stress                  | 640                                      | 9000             | 640                          | 9000             | 640                          | 9000             |
| Pump frame foot stress               | 69                                       | 12,600           | 402                          | 12,600           | 489                          | 27,000           |
| Heat exchanger holddown bolts stress | 585                                      | 20,000           | 5437                         | 20,000           | 7043                         | 32,400           |
| Heat exchanger piping stress         | 1835                                     | 15,000           | 2689                         | 18,000           | 3364                         | 18,000           |
| Motor holddown bolts                 |                                          |                  |                              |                  |                              |                  |
| shear                                | 444                                      | 10,000           | 2033                         | 10,000           | 2816                         | 16,200           |
| tensile                              | 0                                        | 20,000           | 2908                         | 20,000           | 4248                         | 32,400           |
| Motor bearing loads                  |                                          |                  |                              |                  |                              |                  |
| outboard                             | 17                                       | 850              | 53                           | 850              | 70                           | 850              |
| inboard                              | 17                                       | 1430             | 77                           | 1430             | 97                           | 1430             |

HNP-2FSAR-3

**TABLE 3.9-49 (SHEET 1 OF 3)**  
**DIESEL ENGINE GENERATING UNIT**

Skid assembly

|                                                               |                      |                                                                             |            |
|---------------------------------------------------------------|----------------------|-----------------------------------------------------------------------------|------------|
| Combined stress in skid<br>holddown bolts                     | 3092 psi             | Proof strength                                                              | 28,000 psi |
| Shear stress in generator<br>holddown bolts                   | 2434 psi             | Shear strength                                                              | 33,000 psi |
| Combined stress in sub-base<br>middle section holddown bolts  | 6428 psi             | Proof strength                                                              | 28,000 psi |
| Combined stress in sub-base<br>forward section holddown bolts | 5789 psi             | Proof strength                                                              | 28,000 psi |
| Load on last two crankshaft<br>main bearings                  | 3167 lb<br>1156 lb   | Standard practice allows<br>additional load above normal<br>operating load. | 6000 lb    |
| Load on generator bearings                                    | 11,430 lb<br>8775 lb | For particular bearings at<br>900 rpm for 100,000-h rated<br>radial load    | 18,000 lb  |
| Combined stress in turbo-<br>charger mounting bolts           | 22,915 psi           | Proof strength                                                              | 52,000 psi |
| Combined stress in turbo-<br>charger foot bracket             | 22,511 psi           | Yield strength                                                              | 33,000 psi |

Overspeed governor and  
shutdown system

|                                           |        |                                                            |         |
|-------------------------------------------|--------|------------------------------------------------------------|---------|
| Acceleration that would<br>cause shutdown | 2.24 g | Maximum acceleration produced<br>at governor by earthquake | 0.554 g |
|-------------------------------------------|--------|------------------------------------------------------------|---------|

HNP-2FSAR-3

**TABLE 3.9-49 (SHEET 2 OF 3)**

Heat exchanger stack assembly

|                                   |            |                      |            |
|-----------------------------------|------------|----------------------|------------|
| Bending stress in support bracket | 11,940 psi | Allowable stress     | 21,600 psi |
| Shear stress in bracket bolts     | 11,726 psi | Allowable bolt shear | 38,000 psi |
| Stress in brace assembly bars     | 5775 psi   | Allowable stress     | 21,600 psi |
| Weld load at foot of support post | 7507 lb    | Allowable weld load  | 14,400 lb  |
| Combined stress in bolts in feet  | 9120 psi   | Proof strength       | 52,000 psi |
| Bending stress in feet            | 4569 psi   | Allowable stress     | 21,600 psi |

Lube oil filter

|                       |         |                     |           |
|-----------------------|---------|---------------------|-----------|
| Load on bolts in base | 556 lb  | Proof load          | 17,400 lb |
| Weld load at base     | 1372 lb | Allowable weld load | 20,400 lb |

Lube oil strainer

|                       |          |                     |            |
|-----------------------|----------|---------------------|------------|
| Tension load on bolts | 153 lb   | Proof load          | 11,750 lb  |
| Stress in base weld   | 1166 psi | Allowable stress    | 21,600 psi |
| Weld load at base     | 439 lb   | Allowable weld load | 20,400 lb  |

Fuel oil day tank

|                                |          |                  |            |
|--------------------------------|----------|------------------|------------|
| Shear stress in holddown bolts | 2537 psi | Shear strength   | 38,000 psi |
| Bending stress in feet         | 5387 psi | Allowable stress | 21,600 psi |

HNP-2FSAR-3

**TABLE 3.9-49 (SHEET 3 OF 3)**

Jacket water expansion tank

|                                 |          |                     |            |
|---------------------------------|----------|---------------------|------------|
| Combined stress in bolt         | 1938 psi | Allowable stress    | 31,200 psi |
| Bending stress in feet          | 1006 psi | Allowable stress    | 21,600 psi |
| Weld load at attachment to tank | 744 lb   | Allowable weld load | 23,850 lb  |

Air compressor skid

|                                |         |                |            |
|--------------------------------|---------|----------------|------------|
| Shear stress in holddown bolts | 194 psi | Shear strength | 33,000 psi |
|--------------------------------|---------|----------------|------------|

Air receiver tank

|                          |            |                       |            |
|--------------------------|------------|-----------------------|------------|
| Combined stress in bolts | 4992 psi   | Proof strength        | 52,000 psi |
| Bending stress in feet   | 17,611 psi | Yield strength        | 30,000 psi |
| Stress in weld at feet   | 907 psi    | Allowable weld stress | 2400 psi   |

Static exciter components cabinet

|                                                     |          |                |            |
|-----------------------------------------------------|----------|----------------|------------|
| Shear stress in holddown bolts                      | 1808 psi | Shear strength | 33,000 psi |
| Shear stress in high-voltage chassis holddown bolts | 1484 psi | Shear strength | 33,000 psi |
| Shear stress in current transformer bolts           | 174 psi  | Shear strength | 33,000 psi |

NOTE:

1. Relay operation confirmed by test by Basler Electric Company and A. O. Smith Corporation.

TABLE 3.9-50 (SHEET 1 OF 2)

## RHR DISCHARGE PIPING 24-in. CHECK VALVE

| <u>Section</u>                                            | <u>Criteria</u>                                                            | <u>Calculated Value Versus Allowable</u>                  |
|-----------------------------------------------------------|----------------------------------------------------------------------------|-----------------------------------------------------------|
| Seismic Analysis (NB-3524)<br>Static Analysis Method Used |                                                                            |                                                           |
| Base of operator support leg                              | $P_m \leq S_m$ at 500°F                                                    | 2480 ≤ 15,000 psi                                         |
| Bolts                                                     | $P_m \leq S_m$ at 500°F                                                    | 3416 ≤ 30,000 psi                                         |
| Natural frequency of operator                             | $f_n \geq$ design specified limit                                          | 251 ≥ 20 Hz                                               |
| End of valve                                              | $P_m \leq S_m$ at 500°F                                                    | 6424 ≤ 19,400 psi                                         |
| Middle of valve                                           | $P_m \leq S_m$ at 500°F                                                    | 6080 ≤ 19,400 psi                                         |
| ASME Section III<br><u>Reference</u>                      |                                                                            |                                                           |
| <u>Criteria</u>                                           |                                                                            |                                                           |
| <u>Calculated Value Versus Allowable</u>                  |                                                                            |                                                           |
| Design of pressure-retaining parts (NB-3540)              |                                                                            |                                                           |
| NB-3544.1(a)<br>Radius of crotch                          | $R_2 \geq 0.3 t_m$                                                         | 3.0 ≥ 0.67 in.                                            |
| NB-3544.1(b)                                              | $R_4 < R_2$                                                                | 1.5 < 3.0 in.                                             |
| NB-3544.5                                                 | Out of roundness < 5%                                                      | 3.4% < 5%                                                 |
| NB-3544.6<br>Body curved section                          | $\frac{1}{r_{\text{long}}} + \frac{1}{r_{\text{lat}}} \geq \frac{4}{3d_m}$ | 0.096 ≥ 0.069                                             |
| NB-3545.1 Primary crotch stress due to internal pressure  | $P_m \leq S_m$ at 500°F                                                    | Inlet: 17,124 ≤ 21,600 psi<br>Outlet: 18,639 ≤ 21,600 psi |
| NB-3545.2(b) Direct or axial load effect                  | $P_{ed} \leq 1.5 S_m$ at 500°F                                             | Inlet: 8129 ≤ 32,400 psi<br>Outlet: 9493 ≤ 32,400 psi     |

HNP-2-FSAR-3

**TABLE 3.9-50 (SHEET 2 OF 2)**

| <u>ASME Section III Reference</u>                              | <u>Criteria</u>                                          | <u>Calculated Value Versus Allowable</u>                  |
|----------------------------------------------------------------|----------------------------------------------------------|-----------------------------------------------------------|
| Bending load effect                                            | $P_{eb} \leq 1.5 S_m$ at 500°F                           | Inlet: 16,778 ≤ 32,400 psi<br>Outlet: 19,462 ≤ 32,400 psi |
| Torsional load effect                                          | $P_{et} \leq 1.5 S_m$ at 500°F                           | Inlet: 16,783 ≤ 32,400 psi<br>Outlet: 18,972 ≤ 2,400 psi  |
| NB-3545.2 Valve body - primary plus secondary stress at crotch | $S_n \leq 3 S_m$ at 500°F                                | Outlet is worst case:<br>44,537 ≤ 4,800 psi               |
| NB-3545.3                                                      | $N_a \geq 2000$                                          | 11,000 ≥ 2000 cycles                                      |
| NB-3553 Fatigue usage                                          | $\sum \frac{N_i}{N_i} \leq 1.0$                          | 0.265 ≤ .0                                                |
| NB-3554(a) Cyclic stress                                       | $Q_p + P_{eb} + C_6 C_3 C_4 \Delta T_{f(max)} \leq 3S_m$ | 56,091 ≤ 4,800 psi                                        |

| <u>Section</u>                             | <u>Criteria</u>                   | <u>Calculated Value Versus Allowable</u> |
|--------------------------------------------|-----------------------------------|------------------------------------------|
| Structural analysis (NB-3546)              |                                   |                                          |
| Disc (due to pressure)                     | $S_{max} \leq S_m$ at 500°F       | 17,606 ≤ 20,800 psi                      |
|                                            | $S_{shear} \leq 0.6 S_m$ at 500°F | 10,688 ≤ 12,480 psi                      |
| Cover                                      | $S_{max} \leq 1.0 S_m$ at 500°F   | 18,350 ≤ 20,800 psi                      |
| Retainer gasket                            | $S_{shear} \leq 0.6 S_m$ at 500°F | 9929 ≤ 25,980 psi                        |
| Retainer hinge pin                         | $S_{max} \leq S_m$ at 500°F       | 17,147 ≤ 20,800 psi                      |
| Body-to-cover joint                        | $P_L + P_B \leq 1.5 S_m$ at 500°F | 28,678 ≤ 32,400 psi                      |
| Indicator housing                          | $P_L + P_B \leq 1.5 S_m$ at 500°F | 21,000 ≤ 29,580 psi                      |
| Indicator retainer                         | $S_{max} \leq S_m$ at 500°F       | 17,405 ≤ 17,900 psi                      |
| Indicator housing and pin retainer bolting | $S_{max} \leq 2.0 S_m$ at 500°F   | 45,000 ≤ 69,400 psi                      |



**TABLE 3.9-51**

**RHR AND CRD HYDRAULIC SYSTEMS  
3-in. AND 4-in. CHECK VALVES**

Seismic Analysis (NB-3524)-Static Analysis Method Used

| <u>Section</u> | <u>Criteria</u> | <u>Calculated Value<br/>Versus Allowable</u> |
|----------------|-----------------|----------------------------------------------|
| Valve ends     | $P_m \leq S_m$  | 3 in. 3102 ≤ 18,400 psi                      |
|                |                 | 4 in. 3102 ≤ 17,300 psi                      |
| Valve middle   | $P_m \leq S_m$  | 3 in. 3232 ≤ 18,400 psi                      |
|                |                 | 4 in. 3232 ≤ 17,300 psi                      |

Thickness requirement (NB-3541)

| <u>Location</u>   | <u>Criteria</u> | <u>Actual Value<br/>Versus<br/>Minimum Required</u> |
|-------------------|-----------------|-----------------------------------------------------|
| Near welding ends | $t \geq t_m$    | 3 in. 1.03 ≥ 0.43 in.                               |
|                   |                 | 4 in. 1.03 ≥ 0.55 in.                               |

**TABLE 3.9-52 (SHEET 1 OF 3)**  
**HPCI STEAM PIPING 10-in. CHECK VALVE**

| <u>Valve Section</u>                                 | <u>Criteria</u>             | <u>Calculated Value Versus Allowable</u> |
|------------------------------------------------------|-----------------------------|------------------------------------------|
| 1. Seismic analysis-static analysis method (NB-3524) |                             |                                          |
| Support base                                         | $P_m \leq S_m$ at 500°F     | 6046 ≤ 16,200 psi                        |
| Shear in bolts                                       | $S_s \leq 0.6 S_m$ at 500°F | 643 ≤ 17,880 psi                         |
| Tension in bolts                                     | $S_T \leq S_m$ at 500°F     | 1905 ≤ 28,800 psi                        |
| 2. Structural analysis                               |                             |                                          |
| <u>Disc calculations due to pressure</u>             |                             |                                          |
| Disc thickness                                       | $S_1 \leq S_m$ at 500°F     | 12,436 ≤ 20,800 psi                      |
| Disc shear at edge                                   | $S_s \leq 0.6 S_m$ at 500°F | 8911 ≤ 12,480 psi                        |
| <u>Cover calculations</u>                            |                             |                                          |
| Cover thickness                                      | $S_{max} \leq S_m$ at 500°F | 9734 ≤ 20,800 psi                        |
| Retainer (gasket calculations)                       | $S_s \leq 0.6 S_m$ at 500°F | 9800 ≤ 25,980 psi                        |
| Retainer (hinge pin calculations)                    | $S_t \leq S_m$ at 500°F     | 20,274 ≤ 20,800 psi                      |
| Indicator housing and pin retainer bolting           | $S_1 \leq 2 S_m$ at 500°F   | 45,000 ≤ 57,600 psi                      |
| <u>Body-to-cover analysis</u>                        |                             |                                          |
| Axial stress at junction                             | $S_H \leq 1.5 S_m$ Maximum  | 20,999 ≤ 32,400 psi                      |
| Tangential stress at junction                        | $S_T \leq 1.55 S_m$ Maximum | 14,549 ≤ 32,400 psi                      |

TABLE 3.9-52 (SHEET 2 OF 3)

| <u>Valve Section</u>                                           | <u>Criteria</u>                                                            | <u>Calculated Value Versus Allowable</u>     |
|----------------------------------------------------------------|----------------------------------------------------------------------------|----------------------------------------------|
| Radial stress at junction                                      | $S_R \leq 1.5 S_m$ Maximum                                                 | $-2425 \leq 32,400$ psi                      |
| Stress intensity (S)                                           | $S \leq 1.5 S_m$                                                           | $25,241 \leq 32,400$ psi                     |
| 3. Design of pressure-retaining parts - cyclic requirements    |                                                                            |                                              |
| NB-3544.1(a)<br>Radius of crotch                               | $R_2 \geq 0.3 t_m$                                                         | $3.75 \geq 0.339$ in.                        |
| NB.3544.6 Doubly curved section                                | $\frac{1}{r_{\text{long}}} + \frac{1}{r_{\text{lat}}} \geq \frac{4}{3d_m}$ | $0.23 \geq 0.15$ in.                         |
| NB-3544.8 Weld ends                                            |                                                                            |                                              |
| Inlet                                                          | $t_i \geq t_m$                                                             | $2.54 \geq 1.13$ in.                         |
| Outlet                                                         | $t_o \geq t_m$                                                             | $1.38 \geq 1.13$ in.                         |
| NB-3545.1 Primary crotch stress due to internal pressure       | $P_m \leq S_m$ at 500°F                                                    | $11,724 \leq 21,600$ psi<br>(inlet critical) |
| NB-3545.2(b) Secondary stress due to pipe reaction             |                                                                            |                                              |
| Direct or axial load effect                                    | $P_{ed} \leq 1.5 S_m$ at 500°F                                             | $11,176 \leq 32,400$ psi                     |
| Bending load effect                                            | $P_{eb} \leq 1.5 S_m$ at 500°F                                             | $20,746 \leq 32,400$ psi                     |
| Torsional load effect                                          | $P_{et} \leq 1.5 S_m$ at 500°F                                             | $20,746 \leq 32,400$ psi                     |
| NB-3545.2 Valve body - primary plus secondary stress at crotch | $S_n \leq 3 S_m$ at 500°F                                                  | $38,848 \leq 64,800$ psi                     |

HNP-2-FSAR-3

**TABLE 3.9-52 (SHEET 3 OF 3)**

| <u>Valve Section</u>                      | <u>Criteria</u>                                          | <u>Calculated Value Versus Allowable</u> |
|-------------------------------------------|----------------------------------------------------------|------------------------------------------|
| NB.3545.3 Normal-duty fatigue requirement | $N_a \geq 2000$ cycles                                   | $13,000 \geq 2000$ cycles                |
| NB-3553 Fatigue usage                     | $\sum \frac{N_i}{N_i} \leq 1.0$                          | $0.466 \leq 1.0$                         |
| NB-3554(a) Cyclic stress                  | $Q_P + P_{ed} + C_6 C_2 C_4 \Delta T_{f(max)} \leq 3S_m$ | $51,418 \leq 64,800$ psi                 |
| NB-3554(b) Cyclic stress                  | $Q_P + P_{eb} + C_6 C_3 C_4 \Delta T_{f(max)} \leq 3S_m$ | $64,901 \leq 64,800$ psi                 |

**TABLE 3.9-53**  
**RHR 4-in. GLOBE VALVE**

Seismic Analysis (NB-3524) Static Analysis Method Used

| <u>Section</u>                             | <u>Criteria</u>                       | <u>Calculated Value Versus Allowable</u> |
|--------------------------------------------|---------------------------------------|------------------------------------------|
| Operator adapter plate interface           | $P_m \leq S_m$                        | $9035 \leq 28,800$ psi                   |
| Base of yoke                               | $P_m \leq S_m$                        | $7933 \leq 19,400$ psi                   |
| Yoke body bolted joint                     | $P_m \leq S_m$                        | $23,567 \leq 28,800$ psi                 |
| Body bonnet interface                      | $P_m \leq S_m$                        | $16,190 \leq 19,400$ psi                 |
| Natural frequency of valve super-structure | $f_n \geq$ design specification limit | $220 \geq 20$ Hz                         |

Thickness Requirements (NB-3541)

| <u>Section</u>    | <u>Criteria</u> | <u>Actual Value Versus Required Minimum</u> |
|-------------------|-----------------|---------------------------------------------|
| Near welding ends | $t \geq t_m$    | $0.65 \geq 0.60$ in.                        |

**TABLE 3.9-54****CRD HYDRAULIC SYSTEM 3-in. CHECK VALVE**Seismic Analysis-Static Method of Analysis Used

| <u>Section</u>                                   | <u>Criteria</u>                                                | <u>Calculated Value Versus Allowable</u> |
|--------------------------------------------------|----------------------------------------------------------------|------------------------------------------|
| Cylinder-to-body connection bolting (worse case) | $\sigma_{\max} \leq \sigma_{\text{allow}}$                     | 7955 ≤ 28,800 psi                        |
|                                                  | $\tau_{\max} \leq 0.6 \sigma_{\text{allow}}$                   | 4150 ≤ 17,280 psi                        |
| Cylinder-to-body spacer bracket (worst case)     | $\sigma_{\max} \leq \sigma_{\text{allow}}$ (plate)             | 550 ≤ 17,500 psi                         |
|                                                  | $\sigma_{\max} \leq \sigma_{\text{allow}}$ (around bolt holes) | 3630 ≤ 17,500 psi                        |
| Cylinder cap bracket extension (worst case)      | $\sigma_{\max} \leq \sigma_{\text{allow}}$                     | 1440 ≤ 17,500 psi                        |
| Natural frequency of appurtenances               | $f_n \geq$ design specification limit                          | 320 ≥ 20 Hz                              |

Thickness Requirements

| <u>Section</u> | <u>Criteria</u> | <u>Actual Value Versus Required Minimum</u> |
|----------------|-----------------|---------------------------------------------|
| Near weld ends | $t \geq t_m$    | 0.9375 ≥ 0.51 in.                           |

**TABLE 3.9-55 (SHEET 1 OF 4)**  
**FEEDWATER 18-in. CHECK VALVE**

| <u>Valve Section</u>                                   | <u>Criteria</u>                 | <u>Calculated Value Versus Allowable</u> |
|--------------------------------------------------------|---------------------------------|------------------------------------------|
| 1. Seismic analysis - static analysis method (NB-3524) |                                 |                                          |
| a. Cylinder-to-valve body connection bolting           |                                 |                                          |
| Vertical direction                                     |                                 |                                          |
| Tension in bolts                                       | $S_{max} \leq S_{allow}$        | 12,640 ≤ 25,000 psi                      |
| Shear in bolts                                         | $\tau_{max} \leq 0.6 S_{allow}$ | 1950 ≤ 15,000 psi                        |
| Horizontal direction                                   |                                 |                                          |
| Tension in bolts                                       | $S_{max} \leq S_{allow}$        | 8297 ≤ 25,000 psi                        |
| Shear in bolts                                         | $\tau_{max} \leq 0.6 S_{allow}$ | 2615 ≤ 15,000 psi                        |
| b. Cylinder-to-body spacer                             |                                 |                                          |
| X-direction tension in bolts                           | $S_{max} \leq S_{allow}$        | 1045 ≤ 17,500 psi                        |
| Z-direction tension in bolts                           | $S_{max} \leq S_{allow}$        | 550 ≤ 17,500 psi                         |
| c. Cylinder cap bracket                                |                                 |                                          |
| X-direction tension in bolts                           | $S_{max} \leq S_{allow}$        | 1780 ≤ 16,200 psi                        |
| Z-direction tension in bolts                           | $S_{max} \leq S_{allow}$        | 6885 ≤ 16,200 psi                        |
| d. Natural frequency (cylinder appurtenance)           |                                 |                                          |
| Vertical direction                                     | $20 \leq f_n \text{ Hz}$        | 20 ≤ 699 Hz                              |
| Horizontal X-direction                                 | $20 \leq f_n \text{ Hz}$        | 20 ≤ 781 Hz                              |
| Horizontal Z-direction                                 | $20 \leq f_n \text{ Hz}$        | 20 ≤ 1398 Hz                             |

TABLE 3.9-55 (SHEET 2 OF 4)

| <u>Valve Section</u>                         | <u>Criteria</u>                                        | <u>Calculated Value Versus Allowable</u>                     |
|----------------------------------------------|--------------------------------------------------------|--------------------------------------------------------------|
| 2. Structural analysis                       |                                                        |                                                              |
| a. Cover stress ( $P_m + P_b$ ) calculations | $S_{max} \leq 1.5 S_m$ at 500°F                        | 20,575 ≤ 30,750 psi                                          |
| b. Body stress calculations                  |                                                        |                                                              |
| Bearing stress                               | $S_b \leq S_y$ at 500°F                                | 9463 ≤ 28,300 psi                                            |
| Shearing stress                              | $S_s \leq 0.6 S_m$ at 500°F                            | 5116 ≤ 11,340 psi                                            |
| Bending stress total                         | $S_T \leq 1.5 S_m$ at 500°F                            | 24,810 ≤ 28,350 psi                                          |
| Stress range from pressure effect            | $S_{alt} \leq S_A$ at $N_a = 2000$ cycles              | 62,025 ≤ 65,000 psi                                          |
| c. Neck to closure flange area of body       |                                                        |                                                              |
| Maximum stress intensity                     | $S_n \leq 3 S_m$ at 500°F                              | 50,418 ≤ 56,700 psi                                          |
| Maximum stress range for fatigue             | $S_{alt} \leq S_A$ at $N_a = 2000$ cycles              | 31,362 ≤ 65,000 psi                                          |
| d. Load key                                  |                                                        |                                                              |
| Vertical shear stress                        | $S_s \leq 0.6 S_m$ at 500°F                            | 7840 ≤ 13,980 psi                                            |
| Average bearing stress                       | $S_b \leq 1.5 S_m$ at 500°F                            | 9814 ≤ 34,950 psi                                            |
| e. Stuffing box flange                       |                                                        |                                                              |
| Stuffing box bolting areas                   | $A_{m_1} \leq A_{actual}$<br>$A_{m_2} \leq A_{actual}$ | 2.07 ≤ 3.31 in. <sup>2</sup><br>0.28 ≤ 3.31 in. <sup>2</sup> |
| f. Disc thickness calculation                | $S_r \leq S_m$ at 500°F                                | 16,770 ≤ 18,900 psi                                          |



TABLE 3.9-55 (SHEET 3 OF 4)

| <u>Valve Section</u>                                              | <u>Criteria</u>                                                                    | <u>Calculated Value Versus Allowable</u>                  |
|-------------------------------------------------------------------|------------------------------------------------------------------------------------|-----------------------------------------------------------|
| 3. Design of pressure-retaining parts and cyclic requirements     |                                                                                    |                                                           |
| NB-3542.1 Body wall and neck thickness                            | $t_m \leq t_e$                                                                     | 1.63 ≤ 1.71 in.                                           |
| NB-3544.1(a) Radius of crotch                                     | $0.3 t_m \leq r_2$                                                                 | 0.49 ≤ 1.5 in.                                            |
| Figure NB-3544.1(c) Radius of crotch                              | $\left. \begin{array}{l} 0.05t_m \\ \text{or } 0.1h \end{array} \right\} \leq r_3$ | 0.138 ≤ 0.156 in.                                         |
| NB-3544.6 Doubly curved section                                   | $\frac{1}{r_{\text{long}}} + \frac{1}{r_{\text{lat}}} \geq \frac{4}{3d_m}$         | 0.158 in. ≥ 0.091                                         |
| NB-3545.1 Primary crotch membrane stress due to internal pressure | $P_m \leq S_m$ at 500°F<br>$P_m \leq S_m$ at 500°F                                 | Inlet: 16,755 ≤ 18,900 psi<br>Outlet: 14,675 ≤ 18,900 psi |
| NB-3545.2(b) Valve body secondary stresses due to pipe            |                                                                                    |                                                           |
| Direct or axial load effect                                       | $P_{ed} \leq 1.5 S_m$ at 500°F                                                     | 5055 ≤ 28,350 psi                                         |
| Bending load effect                                               | $P_{eb} \leq 1.5 S_m$ at 500°F                                                     | 10,778 ≤ 28,350 psi                                       |
| Torsional load effect                                             | $P_{et} \leq 1.5 S_m$ at 500°F                                                     | 10,210 ≤ 28,350 psi                                       |
| NB-3545.2 Valve body primary plus secondary at stress crotch      | $S_n \leq 3 S_m$ at 500°F                                                          | Inlet: 27,716 ≤ 56,700 psi<br>Outlet: 27,814 ≤ 56,700 psi |
| NB-3545.3 Normal-duty fatigue requirements                        | $2000 \leq N_a$ Hz                                                                 | 2000 ≤ 80,000 Hz                                          |

HNP-2-FSAR-3

**TABLE 3.9-55 (SHEET 4 OF 4)**

| <u>Section III<br/>NB - Paragraph</u> | <u>Criteria</u>                    | <u>Calculated<br/>Versus<br/>Allowable</u> |
|---------------------------------------|------------------------------------|--------------------------------------------|
| NB-3554(b) Cyclic stress              | $S_{n \max} \leq 3 S_m$            | 109,850 $\leq$ 56,700 psi                  |
| NB-3554(c) $K_c$ calculation          | If $S_{n \max} > 3 S_m$            | Allowed per NB-3554(c)                     |
| NB-3553 Fatigue usage                 | $\sum \frac{N_{ri}}{N_i} \leq 1.0$ | 0.9102 $\leq$ 1.0                          |

**TABLE 3.9-56 (SHEET 1 OF 3)**  
**FEEDWATER 18-in. CHECK VALVE**

| <u>Valve Section</u>                              | <u>Criteria</u>                  | <u>Calculated Value Versus Allowable</u> |
|---------------------------------------------------|----------------------------------|------------------------------------------|
| 1. Structural analysis                            |                                  |                                          |
| a. Disc design calculations due to pressure       |                                  |                                          |
| Disc thickness - tensile                          | $S_t \leq S_m$ at 500°F          | 13,426 ≤ 20,800 psi                      |
| Disc thickness - shear                            | $S_s \leq 0.6 S_m$ at 500°F      | 11,157 ≤ 12,480 psi                      |
| b. Cover design calculations                      | $S_{max} \leq S_m$ at 500°F      | 7281 ≤ 20,800 psi                        |
| c. Retainer, gasket design calculations           | $S_s \leq 0.6 S_m$ at 500°F      | 8133 ≤ 25,980 psi                        |
| d. Retainer, hinge pin design calculations        | $S_t \leq S_m$ at 500°F          | 17,103 ≤ 20,800 psi                      |
| e. Body-to-cover joint design calculations        |                                  |                                          |
| Maximum axial stress                              | $Max S_H \leq 1.5 S_m$ at 500°F  | 13,859 ≤ 29,100 psi                      |
| Maximum tangential stress                         | $Max S_T \leq 1.5 S_m$ at 500°F  | 11,429 ≤ 29,100 psi                      |
| Maximum radial stress                             | $Max. S_R \leq 1.5 S_m$ at 500°F | -2425 ≤ 29,100 psi                       |
| Stress intensity (S)                              | $S \leq 1.5 S_m$ at 500°F        | 10,558 ≤ 29,100 psi                      |
| f. Hinge pin retainer bolting                     | $S \leq 2 S_m$ at 500°F          | 45,000 ≤ 57,600 psi                      |
| 2. Seismic analysis - static analysis method used |                                  |                                          |
| a. Valve ends                                     | $S_{max} \leq 0.5 S_y$ at 500°F  | 6698 ≤ 14,550 psi                        |
| b. Valve middle                                   | $S_{max} \leq 0.5 S_y$ at 500°F  | 8115 ≤ 14,550 psi                        |

**TABLE 3.9-56 (SHEET 2 OF 3)**

| Section III<br>NB - Paragraph                                                                            | Criteria                                                     | Calculated Value<br>Versus Allowable                                |
|----------------------------------------------------------------------------------------------------------|--------------------------------------------------------------|---------------------------------------------------------------------|
| 3. Design of pressure-retaining parts and cyclic requirements                                            |                                                              |                                                                     |
| NB-3542 Minimum wall thickness of standard pressure-rated valves                                         | Based on<br>$d_m = 13.25$ in.                                | $t_m = 1.62$ in.                                                    |
| NB-3544.1(a)<br>Radius of crotch                                                                         | $0.3 t_m \leq r_2$                                           | $0.486 \leq 2.12$ in.                                               |
| NB-3544.5 Out of roundness                                                                               |                                                              |                                                                     |
| $\frac{b}{t_b} + \frac{3}{4} \left( \frac{3b^2 - 2ab - a^2}{t_b^2} \right) + 1 \leq 1.5 \frac{S_m}{P_s}$ | Compensated by reinforcement                                 | $20.39 \leq 13.36$                                                  |
| NB-3544.6 Doubly curved section                                                                          | $\frac{1}{r_{long}} + \frac{1}{r_{lat}} \geq \frac{4}{3d_m}$ | $0.101 \geq 0.100$ in.                                              |
| NB-3544.8 Body contours at welding ends                                                                  | $1 \times t_m \leq t_{inlet}$                                | $1.62 \leq 2.98$ in.                                                |
|                                                                                                          | $1 \times t_m \leq t_{outlet}$                               | $1.62 \leq 2.80$ in.                                                |
| NB-3545.1 Primary membrane stress due to internal pressure                                               | $P_m \leq S_m$ at 500°F                                      | Inlet: $11,297 \leq 21,600$ psi<br>Outlet: $13,176 \leq 21,600$ psi |
| NB-3545.2(b) Secondary stress due to pipe reaction                                                       |                                                              |                                                                     |
| Direct or axial load effect                                                                              | $P_{ed} \leq 1.5 S_m$ at 500°F                               | $4455 \leq 32,400$ psi                                              |
| Bending load effect                                                                                      | $P_{eb} \leq 1.5 S_m$ at 500°F                               | $7254 \leq 32,400$ psi                                              |
| Torsional load effect                                                                                    | $P_{et} \leq 1.5 S_m$ at 500°F                               | $7260 \leq 32,400$ psi                                              |
| NB-3545.2 Valve body primary plus secondary stress at crotch                                             | $S_n \leq 3 S_m$ at 500°F                                    | Inlet }<br>Outlet } $26,102 \leq 64,800$                            |
| NB-3545.3 Normal-duty fatigue requirements                                                               | $2000 \leq N_a$ Hz                                           | $2000 \leq 90,000$ Hz                                               |

HNP-2-FSAR-3

**TABLE 3.9-56 (SHEET 3 OF 3)**

| <u>Section III<br/>NB - Paragraph</u> | <u>Criteria</u>                    | <u>Calculated Value<br/>Versus Allowable</u> |
|---------------------------------------|------------------------------------|----------------------------------------------|
| NB-3554(b) Cyclic stress              | $S_{n_{(max)}} \leq 3S_m$          | (a)                                          |
| NB-3554(c) $K_c$ calculation          | If $S_{n_{(max)}} > 3 S_m$         | (a)                                          |
| NB-3553 Fatigue usage                 | $\sum \frac{N_{ri}}{N_i} \leq 1.0$ | (a)                                          |

---

a. Data to be supplied when final calculation is submitted.

TABLE 3.9-57

## DRYWELL PNEUMATIC SYSTEM FILTER ASSEMBLY

Seismic Analysis - Static Analysis Method Used

| <u>Section</u>             | <u>Condition</u> | <u>Criteria</u>                           | <u>Calculated Value Versus Allowable</u> |
|----------------------------|------------------|-------------------------------------------|------------------------------------------|
| Upper section of base legs | Normal + OBE     | $\frac{f_a}{F_a} + \frac{f_b}{F_b} < 1.0$ | 0.0528 < 1.0                             |
|                            | Normal + DBE     | $\frac{f_a}{F_a} + \frac{f_b}{F_b} < 1.0$ | 0.0572 < 1.0                             |
| Lower section of base legs | Normal + OBE     | $\frac{f_a}{F_a} + \frac{f_b}{F_b} < 1.0$ | 0.0386 < 1.0                             |
|                            | Normal + DBE     | $\frac{f_a}{F_a} + \frac{f_b}{F_b} < 1.0$ | 0.0418 < 1.0                             |
| Shell head attachment      | Normal + OBE     | $P_m + P_L + P_b < 1.5 S_m$               | 1539 < 22,500 psi                        |
|                            |                  | $P_m + P_L + P_b + Q < 3.0 S_m$           | 5293 < 45,000 psi                        |
|                            | Normal + DBE     | $P_m + P_L + P_b < 1.5 S_m$               | 1591 < 22,500 psi                        |
|                            |                  | $P_m + P_L + P_b + Q < 3.0 S_m$           | 5343 < 45,000 psi                        |
| Mounting bolts             | Normal + DBE     | $\frac{f_t}{F_t} < 1.0$                   | 0.042 < 1.0                              |

HNP-2-FSAR-3

TABLE 3.9-58 (SHEET 1 OF 3)

FLUED HEAD XB-12

| Loading Condition | Load Combination                                       | Temperature (°F) | Code Stress Category                                                   | Allowable Stress <sup>(a)</sup> |                      | Maximum Stress Intensity |         |       |
|-------------------|--------------------------------------------------------|------------------|------------------------------------------------------------------------|---------------------------------|----------------------|--------------------------|---------|-------|
|                   |                                                        |                  |                                                                        | Basis                           | Value (ksi)          | Value (ksi)              | Element | Theta |
| Design            | P + P <sub>c</sub> + Wt + OBE                          | 562              | $\left\{ \begin{array}{l} P_m \\ P_L \\ P_L + P_b \end{array} \right.$ | S                               | 17.5                 | 12.1 <sup>(c)</sup>      | 354     | 0°    |
|                   |                                                        |                  |                                                                        | 1.5 S                           | 26.3                 |                          |         |       |
|                   |                                                        |                  |                                                                        | 3 S <sub>m</sub>                | 55.2                 |                          |         |       |
| Normal and upset  | P + therm + 2(OBE) + 2(AM) + temperature (328 and 100) | 562              | $\left\{ \begin{array}{l} P_L + P_b \\ + P_c + Q \end{array} \right.$  | y' (S <sub>y</sub> )            | 147.0 <sup>(b)</sup> | 27.6                     | 82      | 180°  |
|                   |                                                        |                  |                                                                        | ---                             | ---                  | 9.7                      | 1-3     | ---   |
| Emergency         | P + P <sub>c</sub> + Wt + therm + DBE + EQ             | 358              | $\left\{ \begin{array}{l} P_m \\ P_L \\ P_L + P_b \end{array} \right.$ | S <sub>y</sub>                  | 31.3                 | 13.1 <sup>(c)</sup>      | 356     | 0°    |
|                   |                                                        |                  |                                                                        | 1.5 S <sub>y</sub>              | 46.9                 |                          |         |       |
|                   |                                                        |                  |                                                                        |                                 |                      |                          |         |       |

HNP-2-FSAR-3

**TABLE 3.9-58 (SHEET 2 OF 3)**

| <u>Loading Condition</u> | <u>Load Combination</u>                       | Temperature<br>(°F) | <u>Allowable Stress<sup>(a)</sup></u> |                    | <u>(<math>\sigma_1 + \sigma_2 + \sigma_3</math>) Maximum</u> |                |              |
|--------------------------|-----------------------------------------------|---------------------|---------------------------------------|--------------------|--------------------------------------------------------------|----------------|--------------|
|                          |                                               |                     | <u>Basis</u>                          | <u>Value (ksi)</u> | <u>Value (ksi)</u>                                           | <u>Element</u> | <u>Theta</u> |
| Design                   | P + P <sub>c</sub> + Wt + OBE                 | 562                 | 4.0 S <sub>m</sub>                    | 73.6               | 12.6                                                         | 347            | 180°         |
| Emergency                | P + P <sub>c</sub> + Wt + Therm +<br>DBE + EQ | 358                 | 4.6S <sub>m</sub>                     | 96.1               | 18.8                                                         | 347            | 180°         |



HNP-2-FSAR-3

**TABLE 3.9-58 (SHEET 3 OF 3)**

| <u>Faulted Condition</u> |                  | <u>Maximum Stress Intensities<sup>(d)</sup> in Critical Areas</u> |                |              |
|--------------------------|------------------|-------------------------------------------------------------------|----------------|--------------|
| <u>Load Location</u>     | <u>Load Type</u> | <u>Value (ksi)</u>                                                | <u>Element</u> | <u>Theta</u> |
| Outside containment      | Axial force      | < 8.5                                                             | At any point   | -            |
|                          | Transverse force | < 8.5                                                             | At any point   | Any position |
|                          | Torsional moment | 25.2                                                              | 88             | -            |
|                          | Bending moment   | 30.9                                                              | 200            | 90°          |
| Inside containment       | Axial force      | < 8.5                                                             | At any point   | -            |
|                          | Transverse force | < 8.5                                                             | At any point   | Any position |
|                          | Torsional moment | 19.6                                                              | 288            | -            |
|                          | Bending moment   | 30.7                                                              | 155            | 0°           |

a. Flued-head material is ASME SA-105, Gr II.

b.  $X = \frac{\text{maximum pressure stress}}{S_y} = \frac{9700}{31,600} = 0.307, \therefore y' (S_y) \sim 4.65 (31,600) = 147 \text{ ksi}$  (Note:  $S_y$  value is for 328°F.)

c. Averaging is not required to satisfy  $P_m$  limits.

d. Values shown must not exceed  $2.4 S_m$  in critical areas indicated in HNP-2 stress calculations. Flued-head material is ASME SA-105, Gr II.  $2.4 S_m = 45.4 \text{ ksi}$  at coincident temperature of 530°F.

HNP-2-FSAR-3

**TABLE 3.9-59 (SHEET 1 OF 3)**  
**FLUED HEADS XB-16A AND B**

| Loading Condition | Load Combination                                      | Temperature (°F) | Code Stress Category                                                             | Allowable Stress <sup>(a)</sup> |                      | Maximum Stress Intensity |         |       |
|-------------------|-------------------------------------------------------|------------------|----------------------------------------------------------------------------------|---------------------------------|----------------------|--------------------------|---------|-------|
|                   |                                                       |                  |                                                                                  | Basis                           | Value (ksi)          | Value (ksi)              | Element | Theta |
| Design            | P + P <sub>c</sub> + Wt + OBE                         | 560              | $\left\{ \begin{array}{l} P_m \\ P_L \\ P_L + P_b \end{array} \right.$           | S                               | 17.5                 | 14.6 <sup>(c)</sup>      | 1       | 180°  |
|                   |                                                       |                  |                                                                                  | 1.5 S                           | 26.3                 |                          |         |       |
|                   |                                                       |                  |                                                                                  | 3 S <sub>m</sub>                | 55.3                 |                          |         |       |
| Normal and upset  | P + therm + 2(OBE) + 2(AM) + temperature (125 and 50) | 560              | $\left\{ \begin{array}{l} P_L + P_b + P_c + Q \\ \text{---} \end{array} \right.$ | y' (S <sub>y</sub> )            | 125.0 <sup>(b)</sup> | 34.1                     | 410     | 0°    |
|                   |                                                       |                  |                                                                                  | ---                             | ---                  | 12.0                     | 1       | ---   |
| Emergency         | P + P <sub>c</sub> + Wt + OBE                         | 195              | $\left\{ \begin{array}{l} P_m \\ P_L \\ P_L + P_b \end{array} \right.$           | S <sub>y</sub>                  | 33.0                 | 6.8 <sup>(c)</sup>       | 3       | 180°  |
|                   |                                                       |                  |                                                                                  | 1.5 S <sub>y</sub>              | 49.5                 |                          |         |       |
|                   |                                                       |                  |                                                                                  |                                 |                      |                          |         |       |

HNP-2-FSAR-3

**TABLE 3.9-59 (SHEET 2 OF 3)**

| <u>Loading Condition</u> | <u>Load Combination</u>       | Temperature<br>(°F) | <u>Allowable Stress<sup>(a)</sup></u> |                    | <u>(<math>\sigma_1 + \sigma_2 + \sigma_3</math>) Maximum</u> |                |              |
|--------------------------|-------------------------------|---------------------|---------------------------------------|--------------------|--------------------------------------------------------------|----------------|--------------|
|                          |                               |                     | <u>Basis</u>                          | <u>Value (ksi)</u> | <u>Value (ksi)</u>                                           | <u>Element</u> | <u>Theta</u> |
| Design                   | P + P <sub>c</sub> + Wt + OBE | 560                 | 4S <sub>m</sub>                       | 73.8               | 14.3                                                         | 12             | 0°           |
| Emergency                | P + P <sub>c</sub> + Wt + OBE | 195                 | 4.6S <sub>m</sub>                     | 101.2              | 7.1                                                          | 12             | 0°           |

HNP-2-FSAR-3

**TABLE 3.9-59 (SHEET 3 OF 3)**

| <u>Faulted Condition</u> |                  | <u>Maximum Stress Intensities<sup>(d)</sup> in Critical Areas</u> |                |              |
|--------------------------|------------------|-------------------------------------------------------------------|----------------|--------------|
| <u>Load Location</u>     | <u>Load Type</u> | <u>Value (ksi)</u>                                                | <u>Element</u> | <u>Theta</u> |
| Outside containment      | Axial force      | < 5.0                                                             | At any point   | -            |
|                          | Transverse force | < 8.0                                                             | At any point   | Any position |
|                          | Torsional moment | 21.9                                                              | 138            | -            |
|                          | Bending moment   | 27.4                                                              | 220            | 90°          |
| Inside containment       | Axial force      | < 5.0                                                             | At any point   | -            |
|                          | Transverse force | < 9.0                                                             | At any point   | Any position |
|                          | Torsional moment | 20.4                                                              | 306            | -            |
|                          | Bending moment   | 26.6                                                              | 236            | 90°          |

a. Flued-head material is ASME SA-105, Gr II.

b.  $X = \frac{\text{maximum pressure stress}}{S_y} = \frac{12,000}{35,200} = 0.341$ ,  $\therefore y' (S_y) \sim 3.55 (35,200) = 125 \text{ ksi}$  - - (Note:  $S_y$  value is for 125°F.)

c. Averaging is not required to satisfy  $P_m$  limits.

d. Values shown must not exceed  $0.7 S_y$  or  $2.4 S_m$ , whichever is less, in critical areas indicated in HNP-2 stress calculations. Flued-head material is ASME SA-105, Gr II.  $2.4 S_m = 44.8 \text{ ksi}$  at coincident temperature of 546°F.

HNP-2-FSAR-3

TABLE 3.9-60 (SHEET 1 OF 3)

FLUED HEADS XB-36

| <u>Loading Condition</u> | <u>Load Combination</u>                    | <u>Temperature (°F)</u> | <u>Code Stress Category</u>                                            | <u>Allowable Stress <sup>(a)</sup></u> |                    | <u>Maximum Stress Intensity</u> |                |              |
|--------------------------|--------------------------------------------|-------------------------|------------------------------------------------------------------------|----------------------------------------|--------------------|---------------------------------|----------------|--------------|
|                          |                                            |                         |                                                                        | <u>Basis</u>                           | <u>Value (ksi)</u> | <u>Value (ksi)</u>              | <u>Element</u> | <u>Theta</u> |
| Design                   | P + P <sub>c</sub> + Wt + OBE              | 340                     | $\left\{ \begin{array}{l} P_m \\ P_L \\ P_L + P_b \end{array} \right.$ | S                                      | 15.3               | 9.2 <sup>(b)</sup>              | 1              | 180°         |
|                          |                                            |                         |                                                                        | 1.5 S                                  | 23.0               |                                 |                |              |
|                          |                                            |                         |                                                                        |                                        |                    |                                 |                |              |
| Normal and upset         | P + therm + 2(OBE) + 2(AM) + temperature   | 150                     | $\left\{ \begin{array}{l} P_L + P_b \\ + P_c + Q \end{array} \right.$  | 3 S <sub>m</sub>                       | 60.0               | 21.8                            | 3              | 180°         |
| Emergency                | P + P <sub>c</sub> + Wt + therm + DBE + EQ | 150                     | $\left\{ \begin{array}{l} P_m \\ P_L \\ P_L + P_b \end{array} \right.$ | S <sub>y</sub>                         | 27.5               | 21.2                            | 3              | 180°         |
|                          |                                            |                         |                                                                        |                                        |                    |                                 |                |              |
|                          |                                            |                         |                                                                        | 1.5 S <sub>y</sub>                     | 41.2               |                                 |                |              |

HNP-2-FSAR-3

**TABLE 3.9-60 (SHEET 2 OF 3)**

| <u>Loading Condition</u> | <u>Load Combination</u>                    | Temperature<br>(°F) | <u>Allowable Stress</u> <sup>(a)</sup> |                    | <u>(<math>\sigma_1 + \sigma_2 + \sigma_3</math>) Maximum</u> |                |              |
|--------------------------|--------------------------------------------|---------------------|----------------------------------------|--------------------|--------------------------------------------------------------|----------------|--------------|
|                          |                                            |                     | <u>Basis</u>                           | <u>Value (ksi)</u> | <u>Value (ksi)</u>                                           | <u>Element</u> | <u>Theta</u> |
| Design                   | P + P <sub>c</sub> + Wt + OBE              | 340                 | 4 S <sub>m</sub>                       | 78                 | 9.8                                                          | 351            | 180°         |
| Emergency                | P + P <sub>c</sub> + Wt + therm + DBE + EQ | 150                 | 4.6 S <sub>m</sub>                     | 92                 | 26.9                                                         | 12             | 0°           |

HNP-2-FSAR-3

**TABLE 3.9-60 (SHEET 3 OF 3)**

| <u>Faulted Condition</u> |                  | <u>Maximum Stress Intensities<sup>(d)</sup> in Critical Areas</u> |                |              |
|--------------------------|------------------|-------------------------------------------------------------------|----------------|--------------|
| <u>Load Location</u>     | <u>Load Type</u> | <u>Value (ksi)</u>                                                | <u>Element</u> | <u>Theta</u> |
| Outside containment      | Axial force      | < 5.0                                                             | At any point   |              |
|                          | Transverse force | < 5.0                                                             | At any point   | Any position |
|                          | Torsional moment | 12.6                                                              | 96             |              |
|                          | Bending moment   | 14.1                                                              | 176            | 90°          |
| Inside containment       | Axial force      | < 5.0                                                             | At any point   |              |
|                          | Transverse force | < 5.0                                                             | At any point   | Any position |
|                          | Torsional moment | 12.5                                                              | 292            |              |
|                          | Bending moment   | 13.8                                                              | 192            | 90°          |

a. Flued-head material is ASME SA-182, F-304.

b. Averaging is not required to satisfy  $P_m$  limits.

c. Values shown must not exceed  $2.4 S_m$  in critical areas indicated in HNP-2 stress calculations. Flued-head material is ASME SA-182, F-304.  
 $2.4 S_m = 48.0$  ksi at coincident temperature of 80°F.

HNP-2-FSAR-3

TABLE 3.9-61 (SHEET 1 OF 2)

LIQUID NITROGEN STORAGE TANK AND RELATED PIPING

| <u>Component</u>                | <u>Method of Analysis</u> | <u>Type of Stress</u>                                      | <u>Maximum Stress (psi)</u> | <u>Allowable Stress (psi)</u> |
|---------------------------------|---------------------------|------------------------------------------------------------|-----------------------------|-------------------------------|
| Control piping (size)           | ASME Section III          | Primary (weight, pressure, DBE)                            |                             |                               |
| 1/2 in.                         |                           |                                                            | 2733                        | 18,800                        |
| 3/4 in.                         |                           |                                                            | 5191                        | 18,800                        |
| 1 in.                           |                           |                                                            | 2817                        | 18,800                        |
| 1 1/2 in.                       |                           |                                                            | 2220                        | 18,800                        |
| 1/2 in.                         |                           | Secondary (thermal)                                        | 17,627                      | 28,200                        |
| 3/4 in.                         |                           |                                                            | 23,090                      | 28,200                        |
| 1 in.                           |                           |                                                            | 6678                        | 28,200                        |
| 1 1/2 in.                       |                           | Primary plus secondary<br>(weight, pressure, DBE, thermal) | 31,239                      | 46,000                        |
| Ambient vaporizer piping (size) | ASME Section III          | Primary (weight, pressure, DBE)                            |                             |                               |
| 1/2-in. tube                    |                           |                                                            | 10,600                      | 18,800                        |
| 1/2-in. pipe                    |                           |                                                            | 400                         | 18,800                        |
| 1 1/2-in. pipe                  |                           |                                                            | 16,940                      | 18,800                        |
| fin                             |                           |                                                            | 62                          | 18,800                        |
|                                 |                           | Secondary (thermal)                                        | 15,128                      | 28,200                        |
|                                 |                           |                                                            | 5509                        | 28,200                        |
|                                 |                           |                                                            | Negligible                  | 28,200                        |
|                                 |                           |                                                            | 91                          | 28,200                        |
| Ambient vaporizer base beam     | ASME Section III          | Bending                                                    | 6630                        | 11,000                        |
| Inner vessel (shell)            | ASME Section VIII         | Primary (pressure, weight, OBE)                            | 7112                        | 18,800                        |
|                                 |                           | Primary (pressure, weight, DBE)                            | 5348                        | 27,000                        |



HNP-2-FSAR-3

**TABLE 3.9-61 (SHEET 2 OF 2)**

| <u>Component</u>                                         | <u>Method of Analysis</u>                      | <u>Type of Stress</u>           | <u>Maximum Stress (psi)</u> | <u>Allowable Stress (psi)</u> |
|----------------------------------------------------------|------------------------------------------------|---------------------------------|-----------------------------|-------------------------------|
| Inner vessel flange                                      | ASME Section VIII                              | Primary (pressure, weight, OBE) | 13,546                      | 18,800                        |
|                                                          |                                                | Primary (pressure, weight, DBE) | 16,366                      | 27,000                        |
| Annular space piping lines<br>A<br>B<br>C<br>D<br>E<br>F | ASME Section III                               | Primary (pressure, weight, DBE) |                             |                               |
|                                                          |                                                |                                 | 2360                        | 18,800                        |
|                                                          |                                                |                                 | 2520                        | 18,800                        |
|                                                          |                                                |                                 | 3000                        | 18,800                        |
|                                                          |                                                |                                 | 4980                        | 18,800                        |
|                                                          |                                                |                                 | 1796                        | 18,800                        |
|                                                          |                                                |                                 | 2495                        | 18,800                        |
| lines<br>A<br>B<br>C<br>D<br>E<br>F                      | Cantilever method                              | Secondary (thermal)             | Actual                      | < 28,200                      |
|                                                          |                                                |                                 | Actual                      | < 28,200                      |
|                                                          |                                                |                                 | Actual                      | < 28,200                      |
|                                                          |                                                |                                 | Actual                      | < 28,200                      |
|                                                          |                                                |                                 | Actual                      | < 28,200                      |
|                                                          |                                                |                                 | Actual                      | < 28,200                      |
| Jacketed pressure vessel rings                           | Zick method                                    | Primary (pressure, weight, OBE) | 17,569                      | 19,800                        |
|                                                          |                                                | Primary (pressure, weight, DBE) | 28,453                      | 29,700                        |
| Saddle support                                           | "Process Equipment Design," Brownell and Young | Bending (weight + DBE)          | 8600                        | 32,400                        |
|                                                          |                                                | Circumferential (weight + DBE)  | 3700                        | 21,520                        |

HNP-2-FSAR-3

TABLE 3.9-62

REACTOR BUILDING SAFEGUARD SYSTEM COOLING UNITS

| <u>Component</u>        | <u>Method of Analysis</u> | <u>Type of Stress</u>                          | <u>Maximum Stress</u> | <u>Allowable Stress (AISC)</u> |
|-------------------------|---------------------------|------------------------------------------------|-----------------------|--------------------------------|
| Fan (Unit 2T41-B001)    | Modal spectrum            | Deflection combined<br>(weight, pressure, DBE) | 0.0035 in.            | 0.025 in                       |
| Plenum/cooler walls     |                           |                                                | 3340 psi              | 21,600 psi                     |
| Plenum/cooler top       |                           |                                                | 4830 psi              | 21,600 psi                     |
| Fan guide vanes         |                           |                                                | 760 psi               | 21,000 psi                     |
| Motor-mounting disc     |                           |                                                | 1310 psi              | 21,000 psi                     |
| Motor shaft             |                           |                                                | 2260 psi              | 32,000 psi                     |
| Fan shaft               |                           |                                                | 5850 psi              | 32,000 psi                     |
| Intermediate tube sheet |                           |                                                | 410 psi               | 18,000 psi                     |
| Foundation bolts        |                           |                                                | 950 psi               | 21,000 psi                     |
| Cooling coil tubes      |                           |                                                | 790 psi               | 13,200 psi                     |
| Fan (Unit 2T41-B002)    | Modal spectrum            | Deflection                                     | 0.0021 in.            | 0.050 in                       |
| Motor shaft             |                           |                                                | 1630 psi              | 32,000 psi                     |
| Fan shaft               |                           |                                                | 2460 psi              | 32,000 psi                     |
| Guide vanes             |                           |                                                | 150 psi               | 21,000 psi                     |
| Motor-mounting disc     |                           |                                                | 1230 psi              | 21,000 psi                     |
| Fan brackets            |                           |                                                | 10 psi                | 21,000 psi                     |
| Mounting bolts          |                           |                                                | 1500 psi              | 21,000 psi                     |
| Fan (Unit 2T41-B005)    | Modal spectrum            | Deflection combined<br>(weight, pressure, DBE) | 0.0040 in.            | 0.025 in                       |
| Plenum/cooler walls     |                           |                                                | 2200 psi              | 21,600 psi                     |
| Plenum/cooler top       |                           |                                                | 4940 psi              | 21,600 psi                     |
| Fan guide vanes         |                           |                                                | 770 psi               | 21,000 psi                     |
| Motor-mounting disc     |                           |                                                | 1120 psi              | 21,000 psi                     |
| Motor shaft             |                           |                                                | 1650 psi              | 32,000 psi                     |
| Fan shaft               |                           |                                                | 2470 psi              | 32,000 psi                     |
| Tube support            |                           |                                                | 915 psi               | 18,550 psi                     |
| Foundation bolts        |                           |                                                | 920 psi               | 21,000 psi                     |
| Cooling coil tubes      |                           |                                                | 3103 psi              | 18,550 psi                     |

HNP-2-FSAR-3

**TABLE 3.9-63**  
**SGTS BLOWER**

| <u>Component</u>       | <u>Method of Analysis</u> | <u>Type of Stress</u> | <u>Maximum Stress</u> | <u>Allowable Stress (AISC)</u> |
|------------------------|---------------------------|-----------------------|-----------------------|--------------------------------|
| Fan shaft              | Static                    | Shear (weight + DBE)  | 2350                  | 12,400                         |
|                        |                           | Normal (weight + DBE) | 4700                  | 20,700                         |
| Fan shaft bearings     | Local rating              | NA <sup>(a)</sup>     | (2.91 safety factor)  |                                |
| Bearing support angles | Standard structural       | Bending               | 6596                  | 32,400                         |


a. NA - not applicable.

HNP-2-FSAR-3

**TABLE 3.9-64**

**SERVICE WATER TO DIESEL EXPANSION JOINTS**

| <u>Component</u> | <u>Method of Analysis</u> | <u>Type of Stress</u>    | <u>Maximum Stress</u> | <u>Allowable Stress (AISC)</u> |
|------------------|---------------------------|--------------------------|-----------------------|--------------------------------|
| Bellows          | ASME, Section III         | Primary (DBE + Pressure) | 22,500                | 27,000                         |



REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

DYNAMIC MODEL OF RPV AND INTERNALS

FIGURE 3.9-1

### **3.10 SEISMIC DESIGN OF SEISMIC CATEGORY I INSTRUMENTATION AND ELECTRICAL EQUIPMENT**

#### **3.10.1 SEISMIC DESIGN CRITERIA**

Subsection 3.2.1 and tables 3.10-1 and 3.10-21 provide a listing of Seismic Category I mechanical, instrumentation, and electrical equipment requiring seismic qualifications.

##### **3.10.1.1 General**

The Seismic Category I mechanical, instrumentation, and electrical equipment is designed to withstand the effects of the design basis earthquake (DBE) and to remain functional during normal and accident conditions.

The parameters used to develop seismic loadings and criteria for nonnuclear steam supply system and nuclear steam supply system (NSSS) Category I structures, systems, and components are described in supplements 3.7A and 3.7B, respectively. The performance requirements of Seismic Category I items and their respective supports are structural as well as functional. The actual service mounting of the equipment was considered in establishing seismic functional capability.

The seismic criterion used in the design and subsequent qualification of all Class 1E instrumentation and electrical equipment supplied by General Electric (GE) is applicable when required for any safety design basis and is as follows:

The Class 1E equipment is capable of performing all safety-related functions during normal plant operation, anticipated transients, design basis accidents (DBAs), and post-accident operation, while being subjected to and after the cessation of the accelerations resulting from the DBE at the point of attachment of the equipment to the building or supporting structure.

The specific criteria for each of the many Class 1E systems are covered in chapter 7. The criteria for each of the devices used in the many Class 1E systems depend on the use in a given system; e.g., a relay in one system may have as its safety function to deenergize and open its contacts within a certain time, while in another system it must energize and close its contacts. Since GE supplies many devices for numerous applications, the approach taken was to test the device in all modes that might be used. In this way, the capability of protective action initiation and the proper operation of safety-feature circuits are assured.

##### **3.10.1.2 Emergency Power System and Engineered Safety Features Actuation System**

In addition to the general criteria described in paragraph 3.10.1.1, the standby power system and Seismic Category I instrumentation and electrical equipment associated with engineered safety features (ESFs) are designed to withstand seismic disturbances having the intensity of the DBE during post-accident operation.

**3.10.1.3 Compliance With Institute of Electrical and Electronic Engineers (IEEE) Standard 344-1971**

Qualification and documentation procedures used for Seismic Category I equipment and/or systems other than the NSSS meet the provisions of either IEEE Standard 344-1971, as amended by supplements 3.7A and 3.7A.A, or IEEE 344-1975.

GE-supplied Class 1E equipment meets the requirement that the seismic qualification should demonstrate the capability to perform the required function during and after the DBE. Both analysis and testing were used, but most equipment was tested. Analysis was used to determine the adequacy of mechanical strength (mounting bolts, etc.) after operating capability was established by testing.

GE-supplied Class 1E equipment with primarily mechanical safety functions (pressure boundary devices, etc.) was analyzed since the passing nature of its critical safety role usually made testing impractical. Analytical methods sanctioned by IEEE-344-1971 were used in such cases. (See table 3.10-1 for indication of the items that were qualified by analysis.)

GE-supplied Class 1E equipment having primarily active electrical safety function was tested in compliance with IEEE-344-1971, Section 3.2.

The documentation verifying the seismic qualification of GE-supplied Class 1E equipment is in accordance with the requirements of IEEE-344-1971, Section 4.

**3.10.2 SEISMIC ANALYSIS, TESTING PROCEDURES, AND RESTRAINT MEASURES**

**3.10.2.1 Equipment Other Than NSSS**

Seismic Category I mechanical, instrumentation, and electrical equipment and components other than the NSSS are designed to ensure functional integrity for the specific operation requirements categorizing them as Seismic Category I. An investigation of the equipment is required to demonstrate its ability to withstand seismic forces without loss of function.

Non-NSSS Seismic Category I equipment installed at HNP-2 was seismically qualified in accordance with either IEEE 344-1971, as amended by supplements 3.7A and 3.7A.A, or IEEE 344-1975. In addition, the qualification of some non-NSSS equipment was established using the criteria developed by the Seismic Qualification Utility Group (SQUG) and documented in the Generic Implementation Procedure (GIP), Revision 2.

There are no control systems components with natural frequencies below 5 Hz.

Various phases and/or processes are associated with the specification, procurement, and acceptance of Seismic Category I mechanical, instrumentation, and electrical equipment supplied for HNP-2. Beginning with the recognized need that the equipment or component must provide, an inquiry specification certified by a registered professional engineer is developed and issued. This specification describes the equipment or component required in terms of design

## HNP-2-FSAR-3

code applicability, seismic requirements, and other pertinent parameters to be applied during fabrication and design.

The inquiry specification issued, dealing with the seismic requirements for the equipment or component, details the essentials associated with the HNP-2 DBE and operating basis earthquake (OBE), as applicable. The following excerpt from the inquiry specification for the plant service water (PSW) pumps is a typical example of such specification requirements:

### EXAMPLE

#### 5.2 SEISMIC REQUIREMENTS

- 5.2.1 The RHR service water and plant service water pumps are designated as seismic Class 1 equipment and shall be designed in accordance with the following criteria.
- 5.2.2 OPERATING BASIS EARTHQUAKE (OBE) - The pumps and motors shall be designed to withstand, without exceeding normal allowable working stresses and without loss of function, the combination of normal loads plus the forces resulting from the "operating basis earthquake" (OBE), caused by a maximum horizontal ground acceleration of .08 g and maximum vertical ground acceleration of .054 g. The final OBE seismic response spectra curves are enclosed.
  - 5.2.2.1 It is believed that a multi-degree-of-freedom system will be required to adequately model the equipment. A modal analysis using the response spectra to be furnished and the appropriate damping factor from Table 1 [not supplied] should be performed.
  - 5.2.2.2 A single-degree-of-freedom system may be acceptable if it can be justified by the pump manufacturer. In this case, determine the natural frequency of the equipment and from each curve of response spectra select the acceleration corresponding to the natural frequency. If it is not practical to determine the natural frequency of the equipment, use the maximum acceleration of the response spectra curves.
  - 5.2.2.3 The forces resulting from the vertical acceleration of the equipment shall be assumed to act simultaneously with the forces resulting from the horizontal accelerations.
  - 5.2.2.4 The stresses resulting from the horizontal and vertical accelerations shall be combined directly, linearly, and in the most unfavorable direction with the stresses resulting from other loading conditions.



EXAMPLE (continued)

- 5.2.3 DESIGN BASIS EARTHQUAKE (DBE) - The pumps and motors shall be designed to withstand, without exceeding 90% of yield stresses, and without loss of function, the normal loads plus the forces resulting from the "design basis earthquake" (DBE) caused by a maximum horizontal ground acceleration of .15 g and a maximum vertical ground acceleration of .10 g. The procedure used for the analysis shall be as given in Paragraph 5.2; however, response spectra and percent damping for the DBE shall be used. The final DBE seismic response spectra curves are enclosed.
- 5.2.4 Certification - The pump and motor manufacturer must furnish certification that his equipment is designed in accordance with the above seismic requirements. Certification may consist of either:
- (a) Calculations checked by an engineer knowledgeable in the design of such equipment, or
  - (b) Written certification that equipment has successfully passed the tests of equal or higher forces and more severe vibration exposure than stated in the above seismic requirement, with a description and the results of such tests clearly stated.
- 5.2.5 Complete calculations and/or test data for certification of the equipment furnished shall be submitted by the manufacturer. All calculations submitted should include the description and justification of the method used and the results of the calculations or test.
- 5.2.6 Response Spectra Data Furnished [not supplied]
- Figure 1 - Horizontal Response Spectra el. 111'-0",  
Figure 2 - Service Water Intake Structure
- Figure 3 - Horizontal Response Spectra, el. 88'-9",  
Figure 4 - River Intake Structure
- Figure 5 - Vertical Response Spectra, el. 111' -0",  
Service Water Intake Structure
- Figure 6 - Vertical Response Spectra, el. 88'-9",  
River Intake Structure
- Table 1 - Percentage of Critical Damping

## EXAMPLE (continued)

5.2.7 Reference

AEC publication TID 7024 "Nuclear Reactor and Earthquakes" is used as the basic design guide for seismic analysis.

## END OF EXAMPLE

As stated in paragraph 5.2.4 of the specification excerpt, the vendor must provide certification, either by a calculation or test report, that his equipment is designed in accordance with the seismic requirements specified. Upon receipt of the vendor's certification, an engineer familiar with the methods employed reviews the certification submitted with the objective being to concur with calculational models, assumptions, and conclusions or testing methods and results. This review is based on the vendor's conformance to the requirements specified in the inquiry specification. Formal written notification of concurrence/nonconformance is forwarded to the vendor upon completion of the review.

Table 3.10-4 provides a list of the major balance-of-plant (BOP) Category I equipment that the NRC Seismic Qualification Review Team reviewed during their seismic audit of HNP-2. This table provides the reasons for determining whether test or analysis or a combination of the two was chosen as the acceptable means for seismic qualification for each item, as well as provides the seismic qualification method(s) used.

A discussion of the parameters used for functional and structural seismic capability verification and the qualification levels and acceptance criteria for each item in table 3.10-4 is as follows:

600-V Station Service Switchgear1. Method of qualification - testing<sup>(a)</sup>

- Sinusoidal vibration tests.
- Inclined shock tests.
- San Fernando Valley earthquake experience.

## 2. Summary of results

- Sinusoidal vibration tests.
  - Input frequency                      Single

---

a. Three copies of the GE Seismic Qualification Report 72LSP-1 were submitted to the NRC for evaluation.

HNP-2-FSAR-3

- Input motion Sinusoidal sweep and dwell
- Single-axis tests Three axes independently
- a. AKD-5 Switchgear
  - Natural frequency - 9 Hz
  - Input horizontal acceleration - 0.5 g
  - Input vertical acceleration - 0.5 g
  - Test response spectrum (TRS) versus required response spectrum (RRS)  
(See figure 3.10-1.)

|                                             |                   |                 |
|---------------------------------------------|-------------------|-----------------|
| b. AK-50 Breaker                            | <u>Horizontal</u> | <u>Vertical</u> |
| - Natural frequency                         | 29 Hz             | 30 Hz           |
| - Input maximum acceleration                | 5 g               | 2.5 g           |
| - Maximum acceleration at mounting location | 2.2 g             | 2.3 g           |

|                                             |                   |                 |
|---------------------------------------------|-------------------|-----------------|
| c. AK-25 Breaker                            | <u>Horizontal</u> | <u>Vertical</u> |
| - Natural frequency                         | 44 Hz             | 60 Hz           |
| - Input maximum acceleration                | 3 g               | 10 g            |
| - Maximum acceleration at mounting location | 2.2 g             | 2.3 g           |

- Inclined shock tests.
  - a. AKD-5 switchgear - biaxially
    - Shock input - 40 g
  - b. AK-50 and AK-25 breakers
    - Shock input - 15 g
- San Fernando Valley earthquake experience.

The location of installation was Sylmar, California, southern terminal of the West Coast HVDC transmission line.

The estimated ground acceleration was 0.3 g to 0.5 g by Dr. G. Housner.

## HNP-2-FSAR-3

### 3. Functional verifications

- No structural damage to the switchgear was observed.
- Breakers normally in the closed position remain closed due to vibration.

### 4. Justifications of single-axis testing

- Equipment has minimum cross coupling in axis orthogonal to the axis of applied vibration.
- The TRS exceeded the RRS by a significant margin.

### 5. Justification of single-frequency testing

- The RRS for the equipment shows a predominant peak response at the fundamental frequency of the structure.
- The lowest frequency of the switchgear was measured to be 9 Hz. The transmissibility value at the breaker position was very low, < 1.3 at that frequency. The lowest frequency of 9 Hz is in the portion of the response spectrum in which there is no significant change in spectral acceleration with increasing frequencies. Therefore, the equipment can be classified as rigid, and higher-mode contributions are insignificant.
- The TRS exceeded the RRS by a significant margin.

## 600 V-ac Motor Control Center (MCC)

### 1. Method of qualification - testing

### 2. Summary of results

- Input frequency (Hz) Single
- Input acceleration (g) See table 3.10-5.
- Input motion Sinusoidal dwell
- RRS versus TRS See table 3.10-5.
- Single-axis tests Three axes independently
- TRS versus RRS See figures 3.10-2 through 3.10-7.

## HNP-2-FSAR-3

### 3. Functional verifications

Circuits were monitored to verify that normal operating positions were unchanged.

#### Battery Charger (new)

##### 1. Method of qualification - testing - IEEE 344-1975

##### 2. Summary of results

- Input motion.
  - Random multifrequency test
  - Random-wave-form motion (30-s duration)
- Axis of test.
  - Side to side and vertical
  - Front to front and vertical
  - (Simultaneous horizontal and vertical)
- Input acceleration (See table 3.10-6.).
- TRS versus RRS (See figure 3.10-8.).

##### 3. Functional verifications

Three channels of electrical monitoring were recorded on an oscillograph recorder during the test. These channels were used to ascertain any change in the input voltage, output current, and output voltage prior to, during, and after the test. It was demonstrated that the specimen possessed sufficient integrity to withstand, without compromise of electrical function, the prescribed simulated seismic environment.

#### Large Induction Motors

Calculated  
Stress

---

OBE

DBE

##### 1. Method of qualification - dynamic analysis

HNP-2-FSAR-3

|    |                                                           | <u>Calculated Stress</u> |            |
|----|-----------------------------------------------------------|--------------------------|------------|
|    |                                                           | <u>OBE</u>               | <u>DBE</u> |
| 2. | Summary of results                                        |                          |            |
| •  | Rotor-shaft assembly and bearings.                        |                          |            |
| -  | Shaft deflection                                          | -                        | 0.273      |
| -  | Shaft stresses                                            | 0.735                    | -          |
| -  | Bearing loading                                           |                          |            |
| ❖  | Guide bearings                                            | -                        | 0.675      |
| ❖  | Guide bearing minimum oil film thickness                  | -                        | -          |
| ❖  | Guide bearing contact stresses at motor standstill        | -                        | 0.174      |
| -  | Thrust bearing loading                                    | -                        | 0.996      |
| -  | Bearing loading for hydraulic upthrust conditions         | -                        | 1.000      |
| -  | Journal sleeve locknuts                                   | -                        | -          |
| •  | Endshield assemblies.                                     |                          |            |
| -  | Lower endshield assembly                                  |                          |            |
| ❖  | Bearing housing stresses                                  | 0.140                    | 0.084      |
| ❖  | Stator frame - lower endshield joint fasteners            | 0.846                    | 0.149      |
| ❖  | Stresses at rabbit fit between stator and lower endshield | 0.525                    | 0.315      |
| ❖  | Maximum stress in body of lower endshield                 | 0.140                    | 0.084      |

HNP-2-FSAR-3

|    |                                                        | <u>Calculated Stress</u> |            |
|----|--------------------------------------------------------|--------------------------|------------|
|    |                                                        | <u>OBE</u>               | <u>DBE</u> |
| -  | Upper endshield assembly                               |                          |            |
| ❖  | Bearing housing stresses                               | 0.251                    | 0.151      |
| ❖  | Bearing housing fasteners                              | -                        | 0.397      |
| ❖  | Stator frame - upper endshield joint fasteners         | 0.647                    | 0.114      |
| ❖  | Discussion regarding maximum stress in upper endshield | 0.772                    | 0.463      |
| •  | Stator.                                                |                          |            |
| -  | Maximum stress in body of stator frame                 | -                        | 0.639      |
| -  | Stator core supports                                   | 0.108                    | 0.033      |
| -  | End turn support system                                | -                        | -          |
| •  | Motor base.                                            |                          |            |
| -  | Base fasteners                                         | 0.658                    | 0.116      |
| -  | Maximum stress in base                                 | 0.170                    | 0.102      |
| •  | Conduit box and miscellaneous components.              |                          |            |
| -  | Conduit box                                            | 0.091                    | 0.016      |
| -  | Screens                                                | 0.080                    | 0.024      |
| -  | Top cap                                                | 0.020                    | 0.003      |
| 3. | Structural verifications                               |                          |            |

Stresses at critical locations were verified to be less than the allowable stresses. Structural integrity of the equipment was maintained under the seismic environment.

## HNP-2-FSAR-3

### 4. Conservatism used in the seismic analysis are as follows:

- The motors were analyzed for horizontal accelerations of 0.48 g (OBE) and 0.85 g (DBE). The seismic analysis for the intake structure where these motors are located indicates that the required horizontal accelerations are 0.15 g (OBE) and 0.39 g (DBE).
- The allowables for thrust bearing loading and for bearing loading for hydraulic upthrust conditions were based on a constant loading throughout the operation of the pump motors. The maximum loadings of the bearings occurring during the entire duration of the earthquake were compared with allowables established for the constant loading for motor operation.

### Power Transformers

#### 1. Method of qualification - analysis

#### 2. Summary of results

- Natural frequency (Hz)
  - Core and coil 28.1
  - Tank 66
  - Low-voltage bar 43.6
- Input horizontal acceleration (g) 0.37
- Input vertical acceleration (g) 0.21
- Comparison of actual and allowable stresses.



HNP-2-FSAR-3

| <u>Component</u>  | <u>Material<br/>GE Spec No.</u> | <u>Actual<br/>Stress<br/>(psi)</u> | <u>Minimum<br/>Yield (psi)</u> | <u>Actual<br/>Minimum-Yield<br/>Stress</u> |
|-------------------|---------------------------------|------------------------------------|--------------------------------|--------------------------------------------|
| Tank plate ends   | Steel<br>B8A3X                  | 21,587                             | 30,000                         | 0.720                                      |
| Tank plate fronts | Steel<br>B8A3X                  | 25,184                             | 30,000                         | 0.839                                      |
| Tank braces       | Steel<br>B8A3X                  | 17,811                             | 30,000                         | 0.594                                      |
| Base-plate        | Steel<br>B50P520                | 12,853                             | 38,000                         | 0.338                                      |
| Top clamp         | Steel<br>B50P517                | 33,091                             | 38,000                         | 0.871                                      |
| Bottom clamp      | Steel<br>B50P520                | 11,165                             | 38,000                         | 0.294                                      |
| Clamp stud        | Steel<br>B50P519                | 863                                | 25,000                         | 0.035                                      |
| X bar bolt        | Steel<br>C1L2                   | 3458                               | 34,000                         | 0.102                                      |
| LV bars           | CU<br>B11B5                     | 707                                | 10,000                         | 0.071                                      |

3. Structural verifications

Stresses at critical locations were verified to be less than the allowable stresses. Structural integrity was maintained under the seismic environment.

100-kW Inverters

1. Method of qualification - testing in accordance with IEEE-344-1975
2. Summary of results
  - Input motion.
    - Random multifrequency test
    - Random-wave-form motion (30-s duration)

## HNP-2-FSAR-3

- Axis of test.
  - Side to side and vertical
  - Front to front and vertical
  - (Simultaneous horizontal and vertical)
- Damping - 3%.
- Input acceleration. (See table 3.10-7.)
- TRS versus RRS. (See figure 3.10-9.)

### 3. Functional verifications

Three channels of electrical monitoring were recorded on an oscillograph recorder during the test. These channels were used to monitor the three 575 V-ac, 60-Hz, 3-phase outputs of the specimen. The specimen was tested in the energized no-load condition. No abnormal voltage levels or spurious operations were indicated by the electrical monitoring during the seismic tests. The specimen continued to function at the proper output voltage when the short-circuit fault was applied and removed.

### Diesel Engine Generating Unit<sup>(a)</sup>

12-cylinder 8 1/8 x 10 turbocharged engine

3250 kW at 900 rpm

1. Method of qualification - combined testing and dynamic analysis
2. Summary of results
  - The following components were analyzed for seismic requirements:
    - Engine generator - skid assembly
    - Heat exchanger stack assembly
    - Lube oil filter
    - Fuel oil day tank (1000 gal)

---

a. Three copies of the Colt Industries Seismic Calculation Report were submitted to the NRC for evaluation.

- Jacket water expansion tank

## HNP-2-FSAR-3

- Air compressor skid
- Air receiver tank
- The following components have been qualified by tests:
  - Basley relays
  - Clark control relays

### Engine Generator Skid Assembly

#### Horizontal Frequencies (Hz)

$$f_1 = 9.47$$

$$f_2 = 13.83$$

$$f_3 = 14.78$$

$$f_4 = 30.36$$

#### Vertical Frequencies (Hz)

$$f_1 = 18.18$$

$$f_2 = 32.00$$

$$f_3 = 68.44$$

$$f_4 = 68.67$$

$$f_5 = 72.13$$

### Stress Summary

| <u>Component</u>                          | <u>Calculated S</u> | <u>Allowable S</u> |
|-------------------------------------------|---------------------|--------------------|
| Foundation holddown bolts - skid          | 3092                | 33,000             |
| Holddown bolts - subbase/skid             | 2434                | 33,000             |
| Holddown bolts - subbase - middle section | 4363                | 28,000             |
| Turbocharger bracket mounting bolts       | 25,915              | 52,000             |
| Turbocharger mounting feet                | 11,528              | 33,000             |

HNP-2-FSAR-3

| <u>Component</u>       | <u>Calculated (lb)</u> | <u>Allowable (lb)</u> |
|------------------------|------------------------|-----------------------|
| Engine bearings No. 14 | 3167                   | 6000                  |
| Engine bearings No. 13 | 1156                   | 6000                  |
| Engine bearings No. 1  | 11,430                 | 18,000                |
| Engine bearings No. 2  | 8775                   | 18,000                |

Overspeed Governor and Shutdown System

- Linear acceleration of rotating-weight system = 2.24 g<sup>(a)</sup>
- Linear acceleration of latch-and-lever system = 51.90 g(a)
- Linear acceleration of manual shutdown = 6.57 g(a)
- Linear acceleration of plunger and latch unhooking = 128 g
- Applied seismic acceleration =  $\frac{2.24}{0.554}$  = 0.554 g
- Applied seismic safety factor = 4.04

Heat Exchanger Stack

Horizontal Mode

| <u>Parallel-to-Engine Crankshaft (Hz)</u> | <u>90° to Crankshaft Centerline (Hz)</u> |
|-------------------------------------------|------------------------------------------|
| f <sub>1</sub> = 10.31                    | f <sub>1</sub> = 11.10                   |
| f <sub>2</sub> = 40.65                    |                                          |
| f <sub>3</sub> = 137.25                   |                                          |
| f <sub>4</sub> = 151.76                   |                                          |

a. Lowest linear acceleration is 2.24 g due to movement of the rotating governor weight.

## HNP-2-FSAR-3

### Vertical Mode

$$f_1 = 20.2$$

$$f_2 = 55.1$$

$$f^3 = 75.5$$

### Stress Summary

- Fore and aft stack bracing stress = 11,940 psi; okay for mild steel.
- Shear stress for bolt = 11,726 psi < allowable of 28,000 psi.
- Stress in tubing = 5775 psi, okay for mild steel.
- Weld capacity at foot of post = 14,400 lb > actual load of 7507 lb.
- Maximum combined shear and tensile principal stress = 9120 psi < allowable proof load = 52,000 psi.

### Lube Oil Filter

$$f_1 = 31.10 \text{ Hz (horizontal)}$$

$$f_1 = 148.000 \text{ Hz (vertical)}$$

- Proof load on bolt = 17,400 lb, > actual load of 556 lb.
- Calculated bending stress = 3644 psi, < allowable bending stress = 33,000 psi.
- Weld capacity = 20,400 lb, > actual load of 1372 lb.

### 1000-gal Fuel Tank

$$f_1 \text{ (horizontal)} = 13.94 \text{ Hz}$$

$$f_1 \text{ (vertical)} = 35.80 \text{ Hz}$$

#### 1. Case A - full tank

- Combined tension and shear principal stress = 2537 psi
- Bending stress = 5387 psi
- Acceptable for mild steel with  $f_y$  = 33,000 psi

## HNP-2-FSAR-3

### 2. Case B - half-full tank (effect of sloshing included)

- Maximum shear = 604 < 2537 psi for full tank.
- Maximum bending stress = 1307 psi < 5387 psi for full tank.
- No-bolt tension - Case A governs.

#### Jacket Water Expansion Tank (100 gal)

$f_1$  (horizontal) = 53.80 Hz (longitudinal)

$f_1$  (horizontal) = 43.80 Hz (lateral)

$f_1$  (vertical) = 45.60 Hz (lateral)

- Maximum bolt shear stress = 1012 psi.
- Maximum bolt tension stress = 1410 psi.
- Combined stress = 1936 psi, okay for mild steel.
- Bending stress = 1006 psi, okay for mild steel.
- Maximum load at weld = 744 lb < capacity of weld = 2385 lb.
- Safety factor = 3.2.

#### Air Compressor Skid Assembly

$f_1$  (horizontal) = 14.48 Hz

$f_2$  (horizontal) = 38.08 Hz

$f_1$  (vertical) = 75.40 Hz

$f_2$  (vertical) = 114.21 Hz

- Overturning moment = 1992 in. lb < resisting moment = 2180 in. lb.
- Shear stress in bolt = 194 psi < 33,000 psi.

#### Air Receiver Tank

$f_1$  = 6.61 Hz (horizontal)

$f_2$  = 33.84 Hz (vertical)

## HNP-2-FSAR-3

- Maximum principal stress = 4992 psi < 52,000 psi (proof load of bolt).
- Bending stress = 17,611 psi < 30,000 psi.
- Maximum stress in weld = 907 lb/in. < 2400 lb/in.

### Generator Control Board

#### 1. Structural rigidity of cabinet - qualification by analysis

- Cabinet.

| <u>Horizontal, Hz</u> | <u>Vertical, Hz</u> |
|-----------------------|---------------------|
| $f_1 = 8.237$         | $f_1 = 13.70$       |
| $f_2 = 8.41$          | $f_2 = 73.72$       |
| $f_3 = 73.42$         | $f_3 = 95.66$       |
| $f_4 = 95.67$         | $f_4 = 98.47$       |
| $f_5 = 98.97$         | $f_5 = 333$         |

- Resisting moment = 27,517.5 in. lb
- Overturning moment = 49,576 in. lb
- Holddown bolts.
  - Tensile force in bolt = 1747 psi
  - Shearing force = 1808 psi < 33,000 psi
- High-voltage chassis holddown bolts.
  - Tensile stress = 986 psi
  - Shear stress = 1484 psi < 33,000 psi
- Holddown bolts of the current transformer.
  - Tensile stress = 1029 psi
  - Shear stress = 174 psi < 33,000 psi

## HNP-2-FSAR-3

### 2. Basler relays - qualification by tests

- Input frequency Single
- Input acceleration See table 3.10-8.
- Input motion Sine dwell
- Maximum acceleration at mounting locations 0.94 g (horizontal)  
0.23 g (vertical)
- Single-axis tests Three axes independently

### 3. Clark control relays - qualification by tests

- Input frequency Single
- Input acceleration 3.6 g from 5 Hz to 20 Hz
- Maximum acceleration at mounting locations 0.94 g (horizontal)  
0.23 g (vertical)
- Single-axis tests Three axes independently

### 4. Functional and structural verifications

Stresses at critical locations of components essential for continuous operation were verified to be less than the allowable stresses. Structural integrity was maintained under the seismic environment.

Relays were monitored in the energized and deenergized armature positions, and no control chatter was noted.

### Main Control Room Environmental Control (MCREC) System

1. Method of qualification - dynamic analysis
2. Summary of results
  - Rectangular



HNP-2-FSAR-3

| Damper size<br>(width x height)       | 36 in.<br>by<br><u>24 in.</u> | 26 in.<br>by<br><u>28 in.</u> |
|---------------------------------------|-------------------------------|-------------------------------|
| Natural frequency (Hz)                | 79                            | 153                           |
| Percent damping                       | 5                             | 5                             |
| Maximum horizontal acceleration (g)   | 0.40                          | 0.40                          |
| Maximum vertical acceleration (g)     | 0.20                          | 0.20                          |
| Maximum stress in blade (psi)         | 842                           | 438                           |
| Allowable stress in blade (psi)       | 20,000                        | 20,000                        |
| Maximum force on bearing (lb)         | 102                           | 86                            |
| Allowable force on bearing (lb)       | 1990                          | 1990                          |
| Maximum shear on anchor bolt (lb)     | 13                            | 13                            |
| Allowable shear on anchor bolt (lb)   | 940                           | 940                           |
| Maximum tension on anchor bolt (lb)   | 8                             | 8                             |
| Allowable tension on anchor bolt (lb) | 1260                          | 1260                          |

| Damper size<br>(width x height)     | 60 in.<br>by<br><u>20 in.</u> | 20 in.<br>by<br><u>16 in.</u> | 60 in.<br>by<br><u>24 in.</u> | 36 in.<br>by<br><u>24 in.</u> |
|-------------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|
| Natural frequency (Hz)              | 45                            | 329                           | 44                            | 108                           |
| Percent damping                     | 5                             | 5                             | 5                             | 5                             |
| Maximum horizontal acceleration (g) | 0.40                          | 0.60                          | 0.40                          | 0.40                          |
| Maximum vertical acceleration (g)   | 0.20                          | 0.20                          | 0.20                          | 0.20                          |
| Maximum stress in blade (psi)       | 1100                          | 232                           | 792                           | 563                           |
| Allowable stress in blade (psi)     | 20,000                        | 20,000                        | 20,000                        | 20,000                        |
| Maximum force on bearing (lb)       | 168                           | 76                            | 219                           | 115                           |
| Allowable force on bearing (lb)     | 4980                          | 4980                          | 4980                          | 4980                          |
|                                     | 60 in.                        | 20 in.                        | 60 in.                        | 36 in.                        |

HNP-2-FSAR-3

| Damper size<br>(width x height)       | by<br><u>20 in.</u> | by<br><u>16 in.</u> | by<br><u>24 in.</u> | by<br><u>24 in.</u> |
|---------------------------------------|---------------------|---------------------|---------------------|---------------------|
| Maximum shear on anchor bolt (lb)     | 23                  | 21                  | 12                  | 25                  |
| Allowable shear on anchor bolt (lb)   | 940                 | 940                 | 940                 | 940                 |
| Maximum tension on anchor bolt (lb)   | 10                  | 25                  | 19                  | 11                  |
| Allowable tension on anchor bolt (lb) | 1260                | 1260                | 1260                | 1260                |
| • Round                               |                     |                     |                     |                     |
| <u>Damper size - diameter (in.)</u>   |                     | <u>36</u>           | <u>18</u>           | <u>28</u>           |
| Natural frequency (Hz)                |                     | 36                  | 119                 | 64                  |
| Percent damping                       |                     | 5                   | 5                   | 5                   |
| Maximum horizontal acceleration (g)   |                     | 0.60                | 0.60                | 0.60                |
| Maximum vertical acceleration (g)     |                     | 0.20                | 0.20                | 0.20                |
| Maximum stress in blade (psi)         |                     | 738                 | 232                 | 387                 |
| Allowable stress in blade (psi)       |                     | 20,000              | 20,000              | 20,000              |
| Maximum force on bearing (lb)         |                     | 175                 | 59                  | 117                 |
| Allowable force on bearing (lb)       |                     | 4980                | 3150                | 4980                |
| Maximum shear on anchor bolt (lb)     |                     | 23                  | 29                  | 23                  |
| Allowable shear on anchor bolt (lb)   |                     | 510                 | 510                 | 510                 |
| Maximum tension on anchor bolt (lb)   |                     | 13                  | 13                  | 11                  |
| Allowable tension on anchor bolt (lb) |                     | 680                 | 680                 | 680                 |

3. Structural verifications

Stresses at critical locations were verified to be less than the allowable stresses. Structural integrity was maintained under the seismic environment.

Fisher Air Operator Nuclear Control Valves

1. Method of qualification - combined analysis and testing

HNP-2-FSAR-3

2. Summary of results

- Valve and actuator assemblies by dynamic analysis

|                                     | <u>Calculated</u> | <u>Allowable</u> |
|-------------------------------------|-------------------|------------------|
| Natural frequency (Hz)              | 70                | -                |
| Maximum horizontal acceleration (g) | 3                 | -                |
| Maximum vertical acceleration (g)   | 3                 | -                |
| Maximum yoke leg stress (psi)       | 3820              | 23,300           |
| Maximum bonnet stress (psi)         | 2060              | 17,340           |
| Maximum yoke boss stress (psi)      | 1150              | 17,340           |

- Instruments by testing

|                        |                                                                      |
|------------------------|----------------------------------------------------------------------|
| Input frequency        | Single                                                               |
| Input acceleration (g) | 4 g at frequencies of 10, 17, 25, and 33 and at resonant frequencies |
| Input motion           | Sine dwell for 1 min                                                 |
| Single-axis tests      | Three axes independently                                             |

3. Functional and structural verifications

Stresses at critical locations were verified to be less than the allowable stresses. Structural integrity was maintained under the seismic environment. Solenoid valve, snap-lock electric switch, I/P transducer, and air set were at their normal operating conditions during tests. The outputs of the instruments were monitored. No malfunctions were indicated.

WKM Air-Operated Nuclear Control Valves

1. Method of qualification - dynamic analysis and testing

2. Summary of results

- Analysis

|                          |    |      |
|--------------------------|----|------|
| - Valve size (in.)       | 1  | 3    |
| - Natural frequency (Hz) | 61 | 36.6 |

## HNP-2-FSAR-3

- Instruments by testing
  - Type of input motion            Sinusoidal
  - Input frequency                    Single
  - Single-axis tests                    Three axes independently

### 3. Functional verifications

Solenoid valve, snap-lock electric switch, I/P transducer, and air set were tested at their normal operating conditions. The outputs of the instruments were monitored. No malfunctions were indicated.

#### Excess-Flow Check Valves

##### 1. Method of qualification - testing

##### 2. Summary of results

- Input frequency                    Single
- Input acceleration (g)              See table 3.10-9.
- Input motion                        Sinusoidal sweep at 1 Hz/s
- TRS versus RRS                    See figure 3.10-10.
- Multi- or single-axis tests        Biaxial

##### 3. Functional verifications

The valve was energized and pressurized before, during, and after testing. Recordings and observations indicate that no circuit interruptions greater than 10 ms, malfunctions, changes or indications, degradation of performance, or physical damage were observed.

#### Standby Gas Treatment System (SGTS) Current-to-Current Converter

##### 1. Method of qualification - testing

##### 2. Summary of results

- Input frequency                    Single
- Input acceleration (g)              See table 3.10-10.
- Input motion                        Sinusoidal dwell

## HNP-2-FSAR-3

- TRS versus RRS See figure 3.10-11.
- Single-axis tests Three axes independently

### 3. Functional verifications

All the switches and relays showed no malfunctions under the seismic environment.

#### Q Panels in Diesel Generator Building

##### 1. Method of qualification - dynamic analysis

##### 2. Summary of results

- Natural frequency (Hz) 50
- Maximum horizontal acceleration (g) 0.40
- Maximum vertical acceleration (g) 0.20
- Maximum stress in beam (psi) 122
- Maximum stress in plate (psi) 26

##### 3. Structural verifications

The calculated stresses in all structural elements for all the cases were very low. These results indicated that the panels are capable of withstanding the prescribed seismic environment.

#### Nuclear Service Power-Operated Valves and Power-Operated Butterfly Valves

##### 1. Method of qualification - combined testing and analysis

##### 2. Summary of results

HNP-2-FSAR-3

- Valve assembly - dynamic analysis      See table 3.10-11.
  - Natural frequency (Hz)                      > 20
  - Input motion (g)                                3
- Motor operator - testing
  - Input frequency                                Single and multiple
  - Input acceleration (g)                        See table 3.10-12.
  - Input motion                                     Sine dwell
  - Single or biaxial testing                      Both

3. Functional and structural verifications

Stresses at critical locations were verified to be less than the allowable stresses. Structural integrity was maintained under the seismic environment. The motor was monitored electrically and performed all control and indicating functions. There was no evidence of contact chatter.

Nuclear Service Air-Operated Valves

1. Method of qualification - dynamic analysis
2. Summary of results - 900 lb feedwater check valve by Atwood & Morrill Company
  - Natural frequency (Hz)                        775
  - Input acceleration (g)                            3

|                          | <u>Calculated</u> | <u>Allowable</u> |
|--------------------------|-------------------|------------------|
| Cylinder connection bolt | 12,640            | 25,000           |
| Brackets spacer          | 1030              | 17,500           |
| Bracket extension        | 6860              | 16,200           |

3. Structural verifications

Stresses at critical locations were verified to be less than the allowable stresses. Structural integrity was maintained under the seismic environment.

Nuclear Service Air-Operated Butterfly Valves<sup>(a)</sup>

1. Method of qualification - dynamic analysis and testing

2. Summary of results

- 18-in. valve - See tables 3.10-13 and 3.10-14.
- 6-in. valve - See tables 3.10-15 and 3.10-16.
- Solenoid qualification.
  - Natural frequency (Hz)            6(H), 11.5(H), > 21(V)<sup>(b)</sup>
  - Input acceleration (g)            3
  - Input motion                        Sine beat  
10 cycles/beat  
5 beats/frequency
  - Single-axis tests                    Three axes independently
- 10-in. valve.

The 10-in. Minitork air-operated butterfly valves were seismically qualified by analysis of the valve-actuator assembly and testing of the solenoid valve and limit switch. The analysis calculates stress levels at critical areas in the valve-actuator assembly. Seismic stresses in other sections of the unit are not calculated because of their insignificance when compared to stress levels incurred during normal operation of the valve.

3. Functional and structural verifications

Stresses at critical locations were verified to be less than the allowable stresses. Structural integrity was maintained under the seismic environment. The solenoid valve performed all control functions.

Service Air System Accumulators for Outboard Main Steam Isolation Valves (MSIVs)

1. Method of qualification - dynamic analysis

2. Summary of Results

a. Three copies each of the Masoneilan International, Inc. seismic calculations for 2P41-F066, F067, and 2T46-F005, in addition to the Environmental Testing Corporation test reports 10696 and 1021G-2 were provided to the NRC for evaluation.

b. H = horizontal frequencies in north-south and east-west directions. V = vertical frequencies.

## HNP-2-FSAR-3

|                                                         | <u>Calculated</u> | <u>Allowable</u> |
|---------------------------------------------------------|-------------------|------------------|
| Natural frequency (Hz)                                  | 339               | -                |
| Percent damping                                         | 2                 | -                |
| Maximum horizontal acceleration (g)                     | 0.39              | -                |
| Maximum vertical acceleration (g)                       | 0.30              | -                |
| Maximum longitudinal component stress in cylinder (psi) | 1830              | 11,450           |
| Maximum longitudinal tension stress in cylinder (psi)   | 3650              | 18,200           |
| Maximum shear on anchor bolt (psi)                      | 95                | 10,000           |
| Maximum circumferential stress at lug attachment (psi)  | 8307              | 18,200           |
| Maximum longitudinal stress at lug attachment (psi)     | 4595              | 18,200           |

### 3. Structural verifications

Stresses at critical locations were verified to be less than the allowable stresses. Structural integrity was maintained under the seismic environment.

#### PSW System Pumps

1. Method of qualification - dynamic analysis

2. Summary of results

Natural frequency (Hz) and Input accelerations (g)



HNP-2-FSAR-3

|                |       | Mode  |       |       |       | Vertical |
|----------------|-------|-------|-------|-------|-------|----------|
|                |       | 1     | 2     | 3     | 4     |          |
| Head and Motor | f     | 25.7  | 295   | 1155  | -     | 178      |
|                | g-OBE | -     | -     | -     | -     | -        |
|                | g-DBE | 0.374 | 0.374 | 0.374 | -     | 0.11     |
| Column         | f     | 5.29  | 17.25 | 36.39 | 62.67 | 61       |
|                | g-OBE | 0.70  | 0.30  | 0.22  | 0.22  | 0.11     |
|                | g-DBE | 1.05  | 0.51  | 0.37  | 0.37  | 0.187    |
| Shaft          | f     | 30.2  | -     | -     | -     | 60.5     |
|                | g-OBE | 0.22  | -     | -     | -     | 0.11     |
|                | g-DBE | 0.374 | -     | -     | -     | 0.187    |

A 3% damping curve was used for OBE.

A 5% damping curve was used for DBE.

Maximum of north-south or east-west values was used in all cases.

3. Structural verifications

Stresses at critical locations were verified to be less than the allowable stresses. (See table 3.10-17.) Structural integrity was maintained under the seismic environment.

H<sub>2</sub> Recombiners

1. Method of qualification - testing - IEEE 344-1975
2. Summary of results

The following test results were obtained for the recombiners, the recombiner control console, and the recombiner power cabinet, previously qualified for a seismic qualification level in excess of the RRS for HNP-2 as shown in figures 7 and 8 of the proprietary Fukushima report provided separately to the NRC.

- Input frequency (Hz)                      Random multifrequency superimposed with sine beat
- Axis of test                                      Two axes simultaneously

3. Functional verifications

For the recombiner the reaction chamber and coils were inspected, and no damage was observed after the test. The pressure transducers and transmitters were monitored. All functional anomalies observed during the tests were corrected.

## HNP-2-FSAR-3

For the recombiner control console, electrical functions were monitored and yielded satisfactory results. No significant visible structural anomalies occurred as a result of seismic testing.

For the recombiner power cabinet, relays were monitored and functioned satisfactorily. The whole cabinet was functioning normally after the test.

### Remote Shutdown Panels, Post-Accident Monitors, and Associated Components

1. Method of qualification - combined analysis and testing
2. Summary of results
  - Panels by dynamic analysis.

|                                       |      |
|---------------------------------------|------|
| - Natural frequency (Hz)              | 108  |
| - Maximum horizontal acceleration (g) | 0.3  |
| - Maximum vertical acceleration (g)   | 0.36 |
| - Maximum stress in beam (psi)        | 317  |
| - Maximum stress in plate (psi)       | 116  |
  - Indicating and alarm instruments - testing.

|                          |                                                                         |
|--------------------------|-------------------------------------------------------------------------|
| - Input frequency        | Single                                                                  |
| - Input acceleration (g) | See tables 3.10-18 through 3.10-20.                                     |
| - Input motion           | Sine beat<br>10 to 15 cycles/beat<br>2 beats/frequency<br>96 beats/axis |
| - Single-axis tests      | Three axes independently                                                |
| - TRS versus RRS         | See figures 3.10-12 and 3.10-13.                                        |
3. Functional and structural verifications

The calculated stresses in all structural elements for the panel were very low. These results indicated that the panels are capable of withstanding the prescribed seismic environment. All the indicating and alarm instruments were monitored at their normal operating mode, and no malfunctions were indicated during the tests.

Recirculation Pump Trip (RPT) Breakers

1. Method of qualification - testing in accordance with IEEE-344-1975
2. Summary of results
  - Input motion - multifrequency sine beats spaced at one-third-octave intervals over the seismic range of 1 to 33 Hz.
  - Axis of test - front to back and vertical, left to right and vertical (simultaneous horizontal and vertical).
  - Damping - 5%.
  - TRS versus RRS. (See figure 3.10-14.)
3. Functional verifications

The equipment was subjected to an excessive number of tests. The switchgear maintained its structural integrity, and there was no physical equipment failure. This equipment performed its intended Class 1E functions during and after the specified seismic events.

**3.10.2.1.1 Seismic Design Adequacy of Supports**

Analyses or tests are performed for all supports of electrical equipment and instrumentation to ensure their structural capability to withstand seismic excitation. The following bases are used in the seismic design and analysis of cable tray supports and instrument tubing supports:

- A. All cable tray supports and instrument tubing supports are designed by the response spectrum method.
- B. Analysis and seismic restraint measures for tray supports and tubing supports are based on combined limiting values for static load, span length, and computed seismic response.
- C. All Class 1E cable tray supports are designed to meet the requirement by dynamic analysis using the appropriate seismic response spectra.
- D. Maximum stress is limited to 90% of minimum yield.

- E. The Seismic Category I instrument tubing systems are such that the allowable stresses permitted by Section III of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code are not exceeded when the tubing is subjected to the loads specified in Section 3.9 for Classes 2 and 3 piping.

For field-mounted instruments, the following is applicable:

- A. The mounting structures for Seismic Category I instruments have a fundamental frequency  $\geq 20$  Hz.
- B. The stress level in the mounting structure does not exceed the material allowable stress when subjected to the maximum acceleration level of the mounting location.

Supports are tested with equipment installed. If the equipment is inoperative during the support test, the response at the equipment-mounting location is monitored. In such a case, equipment is tested separately, and the actual input to the equipment is more conservative in amplitude and frequency content than the monitored response.

### **3.10.2.2 NSSS Equipment**

#### **3.10.2.2.1 Seismic Analysis**

Very few of the GE-supplied Class 1E devices were completely qualified by analysis alone (table 3.10-1). Sometimes, however, besides being used for passive mechanical devices, analysis was used in combination with testing for larger assemblies containing Class 1E devices. For instance, a test might have been run to determine whether there were natural frequencies in the equipment within the critical seismic frequency range. (See IEEE 344-1971, Paragraph 3.2.2.3.1.) If the equipment was determined to be free of natural frequencies in this range, it was assumed to be rigid, and a static analysis was performed as shown in Appendix C of NEDO-10678. (See IEEE 344-1971, Paragraph 3.2.3.4.) If the equipment had natural frequencies in the critical frequency range, calculations of transmissibility and responses to varying input accelerations were performed to determine whether Class 1E devices mounted in the assembly would operate without malfunctioning.

In addition, analyses or tests were performed for all supports of electrical and mechanical equipment and instrumentation. The requirements of the applicable paragraphs of IEEE 344-1971 are applied when conducting tests on equipment supports. In all cases, the combined stresses of the support structures are within the limits of the ASME Code Section III, Appendix XVII-2000.

The analog transmitter trip system (ATTS) instrumentation is discussed in paragraph 3.10.2.2.3.

### 3.10.2.2.2 Testing Procedures

Since the GE-supplied Class 1E equipment was and is used in numerous systems in many different plants under widely varying seismic requirements, the seismic qualifications tests were performed using an expected worst-case envelope of 1.5-g horizontal and 0.5-g vertical at all frequencies from 5 to 33 Hz. (The actual qualification range was 0.25 to 33 Hz, but since test-facility capability usually limited the lower frequency test to 5 Hz, a combination of test and analysis was used to assure that there were no untested resonances. A sample analysis is shown in Appendix B of NEDO-10678.) Based upon experience obtained from seismic tests conducted on devices of various designs, sizes, and types of construction, none of these devices has a resonant frequency in the 1- to 5-Hz region, and very few have any resonances < 33 Hz. Two examples of devices that have been tested only in the 5- to 33-Hz frequency range are Static-O-Ring pressure switch 145C3011 and Robertshaw level switch 145C3047. Based on the rigidity of these and similar devices in the 5- to 33-Hz frequency range, the physical size, mass, type of construction, and design, it is conservative to assume that no resonances are in the 1- to 5-Hz region. These assumptions are borne out by a multitude of seismic tests conducted on devices in the 1- to 5-Hz region with no resonances observed. All control panels and racks tested at the GE test facility in San Jose were tested over the full 1- to 33-Hz frequency range. No panels or racks have exhibited a resonant frequency in the 1- to 5-Hz range.

In general, the Class 1E equipment was tested by using the following procedures:

The test procedure for devices required that the devices be mounted on the vibration machine table in a manner similar to the way it was to be installed. The device was tested in the operating states to be used while performing its Class 1E functions. These states were monitored before, during, and after the test to assure proper function and absence of any spurious function. In the case of a relay, both energized and deenergized states and normally open and normally closed contact configurations were tested if the relay was to be used in those configurations in its Class 1E functions.

The seismic excitation was a single-frequency, continuous test in which the applied vibration was a sinusoidal table motion at a fixed-peak acceleration and a discrete frequency at any given time. Each frequency and acceleration combination was maintained for about 30 s, except when a resonance search was made (IEEE 344-1971, Paragraph 3.2.2.4.1). The vibratory excitation was individually applied in three orthogonal axes with the axes chosen as those coincident with the most probable mounting configuration.

The first step was to search for resonances in each device. This was done since resonances cause amplification of the input vibration and are the most likely cause of malfunction. The resonance search was usually run at low-acceleration levels (0.2 g) to avoid destroying the test sample in case a severe resonance was encountered. The resonance search was run from 5 to 33 Hz, in accordance with IEEE 344, in not < 7 min. If the device was large enough, the vibrations were monitored by accelerometers placed at critical locations from which resonances were determined by comparing the acceleration level with that at the vibration machine table. Usually, the devices were either too small for an accelerometer; their critical parts were in an inaccessible location;

## HNP-2-FSAR-3

or they had critical parts that would be adversely affected by the mounting of an accelerometer. In these cases, the resonances were detected by strobe light (visually), by audible observation, or by performance.

Following the frequency scan and resonance determination, the devices were tested to investigate their malfunction limits. This test was a necessary adjunct to the assembly test, as will be shown later. The malfunction-limit test was run at each resonant frequency as determined by the frequency scan. In this test, the acceleration level was gradually increased until either the device malfunctioned or the limit of the vibration machine was reached. If no resonances were detected (as was usually the case), the device was considered to be rigid,<sup>(a)</sup> and the malfunction limit was, therefore, independent of frequency. To achieve maximum acceleration from the vibration machine, rigid devices were malfunction tested at the upper test frequency (33 Hz) since that allowed the maximum acceleration to be obtained from deflection-limited machines.

The summary of the results of tests on the devices used in Class 1E applications given in table 3.10-1 includes the seismic qualification level and resonant frequencies for each device tested.

The above procedures were required of purchased devices, as well as those made by GE. Vendor test results were reviewed, and, if unacceptable, the tests were repeated either by GE or the vendor. If the vendor tests were adequate, the device was considered qualified to the limits of the test.

Assemblies, i.e., control panels, containing devices that have had seismic malfunction limits established were tested by mounting each assembly on the vibration machine table in the manner that it was to be mounted when in use and by vibration testing it by running a low-level resonance search. As with the devices, the assemblies were tested in the three major orthogonal axes. The resonance search was run in the same manner as that described for devices. If resonances were present, the transmissibility between the input and the location of each Class 1E device was determined by measuring the accelerations at each device location and calculating the magnification between it and the input. Once known, the transmissibilities could be used analytically to determine the response at any Class 1E device location for any given input. As long as the device input accelerations were determined to be below their malfunction limits, the assembly was assumed to be qualified. If no resonances existed, the assembly was considered to be a rigid body with a transmissibility equal to 1 so that a device mounted on the assembly would be limited directly by the assembly input acceleration.

Since control panels and racks constitute the majority of Class 1E electric assemblies supplied by GE, seismic qualification testing of these is discussed in more detail. There are four generic types, as shown in table 3.10-2. Using the above procedures, one or more of each type was tested.

---

a. All parts move in unison.

## HNP-2-FSAR-3

Figures 3-1 through 3-4 of NEDO-10678 illustrate the panel types referenced in table 3.10-2 and show typical accelerometer locations. The results of seismic tests performed on the type of Class 1E panels supplied by GE for HNP-2 are summarized in table 3.10-3.

The full-acceleration level tests previously described disclosed that most of the panel types had more than adequate mechanical strength and that a given panel design acceptability was just a function of its amplification factor and the malfunction levels of the devices mounted in it. Subsequent panels were, therefore, tested at lower acceleration levels and the transmissibilities measured to the various devices. By dividing the device's malfunction levels with the panel transmissibility between the device and the panel input, the panel seismic qualification level could be determined. Several high-level tests have been run on selected generic panel designs to assure conservatism in using the transmissibility analysis described.

The seismic qualification of equipment supplied to GE by others was required to follow the same procedures as those used by GE. The qualification data were supplied to and reviewed by GE for conformance to the required procedures.

The following information regarding the Category I equipment required for safe shutdown is included as a part of the GE generic program on seismic qualification:

- Natural frequency in each direction.
- Functional description and method of functional verification.
- Seismic input employed in the test or analysis in each direction.
- Graphs showing TRS enveloping the RRS.
- Test or analysis results summary.
- For equipment qualified by analysis, identification of the critical structural element(s) demonstrating its structural integrity and functional capability under the DBE.

### Equipment Qualified by GE

- Inverters.
- Relays.
- Switches.
- Pressure transmitters.
- Panels (reactor protection boards).
- Neutron monitoring systems.

- Control rod drive.
- Jet pumps.
- Recirculation pump.
- RHR pump motors.
- MSIVs.

### **3.10.2.2.3 ATTS Seismic Qualification**

The ATTS qualification program was designed to meet or exceed the requirements of IEEE 344-1975. A summary of the program is contained in NEDE-22154-1, with details being presented in NEDC-30039-1. Component qualification was accomplished either by type testing, which simulated triaxial motion, or by similarity analysis. The individual devices covered by this program are listed in table 7.8-1, and information relating to the seismic qualification of these devices is contained in table 3.10-21. Table 3.10-22 identifies the control panels and local instrument racks covered by this program.



TABLE 3.10-1 (SHEET 1 OF 5)

NSSS CLASS 1E EQUIPMENT REQUIRING QUALIFICATION<sup>(a)</sup>

| Component                         | Manufacturer     | Primary Class<br>1E Function                                                      | Qualification<br>Environment <sup>(b)</sup> | Seismic                                |     |     | Resonant<br>Frequency (Hz) <sup>(d)</sup> |
|-----------------------------------|------------------|-----------------------------------------------------------------------------------|---------------------------------------------|----------------------------------------|-----|-----|-------------------------------------------|
|                                   |                  |                                                                                   |                                             | Qualification Level (g) <sup>(c)</sup> |     |     |                                           |
|                                   |                  |                                                                                   |                                             | X                                      | Y   | Z   |                                           |
| Temperature element               | California Alloy | Pressure integrity                                                                | Containment                                 |                                        | (a) |     | ---                                       |
| Temperature element               | Pyco             | Temperature measurement                                                           | Reactor building                            | 5                                      | 5   | 5   | ---                                       |
| Temperature switch                | Transmation      | Contact transfer at temperature setpoint                                          | Containment                                 | 1.5                                    | 1.5 | 0.5 | ---                                       |
| Alarm unit                        | Bailey           | Provide alarm at setpoint                                                         | Control room                                | 7.5                                    | 8.5 | 20  | ---                                       |
| Controller                        | GE               | Provide control signal output                                                     | Control room                                | 9                                      | 9   | 13  | ---                                       |
| Square root converter             | GE               | Convert pressure signal to flow output signal                                     | Control room                                | 4.2                                    | 7   | 1.8 | ---                                       |
| Differential pressure transmitter | Barton           | Pressure integrity                                                                | Containment                                 |                                        | (a) |     | ---                                       |
| Level-indicating switch           | Barton           | Contact transfer at level trip point                                              | Containment                                 | 17                                     | 13  | 1.8 | ---                                       |
| Inverter filter                   | Topaz            | Filter-inverter input                                                             | Control room                                | 10                                     | 10  | 10  | ---                                       |
| dc power supply                   | GE               | Convert 115 V ac to 24 V dc for safety circuits                                   | Control room                                | 2.5                                    | 2.5 | 2.5 | ---                                       |
| Pressure switch                   | Barksdale        | Provide contact transfer at pressure trip point (reactor protection system) (RPS) | Turbine building                            | 2                                      | 2   | 2   | ---                                       |
| Pressure switch                   | Barksdale        | Provide contact transfer at pressure trip point                                   | Reactor building                            | 15                                     | 15  | 15  | ---                                       |
| Power range detector              | GE               | Neutron flux measurement                                                          | Reactor vessel                              |                                        | (f) |     | ---                                       |
| Differential pressure switch      | Barton           | Provide contact transfer at differential pressure trip point                      | Reactor building                            | 10                                     | 5   | 10  | ---                                       |
| Level switch (sump)               | Magnetrol        | Provide contact transfer at level trip point                                      | Condensate storage tank                     | 1.2                                    | 6   | 9.5 | ---                                       |

HNP-2-FSAR-3

**TABLE 3.10-1 (SHEET 2 OF 5)**

| <u>Component</u>                   | <u>Manufacturer</u>       | <u>Primary Class<br/>1E Function</u>                         | <u>Qualification<br/>Environment<sup>(b)</sup></u> | <u>Seismic</u>                               |          |                    |                                                  |
|------------------------------------|---------------------------|--------------------------------------------------------------|----------------------------------------------------|----------------------------------------------|----------|--------------------|--------------------------------------------------|
|                                    |                           |                                                              |                                                    | <u>Qualification Level (g)<sup>(c)</sup></u> |          |                    | <u>Resonant<br/>Frequency (Hz)<sup>(d)</sup></u> |
|                                    |                           |                                                              |                                                    | <u>X</u>                                     | <u>Y</u> | <u>Z</u>           |                                                  |
| Inverter                           | Topaz                     | Control dc input to regulated ac output                      | Control room                                       | 15                                           | 10       | 7                  | ---                                              |
| Power supply                       | GE                        | Input voltage 120-V-ac<br>±10%/output - 24-V-dc ±1%          | Service building                                   | 2.5                                          | 2.5      | 2.5                | ---                                              |
| Relay, time delay                  | Agastat                   | Maintain state or transfer                                   | Control room                                       | 17                                           | 4.6      | 17                 | ---                                              |
| Relay                              | Agastat                   | Maintain state or transfer                                   | Control room                                       | 17                                           | 6.7      | 17                 | ---                                              |
| Switch                             | GE-SBM                    | Supply ac power to MCC                                       | Control room                                       | 25                                           | 25       | 25                 | ---                                              |
| Relay                              | GE-HFA                    | Multipurpose control, logic;<br>annunciator functions        | Control room                                       | 5                                            | 7.5      | 7.5 <sup>(e)</sup> | 30                                               |
| Relay, time delay                  | GE (CR2820)               | Multipurpose control, logic;<br>annunciator functions        | Control room                                       | 25                                           | 25       | 25                 | ---                                              |
| Relay                              | GE-HGA                    | Multipurpose control, logic;<br>annunciator functions        | Control room                                       | 12                                           | 12       | 12 <sup>(e)</sup>  | ---                                              |
| Switch                             | GE (CR2940)               | Apply ac/dc power for manual<br>initiation of safety systems | Control room                                       | 20                                           | 20       | 20                 | ---                                              |
| Timer, motor-driven                | Eagle signal              | Timeout signals; apply or interrupt<br>power to load         | Control room                                       | 10                                           | 10       | 5.5                | ---                                              |
| Pressure transmitter               | Bailey Meter              | Provide current output in response to<br>pressure input      | Reactor building                                   | 5.5                                          | 5.5      | 3.7                | ---                                              |
| Differential pressure<br>indicator | Barton                    | Pressure integrity                                           | Reactor building                                   |                                              | (a)      |                    | ---                                              |
| Contactors                         | GE (CR305) <sup>(g)</sup> | Deenergize; interrupt power to system<br>solenoids           | Control room                                       | 12                                           | 12       | 12                 | 27                                               |
| Switch                             | Cutler Hammer             | Manual initiation of safety systems                          | Control room                                       | 10                                           | --       | --                 | ---                                              |
| Level switch                       | Magnetrol                 | Apply or interrupt power to load upon<br>setpoint trip       | Reactor building                                   | 5.0                                          | 4.1      | 9.5                | ---                                              |

HNP-2-FSAR-3

**TABLE 3.10-1 (SHEET 3 OF 5)**

| <u>Component</u>      | <u>Manufacturer</u> | <u>Primary Class<br/>1E Function</u>                      | <u>Qualification<br/>Environment<sup>(b)</sup></u> | <u>Seismic</u>                               |          |          |                                                  |
|-----------------------|---------------------|-----------------------------------------------------------|----------------------------------------------------|----------------------------------------------|----------|----------|--------------------------------------------------|
|                       |                     |                                                           |                                                    | <u>Qualification Level (g)<sup>(c)</sup></u> |          |          | <u>Resonant<br/>Frequency (Hz)<sup>(d)</sup></u> |
|                       |                     |                                                           |                                                    | <u>X</u>                                     | <u>Y</u> | <u>Z</u> |                                                  |
| Switch, bank mode     | GE                  | Mode selection                                            | Control room                                       | 10                                           | 10       | 10       | ---                                              |
| Range switch          | GE                  | Range selection                                           | Control room                                       | 8.5                                          | 8.5      | 8.5      | ---                                              |
| Pressure switch       | Robertshaw          | Pressure integrity                                        | Reactor building                                   |                                              | (a)      |          | ---                                              |
| Power supply          | GE-MAC (7000)       | Provide power for control circuitry                       | Control room                                       | 2.5                                          | 2.5      | 2.5      | ---                                              |
| Relay                 | Agastat             | Multipurpose control; low-annunciator functions           | Control room                                       | 3.5                                          | --       | --       | 20                                               |
| Indicator/trip unit   | GE                  | Provide trip output for safety system                     | Control room                                       | 15                                           | 15       | 15       | 31                                               |
| Log radiation monitor | GE                  | Provide high-radiation signal to RPS                      | Control room                                       | 3                                            | 3        | 3        | ---                                              |
| Trip auxiliary unit   | GE                  | Provide high-radiation signal to RPS                      | Control room                                       | 17                                           | 17       | 17       | ---                                              |
| Pressure switch       | Barton              | Provide contact transfer at pressure trip point           | Reactor building                                   | 5                                            | 10       | 10       | ---                                              |
| Temperature switch    | Riley/scam          | Provide contact transfer at thermocouple input trip point | Control room                                       | 8                                            | 8.5      | 9.5      | ---                                              |
| Pressure switch       | Static-O-Ring       | Provide contact transfer at pressure trip point           | Reactor building                                   | 15                                           | 15       | 15       | ---                                              |
| Pressure switch       | Barksdale (D2T)     | Provide contact transfer at pressure trip point           | Reactor building                                   | 13                                           | 13       | 10       | ---                                              |
| Pressure transmitter  | Rosemount (11510)   | Provide current output response to pressure input         | Reactor building                                   | 2                                            | 2        | 2        | 7                                                |
| Pressure switch       | Static-O-Ring (12N) | Provide contact transfer at pressure trip point           | Reactor building                                   | 15                                           | 15       | 15       | ---                                              |
| Temperature switch    | Fenwall             | Provide contact transfer at temperature trip point        | Reactor building                                   | 20                                           | 20       | 20       | ---                                              |

HNP-2-FSAR-3

**TABLE 3.10-1 (SHEET 4 OF 5)**

| Component                                     | Manufacturer  | Primary Class<br>1E Function                                         | Qualification<br>Environment <sup>(b)</sup> | Seismic                                |     |     |                                           |
|-----------------------------------------------|---------------|----------------------------------------------------------------------|---------------------------------------------|----------------------------------------|-----|-----|-------------------------------------------|
|                                               |               |                                                                      |                                             | Qualification Level (g) <sup>(c)</sup> |     |     | Resonant<br>Frequency (Hz) <sup>(d)</sup> |
|                                               |               |                                                                      |                                             | X                                      | Y   | Z   |                                           |
| Intermediate range monitor (IRM) preamplifier | GE            | Amplify IRM voltage signal                                           | Reactor building                            | 8.5                                    | 8.5 | 8.5 | ---                                       |
| Rod worth monitor                             | GE            | Rod worth monitor in RC&IS system-rod control and information system | Control room                                | 8.5                                    | 8.5 | 8.5 | 33                                        |
| IRM detector                                  | GE            | Convert IRM signals to voltage output                                | Reactor vessel                              |                                        | (f) |     | ---                                       |
| Detector                                      | GE            | Radiation monitor                                                    | Reactor building                            | 3                                      | 3   | 2   | ---                                       |
| Summer                                        | GE            | Measure flow difference signal                                       | Control room                                | 4.2                                    | 7   | 1.8 | ---                                       |
| Pressure transmitter                          | GE-MAC        | Provides current output signal proportional to pressure input        | Reactor building                            | 10                                     | 10  | 10  | ---                                       |
| Level-indicating transmitter switch           | Barton        | Provide contact transfer at level trip point                         | Reactor building                            | 5                                      | 2   | 5   | 8                                         |
| Alarm unit                                    | Bailey Meter  | Provides contact transfer at trip point                              | Control room                                | 9                                      | 9.5 | 13  | ---                                       |
| Pressure switch                               | Barksdale     | Pressure integrity                                                   | Reactor building                            |                                        | (a) |     | ---                                       |
| Pressure switch                               | Static-O-Ring | Pressure integrity                                                   | Reactor building                            |                                        | (a) |     | ---                                       |
| Pressure switch                               | Barton        | Pressure integrity                                                   | Reactor building                            |                                        | (a) |     | ---                                       |
| Pressure indicator                            | Robertshaw    | Pressure integrity                                                   | Reactor building                            |                                        | (a) |     | ---                                       |
| Differential pressure transmitter             | Rosemount     | Pressure integrity                                                   | Reactor building                            |                                        | (a) |     | ---                                       |
| Level transmitter                             | Yarway        | Shroud water level; analog signal                                    | Reactor building                            | 10                                     | 8   | 1   | 31                                        |
| Level transmitter                             | Bailey        | Analog output to RHR                                                 | Reactor building                            | 10                                     | 10  | 10  | ---                                       |
| Level-indicator switch                        | Yarway        | Contact output for remote shutdown                                   | Reactor building                            | 10                                     | 8   | 1   | 31                                        |
| Level-indicator switch                        | Yarway        | Reactor water level contact output for scram; isolation              | Reactor building                            | 10                                     | 8   | 1   | 31                                        |
| Temperature switch                            | Fenwal        | Pressure integrity                                                   | Reactor building                            |                                        | (a) |     | ---                                       |

HNP-2-FSAR-3

**TABLE 3.10-1 (SHEET 5 OF 5)**

| <u>Component</u>       | <u>Manufacturer</u> | <u>Primary Class<br/>1E Function</u>                              | <u>Qualification<br/>Environment<sup>(b)</sup></u> | <u>Seismic</u>                               |          |     |                                                  |
|------------------------|---------------------|-------------------------------------------------------------------|----------------------------------------------------|----------------------------------------------|----------|-----|--------------------------------------------------|
|                        |                     |                                                                   |                                                    | <u>Qualification Level (g)<sup>(c)</sup></u> |          |     | <u>Resonant<br/>Frequency (Hz)<sup>(d)</sup></u> |
|                        |                     |                                                                   | <u>X</u>                                           | <u>Y</u>                                     | <u>Z</u> |     |                                                  |
| MV/I                   | Bailey Meter        | Convert voltage signal to current signal                          | Control room                                       | 8                                            | 9        | 8   | ---                                              |
| Sensor and converter   | GE                  | Analog electrical input; contact output                           | Control room                                       | 15                                           | 15       | 15  | ---                                              |
| Transducer             | Fisher              | Pressure integrity                                                | Reactor building                                   |                                              | (a)      |     | ---                                              |
| Conductivity element   | Beckman             | Pressure integrity                                                | Reactor building                                   |                                              | (a)      |     | ---                                              |
| Level transmitter      | Rosemount           | Pressure integrity                                                | Reactor building                                   |                                              | (a)      |     | ---                                              |
| Flow transmitter       | Rosemount           | Provide current output in response to flow input                  | Reactor building                                   | 3                                            | 3        | 3   | ---                                              |
| IRM                    | GE                  | Provide contact transfer response to current input                | Control room                                       | 5                                            |          | 4   | 1<br>2                                           |
| M/A station            | GE                  | Provide control signal output                                     | Control room                                       | 5                                            | 5        | 5   | ---                                              |
| Indicator              | Moeller             | Pressure integrity                                                | Reactor building                                   | 5                                            | 5        | 5   | ---                                              |
| Flow element           | Vickery Sims        | Analog output for leak detection                                  | Reactor building                                   |                                              | (a)      |     |                                                  |
| Power range instrument | GE                  | Provide contact transfer and signal conditioning on current input | Control room                                       | 1.8                                          | 1.8      | 1.2 | 8, 19, 26                                        |

a. Class 1E equipment listed as "pressure integrity" is not seismically tested. Integrity is verified by analysis.

b. Qualification environments (normal and accident) are given in tables 3.11-1 through 3.11-4.

c. Seismic qualification data represent the device fragility level or the maximum level at which the device could be tested because of shaker capability or testing restraints.

d. Most devices have resonant frequencies beyond the normal earthquake qualification range of 0.25 to 33 Hz. Data are given only for devices with resonant frequencies within the 0.25- to 33-Hz range.

e. The malfunction limit for relay is worst case with the relay deenergized and normally closed contacts monitored for a 10-ms discontinuity.

f. Qualified by analysis to withstand seismic and vibrational loads in the reactor vessel.

g. Power relays on RPS system which interrupt the scram pilot solenoids have been replaced with GE series CR305 relay.

**TABLE 3.10-2**  
**NSSS PANEL TYPES**

| <u>Panel Type</u>                      | <u>Use</u>                         | <u>Number<br/>Used</u> |
|----------------------------------------|------------------------------------|------------------------|
| Vertical board, benchboard             | Operating information and controls | 13                     |
| Instrument racks, cabinets             | NSSS monitoring instrumentation    | 4                      |
| Local racks                            | Process instruments                | 26                     |
| NEMA-type 12 enclosures <sup>(a)</sup> | Miscellaneous                      | 1                      |

---

a. NEMA-National Electrical Manufacturers Association.

HNP-2-FSAR-3

**TABLE 3.10-3 (SHEET 1 OF 3)**

**SEISMIC QUALIFICATION TEST SUMMARY - NSSS CONTROL PANELS AND LOCAL PANELS AND RACKS**

| <u>Control Panel</u> | <u>Description</u>                            | <u>Type</u>           | <u>Class 1E Equipment Description</u>                                                                                                                                                        | <u>Comments</u>                         |
|----------------------|-----------------------------------------------|-----------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------|
| H11-P601             | Reactor cooling and isolation                 | Benchboard            | SBM and CR2940 switches, GE-MAC instruments                                                                                                                                                  | Too long for test table-not tested      |
| H11-P602             | Reactor water cleanup (RWC) and recirculation | Benchboard            | SBM and CR2940 switches, GE-MAC instruments                                                                                                                                                  | Seismic test in similar-type panel      |
| H11-P603             | Reactor control                               | Benchboard            | Mode switch, IRM range switches                                                                                                                                                              | Seismic test completed                  |
| H11-P606             | Startup neutron monitor                       | 4-bay instrument rack | Trip auxiliary unit, IRM, SRM, main steam line radiation monitor, refueling floor vent exhaust radiation monitor, reactor building potential contaminate area vent exhaust radiation monitor | Seismic test completed                  |
| H11-P608             | Power range neutron monitor                   | 5-bay instrument rack | Average power range monitor, fiber optic bypass switch, quad low-voltage power supply                                                                                                        | Seismic test completed                  |
| H11-P609             | Reactor protection system (RPS)               | Vertical board        | HFA and HMA relays, CR305 contactor                                                                                                                                                          | Panel identical to H11-P611 panel below |
| H11-P611             | RPS                                           | Vertical board        | HFA and HMA relays, CR305 contactor                                                                                                                                                          | Seismic test completed                  |
| H11-P612             | Process instrumentation rack                  | 2-bay instrument rack | GE-MAC instruments (GE-MAC 7000)                                                                                                                                                             | Seismic test completed                  |
| H11-P613             | Process instrumentation rack                  | 2-bay instrument rack | GE-MAC instruments (GE-MAC 7000)                                                                                                                                                             | Seismic test completed                  |
| H11-P614             | Steam temperature recorders                   | Vertical board        | CR2940 switches, HMA, relays, timers, temperature monitor, inverter                                                                                                                          | Seismic test completed                  |
| H11-P617             | RHR relays                                    | Vertical board        | HFA and HMA relays                                                                                                                                                                           | Seismic test on similar-type panel      |
| H11-P618             | RHR relays                                    | Vertical board        | HFA and HMA relays                                                                                                                                                                           | Seismic test on similar-type panel      |
| H11-P620             | High-pressure coolant injection (HPCI) relays | Vertical board        | HFA and HMA relays                                                                                                                                                                           | Seismic test on similar-type panel      |

HNP-2-FSAR-3

**TABLE 3.10-3 (SHEET 2 OF 3)**

| <u>Control Panel</u> | <u>Description</u>                                   | <u>Type</u>        | <u>Class 1E Equipment Description</u>               | <u>Comments</u>                    |
|----------------------|------------------------------------------------------|--------------------|-----------------------------------------------------|------------------------------------|
| H11-P621             | Reactor core isolation cooling (RCIC) relays         | Vertical board     | HFA and HMA relays                                  | Seismic test on similar-type panel |
| H11-P622             | Inboard isolation valve relays                       | Vertical board     | HFA and HMA relays                                  | Seismic test on similar-type panel |
| H11-P623             | Outboard isolation valve relays                      | Vertical board     | HFA and HMA relays                                  | Seismic test on similar-type panel |
| H11-P628             | Automatic depressurization relays                    | Vertical board     | HFA and HMA relays                                  | Seismic test on similar-type panel |
| H21-P001             | Core spray (CS) system A                             | Local rack         | Barton 288, 289, and Barksdale P214 pressure switch | Seismic test completed             |
| H21-P002             | RWC                                                  | Local rack         | Rosemont 1151D pressure transmitter                 | Seismic test on similar-type panel |
| P21-P004             | Reactor pressure vessel (RPV) level and pressure - A | Local rack         | Pressure switches, level indicator/transmitter      | Seismic test on similar-type panel |
| P21-P005             | RPV level and pressure - C                           | Local rack         | Pressure switches, level indicator/transmitter      | Seismic test on similar-type panel |
| H21-P006             | Recirculation pump A                                 | Local rack         | Pressure transmitter                                | Seismic test on similar-type panel |
| H21-P009             | Jet pump                                             | Local rack         | Pressure transmitter                                | Seismic test completed             |
| H21-P010             | Jet pump                                             | Local rack         | Pressure transmitter, pressure switch               | Seismic test on similar-type panel |
| H21-P011             | Standby liquid control                               | Local rack         | Pressure transmitter                                | Seismic test on similar-type panel |
| H21-P013             | Source range monitor (SRM) - IRM preamplifiers       | NEMA-12 enclosures | SRM-IRM preamplifiers                               | Seismic test on similar-type panel |
| H21-P014             | HPCI instruments                                     | Local rack         | Pressure transmitter, pressure switch               | Seismic test on similar-type panel |



HNP-2-FSAR-3

**TABLE 3.10-3 (SHEET 3 OF 3)**

| <u>Control Panel</u> | <u>Description</u>             | <u>Type</u> | <u>Class 1E Equipment Description</u>   | <u>Comments</u>                    |
|----------------------|--------------------------------|-------------|-----------------------------------------|------------------------------------|
| H21-P015             | Main steam flow                | Local rack  | Pressure switch                         | Seismic test on similar-type panel |
| H21-P017             | RCIC panel A                   | Local rack  | Pressure transmitter, pressure switches | Seismic test on similar-type panel |
| H21-P018             | RHR-CHA                        | Local rack  | Pressure switches                       | Seismic test on similar-type panel |
| H21-P019             | CS-CHB rack                    | Local rack  | Pressure transmitter, pressure switch   | Seismic test on similar-type panel |
| H21-P021             | RHR-CHB                        | Local rack  | Pressure switches                       | Seismic test on similar-type panel |
| H21-P025             | Main steam flow                | Local rack  | Pressure switch                         | Seismic test completed             |
| H21-P022             | Recirculation pump B           | Local rack  | Pressure transmitter, pressure switch   | Seismic test on similar-type panel |
| H21-P160             | Recirculation flow instruments | Local rack  | Pressure transmitter                    | Seismic test on similar-type panel |
| H21-P161             | Recirculation flow instruments | Local rack  | Pressure transmitter                    | Seismic test on similar-type panel |
| H21-P161             | Recirculation flow instruments | Local rack  | Pressure transmitter                    | Seismic test on similar-type panel |
| H21-P162             | Recirculation flow instruments | Local rack  | Pressure transmitter                    | Seismic test on similar-type panel |
| H21-P163             | Recirculation flow instruments | Local rack  | Pressure transmitter                    | Seismic test on similar-type panel |

a. "Seismic test on similar-type panel" means that the required seismic tests were made on panels that are sufficiently close to the HNP-2 design to provide adequate representation. These panels are used on other plants.

b. "Seismic test completed" means that a panel identical to the HNP-2 design was tested in another plant.

TABLE 3.10-4 (SHEET 1 OF 2)

**SEISMIC QUALIFICATION OF MAJOR BOP  
ELECTRICAL AND MECHANICAL EQUIPMENT**

| <u>Item</u>                                                       | <u>Analysis</u>     | <u>Testing</u>             | <u>Justification<br/>of Method<br/>Selected</u> |
|-------------------------------------------------------------------|---------------------|----------------------------|-------------------------------------------------|
| 1. 600-V station service switchgear                               |                     | IEEE-344-71                | B1                                              |
| 2. 600-V-ac MCC                                                   |                     | IEEE-344-71                | B1                                              |
| 3. New battery chargers                                           |                     | IEEE-344-75                | B1                                              |
| 4. Large induction motors                                         | Dynamic             |                            | A2, A3                                          |
| 5. Power transformers                                             | Dynamic             |                            | A2, A3                                          |
| 6. Inverters                                                      |                     | IEEE-344-75                | B1                                              |
| 7. Diesel generators and auxiliary equipment                      | Dynamic             | IEEE-344-71                | A2, A3                                          |
| 8. MCREC system dampers                                           | Dynamic             |                            | A1                                              |
| 9. Fisher air-operated nuclear control valves                     | Dynamic             | IEEE-344-71                | A1                                              |
| 10. WKM air-operated nuclear control valves                       | Dynamic             | IEEE-344-71                | A1                                              |
| 11. Excess-flow check valves                                      |                     | IEEE-344-71                | B1                                              |
| 12. SGTS current-to-current converter                             |                     | IEEE-344-71                | B1                                              |
| 13. Q panels in diesel generator building                         | Dynamic             |                            | A1                                              |
| 14. Nuclear service power-operated valves<br>2 1/2 in. and larger | Dynamic             | IEEE-344-71<br>IEEE-344-75 | A1                                              |
| 15. Nuclear service air-operated valves<br>2 1/2 in. and larger   | Dynamic             |                            | A1                                              |
| 16. Nuclear service power-operated<br>butterfly valves            | Dynamic             | IEEE-344-71<br>IEEE-344-75 | A1                                              |
| 17. Nuclear service air-operated butterfly<br>valves              | Dynamic<br>(valves) | IEEE-344-71<br>(Solenoid)  | A1/B1                                           |

**TABLE 3.10-4 (SHEET 2 OF 2)**

| <u>Item</u>                                                           | <u>Analysis</u> | <u>Testing</u> | <u>Justification<br/>of Method<br/>Selected</u> |
|-----------------------------------------------------------------------|-----------------|----------------|-------------------------------------------------|
| 18. Instrument and service air system accumulators for outboard MSIVs | Dynamic         |                | A1                                              |
| 19. PSW system pumps                                                  | Dynamic         |                | A2, A3                                          |
| 20. H2 recombiners                                                    |                 | IEEE-344-75    | B1                                              |
| 21. Remote shutdown panels and associated components                  | Dynamic         | IEEE-344-71    | A1                                              |
| 22. Post-accident monitoring indicators and recorders                 | Dynamic         | IEEE-344-71    | A1                                              |
| 23. RPT breakers                                                      |                 | IEEE-344-75    | B1                                              |

**NOTES:****A. Qualification by analysis is selected for the following reasons:**

1. The equipment can be physically idealized by a mathematical model. Because of the advance in mathematical technology and availability of high-speed computers, complex equipment can be described mathematically, and its dynamic behavior can be predicted with high level of accuracy.<sup>(a)</sup>
2. It is impractical to test the equipment because of its size.
3. The equipment is subjected to environments that cannot be simulated by test, e.g., pressure and thermal transient loads.<sup>(b)</sup>

**B. Qualification by test is selected for the following reason:**

1. The equipment is so complex in nature that conclusions derived from analysis may not be reliable.

a. Stafford, J. R., "Finite Element Predictions of the Dynamic Response of Power Plant Control Cabinets," Second ASCE Specialty Conference on Structural Design of Nuclear Plant Facilities, Vol. 1-A, p 266, 1975.

b. Meligi, A. E., "Unreliability of Qualifying Active Mechanical Equipment by Testing Only," Second ASCE Specialty Conference on Structural Design of Nuclear Plant Facilities, Vol. II, p II-11, 1975.

HNP-2-FSAR-3

**TABLE 3.10-5**

**TEST RESULTS FOR 600-V-ac MOTOR CONTROL CENTER**

| Required Response Spectra    |             |                |         |                       | Test Results      |          |              |                  |          |              |
|------------------------------|-------------|----------------|---------|-----------------------|-------------------|----------|--------------|------------------|----------|--------------|
| Location                     | Direction   | Frequency (Hz) | RRS (g) | RRS for f = 33 Hz (g) | Minimum Input (g) |          |              | Computed TRS (g) |          |              |
|                              |             |                |         |                       | Front to Back     | Vertical | Side to Side | Front to Back    | Vertical | Side to Side |
| Reactor (el 111 ft)          | Horizontal  | 4.0            | 2.7     | 0.24                  | 1.0               | -        | 0.43         | 25.0             | -        | 10.8         |
|                              |             | 10.0           | 1.7     | 0.24                  | 0.60              | -        | 0.90         | 15.0             | -        | 45.0         |
|                              | Vertical    | 6.5            | 6.9     | 0.29                  | -                 | 0.55     | -            | -                | 27.5     | -            |
| (el 130 ft)                  | Horizontal  | 4.0            | 4.9     | 0.28                  | 1.0               | -        | 0.43         | 50.0             | -        | 10.8         |
|                              |             | 10.0           | 2.0     | 0.28                  | 0.6               | -        | 0.90         | 30.0             | -        | 45.0         |
|                              | Vertical    | 6.5            | 12.1    | 0.43                  | -                 | 0.55     | -            | -                | 55.0     | -            |
|                              |             | 18.0           | 1.7     | 0.43                  | -                 | 1.00     | -            | -                | 100.0    | -            |
| Intake structure (el 111 ft) | North-South | 10.0           | 1.75    | 0.37                  | 0.60              | -        | 0.90         | 6.0              | -        | 9.0          |
|                              | East-West   | 7.0            | 4.34    | 0.43                  | 0.80              | -        | 0.85         | 8.0              | -        | 8.5          |
|                              | Vertical    | 16.0           | 0.70    | 0.17                  | -                 | 1.0      | -            | -                | 10.5     | -            |
| Diesel generator (el 130 ft) | Horizontal  | 4.0            | 3.65    | 0.25                  | 1.0               | -        | 0.43         | 10.0             | -        | 4.3          |
|                              | Vertical    | 5.0            | 2.40    | 0.25                  | -                 | 0.30     | -            | -                | 3.0      | -            |

**TABLE 3.10-6**  
**BATTERY CHARGER**  
**TEST RUN DESCRIPTIONS AND INPUT ACCELERATIONS**

| <u>Number</u> | <u>Axes</u>          | <u>Input Acceleration (g)</u> |                            | <u>Test Level</u> |
|---------------|----------------------|-------------------------------|----------------------------|-------------------|
|               |                      | <u>HZPA</u> <sup>(c)</sup>    | <u>VZPA</u> <sup>(d)</sup> |                   |
| 1             | S-S/V <sup>(a)</sup> | 0.48                          | 0.25                       | < OBE             |
| 2             | S-S/V                | 0.60                          | 0.42                       | OBE               |
| 3             | S-S/V                | 0.70                          | 0.40                       | OBE               |
| 4             | S-S/V                | 0.64                          | 0.40                       | OBE               |
| 5             | S-S/V                | 0.63                          | 0.40                       | OBE               |
| 6             | S-S/V                | 0.86                          | 0.52                       | OBE               |
| 7             | S-S/V                | 1.35                          | 0.60                       | DBE               |
| 8             | F-B/V <sup>(b)</sup> | 0.64                          | 0.44                       | OBE               |
| 9             | F-B/V                | 0.67                          | 0.44                       | OBE               |
| 10            | F-B/V                | 0.60                          | 0.46                       | OBE               |
| 11            | F-B/V                | 0.66                          | 0.41                       | OBE               |
| 12            | F-B/V                | 0.93                          | 0.61                       | OBE               |
| 13            | F-B/V                | 1.31                          | 0.65                       | DBE               |

- a. S-S/V = side to side and vertical.  
b. F-B/V = front to back and vertical.  
c. HZPA = horizontal zero-period acceleration.  
d. VZPA = vertical zero-period acceleration.

**TABLE 3.10-7****100-kW INVERTER TEST RUN DESCRIPTIONS**

| <u>Number</u> | <u>Axes</u> | <u>Input Acceleration (g)</u> |             | <u>Test Level</u> |
|---------------|-------------|-------------------------------|-------------|-------------------|
|               |             | <u>HZPA</u>                   | <u>VZPA</u> |                   |
| 1             | S-S/V       | 0.16                          | 0.09        | < OBE             |
| 2             | S-S/V       | 0.24                          | 0.14        | OBE               |
| 3             | S-S/V       | 0.27                          | 0.15        | OBE               |
| 4             | S-S/V       | 0.27                          | 0.16        | OBE               |
| 5             | S-S/V       | 0.25                          | 0.17        | OBE               |
| 6             | S-S/V       | 0.3                           | 0.19        | OBE               |
| 7             | S-S/V       | 0.5                           | 0.26        | DBE               |
| 8             | F-B/V       | 0.29                          | 0.21        | OBE               |
| 9             | F-B/V       | 0.28                          | 0.21        | OBE               |
| 10            | F-B/V       | 0.28                          | 0.2         | OBE               |
| 11            | F-B/V       | 0.28                          | 0.19        | OBE               |
| 12            | F-B/V       | 0.29                          | 0.19        | OBE               |
| 13            | F-B/V       | 0.49                          | 0.28        | DBE               |

HNP-2-FSAR-3

**TABLE 3.10-8**

**BASLER RELAYS INPUT ACCELERATION**

| <u>Hz</u> | <u>Input (g)</u> |
|-----------|------------------|
| 50 - 12   | 5.0              |
| 12        | 4.7              |
| 11        | 3.4              |
| 10        | 2.7              |
| 9         | 2.3              |
| 8         | 1.5              |
| 7         | 1.0              |
| 6         | 0.8              |
| 5         | 0.8              |

HNP-2-FSAR-3

TABLE 3.10-9 (SHEET 1 OF 2)

EXCESS-FLOW CHECK VALVES INPUT ACCELERATION

| Frequency<br>(Hz) | Inputs<br>(g -peak) |          | Outputs<br>(g -peak) |          |
|-------------------|---------------------|----------|----------------------|----------|
|                   | <u>1</u>            | <u>2</u> | <u>3</u>             | <u>4</u> |
| 1                 | 0.3                 | 0.3      | 0.3                  | 0.3      |
| 2                 | 1.0                 | 1.0      | 1.0                  | 1.0      |
| 3                 | 1.0                 | 1.0      | 1.0                  | 1.0      |
| 4                 | 1.0                 | 1.0      | 1.0                  | 1.0      |
| 5                 | 1.1                 | 1.1      | 1.1                  | 1.0      |
| 6                 | 1.1                 | 1.1      | 1.1                  | 1.1      |
| 7                 | 1.1                 | 1.1      | 1.1                  | 1.1      |
| 8                 | 1.0                 | 1.0      | 1.0                  | 1.0      |
| 9                 | 1.0                 | 1.0      | 1.0                  | 1.0      |
| 10                | 1.0                 | 1.0      | 1.1                  | 1.0      |
| 11                | 1.1                 | 1.0      | 1.1                  | 1.0      |
| 12                | 1.1                 | 1.1      | 1.1                  | 1.1      |
| 13                | 1.1                 | 1.0      | 1.1                  | 1.0      |
| 14                | 1.0                 | 1.0      | 1.0                  | 1.0      |
| 15                | 1.0                 | 1.0      | 1.0                  | 1.0      |
| 16                | 1.0                 | 1.0      | 1.0                  | 1.0      |
| 17                | 1.0                 | 1.1      | 1.0                  | 1.1      |
| 18                | 1.0                 | 1.0      | 1.0                  | 1.0      |
| 19                | 1.0                 | 1.0      | 1.0                  | 1.0      |
| 20                | 1.0                 | 1.0      | 1.0                  | 1.0      |
| 21                | 1.1                 | 1.1      | 1.1                  | 1.1      |
| 22                | 1.1                 | 1.1      | 1.1                  | 1.1      |
| 23                | 1.0                 | 1.0      | 1.0                  | 1.0      |
| 24                | 1.0                 | 1.0      | 1.0                  | 1.0      |
| 25                | 1.0                 | 1.0      | 1.0                  | 1.0      |
| 26                | 1.0                 | 1.0      | 1.0                  | 1.0      |
| 27                | 1.0                 | 1.1      | 1.0                  | 1.1      |
| 28                | 1.0                 | 1.0      | 1.0                  | 1.1      |
| 29                | 1.0                 | 1.0      | 1.0                  | 1.0      |
| 30                | 1.1                 | 1.1      | 1.1                  | 1.1      |
| 31                | 1.0                 | 1.0      | 1.0                  | 1.0      |
| 32                | 1.0                 | 1.0      | 1.0                  | 1.0      |
| 33                | 1.0                 | 1.1      | 1.0                  | 1.1      |
| 34                | 1.0                 | 1.0      | 1.0                  | 1.0      |
| 35                | 1.0                 | 1.0      | 1.0                  | 1.0      |



**TABLE 3.10-9 (SHEET 2 OF 2)**

NOTES:

1. Each frequency was maintained for 30 s.
2. No apparent indication of malfunction, degradation of performance, shell leakage, physical damage, or circuit interruptions (NC or NO) > 10  $\mu$ s was observed.
3. Inputs: 1 - Horizontal control on steel bedplate  
2 - Vertical control on steel bedplate  
  
Outputs: 3 - On valve case, horizontal (across the flow)  
4 - On valve case, vertical

**TABLE 3.10-10**

**SGTS CURRENT-TO-CURRENT CONVERTER INPUT ACCELERATION**

| <u>Frequency</u> | <u>g Level</u> | <u>Duration at Each Frequency</u>               | <u>Total Vibration Time</u> |
|------------------|----------------|-------------------------------------------------|-----------------------------|
| 1 to 2 Hz        | 1 g            | 15 s                                            | 2.5 min                     |
| 2 to 4 Hz        | 2 g            | 15 s                                            |                             |
| 4 to 8 Hz        | 2.5 g          | 15 s                                            |                             |
| 8 to 10 Hz       | 2.5 to 4 g     | 15 s                                            |                             |
| 10 to 20 Hz      | 4 g            | 10 s                                            | 1.5 min                     |
| 20 to 30 Hz      | 2 g            | Sweep 4 min per octave (up only, no down sweep) | ~ 8 min                     |
| 30 to 50 Hz      | 1.5 g          |                                                 |                             |
| 50 to 100 Hz     | 1.0 g          |                                                 |                             |

TABLE 3.10-11

**SEISMIC ANALYSIS OF 18-in., 900-lb OSY GATE VALVE  
(MOTOR OPERATOR)<sup>(a)</sup>**

| Component<br>(Critical) | Material            | Actual Stress (psi) |        |          | Total<br>(psi) | Allowable<br>$S_m$ (psi) |
|-------------------------|---------------------|---------------------|--------|----------|----------------|--------------------------|
|                         |                     | Seismic<br>(3 g)    | Thrust | Pressure |                |                          |
| Body neck               | SA-352<br>grade LCB | 423                 | --     | 5183     | 5606           | 18,900                   |
| Bonnet<br>flange bolt   | A-193<br>grade B7   | 1920                | 10,726 | --       | 12,646         | 35,000                   |
| Yoke arm                | A-216<br>grade WCB  | 738                 | 3445   | --       | 4183           | 23,300                   |
| Operator<br>fasten bolt | A-193<br>grade B7   | 1218                | 32,621 | --       | 33,839         | 35,000                   |

a. Frequency = 36 Hz.

HNP-2-FSAR-3

**TABLE 3.10-12 (SHEET 1 OF 2)**

**SEISMIC TEST REPORT INDEX**

| <u>Unit Size</u>          | <u>Test Facility</u> | <u>Report No.</u> | <u>Report Date</u> | <u>Test Base</u>        | <u>g Level<br/>Each Axis</u> |
|---------------------------|----------------------|-------------------|--------------------|-------------------------|------------------------------|
| 1. Electric Operator      |                      |                   |                    |                         |                              |
| SMB-0-25                  | Lockheed Electronics | 2768-4768A        | 10/21/71           | Uniaxial                | 5                            |
| SMB-0-25 + brake          | Lockheed Electronics | 2768-4768         | 10/21/71           | Uniaxial                | 5.3                          |
| SMC-000-5                 | Ogden                | 7K112-11          | 11/27/72           | Uniaxial                | 5.5 nom.                     |
| SMB-0-25                  | Ogden                | 7K112-11          | 11/27/72           | Uniaxial                | 5.5 nom.                     |
| SMB-0-40                  | Lockheed Electronics | 3521-4811         | 6/17/74            | Uniaxial<br>IEEE-344-71 | 6                            |
| SMB-0-25                  | Aero Nav             | 5720              | 1/6/75             | IEEE-344-75<br>modified | 5 at 3 g<br>1 at 6 g         |
| SMB-000-5                 | Aero Nav             | 5721              | 1/7/75             | IEEE-344-75<br>modified | 5 at 3 g<br>1 at 6 g         |
| SMB-1-40                  | Aero Nav             | 5722              | 1/7/75             | IEEE-344-75<br>modified | 5 at 3 g<br>1 at 6 g         |
| SB-3-100                  | Aero Nav             | 5770              | 10/20/75           | IEEE-344-75             | 5 at 3 g<br>1 at 6 g         |
| SMB-000-5                 | Aero Nav             | 5771              | 10/17/75           | IEEE-344-75             | 5 at 3 g<br>1 at 6 g         |
| SMB-3-100                 | Aero Nav             | 5773              | 10/16/75           | IEEE-344-75             | 2 at 5 g<br>1 at 6 g         |
| SB-0-25                   | Aero Nav             | 5774              | 10/22/75           | IEEE-344-75             | 2 at 5 g<br>1 at 6 g         |
| SMB-0-25DC                | Aero Nav             | 5772              | 10/21/75           | IEEE-344-75             | 2 at 5 g<br>1 at 6 g         |
| SMB-1-100<br>E-line motor | Aero Nav             | 5775              | 10/22/75           | IEEE-344-75             | 2 at 5.3 g<br>1 at 6.3 g     |

HNP-2-FSAR-3

**TABLE 3.10-12 (SHEET 2 OF 2)**

| <u>Unit Size</u>                           | <u>Test Facility</u> | <u>Report No.</u>    | <u>Report Date</u> | <u>Test Base</u>                 | <u>g Level<br/>Each Axis</u>    |
|--------------------------------------------|----------------------|----------------------|--------------------|----------------------------------|---------------------------------|
| SMB-5T-250DC                               | Wyle Labs            | 43059-1              | 10/6/75            | Spec. biaxial                    | 1 g                             |
| SMB-0-25DC                                 | AEL                  | 75-149ET             | 10/29/75           | Single axis                      | 4 g                             |
| SMB-5T-250AC                               | Wyle Labs            | 43059-02             | 10/30/75           | Single axis                      | 6 g                             |
| 2. Electric/Manual Operator <sup>(a)</sup> |                      |                      |                    |                                  |                                 |
| SMB-000-2/HOBC                             | Lockheed Electronics | 2773C-4773           | 5/3/72             | Single axis                      | 4.4 g                           |
| SMB-0-25/H3BC                              | Lockheed Electronics | 2786-4786<br>Issue 2 | 9/5/72             | Single axis                      | 3 g                             |
| SMB-3-100-H5BC                             | Lockheed Electronics | 2786-4-4786          | 2/1/73             | Single axis                      | 4 g                             |
| SMB-0-H3BC                                 | Lockheed Electronics | 2786-3-4786          | 2/6/73             | Single axis                      | 3.7 g                           |
| SMB-1-25/H4BC<br>standard adapter          | Aero Nav             | 5-6167-5             | 12/17/75           | IEEE-344-75<br>fragility<br>test | 8.0 g<br>capacity of<br>machine |
| SMB-00-15/H3BC<br>special steel adapter    | Aero Nav             | 5-6167-4             | 12/16/75           | IEEE-344-75                      | 2 at 5.3 g<br>1 at 6.3 g        |
| 3. Manual Operator                         |                      |                      |                    |                                  |                                 |
| H1BC                                       | Lockheed Electronics | 2553-4737            | 12/28/70           | Single axis                      | 5.3 g                           |
| H1BC                                       | Lockheed Electronics | 2786-5-4786          | 1/30/73            | Single axis                      | 4.6 g                           |
| H4BC                                       | Lockheed Electronics | 2786-6-4786          | 1/30/73            | Single axis                      | 4.6 g                           |
| H6BC                                       | Lockheed Electronics | 2786-7-4786          | 1/30/73            | Single axis                      | 3.6 g                           |

a. The g levels tested for the unit sizes are not to be construed as applicable to all sizes and combinations of SMB/H-BC units. The maximum g level allowed for all sizes is limited to 3 g in any axis. In the future, further testing will qualify other sizes for high g levels.

**TABLE 3.10-13 (SHEET 1 OF 2)**  
**STRESS LEVELS FOR VALVE COMPONENTS**

| <u>Component</u>  | <u>Name</u>                                                     | <u>Symbol</u> | <u>Material</u>      | <u>Stress Level (psi)</u> | <u>Allowable Stress Level (psi)</u> |
|-------------------|-----------------------------------------------------------------|---------------|----------------------|---------------------------|-------------------------------------|
| Body              | Primary membrane stress in crotch region                        | $P_m$         | ASME SA-516 grade 55 | 891                       | $S_m = 13,700$                      |
|                   | Primary plus secondary stress due to internal pressure          | $Q_p$         | ASME SA-516 grade 55 | 2674                      | $S_m = 13,700$                      |
|                   | Pipe reaction stress                                            |               | ASME SA-516 grade 55 |                           | $1.5 S_m = 20,550$                  |
|                   | Axial load                                                      | $P_{ed}$      |                      | 950                       |                                     |
|                   | Bending load                                                    | $P_{eb}$      |                      | 1731                      |                                     |
|                   | Torsional load                                                  | $P_{et}$      |                      | 1731                      |                                     |
|                   | Thermal secondary stress                                        | $Q_t$         | ASME SA-516 grade 55 | 2096                      | $S_m = 13,700$                      |
| Operator mounting | Primary plus secondary stress                                   | $S_n$         | ASME SA-516 grade 55 | 5817                      | $3 S_m = 41,100$                    |
|                   | Normal-duty fatigue stress ( $NA \geq 2000$ )                   | $S_p$         | ASME SA-516 grade 55 | 4052                      | $S_m = 13,700$                      |
|                   | Shear tearout of trunnion bolts through tapped hole in trunnion | $S(1)$        | ASME SA-516 grade 55 | 320                       | $0.5 S_m = 6850$                    |
|                   | Bearing stress of trunnion bolt on tapped hole in trunnion      | $S(2)$        | ASME SA-516 grade 55 | 3384                      | $S_m = 13,700$                      |
|                   | Combined stress in trunnion bolt                                | $S(5)$        | SAE grade 2          | 9374                      | 18,500                              |
|                   | Combined stress in trunnion body                                | $S(45)$       | ASME SA-516 grade 55 | 444                       | $S_m = 13,700$                      |

HNP-2-FSAR-3

TABLE 3.10-13 (SHEET 2 OF 2)

| <u>Component</u>        | <u>Name</u>                           | <u>Symbol</u> | <u>Material</u>                       | <u>Stress Level (psi)</u> | <u>Allowable Stress Level (psi)</u> |
|-------------------------|---------------------------------------|---------------|---------------------------------------|---------------------------|-------------------------------------|
| Banjo assembly          | Maximum combined stress in disc       | S(50)         | ASME SA-351 grade CF8M                | 12,753                    | $S_m = 16,500$                      |
|                         | Maximum combined stress in shaft      | S(53)         | ASME SA-564 type 630 condition H-1150 | 18,566                    | $S_m = 33,700$                      |
|                         | Squeeze pin shear stress              | S(58)         | ASME SA-479 type 316                  | 5215                      | $0.5 S_m = 9200$                    |
| Thrust-bearing assembly | Shaft-bearing compressive stress      | S(61)         | Nylatron GS                           | 2404                      | $S_m = 3000$                        |
|                         | Thrust collar bearing stress          | S(64)         | SAE 660                               | 120                       | $S_m = 8800$                        |
|                         | Clamp ring load                       | S(65)         | -                                     | 519                       | 2610 lb                             |
|                         | Shear stress across thrust collar     | S(66)         | SAE 660                               | 98                        | $0.5 S_m = 4400$                    |
|                         | Tensile stress in thrust-bearing bolt | S(67)         | ASME SA-193 grade B-7                 | 915                       | $S_m = 25,000$                      |
|                         | Shear stress in thrust-bearing bolts  | S(68)         | ASME SA-193 grade B-7                 | 367                       | $0.5 S_m = 12,500$                  |

NOTES:

1. Valve size is 18 in.
2. Operator is MDT-4 (handwheel).

TABLE 3.10-14

**NATURAL FREQUENCIES OF VALVE COMPONENTS  
18-in. VALVE**

| <u>Component</u> | <u>Natural<br/>Frequency<br/>Symbol</u> | <u>Material</u>                             | <u>Natural<br/>Frequency<br/>(Hz)</u> |
|------------------|-----------------------------------------|---------------------------------------------|---------------------------------------|
| Body             | $F_{N^1}$                               | ASME SA-516                                 | 56,423                                |
| Banjo            | $F_{N^2}$                               | ASME SA-564<br>type 630<br>condition H-1150 | 7762                                  |
| Cover cap        | $F_{N^3}$                               | ASME SA-515<br>grade 70                     | 1033                                  |



**TABLE 3.10-15 (SHEET 1 OF 2)**  
**STRESS LEVELS FOR VALVE COMPONENTS**

| <u>Component</u>                 | <u>Name</u>                                                     | <u>Symbol</u>        | <u>Material</u>      | <u>Stress Level (psi)</u> | <u>Allowable Stress Level (psi)</u> |
|----------------------------------|-----------------------------------------------------------------|----------------------|----------------------|---------------------------|-------------------------------------|
| Body                             | Primary membrane stress in crotch region                        | $P_m$                | ASME SA-516 grade 55 | 575                       | $S_m = 13,700$                      |
|                                  | Primary plus secondary stress due to internal pressure          | $Q_p$                | ASME SA-516 grade 55 | 1725                      | $S_m = 13,700$                      |
|                                  | Pipe reaction stress                                            |                      | ASME SA-516 grade 55 |                           | $1.5 S_m = 20,550$                  |
|                                  | Axial load                                                      | $P_{ed}$             |                      | 1647                      |                                     |
|                                  | Bending load                                                    | $P_{eb}$             |                      | 2516                      |                                     |
|                                  | Torsional load                                                  | $P_{et}$             |                      | 2516                      |                                     |
|                                  | Thermal secondary stress                                        | $Q_t$                | ASME SA-516 grade 55 | 1097                      | $S_m = 13,700$                      |
| Operator mounting                | Primary plus secondary stress                                   | $S_n$                | ASME SA-516 grade 55 | 3566                      | $3 S_m = 41,100$                    |
|                                  | Normal-duty fatigue stress ( $NA \geq 2000$ )                   | $S_p$                | ASME SA-516 grade 55 | 3418                      | $S_m = 65,500$                      |
|                                  | Shear tearout of trunnion bolts through tapped hole in trunnion | $S(1)$               | ASME SA-516 grade 55 | 197                       | $0.5 S_m = 6850$                    |
|                                  | Bearing stress of trunnion bolt on tapped hole in trunnion      | $S(2)$               | ASME SA-516 grade 55 | 1124                      | $S_m = 13,700$                      |
|                                  | Combined stress in trunnion bolt                                | $S(5)$               | SAE grade 2          | 3909                      | $S_m = 18,500$                      |
| Combined stress in trunnion body | $S(45)$                                                         | ASME SA-516 grade 55 | 201                  | $S_m = 13,700$            |                                     |

HNP-2-FSAR-3

**TABLE 3.10-15 (SHEET 2 OF 2)**

| <u>Component</u>        | <u>Name</u>                           | <u>Symbol</u> | <u>Material</u>                       | <u>Stress Level (psi)</u> | <u>Allowable Stress Level (psi)</u> |
|-------------------------|---------------------------------------|---------------|---------------------------------------|---------------------------|-------------------------------------|
| Banjo assembly          | Maximum combined stress in disc       | S(50)         | ASME SA-351 grade CF8M                | 9254                      | $S_m = 16,500$                      |
|                         | Maximum combined stress in shaft      | S(53)         | ASME SA-564 type 630 condition H-1150 | 21,703                    | $S_m = 33,700$                      |
|                         | Squeeze pin shear stress              | S(58)         | SA-479 type 316                       | 6014                      | $0.5 S_m = 9200$                    |
| Thrust-bearing assembly | Shaft-bearing compressive stress      | S(61)         | Nylatron GS                           | 1270                      | $S_m = 3000$                        |
|                         | Thrust collar bearing stress          | S(64)         | SAE 660                               | 40                        | $S_m = 8800$                        |
|                         | Clamp ring load                       | S(65)         | -                                     | 64.8 lb                   | 2180 lb                             |
|                         | Shear stress across thrust collar     | S(66)         | SAE 660                               | 27.5                      | $0.5 S_m = 4400$                    |
|                         | Tensile stress in thrust-bearing bolt | S(67)         | ASME SA-193 grade B-7                 | 209                       | $S_m = 25,000$                      |
|                         | Shear stress in thrust-bearing bolts  | S(68)         | ASME SA-193 grade B-7                 | 122                       | $0.5 S_m = 12,500$                  |

NOTES:

1. Valve size is 6 in.
2. Operator is MDT-2 (handwheel).

TABLE 3.10-16

**NATURAL FREQUENCIES OF VALVE COMPONENTS  
6-in. VALVE**

| <u>Component</u> | <u>Natural<br/>Frequency<br/>Symbol</u> | <u>Material</u>                             | <u>Natural<br/>Frequency<br/>(Hz)</u> |
|------------------|-----------------------------------------|---------------------------------------------|---------------------------------------|
| Body             | $F_{N^1}$                               | ASME SA-516<br>grade 55                     | 53,386                                |
| Banjo            | $F_{N^2}$                               | ASME SA-564<br>type 630<br>condition H-1150 | 5499                                  |
| Cover cap        | $F_{N^3}$                               | ASME SA-515<br>grade 70                     | 4501                                  |

TABLE 3.10-17

TABULATION OF STRESSES - PSW PUMPS<sup>(a)(b)</sup>

| <u>Item</u>            | <u>Material</u> | <u>Allowable Stress</u> |            | <u>Calculated Stress</u> |            |
|------------------------|-----------------|-------------------------|------------|--------------------------|------------|
|                        |                 | <u>OBE</u>              | <u>DBE</u> | <u>OBE</u>               | <u>DBE</u> |
| Discharge head - shell | SA283 grade D   | 12,600                  | 29,700     | -                        | 580        |
| Discharge head - base  | SA285 grade D   | 13,700                  | 27,000     | 10,986                   | 16,637     |
| Subbase                | SA283 grade D   | 12,600                  | 29,700     | 11,823                   | 18,164     |
| Column pipe            | SA106 grade B   | 15,000                  | 31,500     | 4562                     | 6549       |
| Pipe - hub stress      | SA106 grade B   | 22,500 <sup>(c)</sup>   | 31,500     | 10,792                   | 12,997     |
| Column flange          | SA285 grade C   | 20,550 <sup>(d)</sup>   | 27,000     | 16,592                   | 23,959     |
| Lineshaft              | A276-410A       | 12,000 <sup>(e)</sup>   | 36,000     | -                        | 11,069     |
| <u>Bolting</u>         |                 |                         |            |                          |            |
| Motor-to-head          | SA193-B7        | 35,000                  | 94,500     | -                        | 3477       |
| Head-to-sub base       | SA193-B7        | 35,000                  | 94,500     | 17,155                   | 26,255     |
| Column flange          | SA193-B8        | 20,000 <sup>(f)</sup>   | 27,000     | 15,577                   | 22,398     |
| Anchor bolts           | NF              | -                       | -          | 8147                     | 17,812     |

a. Allowable stresses at OBE are taken from Tables I-7.3 and I-8.3, ASME Code Section III, except where noted.

b. Allowable stresses at DBE are 90% of YS.

c. In accordance with NB 3647.1 Section III. Allowable  $S_H = 1.5 S_m$ .

d. In accordance with NB 3647.1 Section III. Allowable  $S_R = 1.5 S_m$ .

e. Combined shear allowable = 30% of YS in accordance with ANSI B58.1.

f. In accordance with NB 3232.1. Allowable = two times the value listed in I-1.3.

HNP-2-FSAR-3

**TABLE 3.10-18**

**LATERAL PLANE TESTING**

The test fixture was subjected to two beats at each of the following:

| <u>Beat Frequency (Hz)</u> | <u>Peak Acceleration (g)</u> |
|----------------------------|------------------------------|
| 0.5                        | 0.6                          |
| 1.0                        | 0.8                          |
| 2.0                        | 1.0                          |
| 3.0                        | 1.5                          |
| 4.0                        | 4.0                          |
| 5.0                        | 6.4                          |
| 6.0                        | 6.4                          |
| 7.0                        | 6.4                          |
| 8.0                        | 6.4                          |
| 9.0                        | 6.4                          |
| 10.0                       | 6.4                          |
| 11.0                       | 6.4                          |
| 12.0                       | 6.4                          |
| 13.0                       | 6.4                          |
| 14.0                       | 6.4                          |
| 15.0                       | 6.4                          |
| 16.0                       | 6.4                          |
| 18.0                       | 3.6                          |
| 20.0                       | 2.0                          |
| 22.0                       | 1.0                          |
| 24.0                       | 1.0                          |
| 26.0                       | 1.0                          |
| 28.0                       | 1.0                          |
| 30.0                       | 1.0                          |

HNP-2-FSAR-3

**TABLE 3.10-19**

**LONGITUDINAL PLANE TESTING**

The test fixture was subjected to two beats at each of the following:

| <u>Beat Frequency (Hz)</u> | <u>Peak Acceleration (g)</u> |
|----------------------------|------------------------------|
| 0.5                        | 0.6                          |
| 1.0                        | 0.8                          |
| 2.0                        | 1.0                          |
| 3.0                        | 1.5                          |
| 4.0                        | 4.0                          |
| 5.0                        | 6.4                          |
| 6.0                        | 6.4                          |
| 7.0                        | 6.4                          |
| 8.0                        | 6.4                          |
| 9.0                        | 6.4                          |
| 10.0                       | 6.4                          |
| 11.0                       | 6.4                          |
| 12.0                       | 6.4                          |
| 13.0                       | 6.4                          |
| 14.0                       | 6.4                          |
| 15.0                       | 6.4                          |
| 16.0                       | 6.4                          |
| 18.0                       | 3.6                          |
| 20.0                       | 2.0                          |
| 22.0                       | 1.0                          |
| 24.0                       | 1.0                          |
| 26.0                       | 1.0                          |
| 28.0                       | 1.0                          |
| 30.0                       | 1.0                          |

HNP-2-FSAR-3

**TABLE 3.10-20**

**VERTICAL PLANE TESTING**

The test fixture was subjected to two beats at each of the following:

| <u>Beat Frequency (Hz)</u> | <u>Peak Acceleration (g)</u> |
|----------------------------|------------------------------|
| 0.5                        | 0.4                          |
| 1.0                        | 0.6                          |
| 2.0                        | 0.8                          |
| 3.0                        | 1.2                          |
| 4.0                        | 2.8                          |
| 5.0                        | 4.0                          |
| 6.0                        | 4.0                          |
| 7.0                        | 4.0                          |
| 8.0                        | 4.0                          |
| 9.0                        | 4.0                          |
| 10.0                       | 4.0                          |
| 11.0                       | 4.0                          |
| 12.0                       | 4.0                          |
| 13.0                       | 4.0                          |
| 14.0                       | 4.0                          |
| 15.0                       | 4.0                          |
| 16.0                       | 4.0                          |
| 18.0                       | 2.8                          |
| 20.0                       | 1.3                          |
| 22.0                       | 0.7                          |
| 24.0                       | 0.7                          |
| 26.0                       | 0.7                          |
| 28.0                       | 0.7                          |
| 30.0                       | 0.7                          |

HNP-2-FSAR-3

**TABLE 3.10-21**

**CLASS 1E EQUIPMENT COMPRISING THE ATTS**

| <u>Component</u>                                      | <u>Manufacturer</u>     | <u>Primary Class<br/>1E Function</u>                           | <u>Qualification<br/>Environment<sup>(b)</sup></u> | <u>Seismic<br/>Qualification<br/>Level</u> | <u>Resonant<br/>Frequency<sup>(c)</sup><br/>(Hz)</u> |
|-------------------------------------------------------|-------------------------|----------------------------------------------------------------|----------------------------------------------------|--------------------------------------------|------------------------------------------------------|
| Pressure transmitter                                  | Barton                  | Provide current output response to pressure input              | Reactor building                                   | (d)                                        | ----                                                 |
| Differential pressure transmitter                     | Barton                  | Provide current output response to differential pressure input | Reactor building                                   | (d)                                        | ----                                                 |
| Pressure transmitter                                  | Rosemont <sup>(a)</sup> | Provide current output response to pressure input              | Reactor building                                   | (e)                                        | ----                                                 |
| Differential pressure transmitter                     | Rosemont <sup>(a)</sup> | Provide current output response to differential pressure input | Reactor building                                   | (e)                                        | ----                                                 |
| Resistance temperature detector (RTD)                 | Weed                    | Provide current output response to temperature input           | Reactor building                                   | (f)                                        | ----                                                 |
| Pressure switch                                       | PCI                     | Provide contact transfer at pressure trip point                | Drywell                                            | (f)                                        | ----                                                 |
| Trip units (master, slave, RTD, differential voltage) | GE                      | Provide trip function at the process variable trip point       | Control room                                       | (g)                                        | ----                                                 |
| Relay                                                 | Agastat                 | Contact transfer in response to trip unit trip                 | Control room                                       | (g)                                        | ----                                                 |
| Voltage converter                                     | Datametrics             | Provide power to the ATTS cabinets and instrument loops        | Control room                                       | (g)                                        | ----                                                 |

a. The Rosemont transmitters are also used in other applications.

b. For service environments, see tables 4-1 through 4-3 of NEDE-22154-1.

c. No resonant frequencies  $\leq$  33 Hz were identified for any of the devices.

d. See figure 4-12 of NEDE-22154-1. The horizontal qualification levels for these devices are equal to half the acceleration levels defined in figure 4-12. This reduction is employed to account for the simulation of triaxial testing.

e. The Rosemont transmitters, which were not qualified as a part of the original ATTS qualification program, are qualified to seismic levels that exceed the seismic requirements at the transmitter location.

f. See figure 4-11 of NEDE-22154-1. The horizontal qualification levels for these devices are equal to half the acceleration levels defined in figure 4-11. This reduction is employed to account for the simulation of triaxial testing.

g. See figures 4-5 and 4-6 of NEDE-22154-1 for the seismic qualification levels for the cabinets in which these devices are mounted.



HNP-2-FSAR-3

**TABLE 3.10-22 (SHEET 1 OF 2)**

**SEISMIC QUALIFICATION TEST SUMMARY FOR ATTS CONTROL PANELS AND LOCAL RACKS**


| <u>Control Panel No.</u> | <u>Description</u>     | <u>Type</u>   | <u>Class 1E Equipment Description</u>                         | <u>Comments</u>        |
|--------------------------|------------------------|---------------|---------------------------------------------------------------|------------------------|
| H11-P921                 | RPS cabinet            | Control panel | Agastat relays, GE trip units, Datametrics voltage converters | Seismic test completed |
| H11-P922                 | RPS cabinet            | Control panel | Agastat relays, GE trip units, Datametrics voltage converters | Seismic test completed |
| H11-P923                 | RPS cabinet            | Control panel | Agastat relays, GE trip units, Datametrics voltage converters | Seismic test completed |
| H11-P924                 | RPS cabinet            | Control panel | Agastat relays, GE trip units, Datametrics voltage converters | Seismic test completed |
| H11-P925                 | ECCS cabinet           | Control panel | Agastat relays, GE trip units, Datametrics voltage converters | Seismic test completed |
| H11-P926                 | ECCS cabinet           | Control panel | Agastat relays, GE trip units, Datametrics voltage converters | Seismic test completed |
| H11-P927                 | ECCS cabinet           | Control panel | Agastat relays, GE trip units, Datametrics voltage converters | Seismic test completed |
| H11-P928                 | ECCS cabinet           | Control panel | Agastat relays, GE trip units, Datametrics voltage converters | Seismic test completed |
| H21-P016                 | CS/HPCI leak detector  | Local rack    | Process transmitter                                           | Seismic test completed |
| H21-P036                 | HPCI leak detector     | Local rack    | Process transmitter                                           | Seismic test completed |
| H21-P038                 | RCIC leak detector     | Local rack    | Process transmitter                                           | Seismic test completed |
| H21-P401                 | CS system              | Local rack    | Process transmitter                                           | Seismic test completed |
| H21-P402                 | RWC system             | Local rack    | Process transmitter                                           | Seismic test completed |
| H21-P404A                | Reactor pressure/level | Local rack    | Process transmitter                                           | Seismic test completed |
| H21-P404B                | Reactor pressure/level | Local rack    | Process transmitter                                           | Seismic test completed |
| H21-P404C                | Reactor pressure/level | Local rack    | Process transmitter                                           | Seismic test completed |
| H21-P404D                | Reactor pressure/level | Local rack    | Process transmitter                                           | Seismic test completed |

HNP-2-FSAR-3

**TABLE 3.10-22 (SHEET 2 OF 2)**

| <u>Control Panel No.</u> | <u>Description</u>     | <u>Type</u> | <u>Class 1E Equipment Description</u> | <u>Comments</u>        |
|--------------------------|------------------------|-------------|---------------------------------------|------------------------|
| H21-P405A                | Reactor pressure/level | Local rack  | Process transmitter                   | Seismic test completed |
| H21-P405B                | Reactor pressure/level | Local rack  | Process transmitter                   | Seismic test completed |
| H21-P405C                | Reactor pressure/level | Local rack  | Process transmitter                   | Seismic test completed |
| H21-P405D                | Reactor pressure/level | Local rack  | Process transmitter                   | Seismic test completed |
| H21-P409                 | Jet pump               | Local rack  | Process transmitter                   | Seismic test completed |
| H21-P410                 | Jet pump               | Local rack  | Process transmitter                   | Seismic test completed |
| H21-P414A                | HPCI system            | Local rack  | Process transmitter                   | Seismic test completed |
| H21-P414B                | HPCI system            | Local rack  | Process transmitter                   | Seismic test completed |
| H21-P415A                | Main steam line flow   | Local rack  | Process transmitter                   | Seismic test completed |
| H21-P415B                | Main steam line flow   | Local rack  | Process transmitter                   | Seismic test completed |
| H21-P417A                | RCIC system            | Local rack  | Process transmitter                   | Seismic test completed |
| H21-P417B                | RCIC system            | Local rack  | Process transmitter                   | Seismic test completed |
| H21-P418A                | RHR system             | Local rack  | Process transmitter                   | Seismic test completed |
| H21-P418B                | RHR system             | Local rack  | Process transmitter                   | Seismic test completed |
| H21-P419                 | CS system              | Local rack  | Process transmitter                   | Seismic test completed |
| H21-P425A                | Main steam line flow   | Local rack  | Process transmitter                   | Seismic test completed |
| H21-P425B                | Main steam line flow   | Local rack  | Process transmitter                   | Seismic test completed |
| H21-P434                 | HPCI system            | Local rack  | Process transmitter                   | Seismic test completed |
| H21-P435                 | RCIC leak detection    | Local rack  | Process transmitter                   | Seismic test completed |
| H21-P437                 | RCIC leak detection    | Local rack  | Process transmitter                   | Seismic test completed |

- a. Emergency core cooling system.  
b. Reactor core isolation cooling.




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TRS VERSUS RRS - CONTROL BUILDING  
 el 130 (LATERAL AND VERTICAL)

FIGURE 3.10-1




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TRS VERSUS RRS – REACTOR BUILDING  
 el 130 (LATERAL)

FIGURE 3.10-2




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TRS VERSUS RRS – INTAKE STRUCTURE  
 el 111 (LATERAL)

FIGURE 3.10-3




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TRS VS RRS – DIESEL GENERATOR BUILDING  
 el 130 (LATERAL)

FIGURE 3.10-4




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TRS VS RRS - DIESEL GENERATOR BUILDING  
 el 130 (LATERAL)

FIGURE 3.10-5



REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TRS VS RRS – REACTOR BUILDING  
 el 130 (VERTICAL)

FIGURE 3.10-6





REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TRS VS RRS – INTAKE STRUCTURE  
 es 111 (VERTICAL)

FIGURE 3.10-7

FULL-SCALE SHOCK SPECTRUM (g Peak)

1   
  10   
  100   
  1000  
 DAMPING  3%



REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TRS VS RRS – BATTERY CHARGER  
 FULL-SCALE SHOCK SPECTRUM

FIGURE 3.10-8 (SHEET 1 OF 4)

FULL-SCALE SHOCK SPECTRUM (g Peak)

1     10     100     1000  
 DAMPING  3%



REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TRS VS RRS – BATTERY CHARGER  
 FULL-SCALE SHOCK SPECTRUM

FIGURE 3.10-8 (SHEET 2 OF 4)

FULL-SCALE SHOCK SPECTRUM (g Peak)

1   
  10   
  100   
  1000  
 DAMPING  3%



REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TRS VS RRS – BATTERY CHARGER  
 FULL-SCALE SHOCK SPECTRUM

FIGURE 3.10-8 (SHEET 3 OF 4)

FULL-SCALE SHOCK SPECTRUM (g Peak)

1    10    100    1000  
DAMPING  3%



REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2


TRS VS RRS – BATTERY CHARGER  
FULL-SCALE SHOCK SPECTRUM

FIGURE 3.10-8 (SHEET 4 OF 4)

FULL-SCALE SHOCK SPECTRUM (g Peak)

□ 1    ☒ 10    □ 100    □ 1000

DAMPING  9%



REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2


TRS VS RRS – 100-kW INVERTERS  
 FULL-SCALE SHOCK SPECTRUM

FIGURE 3.10-9 (SHEET 1 OF 4)

FULL-SCALE SHOCK SPECTRUM (g Peak)

1  10  100  1000

DAMPING  5%



REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TRS VS RRS – 100-kW INVERTERS  
FULL-SCALE SHOCK SPECTRUM

FIGURE 3.10-9 (SHEET 2 OF 4)

FULL-SCALE SHOCK SPECTRUM (g Peak)

1     10     100     1000  
 DAMPING  5%



FREQUENCY (Hz)

AXIS F-B/VERT.

LOCATION NO. VCA

TEST RUN NO. 13

REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2


TRS VS RRS – 100-kW INVERTERS  
 FULL-SCALE SHOCK SPECTRUM

FIGURE 3.10-9 (SHEET 3 OF 4)



FULL-SCALE SHOCK SPECTRUM (g Peak)

1    10    100    1000  
 DAMPING  5%




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TRS VS RRS – 100-kW INVERTERS  
 FULL-SCALE SHOCK SPECTRUM

FIGURE 3.10-9 (SHEET 4 OF 4)




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TRS VS RRS - REACTOR BUILDING VESSEL AT el 204  
(LATERAL AND VERTICAL)

FIGURE 3.10-10




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TRS VERSUS RRS – CONTROL BUILDING  
el 164 (VERTICAL) (5-PERCENT DAMPING)

FIGURE 3.10-11




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TRS VS RRS - REACTOR BUILDING  
e1 158 (LATERAL)

FIGURE 3.10-12



REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TRS VS RRS – REACTOR BUILDING  
el 158 (VERTICAL)

FIGURE 3.10-13

E.I. HATCH UNIT NO. 2 REACTOR BLDG. NORTH-SOUTH DBE OF 701 HALL

ACCELERATION SPECTRUM POINT 4 ELEV. 185. DRPS VALUES




REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TRS VS RRS  
RPT BREAKERS

FIGURE 3.10-14 (SHEET 1 OF 6)



REV 19 7/01



REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TRS VS RRS  
RPT BREAKERS

FIGURE 3.10-14 (SHEET 3 OF 6)



E.I. HATCH NPP UNIT NO. 2 REACTOR BLDG. EAST-WEST SSE (E. 02) ANGLE




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TRS VS RRS  
RPT BREAKERS

FIGURE 3.10-14 (SHEET 4 OF 6)




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TRS VS RRS  
RPT BREAKERS

FIGURE 3.10-14 (SHEET 5 OF 6)



REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TRS VS RRS  
RPT BREAKERS

FIGURE 3.10-14 (SHEET 6 OF 6)

### **3.11 ENVIRONMENTAL DESIGN OF MECHANICAL AND ELECTRICAL EQUIPMENT**

The mechanical and electrical portions of the engineered safety feature and reactor protection systems are designed, tested, and/or analyzed for the worst-case environmental service conditions.

Many of the analyses confirming the environmental qualification of safety-related equipment meet the definition of a time-limited aging analysis pursuant to 10 CFR 54.3. (See subsection 18.1.3 and section 18.5 for additional information.)

#### **3.11.1 EQUIPMENT IDENTIFICATION**

All equipment that is required to function during and subsequent to any of the design basis accidents (DBAs) is identified in the Final Safety Analysis Report as listed below:

- Equipment supplied by General Electric (GE).
  - Mechanical equipment - tables 3.2-1 and 3.9-34.
  - Electrical equipment (including instrumentation) - paragraphs 3.2.1.4 and 3.2.1.5.
- Equipment not supplied by GE.
  - Mechanical equipment - tables 3.2-1 and 3.9-33.
  - Electrical equipment (including instrumentation) - paragraphs 3.2.1.4 and 3.2.1.5.

#### **3.11.2 QUALIFICATION TESTS AND ANALYSIS**

##### **3.11.2.1 Qualification Tests and Analyses for Equipment Supplied by General Electric**

###### **A. Mechanical Equipment**

Mechanical equipment required to operate during and subsequent to DBAs is designed to the applicable codes and standards specified in table 3.2-1 and the purchase specification.

Where applicable, mechanical equipment is designed to the environments specified in table 3.9-34.

B. Electrical Equipment (Including Instrumentation)

1. Electrical Class 1E Equipment Located in a Harsh Environment and Required to Mitigate a Loss-of-Coolant Accident (LOCA) or High-Energy Line Break.

On May 23, 1980, the Nuclear Regulatory Commission (NRC) issued a Commission Memorandum And Order CLI-80-21 which required the licensee to ensure that all Class 1E equipment meet the requirements of the NRC Division of Operating Reactors (DOR) Guidelines if the equipment was installed before May 23, 1980. The order required that Class 1E equipment installed after May 23, 1980, shall meet the requirements of NUREG-0588, Category I.

Subsequently, the NRC issued Rulemaking 10 CFR 50.49 on February 22, 1983, concerning environmental qualification of electric equipment important to safety. The rule superseded the May 23, 1980 order and required that all equipment installed after February 22, 1983, be upgraded from the DOR guidelines unless there are "sound reasons to the contrary." The acceptable "sound reasons to the contrary" can be found in Regulatory Guide 1.89, Revision 1.

Current information regarding equipment qualification is maintained in the Central File for the Environmental Qualification of Safety Related Equipment.

2. Electrical Class 1E Equipment Not Required to Mitigate a LOCA or High-Energy Line Break but Located in a Harsh Environment, or Class 1E Equipment Located in a Non-Harsh Environment.

All Class 1E equipment supplied by GE was qualified in accordance with Institute of Electrical and Electronics Engineers (IEEE) 323-1971. Since many of these items are used in several systems and in different plant locations, they were tested and analyzed for the worst-case situation.

The Class 1E equipment supplied by GE, which was qualified by testing, was first described by equipment specification which included or enveloped the intended application environment. The equipment design specification requirements are included on the purchased-part drawing for each essential device or are part of a design and performance specification drawing for GE-manufactured devices. Type tests were performed on pilot units to show conformance to the requirements of the equipment specifications. The test results were documented in a qualification test report or vendor-supplied certification.

The test plan, setup, procedure, and acceptability goals and requirements are all part of a qualification file maintained for each essential device. This information is filed according to product drawing number. Two types of documents are written as a condensed version of the detailed information

contained in the actual test reports. These documents are an environmental qualification summary and a seismic qualification summary.

**3.11.2.2 Qualification Tests and Analysis for Equipment Not Supplied by General Electric**

A. Mechanical Equipment

Mechanical equipment required to operate during and subsequent to DBAs is designed to the applicable codes and standards specified in table 3.2-1 and the purchase specification.

Table 3.9-33 lists the active valves in Seismic Category I systems and the environmental conditions to which they are designed.

B. Electrical Equipment (Including Instrumentation)

1. Electrical Class 1E Equipment Located in a Harsh Environment and Required To Mitigate a LOCA or High-Energy Line Break. (See paragraph 3.11.2.1.B.1.)

All Class 1E equipment was qualified as a minimum in accordance with the provisions of 10 CFR 50.49. Since this equipment is used in different systems and plant locations, it was tested or analyzed for the worst-case environmental conditions as specified in the equipment specifications and as listed in the Central File. Table 3.11-1 provides information relative to area design conditions.

2. Electrical Class 1E Equipment Not Required to Mitigate a LOCA or High-Energy Line Break but Located in a Harsh Environment or Class 1E Equipment Located in a Non-Harsh Environment.

For equipment with standardized and proven design, the representative equipment was tested up to and beyond the nominal ratings. In addition, production inspection and testing were performed on the equipment purchased in accordance with National Electrical Manufacturers Association (NEMA) publications and American National Standards Institute (ANSI) standards as indicated below:

| <u>Equipment</u>         | <u>Standards</u> |
|--------------------------|------------------|
| Control panels and racks | NEMA ICS         |
| 5-kV switchgears         | ANSI C-37.20     |
| 600-V load centers       | NEMA SG-3        |
| Motors                   | NEMA MG-1        |

HNP-2-FSAR-3

| <u>Equipment</u>                   | <u>Standards</u> |
|------------------------------------|------------------|
| 250-V-dc switchgears               | NEMA SG-3        |
| Diesel generator control equipment | NEMA ICS         |

**3.11.3 QUALIFICATION TEST RESULTS**

**3.11.3.1 Qualification Test Results for Equipment Supplied by General Electric**

A. Mechanical Equipment

For equipment of standardized and proven design, the production inspection and testing ensure the proper functioning of the equipment under service environmental conditions.

B. Electrical Equipment (Including Instrumentation)

1. Electrical Class 1E Equipment Located in a Harsh Environment and Required to Mitigate a LOCA or High-Energy Line Break. (See paragraph 3.11.2.1.B.1.)

The Plant Hatch Central File provides the normal and accident qualification environments to which Class 1E equipment supplied by GE is exposed during qualification testing. Detailed test results are on file at GE-San Jose.

The analog transmitter trip system (ATTS) instrumentation is qualified to the requirements of IEEE 323-74 and Rulemaking 10 CFR 50.49. Table 7.8-1 provides the instrumentation included in this system. NEDE-22154-1 and NEDC-30039-1 provide a detailed discussion of the environmental qualification program and its applicability to Plant Hatch.

2. Electrical Class 1E Equipment Not Required to Mitigate a LOCA or High-Energy Line Break but Located in a Harsh Environment or Class 1E Equipment Located in a Non-Harsh Environment. (See paragraph 3.11.2.1.B.2.)

For equipment of standardized and proven design, the production inspection and testing ensure the proper functioning of the equipment under service environmental conditions.

**3.11.3.2 Qualification Test Results for Equipment Not Supplied by General Electric**

A. Mechanical Equipment

For equipment of standardized and proven design, the production inspection and testing ensure the proper functioning of the equipment under service environmental conditions.

B. Electrical Equipment (Including Instrumentation)

1. Electrical Class 1E Equipment Located in a Harsh Environment and Required to Mitigate a LOCA or High-Energy Line Break. (See paragraph 3.11.2.1.B.1.)
2. Electrical Class 1E Equipment Not Required to Mitigate a LOCA or High-Energy Line Break but Located in a Harsh Environment, or Class 1E Equipment Located in a Non-Harsh Environment.

For equipment of standardized and proven design, the production inspection and testing ensure the proper functioning of the equipment under service environmental conditions.

**3.11.4 PROCUREMENT OF NEW EQUIPMENT**

All new equipment, which falls under the scope of 10 CFR 50.49, is purchased to meet that requirement. In general, as part of that requirement, new equipment is evaluated against the worst-case environmental profiles through which the equipment must function. These profiles are provided in the central documentation file.

For the applicable equipment inside containment, the evaluation is performed against the composite profile provided in figure 3.11-1. This composite profile was developed using the worst-case guillotine break inside containment and the plant-specific main steam line break analysis developed by General Electric in NSEO-52-0583, dated June 1983. Operator action to initiate drywell spray is assumed to occur after 30 min.

This analysis was developed using the guidelines of NUREG-0588. For equipment inside containment that cannot meet the composite profile, an evaluation against the individual profiles may be performed.



**3.11.5 LOSS OF VENTILATION**

- A. The operability of all Seismic Category I control and electric equipment located in the control room and other areas is ensured by providing each room with redundant Seismic Category I heating, ventilation, and/or air-conditioning systems as described in section 9.4.
- B. The equipment qualification tests and analyses are described in subsection 3.11.2 and table 3.9-24. The summaries of qualification test results the tests and analyses are provided in subsection 3.11.3.

HNP-2-FSAR-3

TABLE 3.11-1 (SHEET 1 OF 2)


AREA ENVIRONMENTAL CONDITIONS FOR EQUIPMENT QUALIFICATION<sup>(a)</sup>

| Location                | Temperature (°F) |                             | Pressure (psia) |                     | Humidity (%) |     | Radiation (rads) <sup>(b)</sup> |
|-------------------------|------------------|-----------------------------|-----------------|---------------------|--------------|-----|---------------------------------|
|                         | Normal           | DBE (max)                   | Normal          | DBE (max)           | Range        | DBE |                                 |
| Containment (drywell)   | (e)              | 330                         | 16.7            | 62.0                | 40-90        | 100 | 1.22 x 10 <sup>8</sup>          |
| Reactor bldg el 203 ft  | 90               | 200                         | 14.7            | 15.0                | 50-80        | 100 | 1.90 x 10 <sup>5</sup>          |
| Reactor bldg el 185 ft  | 90               | 205                         | 14.7            | 15.04               | 50-80        | 100 | 1.90 x 10 <sup>5</sup>          |
| Reactor bldg el 158 ft  | 90               | 210                         | 14.7            | 15.06               | 50-80        | 100 | 2.51 x 10 <sup>6</sup>          |
| Reactor bldg el 130 ft  | 90               | 213                         | 14.7            | 16.7                | 50-80        | 100 | 2.37 x 10 <sup>6</sup>          |
| RWC heat exchanger room | 90               | 217                         | 14.7            | 16.36               | 50-80        | 100 | 9.93 x 10 <sup>6</sup>          |
| RWC pump room           | 90               | 218                         | 14.7            | 16.59               | 50-80        | 100 | 2.19 x 10 <sup>5</sup>          |
| Pipe penetration room   | 105              | 215                         | 14.7            | 16.50               | 50-80        | 100 | 1.55 x 10 <sup>7</sup>          |
| Pipe chase              | 105              | 300                         | 14.7            | 17.75               | 50-80        | 100 | 1.27 x 10 <sup>7</sup>          |
| Torus room              | 105              | 216                         | 14.7            | 16.74               | 50-90        | 100 | 1.40 x 10 <sup>7</sup>          |
| RCIC corner room (NW)   | 105              | 295                         | 14.7            | 15.8                | 50-90        | 100 | 9.85 x 10 <sup>4</sup>          |
| SW corner room          | 105              | 311                         | 14.7            | 16.23               | 50-90        | 100 | 9.85 x 10 <sup>4</sup>          |
| HPCI room               | 105              | 148 for 12 h <sup>(c)</sup> | 14.7            | 14.7 <sup>(d)</sup> | 50-90        | 100 | 9.85 x 10 <sup>4</sup>          |
| NE corner room (RHR)    | 104              | 148                         | 14.7            | 14.7                | 50-90        | 100 | 6.15 x 10 <sup>6</sup>          |
| SE corner room (RHR)    | 104              | 215                         | 14.7            | 16.0                | 50-90        | 100 | 6.15 x 10 <sup>6</sup>          |

HNP-2-FSAR-3

**TABLE 3.11-1 (SHEET 2 OF 2)**

- 
- a. Individual component equipment qualification is based on environmental conditions specified in the Plant Hatch Central File of Environmental Qualification of Safety-Related Equipment. The information in this table should be verified before use.
  - b. Total integrated dose for the area specified (DBA + 60 years, normal dose).
  - c. The temperature is based on a high-energy line break outside the high pressure coolant injection room; an analysis indicates the reactor core decay heat will not produce sufficient steam to drive the HPCI turbine after 12 h.
  - d. 27.4 psia for isolation equipment only.
  - e. Temperature varies depending on drywell location.



NOTES: 1. The profile after this time is to simulate post-accident operation and may be modified by the vendor to accelerate the aging time based on material aging characteristics.

ACAD 2031101

REV 27 10/09



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

WORST-CASE ACCIDENT PROFILE FOR  
EQUIPMENT LOCATED IN CONTAINMENT

FIGURE 3.11-1

## 4.0 REACTOR

### 4.1 REACTOR SUMMARY DESCRIPTION (HNP-1 AND HNP-2)

The information provided in this section is applicable to both HNP-1 and HNP-2, unless specified otherwise.

The reactor assembly of the Edwin I. Hatch Nuclear Plant Unit 1 (HNP-1) and Unit 2 (HNP-2) consists of the reactor pressure vessel (RPV) and its internal components of the core, shroud, steam separator and dryer assemblies, and jet pumps. Also included in the reactor assembly are the control rods, control rod drive (CRD) housings, and the CRD. The HNP-1 and the HNP-2 RPV assembly cutaway (figure 4.1-1) shows the arrangement of reactor assembly components. Loading conditions for reactor assembly components are specified in HNP-1-FSAR appendix C and HNP-2-FSAR table 3.9-4. Summary tables of the pertinent reactor data are presented at the end of sections 4.2, 4.3, and 4.4.

#### 4.1.1 REACTOR PRESSURE VESSEL

The RPV design and description are covered in HNP-1-FSAR section 4.2 and appendix C, and HNP-2-FSAR section 5.4.

#### 4.1.2 REACTOR INTERNAL COMPONENTS

The major reactor internal components are as follows:

- Core (fuel, channels, control blades, and instrumentation).
- Core support structure, including core shroud, top guide, and core support.
- Shroud head and separators.
- Steam dryer assembly.
- Jet pumps.

Except for the Zircaloy in the reactor core, the reactor internals are either stainless steel or other corrosion-resistant alloys. With the exception of the jet pump diffusers, core shroud, core spray (CS) spargers, and jet pump inlet piping, all the major internal components can be removed. The removal of the steam dryers, shroud head and separators, fuel assemblies, incore instruments, control rods, CRDs, and control rod guide tubes can be accomplished on a routine basis.

#### **4.1.2.1 Reactor Core**

The reactor core consists of 560 channeled boiling water reactor (BWR) fuel assemblies; 137 cruciform-shaped, bottom-entry control blades; and 124 fission chamber detectors that continuously monitor core thermal power during power operation. Each core component is described in detail in other sections.

##### **4.1.2.1.1 Core Configuration**

The reactor core is arranged as an upright circular cylinder containing a large number of fuel cells and is located within the RPV. The coolant flows upward through the core. The core arrangement (plan view) is shown in figure 4.1-2. The BWR core is essentially composed of only two components -- fuel assemblies and control rods. Core configurations for each reload core are described in the corresponding supplemental reload licensing report. (Table 15.1-1 provides a list of the cycle-specific supplemental reload licensing reports for HNP-1 and HNP-2.)

##### **4.1.2.1.2 Fuel Assembly Description**

Fuel assemblies are described in subsection 4.2.1.

#### **4.1.2.2 Shroud**

The shroud is a cylindrical, stainless-steel structure that surrounds the core and provides a barrier to separate the upward flow through the core from the downward flow in the annulus. The shroud also provides a floodable volume in the unlikely event of an incident that tends to drain the RPV. A flange at the top of the shroud cylinder mates with a flange on the shroud head to form the core discharge plenum. The jet pump discharge diffusers penetrate the shroud support below the core elevation to introduce the coolant to the lower inlet plenum. The shroud is designed, constructed, and installed to prevent a direct flow path between the inlet and outlet of each recirculation system loop. The shroud support is designed to support and locate the jet pumps and the core support structure, and provides lateral support for the fuel assemblies.

Mounted inside the shroud top cylinder in the space between the top of the core and the flange at the top of the shroud are the two CS spargers with spray nozzles for injection of cooling water. The CS spargers and nozzles do not interfere with the installation or removal of fuel from the core. A pipe for the injection of neutron absorber (sodium pentaborate) solution is mounted below the core to ensure mixing with the cooling water rising through the core.

#### **4.1.2.3 Shroud Head and Separators**

The shroud head and separators consist of a flange and dome onto which is welded an array of standpipes with a steam separator located at the top of each standpipe. The shroud head mounts on the flange at the top of the shroud top cylinder and forms the cover (shroud head) of

the core discharge plenum region. The joint between the shroud head and shroud top cylinder does not require a gasket or other replacement sealing techniques. The fixed axial flow-type steam separators have no moving parts and are made of stainless steel.

In each separator, the steam water mixture rises from the standpipe and impinges on vanes which give the mixture a spin to establish a vortex wherein the centrifugal forces separate the steam from the water. Steam leaves the separator at the top and passes into the wet steam plenum below the dryer. The separated water exits from the lower end of the separator and enters the pool that surrounds the standpipes to enter the downcomer annulus. An internal steam separator schematic is shown on figure 4.1-3.

For ease of removal, the shroud head and separators are bolted to the top cylinder by long shroud head bolts that extend above the separators for easy access during refueling. The shroud head and separators are guided into position on the shroud and flange with guide rods and locating pins. The objective of the long-bolt design is to provide direct access to the bolts during reactor refueling operations with minimum depth underwater tool manipulation during the removal and installation of the assemblies.

#### **4.1.2.4 Steam Dryer Assembly**

The steam dryer assembly is mounted in the RPV above the shroud head and separators, and forms the top and sides of the wet steam plenum. Vertical guide rods on the inside of the RPV provide alignment for the dryer assembly during installation. The dryer assembly is supported by brackets extending from the RPV wall. The RPV top head prevents significant upward movement. Steam from the separators flows upward into the dryer assembly. The steam leaving the top of the dryer assembly flows into four RPV steam outlet nozzles which are located alongside the steam dryer assembly. Moisture is removed by the dryer vanes and flows first through a system of troughs and pipes to the pool surrounding the separators and then into the downcomer annulus between the shroud and RPV wall. A partial schematic of a typical steam dryer is shown on figure 4.1-4.

### **4.1.3 REACTIVITY CONTROL SYSTEMS**

#### **4.1.3.1 Operation**

The 137 control rods perform dual functions of power distribution shaping and reactivity control. Power distribution in the core is controlled during operation of the reactor by manipulation of selected patterns of rods. The rods, which enter from the bottom of the near-cylindrical reactor core, are positioned in such a manner to counterbalance steam voids in the top of the core and effect significant power flattening. These groups of control elements, used for power flattening, experience a somewhat higher duty cycle and neutron exposure than the other rods in the control system.

The reactivity control function requires that all rods be available for either reactor scram or reactivity regulation. Because of this, the control elements are mechanically designed to

withstand the dynamic forces resulting from a scram. They are connected to bottom-mounted, hydraulically actuated drive mechanisms which allow either axial positioning for reactivity regulation or rapid scram insertion. The design of the rod-to-drive connection permits each blade to be attached or detached from its CRD without disturbing the remainder of the control system. The bottom-mounted CRDs permit the entire control system to be left intact and operable for tests with the RPV open.

#### **4.1.3.2 Description of Control Rods**

The control rods are described in paragraph 4.2.3.1.

#### **4.1.3.3 Supplementary Reactivity Control**

Control requirements of the core are met by use of the combined effects of the movable control rods and a supplemental burnable poison. The supplementary burnable poison found in several fuel rods in each bundle is gadolinia ( $Gd_2O_3$ ) mixed with  $UO_2$ .

### **4.1.4 ANALYSIS TECHNIQUES**

#### **4.1.4.1 Reactor Internal Components**

The analysis techniques for HNP-1 are found in HNP-1-FSAR appendix C.

Computer codes used for the HNP-2 initial analysis of the internal components are as follows:

- MASS (Mechanical Analysis of Space Structure).
- SNAP (MULTISHELL).
- GASP.
- NOHEAT.
- FINITE.
- SAMIS (Structural Analysis and Matrix Interpretive System).
- SHELL 5 and SHELL 9.
- HEATER.
- FAP-7I (Fatigue Analysis Program).



For HNP-1 and HNP-2, the reactor internal components and retrofit repairs were evaluated for the increase in rated thermal power to 2804 MWt and reactor operating pressure increase from 1050 psia to 1060 psia.<sup>(1)(2)</sup> All structural criteria for all accident cases required by the safety analysis are met.

#### **4.1.4.2 Fuel Rod Thermal Analysis**

Reference section 4.3.1 of *NEDE-24011-P-A, "GESTAR II - General Electric Standard Application for Reactor Fuel" (incorporated by reference into the FSAR)*. Fuel rod thermal analysis and documentation of methods for the four Westinghouse SVEA-96 Optima2 lead use assemblies loaded into HNP-1 are contained in reference 3.

#### **4.1.4.3 Reactor Systems Dynamics and Nuclear Analysis**

Reference section 3.3 of *NEDE-24011-P-A (GESTAR II)*.

#### **4.1.4.4 Neutron Fluence Calculations**

##### **A. HNP-1**

Neutron vessel fluence calculations for HNP-1 are described in HNP-1-FSAR appendix R, section R.1.

##### **B. HNP-2**

Neutron vessel fluence calculations were carried out using a two-dimensional, discrete ordinates  $S_n$  transport code with general anisotropic scattering. This code is a widely used discrete ordinates code that will solve a wide variety of radiation transport problems. Slab, cylinder, and spherical geometries are allowed with various boundary conditions. The fluence calculations incorporate, as an initial starting point, a distributed fission neutron source distribution prepared from core physics data. Anisotropic scattering is considered for all regions. The cross-sections are represented by third-order Legendre polynomial expansions.

Fast neutron fluxes at locations other than the core midplane were calculated using a one-dimensional, discrete ordinates code which is similar to the two-dimensional code. One-dimensional calculations were performed for several elevations to determine the relative variation of fast flux with elevation.

The fast neutron flux calculations are used to establish the ratio of flux between the surveillance capsule locations and the location of peak vessel inside surface flux, known as the lead factor. Use of the lead factor is discussed in paragraph 4.3.2.8.

**4.1.4.5 Thermal-Hydraulic Calculations**


Thermal-hydraulic calculations are discussed in section 4.3.1 **of NEDE-24011-P-A (GESTAR II)**. Fuel rod thermal-hydraulic analysis and documentation of methods for the four Westinghouse SVEA-96 Optima2 lead use assemblies loaded into HNP-1 are contained in reference 3.

**DOCUMENTS INCORPORATED BY REFERENCE INTO THE FSAR**

***"GESTAR II - General Electric Standard Application for Reactor Fuel," NEDE-24011-P-A.***

REFERENCES

1. "Safety Analysis Report for Edwin I. Hatch Units 1 and 2 Thermal Power Optimization," NEDC-33085P, GE Nuclear Energy, December 2002.
2. "10-PSI Dome Pressure Increase Project Report for Edwin I. Hatch Units 1 and 2," GE-NE-0000-0003-0634-01, Revision 1, GE Nuclear Energy, July 2003.
3. Westinghouse Report NF-BSN-10-10, "Supplemental Licensing Report, SVEA-96 Optima2 Lead Use Fuel Assemblies for Edwin I. Hatch Nuclear Plant, Unit 1," Revision 0, February 2010.



ACAD 040101


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

REACTOR VESSEL CUTAWAY

FIGURE 4.1-1



ACAD 040102


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

CORE ARRANGEMENT AND  
LATTICE CONFIGURATION

FIGURE 4.1-2



ACAD 1040103


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

STEAM SEPARATOR

FIGURE 4.1-3



ACAD 040104

REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

STEAM DRYER

FIGURE 4.1-4

## 4.2 MECHANICAL DESIGN (HNP-1 AND HNP-2)

The design of the fuel system, the reactor core support structures and internals, and the reactivity control and standby liquid control systems is applicable to both HNP-1 and HNP-2, unless specified otherwise.

### 4.2.1 FUEL SYSTEM DESIGN

The description of fuel assemblies in the following sections pertains to fuel bundles supplied by Global Nuclear Fuel (GNF) and described in GESTAR-II. In addition, four SVEA-96 Optima2 lead use assemblies (LUAs) supplied by Westinghouse Electric Company have been installed in the HNP Unit 1 core. The mechanical design description and documentation of methods for these LUAs are contained in references 30, 31, and 32.

#### 4.2.1.1 General Design Description

The design bases for fuel bundles are contained in section 2.2 of ***NEDE-24011-P-A, "GESTAR II - General Electric Standard Application for Reactor Fuel" (incorporated by reference into the FSAR).***

#### 4.2.1.2 Design Bases

##### 4.2.1.2.1 General Design Bases

Reference section 2.2 of ***NEDE-24011-P-A (GESTAR II).***

##### 4.2.1.2.2 Basis for Fuel Safety Evaluation

Reference section 2.2 of ***NEDE-24011-P-A (GESTAR II).***

##### 4.2.1.2.3 Design Ratios

Reference section 2.2.1.1.2 of ***NEDE-24011-P-A (GESTAR II).***

##### 4.2.1.2.4 Maximum Allowable Stresses and Cycling and Fatigue Limits

Reference section 2.2.1.1.3 of ***NEDE-24011-P-A (GESTAR II).***



#### **4.2.1.3 Results of Thermal Mechanical Evaluations**

Reference chapters 2 and 4 of *NEDE-24011-P-A (GESTAR II)*.

#### **4.2.1.4 Operating and Developmental Experience**

Reference section 2.3.3 of *NEDE-24011-P-A (GESTAR II)*.

#### **4.2.1.5 Inspection, Testing, and Surveillance**

Reference section 2.3 of *NEDE-24011-P-A (GESTAR II)*.

### **4.2.2 REACTOR CORE SUPPORT STRUCTURES AND INTERNALS MECHANICAL DESIGN**

#### **4.2.2.1 Design Bases**

##### **4.2.2.1.1 General Design Bases**

**4.2.2.1.1.1 Safety Design Bases.** The reactor core support structures and internals meet the following safety design bases:

- A. Internals are arranged to provide a floodable volume in which the core can be adequately cooled in the event of a breach in the reactor coolant pressure boundary, external to the reactor pressure vessel (RPV). The floodable inner volume is inside the core shroud up to the level of the jet pump suction inlet. The boundary of the inner volume consists of the following:
  - The jet pumps from the jet pump's suction inlet down to the shroud support ring.
  - The shroud support ring, which forms a barrier between the outside of the shroud and the inside of the reactor vessel.
  - The reactor vessel wall below the shroud support ring.
  - The core shroud up to the level of the jet pump suction inlet.
- B. Deformation is limited to ensure the control rods and the emergency core cooling system can perform their safety functions.

- C. The mechanical design of applicable structures ensure safety design bases A and B are satisfied so the safe shutdown of the plant and removal of decay heat are not impaired.

**4.2.2.1.1.2 Power Generation Design Bases.** The reactor core support structures and internals are designed to the following power generation design bases:

- A. They provide the proper coolant distribution during all anticipated normal operating conditions to allow power operation of the core without fuel damage.
- B. They are arranged to facilitate refueling operations.
- C. They are designed to facilitate inspection.

**4.2.2.1.2 Specific Design Characteristics**

**4.2.2.1.2.1 Design Loading Combinations.** The design of the RPV internals specified in this subsection is in accordance with the intent of American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section III. The design condition categories (comparable to normal, upset, emergency, and faulted specified in the ASME Code) and the associated loading combinations may be noted by reference to HNP-1-FSAR section C.2 and table C.2-1, and HNP-2-FSAR paragraph 4.2.2.3.1.1.

**4.2.2.1.2.2 Stress, Deformation, and Fatigue Limits for RPV Internals (Except Core Support Structures).** For HNP-1 and HNP-2, the criteria used for deformation, primary stress, buckling, and fatigue limits are provided in HNP-2-FSAR tables 4.2-1, 4.2-2, 4.2-3, and 4.2-4, respectively. For HNP-1, a more detailed stress summary on a component basis is provided in HNP-1-FSAR table C.3-1. For HNP-2, criteria based upon applicable codes and standards, manufacturer's standards, or empirical methods based upon field experience and testing can also be used.

The following minimum safety factor values (quantity  $SF_{min}$ ) are used for both HNP-1 and HNP-2:

| <u>Design Condition</u> | <u><math>SF_{min}</math></u> |
|-------------------------|------------------------------|
| Normal                  | 2.25                         |
| Upset                   | 2.25                         |
| Emergency               | 1.5                          |
| Faulted                 | 1.125                        |

**4.2.2.1.2.3 Stress, Deformation, and Fatigue Limits for Core Support Structures.** For HNP-1, the stress, deformation, and fatigue limits for core support structures are provided in HNP-1-FSAR table C.3-1. For HNP-2, the stress deformation and fatigue criteria presented in tables 4.2-5, 4.2-6, and 4.2-7 are used. Where applicable, these criteria are supplemented by the criteria for the reactor internals in the previous paragraph, but in no case are the criteria for core support structures presented in these tables exceeded.

**4.2.2.1.2.4 Fuel Assembly Restraints.** The fuel assembly structural design demonstrates sufficient dimensional stability and sufficient fuel rod support to maintain core geometry, thus avoiding fuel damage for both planned operation and anticipated operational occurrences (AOOs).

**4.2.2.1.2.5 Material Selection.** The material used for fabricating most of the reactor core support and reactor internal structures is solution-heat-treated, Type 304 austenitic stainless steel conforming to American Society of Testing Materials (ASTM) specifications. Weld procedures and welders are qualified in accordance with the intent of Section IX of the ASME Boiler and Pressure Vessel Code. Further controls for stainless-steel welding are covered in HNP-1-FSAR subsection 4.2.4 and HNP-2-FSAR subsection 5.2.5.

All materials of construction exposed to the reactor coolant are resistant to stress corrosion in the BWR. Conservative corrosion allowances are to be provided for all exposed surfaces of carbon or low-alloy steels.

Contaminants in the reactor coolant are controlled to very low limits by the reactor water quality specifications. No detrimental effects occur on any of the materials from allowable contaminant levels in the high-purity reactor coolant. Radiolytic products in a BWR have no adverse effect on the construction materials.

**4.2.2.1.2.6 Radiation Effects.** Where feasible, the design is such that irradiation effects on the material properties are minimized. Where irradiation effects cannot be minimized, the design of the RPV internals either has provision for replaceable components, or the design is shown to satisfy a set of stress and fatigue design limits. The fatigue design limits have been determined considering the effect of irradiation damage on the fracture toughness, ductility, and tensile properties of the materials.

**4.2.2.1.2.7 Shock Loads.** The components are designed to accommodate the loadings discussed in HNP-1-FSAR appendix C and HNP-2-FSAR section 3.9.

**4.2.2.1.2.8 Vibration of Reactor Internal Components.**

A. HNP-1

The vibration of reactor internal components is discussed in HNP-1-FSAR appendix C.

B. HNP-2

The core plate bypass leakage holes, that were the source of excessive tube vibration and channel wear, were not drilled in the HNP-2 core plate. Bypass leakage flow is provided by small holes in the fuel assembly lower tie plates, which have been shown by test to produce greatly reduced levels of tube vibration.

The adequacy of these design characteristics, with respect to reduction of vibration and wear of instrument tubes and fuel channels, has been demonstrated by vibration monitoring in a plant similar to HNP-2, prior to HNP-2 initial startup testing.

The HNP-2 design characteristics do not have a significant effect on the vibratory excitation and response of core support or other reactor internals structures. Flow parameters, which could affect the response of these structures, such as the core plate pressure differential and the core coolant flowrate, are not significantly altered by the design modification. Dynamic response characteristics of the structures themselves were not altered by the modification.

**4.2.2.2 Description**

The core support structures and RPV internals (exclusive of fuel, control rods, and incore nuclear instrumentation) include the following components:

A. Core Support Structures

- Shroud.
- Shroud support.
- Core support and hold-down bolts.
- Top guide (including wedges, bolts, and keepers).
- Fuel support pieces.
- Control rod guide tubes.

## HNP-2-FSAR-4

### B. Reactor Internals

- Jet pump assemblies and instrumentation.
- Shroud head and steam separator assembly (including shroud head bolts).
- Steam dryers.
- Feedwater spargers.
- RPV head cooling-spray nozzle (capped).
- Differential pressure and liquid control line.
- Incore flux monitor guide tubes and stabilizers.
- Neutron sources.
- Surveillance sample holders.
- Core spray (CS) lines.

For HNP-1 and HNP-2, a list of the materials and their specifications for major components of the reactor internals and core support structures is given in table 4.2-8.

The overall arrangement of the structures within the RPV is shown in figure 4.1-1. A general assembly drawing of the important reactor components is shown in HNP-1 drawing nos. SX-16121, SX-16122, and SX-16123, and HNP-2 drawing nos. S-28220, S-28221, S-28222, S-28223, S-28224, and S-28225.

The floodable inner volume of the RPV, which is the volume inside the core shroud up to the level of the jet pump suction inlet, is provided in figure 4.2-1.

The core support structure is used to:

- Form partitions within the RPV.
- Sustain pressure differentials across the partitions.
- Locate laterally and support the fuel assemblies, control rod guide tubes, and steam separators.
- Direct the flow of the coolant water.

Figure 4.2-1 shows the RPV internal flow paths.

#### **4.2.2.2.1 Shroud**

The shroud is a stainless-steel cylindrical assembly that provides a partition to separate the upward flow of coolant through the core from the downward recirculation flow. This partition separates the core region from the downcomer annulus, thus providing a floodable region following a recirculation line break.

The volume enclosed by the shroud is characterized by three regions. The upper shroud surrounds the core discharge plenum, which is bounded by the shroud head on top and the top guide below. The central portion of the shroud surrounds the active fuel and forms the longest section of the shroud. This section is bounded at the bottom by the core support. The lower shroud, surrounding part of the lower plenum, is welded to the RPV shroud support (HNP-1-FSAR section 4.2 and HNP-2-FSAR section 5.4).

A set of four radial acting stabilizer assemblies is used to maintain the alignment of the core shroud to the RPV during seismic loading and a design basis accident (DBA). The set of stabilizers replaces the structural functions of the shroud horizontal girth welds. Each stabilizer attaches to the shroud flange at the top of the shroud, and for HNP-1, to a shroud support gusset at the bottom and for HNP-2, to a collet connector installed in the shroud support.

#### **4.2.2.2.2 Shroud Head and Steam Separator Assembly**

The shroud head and steam separator assembly is bolted to the top of the upper shroud to form the top of the core discharge plenum, which provides a mixing chamber for the steam-water mixture before it enters the steam separators. Individual stainless-steel axial flow steam separators, shown in figure 4.1-3, are attached to the top of standpipes that are welded into the shroud head. The steam separators have no moving parts. In each separator, the steam-water mixture rising through the standpipe passes vanes that impart a spin to establish a vortex separating the water from the steam. The separated water flows from the lower portion of the steam separator into the downcomer annulus.

#### **4.2.2.2.3 Core Support**

The core support consists of a circular stainless-steel plate with bored holes stiffened with a rim and beam structure. The plate provides lateral support and guidance for the control rod guide tubes, incore flux monitor guide tubes, peripheral fuel supports, and startup neutron sources. The last two items are also supported vertically by the core support plate.

The entire assembly is bolted to a support ledge between the central and lower portions of the core shroud. Alignment pins that engage slots and bear against the shroud are used to position the assembly correctly before it is secured. Plant modifications to eliminate significant incore vibrations in HNP-1 are described in references 20, 21, and 22.

#### **4.2.2.2.4 Top Guide**

The top guide is formed by a series of stainless-steel beams joined at right angles to form square openings, with the beams fastened to a peripheral rim. Each large opening provides lateral support and guidance for four fuel assemblies or, in the case of peripheral fuel, one or two fuel assemblies. Hanger slots are provided at the top of the beams to receive the top hooks of the temporary control curtains. Notches are provided in the bottom of the beam intersections to anchor the incore flux monitors and startup neutron sources. The top fuel guide is positioned with alignment pins which bare against the shroud.

#### **4.2.2.2.5 Fuel Supports**

The two basic types of fuel supports shown in figures 4.2-2 (HNP-1) and 4.2-3 (HNP-2) are:

1. Peripheral Supports

The peripheral fuel support is located at the outer edge of the active core and is not adjacent to control rods. Each peripheral fuel support supports one fuel assembly and contains a single orifice assembly designed to ensure proper coolant flow to the fuel peripheral assembly.

2. Four-Lobed Orificed Fuel Supports

Each four-lobed orificed fuel support supports four fuel assemblies and is provided with orifice plates to ensure proper coolant flow distribution to each rod-controlled fuel assembly. The four-lobed orificed fuel supports rest in the top of the control rod guide tubes, which are supported laterally by the core support. The control rods pass through slots in the center of the four-lobed orificed fuel support. A control rod and the four adjacent fuel assemblies represent a core cell (subsection 4.2.1).

#### **4.2.2.2.6 Control Rod Guide Tubes**

The control rod guide tubes, located inside the RPV, extend from the top of the control rod drive (CRD) housing up through holes in the core support plate. Each tube is designed as the guide for a control rod and as the vertical support for a four-lobed orificed fuel support piece and the four fuel assemblies surrounding the control rod. The bottom of the guide tube is supported by the CRD housing (HNP-1-FSAR section 4.2 and HNP-2-FSAR section 5.4), which in turn transmits the weight of the guide tube, fuel support, and fuel assemblies to the RPV bottom head. A thermal sleeve is inserted into the CRD housing from below and is rotated to lock the control rod guide tube in place. A key is inserted into a locking slot in the bottom of the CRD housing to hold the thermal sleeve in position.

#### 4.2.2.2.7 Jet Pump Assemblies

The jet pump assemblies are located in two semicircular groups in the downcomer annulus between the core shroud and the RPV wall. The design and performance of the jet pump is covered in detail in references 1 and 2. Each stainless-steel jet pump consists of driving nozzles, suction inlet, throat, or mixing section, and diffuser (figure 4.2-4). The driving nozzle, suction inlet, and throat are joined together as a removable unit, and the diffuser is permanently installed. High-pressure water from the recirculation pumps (HNP-1-FSAR subsection 4.3.4 and HNP-2-FSAR subsection 5.5.1) is supplied to each pair of jet pumps through a riser pipe welded to the recirculation inlet nozzle thermal sleeve. A riser brace consists of cantilever beams extending from pads on the RPV wall. The nozzle entry section is connected to the riser by a metal-to-metal, spherical-to-conical seal joint. Firm contact is maintained by a holddown clamp. The throat section is supported laterally by a bracket attached to the riser. A slip-fit joint is located between the throat and diffuser. The diffuser is a gradual conical section changing to a straight cylindrical section at the lower end.

#### 4.2.2.2.8 Steam Dryers

Steam dryers remove moisture from the wet steam leaving the steam separators. The extracted moisture flows down the dryer vanes to the collecting troughs and flows through tubes into the downcomer annulus (figure 4.1-4). A skirt extends from the bottom of the dryer vane housing to the steam separator standpipe, below the water level. This skirt forms a seal between the wet steam plenum and the dry steam flowing from the top of the dryers to the steam outlet nozzles.

Vertical guide rods facilitate positioning the dryer and shroud head in the vessel. The dryers rest on steam dryer support brackets attached to the reactor vessel wall. The dryers are restricted from lifting by steam dryer holddown brackets attached to the RPV top head over the top of the steam dryer lifting lugs when the head is in place.

#### 4.2.2.2.9 Feedwater Spargers

The feedwater spargers are perforated stainless-steel headers located in the mixing plenum above the downcomer annulus (figure 4.1-1).

During an accident condition, feedwater piping spargers deliver water from the HPCI and RCIC systems to maintain RPV inventory.

##### A. HNP-1

HNP-1 feedwater spargers 284x402G001 have top-mounted elbows, each with a converging discharge nozzle to assure the sparger/thermal sleeve remains full of cold feedwater during low-flow conditions. This design assures that, during low-flow conditions, low-flow stratification is eliminated. The converging discharge orifices eliminate flow separation, which could cause flow hole cracking.



## HNP-2-FSAR-4

A separate sparger is fitted to each feedwater nozzle thermal sleeve via a forged tee connected to the sparger arms and is shaped to conform to the curvature of the RPV wall. The thermal sleeve configuration is drastically different from previous designs. The inner thermal sleeve is the feed pipe for the sparger and is sealed against the safe-end with a piston ring. The inner thermal sleeve is welded to the forged tee. A secondary seal is attached to an intermediate thermal sleeve that is open to the reactor at its downstream end. The annulus between the intermediate and inner thermal sleeves has a low hydraulic resistance and serves to channel leakage to the reactor without impinging on the feedwater nozzle. As a further impediment to leakage and to provide damping against vibration an interference fit is provided between the ring, which contains the secondary seal, and the nozzle safe-end. Sparger end brackets are attached to vessel brackets to support the weight of the spargers. Each feedwater sparger assembly has 28 flow nozzles. The header is fabricated from Type 304 austenitic stainless-steel 6.0-in. schedule 80 pipe.

### B. HNP-2

The design of HNP-2 feedwater sparger 283x688G6 is based on the full-scale flow tests conducted on a Millstone feedwater sparger in the feedwater sparger test facility and is adequately designed to withstand the vibratory loads induced by flow transients (paragraph 4.2.2.3). It is also based on the successful operation of the Millstone "Design IV" feedwater sparger. The feedwater sparger is a top-mounted flow-nozzle design with a welded-in thermal sleeve to the feedwater nozzle safe end. Test data in the full-scale test facility show no differences between the welded-in and the interference fit designs of feedwater spargers in their ability to minimize or eliminate flow-induced vibration.

Feedwater flow enters the center of the spargers and is discharged radially inward to mix the cooler feedwater with the downcomer flow from the steam separators before it contacts the RPV wall. The feedwater also condenses the steam in the region above the downcomer annulus and subcools the water flowing to the jet pumps and recirculation pumps.

Each feedwater sparger assembly has 30 flow nozzles. The header is fabricated from Type 304 austenitic stainless-steel 6.0-in. schedule 80 pipe.

#### **4.2.2.2.10 Core Spray Lines**

The CS lines are the means for directing flow to the CS nozzles, which distribute coolant so that peak fuel cladding temperatures of 2200°F are not exceeded during accident conditions.

Two CS lines enter the RPV through the two CS nozzles (figure 4.1-1, and HNP-1-FSAR subsection 6.4.3 and HNP-2-FSAR section 6.3). The lines divide immediately inside the RPV. The two halves are routed to opposite sides of the RPV and are supported by clamps attached to the RPV wall. The lines are then routed downward into the downcomer annulus and pass through the upper shroud immediately below the flange. The flow divides again as it enters the

## HNP-2-FSAR-4

center of the semicircular sparger, which is routed halfway around the inside of the upper shroud. The ends of the two spargers are supported by brackets designed to accommodate thermal expansion. The line routing and supports are designed to accommodate differential movement between the shroud and RPV. The other CS line is identical, except that it enters the opposite side of the RPV. The spargers are at a slightly different elevation inside the shroud. The correct spray distribution pattern is provided by a combination of distribution nozzles pointed radially inward and downward from the spargers.

### **4.2.2.2.11 Differential Pressure and Liquid Control Line**

The differential pressure and liquid control line (figure 4.1-1) serves a dual function within the RPV:

- Provide a path for the injection of the liquid control solution into the coolant stream (HNP-1-FSAR subsection 3.8.4 and HNP-2-FSAR paragraph 4.2.3.4).
- Sense the differential pressure across the core support plate (HNP-1-FSAR section 4.2 and HNP-2-FSAR section 5.4).

The differential pressure and liquid control line enters the RPV at a point below the core shroud as two concentric pipes. In the lower plenum, the two pipes separate. The inner pipe terminates near the lower shroud with a perforated length below the core support plate. The inner pipe is used to sense the pressure below the core support plate during normal operation and to inject liquid control solution if required. This location facilitates good mixing and dispersion. The inner pipe also reduces thermal shock to the RPV nozzle should the standby liquid control system (SLCS) be actuated. The outer pipe terminates immediately above the core support plate and senses the pressure in the region outside the fuel assemblies.

### **4.2.2.2.12 Incore Flux Monitor Guide Tubes**

The incore flux monitor guide tubes provide a means of positioning fixed detectors in the core and a path for calibration monitors [traversing incore probe (TIP) system] and extend from the top of the incore flux monitor housing (HNP-1-FSAR section 4.2 and HNP-2-FSAR section 5.4) in the lower plenum to the top of the core support plate. The power range detectors for the power range monitoring units and the dry tubes for the source range (SRM) and intermediate range monitor (IRM) detectors are inserted through the guide tubes and are held in place below the top guide by spring tension. A latticework of clamps, tie bars, and spacers gives lateral support and rigidity to the guide tubes. The bolts and clamps are welded in place, after assembly, to prevent loosening during reactor operation.

### **4.2.2.2.13 Surveillance Sample Holders**

The surveillance sample holders are welded baskets containing impact and tensile specimen capsules (HNP-1-FSAR appendix R and HNP-2-FSAR paragraph 5.2.4.4). The baskets hang from brackets that are attached to the inside wall of the RPV and extend to mid-height of the active core. The radial positions are chosen to expose the specimens to the same environment

and maximum neutron fluxes experienced by the RPV itself while avoiding jet pump removal interference or damage.

#### **4.2.2.3 Safety Evaluation**

##### **4.2.2.3.1 Evaluation Methods**

To determine that the safety design bases are satisfied, responses of the RPV internals to loads imposed during normal, upset, emergency, and faulted conditions are examined. The effects on the ability to insert control rods, cool the core, and flood the inner volume of the RPV are determined.

**4.2.2.3.1.1 Input for Safety Evaluation.** The operating conditions that provide the basis for the design of the reactor internals to sustain normal, upset, emergency, and faulted conditions, as well as combinations of design loadings accounted for in design of the core support structure, are covered in HNP-1-FSAR table C.3-1 and HNP-2-FSAR table 4.2-9.

In addition, each combination of operating loads is categorized with respect either to normal, upset, emergency, or faulted conditions, as well as the associated design stress intensity or deformation limits.

The bases for the proposed design stress and deformation criteria are specified in HNP-1-FSAR appendix C and HNP-2-FSAR chapter 3.

**4.2.2.3.1.2 Events To Be Evaluated.** Examination of the spectrum of conditions for which the safety design basis must be satisfied reveals three significant upset events:

- A. Recirculation Line Break [Loss of Coolant Accident (LOCA)]: the accident results in pressure differentials within the RPV.
- B. Main Steam Line Break Accident (MSLBA): a break in one main steam line between the RPV and the flow restrictor. The accident results in significant pressure differentials across some of the structures within the reactor.
- C. Earthquake: it subjects the core support structures and reactor internals to significant forces as a result of ground motion.

For other conditions existing during normal operation, AOOs, and accidents, the loads affecting the core support structures and reactor internals are less severe than these three postulated events.

**4.2.2.3.1.3 Pressure Differential During Rapid Depressurization.** A digital computer code is used to analyze the transient conditions within the RPV following the recirculation line

break accident (LOCA) and the MSLBA.<sup>(3)</sup> The analytical model of the RPV consists of nine nodes that are connected to the necessary adjoining nodes by flow paths having the required resistance and inertial characteristics. The program solves the energy and mass conservation equations for each node to give the depressurization rates and pressure in the various regions of the reactor. Figure 4.2-5 shows the nine reactor nodes.

#### 4.2.2.3.2 Recirculation Line Break Accident and MSLBA

**4.2.2.3.2.1 Accident Definition.** Both a recirculation line break accident (the largest liquid break) and an inside MSLBA (the largest steam break) are considered in determining the design basis accident (DBA) for the reactor internals. The recirculation line break is the same as the design basis LOCA, as described in HNP-2-FSAR subsection 6.3.3 for both HNP-1 and HNP-2. A sudden, complete circumferential break is assumed to occur in one recirculation loop. The analysis of the MSLBA assumes a sudden, complete circumferential break of one main steam line between the RPV vessel and the main steam line restrictor. This is not the same accident described in subsection 15.3.5, which has greater potential radiological effects. A steam line break upstream of the flow restrictors produces a larger blowdown area and, thus, a faster depressurization rate than a break downstream of the restrictors. The larger blowdown area results in greater pressure differentials across the reactor assembly internal structures.

The MSLBA produces higher pressure differentials across the reactor internal structures than does the recirculation line break. This results from the higher reactor depressurization rate associated with the MSLB. The depressurization rate is proportional to the mass flowrate and the excess of fluid escape enthalpy above saturated water enthalpy,  $h_f$ . Mass flowrate is inversely proportional to escape enthalpy,  $h_e$ ; therefore, the depressurization rate is approximately proportional to  $1-h_f/h_e$ . Consequently, depressurization rate decreases as  $h_e$  decreases; that is, the depressurization rate is less for mixture flow than for steam flow. Therefore, the MSLBA is the DBA for internal pressure differentials.

**4.2.2.3.2.2 Effects of Reactor Power and Core Flow.** For illustration, the maximum internal pressure loads can be considered to be composed of two parts: steady-state and transient pressure differentials. For a given plant, core flow and power are the two major factors that influence the reactor internal pressure differentials. The core flow essentially affects only the steady-state part. For a fixed power, the greater the core flow, the larger the steady-state pressure differential. The core power affects both the steady-state and the transient parts. As the power is decreased, there is less voiding in the core, and consequently, the steady-state core pressure differential is less. However, less voiding in the core also means that less steam is generated in the RPV and, thus, the depressurization rate and the transient part of the maximum pressure load are increased.

It is necessary to determine the combination of core power and flow, which results in the maximum internal differential pressure loads. This condition could occur at high power and flow (the upper right corner of the power-to-flow map), or low power and high flow (the lower right corner of the power-to-flow map). The power-to-flow map is provided in figure 15.1-3.

The initial safety analysis was performed at 2537 MWt and 100% core flow for the high power and high flow condition. These faulted pressure differentials were compared to a low power, high core flow case in which the core flow reached ~ 110% of rated. This analysis showed that the low power, high core flow case is more limiting with regard to maximum pressure differentials following a steam line break inside containment. As explained above, this is because the decrease in core flow and power reduces the steady-state part of the maximum pressure load more than the corresponding increase in the transient part. Hence, the maximum pressure loads (steady state plus transient) are less if core flow is reduced from its maximum value.

The safety analysis was performed again for the increase in licensed power level to 2804 MWt and reactor operating pressure increase from 1050 psia to 1060 psia.<sup>(24) (25)</sup> The limiting condition for the MSLBA (faulted) condition, as well as normal operation and AOO (upset) conditions, is reported for HNP-1 and HNP-2 in tables 4.2-10 and 4.2-11, respectively.

Reference 15 contains additional information on reactor internal pressure differences.

**4.2.2.3.2.3 Response of Structures Within the Reactor Pressure Vessel to Pressure Differences.** Maximum differential pressures are used in combination with other structural loads to determine the total loading on the various structures within the reactor. The structures are then evaluated to assess the extent of deformation and buckling instability, if any. Of particular interest are the responses of the guide tubes and the metal channels around the fuel bundles and the potential leakage around the jet pump joints.

A. Guide Tube

The guide tube is evaluated for buckling instability caused by externally applied pressure. The two primary modes of failure analyzed are described in paragraph 4.2.3.1.3. For a guide tube with minimum wall thickness and maximum allowed ovality, the pressure that causes yield stress is 105 psi compared to the design pressure of 37.5 psi. The design pressure is greater than the 30-psi maximum pressure differential the guide tube experiences, including accident conditions. The stress the guide tube could experience is ~ 5400 psi due to external pressure (37.5 psi), a 1.2-g earthquake (include deadweight loading), and lateral loading due to coolant flow, while yield stress at 575°F is 17,500 psi. It is concluded that the guide tube does not fail under the assumed conditions.

B. Fuel Channel

The fuel channel load resulting from an internally applied pressure is evaluated, using a fixed-beam analytical model under a uniform load. Tests to verify the applicability of the analytical model indicate that the model is conservative. A roller at the top of the control rod guides the blade as it is inserted. If the gap between channels is less than the diameter of the roller, the roller deflects the channel walls as it makes its way into the core. The friction force is a small percentage of the total force available to the CRDs for overcoming such friction, and it is concluded that the MSLBA does not impede the insertability of the control rod.

C. Jet Pump Joints

Jet pump joints were analyzed to evaluate the potential leakage from within the floodable inner volume of the RPV during the recirculation line break and subsequent low-pressure coolant injection (LPCI) reflooding. Because the jet pump diffuser is welded to the shroud support, the only remaining source of leakage from the lower plenum to the downcomer annulus is the jet pump throat-to-diffuser joint at 225 gal/min.

LPCI capacity is sized to accommodate on HNP-1 3000 gal/min and on HNP-2 500-gal/min leakage at these locations. It is concluded that the RPV structures retain sufficient integrity during the recirculation line break accident to allow reflooding of the inner volume of the RPV and in sufficient time to prevent significant increases in cladding temperature.

**4.2.2.3.3 Earthquake**

Seismic loads acting on the structures within the RPV are based upon a dynamic analysis of a model as described in HNP-1-FSAR appendix C and HNP-2-FSAR section 3.7.

**4.2.2.3.4 Conclusions**

Response analyses of the reactor structures show that deformations are sufficiently limited to allow both adequate control rod insertion and proper operation of the ECCS. Sufficient integrity of the structures is retained during accident conditions to allow successful reflooding of the RPV inner volume. The analyses considered various loading combinations, including loads imposed by external forces. Thus, the safety design bases listed in paragraph 4.2.2.1.1.1 are satisfied.

**4.2.2.4 Design Bases Criteria**

The reactor core support structures and internals meet the safety design bases and power generation design bases specified in paragraph 4.2.2.1.1. This is accomplished without exceeding the design basis conditions for normal, upset, emergency, and faulted conditions described in HNP-1-FSAR appendix C and HNP-2-FSAR table 4.2-9. The internals and core support structures design stress and deformation criteria are specified in HNP-1-FSAR appendix C and HNP-2-FSAR chapter 3.

**4.2.3 REACTIVITY CONTROL SYSTEM**

The reactivity control system consists of the control rods, the CRDs, supplementary reactivity control, and the SLCS.

#### 4.2.3.1 **Control Rods**

##### 4.2.3.1.1 **Design Bases**

4.2.3.1.1.1 **General Design Bases.** The general design bases for the control rods are as follows:

###### A. Safety Design Bases

1. Control rods have sufficient mechanical strength to prevent displacement of their reactivity control material.
2. Control rods have sufficient strength and are designed to prevent deformation that could inhibit their motion.
3. Each control rod has a device to limit its free-fall velocity sufficiently to avoid damage to the nuclear system process barrier by the rapid reactivity increase resulting from a free fall of one control rod from its fully inserted position to the position where the drive was withdrawn.

###### B. Power Generation Design Bases

The reactivity control mechanical design includes reactivity control devices (control rods and gadolinia burnable poison) that contain and position the material controlling the excess reactivity in the core. Control rods have the capability of being either removed or replaced as required.

4.2.3.1.1.2 **Specific Design Characteristics.** The specific design characteristics of the control rods are as follows:

###### A. Control Rod Clearances

The basis of the mechanical design of the control rod blade clearances is that there is no interference, which restricts passage of the control rod blade.

###### B. Mechanical Insertion Requirements

Mechanical insertion requirements during normal operation are selected to provide adequate operability and the capability to control the reactivity addition resulting from burnout of peak shutdown xenon at 100% power.

Scram insertion requirements are chosen to provide sufficient shutdown margin to meet all safety criteria for AOOs described in section 15.2.

### C. Material Selection

The selection of materials for use in the control rod design is based upon their in-reactor properties. Type 304 high purity stabilized stainless steel is used for absorber tubing for both the GE Duralife models (figures 4.2-6 and 4.2-7) and the GE Marathon model (Figure 4.2-17) control blade designs, comprising a major portion of the control rod assembly for both design types. Type 316L stainless steel is used for the Westinghouse CR 99 control rods.

The absorber tubing in the Duralife control rod designs is thinner than in the Marathon design, since the absorber tubes for the Duralife model are not intended to provide the main structure of the control rod assembly. Type 304 commercial grade stainless steel is typically used for the Duralife sheath and frame structure, with Type 316 stainless steel as an alternate material used later for the tie rod material. The absorber tubing for the GE Marathon design is welded together to form the absorber section and provide the main structure for the control rod assembly. Therefore, the Marathon absorber tubing is thicker with added surface features to allow the tubes to be welded together.

Boron carbide ( $B_4C$ ) powder and Inconel-X are used in the Duralife and Marathon control rod designs. The  $B_4C$  for the Marathon design is first loaded into thin vented capsules of Type 304 commercial grade stainless steel, before being loaded and sealed into the absorber rods. Solid boron carbide ( $B_4C$ ) pins are used in the Westinghouse CR 99 control rod designs.

The primary materials used in the Duralife, Marathon, and Westinghouse designs are well known and are taken into account in establishing the mechanical design of the control rod components. The basic cruciform control rod design and materials have been operating in all GE reactors since the 1980s and before.

Hafnium absorber parts are used in the GE Duralife and Marathon control rod designs. The performance of Hafnium as a reactivity control in a BWR environment is documented in NEDE-22290A.<sup>(8)</sup> The hafnium absorber material used for some of the absorber rods in the Marathon blade design are contained and sealed within the absorber rod tubes and are not exposed to reactor coolant, as described in NEDE-31758-P-A.<sup>(24)</sup>

GE Duralife and Marathon model control rod designs have used 13-8-MO PH stainless steel for the roller pin material since the early 1980s. The roller material is Inconel-X, also used since the early 1980s.

### D. Radiation Effects

The radiation effects on  $B_4C$  powder and solid  $B_4C$  pins include the release of gaseous products, and the  $B_4C$  cladding is designed to sustain the resulting internal pressure buildup. The corrosion rate and the physical properties (density, modulus of elasticity, dimensional aspects) of Type 304 commercial grade and high-purity stabilized stainless steels, Type 316 stainless steel, and Inconel-X are



essentially unaffected by the irradiation experienced in the BWR reactor core. The effects upon the mechanical properties, such as yield strength, ultimate tensile strength, percentage of elongation, and ductility on the Type 304 and Type 316 stainless-steel cladding also are well known and are considered in mechanical design.

#### E. Positioning Requirements

Rod-positioning increments (notch lengths) are selected to provide adequate power-shaping capability. The combination of rod speed and notch length must also meet the limiting reactivity addition rate criteria.

#### 4.2.3.1.2 Description

Plant Hatch uses control rods designed by GE (Duralife and Marathon) and Westinghouse (CR 99).

**4.2.3.1.2.1 GE Control Rods.** The control rods (figures 4.2-6 and 4.2-7 for the GE Duralife model and figure 4.2-17 for the GE Marathon) perform the dual function of power shaping and reactivity control. Power distribution in the core is controlled during operation of the reactor by manipulating selected patterns of control rods. Control rod displacement tends to counterbalance steam void effects at the top of the core and results in significant power flattening.

The control rods are 9.75 in. in total span and are separated uniformly throughout the core on a 12-in. pitch. Each control rod is surrounded by four fuel assemblies.

For the GE Duralife model design, the control rod consists of a sheathed cruciform array of stainless-steel tubes filled with B<sub>4</sub>C powder. For neutron absorption, the GE Duralife design (D-190 and D-230 models used at Hatch) uses B<sub>4</sub>C -filled tubes and solid-Hafnium strips, along with solid-Hafnium plates in the upper 6 in. of the B<sub>4</sub>C -filled tubes.<sup>(11)(12)</sup> The main structural member of the GE Duralife control rod is made of Type 304 and/or Type 316 stainless steel and consists of a top handle, bottom casting or assembly with a velocity limiter and CRD coupling, vertical cruciform center post, and four U-shaped absorber tube sheaths. The top handle, bottom velocity limiter assembly, and center post are welded into a single skeletal structure. The U-shaped sheaths are resistance welded to the center post, handle, and castings to form a rigid housing to contain the absorbing rodlets.

For the GE Marathon model design, the absorber rods are welded together to form the absorber section without the sheathing strip used in the Duralife design. The wings are welded to spacers which make up the tie rod structure to form the cruciform-shaped member of the control rod. Depending on the desired-nuclear design application the absorber rods are loaded with B<sub>4</sub>C-filled capsules, empty capsules (for extra plenum), solid hafnium rods (typically along the outside length of the absorber sections) or left empty (typically next to the tie rod structure). The absorber rods are sealed, then the top handle and bottom velocity limiter assembly with CRD coupler, of similar design to that used on the Duralife model control rod, are attached.<sup>(24)</sup>

## HNP-2-FSAR-4

Operating experience has shown that control rods, constructed as described above, are not susceptible to dimensional distortions. The  $B_4C$  powder in the absorber tubes is compacted to ~ 70% of its theoretical density. The  $B_4C$  contains a minimum of 76.5% by weight natural boron. The boron-10 (B-10) minimum content of the boron is 18% by weight.

Absorber tubes for Duralife and Marathon control rods are made of Type 304 high-purity stabilized stainless steel. Each absorber tube in the Duralife D-190 control rod is 0.188 in. in outside diameter (OD) (0.138-in. inside diameter (ID)). In the GE D-230 control rod, the absorber tube is 0.220 in. in OD (0.180-in. ID). The Hafnium strip thickness is 0.188 in. for both the D-190 and D-230 designs. The Hafnium plates in the D-190 control rods are 0.188 in. thick. The plates in the GE D-230 control rods are 0.220 in. thick.<sup>(8)</sup>

The OD of the absorber tube in the GE Marathon design is 0.298 in. and the OD of the absorber rod capsule in the GE Marathon design is 0.241 in. (~ 0.236-in. ID). The Hafnium rods are ~ 0.215 in. in diameter.<sup>(24) (25)</sup>

For the GE Duralife control rod design, the absorber tubes are sealed by a plug welded into each end. The boron carbide is longitudinally separated into individual compartments by stainless-steel balls at ~ 16-in. intervals. The steel balls are held in place by a slight crimp of the tube. Should boron carbide tend to compact further during service, the steel balls distribute the resulting voids over the length of the absorber tube.

For the GE Marathon control rod design, the absorber rod capsules of ~ 11 to 36 in. in length control the compaction of the  $B_4C$ .<sup>(24) (25)</sup>

The Duralife D-190 and D-230, as well as Marathon control rod designs, are designed such that their control strength (i.e., negative reactivity) nearly matches that of the original all- $B_4C$  control rod design. The reduction in control strength for these hybrid  $B_4C$  and Hafnium control rod designs is described in terms of B-10 depletion.

The operating lifetime of the control blades is governed by either nuclear reactivity or mechanical stress considerations, whichever proves most limiting.

- A. The nuclear lifetime limit is reached when the peak boron depletion results in a 10% loss in relative control worth of any 3-ft axial section of the blade.
- B. The mechanical lifetime limit is reached when the internal helium pressure from the B-10 (neutron, alpha) reaction results in stresses in any absorber tube of the control rod reaching the most restrictive design limit.

The actual replacement of control rods by these criteria depends on the service history of individual control blades.

If the control rod blades are subjected to sufficient exposure to cause ~ 50% local depletion of the poison tube B-10, the potential for tube cracking and boron-leaching exists.<sup>(4, 5, 6, 7)</sup>

The cracking is due to stress corrosion induced by solidification of  $B_4C$  particles and swelling of the compacted  $B_4C$  as helium and lithium concentrations grow. Once primary coolant

penetrates the cladding, i.e., the cracking has progressed through the cladding wall and the helium-lithium pressures are sufficient to open the crack, boron is leached out of the tube at locations with more than 50% B-10 local depletion. (Local depletion is considered to be twice the average depletion.) The cracking and boron loss shorten the design life of the control blade.

The end-of-design life is reached when the reactivity worth of the blade is reduced by 10%, which corresponds to 62% and 58% B-10 depletion averaged over the top quarter in the D-190 and D-230 control blades, respectively, and 56% depletion in the bottom three-quarter segments of the control blade. The end-of-design life for the GE Marathon design (corresponding to the 10% reduction in the reactivity worth of the blade) is 68% B-10 depletion averaged over any of the four axial quarter segments. The average mechanical lifetime of the control rods is calculated to be ~18 years of full-power operation. The actual replacement of control rods depends on the loss of reactivity control capability and gas pressure buildup and varies among control rods. The average expected service life of control rods is ~15 years.

The control rod velocity limiter (figures 4.2-8 and 4.2-9) is an integral part of the bottom assembly of each control rod. This engineered safety feature (ESF) system protects against a high-reactivity insertion rate by limiting the control rod velocity in the event of a control rod drop accident (CRDA). It is a one-way device in that the control rod scram velocity is not significantly affected, but the control rod dropout velocity is reduced to a permissible limit.

The velocity limiter utilizes an optimized twin-reverse jet design.

The hydraulic drag forces on a control rod are proportional to approximately the square of the rod velocity and are negligible at normal rod withdrawal or rod insertion speeds. However, during the scram stroke the rod reaches high velocity, and the drag forces must be overcome by the drive mechanism.

To limit control rod velocity during dropout but not during scram, the velocity limiter is provided with a streamlined profile in the scram (upward) direction. Thus, when the control rod is scrammed, water flows over the smooth surface of the upper side of the limiter into the annulus between the guide tube and the limiter. In the dropout direction, however, water is trapped by the lower curvature of the limiter and discharged through the annulus between the two sections. Because this water is jetted in a partially reversed direction into water flowing upward in the annulus, a severe turbulence is created, thereby slowing the descent of the control rod assembly to < 3.11 ft/s at 70°F.

**4.2.3.1.2.2 Westinghouse BWR CR 99 Control Rod Design.** The basic design of the Westinghouse BWR control rods (figure 4.2-18) consists of four stainless steel plates welded together to form a cruciform shaped rod. Each sheet has horizontally drilled holes to contain the absorber material. A velocity limiter is welded to the bottom of the control rod, also including a coupling device that connects the control rod to the control rod drive.

The CR 99 control rod design for the Hatch units is outlined as follows:

## HNP-2-FSAR-4

### Absorber

The absorber consists of four stainless steel (AISI 316L SS) blade wings discontinuously welded together in the center to a cruciform shape, providing the necessary mechanical stability. There are 15 welded shoulders in the center of the absorber cross. To minimize activation and dose, the cobalt content in the stainless steel blade wings is below 0.02 w/o.

The blade wings are 8.05 mm (0.317-in.) thick. In each blade, 454 holes are horizontally drilled to contain the absorber material, hot isostatic pressed (HIP) boron carbide pins. Each absorber hole contains two boron carbide pins separated by a spring, which presses the pins toward the bar at the edge of the blade and toward the bottom gable of the hole, respectively (see figure 4.2-19).

The boron carbide pins are tapered to provide more space for diametrical swelling in the high peaking factor area close to the outer edge of the blade wing.

In addition to the tapering, the upper 10 and the lower 113 holes are filled with boron carbide pins with reduced dimensions to provide more space for diametrical and axial boron swelling in the upper holes, with high axial peaking factor, and for helium gas expansion in the lower holes.

All absorber holes are covered with a steel bar that fits in a slot along the outer blade wing edge. A leaktight closure is then obtained by welding together the shanks that are rolled over the bar. The holes are still connected to each other through a communication channel in that pressure equalization of the helium gas generated in the boron carbide pins during irradiation can take place. Each blade wing forms a separate enclosure which is tested for leaks after the welding.

### Handle

The design of the lifting double handle is compatible to the control rods of GE design. The handle is integrated with the blade wing, welded together in the center to form the lifting handle.

### Velocity Limiter and Coupling Device

The bottom part of the control rod includes a velocity limiter with a coupling device. The velocity limiter is welded to the blade wings, and the coupling device is mounted by a thread and finally lock-welded to the velocity limiter.

#### **4.2.3.1.3 Safety Evaluation**

**4.2.3.1.3.1 Materials Adequate Throughout Design Lifetime** The adequacy of the materials throughout the design life was evaluated in the mechanical design of the control rods. The primary materials, B<sub>4</sub>C powder, solid B<sub>4</sub>C pins, commercial grade and high-purity stabilized Type 304 stainless steel, Type 316 stainless steel, Inconel-X, and Hafnium were found suitable in meeting the demands of the BWR environment.

**4.2.3.1.3.2 Dimensional and Tolerance Analysis.** Layout studies are made to ensure that, given the worst combination of extreme detail part tolerance ranges at assembly, no interference exists which restricts the passage of control rods. In addition, preoperational verification is made on each control blade system to show that acceptable levels of operational performance are met.

**4.2.3.1.3.3 Thermal Analysis of the Tendency to Warp.** The various parts of the control rod assembly remain at approximately the same temperature during reactor operation, negating the problem of distortion or warpage. What little differential thermal growth could exist is allowed for in the mechanical design. A minimum axial gap is maintained between absorber rod tubes and the control rod frame assembly for this purpose. In addition, dissimilar metals are avoided to further this end.

**4.2.3.1.3.4 Forces for Expulsion.** An analysis of the maximum pressure forces that could tend to eject a control rod from the core was performed. The results of this analysis are given in paragraph 4.2.3.2.3.1. In summary, if the collet were to remain open, which is unlikely, calculations indicate that the steady-state control rod withdrawal velocity will be 2 ft/s for a pressure-under line break, the limiting case for rod withdrawal. (A complete description of the collet is provided in paragraph 4.2.3.2.2.2.)

**4.2.3.1.3.5 Functional Failure of Critical Components.** The consequences of a functional failure of critical components were evaluated, and the results are covered in paragraph 4.2.3.2.3.2.

**4.2.3.1.3.6 Precluding Excessive Rates of Reactivity Addition.** To preclude excessive rates of reactivity addition, the design is based upon analyses that were performed both on the velocity limiter device and the effect of probable control rod failures (paragraph 4.2.3.2.3.1).

**4.2.3.1.3.7 Effect of Fuel Rod Failure on Control Rod Channel Clearances.** The CRD mechanical design ensures a sufficiently rapid insertion of control rods to preclude the occurrence of fuel rod failures which could hinder reactor shutdown by causing significant distortions in channel clearances.

**4.2.3.1.3.8 Effects of Blowdown Loads on Control Rod Channel Clearances.** The fuel channel load resulting from an internally applied pressure is evaluated, using a fixed-beam analytical model under a uniform load. Tests to verify the applicability of the analytical model indicate that the model is conservative. A roller at the top of the control rod guides the blade as it is inserted. If the gap between channels is less than the diameter of the roller, the roller deflects the channel walls as it makes its way into the core. The friction force is a small percentage of the total force available to the CRDs for overcoming such friction, and it is concluded that the MSLBA does not impede the insertability of the control rod.

**4.2.3.1.3.9 Mechanical Damage.** Analyses performed for all areas of the control system showed that system mechanical damage does not affect the capability to provide reactivity control continuously.

In addition to the analysis performed on the CRD (paragraphs 4.2.3.2.3.1 and 4.2.3.2.3.2), the following discussion summarizes the analysis performed on the control rod guide tube.

The guide tube can be subjected to any or all of the following loads:

- Inward load due to pressure differential.
- Lateral loads due to flow across the guide tube.
- Deadweight.
- Seismic.

In all cases, an analysis was performed considering both the LOCA and the MSLBA, events that result in the largest hydraulic loadings on a control rod guide tube.

The two primary modes of failure considered in the guide tube analysis are exceeding allowable stress and excessive elastic deformation. It was found that the allowable stress limit is not exceeded and that the elastic deformations of the guide tube are never great enough to cause free movement of the control rod to be jeopardized.

The first mode of failure is evaluated by the addition of all stresses resulting from maximum loads for the faulted condition. This results in the maximum theoretical stress value for that condition. Making a linear supposition of all calculated stresses and comparing this value to the allowable limit defined by the ASME Boiler and Pressure Vessel Code yields a factor of safety of ~ 3. For faulted conditions, the factor of safety is ~ 4.4.

Evaluation of the second mode of failure is based upon clearance reduction between the guide tube and the control rod. The minimum allowable clearance is ~ 0.1 in. This assumes maximum ovality and minimum diameter of the guide tube and the maximum control rod dimension. The analysis showed that if the approximate 6000 psi for the faulted condition were entirely the result of differential pressure, the clearance between the control rod and the guide tube will reduce by a value of ~ 0.01 in. This gives a design margin of 10 between the theoretically calculated maximum displacement and the minimum allowable clearance.

The two types of instability considered in the analysis of guide tube design are:

- The classic instability associated with vertically loaded columns.
- The diametral collapse when a circular tube experiences external-to-internal differential pressure.

The limiting axially applied load is ~ 77,500 lb, resulting in a material compressive stress of 17,450 psi (Code allowable stress). Comparing the actual load to the yield stress level gives a design margin > 20 to 1. From these values, it is concluded that the guide tube is not an unstable column.

When a circular tube experiences external-to-internal differential pressure, two modes of failure are possible, depending on whether the tube is long or short. In the analysis here, the guide tube is taken to be an infinitely long tube with the maximum allowable ovality and minimum wall thickness. The conditions result in the lowest critical pressure calculation for the guide tube. That is, if the tube is short, the critical pressure calculation gives a higher number. The critical pressure is ~ 140 psi. However, if the maximum allowable stress is reached at a pressure lower than the critical pressure, then that pressure is limiting. This is the case for a BWR guide tube. The allowable stress of 17,450 psi is reached at ~ 93 psi. Comparing the maximum possible pressure differential for a steam line break to the limiting pressure of 93 psi gives a design margin > 3 to 1. Therefore, the guide tube is not unstable with respect to differential pressure. References 17 and 18 provide a detailed discussion of analyses and design margins for the control rod guide tube.

**4.2.3.1.3.10 Evaluation of Control Rod Velocity Limiter.** The control rod velocity limiter limits the free-fall velocity of the control rod to a value that cannot result in nuclear system process barrier damage. This velocity is evaluated by the CRDA analysis in section 15.3.

#### **4.2.3.1.4 Tests and Inspections**

The control rod absorber tube tests are examples of the quality control tests performed on the control rods. The absorber tube tests include the following:

- Material integrity of the tubing and end plug verified by ultrasonic inspection.
- The B-10 fraction of the boron content of each lot of boron carbide verified.
- Weld integrity of the finished absorber tubes verified by helium leak testing.

#### **4.2.3.1.5 Instrumentation**

The instrumentation for both the control rods and the CRDs is defined by that given for the reactor manual control system (RMCS). The objective of the RMCS is to provide the operator with the means to make changes in nuclear reactivity so that reactor power level and power distribution can be controlled. The system allows the operator to manipulate control rods.

The design bases and further discussion are presented in HNP-1-FSAR section 7.7 and HNP-2-FSAR subsection 7.7.1.

#### 4.2.3.2 **CRD System**

##### 4.2.3.2.1 **Design Bases**

4.2.3.2.1.1 **General Design Bases.** The general design bases for the CRD system are as follows:

###### A. Safety Design Bases

The CRD mechanical system meets the following safety design bases:

- Design provides for a sufficiently rapid control rod insertion so that no calculated fuel damage results from any AOO.
- Design includes positioning devices, each of which individually supports and positions a control rod.
- Each positioning device:
  - Prevents its control rod from withdrawing as a result of a single malfunction.
  - Be individually operated so that a failure in one positioning device does not affect the operation of any other positioning device.
  - Be individually energized when rapid control rod insertion (scram) is signaled so that failure of power sources external to the positioning device does not prevent the positioning devices of other control rods from being inserted.
  - Be locked to its control rod to prevent undesirable separation.
- The CRD mechanisms and that part of the CRD hydraulic system (CRDHS) necessary for scram shall be designed to Seismic Category 1 requirements.

###### B. Power Generation Design Bases

The CRD system design provides for positioning the control rods to control power generation in the core.

##### 4.2.3.2.2 **Description**

The CRD system controls gross changes in core reactivity by incrementally positioning neutron-absorbing control rods within the reactor core in response to manual control signals. It



is also required to scram the reactor in emergency situations by rapidly inserting withdrawn control rods into the core in response to a manual or automatic signal. The CRD system consists of locking piston, CRD mechanisms, alternate rod insertion (ARI) system, and the CRDHS (including hydraulic control units, interconnecting piping, instrumentation, and electrical controls).

**4.2.3.2.2.1 Control Rod Drive Mechanism.** The CRD mechanism (drive) used for positioning the control rod in the reactor core is a double-acting, mechanically latched, hydraulic cylinder using water as its operating fluid (figures 4.2-10 through 4.2-13). The individual drives are mounted on the bottom head of the RPV. The drives do not interfere with refueling and are operative even when the RPV head is removed. The drives are also readily accessible for inspection and servicing. The bottom location makes maximum use of the water in the reactor as a neutron shield and gives the least possible neutron exposure to the drive components. Using water from either the condensate and feedwater system taken downstream of the condensate polishing system or the condensate storage tank (CST) as the operating fluid eliminates the need for special hydraulic fluid. Simple piston seals are utilized in drives since leakage does not contaminate the RPV water and allows cooling of the drive mechanisms and their seals.

The drives are capable of inserting or withdrawing a control rod at a slow, controlled rate as well as providing rapid insertion when required. A mechanism on the drive locks the control rod in 6-in. increments of stroke over the length of the core.

A coupling spud at the top end of the drive index tube (piston rod) engages and locks into a mating socket at the base of the control rod. The weight of the control rod is sufficient to engage and lock this coupling. Once locked, the drive and rod form an integral unit that must be manually unlocked by specific procedures before the components can be separated.

The drive holds its control rod in distinct latch positions until the CRDHS actuates movement to a new position. Withdrawal of each rod is limited by the seating of the rod in its guide tube. Withdrawal beyond the overtravel limit can be accomplished only if the rod and drive are uncoupled. Withdrawal past the overtravel limit is annunciated by an alarm.

The individual rod indicators, grouped in one control panel display, correspond to relative rod locations in the core. A separate, smaller display is located just below the large display on the vertical part of the benchboard. This display presents the positions of the control rod selected for movement and the other rods in the affected rod group.

For display purposes, the control rods are considered in groups of four adjacent rods centered around a common core volume. Each group is monitored by four local power range monitor (LPRM) strings (HNP-1-FSAR subsection 7.5.6, and HNP-2-FSAR subsections 4.4.6 and 7.6.1). Rod groups at the periphery of the core may have less than four rods. The small rod display shows the positions, in digital form, of the rods in the group to which the selected rod belongs. A white light indicates which of the four rods is the one selected for movement.

**4.2.3.2.2.2 Control Rod Drive Components.** Figure 4.2-11 illustrates the operating principle of a CRD. Figures 4.2-12 and 4.2-13 illustrate the CRD in more detail. The main components of the CRD and their functions are described as follows.

The CRD piston is mounted at the lower end of the index tube. This tube functions as a piston rod. The CRD piston and index tube make up the main moving assembly in the CRD. The CRD piston operates between positive end stops, with a hydraulic cushion provided at the upper end only. The piston has both inside and outside seal rings and operates in an annular space between an inner cylinder (fixed piston tube) and an outer cylinder (drive cylinder). Because the type of inner seal used is effective in only one direction, the lower sets of seal rings are mounted with one set sealing in each direction.

A pair of nonmetallic bushings prevents metal-to-metal contact between the piston assembly and the inner cylinder surface. The outer piston rings are segmented step-cut seals with expander springs holding the segments against the cylinder wall. A pair of split bushings on the outside of the piston prevents piston contact with the cylinder wall. The effective piston area for downtravel, or withdrawal, is  $\sim 1.2 \text{ in.}^2$  vs  $4.1 \text{ in.}^2$  for uptravel, or insertion. This difference in driving area tends to balance the control rod weight and ensures a higher force for insertion than for withdrawal.

The index tube is a long, hollow shaft made of nitrided Type 304 stainless steel. Circumferential locking grooves spaced every 6 in. along the outer surface transmit the weight of the control rod to the collet assembly.

The collet assembly serves as the index tube locking mechanism. It is located in the upper part of the drive unit. This assembly prevents the index tube from accidentally moving downward. The assembly consists of the collet fingers, a return spring, guide cap, collet housing (part of the cylinder, tube, and flange) and the collet piston.

Locking is accomplished by fingers mounted on the collet piston at the top of the drive cylinder. In the locked or latched position, the fingers engage a locking groove in the index tube. The collet piston is normally held in the latched position by a force of  $\sim 150 \text{ lb}$  supplied by a spring. Metal piston rings are used to seal the collet piston from RPV pressure. The collet assembly does not unlatch until the collet fingers are unloaded by a short, automatically sequenced drive-in signal. A pressure  $\sim 180 \text{ psi}$  above RPV pressure must then be applied to the collet piston to overcome spring force, slide the collet up against the conical surface in the guide cap, and spread the fingers so they do not engage a locking groove.

A guide cap is fixed in the upper end of the CRD assembly. This member provides the unlocking cam surface for the collet fingers and serves as the upper bushing for the index tube.

If RPV water is used during a scram to supplement accumulator pressure, it is drawn through a filter on the guide cap.

The piston tube is an inner cylinder, or column, extending upward inside the CRD piston and index tube. The piston tube is fixed to the bottom flange of the CRD and remains stationary. Water is brought to the upper side of the CRD piston through this tube. A series of orifices at

## HNP-2-FSAR-4

the top of the tube provides progressive water shutoff to cushion the CRD piston at the end of its scram stroke.

A stationary piston, called the stop piston, is mounted on the upper end of the piston tube. This piston provides the seal between RPV pressure and the space above the drive piston. It also functions as a positive end stop at the upper limit of control rod travel. A stack of spring washers just below the stop piston helps absorb the final mechanical shock at the end of control rod travel. The piston rings are similar to the outer drive piston outer rings. A bleedoff passage to the center of the piston tube is located between the two pairs of rings. This arrangement allows seal leakage from the RPV (during a scram) to be bled directly to the discharge line. The lower pair of seals is used only during the cushioning of the CRD piston at the upper end of the stroke.

The center tube of the CRD mechanism forms a well to contain the position-indicator probe. This probe is an aluminum extrusion attached to a cast aluminum housing. Mounted on the extrusion are hermetically sealed, magnetically operated position-indicator switches. Each switch is sheathed in a braided glass sleeve, and the entire probe assembly is protected by a thin-walled stainless-steel tube. The switches are actuated by a ring magnet located at the bottom of the drive piston.

The drive piston, piston tube, and indicator tube are all of nonmagnetic stainless steel, allowing the individual switches to be operated by the magnet as the piston passes. One switch is located at each position corresponding to an index tube groove, thus allowing indication at each latching point. An additional switch is located at each midpoint between latching points to indicate the intermediate positions during drive motion. Thus, indication is provided for each 3 in. of travel. Duplicate switches are provided for the full-in and full-out positions. One additional switch (an overtravel switch) is located at a position below the normal full-out position. Because the limit of down travel is normally provided by the control rod itself as it reaches the backseat position, the CRD can pass this position and actuate the overtravel switch only if it is uncoupled from its control rod. A convenient means is, thus, provided to verify that the drive and control rod are coupled after installation of a drive or at any time during plant operation.

A flange-and-cylinder assembly is made up of a heavy flange welded to the CRD cylinder. A sealing surface on the upper face of this flange forms the seal to the drive housing flange. The seals contain RPV pressure and hydraulic control pressure. Teflon-coated, stainless-steel rings are used for these seals. The CRD flange contains the integral ball, or two-way, check (ball-shuttle) valve. This valve directs either the RPV pressure or the driving pressure, whichever is higher, to the underside of the CRD piston. The RPV pressure is admitted to this valve from the annular space between the drive and drive housing through passages in the flange.

Water used to operate the collet piston passes between the outer tube and the cylinder tube. The inside of the cylinder tube is honed to provide the surface required for the drive piston seals. Both the cylinder tube and outer tube are welded to the CRD flange. The upper ends of these tubes have a sliding fit to allow for differential expansion.

The upper end of the index tube is threaded to receive a coupling spud. The coupling (figure 4.2-10) accommodates a small amount of angular misalignment between the CRD and

## HNP-2-FSAR-4

the control rod. Six spring fingers allow the coupling spud to enter the mating socket on the control rod. A plug then enters the spud and prevents uncoupling.

Two means of uncoupling are provided. With the RPV head removed, the lock plug can be raised against the spring force of ~ 50 lb by a rod extending up through the center of the control rod to an unlocking handle located above the control rod velocity limiter. The control rod, with the lock plug raised, can then be lifted from the CRD.

The lock plug can also be pushed up from below if it is desired to uncouple a drive without removing the RPV head for access. In this case, the central portion of the drive mechanism is pushed up against the uncoupling rod assembly, which raises the lock plug and allows the coupling spud to disengage the socket as the drive piston and index tube are driven down.

The control rod is heavy enough to force the spud fingers to enter the socket and push the lock plug up, allowing the spud to enter the socket completely and the plug to snap back into place. Therefore, the CRD can be coupled to the control rod by using only the weight of the control rod. However, with the lock plug in place, a force in excess of 50,000 lb is required to pull the coupling apart.

### Materials of Construction

Factors that determine the choice of construction materials are discussed in the following paragraphs.

The index tube must withstand the locking and unlocking action of the collet fingers. A compatible bearing combination must be provided that is able to withstand moderate misalignment forces. The reactor environment limits the choice of materials suitable for corrosion resistance. The column and tensile loads can be satisfied by an annealed 300-series stainless steel. The wear and bearing requirements are provided by Malcomizing the completed tube. To obtain suitable corrosion resistance, a carefully controlled process of surface preparation is employed.

The coupling spud is made of Inconel 750 that is aged for maximum physical strength and the required corrosion resistance. Because misalignment tends to cause chafing in the semispherical contact area, the part is protected by a thin chromium plating (electrolyzed). This plating also prevents galling of the threads attaching the coupling spud to the index tube.

Inconel 750 is used for the collet fingers, which must function as leaf springs when cammed open to the unlocked position. Colmonoy 6 hard facing provides a long-wearing surface, adequate for design life, for the area contacting the index tube and unlocking cam surface of the guide cap.

Graphitar 14 is used for seals and bushings on the CRD piston and stop piston. The material is inert and has a low friction coefficient when water lubricated. Because some loss of strength is experienced at higher temperatures, the drive is supplied with cooling water to hold temperatures below 250°F. The Graphitar is relatively soft, which is advantageous when an occasional particle of foreign matter reaches a seal. The resulting scratches in the seal reduce

## HNP-2-FSAR-4

sealing efficiency until worn smooth, but the CRD design can tolerate considerable water leakage past the seals into the RPV.

All CRD components exposed to RPV water are made of American Iron and Steel Institute (AISI) 300-series stainless steel except the following:

1. Seals and bushings on the CRD piston and stop piston are Graphitar 14.
2. All springs and members requiring spring action (collet fingers, coupling spud, and spring washers) are made of Inconel 750.
3. The ball check valve is a Haynes Stellite cobalt-base alloy.
4. Elastomeric O-ring seals are ethylene propylene.
5. Collet piston rings are Haynes 25 alloy.
6. Certain wear surfaces are hard faced with Colmonoy 6.
7. Nitriding by a proprietary new Malcomizing process and chromium plating is used in certain areas where resistance to abrasion is necessary.
8. The CRD piston head is made of Armco 17-4Ph.

Pressure-containing portions of the CRDs are designed and fabricated in accordance with requirements of Section III of the ASME Boiler and Pressure Vessel Code.

**4.2.3.2.2.3 CRDHS.** The CRDHS (HNP-1 drawing nos. H-16064, H-16065, and S-15059 and HNP-2 drawing nos. H-26006, H-26007, S-25311, and S-25312) supplies and controls the pressure and flow to and from the drives through a hydraulic control unit (HCU). The water discharged from the CRDs during a scram flows through the HCUs to the scram discharge volume (SDV). The water discharged from a CRD during a normal control rod positioning operation flows through the HCU, exhaust header, return line, and back into the CRD system. There are as many HCUs as there are CRDs.

The hydraulic requirements, identified by the function they perform, are as follows:

- A. An accumulator hydraulic charging pressure of ~ 1400 to 1500 psig is required. Flow to the accumulators is required only during scram reset or system startup.
- B. Drive pressure of ~ 250 psi above RPV pressure is required. Flowrates of ~ 4 gal/min to insert a control rod and 2 gal/min to withdraw a control rod are required.
- C. Cooling water to the CRDs is required at ~ 20 psi above RPV pressure and at a flowrate of 0.20 to 0.34 gal/min/drive unit. (Cooling water can be interrupted for short periods without damaging the drive.)

## HNP-2-FSAR-4

- D. The SDV is sized to receive and contain all water discharged by the CRDs during a scram. A minimum volume of 3.34 gal/CRD is required.

The CRDHS provides the required functions with the pumps, filter, valves, instrumentation, and piping shown in HNP-1 drawing nos. H-16064, H-16065, and S-15059, and HNP-2 drawing nos. H-26006, S-25311, and S-25312, and described in the following paragraphs.

Duplicate components are included, where necessary, to ensure continuous system operation if an inservice component requires maintenance.

One supply pump pressurizes the system with water from either the CST or the condensate and feedwater system. One spare pump is provided for standby. A discharge check valve prevents backflow through the nonoperating pump. A portion of the pump discharge flow is diverted through a minimum-flow line to the CST. This flow is controlled by an orifice and is sufficient to prevent immediate pump damage if the pump discharge is inadvertently closed.

The drive water filter downstream of the pump is a cleanable-element type with a 50- $\mu$  absolute rating. A differential pressure indicator and a main control room (MCR) alarm monitor the filter element as it collects foreign material.

Accumulator charging pressure is established by the discharge pressure of the system supply pump. During scram, the scram inlet (and outlet) valves open and permit the stored energy in the accumulators to discharge into the CRDs. The resulting pressure decrease in the water header allows the CRD supply pump to run out (flowrate to increase substantially) resulting in high flow, ~ 200 gal/min, into the CRDs via the charging water header. The flow-sensing system upstream of the accumulator charging header detects high flow and closes the flow-control valve. This action maintains increased flow through the charging water header.

Pressure downstream of the drive water filters is monitored in the MCR with a pressure indicator and charging water high-pressure alarm.

During normal operation, the flow-control valve maintains a constant system flowrate. This flow is used for drive flow, drive cooling, and system stability.

The CRD water pressure required in the drive header is maintained by the drive pressure-control valve, which is manually adjusted from the main control room. A flowrate of ~ 6 gal/min (the sum of the flowrate required to insert and withdraw a control rod) normally passes from the CRD water pressure stage through two solenoid-operated stabilizing valves (arranged in parallel) and then goes into the return line downstream from the cooling pressure-control valve. The flow through one stabilizing valve equals the drive insert flow; that of the other stabilizing valve equals the CRD withdrawal flow. When operating a CRD, the required flow is diverted to that CRD by closing the appropriate stabilizing valve. Thus, flow through the CRD pressure-control valve is always constant.

Flow indicators in the CRD water header and in the line downstream from the stabilizing valves allow the flowrate through the stabilizing valves to be adjusted when necessary. Differential pressure between the RPV and the CRD pressure stage is indicated in the MCR.

## HNP-2-FSAR-4

The cooling-water header is located upstream from the cooling-pressure control valve that can be manually adjusted from the MCR to produce the required cooling-water pressure or provide water to the RPV as needed. Water not required for CRD cooling can be passed through the cooling-pressure control valve to the RPV via the reactor water cleanup (RWC) system. However, due to intergranular stress corrosion cracking (IGSCC) concerns, the cooling-pressure control valve to the RPV valve is normally closed. Thus, the CRD pump discharge valves may need to be throttled to help the cooling-pressure control valve maintain required cooling-water pressure.

To eliminate excess water and high pressure from the CRDHS, a backpressure regulated control valve tied to each CRD pump's minimum-flow line (upstream of the minimum-flow orifices via a crosstie and common bypass) bypasses a variable flow up to 30 gal/min around the minimum-flow orifices to the CST. Stop check valves provide isolation between the CRD pumps in the crosstie line. The backpressure regulated control valve's motive force is interruptible instrument air with a fail-closed operator.

The flow through the flow-control valve is virtually constant. Therefore, once adjusted, the CRD pressure-control valve and the cooling pressure-control valve can maintain their required pressures independent of RPV pressure. Changes in setting of the pressure-control valves are required only to adjust for changes in the cooling requirements of the CRDs, as their seal characteristics change with time. A flow indicator in the MCR monitors cooling-water flow. A differential pressure indicator in the MCR indicates the difference between RPV pressure and CRD cooling-water pressure. Although the CRDs can function without cooling water, seal life is shortened by long-term exposure to RPV temperatures. The temperature of each CRD is recorded in a local panel, and excessive temperatures are annunciated in the MCR.

The SDV consists of header piping that connects to each HCU and drains into an instrument volume. The header piping is sized to receive and contain all the water discharged by the CRDs during a scram, independent of the instrument volume.

During normal plant operation, the SDV is empty and vented to atmosphere through its open vent and drain valves. When a scram occurs, upon a signal from the safety circuit these vent and drain valves are closed to conserve RPV water. Lights in the MCR indicate the positions of these valves.

Redundant vent and drain valves and pilot valves are provided to ensure single-failure-proof isolation of the scram discharge header. The pilot valves are redundant-coil solenoid-operated quick exhaust valves which enable vent and drain valve closure within limits set forth in the Technical Specifications. Unit 1 has needle valves installed in the air supply lines to allow sequencing of the inboard and outboard sets of vent and drain valves to preclude possible hydrodynamic forces which might otherwise be present during the opening and closing of these valves. Unit 2 air supply pilot valves to the inboard and outboard sets of vent and drain valves are sequenced to preclude possible hydrodynamic forces via time delay relays installed in the RPS logic and located in MCR panels.

During a scram, the SDV partly fills with water discharged from above the drive pistons. While scrammed, the CRD seal leakage from the reactor continues to flow into the SDV until the

## HNP-2-FSAR-4

discharge volume pressure equals the RPV pressure. A check valve in each HCU prevents reverse flow from the scram discharge header volume to the CRD.

When the initial scram signal is cleared from the reactor protection system (RPS), the SDV signal is overridden with a keylock override switch, and the SDV is drained and returned to atmospheric pressure.

Remote manual switches in the pilot valve solenoid circuits allow the discharge volume vent and drain valves to be tested without disturbing the RPS. Closing the SDV valves allows the outlet scram valve seats to be leak tested by timing the accumulation of leakage inside the SDV.

Ten liquid-level switches (six float level switches and four thermal probes) connected to the instrument volume monitor the volume for abnormal water level. It is set at three levels. At the lowest level, a level switch actuates to indicate that the volume is not completely empty during post scram draining or to indicate that the volume starts to fill through leakage accumulation at other times during reactor operation. At the second level, one level switch produces a rod-withdrawal block to prevent further withdrawal of any control rod when leakage accumulates to half the capacity of the instrument volume. The remaining eight switches (four float level switches and four thermal probes) are interconnected with the trip channels of the RPS and initiate a reactor scram should water accumulation fill the instrument volume.

### Hydraulic Control Units

Each HCU furnishes pressurized water, on signal, to a CRD unit. The CRD then positions its control rod as required. Operation of the electrical system that supplies scram and normal control rod positioning signals to the HCU is described in HNP-1-FSAR and HNP-2-FSAR sections 7.2 and 7.7.

The basic components in each HCU (figure 4.2-14) are manual, pneumatic, and electrical valves; an accumulator; related piping; electrical connections; filters; and instrumentation (HNP-1-FSAR drawing nos. H-16064, H-16065, and S-15059, and HNP-2 drawing nos. H-26006 and H-26007). The components and their functions are described in the following paragraphs.

- A. The insert CRD valve is solenoid operated, opens on an insert signal, and supplies drive water to the bottom side of the main CRD position.
- B. The insert exhaust valve opens by solenoid on an insert signal and discharges water from above the CRD piston to the exhaust water header.
- C. The withdraw CRD valve is solenoid, operated, opens on a withdraw signal, and supplies drive water to the top of the drive piston.
- D. The solenoid-operated withdraw exhaust valve opens on a withdraw signal, discharges water from below the main CRD piston to the exhaust header, and serves as the settle valve. During the settle mode, the valve opens following drive insert and remains open following withdrawal to allow the CRD to settle back into the nearest latch position.



## HNP-2-FSAR-4

- E. The speed-control valves regulate the control rod insertion and withdrawal rates during normal operation. They are manually adjustable flow-control valves used to regulate the water flow to and from the volume beneath the main drive piston. A correctly adjusted valve does not require readjustment, except to compensate for changes in CRD seal leakage.
- F. The scram pilot valves are operated from the RPS trip system. Two scram pilot valves control both the scram inlet valve and the scram exhaust valve. The scram pilot valves are identical three-way, solenoid-operated, normally energized valves. On loss of electrical signal to the pilot valves, such as the loss of external ac power, the inlet ports close and the exhaust ports open on both pilot valves. The pilot valves (HNP-1 drawing nos. H-16064, H-16065, and S-15059, and HNP-2 drawing nos. H-26006 and H-26007) are arranged so that the trip system signal must be removed from both valves before air pressure can be discharged from the scram valve operators. This prevents the inadvertent scram of a single CRD in the event of failure of one of the solenoid pilot valves.
- G. The scram inlet valve opens to supply pressurized water to the bottom of the CRD piston. This quick-opening globe valve is operated by an internal spring and system pressure, and is closed by air pressure applied to the top of its diaphragm operator.
- H. The scram exhaust valve opens slightly before the scram inlet valve, exhausting water from above the CRD piston. The exhaust valve opens faster than the inlet valve because of a larger spring in the valve operator; otherwise, the valves are similar. A position-indication switch on the scram exhaust valve in series with a position-indication switch on the scram inlet valve energizes a light in the MCR as soon as both valves start to open.
- I. The scram accumulator stores sufficient energy to fully insert a control rod at lower RPV pressures. At higher RPV pressures, the accumulator pressure is assisted or supplanted by RPV pressure. The accumulator is a hydraulic cylinder with a free-floating piston that separates the water on top from the nitrogen below. A check valve in the accumulator charging line prevents loss of water pressure in the event supply pressure is lost.

During normal plant operation, the accumulator piston is seated at the bottom of its cylinder.

To ensure the accumulator is always able to produce a scram, it is continuously monitored for water leakage. A float-type level switch actuates an alarm if water leaks past the piston barrier and collects in the accumulator instrumentation block.

**4.2.3.2.2.4 Alternate Rod Insertion System.** The ARI installation fulfills requirement C.3 of 10 CFR 50.62 pertaining to the reduction of risk from anticipated transients without scram (ATWS) events.<sup>(10)</sup>

## HNP-2-FSAR-4

ATWS events are the anticipated occurrences, as defined in Appendix A of 10 CFR 50, followed by a failure of the reactor trip portion of the reactor protection system (RPS). The ARI provides the necessary signals in response to an ATWS event or manual initiation to depressurize the CRD scram pilot valve air header through valves that are different from the RPS scram valves (HNP-1 drawing nos. H-16064 and H-16065, and HNP-2 drawing no. H-26007), providing a parallel path for initiating control rod insertion.

The ARI valves are operated from logic independent from the RPS trip system. They are solenoid-operated and are normally deenergized. There are four valves. One is a three-way valve. On an actuation signal, the inlet will close to block the air supply, and the exhaust will open to vent the scram valve pilot air header. Three of the valves are two-way. On an actuation signal, they open to speed depressurization of the header.

The signals to initiate the ARI function will come from high RPV dome pressure, low RPV water level 2, or manual initiation by pushbuttons on the 1H11-P603 and 2H11-P603 panels in the MCR. The high RPV dome pressure setpoint is set higher, and the low RPV water level setpoint is set lower than the normal scram setpoints such that a normal scram should have already been initiated at the time an ARI setpoint is reached. The signals which initiate the ARI will also initiate an ATWS recirculation pump trip (RPT), which is described in HNP-1-FSAR subsection 7.2.3 and HNP-2-FSAR paragraph 7.6.10.7.

The actuation signals to the ARI system will seal in for 30 to 35 s to assure all control rods have time to fully insert.

**4.2.3.2.2.5 CRD System Operation.** The CRD system performs rod insertion, rod withdrawal, and scram. These operational functions are described in the following paragraphs.

Rod insertion is initiated by a signal from the operator to the insert valve solenoids. This signal causes both insert valves to open. The insert CRD valve applies RPV pressure, plus ~ 90 psi to the bottom of the CRD piston. The insert exhaust valve allows water from above the CRD piston to discharge to the exhaust header.

As is illustrated in figure 4.2-10, the locking mechanism is a ratchet-type device and does not interfere with rod insertion. The speed at which the CRD moves is determined by the flow through the insert speed-control valve, which is set for ~ 4 gal/min for a shim speed (nonscram operation) of 3 in./s. During normal insertion, the pressure on the downstream side of the speed-control valve is 90 to 100 psi above RPV pressure. However, if the CRD slows for any reason, the flow through and pressure drop across the insert speed-control valve decreases and full drive header pressure, up to RPV pressure plus 260 psi, is then available to cause continued insertion. With 260-psi differential pressure acting on the CRD piston, the piston exerts an upward force of 1040 lb.

By design, rod withdrawal is more involved than insertion. The collet finger (latch) must be raised to reach the unlocked position (figure 4.2-11). The index tube notches and the collet fingers are shaped so that the downward force on the index tube holds the collet fingers in place. The index tube must be lifted before the collet fingers can be released. This is done by opening the CRD insert valves (in the manner described in the preceding paragraph) for

## HNP-2-FSAR-4

approximately one second. The withdraw valves are then opened, applying driving pressure above the drive piston and opening the area below the piston to the exhaust header. As the piston rises, the collet fingers are cammed outward, away from the index tube, by the guide cap.

The pressure required to release the latch is set and maintained at a level high enough to overcome the force of the latch return spring plus the force of RPV pressure opposing movement of the collet piston. When this occurs, the index tube is unlatched and free to move in the withdraw direction. Water displaced by the CRD piston flows out through the withdraw speed-control valve, which is set to give the control rod a shim speed of 3 in./s. The entire valving sequence is automatically controlled and is initiated by a single operation of the rod withdraw switch.

During a scram, the scram pilot valves and scram valves are operated as previously described. With the scram valves open, accumulator pressure is admitted under the CRD piston, and the area over the drive piston is vented to the SDV.

The large differential pressure (always several hundred psi, depending on RPV pressure) produces a large upward force on the drive piston. This force gives the rod high initial acceleration and provides a large margin of force to overcome friction. After the initial acceleration is achieved, the CRD continues at a nearly constant velocity. This characteristic provides a high initial rod-insertion rate. As the CRD piston nears the top of its stroke, the piston seals close off the large passage (buffer orifices) in the stop piston tube, and the CRD slows.

Prior to a scram signal, the accumulator in the HCU has ~ 1400 psig on the water side and 1100 psig on the nitrogen side. As the inlet scram valve opens, the full water-side pressure is available at the CRD, acting on a 4.1-in.<sup>2</sup> area. As CRD motion begins, this pressure drops to the gas-side pressure, less the pressure loss between the accumulator and the CRD.

The CRD accumulators are required to scram the control rod when the RPV pressure is low. When the RPV pressure is low, the accumulator retains sufficient stored energy to ensure the complete insertion of the control rod in the required time. The accumulator is not required to scram the control rod in time when the reactor is close to or at full operating pressure. In this instance, the RPV pressure alone scrams the control rod in the required time. However, the accumulator does provide an additional energy boost to the RPV pressure in providing scram action at RPV pressures less than accumulator pressures.

The CRD system, with accumulators, provides the following scram performances at any RPV pressure in terms of average elapsed time after the opening of the RPS trip actuator (scram signal) for the CRDs to attain the scram strokes listed:

## HNP-2-FSAR-4

| <u>Percentage of Full Control Rod Stroke</u> | <u>Stroke (in.)</u> | <u>Average Time(s)</u> |
|----------------------------------------------|---------------------|------------------------|
| 5.0                                          | 7.2                 | 0.49                   |
| 20.0                                         | 28.8                | 0.90                   |
| 50.0                                         | 72.0                | 2.0                    |
| 90.0                                         | 129.6               | 3.5                    |

The Technical Specifications specify the insertion time required to ensure the scram reactivity assumed in the DBA and AOO analyses is met. Accident and AOO analyses use a specific scram reactivity insertion rate that assumes all control rods scram at the same speed. In general, as long as the insertion time of all control rods equals the time used in the analyses, the scram reactivity insertion rate will be maintained.

However, this assumes that the insertion times are normally distributed, with adequate separation of slower CRDs. Therefore, if the average insertion time is maintained, some control must be placed on the local scram reactivity. For simplicity, the Technical Specifications incorporate a format that measures individual CRD insertion time to determine whether the analytical bases (scram reactivity) is met and also checks for signs of degraded scram performance. This ensures that core-wide and local reactivity requirements are met.

The times used for the Technical Specifications are based on actual performance test data and are accurate representations of the expected CRD insertion time. These insertion times are actually faster than the values used in the accident and AOO analyses to allow for a certain number of slow control rods and account for single failures. The Technical Specifications impose limitations on the number and location of slow control rods. The Technical Specifications 5% insertion time is increased above the design average scram time. Based on the evaluation of actual insertion time data, the increased 5% insertion time has been shown to have a negligible impact on plant accident and AOO performance.

### 4.2.3.2.3 Evaluation of Scram Time

The rod scram function of the CRD system provides the negative reactivity insertion required by the safety design bases (see first entry under the third bullet) in paragraph 4.2.3.2.1.1. The scram time shown in the description is adequate as shown by the safety analysis discussed in HNP-2-FSAR chapter 15.

Sufficient driving force is available to overcome the retarding force during a scram. The control rod weighs 158 lb in water and 186 lb in air. The index tube weighs 62 lb in water and 71 lb in air. Other moving parts weigh ~ 5 lb; thus, the wet drive line weight is ~ 225 lb.

At the start of motion, assuming the accumulator is normally charged, the CRD pump supplies ~ 1500 psi at the inlet scram valve. This supplies a 500-psi differential to assist opening of the valve and exists until drive motion starts. Pressure at the CRD immediately drops to RPV pressure due to losses in the piping and valves, and RPV pressure is applied through the ball check valve in the CRD. This pressure, actually slightly less than RPV pressure due to flow

losses as the water comes down the annulus between the CRD and thermal sleeve, is applied to the 4.1-in.<sup>2</sup> under-piston area. The area above the piston, 1.25 in.<sup>2</sup>, is vented to the SDV and initially drops to atmospheric pressure. As soon as drive motion starts, line losses in the discharge line raise the pressure over the piston to ~ 180 psi. The balance of the over-piston area (4.1 minus 1.25 in.<sup>2</sup>) is exposed to RPV pressure. Available force, assuming a stuck rod, reduces simply to 1.25 x 1000 or 1250 lb throughout the stroke after accumulator energy is expended. Since the available force is constant at 1250 lb from the beginning of motion to the end of the strokes, no plot of the force developed by the CRD mechanism versus stroke for a scram with the accumulator and RPV at nominal pressure is necessary.

**4.2.3.2.3.1 Analysis of Malfunction Relating to Rod Withdrawal.** There are no known single malfunctions that cause the unplanned withdrawal of even a single control rod. However, if multiple malfunctions are postulated, studies show that an unplanned rod withdrawal can occur at withdrawal speeds that vary with the combination of malfunctions postulated. In all cases the subsequent withdrawal speeds are less than those assumed in the CRDA analysis as discussed in HNP-2-FSAR subsection 15.3.2. Therefore, the physical and radiological consequences of such rod withdrawals are less than those analyzed in the CRDA.

A. Drive Housing Fails at Attachment Weld

The bottom head of the RPV has a penetration for each CRD location. A CRD housing is raised into position inside each penetration and fastened by welding. The CRD is raised into the CRD housing and bolted to a flange at the bottom of the housing. The housing material is seamless, Type 304 stainless-steel pipe with a minimum tensile strength of 75,000 psi. The basic failure considered here is a complete circumferential crack through the housing wall at an elevation just below the J-weld.

Static loads on the housing wall include the weight of the CRD and the control rod, the weight of the housing below the J-weld, and the RPV pressure acting on the 6-in.-diameter cross-sectional area of the housing and the CRD. Dynamic loading results from the reaction force during CRD operation.

If the housing were to fail as described, the following sequence of events is foreseen:

1. The housing separates from the RPV.
2. The control rod, the CRD, and the housing are blown downward against the support structure by RPV pressure acting on the cross-sectional area of the housing and the CRD.
3. The downward motion of the CRD and associated parts is determined by the gap between the bottom of the CRD and the support structure and by the deflection of the support structure under load. In the current design, maximum deflection is ~ 3 in. If the collet remains latched, no further control

## HNP-2-FSAR-4

rod ejection will occur,<sup>(19)</sup> and the housing will not drop far enough to clear the RPV penetration.

4. RPV water leaks at a rate of ~ 220 gal/min through the 0.03-in. diametrical clearance between the housing and the RPV penetration.

If the basic housing failure occurs while the control rod is being withdrawn (this is a small fraction of the total CRD operating time), and if the collet stays unlatched, the following sequence of events is foreseen:

1. The housing separates from the RPV.
2. The drive and housing are blown downward against the CRD housing support. Calculations indicate the steady-state rod-withdrawal velocity is 0.3 ft/s. During withdrawal, pressure under the collet piston is ~ 250 psi greater than the pressure over it. Therefore, the collet is held in the unlatched position until driving pressure is removed from the pressure-over port.

### B. Rupture of Hydraulic Line(s) to CRD Housing Flange

The three types of possible rupture of hydraulic lines to the CRD housing flange are:

- Pressure-under line break.
- Pressure-over line break.
- Coincident breakage of both of these lines.

For the case of a pressure-under line break, a partial or complete circumferential opening is postulated at or near the point where the line enters the housing flange. Failure is more likely to occur after another basic failure wherein the CRD housing or housing flange separates from the RPV. Failure of the housing, however, does not necessarily lead directly to failure of the hydraulic lines.

If the pressure-under line fails and the collet is latched, no control rod withdrawal will occur. There is no pressure differential across the collet piston and, therefore, no tendency to unlatch the collet. Consequently, the associated control rod cannot be inserted or withdrawn.

The ball check valve is designed to seal off a broken pressure-under line by using RPV pressure to shift the check ball to its upper seat. If the ball check valve is prevented from seating, RPV water will leak to the atmosphere. Because of the broken line, cooling water cannot be supplied to the CRD involved. Loss of cooling water will cause no immediate damage to the CRD. However, prolonged exposure of the CRD to temperatures at or near RPV temperature can lead to deterioration of material in the seals. High temperature is indicated to the operator by the

## HNP-2-FSAR-4

thermocouple in the position indicator probe. A second indication is high cooling water flow.

If the basic line failure occurs while the control rod is being withdrawn, the hydraulic force will not be sufficient to hold the collet open, and the spring force normally causes the collet to latch and stop rod withdrawal. However, if the collet remains open, calculations indicate the steady-state control rod withdrawal velocity will be 2 ft/s.

The case of the pressure-over line breakage considers the complete breakage of the line at or near the point where it enters the housing flange. If the line breaks, pressure over the CRD piston will drop from RPV pressure to atmospheric pressure. Any significant RPV pressure (~ 500 psig or greater) acts on the bottom of the CRD piston and fully insert the CRD. Insertion occurs regardless of the operational mode at the time of the failure. After full insertion, RPV water leaks past the stop piston seals, the contracting seals on the drive piston, and the collet piston seals. This leakage exhausts to the atmosphere through the broken pressure-over line. The leakage rate at 1000-psi RPV pressure is estimated to be 4 gal/min nominal but not more than 10 gal/min, based upon experimental measurements. If the RPV is hot, drive temperature will increase. This situation is indicated to the reactor operator by the drift alarm, by the fully inserted drive, by a high drive temperature (indicated and printed out on a recorder in the control room), and by operation of the drywell sump pump.

For the simultaneous breakage of the pressure-over and pressure-under lines, pressures above and below the CRD piston will drop to zero, and the ball check valve will close the broken pressure-under line. RPV water flows from the annulus outside the CRD, through the RPV ports, and to the space below the drive piston. As in the case of pressure-over line breakage, the CRD inserts at a speed dependent on RPV pressure. Full insertion occurs regardless of the operational mode at the time of failure. RPV water leaks past the CRD seals and out the broken pressure-over line to the atmosphere, as described previously. CRD temperature increases. Indication in the MCR includes the drift alarm, the fully inserted CRD, an HCU high temperature alarm which comes from the CRD temperature recorder located in a local panel, and operation of the drywell sump pump.

### C. All CRD Flange Bolts Fail in Tension

Each CRD is bolted to a flange at the bottom of a CRD housing. The flange is welded to the CRD housing. Bolts are made of AISI-4140 steel, with a maximum tensile strength of 125,000 psi. Each bolt has an allowable load capacity of 15,200 lb. Capacity of the 8 bolts is 121,600 lb. As a result of the RPV design pressure of 1250 psig, the major load on all 8 bolts is 30,400 lb.

If a progressive or simultaneous failure of all bolts occurs, the CRD will separate from the housing. The control rod and the CRD are blown downward against the support structure. Impact velocity and support structure loading are slightly less

than that for CRD housing failure, because RPV pressure acts on the CRD cross-sectional area only and the housing remains attached to the RPV. The CRD is isolated from the cooling-water supply. RPV water flows downward past the velocity limiter piston, through the large CRD filter, and into the annular space between the thermal sleeve and the CRD. For worst-case leakage calculations, the large filter is assumed to be deformed or swept out of the way so it will offer no significant flow restriction. At a point near the top of the annulus, where pressure drops to 350 psi, the water flashes to steam and cause choke-flow conditions. Steam flows down the annulus and out the space between the housing and the CRD flanges to the atmosphere. Steam formation limits the leakage rate to ~ 840 gal/min.

If the collet is latched, control rod ejection is limited to the distance the CRD can drop before coming to rest on the support structure. There will be no tendency for the collet to unlatch, because pressure below the collet piston drops to zero. Pressure forces, in fact, exert 1435 lb to hold the collet in the latched position.

If the bolts fail during control rod withdrawal, pressure below the collet piston will drop to zero. The collet, with 1650-lb return force, latches and stops rod withdrawal.

#### D. Weld Joining Flange to Housing Fails in Tension

The failure considered is a crack in or near the weld that joins the flange to the housing. This crack will extend through the wall and completely around the housing. The flange material is forged, Type 304 stainless steel, with a minimum tensile strength of 75,000 psi. The housing material is seamless, Type 304 stainless-steel pipe, with a minimum tensile strength of 75,000 psi. The conventional full-penetration weld of Type 308 stainless steel has a minimum tensile strength approximately the same as that for the parent metal. The design pressure and temperature are 1250 psig and 575°F, respectively. RPV pressure acting on the cross-sectional area of the CRD; the weight of the control rod, CRD, and flange; and the dynamic reaction force during CRD operation result in a maximum tensile stress at the weld of ~ 6000 psi.

If the basic flange-to-housing joint failure occurs, the flange and the attached CRD are blown downward against the support structure. The support structure loading is slightly less than that for CRD housing failure because RPV pressure acts only on the CRD cross-sectional area. Lack of differential pressure across the collet piston causes the collet to remain latched and limit control rod motion to ~ 3 in. Downward CRD movement is small; therefore, most of the CRD remains inside the housing. The pressure-under and pressure-over lines are flexible enough to withstand the small displacement and remain attached to the flange. RPV water follows the same leakage path described above for the flange-bolt failure, except that exit to the atmosphere will be through the gap between the lower end of the housing and the top of the flange. Water flashes to steam in the annulus surrounding the CRD. The leakage rate is ~ 840 gal/min.



## HNP-2-FSAR-4

If the basic failure occurs during control rod withdrawal (a small fraction of the total operating time) and the collet is held unlatched, the flange will separate from the housing. The CRD and flange are blown downward against the support structure. The calculated steady-state rod-withdrawal velocity is 0.13 ft/s. Because pressure-under and pressure-over lines remain intact, driving water pressure to the CRD will continue, and the normal exhaust line restriction will exist. The pressure below the velocity limiter piston drops below normal as a result of leakage from the gap between the housing and the flange. This differential pressure across the velocity-limiter piston will result in a net downward force of ~ 70 lb. Leakage out of the housing greatly reduces the pressure in the annulus surrounding the CRD. Thus, the net downward force on the CRD piston is less than normal. The overall effect of these events reduces rod withdrawal to approximately one-half of normal speed. With a 560-psi differential across the collet piston, the collet remains unlatched; however, it should relatch as soon as the CRD signal is removed.

### E. Housing Wall Ruptures

This failure is a vertical split in the CRD housing wall just below the bottom head of the RPV. The flow area of the hole is considered equivalent to the annular area between the CRD and the thermal sleeve. Thus, flow through this annular area, rather than flow through the hole in the housing, governs leakage flow. The housing is made of Type 304 stainless-steel seamless pipe with a minimum tensile strength of 75,000 psi. The maximum hoop stress of 11,900 psi results primarily from the RPV design pressure (1250 psig) acting on the inside of the housing.

If such a rupture occurs, RPV water flashes to steam and leak through the hole in the housing to the atmosphere at ~ 1030 gal/min. Choke-flow conditions exist as described above for the flange-bolt failure. However, leakage flow is greater because flow resistance is less; that is, the leaking water and steam will not have to flow down the length of the housing to reach the atmosphere. A critical pressure of 350 psi causes the water to flash to steam.

No pressure differential across the collet piston tends to unlatch the collet, but the CRD inserts as a result of loss of pressure in the CRD housing, causing a pressure drop in the space above the CRD piston.

If the failure occurs during control rod withdrawal, CRD withdrawal is stopped by a reduction of the net downward force acting on the CRD line; however, the collet remains unlatched. The net force reduction occurs when the leakage flow of 1030 gal/min reduces the pressure in the annulus outside the CRD to ~ 540 psig, thereby reducing the pressure acting on top of the CRD piston to the same value. A pressure differential of ~ 710 psi will exist across the collet piston and hold the collet unlatched as long as the operator held the withdraw signal.

### F. Flange Plug Blows Out

To connect the RPV ports with the bottom of the ball check valve, a 3/4-in.-diameter hole is drilled in the CRD flange. The outer end of this hole is

## HNP-2-FSAR-4

sealed with a plug of 0.812-in. diameter, 0.250-in. thick. A full-penetration, Type 308 stainless-steel weld holds the plug in place. The postulated failure is a full circumferential crack in this weld and subsequent blowout of the plug.

If the weld fails, the plug blows out, and the collet remains latched. There is no control rod motion. There is no pressure differential across the collet piston acting to unlatch the collet. RPV water will leak past the velocity-limiter piston, down the annulus between the CRD and the thermal sleeve, through the RPV ports and drilled passage, and out the open plug hole to the atmosphere at ~ 320 gal/min. Leakage calculations assume only liquid flows from the flange. Actually, hot RPV water flashes to steam, and choke-flow conditions exist. Thus, the expected leakage rate is lower than the calculated value. Control rod temperature increases and initiates an alarm in the MCR.

If this failure occurs during control rod withdrawal and the collet stays unlatched, calculations indicate that control rod withdrawal speed will be ~ 0.24 ft/s. Leakage from the open plug hole in the flange will cause RPV water to flow downward past the velocity limiter piston. A small differential pressure across the piston will result in an insignificant driving force of ~ 10 lb, tending to increase withdraw velocity.

A pressure differential of 295 psi across the collet piston holds the collet unlatched as long as the driving signal is maintained.

Flow resistance of the exhaust path from the CRD is normal because the ball check valve is seated at the lower end of its travel by pressure under the CRD piston.

### G. CRD Pressure-Control Valve Closure (RPV Pressure, 0 psig)

The pressure to move a CRD is generated by the pressure drop of practically the full-system flow through the CRD pressure-control valve. This valve is motor operated and adjusted to a fixed opening. The normal pressure drop across this valve develops a pressure 250 psi in excess of RPV pressure.

If the flow through the CRD pressure-control valve is stopped, as by a valve closure or flow blockage, the CRD pressure increases to the shutoff pressure of the supply pump. The occurrence of this condition, during withdrawal of a CRD at zero RPV pressure, results in a CRD pressure increase from 250 psig to not more than 1700 psig. Calculations indicate that the drive will accelerate from 3 to ~ 6 in./s. A pressure differential of 1670 psi across the collet piston holds the collet unlatched. Flow is upward past the velocity limiter piston, but retarding force would be negligible. Rod movement stops as soon as the driving signal is removed.

### H. Ball Check Valve Fails to Close Passage to RPV Ports

Should the ball check valve sealing the passage to the RPV ports become dislodged and prevented from reseating following the insert portion of a CRD withdrawal sequence, water below the CRD piston returns to the RPV through the

RPV ports and the annulus between the CRD and the housing rather than through the speed-control valve. Because the flow resistance of this return path is lower than normal, the calculated withdrawal speed is 2 ft/s. During withdrawal, differential pressure across the collet piston is ~ 40 psi. Therefore, the collet tends to latch and has to stick open before continuous withdrawal at 2 ft/s could occur. Water flows upward past the velocity limiter piston, generating a small retarding force of ~ 120 lb.

I. HCU Valve Failures

Various failures of the valves in the HCU can be postulated, but none can produce differential pressures approaching those described in the preceding paragraphs, and none alone can produce a high-velocity withdrawal. Leakage through either one or both of the scram valves produces a pressure that tends to insert the control rod rather than to withdraw it. If the pressure in the SDV should exceed RPV pressure following a scram, a check valve in the line to the scram discharge header prevents this pressure from operating the CRD mechanism.

J. Collet Fingers Fail to Latch

When the CRD withdraw signal is removed, the drive continues to withdraw at a fraction of normal speed. Without some initiating signal, there is no known means for the collet fingers to become unlocked. If the withdrawal CRD valve fails to close following a rod withdrawal, it would have the same effect as failure of the collet fingers to latch in the index tube. Because the collet fingers remain locked until they are unloaded, accidental opening of the withdrawal CRD valve does not unlock them.

- K. Withdrawal Speed Control-Valve Failure Normal withdrawal speed is determined by differential pressures in the CRD and is set for a nominal value of 3 in/s. Withdrawal speed is maintained by the pressure-regulating system and is independent of RPV pressure. Tests have shown that accidental opening of the speed control valve to the full-open position produces a velocity of ~ 6 in./s.

The CRD system prevents rod withdrawal, and it has been shown above that only multiple failures in a CRD unit and in its control unit could cause an unplanned rod withdrawal.

**4.2.3.2.3.2 Scram Reliability.** High scram reliability is the result of a number of features of the CRD system. For example:

- A. Two sources of scram energy are used to insert each control rod when the reactor is operating, accumulator pressure and RPV pressure.
- B. Each drive mechanism has its own scram and pilot valves so only one drive can be affected if a scram valve fails to open. Two pilot valves are provided for each drive. Both pilot valves must be deenergized to initiate a scram.

- C. The RPS and the HCUs are designed so that the scram signal and mode of operation override all others.
- D. The collet assembly and index tube are designed so they do not restrain or prevent control rod insertion during scram.
- E. The SDV is monitored for accumulated water and scrams the reactor before the volume is reduced to a point that could interfere with a scram.
- F. An ARI system reduces the probability of occurrence of an ATWS event and provides the necessary signals in response to an ATWS event or manual initiation to depressurize the CRD scram pilot valve air header through valves that are different from the RPS scram valves, providing a parallel path for initiating control rod insertion.

**4.2.3.2.3.3 Analysis of BWR Scram System Pipe Breaks.** A generic evaluation of the applicability of postulated breaks in the BWR scram system, which includes an estimate of the probability of occurrence of the postulated sequences of events and the bases for the conclusions, was performed. A generic evaluation of the applicability of the AEOD report relative to BWR plant construction, design, and operation, and a generic evaluation of the AEOD recommendations were performed. The results of the evaluation are in Topical Report NEDE-24342, "GE Evaluation in Response to NRC Request Regarding BWR Scram System Pipe Breaks".<sup>(23)</sup> This conclusion is based upon the following:

- A. The postulated accident is very unlikely due to the GE design and installation specifications, as well as the specified QA requirements. Specifications require the piping system be designed for high pressure and temperature, even though the systems are only exposed to this environment 1% of the time. No scram discharge piping system at any reactor has ruptured in over 20 years of reactor operation.
- B. GE analysis of the probability of this sequence of events resulted in a postulated pipe break of  $< 10^{-7}$  per reactor year. This places the frequency beyond the range of events that is taken into account in the design of nuclear facilities.
- C. Even if a break occurs, alarms and resulting normal inspection by the operating staff will clearly indicate leakage of water, detectable radiation level in the reactor building, and a measurable water level in the reactor building sump. Current procedures provide the operator sufficient guidance to depressurize the reactor; thus, leakage of coolant would be under control to preclude any damage.
- D. Additional pumps that are not part of the ECCS are also available to provide more than sufficient water supply, even if all the ECCS pumps fail to operate.

In summary, the consequences of the small-break LOCA, as a result of a postulated SDV pipe rupture, are well within the mitigation capabilities of the normal and emergency cooling systems. Also, the potential for a SDV pipe rupture and the potential for

unacceptable consequences resulting from a postulated SDV pipe rupture are  $< 1 \times 10^{-7}$  events per year.

**4.2.3.2.3.4 Control Rod Support and Operation.** As described previously, each control rod is independently supported and controlled as required by safety design bases.

#### **4.2.3.2.4 Tests and Inspections**

**4.2.3.2.4.1 Operational Tests.** After installation, all rods and CRD mechanisms can be tested through their full stroke for operability.

During normal operation, each time a control rod is withdrawn a notch, the operator can observe the incore monitor indications to verify that the control rod is following the CRD mechanism. All control rods that are partially withdrawn from the core can be tested for rod following by inserting or withdrawing the rod one notch and returning it to its original position while the operator observes the incore monitor indications.

To make a positive test of control rod-to-CRD coupling integrity, the operator can withdraw a control rod to the end of its travel and then attempt to withdraw the CRD to the overtravel position. Failure of the CRD to overtravel demonstrates rod-to-drive coupling integrity.

Hydraulic supply subsystem pressures can be observed from instrumentation in the MCR. Scram accumulator pressures can be observed on the nitrogen pressure gauges.

**4.2.3.2.4.2 Surveillance Tests.** The surveillance requirements for the CRD system are:

- A. Sufficient control rods are withdrawn, following a refueling outage when core alterations are performed, to demonstrate that the core can be made subcritical at any time in the subsequent fuel cycle with the strongest operable control rod fully withdrawn and all other operable rods fully inserted. This can be demonstrated analytically with a shutdown margin of 0.38%  $\Delta k/k$ , using data derived from measurements made at the beginning of each cycle during normal in-sequence rod pulls. Alternately, this can be demonstrated by actual test, in which case, the value of the shutdown margin must be  $\geq 0.28\% \Delta k/k$  throughout the cycle.
- B. Each fully withdrawn control rod is exercised one notch at least once each week when above the preset power level of the rod worth minimizer (RWM). Each partially withdrawn control rod is exercised once every 31 days when above the preset power level of the RWM. In the event that one or more control rods become incapable of insertion, each operable partially and fully withdrawn control rod must be exercised within 24 h.

These control rod exercises serve as a periodic check against deterioration of the control rod system. The tests also verify the ability of CRDs to scram because, if a

rod can be moved with CRD pressure, it will surely insert when subjected to the higher pressure applied during a scram. This further assures the reliability of the remaining control rods.

- C. The coupling integrity is verified for each withdrawn control rod as follows:

Each time a control rod is withdrawn to the full-out position and prior to declaring the control rod operable after work on the control rod or any work on the CRD system that could affect the coupling, a coupling check is performed by verifying that the control rod does not go to the overtravel position.

The overtravel position feature provides a positive check on the coupling integrity, since only an uncoupled CRD can reach the overtravel position.

- D. During operation, accumulator pressure and level at the normal operating value are verified.

Experience with CRD systems of the same type indicates that weekly verification of accumulator pressure and level is sufficient to ensure operability of the accumulator portion of the CRD system.

- E. During each major refueling outage, each operable control rod is subjected to scram time tests from the fully withdrawn position.

Experience indicates that the scram times of the control rods do not significantly change over the time interval between refueling outages. A test of the scram times at each refueling outage is sufficient to identify any significant lengthening of the scram times.

- F. Float chamber water level activation of the six liquid level switches in the SDV is performed on a frequency corresponding to the refueling frequency, as part of a channel functional test and a logic system functional test.

**4.2.3.2.4.3 Instrumentation.** The general functional requirements for the CRD are discussed in paragraph 4.2.3.1.5.

#### **4.2.3.3 Supplementary Reactivity Control**

Refer to section 3.2.4.2 of *NEDE-24011-P-A (GESTAR II)*.

#### **4.2.3.4 SLCS**

##### **4.2.3.4.1 Design Bases**

The SLCS meets the following safety design bases:

- A. Backup capability for reactivity control is provided, independent of normal reactivity control provisions in the nuclear reactor, to be able to shut down the reactor if normal control ever becomes inoperative.
- B. The backup system has the capacity for controlling the reactivity difference between the steady-state-rated operating condition of the reactor with voids and the cold shutdown condition, including shutdown margin, to ensure complete shutdown from the most reactive condition at any time in core life.
- C. The time required for actuation and effectiveness of the backup control is consistent with the nuclear reactivity rate of change predicted between rated operating and cold shutdown conditions. A fast scram of the reactor or operational control of fast reactivity transients is not specified to be accomplished by this system.
- D. Means are provided by which the functional performance capability of the backup control system components can be verified periodically under conditions approaching actual use requirements. Demineralized water, rather than the actual neutron absorber solution, can be injected into the reactor to test the operation of all components of the redundant control system.
- E. The neutron absorber is dispersed within the reactor core in sufficient quantity to provide a reasonable margin for leakage or imperfect mixing.
- F. The system is reliable to a degree consistent with its role as a special safety system; the possibility of unintentional or accidental shutdown of the reactor by this system is minimized.

##### **4.2.3.4.2 Description**

The SLCS (HNP-1 drawing nos. H-16061 and H-19926, and HNP-2 drawing no. H-26009) is manually initiated from the MCR to pump a boron neutron absorber solution into the reactor if the operator believes the reactor cannot be shut down or kept shut down with the control rods.

The SLCS is required only to shut down the reactor and keep the reactor from going critical again as it cools.

## HNP-2-FSAR-4

The SLCS is used only in the highly improbable event that not enough control rods can be inserted in the reactor core to accomplish shutdown and cooldown in the normal manner. SLCS is required for postulated ATWS events by the Emergency Operating Procedures (EOPs) when it is determined that the reactor cannot be shut down prior to suppression pool temperature reaching the boron injection initiation temperature (BIIT).

The BIIT is a limit defined by appendix B and calculated by appendix C of the Revision 4 Emergency Procedure Guidelines (references 13 and 14). BIIT is identified in the EOPs.

Inhibiting the ADS during an ATWS event can mitigate the event, because RPV water level can be lowered to enhance the effectiveness of the SLCS in shutting down the reactor. This mode of operation is described in HNP-1-FSAR paragraph 7.4.3.1 and HNP-2-FSAR paragraph 7.3.1.2.2.

The boron solution tank, test water tank, the two positive displacement pumps, the two explosive valves, and associated local valves and controls are mounted in the reactor building. The solution is piped into the RPV and discharged near the bottom of the core shroud, so it mixes with the cooling water rising through the core (subsection 4.2.2).

The boron-10 isotope absorbs thermal neutrons and, thereby, terminates the nuclear fission chain reaction in the uranium fuel. The boron-10 isotope makes up ~ 19.8 atomic percent of naturally occurring boron. The boron used is enriched to at least 60-atomic percent boron-10 isotope.

The specified neutron absorber solution is sodium pentaborate ( $\text{Na}_2\text{B}_{10}\text{O}_{16}10\text{H}_2\text{O}$ ), which is prepared by dissolving granular-enriched sodium pentaborate in demineralized water. A sparger is provided in the tank for mixing, using air. To prevent system plugging, the tank outlet is located above the bottom of the tank.

Whenever it is possible to make the reactor critical, the SLCS is able to deliver at least a 6.9% solution of 60-atomic percent boron-10 enriched sodium pentaborate into the reactor to ensure reactor shutdown. Figure 4.2-15 shows the allowable region of operation for solution concentration and volume.

Storage tank solution temperature is maintained by adjusting the storage tank heater-indicating controller to maintain temperature between 65°F and 75°F to prevent precipitation of the sodium pentaborate from solution. Thermostat controlled heat tracing is run along the pump suction piping to maintain suction piping solution temperature. Figure 4.2-16 shows the minimum specified borate solution temperature to ensure that the boron remains in solution and does not precipitate out in the storage tank or in the pump suction piping. The temperature versus concentration curve of figure 4.2-16 ensures a 10°F margin will be maintained above the saturation temperature. A temperature switch located in the suction line will actuate a low-solution temperature alarm in the MCR. Storage tank high or low temperature, and high or low liquid level actuate MCR alarms. Tank level is also indicated in the MCR.



## HNP-2-FSAR-4

Each positive displacement pump is sized to inject the solution into the reactor in 30 to 90 min (~ 43 gal/min), depending on the amount of solution in the tank. The pump and system design pressure between the explosive valves and the pump discharge is 1400 psig. The two relief valves are set slightly under 1400 psig to exceed the RPV operating pressure by a sufficient margin to avoid valve leakage. The relief valves are installed with the discharge lines flooded to prevent evaporation and precipitation within the valve. To prevent bypass flow from one pump, in case of relief valve failure in the line from the other pump, a check valve is installed downstream of each relief valve line in the pump discharge pipe.

The two explosive-actuated injection valves assure opening, when needed, and ensure boron does not leak into the reactor even when the pumps are being tested. Each explosive valve is closed by a plug in the inlet chamber. The plug is circumscribed with a deep groove so the end readily shears off when pushed with the valve plunger. This opens the inlet hole through the plug. The sheared end is pushed out of the way in the chamber; it is shaped so it does not block the ports after release.

The shearing plunger is actuated by an explosive charge with dual ignition primers inserted in the side chamber of the valve. Ignition circuit continuity is monitored by a trickle current, and an alarm occurs in the MCR if either circuit opens. Indicator lights show which primer circuit opened. To service a valve after firing, a 6-in. length of pipe (spool piece) must be removed immediately upstream of the valve to gain access to the shear plug. The SLCS is actuated by a three-position keylocked switch on the MCR console. This ensures that switching from the off position is a deliberate act. Switching to either side starts an injection pump, actuates both of the explosive valves, and closes the RWC system outboard isolation valve to prevent loss or dilution of the boron.

A green light in the MCR indicates that power is available to the pump motor contactor and that the contactor is open (pump not running). A red light indicates that the contactor is closed (pump running).

If the storage tank level, pump lights, pump discharge pressure, or explosive valve lights indicate that liquid may not be flowing, the operator can immediately turn the switch to the other side, which actuates the alternate pump. Cross-piping and check valves ensure a flow path through either pump and either explosive valve. The selected pump starts even though its local switch at the pump is in the STOP position for test or maintenance. Pump discharge pressure indication is also provided in the MCR.

Equipment drains and tank overflow are piped either to a chemical waste drain or to separate containers (such as 55-gal drums) in an effort to prevent boron from reaching the RPV. Although not a safety concern, it is undesirable for boron to reach the RPV due to the effect on reactor power level. The potential for such an occurrence is eliminated if the liquid is routed to separate containers (such as 55-gal drums). If the liquid is routed to a chemical waste drain, it is either filtered (and neutralized, as required) prior to dilution and discharge from the plant or filtered (and neutralized, as required) prior to being treated by an ion exchange and returned to the CST. If the chemical waste is discharged, the potential for boron to enter the reactor vessel is eliminated. If the chemical waste is treated and returned to the CST, a small potential exists for trace amounts of boron to enter the RPV. Such an occurrence requires the use of the RWC system for mitigation.

Instrumentation consisting of solution temperature indication and control, tank level, and heater system status is provided locally at the storage tank.

#### 4.2.3.4.3 Safety Evaluation

The SLCS is a reactivity control system and is maintained in a STANDBY operational status whenever it is permissible for the reactor to be critical. The system is expected never to be needed for safety reasons because of the large number of independent control rods available to shut down the reactor.

However, to ensure availability of the SLCS, two sets of the components required to actuate the system (pumps and explosive valves) are provided in parallel redundancy.

The SLCS is designed to bring the reactor from rated power to a cold shutdown at any time in core life. The reactivity compensation provided reduces reactor power from rated to zero level and permits cooling the nuclear system to room temperature, with the control rods remaining withdrawn in the rated power pattern. It includes the reactivity gains that result from complete decay of the rated power xenon inventory. It also includes the positive reactivity effects from eliminating steam voids, changing water density from hot to cold, reduced Doppler effect in uranium, reducing neutron leakage from boiling to cold, and decreasing control rod worth as the moderator cools.

The specified minimum average concentration of natural boron in the reactor to provide the specified shutdown margin, after operation of the SLCS, is 660 ppm. Calculation of the minimum quantity of sodium pentaborate to be injected into the reactor is based on the required 660-ppm average concentration in the reactor coolant, including recirculation loops, the RHR system in the shutdown cooling mode at 70°F, and RPV normal water level. The result is increased by 25% to allow for imperfect mixing and leakage and to account for the volume in other small piping connected to the reactor.

In addition to meeting the required concentration of 660-ppm natural boron in the reactor, the SLCS also meets the injection rate requirements of 10 CFR 50.62(c)(4), which requires that the system have a control capacity equivalent to that of a system with an injection rate of 86 gal/min of 13 weight percent solution, normalized to a 251-in. diameter RPV. The control capacity of the SLCS refers to the rate at which boron-10 isotopes are injected into the reactor. The SLCS meets the requirements of 10 CFR 50.62(c)(4) by using a sodium pentaborate solution enriched with at least 60-atomic percent boron-10 isotope. Naturally occurring boron contains ~ 19.8% of the boron-10 isotope. The method used to show equivalence to 10 CFR 50.62 is set forth in reference 10.

In figure 4.2-15, the 6.9% minimum concentration limit ensures that the SLCS can meet the injection rate requirements of 10 CFR 50.62. The curve showing the minimum volume versus concentration limit ensures that the SLCS can provide a minimum boron-10 isotope concentration in the reactor equivalent to 660 ppm of natural boron, plus 150-ppm margin. The sodium pentaborate solution temperature versus concentration curve shown in figure 4.2-16 ensures a 10°F margin will be maintained above the solution saturation temperature. The 6.9% concentration limit is also identified on this curve. Additionally, Region B, which is outside

## HNP-2-FSAR-4

10 CFR 50.62 limits, is identified on both curves. Region B corresponds to the original licensing basis limits. If Region A limits are not met, the Technical Specifications allow brief (72 h) operation in Region B.

The 150-ppm margin of natural boron concentration is provided to compensate for any dilution that may occur due to leakage of borated solution from the reactor and replacement with water that is not borated. This margin is adequate to assure minimum boron concentration in the reactor for a period of ~ 24 h after initiation of shutdown. During this 24-h period, an additional charge of sodium pentaborate solution can be prepared in the SLC tank for injection into the reactor if the shutdown period should extend beyond 24 h.

The 24-h time period was determined based upon the following:

- A. Boron injection rate into the reactor is at a conservatively low rate of 8 ppm/min (based upon natural boron concentration in the reactor).
- B. Leakage flow from the reactor is continuous and at the rate of 50 gal/min at 1000-psig reactor operating pressure.
- C. The system is required to shut down the reactor from full power and maintain the reactor subcritical with at least a 0.03- $\Delta$ k margin.

Cooling down of the nuclear system requires a minimum of several hours to remove the thermal energy stored in the reactor, cooling water, and associated equipment and to remove most of the radioactivity decay heat. The controlled limit for the RPV cooldown is 100°F/h, and normal operating temperature is ~ 550°F. Use of the main condenser and various shutdown cooling systems requires 10 to 24 h to lower the RPV to room temperature (70°F).

The SLCS equipment essential for injection of neutron absorber solution into the reactor is designed as Seismic Category I for withstanding the specified earthquake loadings (HNP-1-FSAR subsection 2.5.7 and HNP-2-FSAR chapter 3). Nonprocess equipment such as the test tank is not Seismic Category I. The system piping and equipment are designed, installed, and tested in accordance with requirements given in HNP-1-FSAR appendix A and HNP-2-FSAR chapter 3.

The SLCS is required to be operable in the event of an offsite power failure. Therefore, the pumps, heaters, valves, and controls are powered from the standby ac power supply. The pumps and valves are powered and controlled from separate buses and circuits so that a single active failure does not prevent system operation.

The SLCS and pumps have sufficient pressure margin, up to the system relief valve setting of ~ 1400 psig, to ensure solution injection into the reactor above the normal pressure in the bottom of the reactor. The nuclear system relief and safety valves begin to relieve pressure at setpoints listed in HNP-1-FSAR table 4.11-1 and HNP-2-FSAR table 5.2-4. Therefore, the SLCS positive displacement pumps cannot overpressurize the nuclear system.

Only one of the two SLCS pumps is needed for system operation. If one pump becomes inoperable, there is no immediate threat to shutdown capability, and reactor operation can

continue during repairs. The time during which one redundant component upstream of the explosive valves may be out of operation should be consistent with the probability of failure of both the control rod shutdown capability and the alternative component in the SLCS, and the fact that nuclear system cooldown takes several hours, while liquid control solution injection takes ~ 1 h. Since this probability is small, considerable time is available for repairing and restoring the SLCS to an operable condition while reactor operation continues. Assurance that the system still fulfills its function during repairs is obtained by demonstrating operation of the operable pump.

The SLCS was evaluated for the increase in rated thermal power to 2804 MWt and reactor operating pressure increase from 1050 psia to 1060 psia.<sup>(24) (25)</sup> The ability of the SLCS boron solution to achieve and maintain safe shutdown is not a direct function of core thermal power and reactor vessel pressure; therefore, it is not affected by power uprate.

The SLCS is designed for injection at a maximum RPV pressure equal to the SRV upper analytical pressure, plus system flow and head losses. The SLCS pumps are positive displacement pumps that deliver a constant flowrate regardless of discharge pressure. Therefore, the capability of the SLCS to provide its backup shutdown function is not affected by the SRV mechanical relief setpoint increase. Also, the resulting increase in system operating pressure does not reduce the SLCS pump relief valve pressure margin below recommended levels.

#### **4.2.3.4.4 Tests and Inspections**

Operational testing of the SLCS is performed in at least two parts to avoid inadvertently injecting boron into the reactor. With the valves from the storage tank and to the reactor closed and the three valves to and from the test tank opened, demineralized water in the test tank can be recirculated by locally starting either pump.

During a refueling or maintenance outage, the injection portion of the system can be functionally tested by valving the suction lines to the test tank and actuating the system from the MCR. Both injection valves open on actuation. System operation is indicated in the MCR.

After functional tests, the injection valve shear plugs and explosive charges must be replaced and all the valves returned to their normal positions as indicated on HNP-1 drawing no. H-16061 and HNP-2 drawing no. H-26009.

After closing a local locked-open valve to the reactor, leakage through the injection valves can be determined by opening valves at a test connection in the line between the containment isolation check valves. Position-indicator lights in the MCR indicate that the local valve is closed for tests or open and ready for operation. Leakage from the reactor through the first check valve can be detected by opening the same test connection when the reactor is pressurized.

The test tank contains demineralized water for ~ 3 min of pump operation. Demineralized water from the makeup system or the condensate storage system is available for refilling or flushing the system.

## HNP-2-FSAR-4

Should the boron solution ever be injected into the reactor (either intentionally or inadvertently), after making certain that the normal reactivity controls keep the reactor subcritical, the boron is removed from the reactor coolant system by flushing for gross dilution followed by operating the RWC system (subsection 5.5.8).

The concentration of the sodium pentaborate in the solution tank is determined periodically by chemical analysis. This analysis must be performed any time sodium pentaborate or water is added to the storage tank to verify concentration is within Region A limits of figures 4.2-15 and 4.2-16.

### **4.2.3.4.5 Instrumentation**

The instrumentation and control system for the SLCS is designed to allow the injection of liquid poison into the reactor and the maintenance of the liquid poison solution well above the saturation temperature. Discussion of the SLCS instrumentation is included in HNP-1-FSAR paragraph 7.3.4.8 and HNP-2-FSAR subsection 7.4.2.

**DOCUMENTS INCORPORATED BY REFERENCE INTO THE FSAR**

***"GESTAR II - General Electric Standard Application for Reactor Fuel," NEDE-24011-P-A.***

REFERENCES

1. "Design and Performance of GE BWR Jet Pumps," APED-5460, July 1968.
2. Moen, R. H., "Testing of Improved Jet Pumps for the BWR/6 Nuclear System," NEDO 10602, June 1972.
3. Slifer, B. C., "Loss-of-Coolant Accident and Emergency Core Cooling Models for General Electric Boiling Water Reactors," NEDO-10329, April 1971.
4. "Control Blade Examination Results and Response to Item 4 of IE Bulletin 79-26," NEDO-24325, March 1981.
5. Brayman, K. W., and Cook, K. W., "Evaluation of Control Blade Lifetime With Potential Loss of B<sub>4</sub>C," NEDE-24226-P (Proprietary) and NEDO-24226, December 1979; NEDE-24226-1-P (Proprietary).
6. Brayman, K. W., and Cook, K. W., "Control Blade Lifetime Evaluations Accounting for Potential Loss of B<sub>4</sub>C," NEDO-24232, January 1980.
7. "Boron Loss from BWR Control Blades," IE Bulletin No. 79-26, Rev. 1, USNRC Office of Inspection and Enforcement, Washington, D.C., August 29, 1980.
8. "Safety Evaluation of the General Electric Hybrid I Control Rod Assembly," NEDE-22290-A, September 1983.
9. (Deleted)
10. "Anticipated Transients without Scram Response to NRC ATWS Rule, 10 CFR 50.62," NEDE-31096-P, December 1985.
11. "Safety Evaluation of the General Electric Advanced Longer Life Control Rod Assembly," NEDE-22290-A, Supplement 2, August 1985.
12. "Safety Evaluation of the General Electric Duralife 230 Control Rod Assembly," NEDE-22290-P-A, Supplement 3, May 1988.
13. "BWR Owners' Group Emergency Procedure Guidelines," Volume II, Appendix B, OEI Document 8390-4.
14. "Edwin I. Hatch Nuclear Plant Units 1 and 2 Emergency Procedure Guidelines Calculations," Calculation NPSH89-040, WS-1.

HNP-2-FSAR-4

15. "Extended Power Uprate Safety Analysis Report for Edwin I. Hatch Plant Units 1 and 2," NEDC-32749P, General Electric Company, July 1997.
16. "Safety Review for Edwin I. Hatch Nuclear Power Plant Units 1 and 2 Updated Safety/Relief Valve Performance Requirements, NEDC-32041P, General Electric Company, April 1996.
17. Letter EF2-16969, Heidel, C.M. (Detroit Edison) to Giambusso, A. (AEC), dated May 9, 1973.
18. Letter EF2-21952, Heidel, C.M. (Detroit Edison) to Giambusso, A. (AEC), dated February 14, 1974.
19. Benecki, J. E., " Impact Testing on Collet Assembly for Control Rod Drive Mechanism 7RD B144A," APED-5555, November 1967.
20. "Supplemental Information for Plant Modifications to Eliminate Significant In-Core Vibrations," NEDO-21156.
21. "BWR Channel Mechanical Design and Deflections," NEDP-21354 and Amendments 1 and 2, September 1976.
22. "Peach Bottom Atomic Power Station Units 2 and 3 Safety Analysis Report for Plant Modifications to Eliminate Significant In-Core Vibrations," NEDO-20994, September 1975.
23. "GE Evaluation in Response to NRC Request Regarding BWR Scram System Pipe Breaks," NEDE-24342.
24. NRC Safety Evaluation and GENE Technical Evaluation: "GE Marathon Control Rod Assembly," NEDE-31758P-A, October 1991.
25. "Marathon Control Rod," interface control drawing 107E1422 Revision 6, dated 12/23/2003.
26. WCAP-16182-P-A, "Westinghouse BWR Control Rod CR 99 Licensing Report, March 2005.
27. NRC Letter, H. Berkow (NRC) to J. Gresham (Westinghouse), "Final Safety Evaluation for Topical Report WCAP-16182-P, 'Westinghouse BWR Control Rod CR 99 Licensing Report,' (TAC No. MC 1644), " September 21, 2004.
28. CENPD-390-P-A. "The Advanced PHOENIX and POLCA Codes for Nuclear Design of Boiling Water Reactors," December 2000.
29. NRC Letter, S. Richards to I. Rickard, "Acceptance for Referencing of CENPD-390-P, 'The Advanced PHOENIX and POLCA Codes for Nuclear Design of Boiling Water Reactors,' (TAC No. MA5659)", July 24, 2000.

HNP-2-FSAR-4

30. CENPD-287-PA, "Fuel Assembly Mechanical Design Methodology for Boiling Water Reactors," July 1996.
31. WCAP-15942-P-A, "Fuel Assembly Mechanical Design Methodology for Boiling Water Reactors Supplement 1 to CENP-287," March 2006.
32. Westinghouse Report NF-BSN-10-10, "Supplemental Licensing Report, SVEA-96 Optima2 Lead Use Fuel Assemblies for Edwin I. Hatch Nuclear Plant, Unit 1," Revision 0, February 2010.



**TABLE 4.2-1**  
**DEFORMATION LIMIT**  
**(FOR REACTOR INTERNAL STRUCTURES ONLY)**  
**(HNP-1 AND HNP-2)**

| <u>Either One of (Not Both)</u>                                                                                                | <u>General Limit</u>         |
|--------------------------------------------------------------------------------------------------------------------------------|------------------------------|
| $\left( \frac{\text{Permissible deformation (DP)}}{\text{Analyzed deformation causing loss of function}} \right)$              | $\leq \frac{0.9}{SF_{\min}}$ |
| $\left( \frac{\text{Permissible deformation (DP)}}{\text{Experiment deformation causing loss of function (DE)}} \right)^{(a)}$ | $\leq \frac{1.0}{SF_{\min}}$ |

where:

- DP = permissible deformation under stated conditions of normal, upset, emergency, or fault.
- DL = analyzed deformation which could cause a system loss of function.<sup>(b)</sup>
- DE = experimentally determined deformation which could cause a system loss of function.

---

a. The second equation is not used unless supporting data are provided to the NRC.

b. Loss of function can be defined only quite generally until attention is focused on the component of interest. In cases of interest, where deformation limits can affect the function of equipment and components, they will be specifically delineated. From a practical viewpoint, it is convenient to interchange some deformation condition at which function is ensured with the loss-of-function condition if the required safety margins from the functioning conditions can be achieved. Therefore, it is often unnecessary to determine the actual loss-of-function condition because this interchange procedure produces conservative and safe designs. Examples where deformation limits apply are control rod drive alignment and clearances for proper insertion, core support deformation causing fuel disarrangement, or excess leakage of any component.

TABLE 4.2-2 (SHEET 1 OF 2)

**PRIMARY STRESS LIMIT  
(FOR REACTOR INTERNAL STRUCTURES ONLY)  
(HNP-1 AND HNP-2)**

| <u>Any One Of (Not More Than One Required)</u>                                                                                                  | <u>General Limit</u>               |
|-------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------|
| $\left( \frac{\text{Elastic evaluated primary stresses (PE)}}{\text{Permissible primary stresses (PN)}} \right)$                                | $\leq \frac{2.25}{SF_{\min}}$      |
| $\left( \frac{\text{Permissible load (LP)}}{\text{Largest lower bound limit load (CL)}} \right)$                                                | $\leq \frac{1.5}{SF_{\min}}$       |
| $\left( \frac{\text{Elastic evaluated primary stress (PE)}}{\text{Conventional ultimate strength at temperature (US)}} \right)$                 | $\leq \frac{0.75}{SF_{\min}}$      |
| $\left( \frac{\text{Elastic-plastic evaluated nominal primary stress (EP)}}{\text{Conventional ultimate strength at temperature (US)}} \right)$ | $\leq \frac{0.9}{SF_{\min}}$       |
| $\left( \frac{\text{Permissible load (LP)}}{\text{Plastic instability load (PL)}} \right)^{(a)}$                                                | $\leq \frac{0.9}{SF_{\min}}$       |
| $\left( \frac{\text{Permissible load (LP)}}{\text{Ultimate load from fracture analysis (UF)}} \right)^{(a)}$                                    | $\leq \frac{0.9}{SF_{\min}}$       |
| $\left( \frac{\text{Permissible load (LP)}}{\text{Ultimate load or loss-of-function load from test (LE)}} \right)^{(a)}$                        | $\leq \frac{1.0}{SF_{\min}}^{(b)}$ |
|                                                                                                                                                 | $\leq \frac{0.9}{SF_{\min}}^{(c)}$ |

where:

- PE = primary stresses evaluated on an elastic basis. The effective membrane stresses are to be averaged through the load-carrying section of interest. The simplest average bending, shear, or torsion stress distribution which support the external loading are added to the membrane stresses at the section of interest.
- PN = permissible primary stress levels under normal or upset conditions under ASME Boiler and Pressure Vessel Code, Section III.
- LP = permissible load under stated conditions of normal, upset, emergency, or faulted.
- CL = lower bound limit load with yield point equal to 1.5 S<sub>m</sub> where: S<sub>m</sub> = the tabulated value of allowable stress at temperature of the ASME Code, Section III, or its equivalent. The "lower bound limit load" is defined as that produced from the analysis of an

**TABLE 4.2-2 (SHEET 2 OF 2)**

ideally plastic (nonstrain hardening) material where deformation increases with no further increase in applied load. The lower-bound load is one in which the material everywhere satisfies equilibrium and nowhere exceeds the defined material yield strength, using either a shear theory or a strain energy-of-distortion theory to relate multiaxial yield to the uniaxial case.

- US = conventional ultimate strength at temperature of loading that will cause a system malfunction, whichever is more limiting.
- EP = Elastic-plastic-evaluated nominal primary stress. Strain hardening of the material may be used for the actual monotonic stress-strain curve at the temperature of loading, or any approximation to the actual stress-strain curve that everywhere has a lower stress for the same strain as the actual monotonic curve may be used. Either the shear or strain-energy-of-distortion flow rule may be used.
- PL = plastic instability load. The plastic instability load is defined here as the load at which any load-bearing section begins to diminish its cross-sectional area at a faster rate than the strain hardening can accommodate the loss in area. This type of analysis requires a true stress-true strain curve or a close approximation based on monotonic loading at the temperature of loading.
- UF = ultimate load from fracture analyses. For components that involve sharp discontinuities (local theoretical stress concentration  $< 3$ ) the use of a fracture-mechanics analysis where applicable, using measurements of plain strain fracture toughness, may be applied to compute fracture loads. Correction for finite plastic zones and thickness effects as well as gross yielding may be necessary. The methods of linear elastic stress analysis may be used in the fracture analysis where its use is clearly conservative or supported by experimental evidence. Examples where "fracture mechanics" may be applied are for fillet welds or end-of-fatigue-life crack propagation.
- LE = ultimate load or loss-of-function load as determined from experiment. In using this method, account is taken of the dimensional tolerances which may exist between the actual part and the test part or parts as well as differences which may exist in the ultimate tensile strength of the actual part and the tested parts. The guide to be used in each of these areas is that the experimentally determined load shall use adjusted values to account for material property and dimension variations, each of which has no greater probability than 0.1 of being exceeded in the actual part.

- 
- a. This equation is not used unless supporting data are provided to the NRC.  
 b. HNP-2 only.  
 c. HNP-1 only.

**TABLE 4.2-3**  
**BUCKLING STABILITY LIMIT**  
**(FOR REACTOR INTERNAL STRUCTURES ONLY)**  
**(HNP-1 AND HNP-2)**

| <u>Any One Of (Not More Than One Required)</u>                                                       | <u>General Limit</u>          |
|------------------------------------------------------------------------------------------------------|-------------------------------|
| $\left( \frac{\text{Permissible load (LP)}}{\text{Code normal event permissible load (PN)}} \right)$ | $\leq \frac{2.25}{SF_{\min}}$ |
| $\left( \frac{\text{Permissible load (LP)}}{\text{Stability analysis load (SL)}} \right)$            | $\leq \frac{0.9}{SF_{\min}}$  |
| $\left( \frac{\text{Permissible load (LP)}}{\text{Ultimate buckling collapse}} \right)^{(a)}$        | $\leq \frac{1.0}{SF_{\min}}$  |

where:

- LP = permissible load under stated conditions of normal, upset, emergency, or faulted.
- PN = applicable code normal event permissible load.
- SL = stability analysis load. The ideal buckling analysis is often sensitive to otherwise minor deviations from ideal geometry and boundary conditions. These effects are accounted for in the analysis of the buckling stability loads. Examples of this are ovality in externally pressurized shells or eccentricity on column members.
- SE = ultimate buckling collapse load as determined from experiment. In using this method, account is taken of the dimensional tolerances which may exist between the actual part and the tested part. The guide to be used in each of these areas is that the experimentally determined load is adjusted to account for material property and dimension variations, each of which has no greater probability than 0.1 of being exceeded in the actual part.

a. This equation is not used unless supporting data are provided to the NRC.

**TABLE 4.2-4**  
**FATIGUE LIMIT**  
**(FOR REACTOR INTERNAL STRUCTURES ONLY)**  
**(HNP-1 AND HNP-2)**

Summation of fatigue damage usage with design and operation loads  
following the Miner hypotheses<sup>(a)</sup>

| <u>Any One Of (Not More Than One Required)</u>                            | <u>Limit for Normal and Upset Design Conditions</u> |
|---------------------------------------------------------------------------|-----------------------------------------------------|
| Mean fatigue <sup>(b)(c)</sup> cycle usage from analysis                  | ≤ 0.05                                              |
| Mean fatigue <sup>(b)(c)</sup> cycle usage from test                      | ≤ 0.33                                              |
| Design fatigue cycle usage from analysis, using the method of table 4.2-2 | ≤ 1.0 <sup>(d)</sup>                                |

a. Miner, M. A., "Cumulative Damage in Fatigue," Journal of Applied Mechanics, Vol. 12, ASME, Vol. 67, pp A159-A164, September 1945.


b. Fatigue failure is defined here as a 25% area reduction for a load-carrying member that is required to function, or excess leakage, whichever is more limiting.

c. The first two equations are not used unless supporting data are provided to the NRC.

d. HNP-2 only.

TABLE 4.2-5 (SHEET 1 OF 3)

**CORE SUPPORT STRUCTURES STRESS CATEGORIES AND LIMITS OF STRESS INTENSITY FOR NORMAL AND UPSET CONDITIONS (HNP-2)**



**TABLE 4.2-5 (SHEET 2 OF 3)**

- a. The symbols  $P_m$ ,  $P_b$ ,  $Q$ , and  $F$  do not represent single quantities, but rather sets of six quantities representing the six stress components  $\sigma_t$ ,  $\sigma_1$ ,  $\sigma_r$ ,  $\tau_{t1}$ ,  $\tau_{1r}$ , and  $\tau_{rt}$ .
- b. For configurations where compressive stresses occur, the stress limits are revised to take into account critical buckling stresses. (See paragraph NB-3211 (c) of ASME Code, Section III.) For external pressure, the permissible equivalent static external pressure is as specified by the rules of paragraph NB-3133 of ASME Code, Section III. Where dynamic pressures are involved, the permissible external pressure is limited to 25% of the dynamic instability pressure.
- c. When loads are transiently applied, consideration is given to the use of dynamic load amplification and possible change in modulus of elasticity.
- d. The stresses in category  $Q$  are those parts of the total stress which are produced by thermal gradients, structural discontinuities, etc., and do not include primary stresses which may also exist at the same point. It should be noted, however, that a detailed stress analysis frequently gives the combination of primary and secondary stresses directly, and, when appropriate, this calculated value represents the total of  $P_m + P_b + Q$  and not  $Q$  alone. Similarly, if the stress in category  $F$  is produced by a stress concentration, the quantity  $F$  is the additional stress produced by the notch over and above the nominal stress. For example, if a plate has a nominal stress intensity,  $P_m = S$ ,  $P_b = 0$ ,  $Q = 0$ , and a notch with a stress concentration  $K$  is introduced, then  $F = P_m(K-1)$  and the peak stress intensity equals  $P_m + P_m(K-1) = KP_m$ .
- e. The triaxial stresses represent the algebraic sum of the three primary principal stresses ( $\sigma_1 + \sigma_2 + \sigma_3$ ) for the combination of stress components. Where uniform tension loading is present, triaxial stresses are limited to  $4 S_m$ .
- f. This limitation applies to the range of stress intensity. When the secondary stress is due to a temperature excursion at the point at which the stresses are being analyzed, the value of  $S_m$  shall be taken as the average of the  $S_m$  values tabulated in tables I-1.1, I-1.2, and I-1.3 of the ASME Boiler and Pressure Vessel Code, Section III (ASME III) for the highest and lowest temperature of the metal during the transient. When part of the secondary stress is due to mechanical load, the value of  $S_m$  shall be taken as the  $S_m$  value for the highest temperature of the metal during the transient.
- g.  $S_a$  is obtained from the fatigue curves, figures I-9.1 and I-9.2 of ASME Code, Section III. The allowable stress intensity for the full range of fluctuation is  $2 S_a$ .
- h. In the fatigue data curves, where the number of operating cycles is  $< 10$ , use the  $S_a$  value for 10 cycles; where the number is  $> 10$ , use the  $S_a$  value for  $10^6$  cycles.

**TABLE 4.2-5 (SHEET 3 OF 3)**

- i.  $L_L$  is the lower bound limit load with yield point equal to  $1.5 S_m$  (where  $S_m$  is the tabulated value of allowable stress at temperature as contained in ASME Code, Section III). The lower bound limit load is here defined as that produced from the analysis of an ideally plastic (nonstrain hardening) material where deformations increase with no further increase in applied load. The lower bound load is one in which the material everywhere satisfies equilibrium and nowhere exceeds the defined material yield strength, using either a shear theory of a strain-energy-of-distortion theory to relate multiaxial yielding to the uniaxial case.
- j.  $S_L$  denotes the structural action of shakedown load as defined in paragraph NB-3213.18 of ASME Code, Section III, calculated on a plastic basis as applied to a specific location on the structure.
- k. For normal and upset conditions, the limits on primary membrane plus primary bending need not be satisfied in a component if it can be shown from the test of a prototype or model that the specified loads (dynamic or static equivalent) do not exceed 44% of  $L_u$ , where  $L_u$  is the ultimate load or the maximum load or load combination used in the test. In using this method, account is taken of the size effect and dimensional tolerances which may exist between the actual part and the tested part, or parts, as well as differences which may exist in the ultimate strength or other governing material properties of the actual part and the tested part to ensure that the loads obtained from the test are a conservative representation of the load-carrying capability of the actual component under the postulated loading for normal and upset conditions.
- l. The allowable value for the maximum range of this stress intensity is  $3 S_m$  except for cyclic events which occur less than 1000 times during the design life of the plant. For this exception, in lieu of meeting the  $3 S_m$  limit, an elastic-plastic fatigue analysis may be performed in accordance with ASME Code, Section III to demonstrate that the cumulative fatigue usage attributable to the combination of those low events, plus all other cyclic event, does not exceed a fatigue usage value of 1.0.



TABLE 4.2-6 (SHEET 1 OF 3)

**CORE SUPPORT STRUCTURES STRESS CATEGORIES AND LIMITS OF STRESS INTENSITY FOR EMERGENCY CONDITIONS (HNP-2)**

| Stress Category                            | Primary Stresses                                         |                                               | Secondary Stresses                 | Peak Stresses           |
|--------------------------------------------|----------------------------------------------------------|-----------------------------------------------|------------------------------------|-------------------------|
|                                            | Membrane, $P_m$ <sup>(a)(b)(c)</sup>                     | Bending, $P_b$ <sup>(a)(b)(c)</sup>           | Membrane and Bending Secondary (Q) | Peak, (F)               |
| Emergency                                  | $P_m$                                                    | $P_m + P_b$                                   |                                    |                         |
|                                            | 1.5 $S_m$ <sup>(d)</sup> Elastic analysis <sup>(d)</sup> | 2.25 $S_m$ Elastic analysis <sup>(d)</sup>    |                                    |                         |
|                                            | or                                                       | or                                            |                                    |                         |
|                                            | $L_L$ Limit analysis <sup>(e)</sup>                      | $L_L$ Limit analysis <sup>(e)</sup>           | Evaluation not required            | Evaluation not required |
|                                            | or                                                       | or                                            |                                    |                         |
|                                            | 1.5 $S_m$ Elastic analysis <sup>(f)</sup>                | 2.25 $S_m$ Plastic analysis <sup>(f)(g)</sup> |                                    |                         |
|                                            | or                                                       | or                                            |                                    |                         |
|                                            | 0.6 $L_e$ Test <sup>(h)</sup>                            | 0.5 $S_u$ <sup>(g)</sup>                      |                                    |                         |
| or                                         | or                                                       |                                               |                                    |                         |
| $S_E$ Stress-ratio analysis <sup>(i)</sup> | 0.6 $L_e$ Test <sup>(h)</sup>                            |                                               |                                    |                         |
|                                            | or                                                       |                                               |                                    |                         |
|                                            | $KS_E$ Stress-ratio analysis <sup>(i)</sup>              |                                               |                                    |                         |

**TABLE 4.2-6 (SHEET 2 OF 3)**

- a. The symbols  $P_m$ ,  $P_b$ ,  $Q$ , and  $F$  do not represent single quantities, but rather sets of six quantities representing the six stress components  $\sigma$ ,  $\sigma_1$ ,  $\sigma_r$ ,  $\tau_{t1}$ ,  $\tau_{1r}$ , and  $\tau_{rt}$ .
- b. For configurations where compressive stresses occur, stress limits shall be revised to take into account critical buckling stresses. For external pressure, the permissible equivalent static external pressure is taken as 150% of that permitted by the rules of paragraph HB-3133 of ASME Boiler and Pressure Vessel Code, Section III (ASME III). Where dynamic pressures are involved, the permissible external pressure shall satisfy the preceding requirements or is limited to 50% of the dynamic instability pressure.
- c. When loads are transiently applied, consideration should be given to the use of dynamic load amplification and possible change in modulus of elasticity.
- d. The triaxial stresses represent the algebraic sum of the three primary principal stresses ( $\sigma_1 + \sigma_2 + \sigma_3$ ) for the combination of stress components. Where uniform tension loading is present, triaxial stresses should be limited to  $6 S_m$ .
- e.  $L_L$  is the lower bound limit load with yield point equal to  $1.5 S_m$  (where  $S_m$  is the tabulated value of allowable stress at temperature as contained in ASME III). The lower bound limit load is here defined as that produced from the analysis of an ideally plastic (nonstrain hardening) material where deformation increase with no further increase in applied load. The lower bound load is one in which the material everywhere satisfies equilibrium and nowhere exceeds the defined material yield strength, using either a shear theory or a strain-energy-of-distortion theory to relate multiaxial yielding to the uniaxial case.
- f. This plastic analysis uses an elastic-plastic-evaluation nominal primary stress. Strain hardening of the material may be used for the actual monotonic stress-strain curve at the temperature of loading; or any approximation to the actual stress-strain curve, which everywhere has a lower stress for the same strain as the actual monotonic curve, may be used. Either the shear or strain-energy-of-distortion-flow rule is used to account for multiaxial effects.
- g.  $S_u$  is the ultimate strength at temperature. Multiaxial effects on ultimate strength shall be considered.
- h. For emergency conditions, the stress limits need not be satisfied if it can be shown from the test of a prototype or model that the specified loads (dynamic or static equivalent) do not exceed 60% of  $L_e$ , where  $L_e$  is the ultimate load or the maximum load or load combination used in the test. In using this method, account is taken of the size effect and dimensional tolerances which may exist between the actual part and the tested part or parts as well as differences which may exist in the ultimate strength or other governing material properties of the actual part and the tested parts to assure that the

**TABLE 4.2.6 (SHEET 3 OF 3)**

loads obtained from the test are a conservative representation of the load-carrying capability of the actual component under postulated loading for emergency conditions.

- i. Stress ratio is a method of plastic analysis which uses the stress-ratio combinations (combination of stresses that consider the ratio of the actual stress to the allowable plastic or elastic stress) to compute the maximum load a strain-hardening material can carry.  $K$  is defined as the section factor;  $S_e \leq S_m$  for primary membrane loading.
- j. Where deformation is of concern in a component, the deformation is limited to two-thirds the value given for emergency conditions in the design specification.

TABLE 4.2-7 (SHEET 1 OF 3)

**CORE SUPPORT STRUCTURES STRESS CATEGORIES AND LIMITS  
OF STRESS INTENSITY FOR FAULTED CONDITIONS (HNP-2)**

| Stress<br>Category | Primary Stresses                                          |                                                 | Secondary Stresses                    | Peak Stresses           |
|--------------------|-----------------------------------------------------------|-------------------------------------------------|---------------------------------------|-------------------------|
|                    | Membrane, $P_m$ <sup>(a)(b)(c)</sup>                      | Bending, $P_b$ <sup>(a)(b)(c)</sup>             | Membrane and Bending<br>Secondary (Q) | Peak (F)                |
|                    | $P_m$                                                     | $P_m + P_b$                                     |                                       |                         |
|                    | — 2.4 $S_m$ Elastic analysis                              | — 3.0 $S_m$ Elastic analysis                    |                                       |                         |
|                    | or                                                        | or                                              |                                       |                         |
|                    | — 0.75 $S_u$ <sup>(e)</sup> Limit analysis <sup>(e)</sup> | — 1.33 $L_L$ Limit analysis <sup>(f)</sup>      | Evaluation not required               | Evaluation not required |
|                    | or                                                        | or                                              |                                       |                         |
|                    | — 1.33 $L_L$ Limit analysis <sup>(f)</sup>                | — 0.75 $S_u$ Plastic analysis <sup>(e)(g)</sup> |                                       |                         |
|                    | or                                                        | or                                              |                                       |                         |
|                    | — 0.67 $S_u$ Plastic analysis <sup>(e)(f)</sup>           | — 0.8 $L_F$ Tests <sup>(h)</sup>                |                                       |                         |
|                    | or                                                        | or                                              |                                       |                         |
|                    | — 0.8 $L_F$ Test <sup>(h)</sup>                           | — $K S_F$ Stress-ratio analysis <sup>(i)</sup>  |                                       |                         |
|                    | or                                                        |                                                 |                                       |                         |
|                    | — $S_F$ Stress-ratio analysis <sup>(i)</sup>              |                                                 |                                       |                         |

**TABLE 4.2-7 (SHEET 2 OF 3)**

- a. The symbols  $P_m$ ,  $P_b$ ,  $Q$ , and  $F$  do not represent quantities but rather sets of six quantities representing the six stress components,  $\sigma_t$ ,  $\sigma_1$ ,  $\sigma_r$ ,  $\tau_{t1}$ ,  $\tau_{1r}$ , and  $\tau_{rt}$ .
- b. When loads are transiently applied, consideration is given to the use of dynamic load amplification and possible changes in modulus of elasticity.
- c. For configurations where compressive stresses occur, stress limits take into account critical buckling stresses. For external pressure, the permissible equivalent static external pressure is taken as 2.5 times that given by the rules of paragraph NB-3133 of the ASME Boiler and Pressure Vessel Code Section III (ASME III). Where dynamic pressure is involved, the permissible external pressure shall satisfy the preceding requirements or shall be limited to 75% of the dynamic instability pressure.
- d. Where deformation is of concern in a component, the deformation is limited to 80% of the value given for fault conditions in the design specifications.
- e.  $S_u$  is the ultimate strength at temperature. Multiaxial effects on ultimate strength are considered.
- f.  $L_L$  is the lower bound limit load with yield point equal to  $1.5 S_m$  (where  $S_m$  is the tabulated value of allowable stress at temperature as contained in ASME Code, Section III). The lower bound limit load is here defined as that produced from the analysis of an ideally plastic (nonstrain hardening) material where deformations increase with no further increase in applied load. The lower bound load is one in which the material everywhere satisfies equilibrium and nowhere exceeds the defined material yield strength, using either a shear theory or a strain-energy-of-distortion theory to relate multiaxial yielding to the uniaxial case.
- g. This plastic analysis uses an elastic-plastic-evaluated nominal primary stress. Strain hardening of the material may be used for the actual monotonic stress-strain curve at the temperature of loading; or any approximation to the actual stress-strain curve, which everywhere has a lower stress for the same strain as the actual curve, may be used: either the maximum shear stress of strain-energy-of-distortion-flow rule is used to account for multiaxial effects.
- h. For fault conditions, the stress limits need not be satisfied if it can be shown from the test of a prototype or model that the specified loads (dynamic or static equivalent) do not exceed 80% of  $L_F$ , where  $L_F$  is the ultimate load or load combination used in the test. In using this method, account is taken of the size, effect, and dimensional tolerances as well as differences which may exist in the ultimate strength or other governing material properties of the actual part and the tested parts to assure that the loads obtained from the test are a conservative representation of the load-carrying capability of the actual component under postulated loading for fault condition.

**TABLE 4.2.7 (SHEET 3 OF 3)**

- i. Stress ratio is a method of plastic analysis which uses the stress-ratio combinations (combination of stresses that consider the ratio of the actual stress to the allowable plastic or elastic stress) to compute the maximum load a strain-hardening material can carry.  $K$  is defined as the section factor;  $S_f$  is the lesser of  $2.4 S_m$  or  $0.75 S_u$  for primary membrane loading.

**TABLE 4.2-8****STEAM DRYER, CS LINES, AND CORE STRUCTURE MATERIALS  
(HNP-1 AND HNP-2)**

|                     |                                            |
|---------------------|--------------------------------------------|
| Plate, sheet, strip | ASME SA240 Type 304 or 304L                |
| Bolts               | ASME SA193 Grade B8                        |
| Nuts                | ASME SA194 Grade 8                         |
| Forgings            | ASME SA 182 Grade F304                     |
| Bar                 | ASTM A276 Type 304 or 304L <sup>(a)</sup>  |
| Bar                 | ASME SA479 Type 304 or 304L                |
| Pipe                | ASME SA312 Type 304 or 304L                |
| Tube                | ASTM A269 Type 304 or 304 L <sup>(b)</sup> |
| Pipe fittings       | ASME SA403 Type WP304 or WP304L            |
| Pipe fittings       | ASME SA351 Type CF8                        |

Material used for the shroud backing ring is ASME SB166 or SB168. Material used for the shroud seismic pin is Inconel X-750 per ASTM A 461-65 GR 688.<sup>(c)</sup>

Major components of the shroud support portion of the core support structure are fabricated from:

- SB-168 Ni-Fe-Cr plate.
- SA-533 GRB C1.1 low alloy steel (HNP-2 only).

a. ASTM A276 Condition A is equivalent to ASME SA479 Type 304.

b. ASTM A269 is permitted to be used if the tensile requirements are in accordance with ASTM A249 (ASME SA249).

c. NRC Regulatory Guide 1.85 recognizes the use of ASME Code Cases 1344-5 which provide Appendix I type design information for Inconel X-750.

**TABLE 4.2-9**  
**DESIGN LOADING CONDITIONS AND COMBINATIONS**  
**(HNP-2)**

| <u>Operating Condition and Stress Limits<sup>(a)</sup></u> | <u>Design Loading Conditions and Combinations</u>                                                                                             |
|------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------|
| Normal and upset                                           | N and A <sub>D</sub> or N and U.                                                                                                              |
| Emergency                                                  | N and R or other conditions which have a 40-year encounter probability from 10 <sup>-1</sup> to 10 <sup>-3</sup> .                            |
| Faulted                                                    | N and A <sub>m</sub> and $\bar{R}$ or other conditions which have a 40-year encounter probability from 10 <sup>-3</sup> to 10 <sup>-6</sup> . |

where:

- N = normal loads.
- U = upset loads, excluding earthquake.
- A<sub>D</sub> = OBE, including any associated transients.
- A<sub>m</sub> = DBE, including any associated transients.
- R = any auxiliary pipe-rupture loading, including any associated transients. (Pipe-rupture loadings are not directly considered on piping itself because this is handled by a failure-mode analysis).
- $\bar{R}$  = primary loadings which result from rupture of a main steam line or a recirculation line.

a. The design stress, deformation, and fatigue limits are as follows:

- For RPV and appurtenances - ASME Code, Section III.
- For core support structures - A.5.2.2 of Design Safety Standards, NEDO-10370.
- For reactor internal structures - A.5.2.1 or A.5.2.5 of Design Safety Standards, NEDO-10370.



TABLE 4.2-10

**MAXIMUM DIFFERENTIAL PRESSURES ACROSS  
RPV ASSEMBLY INTERNALS  
(HNP-1)**

| <u>Reactor Component</u>                    | Normal<br>Operation<br>(psi) | Upset<br>(AOOs)<br>(psi) | Faulted<br>(Accident)<br>(psi) |
|---------------------------------------------|------------------------------|--------------------------|--------------------------------|
| Core plate & guide tube                     | 25.59                        | 27.99                    | 32.00                          |
| Shroud support                              | 33.26                        | 35.66                    | 53.0                           |
| Shroud                                      | 7.73                         | 11.59                    | 29.5                           |
| Top guide                                   | 0.65                         | 0.72                     | 3.6 <sup>(a)</sup>             |
| Shroud head                                 | 8.51                         | 12.76                    | 29.5                           |
| Dryer                                       | 0.4                          | 0.52                     | <9.1 <sup>(a)</sup>            |
| Fuel channel wall<br>(maximum power bundle) | 13.25                        | 16.15                    | 15.5                           |


a. Limiting at low-power, high-core flow.

TABLE 4.2-11

**MAXIMUM DIFFERENTIAL PRESSURES ACROSS  
RPV ASSEMBLY INTERNALS  
(HNP-2)**

| <u>Reactor Component</u>                    | Normal<br>Operation<br>(psi) | Upset<br>(AOOs)<br>(psi) | Faulted<br>(Accident)<br>(psi) |
|---------------------------------------------|------------------------------|--------------------------|--------------------------------|
| Core plate and guide tube                   | 22.17                        | 24.57                    | 26.5 <sup>(a)</sup>            |
| Shroud support                              | 29.93                        | 32.33                    | 49.0                           |
| Shroud                                      | 7.81                         | 11.72                    | 29.5 <sup>(a)</sup>            |
| Top guide                                   | 0.64                         | 0.71                     | 3.1 <sup>(a)</sup>             |
| Shroud head                                 | 8.6                          | 12.91                    | 29.0                           |
| Dryer                                       | 0.43                         | 0.56                     | <10 <sup>(a)</sup>             |
| Fuel channel wall<br>(maximum power bundle) | 13.47                        | 16.37                    | 16.0                           |

a. Limiting at low-power, high-core flow.



ACAD 040201


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

REACTOR INTERNALS FLOW PATHS

FIGURE 4.2-1



ACAD 040202


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 1

HNP-1 FUEL SUPPORT PIECES

FIGURE 4.2-2



ACAD 040203


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

HNP-2 FUEL SUPPORT PIECES

FIGURE 4.2-3



ACAD 040204


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

JET PUMP ISOMETRIC

FIGURE 4.2-4



ACAD 040205


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

PRESSURE NODES FOR  
DEPRESSURIZATION ANALYSIS

FIGURE 4.2-5



ACAD 040206

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

DURLIFE D-190  
CONTROL ROD ASSEMBLY

FIGURE 4.2-6





ACAD 040207


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

DURALIFE D-230  
CONTROL ROD ASSEMBLY

FIGURE 4.2-7



ACAD 040208


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

CONTROL ROD VELOCITY LIMITER

FIGURE 4.2-8



ACAD 040209


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

ADVANCED LONGER LIFE  
CONTROL ROD VELOCITY LIMITER

FIGURE 4.2-9



ACAD 040210


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

CONTROL ROD AND  
CONTROL ROD DRIVE COUPLING

FIGURE 4.2-10



ACAD 040211


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

CONTROL ROD DRIVE UNIT

FIGURE 4.2-11



ACAD 040212

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

CONTROL ROD DRIVE UNIT  
(SCHEMATIC)

FIGURE 4.2-12

- 1 - O-RING (BAR FLANGE FACE)
- 1 - O-RING (INLET AND WITHDRAW PORTS)
- 4 - STRAINER
- 5 - FLAT HEAD SCREW (STEAMER-MOUNTING)
- 6 - BARREL ALIGNMENT PIN
- 7 - O-RING (SPACE)
- 8 - NAME PLATE
- 9 - LOCKWASHER FOR PART (3)
- 10 - POSITION INDICATOR FROM
- 11 - POSITION INDICATOR FROM
- 11 - FULLY TIGHT AD SCREW POSITION INDICATOR FROM (MOUNTING)
- 11 - LOCKWASHER FOR PART (3)
- 11 - PISTON TUBE
- 11 - PISTON TUBE
- 12 - RING FLANGE
- 13 - O-RING (PISTON TUBE)
- 13 - CYLINDER TUBE AND FLANGE
- 14 - BALL CHECK VALVE
- 15 - BALL BEARING
- 15 - O-RING (BALL RETAINER)
- 15 - SET SCREW PLUG (COOLING WATER ORIFICE)
- 16 - DRIVE PISTON
- 16 - DRIVE PISTON
- 16 - DRIVE PISTON
- 17 - SEAL RING (COLLET PISTON - INTERNAL)
- 17 - SEAL RING (COLLET PISTON - EXTERNAL)
- 18 - COLLET AND PISTON
- 18 - SPRING WASHER
- 18 - SPRING WASHER
- 18 - SPRING WASHER
- 18 - SPLIT WASHER (STOP PISTON)
- 18 - STOP PISTON
- 18 - SEAL RING (STOP PISTON)
- 18 - BARREL
- 18 - COLLAR FOR STOP PISTON
- 18 - FULLY TIGHT AD SCREW CAP PLUG MOUNTING
- 18 - GUIDE CAP
- 18 - DRILL FULLY TIGHT AD SCREW OUTER PART
- 18 - MOUNTING
- 18 - INNER FILTER
- 18 - ROD
- 18 - TUBE
- 18 - BAND
- 18 - FILTER (OUTER)
- 18 - LIPS
- 18 - SEAL RING (INNER PISTON)
- 18 - COLLET (COLLECT PORTION OF OUTER TUBE)
- 18 - SPACE (PART OF CYLINDER, TUBE, AND FLANGE)
- 18 - O-RING (COLLECT PORTION OF PISTON TUBE - INTERNAL)
- 18 - POSITION INDICATOR (INTERNAL)
- 18 - INDEX EDGE (OUTER)
- 18 - OUTER TUBE (PART OF CYLINDER, TUBE, AND FLANGE)
- 18 - INNER CYLINDER (PART OF CYLINDER, TUBE, AND FLANGE)
- 18 - THE FULL LENGTH (PART OF POSITION INDICATOR FROM)
- 18 - STOP POSITION OF PISTON TUBE
- 18 - COLLET (PART OF COLLET AND PISTON)
- 18 - INDICATOR TUBE (PART OF PISTON TUBE)
- 18 - O-RING (SEALS DRIVE PISTON-BALL BEARING)
- 18 - INTERNAL RUSHING (DRIVE PISTON)
- 18 - EXTERNAL RUSHING (DRIVE PISTON)
- 18 - O-RING (SEALS DRIVE PISTON)



- 18 - INTERNAL PART (INLET AND WITHDRAW PORTS)
- 18 - RING (SEAL) (PART OF DRIVE PISTON)
- 18 - O-RING (COLLECT PORTION OF TUBE)
- 18 - WITHDRAW PORT (WITHDRAW INLET)
- 18 - INLET (COLLET AND SCREW DISCHARGE)
- 18 - INNER SEAL (DRIVE PISTON - DRIVE-DOWN SEAL)
- 18 - INNER SEAL (DRIVE PISTON - DRIVE-UP SEAL)
- 18 - WATER PORTS IN COLLET HOUSING

ACAD 040213


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

CONTROL ROD DRIVE UNIT  
(CUTAWAY)

FIGURE 4.2-13



ACAD 040214

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

CONTROL ROD DRIVE  
HYDRAULIC CONTROL UNIT

FIGURE 4.2-14






REV 26 9/08



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SODIUM PENTABORATE SOLUTION VOLUME-  
CONCENTRATION REQUIREMENTS

FIGURE 4.2-15



ACAD 2040216


REV 26 9/08



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SODIUM PENTABORATE SOLUTION  
TEMPERATURE VERSUS CONCENTRATION  
REQUIREMENTS

FIGURE 4.2-16



REV 24 9/06




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

GE MARATHON CONTROL ROD ASSEMBLY

FIGURE 4.2-17

# CR 99




REV 26 9/08




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

WESTINGHOUSE CR 99  
CONTROL ROD ASSEMBLY

FIGURE 4.2-18



**CR 99**



**Hot Isostatic Pressed  
Boron Carbide Pins**

**REV 26 9/08**



**SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2**

**WESTINGHOUSE CR 99  
BORON CARBIDE PIN DETAIL**

**FIGURE 4.2-19**

### **4.3 NUCLEAR DESIGN (HNP-1 AND HNP-2)**

The nuclear design discussed in this section is applicable to both HNP-1 and HNP-2, unless specified otherwise.

The description of fuel assemblies in the following sections pertains to fuel bundles supplied by Global Nuclear Fuel (GNF) and described in GESTAR II. In addition, four SVEA-96 Optima2 lead use assemblies (LUAs) supplied by Westinghouse Electric Company have been installed in the HNP Unit 1 core. The thermal-hydraulic design description and documentation of methods for these LUAs are contained in references 1 and 2.

#### **4.3.1 DESIGN BASES**

Reference section 3.1 of *NEDE-24011-P-A, "GESTAR II - General Electric Standard Application for Reactor Fuel" (incorporated by reference into the FSAR)*.

##### **4.3.1.1 Safety Design Bases**

Reference section 3.1 of *NEDE-24011-P-A (GESTAR II)*.

###### **4.3.1.1.1 Reactivity Bases**

Reference section 3.1.1 of *NEDE-24011-P-A (GESTAR II)*.

###### **4.3.1.1.2 Overpower Bases**

Reference section 3.1.2 of *NEDE-24011-P-A (GESTAR II)*.

#### **4.3.2 DESCRIPTION**

The general description of the reactor core is contained in section 3.2 of *NEDE-24011-P-A (GESTAR II)*.

##### **4.3.2.1 Nuclear Design Description**

The nuclear design description is contained in section 3.2.1 of *NEDE-24011-P-A (GESTAR II)*. The cycle-specific loading patterns are contained in the appropriate supplemental reload licensing reports listed in table 15.1-1.

#### **4.3.2.2 Power Distribution**

Reference section 3.2.2 of *NEDE-24011-P-A (GESTAR II)*.

##### **4.3.2.2.1 Power Distribution Measurement**

Reference section 3.2.2.1 of *NEDE-24011-P-A (GESTAR II)*.

##### **4.3.2.2.2 Power Distribution Accuracy**

Reference section 3.2.2.2 of *NEDE-24011-P-A (GESTAR II)*.

##### **4.3.2.2.3 Power Distribution Anomalies**

Reference section 3.2.2.3 of *NEDE-24011-P-A (GESTAR II)*.

##### **4.3.2.2.4 Power Distribution Calculations**

Prior to the start of each operating cycle, a 3-D simulator model is used to calculate local, radial, and axial power distributions at various exposures throughout the cycle to assess the effect of different control rod patterns on the margin to power distribution limits stated in the **Core Operating Limits Report (COLR) (incorporated by reference into the FSAR)**. Since differences between the projected operation of a cycle and what is actually achieved always exist, the same 3-D simulator model is used periodically throughout the cycle to recalculate power distributions based upon the actual operating history. The results are used to determine whether the original rod pattern recommendations require revision.

#### **4.3.2.3 Reactivity Coefficients**

Reference section 3.2.3 of *NEDE-24011-P-A (GESTAR II)*.

##### **4.3.2.3.1 Doppler Reactivity Coefficient**

Reference section 3.2.3.1 of *NEDE-24011-P-A (GESTAR II)*.

##### **4.3.2.3.2 Moderator Void Coefficient**

Reference section 3.2.3.2 of *NEDE-24011-P-A (GESTAR II)*.

#### **4.3.2.4 Control Requirements**

Reference section 3.2.4 of *NEDE-24011-P-A (GESTAR II)*.

##### **4.3.2.4.1 Shutdown Reactivity**

Shutdown reactivity for power distribution is discussed in section 3.2.4.1 of *NEDE-24011-P-A (GESTAR II)*. Also, prior to performing the shutdown margin demonstration test at the beginning of each cycle, the following additional design margin is adopted:

$$k_{\text{eff}} < 0.99\% \text{ with the highest-worth rod fully withdrawn}$$

##### **4.3.2.4.2 Reactivity Variations**

Reference section 3.2.4.2 of *NEDE-24011-P-A (GESTAR II)*.

#### **4.3.2.5 Control Rod Patterns and Reactivity Worth**

Below the low-power setpoint, control rod movements are constrained to the banked position withdrawal sequence (BPWS) rod patterns. The constraints prevent the development of high rod-worth patterns to limit the consequences of the control rod drop accident discussed in section 15.3.2.

The range of travel of the control rods is 144 in., which corresponds to the bottom twenty-four 6-in. nodes of the active fuel length.

#### **4.3.2.6 Criticality of Reactor During Refueling**

Criticality during refueling is discussed in section 3.2.5 of *NEDE-24011-P-A (GESTAR II)*. Subsection 7.6.1 contains a description of the reactor design features that prevent criticality during refueling.

#### **4.3.2.7 Stability**

##### **4.3.2.7.1 Xenon Transients**

Reference section 3.2.6.1 of *NEDE-24011-P-A (GESTAR II)*.



#### 4.3.2.7.2 Thermal-Hydraulic Stability

Reference paragraph 4.4.4.5.1.

#### 4.3.2.8 Vessel Irradiation

A. HNP-1

Vessel irradiation for HNP-1 is described in HNP-1-FSAR appendix R, sections R.4 and R.5.

B. HNP-2

The lead factor was calculated using the one- and two-dimensional, discrete ordinates transport codes described in paragraph 4.1.4.4. The discrete ordinates calculations were performed in cylindrical geometry with fission neutron source density distributions as input. The geometry described seven regions with the core modeled as two homogenized regions. In each calculation, the source density distribution, the total source, and the coolant density in each of the two core regions were specified to be appropriate for the elevation under consideration. The two-dimensional calculation model was based on the reactor midplane elevation. One-dimensional calculations were performed for a number of additional elevations. The coolant water region between the core and the shroud contained saturated water. The region between the shroud and vessel was assumed to be filled with subcooled water. The presence of the jet pumps was ignored. The material compositions for the stainless-steel shroud and the carbon-steel vessel contained the mixtures by weight as specified in the ASME material specifications for ASME SA240, 304L, and ASME SA533 Grade B.

The source distribution, which can be separated in space and energy, was obtained from the incremental fuel exposures by axial fuel node and bundle for a typical cycle and from the fission neutron energy spectrum. The integral of source density over space and energy in the core region was normalized to the total fission neutron source rate in the region. In these calculations, the core region was treated as a 1-cm-thick cross-section of the core with no transverse leakage.

*Dosimetry located on the inside surface of the vessel was removed with the first surveillance capsule and tested to determine the flux at that location. The lead factor, relating the dosimeter location to the peak location, was used to calculate the peak vessel inside surface flux. Assuming an 80% capacity factor or 32 effective full power years (EFPYs) in 40 years of operation, the fluence for this operating period was estimated. The measured dosimeter flux and calculated peak flux and fluence are shown in HNP-2-FSAR table 4.3-1.*

#### **4.3.3 ANALYTICAL METHODS**

Reference section 3.3 of *NEDE-24011-P-A (GESTAR II)*.

#### **4.3.4 FINAL LOADING PATTERN**

The final loading pattern must meet the requirements described in section 3.4 of *NEDE-24011-P-A, (GESTAR II)*.

**DOCUMENTS INCORPORATED BY REFERENCE INTO THE FSAR**

***"GESTAR II - General Electric Standard Application for Reactor Fuel," NEDE-24011-P-A.***

***Unit 1 and Unit 2 Core Operating Limits Reports (located in each unit's Technical Requirements Manual, Appendix A).***

**REFERENCES**

1. CENPD-300-P-A, "Reference Safety Report for Boiling Water Reactor Fuel," July 1996.
2. Westinghouse Report NF-BSN-10-10, "Supplemental Licensing Report, SVEA-96 Optima2 Lead Use Fuel Assemblies for Edwin I. Hatch Nuclear Plant, Unit 1," Revision 0, February 2010.

**TABLE 4.3-1**  
**ESTIMATED DOSIMETER**  
**AND**  
**VESSEL PEAK FLUX AND FLUENCE**  
**(HNP-2)**

Time at Power

|          |                                    |
|----------|------------------------------------|
| EOC 8    | 6.58 EFPYs ( $2.08 \times 10^8$ s) |
| 32 EFPYs | $1.01 \times 10^9$ s               |

Lead Factors

|                     |      |
|---------------------|------|
| Inside surface (ID) | 0.79 |
|---------------------|------|

|                                               |                    |
|-----------------------------------------------|--------------------|
| <u>Dosimeter Flux (<math>n/cm^2-s</math>)</u> | $1.12 \times 10^8$ |
|-----------------------------------------------|--------------------|

Fluence ( $n/cm^2$ )

|                  |                      |
|------------------|----------------------|
| EOC 8 dosimeter  | $2.3 \times 10^{17}$ |
| 32 EFPYs peak ID | $1.4 \times 10^{18}$ |

LEGEND:

|       |   |                            |
|-------|---|----------------------------|
| EOC   | = | end of cycle               |
| ID    | = | inside diameter            |
| EFPYs | = | effective full power years |

#### **4.4 THERMAL AND HYDRAULIC DESIGN (HNP-1 AND HNP-2)**

The information provided in this section is applicable to both HNP-1 and HNP-2, unless specified otherwise.

The description of fuel assemblies in the following sections pertains to fuel bundles supplied by Global Nuclear Fuel (GNF) and described in GESTAR II. In addition, four SVEA-96 Optima2 lead use assemblies (LUAs) supplied by Westinghouse Electric Company have been installed in the HNP Unit 1 core. The thermal-hydraulic design description for these LUAs is contained in reference 1.

##### **4.4.1 DESIGN BASES**

Design bases information is found in ***NEDE-24011-P-A, "GESTAR II - General Electric Standard Application for Reactor Fuel" (incorporated by reference into the FSAR)***. Additionally, design basis information is found in the lead-plant report "Hatch 2 Lead Assembly Compatibility Report: Mechanical, Thermal and Neutronic Design for ANF 9x9 Lead Assemblies," ANF-87-77(P), which is applicable to both HNP-1 and HNP-2.

###### **4.4.1.1 Safety Design Bases**

Reference section 4.1.1 of ***NEDE-24011-P-A (GESTAR II)***.

###### **4.4.1.2 Power Generation Design Bases**

Reference section 4.1.2 of ***NEDE-24011-P-A (GESTAR II)***.

###### **4.4.1.3 Requirements for Steady-State Conditions**

Reference section 4.1.2 of ***NEDE-24011-P-A (GESTAR II)***.

###### **4.4.1.4 Requirements for Anticipated Operational Occurrences (AOOs)**

Reference section 4.1.3 of ***NEDE-24011-P-A (GESTAR II)***.

###### **4.4.1.5 Summary of Design Bases**

Reference section 4.1.4 of ***NEDE-24011-P-A (GESTAR II)***.

#### **4.4.2 DESCRIPTION OF THERMAL-HYDRAULIC DESIGN OF REACTOR CORE**

##### **4.4.2.1 Critical Power Ratio**

Reference sections 4.2.1 and 4.3.1 of *NEDE-24011-P-A (GESTAR II)*.

##### **4.4.2.2 Average Planar Linear Heat Generation Rate (APLHGR)**

Reference section 4.2.2 of *NEDE-24011-P-A (GESTAR II)*.

##### **4.4.2.3 Core Coolant Flow Distribution and Orificing Pattern**

Reference section 4.2.3 of *NEDE-24011-P-A (GESTAR II)*.

##### **4.4.2.4 Void Fraction Distribution**

The distribution of void fractions in individual fuel assemblies and the core is a complex function of power level, fuel design, and rod pattern. Likewise, the bundle exit and the core steam quality depends upon the same factors. Void fraction distribution and steam quality are calculated by a 3-D core simulator code that incorporates thermal-hydraulic and neutronic feedback models.

##### **4.4.2.5 Core Pressure Drop and Hydraulic Loads**

Reference section 4.2.4 of *NEDE-24011-P-A (GESTAR II)*.

###### **4.4.2.5.1 Friction Pressure Drop**

Reference section 4.2.4.1 of *NEDE-24011-P-A (GESTAR II)*.

###### **4.4.2.5.2 Local Pressure Drop**

Reference section 4.2.4.2 of *NEDE-24011-P-A (GESTAR II)*.

###### **4.4.2.5.3 Elevation Pressure Drop**

Reference section 4.2.4.3 of *NEDE-24011-P-A (GESTAR II)*.

**4.4.2.5.4 Acceleration Pressure Drop**

Reference section 4.2.4.4 of *NEDE-24011-P-A (GESTAR II)*.

**4.4.2.6 Correlation and Physical Data**

Reference section 4.2.5 of *NEDE-24011-P-A (GESTAR II)*.

**4.4.2.6.1 Pressure Drop Correlation**

Reference section 4.2.5.1 of *NEDE-24011-P-A (GESTAR II)*.

**4.4.2.6.2 Void Fraction Correlation**

Reference section 4.2.5.2 of *NEDE-24011-P-A (GESTAR II)*.

**4.4.2.6.3 Heat Transfer Correlation**

Reference section 4.2.5.3 of *NEDE-24011-P-A (GESTAR II)*.

**4.4.2.7 Thermal Effect of AOOs**

Reference section 4.2.6 of *NEDE-24011-P-A (GESTAR II)*.

**4.4.2.8 Uncertainties in Estimates**

Reference section 4.2.7 of *NEDE-24011-P-A (GESTAR II)*.

**4.4.2.9 Flux Tilt Considerations**

Reference section 4.2.8 of *NEDE-24011-P-A (GESTAR II)*.

**4.4.2.10 Thermal-Hydraulic Uncertainties**

Reference sections 4.2 and 4.3 of *NEDE-24011-P-A (GESTAR II)*.

#### **4.4.2.11 Gross Power Tilt Considerations**

Reference section 3.2.2.3 of *NEDE-24011-P-A (GESTAR II)*.

### **4.4.3 DESCRIPTION OF THERMAL AND HYDRAULIC DESIGN OF REACTOR COOLANT SYSTEM**

#### **4.4.3.1 Plant Configuration Data**

Table 4.4-1 provides the flow path length, height, liquid level, minimum elevations, and minimum flow areas for each major flow path volume within the reactor pressure vessel (RPV) and recirculation loops of the RCS.

#### **4.4.3.2 Operating Restrictions on Pumps**

##### **A. Pump Characteristics**

Limitations on pump performance are discussed in section S.5.2.1 of *NEDE-24011-P-A (GESTAR II)*.

##### **B. Performance Range for Normal Operation**

A boiling water reactor (BWR) must operate with certain restrictions because of pump NPSH, overall plant control characteristics, and core thermal power limits.

Paragraph 4.4.3.3, together with the power-to-flow map (figure 15.1-3), describes the region where the plant may normally operate. This region is bounded by the considerations stated. Minimum power at high-forced circulation (bottom of map) is bounded to protect recirculation loop components from cavitation. Interlocks are provided to prevent operation below this bound. Maximum power is bounded for thermal margin considerations and protected by rod block and scram lines.



**4.4.3.3 Power-to-Flow Map**

As shown on figure 15.1-3, the licensed (analyzed) region of power operation is limited by the following power and flow relationships:

| <u>Core Flow (% of RTP)</u> | <u>Maximum Core Power (% of RTP)</u>                        |
|-----------------------------|-------------------------------------------------------------|
| 0 to 10                     | 24                                                          |
| 10 to ~ 92.9                | Maximum extended load line limit (MELL) (~ 106.5% rod line) |
| ~ 92.9 to 105               | 100                                                         |
| 105 to 110                  | decreasing to 69                                            |

**4.4.4 EVALUATION**

Reference section 4.3 of *NEDE-24011-P-A (GESTAR II)*.

**4.4.4.1 Critical Power**

Reference section 4.3.1 of *NEDE-24011-P-A (GESTAR II)*.

**4.4.4.1.1 Fuel Cladding Integrity Safety Limit**

Reference section 4.3.1.1 of *NEDE-24011-P-A (GESTAR II)*.

**4.4.4.1.2 Operating Limit Minimum Critical Power Ratio Calculational Procedures (OLMCPR)**

Reference section 4.3.1.2 of *NEDE-24011-P-A (GESTAR II)*.

**4.4.4.2 Core Hydraulics**

Reference section 4.3.2 of *NEDE-24011-P-A (GESTAR II)*.

**4.4.4.3 Influence of Power Distribution**

Reference section 4.3.3 of *NEDE-24011-P-A (GESTAR II)*.

#### **4.4.4.4 Core Thermal Response**

Reference section 4.3.4 of *NEDE-24011-P-A (GESTAR II)*.

#### **4.4.4.5 Analytical Methods**

Reference section 4.3.5 of *NEDE-24011-P-A (GESTAR II)*.

##### **4.4.4.5.1 Thermal-Hydraulic Stability Analysis**

Thermal-hydraulic instabilities are unlikely to occur during normal power operations; however, some BWRs have experienced instabilities while operating at high power with little or no forced circulation. General Design Criterion (GDC) 12 of Title 10 Code of Federal Regulations (CFR) Part 50, Appendix A, requires that the reactor core and associated coolant, control, and protection systems be designed to ensure such power oscillations are not possible or can be reliable and readily detected and suppressed prior to the violation of the safety limit MCPR (SLMCPR) by the oscillation power range monitor (OPRM). (Reference HNP-1-FSAR subsection 7.5.10 and HNP-2-FSAR paragraph 7.6.2.2.7.)

The thermal-hydraulic stability analysis performed for reloads is described in HNP-2-FSAR subsection 15.4.1.

##### **4.4.4.5.2 Power Test Program**

Core performance is evaluated at or near rated temperature and pressure. Evaluations include a reactor heat balance at rated temperature. Local power range monitor (LPRM) calibrations, which include use of the flux mapping and calibration system, are made. Each LPRM is calibrated to read in terms of the local fuel rod surface heat flux. Axial power distribution is measured with the traversing incore probe (TIP) system after significant changes in power, control rod pattern, or flowrate. Core void distribution is determined by calculation at several node points.

Additional tests include measuring response to changes in reactor setpoints, flow control tests to substantiate load-following characteristics, and measuring core plate pressure drop.

The stability of the nuclear system is verified during startup testing by introducing the same near-step perturbations that were used during the analytical simulation. Compliance with the ultimate performance limit is demonstrated at selected responsive plant conditions by the absence of divergent or limit-cycle oscillations excluding those minor limit cycles that can be induced by controller deadband characteristics.

The detailed core power and critical power ratio (CPR) distributions are calculated periodically. The unit is operated as necessary to maintain MCPR and the maximum linear heat generation rate within the operating limits for the plant.

#### **4.4.5 INSTRUMENTATION REQUIREMENTS**

The RPV instrumentation monitors the key operating parameters during planned operation to ensure sufficient parameter control. The following RPV sensors are discussed in HNP-1-FSAR subsection 7.8.5 and HNP-2-FSAR subsection 7.6.7:

- Temperature (function of coolant temperature).
- Water level.
- Coolant flowrates and differential pressures.
- Internal pressure.

The nuclear incore monitoring system is discussed in HNP-1-FSAR section 7.5 and HNP-2-FSAR subsection 7.6.2.

**DOCUMENTS INCORPORATED BY REFERENCE INTO THE FSAR**

***"GESTAR II - General Electric Standard Application for Reactor Fuel," NEDE-24011-P-A.***

REFERENCE

1. CENPD-300-P-A, "Reference Safety Report for Boiling Water Reactor Fuel," July 1996. |

HNP-2-FSAR-4

**TABLE 4.4-1**

**PLANT CONFIGURATION DATA  
(HNP-1 AND HNP-2)**

|                                                  | <u>Flow Path<br/>Length</u> | <u>Height &amp;<br/>Liquid<br/>Level<br/>(in.)</u> | <u>Elevation<br/>of Bottom of<br/>Each Volume<sup>(a)</sup><br/>(in.)</u> | <u>Minimum<br/>Flow Areas<br/>(ft<sup>2</sup>)</u> |
|--------------------------------------------------|-----------------------------|----------------------------------------------------|---------------------------------------------------------------------------|----------------------------------------------------|
| Lower plenum                                     | 209 in.                     | 209<br>209                                         | -161                                                                      | 80.0                                               |
| Core                                             | 164 in.                     | 164<br>164                                         | 47                                                                        | 106.0<br>(includes<br>bypass)                      |
| Upper plenum<br>and separators                   | 179 in.                     | 179<br>179                                         | 211                                                                       | 33.0                                               |
| Dome (above<br>normal water<br>level)            | 280 in.                     | 280<br>0                                           | 390                                                                       | 264.0                                              |
| Downcomer area                                   | 328 in.                     | 328<br>328                                         | -52                                                                       | 91.0                                               |
| Recirculation<br>loops & jet pumps<br>(one loop) | 136 ft                      | 497<br>497                                         | -480                                                                      | 90.8                                               |

a. Reference point is recirculation nozzle outlet.

#### **4.5 CONTROL ROD DRIVE HOUSING SUPPORTS (HNP-1 AND HNP-2)**

The information provided in this section is applicable to both HNP-1 and HNP-2, unless specified otherwise.

##### **4.5.1 SAFETY DESIGN BASES**

The CRD housing supports meet the following safety design bases:

- A. Following a postulated CRD housing failure, control rod downward motion is limited so that any resulting nuclear transient could not be sufficient to cause fuel damage.
- B. The clearance between the CRD housings and the supports is sufficient to prevent vertical contact stresses caused by thermal expansion during plant operation.

##### **4.5.2 DESCRIPTION**

The CRD housing supports are shown in figure 4.5-1. Horizontal beams are installed immediately below the bottom head of the RPV, between the rows of CRD housings. The beams are bolted to brackets welded to the inner steel ring of the drive room in the reactor support pedestal.

Hanger rods, ~ 10 ft long and 1 3/4 in. in diameter, are supported from the beams on stacks of disk springs, which compress ~ 2 in. under the design load.

The support bars are bolted between the bottom ends of the hanger rods. The spring pivots at the top and the beveled, loose-fitting ends on the support bars prevent substantial bending movement in the hanger rods if the support bars are overloaded.

Individual grids rest on the support bars between adjacent beams. Because a single-piece grid is difficult to handle in the limited work space and because it is necessary that CRD position indicators and incore instrumentation components be accessible for inspection and maintenance, each grid is designed for in-place assembly or disassembly. Each grid assembly is made up of two grid plates, a clamp, and a bolt. The top part of the clamp guides the grid to its correct position directly below the respective CRD housing that it would support in the postulated accident.

When the support bars and grids are installed, a gap of ~ 1 in. at room temperature (~ 70°F) is provided between the grid and the bottom contact surface of the CRD flange.

During system heatup, this gap is reduced by a net downward expansion of the housings with respect to the supports. In the hot operating condition, the gap is ~ 1/4 in.

In the postulated CRD housing failure, the CRD housing supports are loaded when the lower contact surface of the CRD flange contacts the grid. The resulting load is then carried by two grid plates, two support bars, four hanger rods, their disk springs, and two adjacent beams.

The American Institute of Steel Construction (AISC) Manual of Steel Construction, "Specification for the Design, Fabrication, and Erection of Structural Steel for Buildings," was used in designing the CRD housing support system. However, to provide structure that absorbs as much energy as practical without yielding, the allowable tension and bending stresses used were 90% of yield, and shear stress used was 60% of yield. These design stresses are 1.5 times the AISC allowable stresses (60% and 40% of yield, respectively).

For purposes of mechanical design, the postulated failure resulting in the highest forces is an instantaneous circumferential separation of the CRD housing from the RPV, with an internal pressure of 1250 psig (RPV design pressure) acting on the area of the separated housing. The weight of the separated housing, CRD, and blade, plus the pressure of 1250 psig acting on the area of the separated housing, gives a force of ~ 35,000 lb. This force is multiplied by a factor of 3 for impact, conservatively assuming that the housing travels through a 1-in. gap before it contacts the supports. The total force (105,000 lb) is treated as a static load in design.

Except for the following items, all CRD housing support subassemblies are fabricated of American Society of Testing Materials (ASTM) A 36 structural steel:

- Grid - ASTM A 441.
- Disc springs - Schnorr, Type BS-125-71-8.
- Hex bolts and nuts - ASTM A 307.

#### **4.5.3 SAFETY EVALUATION**

For design purposes, the postulated failure resulting from an instantaneous circumferential separation of the CRD housing from the RPV, with an internal pressure of 1250 psig (RPV design pressure) acting on the area of the separated housing is the governing design condition. The vertical force (dead load) of the separated housing, CRD, and blade, plus the force of 1250-psig pressure acting on the area of the separated housing multiplied by an impact factor of three gives the design static load on the CRD housing support members. The effect of an earthquake on the design load is not considered in the design because the earthquake load is only 3% of the design load.

Downward travel of the CRD housing and its control rod following the postulated housing failure equals the sum of the following distances:

- The compression of the disk springs under dynamic loading.
- The initial gap between the grid and the bottom contact surface of the CRD flange.

If the reactor is cold and pressurized, the downward motion of the control rod is limited to the spring compression (~ 2 in.), plus a gap of ~ 1 in. If the reactor is hot and pressurized, the gap is ~ 1/4 in., and the spring compression is slightly less than in the cold condition. In either case, the control rod movement following a housing failure is substantially limited below one drive

## HNP-2-FSAR-4

notch movement (6 in.). Sudden withdrawal of any control rod through a distance of one drive notch at any position in the core does not produce a transient sufficient to damage any radioactive material barrier.

The stress criterion (1.5 times the AISC-allowable stresses) is considered desirable for this application and adequate for the once-in-a-lifetime loading condition. The effect of stress raisers in the structural support members is considered by designing the actual stress in areas of stress concentration to be less than the AISC-allowable flexural stresses at 60% of yield.


The CRD housing supports are in place during power operation and when the nuclear system is pressurized. If a control rod is ejected during shutdown, the reactor remains subcritical because it is designed to remain subcritical with any one control rod fully withdrawn at any time.

At plant operating temperature, a gap of ~ 1/4 in. exists between the CRD housing and the supports. At lower temperatures the gap is greater. Because the supports do not contact any of the CRD housing, except during the postulated accident condition, vertical contact stresses are prevented.

### **4.5.4 INSPECTION AND TESTING**

CRD housing supports are removed for inspection and maintenance of the CRDs. The supports for one control rod can be removed during reactor shutdown, even when the reactor is pressurized, because all control rods are then inserted. When the support structure is reinstalled, it is inspected for correct assembly with particular attention to maintaining the correct gap between the CRD flange lower contact surface and the grid.





ACAD 040501

REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1 & UNIT 2

CONTROL ROD DRIVE  
HOUSING SUPPORT

FIGURE 4.5-1

**SUPPLEMENT 4A**

**INITIAL CORE  
(HNP-1 AND HNP-2)**

**4A.1 GENERAL**

*The Edwin I. Hatch Nuclear Plant (HNP) Unit 1 (HNP-1) and Unit 2 (HNP-2) initial core fuel was irradiated in the initial core and subsequent reloads. The initial core no longer resides in the core, but does reside onsite. This supplement provides information consistent with its current status.*

**4A.2 FUEL CONFIGURATION**

*The initial core fuel configuration for HNP-1 and HNP-2 is described in the following paragraphs.*

*A typical cross-section of a fuel assembly for HNP-1 and HNP-2 is shown in figures 4A-1 and 4A-2, respectively. A summary of the core fuel assembly data for HNP-1 and HNP-2 initial core is provided in tables 4A-1 and 4A-2, respectively. The initial core fuel for HNP-1 was 7x7 matrix while HNP-2 was an 8x8 matrix with 2 water rods.*

**4A.3 NUCLEAR DESIGN**

*Each HNP-1 fuel assembly contains 49 fuel rods which are spaced and supported in a square (7x7) array by the lower and upper tie plates. End fittings were designed so that it was not mechanically possible to complete the assembly of a fuel element with any high enrichment rods in positions specified to receive a lower enrichment. Gadolinia bearing pellets were used for some of the highest enrichment rods. The gadolinia-uranium fuel rods were designed with characteristic extended end plugs for each rod type. The extended end plug permitted a positive visual check on the location of each gadolinia-uranium rod after assembly. The bundle average enrichment was 1.0.*

*Each HNP-2 fuel assembly contains 62 fuel rods and 2 water rods. The water rods have a slightly larger diameter than the fuel rods. The enrichment distribution in the high- and medium-enrichment bundles is designed to meet the design bases. Gadolinia in the form of  $Gd_2O_3$  is selectively placed in fuel rods in the high- and medium-enrichment bundles to provide reactivity control and is distributed axially to flatten the axial power distribution. The reactivity variations of the high- and medium-enrichment bundles are designed to complement each other. The low-enrichment bundle is composed entirely of natural uranium rods. The bundle average enrichments, including the natural uranium at the top and bottom, are 2.21 and 1.76, respectively. These three bundle types combine for a core enrichment of 1.87. The natural uranium bundles do not contain gadolinia rods.*

**TABLE 4A-1**

**HNP-1 INITIAL CORE FUEL**

|                                                   | <u>Value</u> |
|---------------------------------------------------|--------------|
| <u>Fuel Assembly Data</u>                         |              |
| Overall length (in.)                              | 175.83       |
| Nominal active fuel length (in.)                  | 144.00       |
| Fuel rod pitch (in.)                              | 0.738        |
| Space between fuel rods (in.)                     | 0.175        |
| Fuel channel wall thickness (in.)                 | 0.80         |
| Fuel bundle heat transfer area (ft <sup>2</sup> ) | 86.513       |
| <u>Fuel Rod Data</u>                              |              |
| Outside diameter (in.)                            | 0.563        |
| Cladding thickness (in.)                          | 0.037        |
| Pellet outside diameter (in.)                     | 0.477        |
| Fission gas plenum length (in.)                   | 16.00        |
| Pellet immersion density (g/cc)                   | 10.420       |

HNP-2-FSAR-4A

**TABLE 4A-2 (SHEET 1 OF 2)**

**HNP-2 INITIAL CORE FUEL**

|                                                   | <u>Value</u> |
|---------------------------------------------------|--------------|
| <u>Fuel Assembly Data</u>                         |              |
| Overall length (in.)                              | 176.16       |
| Nominal active fuel length (in.)                  | 150.0        |
| Fuel rod pitch (in.)                              | 0.640        |
| Space between fuel rods (in.)                     | 0.157        |
| Fuel channel wall thickness (in.)                 | 0.100        |
|                                                   | or           |
|                                                   | 0.080        |
| Fuel bundle heat transfer area (ft <sup>2</sup> ) | 98.0         |
| Channel width (inside) (in.)                      | 5.278        |
| <u>Fuel Rod Data</u>                              |              |
| Outside diameter (in.)                            | 0.483        |
| Cladding inside diameter (in.)                    | 0.419        |
| Cladding thickness (in.)                          | 0.032        |
| Fission gas plenum length (in.)                   | 10.0         |
| Pellet immersion density (% TD)                   | 95.000       |
| Pellet outside diameter (in.)                     | 0.410        |
| Pellet length (in.)                               | 0.410        |
| <u>Water Rod Data</u>                             |              |
| Outside diameter (in.)                            | 0.591        |
| Inside diameter (in.)                             | 0.531        |

HNP-2-FSAR-4A

**TABLE 4A-2 (SHEET 2 OF 2)**

Zircaloy-2 Cladding

Thermal conductivity  $T = (600 - 800^{\circ}F)$   
 $k = 9 - 10$  (Btu/h-ft- $^{\circ}F$ )

Coefficient of linear thermal expansion:

$$\frac{1}{L_0} \left( \frac{\Delta L}{\Delta T} \right) \sim 3 \times 10^{-6} \text{ (F}^{-1}\text{)}$$


Total elongation (irradiated)  $\geq 1\%$

UO<sub>2</sub> Pellets

Thermal conductivity =  $\left( \frac{3978.1}{692.61 + T} \right) + 6.02366 \times 10^{-12} (T + 460)^3$  (Btu/h-ft- $^{\circ}F$ )

Melting temperature =  $5080 - 63.5 \times 10^{-4} E$  ( $^{\circ}F$ )

where:  $E = \text{exposure MWd/T}$



ACAD 04A01


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1

HNP-1 FUEL ASSEMBLY

FIGURE 4A-1



ACAD 04A02

REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

HNP-2 FUEL ASSEMBLY

FIGURE 4A-2

## 5.0 REACTOR COOLANT SYSTEM AND CONNECTED SYSTEMS

### 5.1 SUMMARY DESCRIPTION

The reactor coolant system (RCS) includes those systems and components that contain or transport fluids to or from the reactor core. These systems form a major portion of the nuclear system process barrier. This chapter provides information regarding the RCS and pressure-containing appendages out to and including isolation valving. This group of components is defined as the reactor coolant pressure boundary (RCPB) in Section 50.2(v) of 10 CFR 50 as follows:

The RCPB means all those pressure-containing components of boiling and pressurized water-cooled nuclear power reactors, such as pressure vessels, piping, pumps, and valves, which are:

- Part of the RCS.
- Connected to the RCS, up to and including all of the following:
  - The outermost containment isolation valve in system piping which penetrates primary reactor containment.
  - The second of the two valves normally closed during normal reactor operation in system piping which does not penetrate primary reactor containment.
  - The RCS safety relief valves.

Section 5.5 of this chapter also deals with various subsystems to the RCPB which are closely allied to it. These are briefly reviewed below.

The nuclear pressure relief system (NPRS) protects the RCPB from damage due to overpressure. To protect against overpressure, pressure-operated safety relief valves are provided to discharge steam from the nuclear steam supply system (NSSS) to the suppression pool. The NPRS also acts to automatically depressurize the NSSS in the event of a loss-of-coolant accident (LOCA) in which the high-pressure coolant injection (HPCI) system fails to maintain reactor pressure vessel (RPV) water level. Depressurization of the NSSS allows the low-pressure core cooling systems to supply enough cooling water to adequately cool the fuel.

The RCPB leak detection system, described in subsection 5.2.7, detects system leakage inside the primary containment so that appropriate action can be taken before the integrity of the nuclear system process barrier is impaired.

The RPV and appurtenances are described in section 5.4. The major safety functions of the RPV are to maintain water over the core and to act as a radioactive material barrier. The RPV meets the requirements of applicable codes and criteria. The possibility of brittle fracture is



## HNP-2-FSAR-5

considered and suitable design and operational limits are established that avoid conditions where brittle fracture is possible.

The reactor recirculation system (RRS) provides coolant flow through the core. Adjustment of the core coolant flowrate changes reactor power output, thus providing a means of following plant load demand without adjusting control rods. The RRS is designed to provide a slow coastdown of flow so that fuel thermal limits cannot be exceeded as a result of RRS malfunctions. The arrangement of the RRS routing is such that a piping failure cannot compromise the integrity of the floodable inner volume of the reactor vessel, thereby ensuring adequate core cooling following a LOCA.

The main steam line flow restrictors are venturi-type flow devices. One restrictor is installed in each main steam line inside the primary containment. The restrictors are designed to limit the loss-of-coolant resulting from a main steam line break outside the primary containment. The coolant loss is limited so that RPV water level remains above the top of the core during the time required for the main steam line isolation valves (MSIVs) to close. This action maintains the integrity of the fuel cladding (fuel barrier).

The MSIVs automatically close to isolate the nuclear system process barrier in the event a pipe break occurs downstream of the isolation valves, thereby limiting the loss-of-coolant and the release of radioactive materials from the NSSS. Two MSIVs are installed on each main steam line, one inside and the other outside the primary containment. Closure of either of the two MSIVs acts to seal the primary containment in the event that a main steam line break occurs there.

The reactor core isolation cooling system provides makeup water to the core during a reactor shutdown in which feedwater flow is not available. The system is started either automatically upon receipt of a low reactor water level signal or manually by the operator. Water is pumped to the core by a turbine-pump driven by reactor steam.

The residual heat removal (RHR) system includes a number of pumps and heat exchangers that can be used to cool the NSSS under a variety of situations. During normal shutdown and reactor servicing, the RHR system removes residual and decay heat. The RHR system allows decay heat to be removed whenever the main heat sink (main condenser) is not available, i.e., hot standby. Another operational mode of the RHR system is low pressure coolant injection (LPCI). The LPCI operation is an engineered safety feature system for use during a LOCA. This operation is described in paragraph 6.3.2.2.4. Another mode of RHR system operation allows heat to be removed from the primary containment following a LOCA.

The reactor water cleanup system functions to maintain the required purity of reactor coolant by circulating coolant through a system of filter-demineralizers.

The following low-pressure systems interface with the high-pressure RCS on HNP-2:

- Radwaste systems.
- RHR system.

- Core spray (CS) system.

Due to the involvement of the RHR and CS systems in the emergency core cooling system function, the recommendations of BTP EICSB-3 are not required to be implemented for these systems. A description of overpressure protection for the RHR system is provided in section 6.3 and paragraph 7.3.1.2.3.

The radwaste systems comply with the intent of BTP EICSB-3 in that the systems cannot be overpressurized by the high-pressure RCS. The high-pressure RCS is connected to the radwaste system to facilitate drainage and venting for maintenance. Where maintenance drains are provided, the systems are separated by two normally closed, manually operated valves in series. The radwaste system also provides a collection point for gas and vapor venting from the RPV during RPV heatup. Two normally closed remote manually actuated, air-operated valves are provided with valve position indication in the main control room, and opening and closing evolutions are controlled administratively during startup and shutdown of the reactor.

In view of the size of the air-operated valves (drawing no. H-26000, valves F003 and F004) and the fact that the valves discharge into uninsulated drywell equipment drain piping which is of a much larger size (2-in.-nominal diameter connector pipe to a 4-in.-nominal diameter nonisolable collection header to the drywell equipment sump which is vented to the drywell volume), the failure of administrative controls for these valves would not cause overpressurization of the radwaste system.

#### **5.1.1 SCHEMATIC FLOW DIAGRAM**

A process flow diagram of the RCS denoting all major components, principal pressures, temperatures, flowrates, coolant volumes, and enthalpy under normal steady-state full-power operating conditions is presented in figure 5.1-1.

#### **5.1.2 PIPING AND INSTRUMENTATION DIAGRAM**



A piping and instrumentation diagram for the nuclear boiler system is presented in drawing nos. H-26000, H-26001 and H-26189.

#### **5.1.3 ELEVATION DRAWING**

Sections through the reactor building showing the primary containment and the major pieces of equipment of the RCS are shown on drawing nos. H-26104 and H-26105.

|                                                   | PRESSURE (Psia) | FLOW (lbs/hr)        | TEMPERATURE (°F) | ENTHALPY (Btu/lb) |
|---------------------------------------------------|-----------------|----------------------|------------------|-------------------|
| 1. CORE INLET                                     | 1100            | $77 \times 10^6$     | 534.6            | 529.7             |
| 2. CORE OUTLET                                    | 1073            | $77 \times 10^6$     | 552              | 651.1             |
| 3. SEPARATOR OUTLET (STEAM DOME)                  | 1060            | $12.171 \times 10^6$ | 551.7            | 1190.4            |
| 4. STEM LINE (2 <sup>nd</sup> ISOLATION VALVE)    | 1025            | $12.171 \times 10^6$ | 579              | 1190.4            |
| 5. FEEDWATER INLET (INCLUDES CLEANUP RETURN FLOW) | 1085            | $12.241 \times 10^6$ | 425.8            | 403.9             |
| 6. RECIRC PUMP SUCTION                            | 1072            | $34.3 \times 10^6$   | 534              | 529.6             |
| 7. RECIRC PUMP DISCHARGE                          | 1246            | $34.3 \times 10^6$   | 535              | 530.3             |

|                                   | VOLUME OF FLUID (ft <sup>3</sup> ) |
|-----------------------------------|------------------------------------|
| A LOWER PLENUM                    | 2844                               |
| B CORE                            | 1525                               |
| C UPPER PLENUM & SEPARATORS       | 926                                |
| D DOME (ABOVE NORMAL WATER LEVEL) | 5266                               |
| E DOWNCOMER REGION                | 4533                               |
| F RECIRC LOOPS & JET PUMPS        | 1236                               |



ACAD 2050101

REV 22 9/04



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

REACTOR COOLANT SYSTEM  
FLOW DIAGRAM

FIGURE 5.1-1

## **5.2 INTEGRITY OF REACTOR COOLANT PRESSURE BOUNDARY (RCPB)**

### **5.2.1 DESIGN OF RCPB COMPONENTS**

#### **5.2.1.1 Performance Objectives**

##### **5.2.1.1.1 Reactor Pressure Vessel (RPV) and Appurtenances**

The objective of the RPV design is to provide a volume in which the core can be submerged in coolant, thereby allowing power operation of the reactor. Design of the RPV and appurtenances provides the means for attaching pipelines to the RPV and for installing RPV internal components.

##### **5.2.1.1.2 Reactor Recirculation System (RRS)**

The objective of the RRS is to provide a variable moderator (coolant) flow to the reactor core for adjusting reactor power level.

##### **5.2.1.1.3 Nuclear Pressure Relief System (NPRS)**

The objective of the NPRS is to limit any overpressure that occurs during an anticipated operational occurrence (AOO).

##### **5.2.1.1.4 Main Steam Line Flow Restrictors**

The objective of the main steam line flow restrictors is to protect the fuel barrier by limiting the loss of coolant from the RPV before main steam isolation valve (MSIV) closure, should a rupture occur in a main steam line outside the primary containment.

##### **5.2.1.1.5 Main Steam Line Isolation Valves**

The objective of the MSIVs, one of which is on the drywell side while the other is just outside the primary containment, is to prevent damage to the fuel barrier by limiting loss of reactor coolant for a major steam piping leak outside the primary containment. MSIVs also limit radioactive releases to the plant environs.

#### **5.2.1.1.6 Reactor Core Isolation Cooling (RCIC) System**

The RCIC system provides core cooling during reactor shutdown by pumping makeup water into the reactor vessel in case of a loss of flow from the main feed system and is activated in time to preclude conditions which lead to inadequate core cooling.

#### **5.2.1.1.7 Residual Heat Removal (RHR) System**

The objectives of the RHR system are:

- To restore and maintain the coolant inventory in the RPV so that the core is adequately cooled after a loss-of-coolant accident (LOCA).
- To provide containment (suppression pool) cooling so that condensation of the steam resulting from the blowdown due to the design basis LOCA is ensured.
- To remove decay heat and residual heat from the nuclear steam supply system (NSSS) so that refueling and NSSS servicing can be performed.
- To supplement the fuel pool cooling and cleanup system (FPCCS) capacity, when necessary, with additional cooling capacity.

#### **5.2.1.1.8 Reactor Water Cleanup (RWC) System**

The RWC system maintains high reactor water purity to limit chemical and corrosive action, thereby limiting fouling and deposition on heat transfer surfaces. It also removes corrosion products to limit impurities available for neutron activation and resultant radiation from deposition of corrosion products.

#### **5.2.1.1.9 Nuclear System Leak Detection System (LDS)**

The objective of the NSSS LDS is to detect leakage from the nuclear system process barrier and from systems essential to safe plant shutdown before predetermined limits are exceeded.

#### **5.2.1.1.10 High-Pressure Coolant Injection (HPCI) System**

The HPCI system supplies makeup water to the reactor vessel in the event of a LOCA or reactor isolation and failure of the RCIC system. The makeup water is required to maintain sufficient reactor water inventory since steam generation will continue at a reduced rate due to the core fission product decay heat, even though the reactor has scrammed. A turbine-driven pumping system is used to supply demineralized makeup water from the condensate storage tank (CST) to the reactor; an alternate source of water is available from the suppression pool.

The turbine is driven with a portion of the decay heat steam from the reactor vessel, and exhausts to the suppression pool.

#### **5.2.1.1.11 Core Spray (CS) System**

The CS system consists of two completely independent spray loops. The equipment for each loop consists of a CS pump, a sparger ring, a spray nozzle, and the necessary piping, valves, and instrumentation. Each loop pump takes water from the suppression chamber by suction and sprays the water through the sparger ring into the plenum chamber above the core.

The CS system is designed to deliver sufficient spray to each fuel bundle in the core to prevent fuel clad melting during loss-of-coolant conditions. The design is coordinated with the total emergency core cooling system (ECCS) in such a manner that for all rates of coolant loss from the primary reactor system, the core will be adequately cooled.

#### **5.2.1.2 Design Parameters**

Table 5.2-1 lists design temperature, pressure, and maximum test pressure for the RCPB structures and components. Stress analyses for RPV components are performed using the methods described in paragraph 5.4.6.4. A discussion of the input criteria for seismic design is contained in section 3.7.

The design requirements established to protect the principal components of the reactor coolant system (RCS) against environmental effects are discussed in subsection 3.11.2.

Due to intergranular stress corrosion cracking, the recirculation piping, stainless steel portions of the RHR suction and return lines, and a portion of the RWC piping have been replaced with Type 316 Nuclear Grade stainless steel. The extent of the replacement is described in table 3.2-1. The recirculation piping flow element is replaced with a flow element which has the same configuration as the original one and is made from Nuclear Grade CF3 material.

Boiling water reactor operating history has indicated that certain stainless steel piping in the RCS pressure boundary has been susceptible to stress corrosion cracking. To preclude potential cracking, the recirculation pump discharge valve 4-in. bypass lines have been removed from the original recirculation piping system and excluded in the replacement of the recirculation piping system. The control rod drive hydraulic return line has been removed from the RPV and rerouted within the CRD system. (See drawing no. H-26007.) The CRD return line RPV nozzle has been capped. The CS piping has been replaced with carbon steel, and the stainless steel safe end has been replaced with one of a low-alloy steel.

#### **5.2.1.3 Compliance with 10 CFR 50, Section 50.55a**

Compliance with the guidelines of 10 CFR 50, Section 50.55a, Codes and Standards, is tabulated in section 3.2.

#### **5.2.1.4 Applicable Code Cases**

Code cases that were applied to the RPV are:

- ASME Section III, 1968 Edition including Addenda through Summer 1970.
- 1332-5.
- 1441-1.
- 1459-1.
- 1401-1.

No code cases were applied for pumps, valves, and piping.

The only code case invoked in the replacement recirculation piping design was American Society of Mechanical Engineers (ASME) Code, Section III, 1980 Edition, Case N-122, "Stress Indices for Integral Structural Attachments, Class 1." This code case is used for calculating stresses in the pipe wall in the vicinity of rectangular lugs welded to the pipe wall.

#### **5.2.1.5 Design Transients**

##### **5.2.1.5.1 Loading and Stress Criteria for RCPB Components Designed by Stress Analysis**

The loading conditions may be divided into four categories: normal, upset, emergency, and faulted conditions. These categories are generically described in the ASME Boiler and Pressure Vessel Code, Section III, N-412, 1968 Edition. For the replaced recirculation piping system (RHR and RWC piping from their connections to the reactor pressure vessel, recirculation piping, and RHR suction, respectively) the loading conditions are service levels A, B, C, and D as described in the ASME Boiler and Pressure Vessel Code, Section III, 1980 Edition. The actual loading combinations, design procedures, and acceptability criteria are tabulated in section 3.9. These tables include the pressure-retaining components of the RCPB. The seismic criteria for the RCPB are discussed in section 3.7.

##### **5.2.1.5.2 Analyses of RCPB Pressure Parts of the Reactor Pressure Vessel**

The RPV is designed in accordance with the ASME Boiler and Pressure Vessel Code (1968), Section III, its interpretations and applicable requirements for Class A vessels as defined therein, as of the Summer 1970 Addenda.

Both elastic and inelastic stress analysis techniques were used in the design of the RPV core support and reactor internal structures to show that stress limits were not exceeded. Before an

inelastic stress analysis was performed on these components, the elastic (linear) system analysis was checked to see if the analysis required modification. The procedure is to perform a linear analysis with the stiffness of the inelastic component reduced to the stiffness value corresponding to the inelastic displacement value. A nonlinear dynamic analysis is performed if the natural frequencies of the system with reduced stiffness deviate significantly from that of the unreduced system.

Stress analysis requirements and load combinations for the RPV are tabulated in section 3.9. The RPV was designed for a minimum useful life of 40 years. However, aging management programs (subsections 18.1.2, 18.2.9, 18.2.12, 18.2.15, and 18.2.17) monitor the ongoing condition of the reactor vessel so that actions are taken to provide reasonable assurance that the vessel is capable of performing its intended function for 40 years and beyond.

#### **5.2.1.6 Identification of Active Pumps and Valves**

##### **5.2.1.6.1 Classification of Pumps and Valves**

Active components are those whose operability is relied on to perform a safety function, as well as reactor shutdown function, during the transients or events considered in the respective operating condition categories.

Inactive components are those whose operability (e.g., valve opening or closure, pump operation or trip) are not relied on to perform the system function during the transients or events considered in the respective operating condition categories.

Active valves within the RCPB are shown in tables 3.9-33 and 3.9-34.

The isolation signals which activate the isolation valves are described in section 7.3.2.

The times for closed or open cycles are listed in ***Technical Requirements Manual (TRM) table T7.0-1 (incorporated by reference into the FSAR)*** and table 6.3-4.

Leaktightness capability requirements for all active valves are included in the applicable valve specifications. Valve parts forming the RCPB were pressure tested per the requirements of the Draft Nuclear Pump and Valve Code or ASME Boiler and Pressure Vessel Code, Section III. The maximum allowable leakage past valve seats is 2 cm<sup>3</sup>/h/in. of seat diameter under the system design pressure during manufacturer's shop test.

There are no active pumps in the RCPB.

##### **5.2.1.6.2 Design Methods and Procedures for Pipe Rupture**

The design criteria employed to ensure that active components function as designed in the event of a pipe rupture are described in the following:



## HNP-2-FSAR-5

### A. RRS Pump

1. The LOCA does not degrade pump coastdown performance in the unbroken loop to the extent that the core is deprived of adequate cooling.
2. The pump bearings have sufficient dynamic load capability at rated operating condition to withstand the design basis earthquake (DBE).

### B. RRS Discharge Block Valves

1. The valve in the unbroken loop is capable of automatic closure after the LOCA.
2. The valve in the unbroken loop maintains pressure integrity and operability following the DBE.
3. The valve in the unbroken loop closes automatically on a signal initiated by low reactor water level or high drywell pressure.
4. The valve closes in the maximum time span specified in table 6.3-4.
5. The maximum permissible leak rate is conservatively estimated to be 5 gal/min.

### C. The automatic depressurization system (ADS) portion of the safety relief valves (7 of 11 safety relief valves) is required to operate during a small break LOCA. The ADS is activated by simultaneous signals from:

- Drywell high pressure.
- RPV low water level.
- Output pressure from at least one LPCI or one CS pump.

### D. Isolation Valves as Required for System Functions

1. Valves required for the ECCS remain operable, for both opening or closing, as required for system functions after an accident.
2. Valve operation is controlled by the signals described in subsection 7.3.2.

### E. Pipe Rupture

Protection against dynamic effects of pipe rupture is described in section 3.6. Protection is provided on the assumption that either longitudinal (slot) failure or circumferential (guillotine) failure may occur at selected locations along the piping within the primary containment.

### **5.2.1.7 Design of Active Pumps and Valves**

In order to ensure the functional performance of active valves of the RCPB, stringent design requirements were applied. There are no active pumps in the RCPB. Operability is ensured as described in the following paragraphs.

*All active valves were qualified for operability assurance by first being subjected to the following tests:*

- A. Shop tests which include hydrostatic tests and seal leakage tests were performed as specified in the applicable code.*
- B. The valves are required to open and close within specified time limits when subjected to design or environmental conditions as required by applicable codes. These valves were subjected to cold hydrostatic tests and hot functional tests as part of the Preoperational Test Program.*

Conservative seismic accelerations of 1.5-g horizontal and 0.144-g vertical were used simultaneously in the structural analyses. The above loads were combined with other normal and transient operational loads, and the worst-case combined stress levels were determined and shown to meet the stress criteria. Assurance is therefore provided that the components will function as required.

Active valves are also operated periodically, as required in the Technical Specifications. This repeated operability requirement throughout the life of the specified valve further provides assurance of reliable valve operation.

The representative combination of loads and analyses are tabulated in section 3.9.

### **5.2.1.8 Inadvertent Operation of Valves**

A discussion of the design basis events and appropriate limits for this plant is given in chapter 15 and tabulated in section 3.9. The events in chapter 15 have been selected to envelope the most severe change in critical parameters from events that have been postulated to occur during planned operation.

### **5.2.1.9 Stress and Pressure Limits**

The allowable stress limits and design loads for RCPB components are tabulated in section 3.9. Active valves of the RCPB are delineated in tables 3.9-33 and 3.9-34.

### **5.2.1.10 Stress Analysis for Structural Adequacy**

Stress analysis is used to determine structural adequacy of pressure components of the RCPB under various operating conditions and earthquakes. Significant discontinuities such as nozzles and flanges are considered. In addition to the design calculations required by the ASME Codes,

stress analysis is performed by methods outlined in the code appendices or by other methods applicable to the design condition through reference to analogous codes or other published literature.

Results of significant areas of consideration are tabulated for major components in section 3.9.

#### **5.2.1.11 Analysis Method for Faulted Condition**

In the event that an inelastic stress analysis was performed, the elastic (linear) system analysis was checked to see if the analysis requires modification in accordance with the procedure described in paragraph 5.2.1.5.2.

#### **5.2.1.12 Protection Against Environmental Factors**

The protection of the principal components of the RCS against environmental effects is discussed in section 3.11. Missile protection is discussed in section 3.5, and fire protection is discussed in subsection 9.5.1.

#### **5.2.1.13 Compliance With Code Requirements**

For components that were constructed in accordance with Section III of the ASME Boiler and Pressure Vessel Code, Subsection NB, the analytical calculations or experimental testing was performed to demonstrate compliance with the code. Brief descriptions of the mathematical or test models and the methods of calculation or testing, including any simplifying assumptions with summary of results, are tabulated and discussed in section 3.9.

#### **5.2.1.14 Stress Analysis for Emergency and Faulted Condition Loadings**

The types of stress analysis that were used for the emergency and faulted conditions are given in the tables in section 3.9.

#### **5.2.1.15 Stress Levels in Seismic Category I Systems**

A list of Seismic Category I systems and associated stress levels (i.e., seismic, deadweight plus pressure and LOCA) at all points of high changes in flexibility under the faulted conditions are tabulated in section 3.9.

#### **5.2.1.16 Analytical Methods for Stresses in Pumps and Valves**

The methods and criteria for analysis of stresses and deformations in the pressure boundary portions of Class 1 pumps and valves are as described in either the 1971 edition of the ASME Code, Section III, or the Draft Nuclear Pump and Valve Code.

The methods and criteria for design and acceptability of stresses as determined for the pressure boundary portions of Class 1 valves and safety relief valves are those described in the applicable portions of the ASME Code, Section III, and the Draft ASME Nuclear Pump and Valve Code. In the event that components supplied with geometries or design conditions for which code limits had not been developed, a complete description of the analytical methods and criteria used for evaluation of stresses and deformations were submitted by the manufacturer. The summary of the analyses for the RCPB components (analytical models, methods of calculation, and a summary of results) is presented in section 3.9.

#### **5.2.1.17 Analytical Methods for Evaluation of Pump Speed and Bearing Integrity**

##### **5.2.1.17.1 Pump Shaft Critical Speed**

The first critical speed of the recirculation pump shaft has been calculated to be above 130% of the operating speed. The absence of shaft vibration has been verified by testing the pump up to its maximum rated speed. The absence of vibration was further verified in the plant during preoperational testing.

##### **5.2.1.17.2 Pump Bearing Integrity**

Adequacy of the bearing design has been verified by full temperature and pressure performance tests conducted to simulate expected loads.

#### **5.2.1.18 Operation of Active Valves Under Transient Loadings**

The qualification test program to verify that active valves within the RCPB whose operability is relied upon to perform a safety function or to shut down the reactor operate under the transient loadings experienced during service life is described in the following subsections.

##### **5.2.1.18.1 Motor-Operated Gate Valve**

A motor operator built to the same design as that of the motor operator for the RRS gate valves has been tested to demonstrate its performance capability under expected operating conditions, including the containment environment after the LOCA. Performance was tested under maximum moisture, pressure, and temperature conditions after exposure to lifetime radiation dose and under design basis seismic conditions. The specific conditions under which the operators were qualified are provided in section 3.11.

##### **5.2.1.18.2 Main Steam Line Isolation Valves**

Components of the MSIVs, which are required to operate during transient conditions and whose functional capabilities are sensitive to the abnormal ambient pressure and temperature

associated with the transient, were subjected to a test sequence that simulates the abnormal ambient conditions. Functional requirements were verified throughout the test sequence. Components prototypical of HNP-2 valve components were tested.

The MSIVs have been tested in accordance with the ASME Boiler and Pressure Vessel Code, Section III. Thermal transient loadings on the MSIVs were not simulated, but were shown to be acceptable by analysis.

#### **5.2.1.18.3 Safety Relief Valves**

The safety relief valves are subjected to tests that simulate conditions experienced during service life.

#### **5.2.1.18.4 Other Provisions to Ensure Operability**

To ensure operability of active valves under the transient loadings to be experienced during plant service life, design specifications include the following requirements:

- A. Valve bodies and yoke structures are designed to withstand seismic forces.
- B. Valve operators are sized to open or close under the maximum differential pressure across the valve seat, dictated by the transient service conditions.
- C. Valves are qualified by analysis or prototype tests at the vendor's shop before delivery to substantiate the vendor's guarantee that they will operate under actual service pressure conditions.
- D. All motor-operated valves are equipped with handwheels so that motors can be declutched and valves cycled manually after installation.

#### **5.2.1.19 Field Run Piping**

A discussion of field run piping and associated simplified procedures for the design and installation of field run piping is presented in subsection 3.7A.3.14.

### **5.2.2 OVERPRESSURIZATION PROTECTION**

#### **5.2.2.1 Location of Pressure Relief Devices**

Drawing nos. H-26000 and H-26001 show the schematic location of pressure-relieving devices for the RCS.

### **5.2.2.2 Mounting of Pressure Relief Devices**

#### **5.2.2.2.1 Safety Design Bases**

The NPRS is designed:

- To prevent overpressurization of the nuclear system in order to prevent failure of the nuclear system process barrier due to pressure.
- To provide automatic depressurization for small breaks in the nuclear system so that the LPCI and the CS systems can operate to protect the fuel barrier.
- Such that the safety relief valve discharge piping can accommodate forces resulting from relief action and be supported for reactions due to flow at maximum relief discharge capacity so that system integrity is maintained.
- For testing prior to nuclear system operation and for verification of the operability of the pressure relief system.
- To withstand adverse combinations of loadings and forces resulting from operation during AOOs, accidents, or special events.

#### **5.2.2.2.2 Power Generation Design Bases**

The NPRS safety relief valves are designed to:

- Discharge to the primary containment suppression pool.
- Properly reclose following a plant isolation or load rejection so that normal operation can be resumed as soon as possible.

#### **5.2.2.2.3 Description**

The NPRS consists of 11 safety relief valves located on the main steam lines between the reactor vessel and the first isolation valve within the drywell. These valves protect against overpressure of the nuclear system.

The three-stage pilot-operated safety relief valve consists of two principle assemblies: a pilot valve section/air-operated section (top works) and the main valve section. Figure 5.2-2 shows the topworks for the three-stage valve. Reactor pressure is communicated through port (5) to the pilot (6). When the reactor pressure reaches the pilot setpoint, the pilot lifts and the disc (7) releases pressure to the second-stage disc chamber (1). The bellows holds the pilot disc open as long as the pressure is at the setpoint. The open pilot releases pressure to open the second-stage disc (2). The pressure opens the second-stage disc and forms part of the path that

## HNP-2-FSAR-5

releases the steam from chamber (8) out of port (9). The pressure in chamber (8) drops quickly and differential pressure across the main piston opens the main stage.

The principal innovations of the design, and how they relate to improved performance, are described as follows:

- A. The pilot valve is not connected directly to the main piston chamber (8). If there is leakage past the pilot, it comes from the inlet pressure port (5) and does not pass the pilot (6) unless the pressure setpoint is reached. This maintains the pressure in chamber (8). Tests have shown that if leakage occurs between port (5) and chamber (1), there is no appreciable effect on setpoint performance, and leakage will cause the valve to open and blow down the reactor.
- B. This approach eliminates the following problems that have occurred with pilot-operated safety relief valves in the past; these problems are:
  - Switch failures.
  - Short circuits in switch wiring.
- C. The air actuator is separate from the mechanical setpoint assembly but uses the same second-stage depressurization chamber, which opens the main valve.

The pressure-retaining topwork's components are Inconel 600 (ASME-SB-564). The pilot is one-piece solid Monel (MIL-N-24106), and its seats are Inconel (ASME-SB-166).

The safety relief valves provide two main protection functions:

- A. Overpressure Safety Operation

The valves function as safety valves and open to prevent nuclear system overpressurization.

- B. Depressurization Operation

The ADS valves open automatically as part of the ECCS for events involving small breaks in the nuclear system process barrier. The location and number of the ADS valves can be determined from drawing no H-26000.

The majority of events that lead to actuation of the primary system safety relief valves are those that initially or eventually produce a nuclear system pressure increase. These pressure increase events result from sudden reductions of steam flow while the reactor is operating at power.

Table 5.2-4 shows the set pressures of the safety relief valves used for pressure relief during occurrences of reactor pressure increase.

## HNP-2-FSAR-5

A list of the events that are expected to activate the primary system safety relief valves is presented in table 5.2-4. This table also lists the number of valves expected to operate during the initial blowdown of the valves and the expected duration of this first blowdown. The duration of each relief discharge should in most cases be < 5 s. Remote-manual actuation of the valves from the main control room (MCR) is provided to minimize the total number of these discharges, with the intent of achieving extended valve seat life.

The safety relief valves are designed to operate in the accident environments shown in table 3.9-34.

The environmental design requirements for the electrical portion of these valves are provided in the Plant Hatch Central File.

Each safety relief valve discharge is piped to the suppression pool. Each valve is of the pilot-operated type with the pilot spring-loaded to close. To prevent back pressure from affecting the main disc seat, the drywell is vented to the safety relief valve outlet piping.

The safety relief valves used in HNP-2 are manufactured by Target Rock. All valves are equipped with air accumulators and can be pneumatically operated. Any of the 11 valves can be pneumatically operated by manual action from the MCR. No particular setpoint applies to this method of operation as the operator may open a valve at his discretion for blowdown or test over a wide-pressure range.

Seven of the 11 safety relief valves are selected for ADS use. Initiation is automatic, after a 130-s time delay, from RPV water levels 1 and 3, together with high drywell pressure or a sustained RPV water level 1 signal after a 13-min time delay with an RPV water level 3 signal.

In the event of an anticipated transient without scram (ATWS), ADS operation can be manually inhibited. This enhances SLCS effectiveness by allowing a minimum RPV water level to be maintained and by preventing boron loss to the torus. This mode of operation is described in paragraph 7.3.1.2.2.

The remaining four valves are used for the low-low set (LLS) relief logic system.

The LLS system is an automatic safety relief valve control system which will initiate upon concurrent signals of any safety relief valve opening and high reactor pressure. The LLS controls preselected safety relief valves by use of the pneumatic actuator to open and close at predetermined setpoints which are lower than the pilot actuation setpoints. This results in a longer blowdown, lowered reactor pressure, and reduced number of safety relief valve actuations. The LLS system is described in subsection 5.5.17.

All 11 valves that function in a pressure-responsive (safety valve action) mode are listed in table 5.2-4.

The mechanical actuation mode is augmented by an electrical actuation logic used as a backup. Each steam relief valve can be actuated by its electric pilot solenoid valve. Each of the four steam lines is monitored by a pressure transmitter tied to three trip units (drawing nos. H-26000 and H-26001). The setpoints for the electrical backup are distributed among the 3 groups listed in table 5.2-4. Each of the three trip units is set to one of these group settings. The trip units



## HNP-2-FSAR-5

reset at a pressure below the mechanical closing pressure (drawing nos. H-24709 through H-24711). This redundant control capability is, in itself, nonsafety related and is isolated by fuses from the safety-related portion of the pilot valve's circuit that serves either the ADS or the LLS system. The equipment serving the backup functions is installed and procured as if it were required to be safety related, but is nonsafety related (reference 14).

For automatic actuation of the ADS safety relief valves, an external pneumatic operator is provided to open the second-stage pilot; the pressure in chamber (8) drops quickly and differential pressure across the main piston (4) opens the main stage valve. This operation permits the main disc to open at any valve inlet pressure above 100 psig. Once open, the main disc will stay open down to an inlet pressure of 50 psig with the second stage open. The control system for the actuator for depressurization operation is described in section 7.3.

Each safety relief valve discharges steam through a discharge line to a point below the minimum water level in the suppression pool. Steam flow through the safety relief valve discharge line is indicated by both temperature and pressure indicators located on the discharge lines. (See drawing no. H-26000.) The safety relief valve discharge piping is designed to limit valve outlet pressure to 40% of maximum valve inlet pressure with the valve wide open. Water in the line more than a few feet above suppression pool water level would cause excessive pressure at the valve discharge when the valve is again opened. For this reason, one or two vacuum relief valves are provided on each safety relief valve discharge line to prevent drawing an excessive amount of water up into the line as a result of steam condensation following termination of relief operation. The safety relief valves are located on the main steam line piping, rather than on the reactor vessel top head, primarily to simplify the discharge piping to the pool and to avoid the necessity of having to remove sections of this piping when the reactor head is removed for refueling. In addition, valves located on the steam lines are more accessible during a shutdown for valve maintenance.

Each of the safety relief valves provided for automatic depressurization is equipped with an air accumulator and check valve arrangement. These accumulators ensure that the valves can be held open following failure of the air supply to the accumulators. They are sized to be capable of opening the valves twice and holding them open against 70% of maximum allowable drywell pressure ( $0.70 \times 62 \text{ psig} = 43.4 \text{ psig}$ ). This is equivalent to four-to-five actuations of the pilot valve with the drywell at atmospheric pressure following the loss of pneumatic supply to the accumulator. Assuming an allowable leakage rate of  $4.5 \text{ sf}^3/\text{h}$ , the accumulator can provide 2 actuations during the first one-half hour following the loss of pneumatic supply to the accumulator. Only one actuation of any three ADS valves is needed for depressurization.

The elevated drywell pressure specified above is the result of the largest primary system break for which ADS is required. For smaller breaks in the drywell or for breaks outside the drywell, the accumulator availability will be considerably extended. For events not involving breaks in the drywell, accumulator capacity is sufficient to ensure multiple safety relief valve actuations for  $> 2 \text{ h}$ .

The ADS accumulators have a volume of  $5.48 \text{ ft}^3$  and each ADS valve requires  $25 \text{ in.}^3/\text{actuation}$ .

The NPRS depressurizes the nuclear system sufficiently to permit the low-pressure coolant injection (LPCI) and CS systems to operate as a backup for the HPCI system. Automatic

depressurization occurs when some of the safety relief valves are opened automatically. The signal for the safety relief valves to open and to remain open is based on simultaneous signals from:

- Drywell high pressure.
- RPV water levels 1 and 3 sustained for 130 s.
- Output pressure from at least one LPCI or one CS pump.

OR

- RPV water level 1 sustained for 13 min.
- RPV water level 3 sustained for 130 s.
- Output pressure from at least one LPCI or one CS pump.

Further descriptions of the operation of the automatic depressurization feature are found in sections 6.3 and 7.3.

The nuclear system can be depressurized manually if the main condenser is not available as a heat sink after reactor shutdown. The safety relief valves are operated by remote-manual controls from the MCR.

#### **5.2.2.2.4 Safety Evaluation**

The ASME Boiler and Pressure Vessel Code requires that each vessel designed to meet Section III be protected from overpressure. The code allows a peak allowable pressure of 110% of vessel design pressure. The Code specifications for safety valves require that:

- The lowest safety valve be set at or below vessel design pressure.
- The highest safety valve be set to open  $\leq 105\%$  of vessel design pressure.

The safety relief valves are set to open by self-actuation (overpressure safety mode - table 5.2-4). This satisfies ASME Code specifications for safety valves, because all valves open at  $< 1250$  psig (nuclear system design pressure). A nonsafety electrical backup to the mechanical relief is wired to open the safety relief valve at setpoints distributed among three groups (table 5.2-4).

Two major transients (the closure of all MSIVs and a turbine trip with a failure of the turbine steam bypass system valves to open) provide the most severe events resulting in a nuclear system pressure rise.

## HNP-2-FSAR-5

The transient produced by the closure of all MSIVs represents the most severe event resulting in a nuclear system pressure rise when direct scrams are ignored. The required safety valve capacity is determined by analyzing the pressure rise from this event. Original analyses assumed the plant to be operating at the turbine-generator design conditions at a maximum vessel dome pressure of 1020 psig. The analysis hypothetically assumes the failure of the direct isolation valve position scram. The reactor is shut down by the backup, indirect, high neutron flux scram. The analysis indicates that the design valve capacity is capable of maintaining adequate margin below the peak ASME Code allowable pressure in the nuclear system (1375 psig). The sequence of events assumed in this analysis was investigated to meet Code requirements and to evaluate the pressure relief system exclusively.

Increase of the initial reactor pressure relative to the initial value used in the overpressure report analysis has been investigated and shown to have the following effects. For the case of pressure scrams (failure of flux scram and direct trip scram), increasing the initial pressure progressively reduces the peak pressure reached because the initial pressure is closer to the scram setpoint, thus resulting in a more rapid termination of the transient.

For the case of flux scrams (failure of direct trip scram), increasing the initial pressure results in an increase of the peak pressure reached, which is less than half of the initial pressure increase as shown in figure 5.2-5. Thus, for HNP-2, the maximum transient pressure cannot increase by more than 10 psi; thus, the event would still be well within Code allowable limits.

It should also be noted that there is a very low probability that the initial pressure could be above the analyzed initial value during normal plant operation. This follows from the fact that the operating pressure setpoint control must be set during plant startup to the value which corresponds to the established turbine stop valve conditions required at 100% power operation. The vessel dome pressure increases automatically as power is increased, and any deviation would soon become obvious to the operator. Under the general requirements for protection against overpressure as given in Section III of the ASME Boiler and Pressure Vessel Code, credit can be allowed for a scram from the reactor protection system (RPS). In addition, credit is derived when determining the required safety relief valve capacity. The safety relief valve performance requirements were updated in references 18 and 19, and are reanalyzed each reload.

The design basis which employs the neutron flux scram for determining the required capacity of the pressure relieving dual-purpose safety relief valves is in full compliance with all requirements of ASME Section III, 1968 Edition including Addenda through Summer 1970. This design basis is conservative because the neutron flux scram is the second or backup signal to produce a reactor scram for the transient on which valve sizing is based; the reliable hard-wired scram from MSIV position switches having been assumed to fail. In addition, this design basis using the neutron flux scram is coupled with an availability index  $I_A \geq 0.99999$  for the overpressure protection system. The subject of safety relief valve sizing for the original plant design is treated more fully in supplement 5A.

Application of the direct position scrams in the design basis could be used since they qualify as acceptable pressure protection devices when determining the required safety relief valve capacity of nuclear vessels under the provisions of the ASME Code.

## HNP-2-FSAR-5

The loadings which the main steam pipe and relief valve discharge pipe impose on the safety relief valves include:

- The thermal expansion effects of the connecting piping.
- The dynamic effects of the piping due to earthquake.
- The jet force exerted on the safety relief valves during the first millisecond after the valve is opened and prior to the time steady-state flow has been established. (With steady-state flow, the dynamic flow reaction forces is self-equilibrated by the valve discharge piping.)
- The dynamic effect of the kinetic energy of the piston disc assembly when it impacts on the base casting of the valve.

In no case will allowable valve flange loads be exceeded nor will the stress at any point in the piping exceed code allowables for any specified combination of loads.

The automatic depressurization capability of the NPRS is evaluated in section 6.3.

Criteria for the selection of safety relief valves require that the valves:

- Meet the requirements of ASME Section III, 1968 through 1970 Addenda
- Qualify for 100% of nameplate capacity credit for overpressure protection function.
- Meet additional performance criterion such as response time, etc., necessary to provide relief functions.

The safety relief valve discharge piping is designed, installed, and tested in accordance with the ASME Code, Section III.

A temperature element is installed in the discharge line from each safety relief valve. Each temperature element is connected to a temperature recorder in the control room. When a safety relief valve opens, discharge line temperature increases and the temperature recorder provides a permanent record of valve actuation.

#### 5.2.2.2.5 Tests and Inspections

The safety relief valves are tested in accordance with the manufacturer's quality control procedures to detect defects and to prove operability prior to installation. The following tests are conducted:

- Hydrostatic test at specified test conditions as defined in the applicable code.
- Seat leakage test at 90% of set pressure.
- Set pressure test: The valve is pressurized with saturated steam, or other appropriate test medium, with the pressure rising to the valve set pressure.
- Response time test: Each safety relief valve is tested to demonstrate acceptable response time.

The valves are installed as received from the factory. The setpoints are adjusted, verified, and indicated on the valves by the vendor. Manual and remote opening circuitry of each safety relief valve is verified during the preoperational test program.

The valves are mounted on 6-in. diameter, 1500-lb primary service rating flanges. They can be removed for maintenance or bench checks and reinstalled during normal plant shutdowns. The external surface and seating of all safety relief valves are 100% visually inspected when the valves are removed for maintenance or bench checks.

#### 5.2.2.3 Report on Overpressure Protection

An overpressure protection report for the original plant design is provided in supplement 5A. The report supplies sufficient information and documentation to show compliance with all the requirements of Article 9 of the ASME Code, Section III, 1968, including summer 1970 addenda. Included also is the design basis for the sizing of the safety relief valves, the overpressure protection analysis, the analysis of the safety valve (RPS availability), and the effects of the vessel pressure transients of various combinations of valve failures.

As described in subsection 15.4.2, overpressure protection is considered a potentially limiting event for reloads and plant modifications that can increase the peak RPV pressure during pressurization events. As a result, overpressure protection was analyzed for extended power uprate core power of 2763 MWt<sup>(18)</sup> and is reanalyzed each operating cycle as part of the process for demonstrating compliance with the ASME Boiler and Pressure Vessel Code. The reload report that provides the analysis results for the reload applicable to the current FSAR revision is identified in table 15.1-1. The following discussion provides the results of the extended power uprate analysis that demonstrates the acceptability of the increase in rated power level.

The analysis for extended power uprate confirmed that closure of all MSIVs with a flux scram is the most limiting event associated with the overpressure protection requirements. In the

extended power uprate analysis of overpressure protection, the analysis methods described in subsection 15.1.7 were used. The 1-D transient analysis model was used to simulate the event. The key initial conditions and analysis assumptions are provided in table 5.2-5. Figure 5.2-3 shows the analysis results. The peak calculated RPV bottom head pressure is 1347 psig, which is well within the event acceptance limit of 1375 psig.

The impact of thermal power optimization (2804 MWt) and reactor operating pressure increase to 1060 psia has been evaluated with a peak calculated RPV bottom head pressure increase to 1349 psig, which is well within the event acceptance limit of 1375 psig.

### **5.2.3 GENERAL MATERIAL CONSIDERATIONS**

#### **5.2.3.1 Material Specifications**

The principal pressure-retaining materials and the appropriate material specifications for the RCPB components are listed in table 5.2-6.

#### **5.2.3.2 Compatibility With Reactor Coolant**

The construction materials exposed to the reactor coolant are:

- Solution-annealed austenitic stainless steels (both wrought and cast) Types 304, 304L, 316, and 316L.
- Nickel-base alloys, Inconel 600 and Inconel X750.
- Carbon steel and low-alloy pressure vessel steel.
- Some 400 series martensitic stainless steel, all tempered at a minimum of 1100°F.
- Colmonoy and Stellite hardfacing materials.

All of these construction materials are resistant to stress corrosion in the boiling water reactor (BWR) coolant. General corrosion on all materials except carbon and low alloy steel is negligible. Conservative corrosion allowances are provided for all exposed surfaces of carbon or low-alloy steels.

Contaminants in the reactor coolant are controlled to very low limits by the reactor water quality specifications. No detrimental effects will occur on any of the materials from allowable contaminant levels in the high purity reactor coolant. Radiolytic products in a BWR have no adverse effects on the construction materials.

#### **5.2.3.2.1 BWR Water Quality Effects On Sensitized Stainless Steel**

Boiling water reactor primary water contains 0.2 to 0.4 ppm oxygen during normal operation; these levels are inherent in the operating characteristics of the BWR. The oxygen content is the direct result of radiolysis and cannot be controlled.

Oxygen levels in the range of 8.0 to 100 ppm in highly accelerated screening tests have been shown to have some effect on the stress corrosion cracking susceptibility of furnace-sensitized stainless steel.

However, at the time of original construction, there was no substantiated evidence which indicated that these very severe screening tests could be used to predict performance of as-welded SS304 in normal BWR service.

Subsequent extensive laboratory testing, plus operating BWR experience, has shown that oxygen levels of 0.2 to 0.4 ppm can cause intergranular stress corrosion cracking (IGSCC) given sufficient stress and susceptible material condition. As-welded Types 304 and 316 have been found in some cases to be susceptible to IGSCC in the weld heat-affected zone in highly stressed joints. However, a large body of operating reactor experience has shown that at lower stresses these materials perform satisfactorily.

#### **5.2.3.2.2 Stress Corrosion Resistance of Type 316 Nuclear Grade**

For superior resistance to IGSCC in the BWR environment, Type 316 Nuclear Grade was used for systems such as the replacement recirculation system piping, stainless steel portions of RHR pipe, and RWCU pipe. This material has been demonstrated to be highly resistant to IGSCC.<sup>(6)</sup>

#### **5.2.3.3 Compatibility With External Insulation and Environmental Atmosphere**

The RCPB is insulated with an all-metal (stainless steel and aluminum) reflective-type insulation in compliance with Regulatory Guide 1.36 (February 1973). This type of insulation does not contain any silica, fluorides, or chlorides. It does not contribute to surface contamination, and it has no effect on the stainless steel components of the RCPB. The insulation is designed for a 40-year service life; however, this insulation is monitored so that actions are taken to provide reasonable assurance that the insulation is capable of fulfilling its intended function for 40 years and beyond.

The RRS piping, valves and pump casings, the stainless steel portions of the RHR, and the drywell portions of the RWC are covered with a glass fiber type insulation comprised of a flexible light-density, fibrous glass pad insulation, encapsulated in woven glass cloth forming a composite blanket. The blanket is then covered by stainless steel jackets and a mechanism for locating and identifying each weld under the insulation. Removable insulation sections are provided at all field welds to facilitate periodic inspection as required by the ASME Boiler and Pressure Vessel Code, Section XI rules for inservice inspection of nuclear reactor coolant systems. This insulation is designed for a 40-year service life; however, this insulation is

monitored so that actions are taken to provide reasonable assurance that the insulation is capable of fulfilling its intended function for 40 years and beyond.

#### **5.2.3.4 Chemistry of Reactor Coolant**

Reactor coolant chemistry controls are based upon EPRI TR-103515, "BWR Water Chemistry Guidelines," or latest approved industry guidance which was developed by an industry committee of chemistry and materials specialists and considered available field and laboratory data. EPRI TR-103515 provides a flexible approach to reactor coolant chemistry control and includes information on technical bases, options for different chemical control strategies, and data evaluation techniques. Subsection 18.2.1 provides further information regarding reactor coolant chemistry controls.

The TRM establishes upper limitations for reactor coolant chemistry during all operating modes.

#### **5.2.4 FRACTURE TOUGHNESS (HNP-1 AND HNP-2)**

The information provided in this section is applicable to both HNP-1 and HNP-2, unless specified otherwise.

##### **5.2.4.1 Compliance With 10 CFR 50, Appendix G, Fracture Toughness Requirements**

Nuclear Regulatory Commission (NRC) 10 CFR 50, Appendix G,<sup>(7)</sup> specifies fracture toughness requirements to provide adequate margins of safety during the operating conditions to which a pressure-retaining component may be subjected over its service lifetime. The limits for pressure and temperature (P/T) are required by 10 CFR 50, Appendix G, for three categories of operation:

- Hydrostatic pressure tests and leak tests (curve A).
- Core not critical heatup/cooldown (curve B).
- Core critical (curve C).

10 CFR 50, Appendix G, requires that P/T limit curves for the reactor pressure vessel (RPV) be at least as conservative as those obtained by applying the of the 1989 American Society of Mechanical Engineers (ASME) Code, Section XI, Appendix G<sup>(21)</sup> methodology.

HNP-1 and HNP-2 P/T limit curves for 54 effective full power years (EFPYs) are based upon the 1989 ASME Code, Section XI, Appendix G, methodology with the following two modifications:



## HNP-2-FSAR-5

### 1. Use of Code Case N-588.

This Case permits both the postulation of a circumferentially-oriented flaw in lieu of an axially-oriented flaw for the evaluation of RPV circumferential welds and the use of the revised formula for stress intensity factors due to pressure and thermal gradient for axial flaws.

### 2. Use of Code Case N-640.

This Case permits the use of the plane strain fracture toughness ( $K_{Ic}$ ) curve instead of the crack-arrest fracture toughness ( $K_{Ia}$ ) curve for RPV materials in determining the P/T limits.

HNP-1 and HNP-2 Technical Specification 3.4 show all three operating limit curves, including irradiation shift of the core beltline region curves to their positions at end-of-life (EOL).

#### **5.2.4.1.1 Method of Initial $RT_{NDT}$ Evaluation**

*For the purpose of setting the operating limits, the initial  $RT_{NDT}$  was determined from the toughness test data taken in accordance with requirements of the Code and the General Electric (GE) purchase specification to which the RPV was designed and manufactured. These toughness test data, Charpy V-Notch and drop-weight nil ductility transition temperature (NDTT), were analyzed to establish compliance with the intent of 10 CFR 50, Appendix G. Because all toughness testing needed for strict compliance was not required at the time of RPV procurement, some toughness results are not available. For example, longitudinal Charpy V-Notch, instead of transverse, was tested, usually at a single test temperature of + 10°F or + 40°F, for absorbed energy. Also, at the time, either Charpy V-Notch or NDTT testing was permitted; therefore, in some cases both tests were not performed as is currently required. To substitute for this absence of certain data, toughness property correlations were derived for the vessel materials in order to give a conservative estimate of  $RT_{NDT}$ , compliant with the intent of 10 CFR 50, Appendix G, criteria. These toughness correlations vary, depending upon the specific material analyzed, and were derived from NEDC-32399-P, "Basis for GE  $RT_{NDT}$  Estimation Method." <sup>(27)</sup>*

*In the case of vessel plate material (SA-533 Grade B, Class 1), the predicted limiting toughness property is either NDTT or transverse Charpy V-Notch 50 ft-lb temperature of - 60°F, whichever is greater. As a matter of practice, where NDTT results are missing, NDTT is estimated as the longitudinal Charpy V-Notch 35 ft-lb transition temperature. The transverse Charpy V-Notch 50 ft-lb transition temperature was estimated from longitudinal Charpy V-Notch data in the following manner. The lowest longitudinal Charpy V-Notch energy, if below 50 ft-lb, was adjusted to derive a longitudinal Charpy V-Notch 50 ft-lb transition temperature by adding 2°F per ft-lb to the test temperature. If the actual data equaled or exceeded 50 ft-lb, the test temperature was derived by interpolation or conservatively taken as the transition temperature. Once the longitudinal 50 ft-lb temperature was derived, an additional 30°F was added to account for the orientation change from longitudinal 50 ft-lb to transverse 50 ft-lb.*

*For forgings (ASTM A508, Class 2), the predicted limiting property is the same as for vessel plates, and the  $RT_{NDT}$  was estimated in the same way as for vessel plates.*

## HNP-2-FSAR-5

For the vessel weld metal, the predicted limiting property is the Charpy V-Notch 50 ft-lb transition temperature - 60°F, as BWR materials experience indicates that drop-weight NDT values are typically - 50°F or lower for weld materials. The Charpy V-Notch 50 ft-lb temperature was derived in the same way as for the vessel plate material, except the 30°F addition for orientation effects was omitted since there is no principal working direction in weld metal. When NDT values are available, they are also considered, and the  $RT_{NDT}$  is taken as the higher of either the NDTT or the 50-ft-lb temperature minus 60°F. When the NDTT is not available, the  $RT_{NDT}$  shall not be < -50°F, since lower values are not supported by the correlation data.

For the vessel weld heat-affected zone (HAZ) material, the  $RT_{NDT}$  was assumed the same as for the base material, since ASME Code weld procedure qualification test requirement, and post-weld heat treatment data indicate this assumption is valid.

Original closure bolting material (ASTM A540, Grade B23 or B24) toughness test requirements was for Charpy V-Notch 30 ft-lb energy at 60°F below the bolt-preload temperature. Considering 10 CFR 50, Appendix G, requirements of 45 ft-lb and 25 mil lateral expansion at the bolt-preload or lowest service temperature, some closure stud materials do not meet 45 ft-lb absorbed energy at + 10°F, and mil lateral expansion results were not reported. Based on fabrication data showing 30-ft-lb CVN energy at 10°F, the lowest service temperature for the closure studs is 70°F.

Calculated values of initial  $RT_{NDT}$  for HNP-1 are shown in table 5.2-9. GE provided similar data for HNP-2.

### 5.2.4.2 Adjusted Reference Temperature at 54 EFPYs

The effect upon adjusted reference temperature (ART) due to irradiation in the beltline materials is determined according to the methods specified in Regulatory Guide (RG) 1.99, Rev 2,<sup>(8)</sup> as a function of neutron fluence and the element contents of copper (Cu) and nickel (Ni). The specific relationship from RG 1.99, Rev 2 is:

$$ART = \text{Initial } RT_{NDT} + \Delta RT_{NDT} + \text{Margin}$$

where:

$$\Delta RT_{NDT} = CF * f^{(0.28-0.10 \log f)}$$

$$\text{Margin} = 2\sqrt{\sigma_i^2 + \sigma_{\Delta}^2}$$

CF = chemistry factor.

f = 1/4T fluence (n/cm<sup>2</sup>) divided by 10<sup>19</sup>.

$\sigma_i$  = standard deviation on initial  $RT_{NDT}$  which is taken to be 0°F.

$\sigma_{\Delta}$  = standard deviation on  $\Delta RT_{NDT}$ , 28°F for welds and 17°F for base material, except that  $\sigma_{\Delta}$  need not exceed 0.50 times the  $\Delta RT_{NDT}$  value.

$\Delta RT_{NDT}$  is a product of a chemistry factor and a fluence factor. The chemistry factor is dependent upon the amount of copper and nickel in the material and may be determined from tables in RG 1.99, Rev 2 or from surveillance data. The fluence factor is dependent upon the neutron fluence at the maximum postulated flaw depth. The margin term is dependent upon whether the initial  $RT_{NDT}$  is a plant-specific or a generic value and whether the chemistry factor (CF) was determined using the tables in RG 1.99, Rev 2, or surveillance data. The margin term is used to account for uncertainties in the values of the initial  $RT_{NDT}$ , the copper and nickel contents, the fluence, and the calculational procedures. RG 1.99, Rev 2 describes the methodology to be used in calculating the margin term.

The 54-EFPY peak fluence values for HNP-1 and HNP-2, used to calculate the 54 EFPYs 1/4T fluence values are provided in Table 5.2-7. The 54-EFPY 1/4T fluence is used to calculate the ARTs and the upper-shelf energy (USE) decrease for the beltline materials.

Beginning in December 2004, the methodology used by SNC/Hatch to calculate neutron fluence will comply with the requirements of Regulatory Guide 1.190.

#### 5.2.4.2.1 ART Versus EFPYs

Each beltline plate and weld  $\Delta RT_{NDT}$  value is determined by multiplying the CF from RG 1.99, Rev 2, determined for the Cu-Ni content of the material, by the fluence factor for the EFPYs being evaluated. The initial  $RT_{NDT}$ ,  $\Delta RT_{NDT}$  and margin are added to obtain the ART of the material. The 54-EFPY ART values for all of the beltline plates and welds are shown in table 5.2-7. The ART for the limiting beltline material in HNP-1 and HNP-2 is lower than the 200°F requirements of 10 CFR 50, Appendix G, and RG 1.99, Rev 2.

Figure 5.2-4 shows the ART for the lower-shell longitudinal welds as a function of operating time in EFPYs. The information in figure 5.2-4 is used to adjust the beltline curves in the operating limits.

#### 5.2.4.2.2 Upper-Shelf Energy at 54 EFPYs

Unirradiated upper-shelf data were not available for all the material heats. Due to the lack of specific pre-operational USE data, HNP-1 and HNP-2 were evaluated in GE Report "Plant Hatch Units 1 & 2 RPV Pressure Temperature Limits License Renewal Evaluation," GE-NE-B1100827-00-01,<sup>(23)</sup> to verify that GE Owners Group Report "10 CFR 50 Appendix G Equivalent Margin Analysis for Low Upper Shelf Energy in BWR/2 through BWR/6 Vessels, Rev 1," NEDO-32205-A,<sup>(15)</sup> margin analyses are applicable. The equivalent margin analyses demonstrate that the 10 CFR 50, Appendix G safety requirements are satisfactorily met for HNP-1 and 2. The NRC approved NEDO-32205-A<sup>(15)</sup> on December 8, 1993. The NEDO analysis meets the definition of a time-limited aging analysis (TLAA) pursuant to 10 CFR 54.3. (See section 18.5 for further information.)

### 5.2.4.3 Pressure-Temperature Curves

As stated previously, 10 CFR 50, Appendix G, requires P/T limits for three categories of operation listed in paragraph 5.2.4.1. The heat transfer characteristics for these three categories are:

- Isothermal conditions for the hydrostatic test (curve A).
- Insulated outside surface and metal temperature equaling the fluid temperature for 100°F/h heatup/cooldown thermal rate (curves B and C).

Heat transfer characteristics for the other transient conditions were based upon flow and temperature conditions in the thermal cycle diagrams. The condition that results in the highest required temperature for the limiting material determines the minimum allowable RPV temperature.

The following four vessel regions defined in the thermal cycle diagram should be monitored against the P-T curve operating limits:

- Core beltline.
- Closure flange.
- Upper vessel.
- Lower vessel.

The core beltline is the vessel location adjacent to the active fuel such that the neutron fluence is sufficient to cause a significant shift of  $RT_{NDT}$ . The closure flange region, which is discussed in detail in paragraph 5.2.4.3.2, includes the bolts, top head flange, vessel flange, and adjacent plates and welds. The remaining portion of the vessel (i.e., upper vessel and lower vessel) includes the shells; components such as the nozzles; support skirt; and stabilizer brackets.

Non-beltline regions are defined as the vessel locations that are remote from the active fuel and where the neutron fluence is not sufficient to cause any significant shift of  $RT_{NDT}$ . Non-beltline components include most nozzles, the closure flanges, some shell plates, the top and bottom head plates and the control rod drive (CRD) penetrations. The limiting BWR/4 components are the feedwater nozzle and the CRD penetration (bottom head). All other components in the non-beltline regions are categorized under one of these two components.

Under certain conditions, the minimum bottom head temperature can be significantly cooler than the beltline or closure flange region. These conditions can occur when the recirculation pumps are operating at low speed or are turned off, and during water injection through the CRDs. To account for these circumstances, individual temperature limits for the bottom head were established. Bottom head curves are not provided for the core critical curve, since during core critical operation, the entire RPV follows the steam saturation curve that is well to the right of the core critical curve.

## HNP-2-FSAR-5

The P-T curves for the heatup and cooldown operating conditions at a given EFPY apply for both the 1/4T and 3/4T locations. When combining pressure and thermal stresses, it is usually necessary to evaluate stresses at the 1/4T location (inside surface flaw) and the 3/4T location (outside surface flaw), because the thermal gradient tensile stress of interest is in the inner wall during cooldown and in the outer wall during heatup. However, as a conservative simplification, the thermal gradient stress at 1/4T is assumed to be tensile for both heatup and cooldown. This results in the approach of applying the maximum tensile stress at the 1/4T location. This approach is conservative for two reasons:

1. The maximum stress is used regardless of flaw location.
2. The irradiation effects cause the allowable toughness,  $K_{IR}$ , at 1/4T to be less than that at 3/4T for a given metal temperature. This approach causes no operational difficulties, since the BWR vessel metal temperature is at steam saturation conditions during normal operation, satisfying the heatup/cooldown curve limits.

Three vessel regions affect the operating limits:

- Core beltline.
- Non-beltline.
- Closure flange.

The beltline region minimum temperature limits are adjusted to account for vessel irradiation. The closure flange region limits are controlling at lower pressures primarily because of 10 CFR 50, Appendix G, requirements.

### **5.2.4.3.1 54 EFPY P-T Curve Evaluation Using Methodology of 10 CFR 50, Appendix G, with Allowance of Code Cases N-588 and N-640**

GE report GE-NE-B1100827-00-01<sup>(23)</sup> developed P-T curves in accordance with the 1989 ASME Code, Section XI, Appendix G; 10 CFR 50, Appendix G; and Welding Research Council Bulletin 175. The analysis performed for the original license term met the definition of a TLAA pursuant to 10 CFR 54.3. (See subsections 18.1.1 and 18.1.3, and section 18.5 for further information.)

Detailed stress analyses of the non-beltline components were performed for a BWR/6 plant specifically for the purpose of fracture toughness analysis. The analysis was considered appropriate for HNP-1 and HNP-2 since the plant-specific geometric values are bounded by the generic analysis. The generic value was adapted to the conditions at HNP-1 and HNP-2 by using plant-specific  $RT_{NDT}$  values for the RPV. The analyses took into account all mechanical loading and anticipated thermal transients. Transients considered include:

- 100°F/h startup and shutdown.
- Scram.

## HNP-2-FSAR-5

- Loss of feedwater heaters or flow.
- Loss of recirculation pump flow.
- All transients involving emergency core cooling injections.

Primary membrane and bending stresses, and secondary membrane and bending stresses due to the most severe of these transients were used according to the ASME Code to develop plots of allowable pressure (P) versus temperature relative to the reference temperature (T - RT<sub>NDT</sub>). Plots were developed for the limiting BWR/4 components; i.e., the feedwater nozzle and the CRD penetration (bottom head). The non-beltline curves were shifted based upon the most limiting initial RT<sub>NDT</sub> values for the appropriate non-beltline components.

RT<sub>NDT</sub> estimates were developed for the RPV materials in accordance with RG 1.99, Rev 2, for the different EFPY levels (table 5.2-10, sheets 1 and 2, for HNP-1 and HNP-2, respectively). The inputs used for the calculations were based upon table 5.2-7. The fluence estimates account for a rated thermal power (RTP) of 2804 MWt and reactor operating pressure increase to 1060 psia.<sup>(33) (34)</sup>

Structural Integrity Associates in "Structural Integrity Report SIR-00-037, Revised Pressure-Temperature Curves for Plant Hatch,"<sup>(24)</sup> developed the current HNP 1 and HNP-2 P/T curves using the same methodology contained in GE report "Plant Hatch Units 1 & 2 RPV Pressure Temperature Limits License Renewal Evaluation,"<sup>(23)</sup> modified to incorporate the methodology specified in ASME Code Cases N-588<sup>(25)</sup> and N-640<sup>(26)</sup>.

The current P-T curve methodology includes the following:

1. K<sub>IC</sub> was used in place of K<sub>IA</sub> in accordance with Code Case N-640:

$$K_{IC} = 20.734 e^{[0.02(T-ART_{NDT})]} + 33.2$$

where:

T = metal temperature at assumed flaw tip (°F).  
= conservatively set equal to the fluid temperature.

ART<sub>NDT</sub> = adjusted reference temperature for location under consideration and desired EFPY (°F).

K<sub>IC</sub> = critical stress intensity factor (ksi√in.). (Note that a maximum value of 200 ksi√in. is allowed per reference 21.)

2. For the beltline region, the thermal stress intensity factor, K<sub>IT</sub>, was calculated for a cooldown transient in accordance with ASME Code Case N-588:

$$K_{IT} = 9.53 \times 10^{-4} CR t^{2.5}$$

## HNP-2-FSAR-5

where:

$K_{IT}$  = thermal stress intensity factor (ksi $\sqrt{in.}$ ).

CR = transient cooldown rate ( $^{\circ}F/h$ ).

T = vessel wall thickness (in.).

3. For the beltline region, the allowable pressure, P, was calculated in accordance with ASME Code Case N-588 for an inside surface axial flaw:

$$K_{IP} = M_m \sigma_m$$

where:

$K_{IT}$  = membrane stress correction factor.

$\sigma_m$  = membrane-stress due to pressure (ksi).  
=  $PR/t$ .

P = pressure (ksi).

R = vessel radius (in.).

t = vessel wall thickness (in.).

$$\text{Thus, } P = K_{IP}t/(RM_m)$$

Note that Code Case N-588 is not applicable for the bottom head or upper vessel region, since the stress intensity factor relationships are for shells and heads remote from discontinuities.

All other aspects of the methodology detailed in reference 23 were maintained for the current P-T curves. The resulting P-T curves relate the minimum required reactor metal temperature to the RPV pressure.

### 5.2.4.3.2 Closure Flange Region

10 CFR 50, Appendix G, sets several minimum requirements for pressure and temperature in addition to those outlined in the ASME Code, based upon the closure flange region  $RT_{NDT}$ . In some cases, analysis results for other regions exceed these requirements, and closure flange limits do not affect the shape of the P-T curves. However, some closure flange requirements do impact the curves; e.g., HNP-1 and HNP-2 at low pressures.

The original ASME Code requirement for bolt-up was at qualification temperature ( $T_{30L}$ ) plus 60 $^{\circ}F$ . The Code used for the currently licensed P-T curves is the 1989 ASME Code, no addenda. The ASME Code requirements state in Paragraph G-2222(c) that, for application of full-bolt preload and RPV pressure up to 20% of hydrostatic test pressure, the RPV metal

## HNP-2-FSAR-5

temperature must be at  $RT_{NDT}$  or greater. The approach used for HNP-1 and HNP-2 for the bolt-up temperature was based upon a more conservative value of  $(RT_{NDT} + 60)$ , or the LST of the bolting materials, whichever is greater. The 60°F adder is included for two reasons:

1. The pre-1971 requirements of ASME Code, Section III, Subsection NA, Appendix G, included the 60°F adder.
2. Inclusion of the additional 60°F requirement above the  $RT_{NDT}$  provides the additional assurance that a flaw size between 0.1 and 0.24 in. is acceptable.

The limiting initial  $RT_{NDT}$  values for the closure flange region were 16°F for HNP-1 and 30°F for HNP-2 due to the flange, upper vessel and top head plate materials. The LST of the closure studs was 70°F for both units; therefore, the bolt-up temperature values used were 76°F (HNP-1) and 90°F (HNP-2). This conservatism is appropriate, because bolt-up is one of the more limiting operating conditions (high stress and low temperature) for brittle fracture.

10 CFR 50, Appendix G, Paragraph IV.A.2, including Table 1, sets minimum temperature requirements for pressure above 20% hydrostatic test pressure based upon the  $RT_{NDT}$  of the closure region. Curve A temperature must be no less than  $(RT_{NDT} + 90^\circ\text{F})$ , while Curve B temperature must be no less than  $(RT_{NDT} + 120^\circ\text{F})$ .

For pressures below 20% of preservice hydrostatic test pressure (312 psig) and with full-bolt preload, the closure flange region metal temperature is required to be at  $RT_{NDT}$  or greater as described above. At low pressure, the ASME Code allows the beltline and bottom head regions to experience even lower metal temperatures than the flange region  $RT_{NDT}$ . However, temperatures should not be permitted to be lower than 68°F for the reason discussed below.

The shutdown margin, provided in the HNP-1 and HNP-2 Technical Specifications, is calculated for a water temperature of 68°F. Shutdown margin is the quantity of reactivity needed for a reactor core to reach criticality with the strongest-worth control rod fully withdrawn and all other control rods fully inserted. Although it may be possible to safely allow the water temperature to fall below this 68°F limit, further extensive calculations would be required to justify a lower temperature. The 76°F (HNP-1) and 90°F (HNP-2) limits apply when the head is on and tensioned, and the 68°F limit applies when the head is off while fuel is in the vessel.

### 5.2.4.3.3 Core Critical Operation

The core critical operation curve (Curve C) is generated based upon the requirements of 10 CFR 50, Appendix G, Table 1, which requires that core critical P-T limits be 40°F above any Curve A or B limits when pressure exceeds 20% of the preservice system hydrostatic test pressure. Curve B is more limiting than Curve A; therefore, limiting Curve C values are at least Curve B plus 40°F for pressures above 312 psig.

Table 1 indicates that for a BWR with water level within normal range for power operation, the allowed temperature for initial criticality at the closure flange region is  $(RT_{NDT} + 60^\circ\text{F})$  at pressures below 312 psig. This requirement results in the minimum criticality temperatures of 76°F (HNP-1) and 90°F (HNP-2), based upon  $RT_{NDT}$  values of 16°F and 30°F for HNP-1 and



HNP-2, respectively. In addition, above 312 psig, the Curve C temperature must be at least the greater of  $RT_{NDT}$  of the closure region + 160°F or the temperature required for the hydrostatic pressure test (Curve A at 1105 psig). Therefore, this requirement causes a temperature shift in Curve C at 312 psig.

#### Operating Limits Versus Operating Conditions

Comparison of the pressure versus temperature limits in HNP-1 and 2 Technical Specification 3.4, with operating conditions for the most severe upset transient, shows the limits will not be exceeded during the design life of the vessel. Reactor operating procedures were established such that actual transients will not be more severe than those for which the vessel design adequacy has been demonstrated. Of the design transients, the upset condition producing the most adverse temperature and pressure condition anywhere in the vessel yields a minimum fluid temperature of 250°F in the bottom head and a maximum pressure peak of 1180 psig. A scram automatically occurs with initiation of this upset condition. For a temperature of 250°F, the maximum allowable pressure exceeds 1180 psig for the intended margin against nonductile failure. The maximum transient pressure of 1180 psig is, therefore, within the specified allowable limits.

#### **5.2.4.4 Compliance With 10 CFR 50, Appendix H, Reactor Vessel Material Surveillance Program Requirements**

Charpy impact specimens for the reactor vessel material surveillance program are of the longitudinal orientation consistent with the ASME requirements prior to the issue of the summer 1972 addenda and American Society for Testing and Materials (ASTM) E 185-73. Based on BWR operating experience, the amount of shift measured by these irradiated longitudinal test specimens is essentially the same as shift in an equivalent transverse specimen. The program includes three sets of specimens in the reactor. The specimens are manufactured from a plate actually used in the beltline region and a weld typical of those in the beltline region and thus represent base metal, weld metal, and the transition zone between base metal and weld.

Sufficient tensile and CVN specimens are provided in each of the three in-reactor sets and in the out-of-reactor set to measure strength, ductility, and toughness of each of the three materials (base, weld, heat affected zone), both in the unirradiated and irradiated conditions. In total, the program consists of 84 impact and 24 tensile specimens. In addition, there are 72 impact and 12 tensile archive and spare specimens.

The reactor vessel surveillance program specimens in HNP-2 meet the requirements of 10 CFR 50, Appendix H, and ASTM E 185-73, except for the following:

- A. The plate material is from the beltline material but was chosen at random from the three beltline plates rather than in accordance with E 185-73. The weld material is typical of the beltline welds but was not used in the beltline.
- B. The base metal specimens are longitudinal.

- C. Two of the three groups of impact specimens are in sets of 8 rather than sets of 12 specimens.

It is General Electric's technical judgment that none of these three variations affect the value of data from these specimens.

The Plant Hatch schedule for removal of the Unit 2 surveillance capsule is given by the integrated surveillance program (ISP) and is provided in table 5.2-3.

This program was developed by the BWR Vessel and Internals Project in 1998. The ISP combines all the participating US BWR surveillance programs into a single integrated program and adds data from a supplemental surveillance program (SSP). The ISP has been designed to meet the criteria for an integrated surveillance program in 10 CFR 50 Appendix H.

A matrix of capsules containing the representative weld and plate materials and the planned schedules for withdrawing and testing is provided in table 5.2-11. The overall ISP, as documented in references 28 through 32, replaces the existing material and surveillance monitoring programs with an integrated program using host reactor capsules containing the selected materials.

The aging management aspects of the reactor pressure vessel materials surveillance program are further discussed in subsection 18.2.17.

#### **5.2.4.4.1 Positioning of Surveillance Capsules**

The sealed capsules are not attached to the vessel but are in welded capsule holders. The capsule holders are mechanically retained by capsule brackets welded to the vessel cladding. The capsule holder brackets allow the capsule holder to be removed at any desired time in the life of the plant for specimen testing. These brackets are designed, fabricated, and analyzed to the requirements of Section III of the ASME Code.

#### **5.2.4.4.2 Time and Number of Dosimetry Measurements**

Separate neutron dosimeters were provided so that fluence measurements could be made at the vessel ID during the first fuel cycle to verify the predicted fluence at an early date in plant operation. Dosimetry is also available in each surveillance capsule to measure flux over longer operating periods and evaluate effects of changing core power distribution, if any.

#### **5.2.4.5 Reactor Pressure Vessel Annealing**

Inplace annealing of the RPV because of radiation embrittlement is not necessary, since shifts in transition temperature and USE values are within the allowables of 10 CFR 50, Appendix G.

## 5.2.5 AUSTENITIC STAINLESS STEEL

### 5.2.5.1 Cleaning and Contamination Protection Procedures

*During fabrication, the stainless steel surfaces were cleaned by mechanical methods (grinding, brushing with stainless steel brushes, machining), solvent cleaners, or chemical cleaning agents. Caustic cleaners and other solvents and cleaners containing halogens, sulphides, or other harmful constituents were not used for cleaning parts that contain crevices or entrapment areas.*

*Stainless steel materials were not pickled unless they were in the solution heat-treated condition. Stainless steel components were suitably packaged and protected during shipment, storage, and construction to prevent contamination from potential corrosive agents. The reactor vessel or vessel parts containing stainless steel components were not stored outside without full protection to prevent rainwater or condensate moisture from washing or collecting on stainless surfaces.*

*Immediately prior to hydrostatic testing of the reactor vessel, all interior surfaces that would contact water during the hydrostatic test, all nozzle fixtures, all piping to be used to fill the vessel, and all external surfaces of stainless and nickel-chrome-iron components were cleaned of all halogen bearing soils, grease, oil, penetrant materials, inks, chalk or crayon marks, and all dirt and debris. Testing and operation of components and systems were performed using either inhibited water or high-purity demineralized water to avoid exposure to detrimental contaminants.*

*All loose dirt and other foreign materials were removed by sweeping or vacuuming. Deposits of grease and oil were removed with an approved solvent. Tightly adhering soils were removed with the aid of stainless steel brushes or by grinding. The vessel interior was then cleaned with high-pressure potable water containing corrosion-inhibiting additives. The vessel and water temperature was < 180°F during the cleaning step, the water pressure was a minimum of 6,000 psi, and the water contained < 35 ppm chlorides, 10 ppm fluorides, and 1 ppm sulfides.*

*The cleanliness of the vessel was checked visually and with the aid of an ultraviolet light to ensure the vessel was clean. The ultraviolet examination was conducted under darkened conditions with a lamp providing a minimum intensity of 100 fc. All fluorescent materials were removed from the surface. All plumbing, welding, or testing work was performed prior to cleaning. During any entry of personnel into the vessel after cleaning was completed, shoe covers were worn and clean conditions were maintained in the reactor vessel.*

### 5.2.5.2 Solution Heat Treatment Requirements

Replaced recirculation piping, stainless steel portions of RHR, and replaced portions of RWC piping are solution annealed by heating to a temperature between 1900 and 2000°F (metal temperature) and are held at this temperature for a minimum of 15 min with a maximum time at temperature of 30 min. This is followed by quenching in water to a temperature below 800°F within 3 min following the heating.

Replaced recirculation, RHR, and RWC fittings and subassemblies are solution annealed by heating to a temperature between 1900 and 2100°F (metal temperature) and are held at this

temperature for a minimum of 15 min/in. of thickness but not < 15 min regardless of thickness. This is followed by quenching in water to a temperature below 800°F within 3 min following the heating.

Solution heat treatment of other austenitic stainless steel consisted of heating the material to 1900 to 2100°F, holding for 1/2 h/in. of thickness (minimum 1/2 h) and quenching in water to below 800°F. Nickel-chrome-iron alloys, which may have been subjected to temperatures in excess of 1700°F exclusive of welding, were rechecked for grain size (for information) and specified mechanical properties (for acceptance).

#### **5.2.5.3 Material Inspection Program**

*The raw material inspection program used to verify that the unstabilized austenitic stainless steels were properly solution heat treated and not susceptible to intergranular attack is as follows:*

- A. For replaced recirculation system piping following solution heat treatment and pickling, material representatives of every heat treat lot were tested for sensitization by a modified version of ASTM A 262, Practice A and examined for intergranular attack.*
- B. For other austenitic stainless steel components, no testing was required if valid documentation was furnished proving that the stainless steel had been given a suitable water quench from a temperature above 1800°F, and no subsequent heating had been employed.*
- C. If documentation to verify adequate water quenching was not available, the material was required to be tested in accordance with ASTM A 262, Practice E.*

#### **5.2.5.4 Unstabilized Austenitic Stainless Steels**

The unstabilized grades of austenitic stainless steels with a carbon content > 0.03% used for RCPBs are Types 304 and 316.

#### **5.2.5.5 Avoidance of Sensitization**

Wrought and cast austenitic stainless steels used for the reactor vessel system (except for vessel cladding) were supplied in the solution heat-treated condition and, thereafter were not subjected to any heating above 800°F, except for welding or resolution heat treatment.

Sensitization of wrought austenitic stainless steel was avoided for piping and RCPB pumps and valves. Austenitic stainless steel was considered to be severely sensitized if it was heated by means other than welding within the range of 800°F to 1800°F, regardless of a subsequent cooling rate. Such stainless steel was required to either pass the requirements of ASTM A 262, Practice E, or be resolution heat treated. When heated above 1800°F, the austenitic stainless steel was required to be rapidly cooled through the range 1800°F to below 800°F by water

quench to produce an acceptable grain structure. Where severe sensitization could not be avoided, such as for parts which were required to be hard surfaced, low carbon, type 304 cast material was used.

#### **5.2.5.5.1 Welding Controls**

During stainless steel welding, the interpass temperature is controlled to a maximum of 350°F. Weld layers are built up uniformly along the joint and across the width of the joint. Block welding is not permitted, and weld stops and starts are staggered. Welds are cleaned free of slag, flux, and other foreign material prior to depositing subsequent beads.

Austenitic stainless steel filler metal for seam welds of recirculation piping, stainless steel portions of RHR, and replaced portions of RWC components were required to contain 5 FN (Ferrite Number) in the undiluted weld deposit. For butt welds and attachment welds that would not subsequently be solution heat treated, the filler metal was required to contain 8.0 FN in the undiluted weld deposit. Other austenitic weld materials are selected and controlled to produce welds which contain a minimum of 3% ferrite. Ferrite content is determined by one of the following methods:

- Actual chemical analysis compared to the Schaeffler and Schoeffer analysis.
- Magne gauge.
- Metallography.
- Severn gauge.
- Ferrite scope.

#### **5.2.5.6 Retesting Unstabilized Austenitic Stainless Steels Exposed to Sensitizing Temperatures**

Welding procedures require control of heat input to avoid severe sensitization and susceptibility to intergranular attack. No retesting of as-welded unstabilized austenitic stainless steel is required or planned.

Unstabilized austenitic stainless steel subjected to heat in the range of 800°F to 1500°F by any means other than welding is required to be retested in accordance with ASTM A 262, Practice E.

#### **5.2.5.7 Control of Delta Ferrite**

The procedures and requirements used for the control of delta ferrite in austenitic stainless steel welds are discussed in paragraph 5.2.5.5.

#### **5.2.6 PUMP FLYWHEELS**

Pumps with flywheels are not used in HNP-2.

#### **5.2.7 REACTOR COOLANT PRESSURE BOUNDARY LEAK DETECTION SYSTEM**

##### **5.2.7.1 Design Bases**

The LDS is designed to:

- Detect the occurrence of, and alert operating personnel to, abnormal leakage from the RCPB.
- Detect leakage in the vicinity of the ECCS pumps and pump suction piping.
- Detect leakage from the nuclear process barrier at selected locations outside the primary containment.

##### **5.2.7.2 Leak Detection Methods**

The RCPB LDS consists of temperature, pressure, flow, and fission-product sensors with associated instrumentation and alarms. This system detects and annunciates abnormal leakage in the following systems:

- Main steam.
- RWC.
- RHR.
- RCIC.
- Reactor feedwater.
- HPCI.
- Reactor recirculation.

A summary of isolation and/or alarms of affected systems and the methods used appears in table 5.2-8.

Small leaks are generally detected by temperature and pressure changes, fillup rate of drain sumps, and fission product concentration inside the primary containment. Large leaks are also detected by changes in reactor water level and changes in flowrates in process lines.

#### **5.2.7.2.1 Detection of Abnormal Leakage Within the Primary Containment**

Leaks within the primary containment are detected by monitoring for:

- Abnormally high pressure and temperature within the primary containment.
- Rapid fillup and/or slow pump-down of equipment and floor drain sumps.
- Excessive temperature difference between the inlet and outlet cooling water for the primary containment equipment coolers.
- A decrease in the RPV water level.
- Changes in hydrogen and oxygen concentration (subsection 6.2.5).
- High flowrate in process lines.
- High particulate and gaseous radiation levels in the primary containment atmosphere.

Temperatures within the primary containment are monitored at various elevations. (Also, the temperature of the air to the atmosphere coolers is monitored.) Excessive temperature in the primary containment, increased drain sump activity, and increased fission product radiation level are annunciated by alarms in the MCR. RPV water levels 2 and 3 and high drywell pressure are annunciated by alarms in the MCR and cause automatic isolation of the containment. In addition, RPV water level 1 isolates the main steam lines and the main steam line drain and reactor water sample valves.

The systems within the drywell share a common area; therefore, their LDSs are common. Each LDS inside the drywell is designed with a capability of detecting leakage less than established leakage rate limits.

#### **5.2.7.2.2 Leak Detection**

The drywell floor drain sump measurement monitors the normal design leakage collected in the floor drain sump. This leakage consists of leakage from the CRDs, valve flange leakage, closed cooling water, air cooler drains, and any leakage not connected to the equipment drain sump.

## HNP-2-FSAR-5

Leakage from the RCPB inside the drywell may be detected by any one of a variety of independent monitored variables, such as drywell pressure and temperature, sump level changes, and containment gaseous and particulate radioactivity levels. While some of these systems are not redundant in themselves, it is not postulated that any one event could render all means of leak detection inoperable.

The normal operational method for monitoring leakage in the drywell is with the drywell floor drain sump LDS. The Technical Specifications require the drywell floor drain sump LDS to be operable whenever the plant is operating.

The drywell equipment drain sump measurement monitors identified leakage collected in the equipment drain sump. The sump receives condensate drainage from pump seal leakoff. Collection in excess of background leakage would indicate reactor coolant leakage. Equipment sump drain temperature is also monitored and thus will indicate leakage.

Leakage from various equipment located in the drywell is piped directly to the drywell equipment drain sump. The sump itself is covered and all of the various drain lines are open only to the equipment they serve, thereby forming a closed system which receives leakage only from identified sources.

The drywell floor drain and equipment drain sumps are provided with redundant level transmitters that supply remote level indications. The level indicators are equipped with switches that start and stop the pumps as required and provide signals to the LDS. The LDSs have two timers that are energized and deenergized by the sump level switches to determine if the leakage rate into the sump is in excess of the expected design value. One timer is started each time the sump is pumped down to the low-level setpoint, at which time the sump pumps are automatically stopped. Should the sump fill up to the high-level setpoint (automatically starting the sump pumps) prior to the expiration of time on the timer, an alarm is sounded in the MCR indicating a leakage rate into the sump in excess of the design limit.

A second timer is started when the sump pumps are started on high level. Should this timer run out prior to the sump level reaching the low-level pump cutoff setpoint, an alarm is sounded in the MCR indicating a leakage rate into the sump in excess of the design limit.

Additionally, a flow indicator is installed in the discharge of the drywell equipment sump pumps which provides sump pump flow indication in the MCR.

The drywell floor drain sump has a smaller volume than the drywell equipment drain sump to provide for a more rapid response to the LDS for unidentified leakage. All drains inside the drywell empty into one of these two sumps, and since unidentified leakage is excluded from the drywell equipment drain sump, both identified and unidentified leakage can be quantified.

In the operating range of sump level, the relationship between leakage and level is 13 gal/in. for the floor drain and 22 1/2 gal/in. for the equipment drain. All leakage inside the drywell will flow directly either to the floor drain or to equipment drain sumps, depending on the source of leakage. As shown on drawing no. H-26202, the drywell floor is provided with floor drain fittings spaced uniformly around the reactor vessel pedestal which drain directly to the floor drain sump. The drywell floor is finished such that these floor drain fittings are located at the low points. The



## HNP-2-FSAR-5

floor drain sump, located inside the reactor vessel pedestal, is provided with a grated cover so that any leakage in that area will flow directly into the sump.

There are no reservoirs in the drywell which could retain enough leakage to prevent the actuation of the LDS.

Drawing no. H-26202 shows the drywell floor arrangement and the locations and elevations of the drywell sumps and instrumentation used for leak detection. Level transmitters 2G11-N074 A and B and N075 A and B are the only components of the drywell LDS actually located inside the drywell. The remainder of the equipment is located in the reactor building and the MCR.

The primary containment is maintained at a slightly positive pressure during reactor operation. The pressure fluctuates slightly as a result of barometric pressure changes and out-leakage. A pressure rise above the normally indicated values indicates the presence of a leak within the drywell.

The drywell cooling system recirculates the primary containment atmosphere through heat exchangers (air coolers) to maintain the primary containment at its average operating temperature of 135°F. The drywell average air temperature limit for normal operation is  $\leq 150^\circ\text{F}$ . The primary containment chilled water system provides cooling water to the air coolers. An increase in primary containment atmosphere temperature would increase the temperature rise in the cooling water passing through the coils of the air coolers. Thus, the temperature difference increase between inlet and outlet to the air coolers indicates the presence of a reactor coolant or steam leakage. Also, a drywell ambient temperature rise above normal may indicate the presence of reactor coolant or steam leakage.

Radiation monitoring of the primary containment is provided as required by Criterion 64 of 10 CFR 50, Appendix A, and Regulatory Guide 1.45, (May 1973), as clarified in Appendix A, Regulatory Guide Evaluations. The post-accident radiation monitoring system (RMS) is part of the redundant LDS. Information from this system is used in conjunction with the drywell floor drain sump level indicating system. It is provided to improve the total drywell LDS diversity and sensitivity. The design basis, the associated instrumentation, and maintenance requirements for the leak detection RMS are presented in section 11.4. The post-accident radiation monitors discussed in paragraph 11.4.2.8.12 are redundant, qualified Seismic Category I, and would be available to detect coolant leakage should the drywell sump LDS become inoperable, thus assuring the capability of the LDS to detect unidentified leakage.

Since most of the parameters listed in table 5.2-8 are not a true measurement of leakage but rather a certain indication that would be expected to accompany a fluid system leak, there is not a direct correlation in each case between leakage rate and the monitoring system indication.

The containment atmosphere fission product monitors and the post-accident radiation monitors are capable of detecting leakage from the RCPB.

The equipment area temperature and high differential temperature alarms are set at the lowest temperature consistent with normal operational variations in order to provide early indication of a possible leak. These alarms and their setpoints are discussed in subsection 7.6.9

**5.2.7.2.2.1 Reactor Vessel Head Seal Leak Detection.** The RPV head is provided with double seals with a pressure switch sensing the pressure between the seals. High pressure is indicative of leakage past the inner seal and activates an annunciator in the MCR. Leakoff between the seals is piped to the equipment drain sump.

**5.2.7.2.2.2 Recirculation Pump Seal Leak Detection.** There are two recirculation pump LDSs, one for each of the pumps in the recirculation loop. Each LDS monitors the flowrate (leakage) past its associated pump's shaft by measuring the pressure within the seal cavity. There are two monitored seal cavities per pump.

The recirculation pump LDS consists of two types of monitoring circuits. The first of these monitors the pressure levels within the seal cavities, presenting the plant operator with a visual display of the pressure in each cavity. The second type of circuit monitors the rate of liquid flow from the seal cavities. The pressure levels within seal cavity no. 1 and seal cavity no. 2 are measured with identical instrumentation.

All condensate flowing past the recirculation pump seal packings and into the seal cavities is collected and sent by one of two drain systems to the drywell equipment drain sump for disposal. The first system drains the major portion of the condensate collected within the no. 2 seal cavity. The condensate flowrate through the drain system is measured (high/low) by a flow switch. The point at which the microswitch closes can be adjusted so that switch actuation occurs only above or below certain flowrates. Excessively high or low flowrates through this drain system activate the pump seal staging flow annunciator in the MCR.

**5.2.7.2.2.3 Safety Relief Valve (ADS) Leak Detection.** A temperature element (sensor) is used to detect leakage past each safety relief valve. These temperatures are recorded on a multipoint recorder in the MCR. Normally, all safety relief valves are in the shut-tight condition and remain at about the same temperature.

Steam passage through the valve elevates the sensed temperature at the exhaust, causing an abnormal temperature reading on the recorder. Microswitch contacts on the recorder close on high temperature to activate the safety/blowdown valve leaking annunciator in the MCR.

### **5.2.7.2.3 Detection of Abnormal Leakage Outside the Primary Containment**

Outside the primary containment, the piping within each system monitored for leakage is in compartments or rooms, separate from other systems where feasible, so that leakage may be detected by area temperature indications. Each LDS discussed below is designed to detect leak rates that are less than the established leakage limits. The method used to monitor for leakage for each RCPB component is shown in table 5.2-8.

**5.2.7.2.3.1 ECCS Suction Lines Leak Detection.** The purpose of this LDS is to provide information which would allow the closing of the valve in a broken ECCS suction line.

A description of the LDS employed is presented in subsection 9.3.3.

**5.2.7.2.3.2 Reactor Building Sump Flow Measurement.** A description of the reactor building sump flow measurement system utilized for leakage detection is discussed in subsection 9.3.3.

**5.2.7.2.3.3 Visual and Audible Inspection.** Accessible areas are inspected periodically. The temperature and flow indicators discussed above are monitored regularly. Any instrument indication of abnormal leakage is investigated.

**5.2.7.2.3.4 Reactor Water Cleanup System Leak Detection.** Leakage in the high temperature process flow of the RWC system external to the primary containment is detected by temperature-sensing elements. The RWC rooms are maintained at a negative pressure. Resistance temperature detectors (RTDs) are located near the entrances to the rooms and inside the rooms to measure temperature differential. RTDs are also located to measure the inlet and outlet air temperature differential of the RWC pump and heat exchanger area cooling unit. Local ambient temperature is also sensed by one of these RTDs. Cables are routed from these RTDs to the trip units in the MCR. A high cleanup room temperature rise or a differential temperature rise actuates automatic isolation of the RWC system.

The RTDs and associated trip units are part of the analog transmitter trip system (ATTS), which is described in section 7.8.

In addition, thermocouple-type sensors located near the RTDs are coupled with temperature switches and an indicating recorder in the MCR. Alarms in the MCR annunciate a temperature rise corresponding to excessive leakage.

In addition to the temperature detection method, leakage is detected by means of a flow comparison between RWC system inlet and outlet. If the inlet flow exceeds outlet flow by at least 79 gal/min for more than 45 s, an alarm is actuated, and the RWC system is isolated automatically. However, this differential flow monitoring of the RWC system leakage detection is not required to mitigate a design basis event.

**5.2.7.2.3.5 Main Steam Line Leak Detection Outside Primary Containment.** The main steam lines are continuously monitored for leaks by the main steam line LDS. Steam line leaks will cause changes in at least one of the following monitored operating parameters:

- Sensed temperature.
- Flowrate.
- Low water level in the RPV.

If a leak is detected, the detection system responds by triggering an annunciator in the MCR and, depending upon the activating parameter, initiates steam line isolation action.

The temperature around the main steam line is monitored by RTDs placed along the main steam line piping in the main steam pipe chase. Cables are routed from these RTDs to trip units in the MCR. The contacts of each set of trip units are wired for coincidence closure of the MSIVs on high temperature. This instrumentation is part of the ATTS, which is described in section 7.8. In addition, thermocouples are mounted at the inlet and outlet of the steam tunnel to measure the tunnel ambient and temperature difference and to alarm on temperature rise in the MCR. There are also thermocouples and temperature-indicating switches in the turbine building which sense the ambient temperature in the vicinity of the main steam lines. An excessive temperature rise isolates the main steam lines.

The flowrate monitoring components of the main steam line leak detection system consist of a set of four differential pressure transmitters and trip units for each main steam line. The outputs of the differential pressure trip units are connected to components of the nuclear steam supply shutoff system to provide the main steam line high flow signal for main steam line isolation (table 7.3-9). (The main steam line flow differential pressure relays associated with the RCIC isolation are time delay relays which prevent isolation of the RCIC on high steam line flow for a finite period after the signal has been received.)

Reactor water level and main steam line tunnel area temperature are monitored by circuits associated with the RPV and primary containment isolation system to indicate the presence of a steam leak. The coverage of this discussion extends only to the sensing instrumentation and not to circuit arrangement or response. Such information may be found in the description of the RPV and primary containment isolation system.

Under conditions of normal reactor operation at constant power, reactor water level should remain fairly constant at its programmed level since the rate of steam mass flow leaving the boiler is matched by the feedwater mass flowrate into the RPV. However, given a condition of continued steam leakage from the closed system, the condensate reservoir level and the reactor water level decrease.

Reactor water level is monitored by four level transmitters and trip units of the containment isolation system in addition to the normal complement of process monitoring instruments. Reactor water level falling below the predetermined minimum allowable level (level 1) results in switch actuation and subsequent containment isolation system response.

**5.2.7.2.3.6 Residual Heat Removal System Leak Detection.** The RHR leak detection components are divided into two groups; one sensitive to RHR system leaks external to the primary containment and the other group sensitive to system leaks internal to the primary containment. Leak detection instruments of the first group utilize devices which are sensitive to temperature and which monitor area ambient and differential temperatures. The second group of instruments monitors the pressure and temperature level within the drywell. Additionally, liquid leakage from system components contained within the drywell is collected, and the rate of accumulation is measured. The ambient and differential temperature monitoring circuits consist of thermocouples, 36 temperature switch point modules, 2 selector switches, and 2 meters. Of

the 36 monitored signals available, only 4 are from the RHR system. The other 32 are used to monitor temperatures of other reactor subsystems.

The thermocouples are mounted in their individual holders which, in turn, are mounted in the RHR equipment area such that they are sensitive primarily to the air temperature. The four-point modules, the selector switches, meter modules, and meters are mounted on the leak detection panel in the MCR. A high ambient temperature lights the point module alarm indicator on the leak detection panel and sounds the high ambient temperature alarm.

**5.2.7.2.3.7 Reactor Core Isolation Cooling and High-Pressure Coolant Injection Systems.** Leaks in the RCIC or HPCI systems are detected by differential pressure transmitters and trip units and by local temperature detectors which are functionally the same as those described for main steam line leak detection.

Downstream of the differential pressure elements, gross leaks in the system are detected by a set of two differential pressure transmitter and trip units sensing differential pressure across an elbow. Flow in excess of specified limits isolates the system and activates an alarm in the MCR. Gross leaks upstream of the differential pressure elements may be picked up by a set of four pressure transmitter and trip units. The primary function of these trip units is to detect low reactor pressure and to provide HPCI or RCIC turbine isolation signal.

The turbine exhaust vent lines of the HPCI system and the RCIC system are monitored for pressure by means of four pressure transmitter and trip units. A high-pressure signal isolates the system and activates an alarm in the MCR. Temperature sensors are located in the inlet to emergency coolers for measuring room ambient temperature in the event of steam leakage. High temperature is annunciated in the MCR and isolates the system.

The power required to operate the timer logics associated with the RCIC and HPCI LDSs is continuously monitored. Loss of power is identified by the RCIC logic power failure or HPCI logic power failure annunciators in the MCR.

Temperature elements are also located near the inlet and outlet of the ventilation ducts of the suppression pool area and near the steam lines. High differential temperature between the inlet and outlet ventilation ducts or high ambient temperature near the steam lines is annunciated in the MCR and actuates a timer. Timer actuation notification is provided by a separate MCR annunciator. This annunciator will notify the operator of possible system isolation. If the temperature rise is not reduced before the timer has run out, the RCIC and HPCI systems are isolated automatically. The alarm and the timer are activated by the temperature rise corresponding to steam leakage. Once the alarm is actuated, manual isolation of the system is permitted.

The LDS instrumentation is part of the ATTS, which is described in section 7.8.

**5.2.7.2.3.8 Feedwater Leak Detection.** A separate feedwater LDS is not provided. Leaks from the feedwater lines will be detected by one or a combination of the following methods:

- Primary containment sumps high flowrate.
- Primary containment air cooler cooling water high temperature differential.
- Primary containment high pressure.
- Primary containment high temperatures.
- Reactor building sump high flowrate.

### **5.2.7.3 Indication in Main Control Room**

Details of the LDS indications are included in paragraph 5.2.7.2, subsection 7.6.9, and section 7.8.

### **5.2.7.4 Limits for Reactor Coolant Leakage**

#### **5.2.7.4.1 Total Leakage Rate**

The total leakage rate consists of all leakage, identified and unidentified, that flows to the drywell floor drain and equipment drain sumps. The criterion for establishing the total leakage rate limit is based on the makeup capability of the RCIC systems and is independent of the reactor feedwater system, normal ac power, and the ECCS. The total leakage rate limit is established at 30 gal/min averaged over any 24-h period.

The total leakage rate limit is also set low enough to prevent overflow of the drywell sumps. The equipment drain sump and the floor drain sump, which collect all leakage, are each drained by two 100-gal/min pumps. The total leakage rate limit for both sumps of 30 gal/min is set below the removal capacity of one pump in each sump.

#### **5.2.7.4.2 Identified Leakage**

The pump packing glands, valve stems, and other seals in systems that are part of the nuclear system process barrier and from which a normal design leakage less than the 25 gal/min limit is expected are provided with drains or auxiliary sealing systems. NSSS valves and pumps inside the drywell are equipped with double seals and packings.

Leakage from the primary RRS pump seals is piped to the equipment drain sump as described in subsection 5.5.1. Leakage from the main steam line safety relief valves is identified by temperature sensors that transmit to the MCR. Any temperature increase above the drywell ambient temperature detected by these sensors indicates valve leakage. Leakage from the RPV head flange gasket is detected by a pressure switch, as described above.

Thus, the leakage rates from pumps, valve seals, and the RPV head seal are measurable during plant operation. These leakage rates, plus any other leakage rates measured while the drywell is open, are defined as identified leakage rates.

#### 5.2.7.5 Unidentified Leakage

The unidentified leakage rate is the portion of the total leakage rate received in the drywell sumps that is not identified as previously described. A threat of significant compromise to the nuclear system process barrier exists if the barrier contains a crack that is large enough to propagate rapidly. The unidentified leakage rate limit must be low. This is because the unidentified leakage rate might be emitted from a single crack in the nuclear system process barrier.

An allowance is made for normal plant operation leakage that does not compromise barrier integrity and is not identifiable. The unidentified leakage rate limit is established at a 5-gal/min rate to allow time for corrective action before the nuclear system process barrier could be significantly compromised. This proposed limit is based on a calculated flow from a critical crack in a primary containment system pipe.

##### 5.2.7.5.1 Sensitivity and Response Time

The LDS is able to detect unidentified leakage of 5 gal/min within 1 h.

##### 5.2.7.5.2 Length of Through-Wall Flaw

Experiments conducted by General Electric and Battelle Memorial Institute (BMI) permit an analysis of critical crack size and crack opening displacement. This analysis is related to axially oriented through-wall cracks. (References 3 and 4 were used to develop the critical crack analysis.)

**5.2.7.5.2.1 Critical Crack Length.** Both the General Electric and BMI test results indicate that theoretical fracture mechanics formulas do not predict critical crack length. However, satisfactory empirical expressions may be developed to fit test results. A simple equation which fits the data in the range of normal design stresses for carbon steel pipe is:

$$l_c = \frac{15,000D}{\sigma_h} \quad (1)$$

where:

$l_c$  = critical crack length (in.)

D = mean pipe diameter (in.)

$\sigma_h$  = nominal hoop stress (psi)

Data correlation for equation 1 is shown in figure 5.2-1.

**5.2.7.5.2.2 Crack Opening Displacement.** The elasticity theory predicts a crack opening displacement of:

$$w = \frac{2\ell\sigma}{E} \quad (2)$$

where:

$\ell$  = crack length (in.)

$\sigma$  = applied nominal stress (psi)

$E$  = Young's modulus (psi)

Measurements of crack opening displacement made by BMI show that local yielding greatly increases the crack opening displacement as the applied stress approaches the failure stress  $\sigma_f$ . A suitable correction factor for elasticity effects is:

$$C = \sec \frac{\pi}{2} \frac{\sigma}{\sigma_f} \quad (3)$$

The crack opening area is given by:

$$A = C \frac{\pi}{4} w \ell = \frac{\pi \ell^2 \sigma}{2E} \sec \left( \frac{\pi}{2} \frac{\sigma}{\sigma_f} \right) \quad (4)$$

For a given crack length  $\ell$ ,  $\sigma_f = 15,000 D / \ell$ .

**5.2.7.5.2.3 Leakage Flowrate.** The maximum flowrate for blowdown of saturated water at 1000 psi is 55 lb/s/in.<sup>2</sup>; and for saturated steam, the rate is 14.6 lb/s/in.<sup>2(5)</sup> Friction in the flow passage reduces this rate, but for cracks leaking at 5 gal/min (0.7 lb/s), the effect of friction is small. The required leak size for a 5-gal/min flow is:

- $A = 0.0126 \text{ in.}^2$  (saturated water).
- $A = 0.0475 \text{ in.}^2$  (saturated steam).

From this mathematical model, the critical crack length and the 5-gal/min crack length have been calculated for representative BWR pipe sizes (schedule 80) and pressure (1050 psi). Results are tabulated as follows:



HNP-2-FSAR-5

| Nominal Pipe Size<br>(Schedule 80)<br>(in.) | Average Wall Thickness<br>(in.) | 5-gal/min Crack Length, $\ell$ ,<br>(in.) |            | Critical Crack Length, $\ell_c$ ,<br>(in.) |            |
|---------------------------------------------|---------------------------------|-------------------------------------------|------------|--------------------------------------------|------------|
|                                             |                                 | Steam Line                                | Water Line | Steam Line                                 | Water Line |
| 4                                           | 0.337                           | 7.2                                       | 4.9        | 9.7                                        | 9.6        |
| 12                                          | 0.687                           | 8.5                                       | 4.8        | 19.7                                       | 19.8       |
| 24                                          | 1.218                           | 8.6                                       | 4.6        | 34.8                                       | 34.8       |

The ratios of crack length ( $\ell$ ) to the critical crack length ( $\ell_c$ ) as a function of nominal pipe size are:

| Nominal Pipe Size<br>(Schedule 80) (in.) | Ratio, $\ell/\ell_c$ |            |
|------------------------------------------|----------------------|------------|
|                                          | Steam Line           | Water Line |
| 4                                        | 0.745                | 0.510      |
| 12                                       | 0.432                | 0.243      |
| 24                                       | 0.247                | 0.132      |

It is important to recognize that the failure of ductile piping with a long through-wall crack is characterized by large crack opening displacements which precede unstable rupture. Judging from observed crack behavior in the General Electric and BMI experimental programs involving both circumferential and axial cracks, it is estimated that leak rates of hundreds of gallons per minute will precede crack instability. Measured crack opening displacements for the BMI experiments were in the range of 0.1 to 0.2 in. at the time of incipient rupture, corresponding to leaks of the order of 1 in.<sup>2</sup> in size for plain carbon steel piping. For austenitic stainless steel piping, even larger leaks are expected to precede crack instability, although there is insufficient data to permit quantitative prediction.

The results given are for a longitudinally oriented flaw at normal operating hoop stress. A circumferentially oriented flaw could be subjected to stress as high as the 550°F yield stress, assuming high thermal expansion stresses exist. A good mathematical model which is supported by test data is not available for the circumferential crack. Therefore, it is assumed that the longitudinal crack, subject to a stress as high as 30,000 psi, approaches worst case with regard to leak rate versus critical size relationships. Given the same stress level, differences between the circumferential and longitudinal orientations are not expected to be significant in this comparison.

Figure 5.2-6 shows general relationships between crack length, leak rate, stress, and line size, using the mathematical model described above. The asterisks denote conditions at which the crack opening displacement is 0.1 in., at which time instability is imminent. This provides a realistic estimate of the leak rate to be expected from a crack of critical size. In every case, the leak rate from a crack of critical size is > the 5-gal/min criterion.

### 5.2.7.5.3 Margins of Safety

The margins of safety for a detectable flow to assume critical size are presented in paragraph 5.2.7.5.2. Figure 5.2-6 shows general relationships between crack length, leak rate, stress and line size using the mathematical model.

### 5.2.7.5.4 Criteria to Evaluate Adequacy and Margin of Leak Detection System

For process lines that are normally open, there are at least two different methods of detecting abnormal leakage from each system within the nuclear system process barrier located in the primary containment and reactor building (table 5.2-8). The instrumentation can be set to provide alarms at established leakage rate limits and isolate an affected system when necessary. The alarm points are determined analytically or, where appropriate, based on measurements of appropriate parameters made during startup and preoperational tests.

The unidentified leakage rate limit is based, with an adequate margin for contingencies, on the crack size large enough to propagate rapidly. The established limit is sufficiently low so that, even if the entire unidentified leakage rate were coming from a single crack in the nuclear system process barrier, corrective action could be taken before the integrity of the barrier would be threatened.

### 5.2.7.6 Maximum Allowable Total Leakage

The total leakage rate is presented in paragraph 5.2.7.4.1.

### 5.2.7.7 Differentiation Between Identified and Unidentified Leaks

Paragraph 5.2.7.2 describes the systems that are monitored by the LDS. The ability of the LDS to differentiate between identified and unidentified leakage is discussed in paragraphs 5.2.7.2 through 5.2.7.5.

### 5.2.7.8 Sensitivity and Operability Tests

Testability of the LDS is discussed in subsection 7.6.9.

## 5.2.8 PRESERVICE AND INSERVICE INSPECTION PROGRAMS

### 5.2.8.1 Preservice Inspection Program

*The construction permit for the Edwin I. Hatch Nuclear Plant-Unit 2 was issued in December 1972, and as a result, the preservice inspection program was required to meet the requirements of the ASME Boiler and Pressure Vessel Code, Section XI, through the Summer 1971 Addenda. This edition of the code does*

*not address inspection of Code Class 2 components. However, a commitment was made by the applicant to provide access for inspection of the Code Class 2 portions of the ECCS components. The preservice inspection program meets, to the extent practical, ASME Code, Section XI, 1974 through Summer 1975 Addenda.*

### **5.2.8.2 Inservice Inspection Program**

The inservice inspection and testing programs are described in the Edwin I. Hatch Nuclear Plant-Units 1 and 2 Inservice Inspection Program and the Edwin I. Hatch Nuclear Plant-Unit 1 and Unit 2 Inservice Testing Program. These documents describe the programs for Class 1, 2, and 3 component and piping examinations and for pump and valve surveillance testing. Nuclear Regulatory Commission approvals and exceptions are documented in these programs. It should be noted that the classification of components as ASME Class 1, 2, or 3 equivalent for inservice inspection does not imply that the components were designed in accordance with ASME requirements.

The component design codes remain as stated in the FSAR.

The inservice inspection program was augmented to satisfy guidelines of Generic Letter 88-01 and NUREG-0313, Revision 2. This is documented in submittals to the Nuclear Regulatory Commission.<sup>(9,10,11)</sup> Nuclear Regulatory Commission approvals and exceptions are documented in reference 12.

#### **5.2.8.2.1 Class 1 RCPB Access Provisions**

The ASME Section III Class 1 components of the RCPB subject to inspection are those defined in Section XI of the Code, unless excluded under IWB-1220 of Section XI.

The criteria followed to provide access in accordance with ASME Section XI for areas and components of the RCS are discussed as follows:

##### **A. Piping Welds**

Accessibility requirements for piping welds were based on providing the necessary space for ultrasonic inspection. Requirements for visual or surface inspection are less stringent and are, therefore, met by the ultrasonic access provisions. An angle about the longitudinal axis of the pipe, a length along the longitudinal axis, and a radial distance outward from the piping outside diameter were considered in determining the volume about the inspection area which must be kept free of obstructions to permit inspection.

For circumferential welds subject to surface and volumetric examination, the weld and base metal are accessible for 360 degrees about the pipe axis. The length along the longitudinal axis is a function of the piping wall thickness and the angle of the ultrasonic beam in the material.

## HNP-2-FSAR-5

The radial distance required outward from the piping surface was dependent on the piping diameter and on the choice of manual or automatic scanning.

The radial dimension allowed for inspection of those welds to be automatically scanned was that required for the installation, operation, and removal of the scanning device. To ensure that accessibility would be adequate for a variety of device designs, this dimension was conservatively selected for all pipe sizes. For the manual scanning operation, the radial dimension is based on allowing free movement of the operator's hand and arm about the inspection area with head access as required to allow direct visual following of all prescribed movements.

Removable insulation is provided for piping circumferential weld joints required to be inspected during the life of the plant.

Review of the high-energy fluid system piping between the first isolation valve outside the containment and the first isolation valve inside the containment reveals that all but 2 welds can be 100% volumetrically inspected, using ultrasonic inspection methods.

The RCIC steam supply piping contains a 4-in. elbow-to-penetration weld that is not 100% ultrasonically inspectable. The curvature of a 4-in.-long radius elbow is too great to facilitate ultrasonic angle beam scanning on the inside radius. However, most of the circumferential elbow weld is inspectable using this method.

A half-coupling for an ILRT test connection, located close to the weld on the HPCI steam supply piping, prevents this pipe-to-valve weld from being 100% volumetrically inspectable using ultrasonic inspection methods. Because of a blind area behind the half-coupling, only 95% of the weld is inspectable using an ultrasonic angle beam scanning technique.

The penetration assemblies are designed such that no circumferential pipe welds are enclosed. No inspection inside guard pipes are necessary.

Inspection intervals shall be in accordance with the requirements of ASME Code Section XI as described in the Inservice Inspection Program.

### B. Pumps and Valves

Accessibility requirements include provision of sufficient space to disassemble and reassemble the pump or valve. For pumps or valves requiring only a visual examination, space for lighting and inspector access sufficient to permit observation of the entire valve inner surface was allowed. There are no through-wall casing welds in ASME Code-affected Class 1 pumps or valves.

### C. Supports

The specific access requirements for supports depend on the type and detailed design of the support.

D. Reactor Vessel

The reactor vessel shield wall and insulation are designed to allow the reactor vessel longitudinal and circumferential shell welds, including the vessel-to-bottom head weld and bottom head welds, to be inspected from the outside diameter by a remotely operated scanning device. Primary nozzle-to-vessel welds, nozzle-to-vessel inside radiused section, and primary nozzle-to-safe end welds can also be examined by the use of the same type fixture.

The vessel-to-flange weld and the flange ligaments between the threaded stud holes are accessible during refueling.

Closure head-to-flange weld, closure head circumferential and meridional welds are accessible for inspection from the outside.

Reactor vessel closure studs, nuts, and washers can be removed to dry storage when the vessel head is removed. This will provide adequate access.

**5.2.8.2.2 Class 2 Pressure-Retaining Components Access Provisions**

The ASME Code, Section III, Class 2 pressure-retaining components subject to inspection are those components which comprise the ECCS and the main steam system from the outboard containment isolation valves to the main turbine stop valves and all branch lines larger than 4-in. nominal diameter to the first branch isolation valve.

The criteria followed to provide the accessibility for the performance of inspections per ASME Code, Section XI, for these components are:

A. Piping Welds

The accessibility for piping welds is based on providing the necessary unencumbered volume for ultrasonic inspection of the weld and base metal, as well as for visual and surface inspection of the weld and heat-affected zone on either side of the weld where ultrasonic examination will not be used.

For circumferential welds subject to surface and/or volumetric examination, the weld and base metal are accessible for 360 degrees about the pipe axis.

The following welds did not receive a full-code examination:

1. A weld between a tee and a weld-neck flange in the HPCI turbine steam line - The tee fitting and flange connect the auxiliary steam system to the HPCI turbine steam supply line for system testing of the HPCI turbine. Reconfiguration of the weld to accommodate inservice inspection would require redesign of the auxiliary steam system piping and removal and reinstallation of the weld-neck flange and a spool piece. In the case of the HPCI steam supply line, the result would be to replace one weld with two

## HNP-2-FSAR-5

welds, thus increasing the inservice inspection work load by yet another weld. In the case of the auxiliary steam system, the result would be the removal and replacement of many feet of 10-in. nominal diameter pipe to ensure correct condensate removal from the steam line.

This weld is evaluated in the high-energy line breaks report and has not been postulated as a break location because of its low calculated stresses. (Stress range is 30.3% of  $0.8 (S_h + S_A)$ , including earthquake.) Postulating failure at this weld would result in no more serious consequences than the weld discussed in item 2 below.

2. A weld between the outboard isolation valve and the tee discussed for the weld above - Reconfiguration of this weld would entail the addition of a spool piece between the valve and the tee, as well as the redesign of connected piping under the el 130-ft floor. The redesign of the connected piping would result in the fabrication of replacement pipe spools (ASME Code Section III, Class 2) for the installed piping, and would also result in core drilling the pipe penetration room floor to allow displacement of the HPCI steam line by the distance of the added spools. As in the case of the weld above, the addition of the spool piece will add an additional weld for inservice inspection.

Although the physical rework is significant, the redesign would also require reanalysis of the piping system.

Because this weld is classified as a "terminal end" under the high-energy line break criteria, failure of this weld was evaluated and is discussed in paragraph 15A.5.3.1.C.

3. Two RHR system mirror-image welds on the reduced pressure steam supply pipe are located between the pressure-reducing valve and the RHR heat exchanger on both RHR system heat exchangers. The welds connect a 6-in. nominal diameter supply pipe to a 16-in. nominal diameter, 180-degree return bend/expansion loop. Reconfiguration of the weld for inservice inspection would require the addition of two pipe reducer fittings, a spool piece between the reducer fittings, and modification of the already installed piping return bend.

As in the case of the weld reconfiguration in the HPCI steam supply line, the redesign and modification of this piping would also require reanalysis of the piping system.

The RHR system is classified for high-energy/moderate-energy line breaks criteria as a moderate-energy line. Cracks are postulated to occur in the moderate-energy fluid system lines wherever the calculated stresses exceed  $0.4 (1.2 S_h + S_A)$ . A review of the stress analysis, including earthquake loadings, indicates that these welds have calculated stresses  $< 0.4 (1.2 S_h + S_A)$ .

B. Pumps and Valves

Accessibility requirements to permit inspection are, in most cases, less stringent than the space requirements for disassembly and maintenance of the equipment; therefore, maintenance accessibility was the overriding consideration during design.

For pumps and valves with pressure-retaining welds, access for volumetric examination of the weld and one thickness of base metal was provided where practical.

C. Supports

The access requirements for supports devices and components depend upon the specific of the support design, and sufficient space is provided for inspection activities where practical.

**5.2.8.2.3 Equipment for Inservice Inspections**

Reactor vessel insulation design provides an annulus between the vessel outside diameter and the inner surface of the insulation. This annulus was planned to extend from the lower portion of the support skirt to above the top of the sacrificial shield. The insulation design also includes design features at the nozzle to provide an annulus between the nozzle-to-safe-end weld and the inner surface of the insulation.

The equipment used for inservice inspection on HNP-2 is similar to that used on HNP-1. An ultrasonic device similar to the device used on other recent BWR vessels operates within the reactor vessel insulation annulus. This device is capable of virtually unlimited vertical travel from point of entry and out to a distance of 19 in. on either side of the traverse line. This allows inspection of virtually all of the vertical welds and ~ 70 ft of the circumferential weld. The reactor vessel bottom head design minimizes the welds to be inspected. An ultrasonic device has been developed capable of inspecting these welds by utilizing tracks and entry from four inspection ports in the reactor vessel support skirt.

A device is available to operate in the annulus provided around the nozzles.

**5.2.8.2.4 Recording and Comparing Data**

The results of manual inspections were recorded on forms designated for electronic data processing. This data can be transferred to a computer for correlation on subsequent inspections.

The results of mechanized scans were recorded by a data acquisition system. This system uses a stop-motion camera or video tape to record the information on a data panel. This panel contains meters and digital counters that indicate the position of the inspection device,

transducer angle, and scan path. Cathode ray tubes display the ultrasonic information from each instrument. A graphic presentation of the weld being inspected, showing idealized beam paths weld geometry, etc., can be recorded on video tape along with the cathode ray tube display. In addition, indications above a preset level are recorded on a strip chart recorder, with both time and amplitude being recorded.

#### **5.2.8.2.5 Reactor Vessel Acceptance Standards**

The acceptance standards that were used to establish the acceptability of the reactor vessel by ultrasonic examination are those of the 1974 ASME Code, Section XI, through the Summer 1975 Addenda. See paragraph 5.2.8.2 for current commitments.

#### **5.2.8.2.6 Coordination of Inspection Equipment With Access Provisions**

SNC has available the services of an experienced consulting firm for assistance in future inservice inspections, if required.



**DOCUMENTS INCORPORATED BY REFERENCE INTO THE FSAR**

***Technical Requirements Manual Table T7.0-1, Primary Containment Penetrations.***

REFERENCES

1. Williams, W. L., Corrosion, Volume 13, p 539t, 1957.
2. Skarpelos, J. M., and Bagg, J. W., "Chloride Control in BWR Coolants," NEDO-10899, June 1973.
3. Reynolds, M. B., "Failure Behavior in ASTM A 106 B Pipes Containing Axial Through-Wall Flaws," GEAP-5620, April 1968.
4. Duffy, A. R., Eiber, R. J., and Maxey, W. A., Recent Work on Flow Behavior in Pressure Vessels, April 1969; Eiber, et al., "Investigation of the Initiation and Extent of Ductile Pipe Rupture," Quarterly Progress Reports, May 1966 through 1969.
5. Moody, F. J., "Maximum Two-Phase Vessel Blowdown from Pipes," APED-4827, April 1965.
6. "Alternate Alloys for BWR Pipe Applications," EPRI, NP-2671-LD, Final Report, October 1982.
7. "Fracture Toughness Requirements", Appendix G to Title 10 Code of Federal Regulations Part 50, December 1995.
8. "Radiation Embrittlement of Reactor Vessel Materials", USNRC Regulatory Guide 1.99, Revision 2, May 1988.
9. Georgia Power Company letter to the Nuclear Regulatory Commission, dated June 30, 1988.
10. Georgia Power Company letter to the Nuclear Regulatory Commission, dated September 27, 1988.
11. Georgia Power Company letter to the Nuclear Regulatory Commission, dated October 19, 1988.
12. Nuclear Regulatory Commission letter to Georgia Power Company, dated February 16, 1990.
13. Georgia Power Company letter to the Nuclear Regulatory Commission, dated August 20, 1990.

HNP-2-FSAR-5

14. Nuclear Regulatory Commission Safety Evaluation Report, "Main Steam Safety Relief Valve Pressure Sensor Activation Modification," Hatch Nuclear Plant, Docket Nos. 50-321 and 50-366, dated July 24, 1992.
15. H. S. Mehta, T. A. Caine, and S. E. Plaxton, "10 CFR 50 Appendix G Equivalent Margin Analysis for Low Upper Shelf Energy in BWR/2 through BWR/6 Vessels, NEDO-32205-A, Revision 1, General Electric Company, San Jose, CA, February 1994.
16. Frew, B. D., "Plant Hatch Unit 1 RPV Surveillance Materials Testing and Analysis", GE-NE-131100691-01R1, March 1997.
17. Paine, T. A. "E.I. Hatch Nuclear Power Station Unit 2 Vessel Surveillance Materials Testing and Fracture Toughness Analysis," SASR 90-104, May 1991.
18. "Extended Power Uprate Safety Analysis Report for Edwin I. Hatch Nuclear Plant Units 1 and 2," NEDC-32749P, General Electric Company, July 1997.
19. "Safety Review for Edwin I. Hatch Nuclear Power Plant Units 1 and 2 - Uprated Safety/Relief Valve Performance Requirements," NEDC-32041P, General Electric Company, April 1996.
20. "PVRC Recommendations on Toughness Requirements for Ferritic Materials," Welding Research Council Bulletin 175, August 1972.
21. ASME Boiler and Pressure Vessel Code, Section XI, Rules for Inservice Inspection of Nuclear Power Plant Components, Nonmandatory Appendix G, "Fracture Toughness Criteria for Protection Against Failure," 1989 Edition, No Addenda.
22. "Design Stress Intensity Values, Allowable Stresses, Material Properties, and Design Fatigue Curves," ASME Boiler and Pressure Vessel Code, Section III, Appendix I, 1989.
23. "Plant Hatch Units 1 & 2 RPV Pressure Temperature Limits License Renewal Evaluation," General Electric Report GE-NE-B1100827-00-01, Class II, March 1999.
24. "Structural Integrity Report SIR-00-037, Revised Pressure-Temperature Curves for Plant Hatch," Revision 0, March 2000.
25. ASME Boiler and Pressure Vessel Code, Code Case N-588, "Attenuation to Reference Flow Orientation of Appendix G for Circumferential Welds in Reactor Vessels," Section XI, Division 1, approved December 12, 1997.
26. ASME Boiler and Pressure Vessel Code, Code Case N-640, "Alternative Reference Fracture Toughness for Development of P-T Limit Curves," Section XI, Division 1, approved February 26, 1999.
27. Paine, T. A. "Basis for GE RT<sub>NDT</sub> Estimation Method," NEDC-32399-P, General Electric Company, November 1993.

HNP-2-FSAR-5

28. C. Terry (BWRVIP) to U.S. NRC Document Control Desk, "Project No. 704-BWR Vessel and Internals Project, BWR Integrated Surveillance Program Plan (BWRVIP-78)," December 22, 1999.
29. C. Terry (BWRVIP) to U.S. NRC Document Control Desk, "Project No. 704-BWRVIP-86: BWR Vessel and Internals Project, BWR Integrated Surveillance Program Implementation Plan," EPRI Technical Report 1000888, December 22, 2000.
30. C. Terry (BWRVIP) to U.S. NRC Document Control Desk, "Project No. 704-BWRVIP Response to NRC Request for Additional Information Regarding BWRVIP-78," December 15, 2000.
31. C. Terry (BWRVIP) to U.S. NRC Document Control Desk, "Project No. 704-BWRVIP Response to Second NRC Request for Additional Information on the BWR Integrated Surveillance Program," May 30, 2001.
32. W. H. Bateman (USNRC) to C. Terry (BWRVIP), "Safety Evaluation Regarding EPRI Proprietary Reports," BWR Vessel and Internals Project, BWR Integrated Surveillance Program Plan (BWRVIP-78)" and "BWRVIP-86: BWR Vessel and Internals Project, BWR Integrated Surveillance Program Implementation Plan," February 1, 2002.
33. "Safety Analysis Report for Edwin I. Hatch Units 1 and 2 Thermal Power Optimization," NEDC-33085P, GE Nuclear Energy, December 2002.
34. "10-PSI Dome Pressure Increase Project Report for Edwin I. Hatch Units 1 and 2," GE-NE-0000-0003-0634-01, Revision 1, GE Nuclear Energy, July 2003.

TABLE 5.2-1 (SHEET 1 OF 3)

**DESIGN TEMPERATURE AND PRESSURE AND MAXIMUM TEST  
PRESSURE FOR RCPB COMPONENTS**

| <u>Component</u>                        | Design<br>Temperature<br>(°F) | Design<br>Pressure<br>(psig) | Maximum Test<br>Pressure <sup>(a)</sup><br>(psig) |
|-----------------------------------------|-------------------------------|------------------------------|---------------------------------------------------|
| RPV                                     | 575                           | 1250                         | 1563 <sup>(a)</sup>                               |
| RRS                                     |                               |                              |                                                   |
| Pump discharge piping                   | 575                           | 1450                         | (b)                                               |
| Pump suction piping                     | 575                           | 1250                         | (b)                                               |
| Discharge valves                        | 575                           | 1525                         | (c)                                               |
| Suction valves                          | 575                           | 1250                         | (c)                                               |
| Pump                                    | 575                           | 1500                         |                                                   |
| RPV drain line                          | 575                           | 1275                         | (b)                                               |
| Main steam line                         | 575                           | 1250                         | (b)                                               |
| MSIVs                                   | 575                           | 1250                         | (c)                                               |
| RHR system                              |                               |                              |                                                   |
| Shutdown suction                        |                               |                              |                                                   |
| RRS header to second<br>isolation valve |                               |                              |                                                   |
| Piping                                  | 575                           | 1250                         | (b)                                               |
| Valves                                  | 575                           | 1250                         | (c)                                               |
| Pump discharge                          |                               |                              |                                                   |
| RRS header to second<br>isolation valve |                               |                              |                                                   |
| Piping                                  | 575                           | 1450                         | (b)                                               |
| Valves                                  | 575                           | 1450                         | (c)                                               |
| Reactor Feedwater System                |                               |                              |                                                   |
| RPV to second isolation valve           |                               |                              |                                                   |
| Piping                                  | 575                           | 1300                         | 1563                                              |
| Valves                                  | 575                           | 1300                         | 1563                                              |

HNP-2-FSAR-5

**TABLE 5.2-1 (SHEET 2 OF 3)**

| <u>Component</u>                                | <u>Design Temperature (°F)</u> | <u>Design Pressure (psig)</u> | <u>Maximum Test Pressure<sup>(a)</sup> (psig)</u> |
|-------------------------------------------------|--------------------------------|-------------------------------|---------------------------------------------------|
| RCIC System                                     |                                |                               |                                                   |
| Steam to RCIC turbine                           |                                |                               |                                                   |
| RPV to second isolation valve                   |                                |                               |                                                   |
| Piping                                          | 575                            | 1250                          | (b)                                               |
| Valves                                          | 575                            | 1250                          | (c)                                               |
| HPCI system                                     |                                |                               |                                                   |
| Steam to HPCI turbine                           |                                |                               |                                                   |
| RPV to second isolation valve                   |                                |                               |                                                   |
| Piping                                          | 575                            | 1250                          | 1663                                              |
| Valves                                          | 575                            | 1250                          | 1663                                              |
| CS system                                       |                                |                               |                                                   |
| Pump discharge                                  |                                |                               |                                                   |
| RPV to first isolation valve                    |                                |                               |                                                   |
| Piping                                          | 575                            | 1250                          | (b)                                               |
| Valves                                          | 575                            | 1250                          | (c)                                               |
| First isolation valve to second isolation valve |                                |                               |                                                   |
| Piping                                          | 560                            | 1124                          | (b)                                               |
| Valves                                          | 560                            | 1124                          | (c)                                               |
| Standby Liquid Control System                   |                                |                               |                                                   |
| Pump discharge to RPV                           |                                |                               |                                                   |
| Reactor to second isolation valve               |                                |                               |                                                   |
| Piping                                          | 575                            | 1250                          | (b)                                               |
| Valves                                          | 575                            | 1250                          | (c)                                               |

HNP-2-FSAR-5

**TABLE 5.2-1 (SHEET 3 OF 3)**

| <u>Component</u>                              | <u>Design Temperature (°F)</u> | <u>Design Pressure (psig)</u> | <u>Maximum Test Pressure<sup>(a)</sup> (psig)</u> |
|-----------------------------------------------|--------------------------------|-------------------------------|---------------------------------------------------|
| RWC system                                    |                                |                               |                                                   |
| Pump suction                                  |                                |                               |                                                   |
| RHR piping to isolation valve outside drywell |                                |                               |                                                   |
| Piping                                        | 575                            | 1250                          | (b)                                               |
| Valves                                        | 575                            | 1250                          | (c)                                               |
| Control Rod Drive Hydraulic System            |                                |                               |                                                   |
| Reactor to second isolation valve             |                                |                               |                                                   |
| From RPV to F087                              | 560                            | 1250                          | 1563                                              |
| From F087 to F121                             | 150                            | 1750                          | 2188                                              |

a. Excluding shell test for valves according to Sections NB-3531-8 and NB-3531-9 of ASME B&PV Code Section III. The stress intensity ratio is interpreted from Section NB-6221 of the code to be the ratio of the allowable stress,  $S_m$ , at test temperature to the allowable stress,  $S_m$ , at design temperature.

b. Test pressure is 1.25 x design pressure x lowest stress intensity ratio.

c. Test pressure is 1.50 x design pressure x lowest stress intensity ratio.

HNP-2-FSAR-5

TABLE 5.2-3

REACTOR VESSEL MATERIAL IRRADIATION SURVEILLANCE SCHEDULE

| ISP Capsule    | Year to be Withdrawn or Tested |      |         |         |         |         |         |      |         |      |      |      |      |      |      |      |      |      |      |       |          |   |  |          |
|----------------|--------------------------------|------|---------|---------|---------|---------|---------|------|---------|------|------|------|------|------|------|------|------|------|------|-------|----------|---|--|----------|
|                | 2000                           | 2001 | 2002    | 2003    | 2004    | 2005    | 2006    | 2007 | 2008    | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | Later |          |   |  |          |
| Browns Ferry 2 |                                | X    | ----->> |         |         |         |         |      |         |      |      | X    |      |      |      |      |      |      |      |       |          |   |  |          |
| Cooper         |                                |      |         |         |         |         |         |      |         |      |      |      |      |      |      |      | X    |      |      |       |          |   |  |          |
| Dresden 3      |                                |      | X       | ----->> |         |         |         |      |         |      |      |      |      |      |      |      |      |      |      | X     |          |   |  |          |
| Duane Arnold   |                                |      |         |         |         |         |         |      |         |      |      |      |      | X    |      |      |      |      |      |       |          |   |  |          |
| Hatch 1        |                                |      |         |         |         |         |         |      |         |      |      |      |      |      |      |      |      |      | X    |       |          |   |  |          |
| Hatch 2        |                                | X    | ----->> |         |         |         |         |      |         |      |      |      |      |      |      |      |      |      | X    |       |          |   |  |          |
| Hope Creek     |                                |      |         |         | X       | ----->> |         |      |         |      |      |      |      |      |      | X    |      |      |      |       |          |   |  |          |
| LaSalle 1      |                                |      |         |         |         | X       | ----->> |      |         |      | X    |      |      |      |      |      |      |      |      |       |          |   |  |          |
| Monticello     |                                |      |         | X       | ----->> |         | X       |      |         |      |      |      |      |      |      |      |      |      |      |       |          |   |  |          |
| Peach Bottom 2 |                                |      | X       | ----->> |         |         |         |      |         |      |      |      |      |      |      |      |      |      |      |       |          | X |  |          |
| Perry          |                                |      |         |         |         |         |         | X    | ----->> |      |      | X    |      |      |      |      |      |      |      |       | X (2026) |   |  |          |
| River Bend     |                                |      | X       |         | X       | ----->> |         |      |         |      |      |      |      |      |      |      |      |      |      |       |          |   |  | X (2025) |
| Susquehanna 1  |                                |      | X       | ----->> |         |         |         |      |         |      |      | X    |      |      |      |      |      |      |      |       |          |   |  |          |
| SSP-A          |                                |      |         | X       |         |         |         |      |         |      |      |      |      |      |      |      |      |      |      |       |          |   |  |          |
| SSP-B          |                                |      |         | X       |         |         |         |      |         |      |      |      |      |      |      |      |      |      |      |       |          |   |  |          |
| SSP-C          |                                |      |         | X       |         |         |         |      |         |      |      |      |      |      |      |      |      |      |      |       |          |   |  |          |
| SSP-D          | X                              |      |         |         |         |         |         |      |         |      |      |      |      |      |      |      |      |      |      |       |          |   |  |          |
| SSP-E          |                                | X    |         |         |         |         |         |      |         |      |      |      |      |      |      |      |      |      |      |       |          |   |  |          |
| SSP-F          |                                | X    |         |         |         |         |         |      |         |      |      |      |      |      |      |      |      |      |      |       |          |   |  |          |
| SSP-G          | X                              |      |         |         |         |         |         |      |         |      |      |      |      |      |      |      |      |      |      |       |          |   |  |          |
| SSP-H          | X                              |      |         |         |         |         |         |      |         |      |      |      |      |      |      |      |      |      |      |       |          |   |  |          |
| SSP-I          |                                | X    |         |         |         |         |         |      |         |      |      |      |      |      |      |      |      |      |      |       |          |   |  |          |

Notes:

1. Bold X indicates the schedule under the ISP; arrows indicate shifts from the existing schedule.
2. Browns Ferry 2 was scheduled to withdraw its second capsule in 2001; to increase fluence per NRC Staff recommendations, the ISP delays withdrawal until 2011.
3. Dresden 3, Hatch 2, Hope Creek, LaSalle 1, Monticello, Peach Bottom 2, and Susquehanna 1 final capsule withdrawals are deferred to increase capsule fluence.
4. River Bend withdrew a capsule in 2000 and will test and report the results in 2003.
5. River Bend was scheduled to withdraw its second capsule in 2004, soon after withdrawing its first; to increase fluence per NRC Staff recommendations, the ISP delays withdrawal until 2025.
6. Cooper, Duane Arnold, and Hatch 1 are scheduled for third capsule withdrawals as shown, based on NRC Staff recommendations.
7. Year for capsule withdrawal is approximate; to be coordinated with plant outage schedule.

TABLE 5.2-4

**NUCLEAR STEAM SUPPLY SYSTEM SAFETY RELIEF VALVES AND ELECTRICAL  
BACKUP: SET PRESSURES, CAPACITIES, AND DURATION OF BLOWDOWN**

| <u>No. of Valves<sup>(a)</sup></u> | <u>Mechanical Set Pressure (psig)</u> | <u>Set Pressure (psig)<sup>(b)</sup></u> | <u>Approximate Capacity at 103 % of Mechanical Set Pressure (lb/h each)</u> |
|------------------------------------|---------------------------------------|------------------------------------------|-----------------------------------------------------------------------------|
| 4                                  | 1150                                  | 1120                                     | 916,600                                                                     |
| 4                                  | 1150                                  | 1130                                     | 916,600                                                                     |
| 3                                  | 1150                                  | 1140                                     | 916,600                                                                     |

| <u>Events Resulting in Pressure Relief Actuation</u> | <u>No. of Valves Expected to Operate During First Blowdown</u> | <u>Duration of First Blowdown(s)</u> |
|------------------------------------------------------|----------------------------------------------------------------|--------------------------------------|
| Generator load rejection                             | 10 of 11                                                       | 5                                    |
| Turbine trip (nominal)                               | 10 of 11                                                       | 5                                    |
| Turbine trip without bypass                          | 10 of 11                                                       | 5                                    |
| Turbine trip without bypass - low power              | < 11                                                           | -                                    |
| Closure of all MSIVs                                 | 10 of 11                                                       | > 8                                  |
| Pressure regulator failure - fail open               | 4                                                              | 2                                    |
| Loss of auxiliary power                              | 8                                                              | 3                                    |
| Feedwater controller failure - maximum flow          | 0                                                              | -                                    |
| Inadvertent opening of a safety relief valve         | 1                                                              | -                                    |

a. The number of safety relief valves required to actuate to provide automatic depressurization is six of seven. This provides sufficient flow capacity to satisfy automatic depressurization requirements, assuming one ADS valve fails to open.

b. This column reflects the nominal safety relief valve set pressure for nonsafety electrical backup to mechanical relief valves.



TABLE 5.2-5

**KEY ANALYSIS INPUT PARAMETERS AND ASSUMPTIONS  
FOR EXTENDED POWER UPRATE OVERPRESSURE PROTECTION ANALYSIS**

| <u>Parameter</u>                                                       | <u>Value</u>    |
|------------------------------------------------------------------------|-----------------|
| Rated thermal power (MWt)                                              | 2763            |
| Analysis power (MWt) (102% of rated)                                   | 2818            |
| Core flow (% of rated)                                                 | 105             |
| Dome pressure (psia)                                                   | 1073            |
| Rated feedwater temperature (°F)                                       | 425             |
| No. of safety relief valves (SRVs)                                     | 10 of 11        |
| SRV type                                                               | Target Rock     |
| SRV opening response time (s)                                          | 0.15            |
| SRV opening delay time (s)                                             | 0.4             |
| Total SRV capacity (% rated steam flow) <sup>(a)</sup><br>at 1090 psig | 71              |
| Scram speed                                                            | GEMINI Option A |

The impact of thermal power optimization (2804 MWt) and reactor operating pressure increase to 1060 psia has been evaluated with a peak calculated RPV bottom head pressure increase to 1349 psig, which is well within the event acceptance limit of 1375 psig.

a. The absolute SRV capacity at 1090 psig does not change with power uprate. The reduction in the capacity relative to the rated steam flow at 2763 MWt is due to the increase in the rated value with power uprate.

TABLE 5.2-6 (SHEET 1 OF 2)

## REACTOR COOLANT PRESSURE BOUNDARY MATERIALS

| <u>Component</u>  | <u>Form</u>              | <u>Material</u>                                   | <u>Specification<br/>(ASTM/ASME)</u>                                                       |
|-------------------|--------------------------|---------------------------------------------------|--------------------------------------------------------------------------------------------|
| RPV heads, shells | Rolled plate or forgings | Low-alloy steel                                   | SA-533 Grade B or SA-508 Cl 2                                                              |
|                   | Welds                    | Low-alloy steel                                   | SFA-5.5                                                                                    |
| Closure flange    | Forged ring              | Low-alloy steel                                   | SA-508 Cl 2                                                                                |
|                   | welds                    | Low-alloy steel                                   | SFA-5.5                                                                                    |
| Nozzles           | Forged shapes            | Low-alloy steel                                   | SA-508 Cl 2                                                                                |
|                   | welds                    | Low-alloy steel                                   | SFA-5.5                                                                                    |
| Cladding          | Weld overlay             | Austenitic stainless steel                        | SFA-5.9 or SFA-5.4<br>TP 309 with carbon content of final surface limited to 0.08% maximum |
| CRD stub tubes    | Forged or extruded       | Inconel-clad low-alloy steel or clad carbon steel | SB166, SB16T or SA-508                                                                     |
|                   | Welds                    | Inconel or stainless steel                        | SFA-5.14 TP ERNiCr-3, SFA-5.11 TP ERNiFE-3 or SFA-5.9, SFA-5.4 TP, 308L or 316L            |
| Control rod       | Pipe                     | Austenitic stainless steel                        | SA-312                                                                                     |
| Drive housings    | Welds                    | Stainless steel                                   | SFA-5.9 TP308 or 316, or SFA-5.2 TP308 or 316L                                             |
| Incore            | Pipe                     | Austenitic stainless steel                        | SA-213                                                                                     |
| Housings          | Welds                    | Stainless steel                                   | SFA-5.9 or 5.4 TP 308 or 316                                                               |

Additional RCPB component materials and specifications to be used are specified as follows.

Depending on whether impact tests are required and depending on the lowest service metal temperature when impact tests are required, the following ferritic materials and specifications are to be used:

**TABLE 5.2-6 (SHEET 2 OF 2)**

|                  |                                                                                                      |
|------------------|------------------------------------------------------------------------------------------------------|
| Pipe             | SA-106 Grade B, SA-333 Grade 6, and SA-155 Grade KCF-70                                              |
| Valves           | SA-105 Grade II, SA-350 Grade LF1, and SA-216 Grade WCB                                              |
| Fittings         | SA-105 Grade II, SA-350 Grade LF1, SA-234 Grade WPB, and SA-420 Grade WPL1 or WPL6                   |
| Bolting          | SA-193 Grade B7, SA-194 Grades 7 and 2H, and SA-540 Grade B22, B23, and B24                          |
| Welding material | SFA-5.1 (E-7015, E-7016, E-7018)<br>SFA-5.5 (E-7010A1, E-7015, E-7016, E-7018)<br>SFA-5.17, SFA-5.18 |

The replaced HNP-2 recirculation piping system, stainless steel portions of RHR, and replaced portion of RWC are fabricated of materials according to the following specifications:

|                                 |                                           |
|---------------------------------|-------------------------------------------|
| Pipe                            | SA-358 Type 316NG, Class 1                |
| Fittings                        | SA-403 Grade WP316NG                      |
| Forgings                        | SA-182 Grade F316NG                       |
| Weld filler metal               |                                           |
| Seam welds                      | SFA 5.9 Type ER316L                       |
| Butt welds and attachment welds | SFA 5.4 Type E308L<br>SFA 5.9 Type ER308L |

For the recirculation system pumps and valves and other systems or portions of systems requiring austenitic stainless steel, the following materials and specifications are to be used:

|                  |                                                                            |
|------------------|----------------------------------------------------------------------------|
| Pipe             | SA-376 Type 304, SA-312 Type 304, SA-358 Type 304                          |
| Valves           | SA-182 Grade F-304, SA-351 Grades CR-8 and CR-8M                           |
| Pump             | SA-182 Grade F-304, SA-351 Grades CF-8 and CR-8M                           |
| Flanges          | SA-182 Grade F-316                                                         |
| Bolting          | SA-193 Grade B7, SA-194 Grades 7 and 2H, SA-540 Grades B22, B23, B24       |
| Welding material | SFA-5.4 (E308-15, E308L-15, E316-15),<br>SFA-5.9 (ER-308, ER-308L, ER-316) |

HNP-2-FSAR-5

**TABLE 5.2-7 (SHEET 1 OF 2)**  
**BELTLINE ART VALUES**

HNP-1

|                                                  |                           |                            |                                                       |                                                        |                                                        |
|--------------------------------------------------|---------------------------|----------------------------|-------------------------------------------------------|--------------------------------------------------------|--------------------------------------------------------|
| Thickness (in.) = 5.38                           | <b>Lower Intermediate</b> | Ratio Peak/Location = 1.00 | 54 EFPY Peak I.D. fluence = 3.5E+18 n/cm <sup>2</sup> | 54 EFPY Peak 1/4 T fluence = 2.5E+18 n/cm <sup>2</sup> | 54 EFPY Peak 1/4 T fluence = 2.5E+18 n/cm <sup>2</sup> |
| Girth Weld Thickness (in.) = 5.38                | <b>Lower</b>              | Ratio Peak/Location = 0.68 | 54 EFPY Peak I.D. fluence = 2.4E+18 n/cm <sup>2</sup> | 54 EFPY Peak 1/4 T fluence = 1.7E+18 n/cm <sup>2</sup> | 54 EFPY Peak 1/4 T fluence = 1.7E+18 n/cm <sup>2</sup> |
| Plate & Longitudinal Weld Thickness (in.) = 6.38 |                           | Ratio Peak/Location = 0.68 | 54 EFPY Peak I.D. fluence = 2.4E+18 n/cm <sup>2</sup> | 54 EFPY Peak 1/4 T fluence = 1.6E+18 n/cm <sup>2</sup> | 54 EFPY Peak 1/4 T fluence = 1.6E+18 n/cm <sup>2</sup> |

| Component                                  | Heat or Heat/Lot      | %Cu   | %Ni   | CF  | Initial RT <sub>ndt</sub> (°F) | ¼ T Fluence n/cm <sup>2</sup> | 54 EFPY ΔRT <sub>ndt</sub> (°F) | σ <sub>1</sub> | σΔ | Margin (°F) | 54 EFPY Shift (°F) | 54 EFPY ART (°F) |
|--------------------------------------------|-----------------------|-------|-------|-----|--------------------------------|-------------------------------|---------------------------------|----------------|----|-------------|--------------------|------------------|
| <b>PLATES:</b>                             |                       |       |       |     |                                |                               |                                 |                |    |             |                    |                  |
| <b>Lower</b>                               |                       |       |       |     |                                |                               |                                 |                |    |             |                    |                  |
| G-4805-1                                   | C4112-1               | 0.13  | 0.64  | 92  | 8                              | 1.6E+18                       | 48                              | 0              | 17 | 34          | 81.9               | 89.9             |
| G-4805-2                                   | C4112-2               | 0.13  | 0.64  | 92  | 10                             | 1.6E+18                       | 48                              | 0              | 17 | 34          | 81.9               | 91.9             |
| G-4805-3                                   | C4149-1               | 0.14  | 0.57  | 99  | -10                            | 1.6E+18                       | 52                              | 0              | 17 | 34          | 85.5               | 75.5             |
| <b>Lower-Intermediate</b>                  |                       |       |       |     |                                |                               |                                 |                |    |             |                    |                  |
| G-4803-7                                   | C4337-1               | 0.17  | 0.62  | 128 | -20                            | 2.5E+18                       | 80                              | 0              | 17 | 34          | 114.3              | 94.3             |
| G-4804-1                                   | C3985-2               | 0.13  | 0.58  | 90  | -20                            | 2.5E+18                       | 56                              | 0              | 17 | 34          | 90.5               | 70.5             |
| G-4804-2*                                  | C4114-2               | 0.13  | 0.70  | 245 | -20                            | 2.5E+18                       | 154                             | 0              | 17 | 34          | 187.7              | 167.7            |
| <b>WELDS:</b>                              |                       |       |       |     |                                |                               |                                 |                |    |             |                    |                  |
| <b>Lower Longitudinal</b>                  | 13253/1092 Flux 3791  | 0.221 | 0.732 | 189 | -50                            | 1.6E+18                       | 98                              | 0              | 28 | 56          | 154.4              | 104.4            |
| <b>Lower Intermediate Longitudinal</b>     | IP2809/1092 Flux 3854 | 0.270 | 0.735 | 206 | -50                            | 2.5E+18                       | 129                             | 0              | 28 | 56          | 185.0              | 135.0            |
| 1-308                                      | IP2815/1092 Flux 3854 | 0.316 | 0.724 | 219 | -50                            | 2.5E+18                       | 137                             | 0              | 28 | 56          | 193.4              | 143.4            |
| <b>Girth (Lower to Lower-Intermediate)</b> | 90099/0091 Flux 3977  | 0.197 | 0.060 | 91  | -10                            | 1.7E+18                       | 49                              | 0              | 24 | 48          | 97.3               | 87.3             |
| 1-313                                      | 33A277/0091 Flux 3977 | 0.258 | 0.165 | 126 | -50                            | 1.7E+18                       | 67                              | 0              | 28 | 56          | 123.3              | 73.3             |

\*CF adjusted by a factor of 2.62.

HNP-2-FSAR-5

**TABLE 5.2-7 (SHEET 2 OF 2)**  
**BELTLINE ART VALUES**

HNP-2

|                                                  |                           |  |                            |                                      |                   |
|--------------------------------------------------|---------------------------|--|----------------------------|--------------------------------------|-------------------|
| Thickness (in.) = 5.38                           | <b>Lower Intermediate</b> |  | Ratio Peak/Location = 1.00 | 54 EFPY Peak I.D. fluence = 3.9E+18  | n/cm <sup>2</sup> |
|                                                  |                           |  |                            | 54 EFPY Peak 1/4 T fluence = 2.8E+18 | n/cm <sup>2</sup> |
|                                                  |                           |  |                            | 54 EFPY Peak 1/4 T fluence = 2.8E+18 | n/cm <sup>2</sup> |
| Girth Weld Thickness (in.) = 5.38                | <b>Lower</b>              |  | Ratio Peak/Location = 0.64 | 54 EFPY Peak I.D. fluence = 2.5E+18  | n/cm <sup>2</sup> |
|                                                  |                           |  |                            | 54 EFPY Peak 1/4 T fluence = 1.8E+18 | n/cm <sup>2</sup> |
|                                                  |                           |  |                            | 54 EFPY Peak 1/4 T fluence = 1.8E+18 | n/cm <sup>2</sup> |
| Plate & Longitudinal Weld Thickness (in.) = 6.38 | <b>Lower Intermediate</b> |  | Ratio Peak/Location = 0.64 | 54 EFPY Peak I.D. fluence = 2.5E+18  | n/cm <sup>2</sup> |
|                                                  |                           |  |                            | 54 EFPY Peak 1/4 T fluence = 1.7E+18 | n/cm <sup>2</sup> |
|                                                  |                           |  |                            | 54 EFPY Peak 1/4 T fluence = 1.7E+18 | n/cm <sup>2</sup> |

| Component                                   | Heat or Heat/Lot              | %Cu   | %Ni   | CF | Initial RT <sub>ndt</sub> (°F) | 1/4 T Fluence n/cm <sup>2</sup> | 54 EFPY Δ RT <sub>ndt</sub> (°F) | σ <sub>1</sub> | σ <sub>Δ</sub> | Margin (°F) | 54 EFPY Shift (°F) | 54 EFPY ART (°F) |
|---------------------------------------------|-------------------------------|-------|-------|----|--------------------------------|---------------------------------|----------------------------------|----------------|----------------|-------------|--------------------|------------------|
| <b>PLATES:</b>                              |                               |       |       |    |                                |                                 |                                  |                |                |             |                    |                  |
| <b>Lower</b>                                | C8553-2                       | 0.08  | 0.58  | 51 | -20                            | 1.7E+18                         | 27                               | 0              | 13             | 27          | 54.0               | 34.0             |
| G6603-1                                     | C8553-1                       | 0.08  | 0.58  | 51 | 24                             | 1.7E+18                         | 27                               | 0              | 13             | 27          | 54.0               | 78.0             |
| G6603-2                                     | C8571-1                       | 0.08  | 0.53  | 51 | 0                              | 1.7E+18                         | 27                               | 0              | 13             | 27          | 54.0               | 54.0             |
| G6603-3                                     |                               |       |       |    |                                |                                 |                                  |                |                |             |                    |                  |
| <b>Lower-Intermediate</b>                   | C8554-1                       | 0.08  | 0.57  | 51 | -20                            | 2.8E+18                         | 33                               | 0              | 17             | 33          | 66.5               | 46.5             |
| G6602-2                                     | C8554-2                       | 0.08  | 0.63  | 51 | -10                            | 2.8E+18                         | 33                               | 0              | 17             | 33          | 66.5               | 56.5             |
| G6602-1                                     | C8579-2                       | 0.11  | 0.48  | 73 | -4                             | 2.8E+18                         | 48                               | 0              | 17             | 34          | 81.6               | 77.6             |
| G6601-4                                     |                               |       |       |    |                                |                                 |                                  |                |                |             |                    |                  |
| <b>WELDS:</b>                               |                               |       |       |    |                                |                                 |                                  |                |                |             |                    |                  |
| <b>Lower Longitudinal</b>                   | 10137, Linde 0091             | 0.216 | 0.043 | 98 | -50                            | 1.7E+18                         | 52                               | 0              | 26             | 52          | 103.7              | 53.7             |
| 101-842                                     |                               |       |       |    |                                |                                 |                                  |                |                |             |                    |                  |
| <b>Lower-Intermediate Longitudinal</b>      | 51874, Linde 0091, Flux 3458  | 0.147 | 0.037 | 68 | -50                            | 2.8E+18                         | 44                               | 0              | 22             | 44          | 88.7               | 38.7             |
| 101-834                                     |                               |       |       |    |                                |                                 |                                  |                |                |             |                    |                  |
| <b>Girth (Lower to Lower- Intermediate)</b> | 4P6052, Linde 0091, Flux 0145 | 0.047 | 0.049 | 31 | -50                            | 1.8E+18                         | 17                               | 0              | 8              | 17          | 33.7               | -16.3            |
| 301-871                                     |                               |       |       |    |                                |                                 |                                  |                |                |             |                    |                  |

TABLE 5.2-8

**SUMMARY OF ISOLATION/ALARM OF SYSTEMS MONITORED AND DETECTION METHODS USED**

| Function           |          | A                   | A                     | A                          | A                                    | A/I                     | A                     | A/I                     | A/I                                              | A                  | A/I              | A/I                           | I                | I                                  | A/I              |
|--------------------|----------|---------------------|-----------------------|----------------------------|--------------------------------------|-------------------------|-----------------------|-------------------------|--------------------------------------------------|--------------------|------------------|-------------------------------|------------------|------------------------------------|------------------|
| Source of Leakage  | Location | PC High Temperature | PC Sump High Flowrate | PC Air Cooler CW ΔT (High) | Equipment Area T & ΔT (High)         | Low Steam Line Pressure | RB Sump High Flowrate | Equipment Area T (High) | Suppression Pool Area T and ΔT (high) Time Relay | PC Pressure (High) | High Flowrate    | High Turbine Exhaust Pressure | CU Δ Flow (High) | Reactor Low Water Level 1, 2, or 3 | Reactor Pressure |
| Main steam line    | PC       | X                   | X                     | X                          |                                      |                         |                       |                         |                                                  | X                  |                  |                               |                  | X                                  |                  |
|                    | RB<br>TB |                     |                       |                            | X <sup>(a)</sup><br>X <sup>(a)</sup> |                         | X                     |                         |                                                  |                    | X <sup>(b)</sup> |                               |                  | X                                  |                  |
| RHR                | PC       | X                   | X                     | X                          |                                      |                         |                       |                         |                                                  | X                  |                  |                               |                  | X <sup>(d)</sup>                   | X <sup>(d)</sup> |
|                    | RB       |                     |                       |                            | X                                    |                         | X                     |                         |                                                  |                    |                  |                               |                  |                                    |                  |
| RCIC or HPCI steam | PC       | X                   | X                     | X                          |                                      |                         |                       |                         |                                                  | X                  |                  |                               |                  |                                    |                  |
|                    | RB       |                     |                       |                            |                                      | X                       | X                     | X                       | X                                                |                    | X <sup>(b)</sup> |                               | X                |                                    |                  |
| RCIC or HPCI water | PC       |                     |                       |                            |                                      |                         |                       |                         |                                                  |                    |                  |                               |                  |                                    |                  |
|                    | RB       |                     |                       |                            |                                      |                         | X                     |                         |                                                  |                    |                  |                               |                  |                                    |                  |
| Cleanup water      | PC       | X                   | X                     | X                          |                                      |                         |                       |                         |                                                  | X                  |                  |                               | X                |                                    |                  |
|                    | RB       |                     |                       |                            | X <sup>(c)</sup>                     |                         | X                     |                         |                                                  |                    |                  |                               | X                | X                                  |                  |
|                    | RB       |                     |                       |                            |                                      |                         | X                     |                         |                                                  |                    |                  |                               | X                | X                                  |                  |
| Feedwater          | PC       | X                   | X                     | X                          |                                      |                         |                       |                         |                                                  | x                  |                  |                               |                  |                                    |                  |
|                    | RB       |                     |                       |                            |                                      |                         | X                     |                         |                                                  |                    |                  |                               |                  |                                    |                  |

**LEGEND:**

- A - Alarm
- I - Isolation
- PC - Primary containment
- RB - Reactor building
- CU - Reactor water cleanup
- CW - Reactor building chilled water
- TB - Turbine building

- a. Isolates on high ambient temperature in main steam tunnel or pipe chase.
- b. Break downstream of flow element will isolate the steam line.
- c. Isolates on high temperature or high differential temperature in the RWC equipment room.
- d. Isolates shutdown cooling suction path of RHR only.

HNP-2-FSAR-5

TABLE 5.2-9 (SHEET 1 OF 2)

**RT<sub>NDT</sub> VALUES FOR REACTOR VESSEL MATERIALS  
(HNP-1)**

| <u>Component</u>                | <u>ID</u> | <u>Heat</u> | <u>Test Temp</u><br><u>(°F)</u> | <u>Charpy Energy</u><br><u>(ft-lb)</u> |     |     | <u>(T<sub>sol</sub>-60)</u><br><u>(°F)</u> | <u>Drop</u><br><u>Weight</u><br><u>NDT</u> | <u>RT<sub>NDT</sub></u><br><u>(°F)</u> |
|---------------------------------|-----------|-------------|---------------------------------|----------------------------------------|-----|-----|--------------------------------------------|--------------------------------------------|----------------------------------------|
| <u>Plates &amp; Forgings</u>    |           |             |                                 |                                        |     |     |                                            |                                            |                                        |
| <u>Top Head &amp; Plate</u>     |           |             |                                 |                                        |     |     |                                            |                                            |                                        |
| Dollar Plate                    | G-4412    | C4845-3     | 10                              | 48                                     | 52  | 53  | -16                                        | -10                                        | -10                                    |
| Top Head Torus                  | G-4811    | C4180-2     | 10                              | 74                                     | 83  | 67  | -20                                        | -10                                        | -10                                    |
| Top Head Flange                 | G-4802    | AHY-120     | 10                              | 141                                    | 148 | 188 | -20                                        | 10                                         | 10                                     |
| <u>Shell Courses</u>            |           |             |                                 |                                        |     |     |                                            |                                            |                                        |
| <u>Upper Shell</u>              |           |             |                                 |                                        |     |     |                                            |                                            |                                        |
|                                 | G-4803-2  | C4134-2     | 10                              | 50                                     | 53  | 52  | -20                                        | -10                                        | -10                                    |
|                                 | G-4803-3  | C4121-2     | 10                              | 45                                     | 32  | 40  | 16                                         | -10                                        | 16                                     |
|                                 | G-4803-5  | C4116-2     | 10                              | 41                                     | 49  | 47  | -2                                         | -10                                        | -2                                     |
| <u>Flange</u>                   |           |             |                                 |                                        |     |     |                                            |                                            |                                        |
|                                 | G-4801    | AFZ-148     | 10                              | 86                                     | 67  | 70  | -20                                        | 10                                         | 10                                     |
| <u>Upper Intermediate Shell</u> |           |             |                                 |                                        |     |     |                                            |                                            |                                        |
|                                 | G-4803-1  | C4114-1     | 10                              | 26                                     | 23  | 30  | 34                                         | -10                                        | 34                                     |
|                                 | G-4803-4  | C4116-1     | 10                              | 23                                     | 24  | 24  | 34                                         | -10                                        | 34                                     |
|                                 | G-4803-6  | C4121-1     | 10                              | 32                                     | 35  | 23  | 34                                         | -10                                        | 34                                     |
| <u>Lower Intermediate Shell</u> |           |             |                                 |                                        |     |     |                                            |                                            |                                        |
|                                 | G-4803-7  | C4337-1     | 10                              | 74                                     | 78  | 53  | -20                                        | -40                                        | -20                                    |
|                                 | G-4804-1  | C3985-2     | 10                              | 65                                     | 82  | 71  | -20                                        | -20                                        | -20                                    |
|                                 | G-4804-2  | C4114-2     | 10                              | 84                                     | 80  | 82  | -20                                        | -40                                        | -20                                    |
| <u>Lower Shell</u>              |           |             |                                 |                                        |     |     |                                            |                                            |                                        |
|                                 | G-4805-1  | C4112-1     | 10                              | 42                                     | 40  | 36  | 8                                          | -10                                        | 8                                      |
|                                 | G-4805-2  | C4112-2     | 10                              | 38                                     | 50  | 35  | 10                                         | -10                                        | 10                                     |
|                                 | G-4805-3  | C4149-1     | 10                              | 49                                     | 67  | 58  | -18                                        | -10                                        | -10                                    |
| <u>Bottom Head Dollar Plate</u> |           |             |                                 |                                        |     |     |                                            |                                            |                                        |
|                                 | G-4810    | C4351-3     | 10                              | 70                                     | 68  | 60  | -20                                        | 10                                         | 10                                     |
| <u>Bottom Head Torus</u>        |           |             |                                 |                                        |     |     |                                            |                                            |                                        |
|                                 | G-4807    | C4100-2     | 10                              | 71                                     | 65  | 76  | -20                                        | -10                                        | -10                                    |
|                                 | G-4808    | C4100-1     | 10                              | 80                                     | 86  | 91  | -20                                        | -10                                        | -10                                    |
|                                 | G-4809    | C4182-3     | 10                              | 85                                     | 82  | 92  | -20                                        | -10                                        | -10                                    |

HNP-2-FSAR-5

**TABLE 5.2-9 (SHEET 2 OF 2)  
(HNP-1)**

| <u>Component</u>            | <u>ID</u>   | <u>Heat</u> | <u>Test Temp</u><br><u>(°F)</u> | <u>Charpy Energy</u><br><u>(ft-lb)</u> |     |     | <u>(T<sub>sol</sub>-60)</u><br><u>(°F)</u> | <u>Drop</u><br><u>Weight</u><br><u>NDT</u> | <u>RT<sub>NDT</sub></u><br><u>(°F)</u> |
|-----------------------------|-------------|-------------|---------------------------------|----------------------------------------|-----|-----|--------------------------------------------|--------------------------------------------|----------------------------------------|
| <u>Nozzles</u>              |             |             |                                 |                                        |     |     |                                            |                                            |                                        |
| Recirc Outlet Nozzle        | G-4819-1    | AV-2798     | 10                              | 35                                     | 51  | 42  | 10                                         | 0                                          | 10                                     |
|                             | G-4819-2    | AV-2797     | 10                              | 38                                     | 43  | 49  | 4                                          | 0                                          | 4                                      |
| Recirc Inlet Nozzle         | G-4817-1-4  | EV-9754     | 10                              | 118                                    | 120 | 75  | -20                                        | -20                                        | -20                                    |
|                             | G-4817-5, 6 | AV-1973     | 10                              | 42                                     | 37  | 25  | 30                                         | 0                                          | 30                                     |
|                             | G-4817-7-10 | EV-9753     | 10                              | 84                                     | 68  | 72  | -20                                        | -10                                        | -10                                    |
| Steam Outlet Nozzle         | G-4818-1, 2 | AV-2805     | 10                              | 103                                    | 74  | 83  | -20                                        | 10                                         | 10                                     |
|                             | G-4818-3    | AV-2840     | 10                              | 78                                     | 102 | 76  | -20                                        | 10                                         | 10                                     |
|                             | G-3443-1    | AV-1576     | 10                              | 42                                     | 44  | 64  | -4                                         | 40                                         | 40                                     |
| Feedwater Nozzle            | G-4816-1-4  | AV-2796     | 10                              | 66                                     | 40  | 57  | 0                                          | 10                                         | 10                                     |
| Core Spray Nozzle           | G-4815-1, 2 | AV-2796     | 10                              | 66                                     | 40  | 57  | 0                                          | 10                                         | 10                                     |
| Top Head Instrumentation    | G-2921-5, 6 | EV-9781     | 10                              | 82                                     | 69  | 72  | -20                                        | 0                                          | 0                                      |
| Vent Nozzle                 | G-2920      | AV-2374     | 10                              | 145                                    | 182 | 185 | -20                                        | 0                                          | 0                                      |
| Jet Pump Instrumentation    | G-4813-1, 2 | AV-2374     | 10                              | 145                                    | 182 | 185 | -20                                        | -40                                        | -20                                    |
| CRD Hydraulic System Return | G-4814      | AV-1909     | 10                              | 84                                     | 117 | 78  | -20                                        | 10                                         | 10                                     |
| Drain Nozzle                | G-4004      | AV-1901     | 10                              | 112                                    | 90  | 98  | -20                                        | NA                                         | -20                                    |
| <u>Welds</u>                |             |             |                                 |                                        |     |     |                                            |                                            |                                        |
| Vertical Welds              | I-307       | 13253       |                                 |                                        |     |     |                                            |                                            | -50                                    |
|                             | I-308       | 1P2809      |                                 |                                        |     |     |                                            |                                            | -50                                    |
|                             |             | 1P2815      |                                 |                                        |     |     |                                            |                                            | -50                                    |
| Girth Welds                 | I-313       | 90099       |                                 |                                        |     |     |                                            |                                            | -10                                    |
|                             |             | 33A277      |                                 |                                        |     |     |                                            |                                            | -50                                    |
| <u>Studs</u>                |             |             |                                 |                                        |     |     |                                            |                                            |                                        |
|                             | G-4851      | 38094       | 10                              | 55                                     | 50  | 54  | LST<br>10                                  | OK                                         |                                        |
|                             |             | 37965       | 10                              | 44                                     | 46  | 42  | 70                                         | OK                                         |                                        |
|                             |             | 13921       | 10                              | 50                                     | 54  | 55  | 10                                         | OK                                         |                                        |



HNP-2-FSAR-5

TABLE 5.2-10 (SHEET 1 OF 2)

LIMITING RPV MATERIAL ART<sub>NDT</sub>

HNP-1

| Part Name and Material            | Heat No. | Initial RT <sub>NDT</sub> (°F) | Chemistry |       | CF  | EFPY | Adjustments for 1/4T    |         |                     |                         |
|-----------------------------------|----------|--------------------------------|-----------|-------|-----|------|-------------------------|---------|---------------------|-------------------------|
|                                   |          |                                | %Cu       | %Ni   |     |      | Margin Terms            |         |                     | ART <sub>NDT</sub> (°F) |
|                                   |          |                                |           |       |     |      | ΔRT <sub>NDT</sub> (°F) | σΔ (°F) | σ <sub>1</sub> (°F) |                         |
| Beltline<br>Lower<br>Intermediate | C4114-2  | -20                            | 0.130     | 0.700 | 245 | 20.0 | 96.7                    | 17.0    | 0.0                 | 110.7                   |
|                                   |          |                                |           |       |     | 24.0 | 105.8                   | 17.0    | 0.0                 | 119.6                   |
|                                   |          |                                |           |       |     | 28.0 | 113.4                   | 17.0    | 0.0                 | 127.4                   |
|                                   |          |                                |           |       |     | 32.0 | 120.0 <sup>(3)</sup>    | 17.0    | 0.0                 | 133.9 <sup>(3)</sup>    |
|                                   |          |                                |           |       |     | 36.0 | 127.0                   | 17.0    | 0.0                 | 141.0                   |
|                                   |          |                                |           |       |     | 40.0 | 133.5                   | 17.0    | 0.0                 | 147.5                   |
|                                   |          |                                |           |       |     | 44.0 | 139.7                   | 17.0    | 0.0                 | 153.7                   |
|                                   |          |                                |           |       |     | 48.0 | 145.4                   | 17.0    | 0.0                 | 159.4                   |
|                                   |          |                                |           |       |     | 54.0 | 154.0 <sup>(3)</sup>    | 17.0    | 0.0                 | 167.7 <sup>(3)</sup>    |

| Location                          | Wall thickness (in.) |       | EFPY | Fluence at ID (n/cm <sup>2</sup> ) | Attenuation at 1/4T e <sup>-0.24nt</sup> | Fluence at 1/4T (n/cm <sup>2</sup> ) | Fluence Factor, FF f <sup>(0.28 - 0.10 log f)</sup> | Comments                                                              |
|-----------------------------------|----------------------|-------|------|------------------------------------|------------------------------------------|--------------------------------------|-----------------------------------------------------|-----------------------------------------------------------------------|
|                                   | Full                 | 1/4T  |      |                                    |                                          |                                      |                                                     |                                                                       |
| Beltline<br>Lower<br>Intermediate | 5.380                | 1.345 | 20.0 | 1.23E+18                           | 0.724                                    | 8.93E+17                             | 0.395                                               | Fluence was linearly interpolated based on 36 EFPYs.                  |
|                                   |                      |       | 24.0 | 1.48E+18                           | 0.724                                    | 1.07E+18                             | 0.431                                               | Fluence was linearly interpolated based on 36 EFPYs.                  |
|                                   |                      |       | 28.0 | 1.73E+18                           | 0.724                                    | 1.25E+18                             | 0.463                                               | Fluence was linearly interpolated based on 36 EFPYs.                  |
|                                   |                      |       | 32.0 | 2.00E+18 <sup>(3)</sup>            | 0.724                                    | 1.40E+18 <sup>(3)</sup>              | 0.492                                               | Fluence was linearly interpolated based on 36 EFPYs.                  |
|                                   |                      |       | 36.0 | 2.22E+18                           | 0.724                                    | 1.61E+18                             | 0.518                                               | Fluence assumed such that resulting ART matched that given in ref 23. |
|                                   |                      |       | 40.0 | 2.49E+18                           | 0.724                                    | 1.80E+18                             | 0.545                                               | Fluence assumed such that resulting ART matched that given in ref 23. |
|                                   |                      |       | 44.0 | 2.77E+18                           | 0.724                                    | 2.01E+18                             | 0.570                                               | Fluence assumed such that resulting ART matched that given in ref 23. |
|                                   |                      |       | 48.0 | 3.05E+18                           | 0.724                                    | 2.21E+18                             | 0.593                                               | Fluence assumed such that resulting ART matched that given in ref 23. |
|                                   |                      |       | 54.0 | 3.50E+18 <sup>(3)</sup>            | 0.724                                    | 2.50E+18 <sup>(3)</sup>              | 0.625                                               | Fluence for this EFPY was given in ref 23.                            |

HNP-2-FSAR-5

TABLE 5.2-10 (SHEET 2 OF 2)

HNP-2

| Part Name and Material | Heat No. | Initial RT <sub>NDT</sub> (°F) | Chemistry           |                     | CF  | EFPY                | Adjustments for 1/4T    |                     |                     |                         |
|------------------------|----------|--------------------------------|---------------------|---------------------|-----|---------------------|-------------------------|---------------------|---------------------|-------------------------|
|                        |          |                                | %Cu                 | %Ni                 |     |                     | ΔRT <sub>NDT</sub> (°F) | σΔ (°F)             | σ <sub>1</sub> (°F) | ART <sub>NDT</sub> (°F) |
| Beltline Lower         | C8553-1  | 24                             | 0.08                | 0.58                | 51  | 20.0                | 16.7                    | 13.4                | 0.0                 | 67.5                    |
|                        |          |                                |                     |                     |     | 24.0                | 18.4                    | 13.4                | 0.0                 | 69.2                    |
|                        |          |                                |                     |                     |     | 28.0                | 19.8                    | 13.4                | 0.0                 | 70.6                    |
|                        |          |                                |                     |                     |     | 32.0                | 21.0 <sup>(3)</sup>     | 10.0 <sup>(3)</sup> | 0.0                 | 65.5 <sup>(3)</sup>     |
|                        |          |                                |                     |                     |     | 36.0                | 22.4                    | 13.4                | 0.0                 | 73.2                    |
|                        |          |                                |                     |                     |     | 40.0                | 23.5                    | 13.4                | 0.0                 | 74.3                    |
|                        |          |                                |                     |                     |     | 44.0                | 24.6                    | 13.4                | 0.0                 | 75.4                    |
|                        |          |                                |                     |                     |     | 48.0                | 25.5                    | 13.4                | 0.0                 | 76.3                    |
|                        |          | 54.0                           | 27.0 <sup>(3)</sup> | 13.0 <sup>(3)</sup> | 0.0 | 78.0 <sup>(3)</sup> |                         |                     |                     |                         |


  

| Location       | Wall thickness (in.) |       | EFPY | Fluence at ID (n/cm <sup>2</sup> ) | Attenuation at 1/4T e <sup>-0.24nt</sup> | Fluence at 1/4T (n/cm <sup>2</sup> ) | Fluence Factor, FF f <sup>(0.28 - 0.10 log f)</sup> | Comments                                             |
|----------------|----------------------|-------|------|------------------------------------|------------------------------------------|--------------------------------------|-----------------------------------------------------|------------------------------------------------------|
|                | Full                 | 1/4T  |      |                                    |                                          |                                      |                                                     |                                                      |
| Beltline Lower | 5.380                | 1.345 | 20.0 | 8.56E+17                           | 0.724                                    | 6.20E+17                             | 0.328                                               | Fluence was linearly interpolated based on 54 EFPYs. |
|                | (See Note 2.)        |       | 24.0 | 1.03E+18                           | 0.724                                    | 7.43E+17                             | 0.360                                               | Fluence was linearly interpolated based on 54 EFPYs. |
|                |                      |       | 28.0 | 1.20E+18                           | 0.724                                    | 8.67E+17                             | 0.389                                               | Fluence was linearly interpolated based on 54 EFPYs. |
|                |                      |       | 32.0 | 2.20E+18 <sup>(3)</sup>            | 0.724                                    | 1.60E+18 <sup>(3)</sup>              | 0.415                                               | Fluence was linearly interpolated based on 54 EFPYs. |
|                |                      |       | 36.0 | 1.54E+18                           | 0.724                                    | 1.12E+18                             | 0.439                                               | Fluence was linearly interpolated based on 54 EFPYs. |
|                |                      |       | 40.0 | 1.71E+18                           | 0.724                                    | 1.24E+18                             | 0.461                                               | Fluence was linearly interpolated based on 54 EFPYs. |
|                |                      |       | 44.0 | 1.88E+18                           | 0.724                                    | 1.36E+18                             | 0.482                                               | Fluence was linearly interpolated based on 54 EFPYs. |
|                |                      |       | 48.0 | 2.05E+18                           | 0.724                                    | 1.49E+18                             | 0.501                                               | Fluence was linearly interpolated based on 54 EFPYs. |
|                |                      |       | 54.0 | 3.90E+18 <sup>(3)</sup>            | 0.724                                    | 2.80E+18 <sup>(3)</sup>              | 0.528                                               | See Note 3.                                          |

Notes:

- HNP-1 data obtained from table 3.1 of reference 23. HNP-2 data obtained from table 3.2 of reference 23.
- Reference 23 report developed a bounding P-T curve by using the smaller weld thickness, combined with the thicker lower plate material properties. For this analysis, the smaller thickness is shown (since the P-T curves are based on this thickness), but the ID fluence was adjusted to yield a 1/4T fluence that matched the value in table 3-2<sup>(23)</sup> for the limiting thicker plate. Therefore, the ID fluence value for 54 EFPYs was iterated until the appropriate calculated value at 1/4T was obtained. In effect, the values shown in this table reconcile the analysis case with the bounding case documented in reference 23.
- Values updated based on RPV fracture toughness evaluation for TPO (GE-NE-0000-8119-01, Rev. 0, August 2002). The reactor operating pressure increase (ROPI) to 1060 psia had no impact on these values.







REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

AXIAL THROUGH-WALL CRACK

FIGURE 5.2-1



REV 29 9/11







SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TWO-STAGE SAFETY RELIEF VALVES

FIGURE 5.2-2

(102% extended uprate power; 105% rated core flow; 1073 psia initial dome pressure)



ACAD 2050234


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

RESPONSE TO MSIV  
CLOSURE WITH FLUX SCRAM

FIGURE 5.2-3




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

ADJUSTED REFERENCE TEMPERATURE FOR  
 LIMITED BELTLINE MATERIALS

FIGURE 5.2-4



REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

SENSITIVITY OF PEAK RPV PRESSURE OF INITIAL PRESSURE  
 FOR CODE OVERPRESSURE PROTECTION EVENT

FIGURE 5.2-5





- AXIALLY ORIENTED CRACK
- SATURATES WATER SYSTEM AT 1000 Psig
- ASTERISKS DENOTE CRACK OPENING OF 0.1 in.

REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

CALCULATED LEAK RATE AS A FUNCTION OF  
CRACK LENGTH AND APPLIED HOOP STRESS

FIGURE 5.2-6

### **5.3 THERMAL-HYDRAULIC SYSTEM DESIGN**

#### **5.3.1 ANALYTICAL METHODS AND DATA**

The analytical methods, thermodynamic and hydrodynamic data, used to determine the thermal and hydraulic characteristics of the reactor coolant system are presented in section 4.4.

#### **5.3.2 OPERATING RESTRICTIONS ON PUMPS**

The operating restrictions imposed on the coolant pump to meet net positive suction head requirements are contained in paragraph 4.4.3.2.

#### **5.3.3 POWER-TO-FLOW OPERATING MAP**

A power-to-flow operating map which indicates the permissible operating range is shown in figure 15.1-3.

#### **5.3.4 TEMPERATURE-POWER OPERATING MAP FOR PRESSURIZED WATER REACTOR**

This subsection is not applicable to a boiling water reactor.

#### **5.3.5 LOAD FOLLOWING CHARACTERISTICS**

Load following is not used at Plant Hatch.

#### **5.3.6 TRANSIENT EFFECTS**

The transient effects are presented in section 4.4 and chapter 15.

#### **5.3.7 THERMAL AND HYDRAULIC CHARACTERISTICS SUMMARY TABLE**

Thermal and hydraulic characteristics of the initial core are summarized in table 4A-5.

## **5.4 REACTOR PRESSURE VESSEL AND APPURTENANCES**

### **5.4.1 PROTECTION OF CLOSURE STUDS**

The Hatch Nuclear Plant-Unit 2 (HNP-2) design and inspection procedures are in conformance with the requirements of Regulatory Guide 1.65 (October 1973) except those in Regulatory Positions 2b, 2e, and 3.

Studs were examined in accordance with the requirements of American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section III, N-325; (1968 Edition plus Summer 1970 Addendum in effect at the time of the contract). Bored blank nuts were ultrasonically examined by both the longitudinal and shear wave methods. Shear wave examination of the nuts was performed in both the axial and circumferential directions.

Regulatory Position 3 recommends provision for adequate corrosion protection during venting and filling of the vessel, and while the head is removed. General Electric (GE) supplies thread protectors which prevent stud damage, but stud holes are not plugged, and neither stud nor flange threads are protected from exposure to water. In practice, this has been found to be adequate, as exposure to applied loads and operating and servicing environments has not required the replacement of any boiling water reactor (BWR) studs or flange threads. No corrosion protection for studs is provided.

### **5.4.2 SPECIAL PROCESSES FOR FABRICATION AND INSPECTION**

In addition to the normal radiographic techniques for inspection of welds, ultrasonic techniques were used in accordance with Section III of the ASME Boiler and Pressure Vessel Code.

### **5.4.3 FEATURES FOR IMPROVED RELIABILITY**

No special design or fabrication features were required for the HNP-2 reactor pressure vessel (RPV) to improve its reliability or reduce its potential for failure.

### **5.4.4 QUALITY ASSURANCE SURVEILLANCE**

The RPV was fabricated for GE by Combustion Engineering and was subject to Georgia Power Company (GPC) quality assurance (QA) audit.

QA surveillance procedures were used to ensure that purchased material, equipment, and services associated with the RPV and appurtenances conformed to the requirements of the purchase documents. These procedures include provisions, as appropriate, for source evaluation and selection, objective evidence of quality furnished, inspection at the vendor source, and examination of the RPV upon delivery at the construction site.

#### **5.4.5 MATERIALS AND INSPECTIONS**

The materials which were used in the RPV are listed in table 5.2-6.

The RPV was subject to the inspection requirements in accordance with Section III of the ASME Boiler and Pressure Vessel Code, 1968 edition plus summer 1970 addendum, and the ultrasonic inspection discussed in subsection 5.4.2.

#### **5.4.6 REACTOR PRESSURE VESSEL DESIGN**

##### **5.4.6.1 Safety Design Bases**

The RPV and appurtenances are designed to:

- A. Withstand adverse combinations of loading and forces resulting from operation under abnormal and accident conditions.
- B. Minimize the possibility of brittle fracture of the nuclear system process barrier by the following:
  1. Maximum impact properties at temperatures related to RPV operation were specified for materials used in the RPV.
  2. Expected shifts in nil ductility transition temperature (NDTT) during design service life as a result of environmental conditions, such as neutron flux, were considered and employed in the design.
  3. Operational margins to be observed with regard to the NDTT were specified for each mode of operation.

##### **5.4.6.2 Power Generation Design Basis**

The RPV and appurtenances are designed:

- For a minimum useful life of 40 years. Aging management programs (subsections 18.2.1, 18.2.9, 18.2.12, 18.2.15, and 18.2.17) monitor the condition of the reactor vessel so that actions are taken to provide reasonable assurance that the vessel is capable of performing its intended function for 40 years and beyond.
- So that stresses in the RPV and supports that result from reactions at external and internal supports that are part of the RPV are within ASME Code limits.
- To allow for a suitable program of inspection and surveillance.

### 5.4.6.3 Description

#### 5.4.6.3.1 Reactor Pressure Vessel

The RPV, shown in figure 4.1-1, is a vertical, cylindrical pressure vessel with hemispherical heads of welded construction. The vessel design data are listed in table 5.4-1.

The RPV is designed, fabricated, tested, inspected, and stamped in accordance with the ASME Boiler and Pressure Vessel Code, Section III, Class A (1968 edition plus summer 1970 addendum). Design of the RPV and its support system meets Seismic Category I equipment requirements.

The cylindrical shell and bottom head of the RPV are fabricated of low-alloy steel, the interior of which is clad with stainless steel weld overlay. Internal surfaces of nozzles that connect to stainless steel pipe are also clad. The feedwater cladding was subsequently removed. See paragraph 5.4.6.3.9.

Inplace annealing of the RPV because of radiation embrittlement is unnecessary, as described in paragraph 5.2.4.5.

QA methods used during the fabrication and assembly of the RPV and appurtenances ensure that design specifications are met.

The RPV top head is secured to the RPV by studs and nuts. These nuts are tightened with a stud tensioner. The RPV flanges are sealed with two concentric metal seal-rings designed to permit no detectable leakage through the inner or outer seal at any operating condition, including heating to operating pressure and temperature at a maximum rate of 100°F/h and cold hydrostatic pressure testing at the pressure specified in the ASME Code. To detect seal failure, a 1-in. vent tap is located between the two seal-rings. A monitor line is attached to the tap to provide an indication of leakage from the inner seal-ring seal.

Thermocouples are located on the exterior of the RPV. At other thermocouple locations, two 3/4-in. pads are provided. One is an end pad to hold the end of a 3/16-in.-diameter thermocouple and the other is a clamp pad equipped with a set screw to secure the thermocouple. These thermocouple locations provide a means of observing RPV temperature in response to changes in RPV coolant flowrate. Because RPV metal thickness and the thermal time constant cause the temperature of the RPV surface to lag the coolant temperature, measurements of surface temperature do not afford an effective means of controlling thermal stresses in the RPV.

Procedural controls on plant operation are necessary to hold these thermal stresses within acceptable ranges. These restrictions on coolant temperature are:

- A. The average rate of change of reactor coolant temperature during normal heatup and cooldown does not exceed 100°F during any 1-h period.

- B. The RRS pumps are not operated unless the coolant temperatures in the upper and lower regions of the RPV are within 145°F of each other.
- C. The pump in an idle RRS loop is not started unless the coolant temperature in that loop is within 50°F of reactor coolant temperature.

The limit regarding the normal rate of heatup and cooldown described in item A ensures that the RPV closure, closure studs, RPV support skirt, control rod drive (CRD) housing, and stub tube stresses and usage remain within acceptable limits. The RPV temperature limit on RRS pump operation restriction described in item B augments the item A limit by ensuring that the RPV bottom head region is not warmed at an excessive rate caused by rapid sweep-out of cold coolant in the RPV lower head region by RRS pump operation. Cold coolant can accumulate as a result of CRD inleakage and/or low recirculation flowrate during startup or hot standby. The item C limit further restricts operation of the RRS pumps to avoid high thermal stress effects in pumps and piping while also minimizing thermal stresses on the vessel nozzles.

#### **5.4.6.3.2 Shroud Support**

The reactor vessel shroud is a cylindrical shell that surrounds the reactor core assembly and provides a barrier to separate the upward core flow from the downcomer annulus flow. The shroud support is a circular plate welded to the RPV wall. This support is designed to carry the weight of the shroud, shroud head, core support plate, top guide, the steam separators, the jet pump system, and to laterally support the fuel assemblies. Design of the shroud support also accounts for pressure differentials across the shroud support plate, for the restraining effect of components attached to the support, and for earthquake loadings. The shroud support design is specified to meet appropriate ASME Code stress limits.

#### **5.4.6.3.3 Reactor Pressure Vessel Supports (Refer also to supplement 6A)**

**5.4.6.3.3.1 Vessel Support Assembly.** The RPV support pedestal consists of two concentric steel shells 18 ft 3 in. and 26 ft 3 in. in diameter with concrete fill in between the shells to provide mass and stability. Stiffeners are provided at different locations to distribute the load uniformly over larger areas of the shell. The bottom of the pedestal is anchored to the base slab by means of ninety-two 3-in. diameter A 193 B7 anchor bolts which transfer the loads to the foundation. The top surface of the pedestal is machined and bolt holes are drilled using an identical template that is used for the RPV support skirt which is bolted to the top of the pedestal. Provisions are made at the top of the inner shell to inspect the reactor vessel bolting rings. Details of the RPV support pedestal are described in subsection 3.8.3.

**5.4.6.3.3.2 Reactor Pressure Vessel Stabilizers.** The RPV stabilizers are designed to permit radial and axial vessel expansion, to limit horizontal vibration, and to resist seismic and jet reaction forces. The stabilizers are connected between the RPV and the top of the shield wall surrounding the RPV to provide lateral stability for the upper part of the RPV. Six stabilizer brackets are attached by full penetration welds to the RPV at evenly spaced locations around

the RPV below the flange. Each RPV stabilizer consists of a stabilizer rod threaded at the ends, springs, washers, a nut, a plate, and a bumper bracket with tapered shims. The stabilizers are attached to each bracket and apply tension in opposite directions. The stabilizers are evenly preloaded with tensioners to the values of the residual loads.

#### **5.4.6.3.4 Control Rod Drive Housings**

The CRD housings are inserted through the CRD penetrations in the RPV bottom head and are welded to stub tubes extending into the RPV. Each housing transmits a number of loads to the bottom head of the reactor. These loads include the weights of a control rod, a CRD, a control rod guide tube, a four-lobed fuel support piece, and the four fuel assemblies that rest on the fuel support piece. The housings are fabricated of Type 304 austenitic stainless steel.

#### **5.4.6.3.5 Control Rod Drive Housing Supports**

The CRD housing support is designed to prevent a nuclear transient in the unlikely event that there is a CRD housing failure. This device consists of a grid structure located below the RPV from which housing supports are suspended. The supports allow only slight movement of the CRD or housing in the event of failure. The CRD housing support is discussed in section 4.5.

#### **5.4.6.3.6 Incore Neutron Flux Monitor Housings**

Each incore neutron flux monitor housing is inserted through the incore penetrations in the bottom head of the RPV and is welded to the inner surface of the bottom head.

An incore flux monitor guide tube is welded to the top of each housing, as described in subsection 4.2.2. Either a source range monitor/intermediate range monitor (SRM/IRM) drive unit or a local power range monitor (LPRM) is bolted to the seal-ring flange at the bottom of the housing, as described in subsection 4.2.2.

#### **5.4.6.3.7 Refueling Bellows**

The refueling bellows forms a seal between the RPV and the surrounding primary containment drywell to permit flooding of the space (reactor well) above the RPV during refueling operations. The refueling bellows assembly consists of a Type 304 stainless steel bellows, a backing plate, a spring seal, and a removable guard ring. The backing plate surrounds the outer circumference of the bellows to protect it and is equipped with a tap for testing and for monitoring leakage. The self-energizing spring seal is located in the area between the bellows and the backing plate. This seal is designed to limit water loss in the event of a bellows rupture by yielding to make a tight fit to the backing plate when subjected to full hydrostatic pressure. The guard ring attaches to the assembly and protects the inner circumference of the bellows. The guard ring can be removed from above to inspect the bellows. The assembly is welded to the reactor bellows support skirt and the reactor well seal bulk-head plate. The reactor bellows support skirt is welded to the RPV shell flange. The reactor well seal bulkhead plate bridges the

distance to the primary containment drywell wall. Six watertight hinged covers are bolted in place for normal refueling operation. For normal operation, these covers are opened and removable air supply ducts and air return ducts permit circulation of ventilation air in the region above the reactor well seal.

#### **5.4.6.3.8 Reactor Pressure Vessel Insulation**

The reactor vessel insulation has an average maximum heat transfer rate of  $\sim 0.2$  Btu/h/ft<sup>2</sup>/°F at the operating conditions of 551.7°F for the vessel and 135°F for the drywell air. The drywell average air temperature limit for normal operation is  $\leq 150^\circ\text{F}$ . The insulation panels for the cylindrical shell of the RPV are held in place by resting on circumferential steel rings which have welded brackets which are in turn welded to the biological shield. The insulation is designed to be removable where inspection is required by the inservice inspection code. Shell course welds are inspected remotely.

#### **5.4.6.3.9 Reactor Pressure Vessel Nozzles**

All piping connecting to the RPV nozzles, including instrument piping, has been designed so as not to exceed the allowable loads on any nozzle.

The RPV nozzles are low-alloy steel forgings made in accordance with the ASME Code A508. Nozzles of nominal size larger than 3-in. are full-penetration welded to the vessel. Nozzles of 3-in. nominal size and under may be partial penetration welded, as permitted by ASME Boiler and Pressure Vessel Code, Section III. Nozzles which are partial penetration welded are nickel-chromium-iron forgings made in accordance with ASME Code SB 166 or SB 167.

The RPV top head nozzles are provided with flanges with small groove facing. The drain nozzle is of the full penetration weld design and extends below the bottom outside surface of the RPV. The RRS inlet nozzles, feedwater inlet nozzles, and core spray inlet nozzles all have thermal sleeves similar to those shown in the detail in figure 5.4-1. Information on feedwater nozzle blend radii cracking is provided in NEDO-21821 (NEDE-21821), "Boiling Water Reactor Feedwater Nozzle/Sparger Final Report," and Supplement to that report. The HNP-2 feedwater thermal sleeves and nozzles are the welded-in design and are fully described in NEDO-21821 (NEDE-21821) and their supplements.

Nozzles connecting to stainless piping have safe-ends made of stainless steel. These safe-ends are welded to the nozzles after the RPV has been heat treated to avoid furnace sensitization of the stainless steel.

The nozzle for the core differential pressure and liquid control pipe is designed with a transition so that the stainless steel outer-pipe of the differential pressure and liquid control line can be socket-welded to the inner end of the nozzle and so that the inner pipe passes through the nozzle. This design provides an annular region between the nozzle and the inner liquid control line to minimize thermal shock effects on the RPV in the event that use of the standby liquid control system is required.



#### 5.4.6.4 Safety Evaluation

The RPV design pressure of 1250 psig is based on an analysis of margins required to provide a reasonable operating range. The margins include additional allowances to accommodate transients above the operating pressure (~ 1048 psig at the level of the top head flange) without initiating safety relief valve action. The RPV design temperature of 575°F is based on the saturation temperature of water that corresponds to the design pressure.

To withstand external and internal loadings while maintaining a high degree of corrosion resistance, a high strength carbon alloy steel is used as the base metal, and an internal cladding of stainless steel is applied using weld overlay.

High fatigue usage components are selected to be in a thermal cycle tracking program to assure that such components will continue to meet the cumulative fatigue usage factor (CFUF) requirements of the ASME Code, Section III, design requirement value of 1.00. The thermal cycle tracking program records the pressure and temperature histories during plant transient events. A description of the component cyclic or transient limit program is provided in subsection 18.2.12.

The data are used to update the CFUFs of these high fatigue components to assure reactor vessel component structural adequacy based on actual plant duty. The components selected for monitoring on Units 1 and 2 are the RPV main closure studs, the RPV shell, the RPV recirculation inlet nozzles, and the RPV feedwater nozzles.

The following calculations are used to determine the CFUF for each of the limiting RPV components.

##### RPV Main Closure Studs

$$U_{sc} = X_{cs} + (520.75n_1 + 60.32n_2 + 115.87n_3 + 28.57n_4 + 34.92n_5 + 11.11n_6 + 15.38n_7) \times 10^{-5}$$

where:

- $U_{sc}$  = new CFUF
- $X_{cs}$  = most recently calculated CFUF
- $n_1$  = no. of boltups
- $n_2$  = no. of hydrostatic tests to 1250 psig
- $n_3$  = no. of cooldowns from > 488°F (600 psig) to < 470°F (500 psig)
- $n_4$  = no. of rapid cooldowns at rates > 100°F/h
- $n_5$  = no. of rapid heatups at rates > 100°F/h
- $n_6$  = other scrams (manual scrams that are not performed during shutdown)
- $n_7$  = no. of cooldowns from 551°F (1040 psig) > 20°F to 470°F (500 psig) or above

( $n_1$  through  $n_7$  equals the number of event types during the surveillance period).

##### RPV Shell

$$U_s = X_s + (43.48n_1 + 3.33n_2) \times 10^{-5}$$

where:

## HNP-2-FSAR-5

- Us = new CFUF
- Xs = most recently calculated CFUF
- n<sub>1</sub> = no. of boltups in the surveillance period
- n<sub>2</sub> = no. of any heatups or cooldowns > 100°F during the surveillance period

### RPV Recirculation Inlet Nozzles

$$U_r = X_r + (5n_1 \times 10^{-4})$$

where:

- U<sub>r</sub> = new CFUF
- X<sub>r</sub> = most recently calculated CFUF
- n<sub>1</sub> = no. of recirculation suction temperature cycles of amplitude > 50°F during the surveillance period

### RPV Feedwater Nozzles

$$U_f = X_f + (7.338 \times 10^{-4})(n_1 + n_2)$$

where:

- U<sub>f</sub> = new CFUF
- X<sub>f</sub> = most recently calculated CFUF
- n<sub>1</sub> = no. of startups during the surveillance period
- n<sub>2</sub> = no. of scrams during the surveillance period

These areas have been shown by analysis to have the highest CFUF predictions over the life of the RPV. All other areas of the RPV have been analyzed to have a negligible effect on the fatigue of the RPV and thus are not monitored. The methodology used for calculating the CFUFs is contained in the GE report, "Reactor Pressure Vessel Thermal Cycle Evaluation for Edwin I. Hatch Nuclear Power Station Units 1 and 2," GPC-103-1, DRF:B11-00362, August 1986, GE Letter GEH-042, "Hatch 1 & 2 Extended Power Uprate Cumulative Fatigue Usage Formulas," August 13, 1997, and "Fatigue Analysis for the Recirculation Inlet Nozzles and Main Closure Studs, Edwin I. Hatch Nuclear Power Station Unit 1," GE-NE-523-103-0793, Rev. 0, DRF 137-0010-6. This methodology is reflected in the HNP-1 and HNP-2 procedure for CFUF monitoring, and is performed on an annual basis. Stress evaluation for the RPV has also been performed for thermal power level of 2804 MWt and reactor operating pressure of 1060 psia.<sup>(1, 2)</sup>

### **5.4.7 REACTOR PRESSURE VESSEL SCHEMATIC**

The RPV schematic is shown in figure 5.4-2.


## HNP-2-FSAR-5

### REFERENCES

1. "Safety Analysis Report for Edwin I. Hatch Units 1 and 2 Thermal Power Optimization," NEDC-33085P, GE Nuclear Energy, December 2002.
2. "10-PSI Dome Pressure Increase Project Report for Edwin I. Hatch Units 1 and 2," GE-NE-0000-0003-0634-01, Revision 1, GE Nuclear Energy, July 2003.


**TABLE 5.4-1**  
**REACTOR PRESSURE VESSEL DESIGN DATA**

|                                               |             |
|-----------------------------------------------|-------------|
| Reactor Pressure Vessel                       |             |
| Inside diameter (in.) (minimum)               | 218         |
| Inside length (including closure head)        | 68 ft 8 in. |
| Design pressure and temperature (psig @ °F)   | 1250 @ 575  |
| Reactor Pressure Vessel Support               |             |
| Design horizontal seismic shear (kips)        | 252         |
| Design seismic moment (ft-kips)               | 7016        |
| Vessel Nozzles [No./Size (in.)]               |             |
| Recirculation outlet                          | 2/28        |
| Steam outlet                                  | 4/24        |
| Recirculation inlet                           | 10/12       |
| Feedwater inlet                               | 4/12        |
| Core spray inlet                              | 2/10        |
| CRD                                           | 137/6       |
| Jet pump instrumentation                      | 2/4         |
| Vent                                          | 1/4         |
| Instrumentation                               | 6/2         |
| Head spray (spare connections)                | 2/6         |
| Drain                                         | 1/2         |
| CRD hydraulic system return                   | 1/3         |
| Core differential pressure and liquid control | 1/2         |
| Incore flux instrumentation                   | 43/2        |
| Head seal leak detection                      | 2/1         |




**FEEOWATER NOZZLE**

DETAIL "A"  
TRANSITION FROM A CLAD SHELL TO AN UNCLAD NOZZLE




**CORE DIFFERENTIAL PRESSURE & LIQUID CONTROL NOZZLE**

(SEE VPF 3062-204 AND 3062-227)




**RECIRCULATION INLET NOZZLE**

(SEE VPF 3062-253)



**CORE SPRAY NOZZLE**


(SEE VPF 3062-253)




**N6A NOZZLE ON HEAD**

(SEE VPF 3062-214 AND VPF 3062-216)

NOTE: THIS DRAWING PROVIDES FUNCTIONAL REQUIREMENTS & IS NOT INDICATIVE OF DETAIL DESIGN OF NOZZLES OR THERMAL SLEEVES. THE SUPPLIER SHALL PROVIDE DETAIL DESIGN TO CARRY IMPOSED LOADS & ACCOMMODATE THERMAL TRANSIENTS. THERMAL SLEEVES SHALL BE DESIGNED SO THAT THEY CAN BE INSERTED INTO THE NOZZLE FROM A POSITION INSIDE THE VESSEL.




DETAIL "C"  
INSTRUMENT NOZZLE END



**CONTROL ROD DRIVE HYDRAULIC SYSTEM RETURN NOZZLE**

(SEE VPF 3062-253)



**RECIRCULATION OUTLET NOZZLE**

(SEE VPF 3062-170 FOR HNP-2)

ACAD 2050401


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

REACTOR VESSEL NOZZLES AND PENETRATIONS

FIGURE 5.4-1



REV 21 7/03



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

REACTOR VESSEL SCHEMATIC

FIGURE 5.4-2

## **5.5 COMPONENT AND SUBSYSTEM DESIGN**

This section presents discussions of the performance requirements and design features to ensure overall safety of the various components within the reactor coolant pressure boundary (RCPB) and those subsystems closely allied with the reactor coolant system (RCS) but not a portion of the RCPB. The subsystems and components discussed in this section are the reactor recirculation system (RRS), reactor core isolation cooling (RCIC) system, residual heat removal (RHR) system, reactor water cleanup (RWC) system, main steam lines and feedwater piping from the reactor pressure vessel (RPV) out to the first isolation valve including drains, valves, and component supports. The portions of these subsystems which are within the RCPB are discussed in sections 5.1 through 5.4.

### **5.5.1 RRS AND PUMPS**

#### **5.5.1.1 Safety Design Bases**

The RRS is designed to:

- Ensure an adequate fuel barrier thermal margin during postulated transients.
- Not compromise the ability of the RPV internals to provide a refloodable volume should a failure of piping integrity occur.
- Maintain pressure integrity during adverse combinations of loadings and forces occurring during anticipated operational occurrence (AOO), accident, and special event conditions.

#### **5.5.1.2 Power Generation Design Bases**

The RRS is designed to:

- Provide sufficient flow to remove heat from the fuel over the entire load range.
- Provide an automatic load-following capability over the range of 65 to 100% rated power (see paragraph 7.1.1.2).
- Minimize maintenance situations that would require core disassembly and fuel removal.

#### **5.5.1.3 System Description**

The RRS consists of the two RRS pump loops external to the RPV. These loops provide the piping path for the driving flow of water to the RPV jet pumps, as shown on figure 5.5-1 and

drawing no. H-26003. Each external loop contains one variable-speed motor-driven RRS pump, two motor-operated gate valves, and an adjustable speed drive (ASD) to control RRS pump speed. Each pump discharge line contains a venturi-type flow meter nozzle.

The RRS loops are part of the nuclear system process barrier and are located inside the primary containment structure. The jet pumps are RPV internals. Their location and mechanical design are discussed in subsection 4.2.2. However, certain operational characteristics of the jet pumps are discussed in this subsection. Table 5.5-1 summarizes the design characteristics of the RRS.

The recirculated coolant consists of saturated water from the steam separators and dryers that has been subcooled by incoming feedwater. This water passes down the annulus between the RPV wall and the core shroud. A portion of the coolant flows from the RPV through the two external RRS loops and becomes the driving flow for the jet pumps. Each of the two external RRS loops discharges high-pressure flow into an external manifold from which individual recirculation inlet lines are routed to the jet pump risers within the RPV. The remaining portion of the coolant mixture in the annulus becomes the driven flow for the jet pumps. This flow enters the jet pump at suction inlets and is accelerated by the driving flow. The flows, both driving and driven, are mixed in the jet pump throat section and result in partial pressure recovery. The balance of recovery is obtained in the jet pump diffusing section shown in figure 5.5-2. The adequacy of the total flow to the core is discussed in subsection 4.4.4. Documented tests show that the jet pump design is sound and that jet pump operation is stable and predictable.

There is actually a very low probability that an RRS loop that has been allowed to cool would need to be placed in service again when the nuclear system is hot. The only valid reason for closing both the pump discharge valve and the suction valve is to prevent leakage out of that portion of the RRS loop between the valves, e.g., excessive leakage through the pump mechanical seal. A leak of this nature cannot be repaired without permitting access to the drywell. The nuclear system would in all probability be cooled prior to repair of the leak.

Since the removal of RRS valve internals normally requires unloading of the nuclear fuel, the valves are provided with high-quality back seats and a trim to facilitate stem-packing renewal with the system full of water and to provide adequate leaktightness. The design objective of the back seats and trim is to minimize the need for maintenance of the valve internals.

The feedwater flowing into the reactor vessel annulus during operation provides subcooling for the fluid passing to the recirculation pumps, thus providing the additional net positive suction head (NPSH) available beyond that provided by the pump location below the reactor vessel water level. If feedwater flow is below 20%, the recirculation pump speed is automatically limited. Therefore, automatic protection against recirculation pump cavitation is provided by the 20% feedwater flow limiter. The reactor is designed so that it may be operated with only one recirculation pump.

The RRS pumps can be operated at low speeds during nuclear steam supply system (NSSS) heatup for hydrostatic tests. At this time, they act in conjunction with any contribution from reactor core decay heat to raise NSSS temperature above the limit imposed on the RPV by nil ductility transition temperature considerations so the hydrostatic test can be conducted.



## HNP-2-FSAR-5

Each RRS pump is a single-stage, variable-speed, vertical, centrifugal pump equipped with mechanical shaft seal assemblies.

The RRS pump shaft seal assembly consists of two individual seals built into a cartridge which can be readily replaced without removing the motor from the pump. The seal assembly is designed to require minimum maintenance over a long period of time, regardless of whether the pump is stopped or is operating at various speeds, with water at various pressures and temperatures. Each seal is designed for a life of 1 year based on a 90% probability factor. Each individual seal in the cartridge is capable of sealing against pump design pressure so that any one seal can adequately limit leakage in the event that the other seal should fail. A breakdown orifice is provided in the pump casing to reduce leakage in the event of a gross failure of both shaft seals. Provision is made for monitoring the pressure drop across each individual seal as well as the cavity temperature of each seal. Provision is also made for piping the seal leakage to a flow-measuring device which alarms on high leakage.

Each RRS pump motor is a variable-speed ac electric motor which can drive the pump over a controlled range of 20 to 100% of rated pump speed. The motor is designed to operate continuously at any speed within the power supply frequency range of 11.5 to 57.5 Hz. Electrical equipment is designed, constructed, and tested in accordance with the applicable sections of National Electrical Manufacturers Association standards.

A variable-frequency ASD located outside the drywell supplies power to each RRS pump motor. The pump motor is electrically connected to the ASD and is started when the ASD is energized. Minimum speed corresponds to a frequency of 11.5 Hz.

The combined rotating inertias of the RRS pump and motor are chosen to provide an acceptable coastdown of flow following loss of power to the drive motors so that the core is adequately cooled during AOOs. The effective inertias of these devices are specified in the following form, which takes into account the torque and speed conditions on each rotating shaft:

$$\sum_{\text{All shafts}} \left[ \frac{\text{Inertia (lb-ft}^2\text{)} \times \text{speed (radian/s)}}{\text{g(ft/s}^2\text{)} \times \text{(torque ft-lb)}} \right]$$

The design objective for the RRS pump internals is to provide a unit that does not require removal from the system for rework or overhaul at intervals of < 5 years. Erosion, corrosion, and material fatigue were accounted for in the design of the pump casings and valve bodies. Aging management programs (subsections 18.2.1, 18.2.6, 18.2.12, 18.3.2, and 18.5.1) monitor the condition of the pumps and valves so that actions are taken to provide reasonable assurance that these components are capable of performing their intended functions for 40 years and beyond. The pump drive motor, impeller, and wear rings are designed for as long a life as is practical. Pump mechanical-seal parts are expected to have a life exceeding 1 year to afford convenient replacement during refueling outages.

The original RRS piping made from Type 304 stainless steel material was replaced with Type 316 nuclear grade material. The replaced RRS is of all-welded construction but is modified to reduce the number of welds; i.e., no end caps, no contour nozzles, one-piece

cross-reducer-tee, and use of extra-long tangent elbows in lieu of an elbow and a short pipe spool. The replaced RRS is designed to meet the requirements of the 1980 ASME Boiler and Pressure Vessel Code, Section III, Class 1, with Addenda through Winter 1981 and is constructed to the 1980 Edition of the ASME Boiler and Pressure Vessel Code, Section III, Class 1, with Addenda through Winter 1980.

Except for the ASD, the RRS is designed as Seismic Category I. The pump is assumed to be filled with water for the analysis. Vibration snubbers located at the top of the motor and at the bottom of the pump casing are designed to resist horizontal reactions.

The RRS piping, valves, and pumps are supported by constant-support and variable-support hangers to avoid the use of expansion loops that would be required if the pumps were anchored. In addition, the RRS loops are provided with a system of restraints designed so that reaction forces associated with any split or circumferential break do not jeopardize containment integrity. This restraint system provides adequate clearance for normal thermal expansion movement of the loop. Because possible pipe movement is limited to slightly more than the clearance required for thermal expansion movement, no impact loading on limit stops is considered.

The RRS piping, valves, and pump casings are covered with thermal insulation which is a glass fiber-type insulation comprised of a flexible light-density, fibrous glass pad insulation and encapsulated in woven glass cloth forming a composite blanket. The blanket is then covered by stainless-steel jackets and a mechanism for locating and identifying each weld under the insulation. Removable insulation sections are provided at all field welds to facilitate periodic inspection as required by ASME Boiler and Pressure Vessel Code, Section XI rules for inservice inspection of nuclear reactor coolant systems.

#### **5.5.1.4 Safety Evaluation**

RRS malfunctions that pose threats of damage to the fuel barrier are described and evaluated in section 15.2. It is shown in section 15.2 that none of the malfunctions result in fuel damage. The RRS has sufficient flow coastdown characteristics to maintain fuel thermal margins during AOOs.

Figure 5.5-3 shows the core flooding capability provided by a jet pump design plant. No recirculation line break can prevent reflooding of the core to the level of the jet pump suction inlet. The core flooding capability of the RRS and of a jet pump design plant is discussed in reference 1 and in section 15.2.

Piping and pump design pressures for the RRS are based on peak steam pressure in the reactor dome, appropriate pump head allowances, and the elevation head above the lowest point in the RRS loop. Piping and related equipment pressure parts are chosen in accordance with applicable codes. Use of the applicable code design criteria, tabulated in section 3.9, ensures that a system designed, built, and operated within design limits has an extremely low probability of failure caused by any known failure mechanism.

## HNP-2-FSAR-5

General Electric (GE) purchase specifications require that the RRS pump's first critical speed be not < 130% of operating speed. GE purchase specifications also require that integrity of the pump case be maintained through all transients and that the pump remain operable through all normal and upset transients. The design of the pump and motor bearings is required to be such that the dynamic load capability at rated operating conditions is not exceeded during the design basis earthquake (DBE).

The hypothetical loss of component cooling water to the RRS pumps was examined and is tabulated below (drawing no. H-26003):

### A. Closed Cooling Water to Pump Motor Bearings and Windings

Assumptions: Closed cooling water is stopped.

Sequence of events

Low flow alarm from FS N008 (windings)

High temperature alarms

|                                                     |   |                                           |
|-----------------------------------------------------|---|-------------------------------------------|
| TE N009                                             | - | Motor winding cooling water discharge     |
| TE N001                                             | - | Motor bearing oil cooling water discharge |
| TE B <sub>1</sub> , B <sub>2</sub>                  | - | Motor thrust bearing lower face           |
| TE A <sub>1</sub> , A <sub>2</sub>                  | - | Motor thrust bearing upper face           |
| TE C <sub>1</sub> , C <sub>2</sub>                  | - | Upper guide bearing                       |
| TE D <sub>1</sub> , D <sub>2</sub> , E <sub>1</sub> | - | Motor winding E@, F!, F@                  |
| TE G <sub>1</sub> , G <sub>2</sub>                  | - | Lower guide bearing                       |

If the operator ignores all these alarms, bearing damage occurs in 10 to 15 min.

The pump continues to run until a winding short occurs due to excessive winding temperature. This causes an immediate pump trip.

### B. Closed Cooling Water to Pump Seals

Assumption: Closed cooling water is stopped.

Sequence of events

Low-flow alarm from FS N004

## HNP-2-FSAR-5

Seal purge provides enough cooling to keep the seal cavities from heating up enough to cause damage to the seals.

### C. Seal Purge Water

Assumption: Control rod drive (CRD) system water is stopped.

Sequence of events

Seal flow reverses due to the decrease in pressure in the seal cavities. The seal cavity temperatures increase slightly due to the entry of reactor water. The pump seal cooling system removes this additional heat.

### D. Pump Seal Cooling Water and Seal Purge Water

Assumptions:

1. Closed cooling water is stopped.
2. CRD system water is stopped.

Sequence of events

Low-flow alarm from FS N004

Seal cavities start to heat up due to loss of cooling.

Temperature alarms

TE N003 - Pump seal flow

Seal cavity temperatures

No. 1 cavity

No. 2 cavity

Seals start to deteriorate, increasing leakage into No. 2 cavity and eventually out of No. 2 cavity.

- Seal staging high-flow alarm - FS N007
- Seal leak detection high-flow alarm - FS N002

The pump continues to operate until the reactor is shut down due to high identified leakage in the drywell, or the pump is tripped and isolated to reduce the leakage.

Since the failures discussed in items A through D produce no consequences that are important to reactor safety, it is not necessary to provide a single-failure proof cooling water system.

Additional discussion is contained in NEDO-24083, Recirculation Pump Shaft Seal Leakage Analysis.

Analyses were also performed to investigate the possibility of the RRS pump becoming a missile during the postulated double ended pipe break in the RRS pump suction or discharge lines.

This analysis demonstrates that for the complete spectrum of breaks in piping on the discharge side of the recirculation pump, no overspeed conditions exist. The study indicates by conservative analysis that in the unlikely event of a completely offset guillotine suction break, potential overspeed may be calculated. However, further considerations support the conclusion that this calculated overspeed condition would not realistically create an unsafe condition. As a result, there is no need for protective equipment on the recirculation pumps in GE boiling water reactors (BWRs).

#### **5.5.1.5 Tests and Inspections**

*Quality control methods are used during fabrication and assembly of the RRS to ensure that design specifications are met. Tests and inspections are carried out as described in chapter 14.*

*The RCS was thoroughly cleaned and flushed before fuel was loaded initially and after replacement of the recirculation piping system.*

*During the preoperational test program, the RRS was hydrostatically tested at 125% reactor vessel design pressure. See paragraph 3.9.1.1.1 for the restart test program after the recirculation pipe replacement. Preoperational tests on the RRS also include checking for proper operation of the valves. Pumps and motor-generator sets are preoperationally tested, and operation of the flow-control system is checked.*

*During the startup test program, horizontal and vertical motions of the RRS piping and equipment were observed, and supports were adjusted as necessary to ensure that components are free to move as designed. NSSS responses to RRS pump trips at rated temperatures and pressure were evaluated during the startup tests, and plant power response to recirculation flow control was determined*

A hydrostatic test at a pressure not to exceed system operational pressure is made following each removal and replacement of the reactor vessel head.

Inservice inspection is considered in the design of the RRS to ensure adequate working space and access for inspection of selected components in accordance with the ASME Boiler and Pressure Vessel Code, Section XI. The criteria for selecting the components and locations to be inspected are based on the probability of a defect occurring or enlarging at a given location, including areas of known stress concentrations and locations where cyclic strain or thermal stress might occur. The RRS pump casings, valve bodies, and piping connection welds are

visually inspected and given other nondestructive inspections from at least one side on a periodic basis.

## **5.5.2 STEAM GENERATORS**

Steam generators are not applicable to a BWR.

## **5.5.3 REACTOR COOLANT PIPING**

The RRS piping is discussed as part of the RRS in subsection 5.5.1. The RRS loops are shown on figure 5.5-1 and drawing no. H-26003. The design characteristics are presented in table 5.5-1.

## **5.5.4 MAIN STEAM LINE FLOW RESTRICTORS**

### **5.5.4.1 Safety Design Bases**

The main steam line flow restrictors are designed to:

- Limit the loss of coolant from the RPV following a steam line rupture outside the primary containment to the extent that the RPV water level does not fall below the top of the core within the time required to close the main steam isolation valves (MSIVs).
- Withstand the maximum pressure difference expected across the restrictor, following complete severance of a main steam line.

### **5.5.4.2 Description**

A main steam line flow restrictor is provided for each of the four main steam lines, as shown in figure 5.5-4. The restrictor is a complete assembly welded into the main steam line. It is located between the RPV and first MSIV and is downstream of the main steam line safety relief valves. The restrictor limits the coolant blowdown rate from the RPV in the event a main steam line break (MSLB) occurs outside the primary containment to the maximum (choke) flow specified. The restrictor assembly consists of a venturi-type nozzle insert welded, in accordance with applicable code requirements, into the main steam line. The flow restrictor is designed and fabricated to ASME Code, Section III.

The flow restrictor has no moving parts. Its mechanical structure can withstand the velocities and forces associated with an MSLB. The maximum differential pressure is 1375 psi, the ASME Code limit. The rated capacity of the RPV pressure-relieving devices is sufficient to prevent a rise in pressure within the protected vessel of more than 110% of the design pressure ( $1.10 \times 1250 = 1375$  psig).

The ratio of venturi-throat diameter to steam line diameter of approximately 0.5058 results in a maximum pressure differential of 10 psi at rated flow. This design limits the steam flow in a severed line to approximately 200% rated flow, yet it results in negligible increase in steam moisture content during normal operation. The restrictor is also used to measure steam flow and to initiate closure of the MSIVs when the steam flow exceeds preselected operational limits.

#### **5.5.4.3 Safety Evaluation**

In the event a main steam line should break outside the primary containment, the critical flow phenomenon would restrict the steam flowrate in the venturi throat to 200% of rated value. Prior to isolation valve closure, the total coolant losses from the RPV are not sufficient to cause core uncovering. Thus, the core is adequately cooled at all times.

Analysis of the main steam line break accident (MSLBA) shows that the core remains covered with water and that the amount of radioactive material released to the environs through the MSLB does not exceed the guideline values of 10 Code of Federal Regulation (CFR) 100. The MSLBA analysis is described in section 15.3.

Tests on a scale model determined final design and performance characteristics of the flow restrictor. The characteristics include maximum flowrate of the restrictor corresponding to the accident conditions, irreversible losses under normal plant operating conditions, and discharge moisture level. The tests showed that flow restriction at critical throat velocities is stable and predictable. Unrecovered differential pressure across a scale model restrictor is consistently about 10% of the total nozzle pressure differential, and the restrictor performance is in agreement with existing ASME correlation. Full-scale restrictors have a hydraulic shape that is slightly different and a differential pressure loss of ~ 15%.

If moisture forms in the nozzle throat due to a momentary large static pressure reduction, the droplets of wet steam would have to be at saturation temperature corresponding to throat static pressure. When proceeding to the downstream region where vapor temperatures are higher, the droplets of wet steam vaporize somewhat and reach equilibrium with vapor at a lower pressure. The moisture is reduced and actually is negligible. It has negligible corrosion effect on the highly corrosion-resistant material (A351 stainless steel) being used for the inlet and throat sections. High-velocity steam also has negligible erosion effect on this material.

The steam-flow restrictor is exposed to steam of 0.1 to 0.2% moisture flowing at velocities of 150 ft/s (steam piping inside diameter) to 600 ft/s (steam restrictor throat). American Society of Testing Materials (ASTM) A 351 (Type 304) cast stainless steel was selected for the steam-flow restrictor material because it has excellent resistance to erosion-corrosion in this environment. The excellent performance of stainless steel in high-velocity steam appears to be due to its resistance to corrosion. A protective surface film forms on the stainless steel which prevents any surface attack, and this film is not removed by the steam.

Surface finish has a minor effect on erosion-corrosion. Experience shows that a machined or a ground surface is sufficiently smooth and that no detrimental erosion occurs.

#### **5.5.4.4 Tests and Inspections**

The flow restrictor forms a permanent part of the main steam line piping and has no moving components. Only very slow erosion occurs with time, and such a slight enlargement has no safety significance. Stainless steel resistance to corrosion has been substantiated by turbine inspections at the Dresden Unit 1 facility, which have shown no noticeable effects from erosion on the stainless steel nozzle partitions. Aging management programs (subsections 18.2.1 and 18.2.12) monitor the condition of the flow restrictors so that actions are taken to provide reasonable assurance that these components are capable of performing their intended function for 40 years and beyond.

#### **5.5.5 MAIN STEAM LINE ISOLATION VALVES**

##### **5.5.5.1 Safety Design Basis**

The MSIVs, individually or collectively, are designed to:

- Close the main steam lines within the time established by design basis accident (DBA) analysis to limit the release of reactor coolant.
- Close the main steam lines slowly enough that simultaneous (inadvertent) closure of all steam lines does not exceed NSSS design limits.
- Close the main steam lines when required, despite single failure in either valve or in the associated controls, to provide a high level of reliability for the safety function.
- Use separate energy sources as the motive force to independently close the redundant isolation valves in the individual steam lines.
- Use local stored energy (compressed air and springs) to close at least one isolation valve in each steam pipeline without relying on the continuity of any variety of electrical power to furnish the motive force to achieve closure.
- Be able to close the steam lines, either during or after seismic loadings, to ensure isolation if the nuclear system is breached.
- Have the capability for being tested, during normal operating conditions, to demonstrate that the valves function.



### 5.5.5.2 Description

Two isolation valves are welded in a horizontal run of each of the four main steam pipes. One valve is as close as possible to the primary containment barrier and inside it, and the other is just outside the barrier. When closed, the valves form part of the nuclear system process barrier for openings outside the containment and part of the pressure barrier for nuclear system breaks inside the containment.

Figure 5.5-5 shows an MSIV. Each is a 24-in., Y-pattern globe valve. Design steam flowrate through each valve is  $3.04 \times 10^6$  lb/h. The main disc or poppet is attached to the lower end of the stem and moves in guides at a 45-degree angle from the inlet pipe. Normal steam flow tends to close the valve, and higher inlet pressure tends to exert a higher closing force on the valve disk.

The stem disk attached to the end of the valve stem closes a small pressure-balancing hole in the poppet. When the hole is open, it acts as a pilot valve to relieve differential pressure forces on the poppet. Valve stem travel is sufficient to give a flow area past the wide-open poppet approximately equal to the seat port area. The poppet travels ~ 90% of the valve stem travel, and the last 10% of travel closes the pilot hole. A helical spring between the stem and the poppet keeps the pilot hole open when the poppet is off its seat, but failure of the spring does not prevent closure of the valve. The air cylinder can open the poppet with a maximum differential pressure of 200 psi across the isolation valve in a direction that tends to hold the valve closed.

The 45-degree angle permits the inlet and outlet passages to be streamlined. This minimizes pressure drop during normal steam flow and helps prevent debris blockage. The pressure drop at rated flow is ~ 7 psi. The valve stem penetrates the valve bonnet through a stuffing box that has replaceable packing. To help prevent leakage through the stem packing, the poppet backseats when the valve is fully open. The bonnet provides for seal welding in case leaks develop after the valve has had extensive service.

Attached to the upper end of the stem is an air cylinder that opens and closes the valve and a hydraulic dashpot that controls its speed. The speed is adjusted by a valve in the hydraulic return line bypassing the dashpot piston. Valve closing time is adjustable to between 3 and 5 s.

The air cylinder is supported on large shafts screwed and pinned into the valve bonnet. The shafts are also used as guides for the helical springs used to close the valve in the event that air pressure is not available. The springs exert downward force on the spring seat member which is attached to the stem. Spring guides prevent scoring in normal operation and prevent binding if a spring breaks. The spring seat member is also closely guided on the support shafts and rigidly attached to the stem to control any eccentric force in case a spring breaks.

The motion of the spring seat member actuates switches at fully open, 90% open, and fully closed valve positions. Starting from the full open position, switches at the 90% open position turn on the close light, while the open light stays on for valve testing, and initiate reactor scram if several valves close simultaneously.

## HNP-2-FSAR-5

The valve is operated by pneumatic pressure and by the action of compressed springs. The control unit is attached to the air cylinder. This unit contains three types of control valves: pneumatic, ac control system A, and ac control system B. These control valves open and close the main valve and exercise it at slow and fast speed. Remote-manual switches in the main control room (MCR) enable the operator to operate the valves.

Operating air is supplied to the valves from the plant compressed-air system or nitrogen supply through a check valve. An accumulator tank between the control valve and the check valve provides backup operating air. Each valve is designed to accommodate saturated steam at 1250 psig and 575°F, with a moisture content of ~ 0.23%, an oxygen content of 30 ppm, and a hydrogen content of 4 ppm.

In the worst-case conditions of the main steam line rupturing downstream of the valve, steam flow would quickly increase to 200% of rated flow. Further increase is prevented by the venturi flow restrictor upstream of the valves.

During approximately the first 75% of closing, the valve has little effect on flow reduction because the flow is choked by the venturi restrictor upstream of the valves. After the valve is ~ 75% closed, flow is reduced as a function of the valve area versus travel characteristic.

The design objective for the valve is a minimum of 40-years service at the specified operating conditions. Operating cycles are estimated to be 100 cycles per year during the first year and 50 cycles per year thereafter.

Corrosion is accounted for in the design of the MSIVs. Aging management programs (subsections 18.2.1, 18.2.9, and 18.4.5) monitor the condition of the valves so that actions are taken to provide reasonable assurance that these components are capable of performing their intended functions for 40 years and beyond.

Design specification ambient conditions for normal plant operation are 135°F normal temperature, 150°F maximum temperature, 100% humidity, in a radiation field of 15 R/h due to radiation gamma and 25 R/h due to neutron-plus-gamma radiation, continuous for design life. The inside valves are not continuously exposed to maximum conditions, particularly during reactor shutdown, and valves outside the primary containment and shielding are in ambient conditions that are considerably less severe.

The MSIVs are designed to close under accident environmental conditions of 340°F for < 60 s at 65 psig.

In addition, they are designed to remain closed under the following post-accident environmental conditions:

- 340°F for 3 h at 45 psig.
- 320°F for an additional 3 h at 45 psig.
- 250°F for an additional 24 h at 25 psig.

## HNP-2-FSAR-5

- 200°F for an additional 100 days at 20 psig.

(Refer to the Plant Hatch Central File for the environmental requirements of the electrical portion of the MSIVs.)

To sufficiently resist the response motion from the DBE, the MSIV installations are designed as Seismic Category I equipment. The valve assembly is manufactured to withstand the design basis seismic forces applied at the mass center, assuming the cylinder/spring operator is cantilevered from the valve body and the valve is located in a horizontal run of pipe. The stresses caused by horizontal and vertical seismic forces are assumed to act simultaneously and are combined. The stresses in the actuator supports caused by seismic loads are combined with the stresses caused by other live and dead loads, including operating loads. The allowable stress for this combination of loads is based on the ordinary allowable stress set forth in the applicable codes. The parts of the MSIVs that constitute a process fluid pressure boundary are designed, fabricated, inspected, and tested as required by the ASME Boiler and Pressure Vessel Code, Section III, for Class I valves.

HNP-2 processes MSIV leakage which could leak through the closed MSIVs following a loss-of-coolant accident (LOCA). The leakage is directed from the MSIV through the main steam drain line to the isolated condenser where the leakage decays off and plates out. A description of the MSIV leakage treatment system is presented in section 9.5.10.

### **5.5.5.3 Safety Evaluation**

In a direct-cycle nuclear power plant, the reactor steam goes to the turbine and to other equipment outside the reactor containments. Radioactive materials in the steam are released to the environs through process openings in the steam system or they escape from accidental openings. A large break in the steam system can drain the water from the reactor core faster than it is replaced by feedwater.

The analysis of a complete, sudden steam line break outside the primary containment is described in chapter 15. The analysis shows that the fuel barrier is protected against loss of cooling if MSIV closure takes  $\leq 5.5$  s. This 5.5-s limitation includes as much as 0.5 s for the instrumentation to initiate valve closure after the break. The calculated radiological time effects of the radioactive material assumed to be released with the steam are shown to be well within the guideline values for such an accident.

The shortest closing time,  $\sim 3$  s, of the MSIVs is also shown in chapter 15 to be satisfactory. The switches on the valves initiate reactor scram when several valves are more than 10% closed. The pressure rise in the system from stored and decay heat may cause the NSSS safety/relief valves to open briefly, but the rise in fuel-cladding temperature is insignificant. The transient is less than that from sudden closure of the turbine stop valves ( $\sim 0.1$  s) coincident with postulated failure of the turbine bypass valves to open. No fuel damage results.

The ability of this 45-degree, Y-design globe valve to close in a few seconds after a steam line break, under conditions of high-pressure differentials and fluid flows with fluid mixtures ranging from mostly steam to mostly water, has been demonstrated in a series of tests in dynamic test

## HNP-2-FSAR-5

facilities. Dynamic tests with a 1-in. valve show that the analytical method is valid. A full-size, 20-in. valve was tested in a range of steam-water blowdown conditions simulating postulated accident conditions.<sup>(2)</sup>

The following specified hydrostatic, leakage, and stroking tests, as a minimum, are performed by the valve manufacturer in shop tests:

- A. To verify its capability to close between 3 and 5 s, each valve was tested at rated pressure (1000 psig) and no flow. The valve was stroked several times, and the closing time was recorded. The valve was closed by spring only and by the combination of air cylinder and springs.
- B. Leakage was measured with the valve seated and backseated. Seat leakage was measured by pressurizing the upstream side of the valve. The specified maximum seat leakage, using cold water at design pressure, is 2 cc/h/in. of nominal valve size. Backseat leakage is 2 cc/h/in. of stem diameter. In addition, an air seat leakage test was conducted using 50-psi pressure upstream. Maximum permissible leakage is 0.1 sf<sup>3</sup>/h/in. of nominal valve size. There must be no visible leakage from either set of stem packing at design pressure. The valve stem is operated a minimum of three times from the closed position to the open position, and the packing leakage must still be zero by visual examination.
- C. Each valve was hydrostatically tested in accordance with the requirements of the draft ASME Nuclear Pump and Valve Code through Winter 1971. During valve fabrication, extensive nondestructive tests and examinations were conducted. Tests included radiographic, liquid penetrant, or magnetic particle examinations of casting, forgings, welds, hard facings, and bolts.
- D. The spring guides, the guiding of the spring seat member on the support shafts, and rigid attachment of the seat member ensure correct alignment of the actuating components. Binding of the valve poppet in the internal guides is prevented by making the poppet in the form of a cylinder longer than its diameter and by applying steam force near the bottom of the poppet. Clearance between the poppet or warpage of the seat can be tolerated and a seat still achieved.

After the valves were installed in the NSSS, each valve was tested several times in accordance with the preoperational and startup test procedures. Two isolation valves provide redundancy in each steam line so that either can perform the isolation function, and either can be tested for leakage after the other is closed. The inside valve and outside valve and their respective control systems are separated physically.

The isolation valves and their installation are designed as Seismic Category I equipment. The design of the isolation valve has been analyzed for earthquake loading. These loads are small compared with the pressure and operating loads that the valve components are designed to withstand. The cantilevered support of the air cylinder, hydraulic cylinder, springs, and controls is the key area. The increase in loading caused by the specified earthquake loading is negligible at the joints between the support shafts and the valve bonnet.

Electrical equipment that is associated with the isolation valves and that operates in an accident environment is limited to the wiring, solenoid valves, and position switches on the isolation valves. The containment pressure and temperature transient following an accident is discussed in section 6.2.

#### **5.5.5.4 Tests and Inspections**

The MSIVs can be functionally tested for operability during plant operation and refueling outages. The test operations are listed below. During a refueling outage the MSIVs can be functionally tested, leaktested, and visually inspected. The MSIVs can be tested and exercised individually to the 90% open position because the valves still pass rated steam flow when 90% open.

The MSIVs can be tested and exercised individually to the fully closed position if reactor power is reduced sufficiently to avoid scram from reactor overpressure or high flow in the remaining main steam lines through the flow restrictors.

Leakage from the valve stem packing becomes suspect during reactor operation from measurements of leakage into the primary containment or from observations or similar measurements in the secondary containment.

Any excessive leakage found is corrected, and the leak-rate measurement is repeated. During prestartup tests following an extensive shutdown, the valves receive the same hydrostatic tests (~ 1000 psi) that are imposed on the primary system.

Such a test and leakage measurement program ensures that the valves are operating correctly and that a leakage trend is detected.

#### **5.5.6 RCIC SYSTEM**

##### **5.5.6.1 Safety Design Bases**

The RCIC system is designed to:

- Ensure that adequate core cooling takes place to prevent the reactor fuel from overheating in the event that reactor isolation is accompanied by loss of flow from the reactor feedwater system.
- Withstand the effects of an earthquake without a failure.

### **5.5.6.2 Power Generation Design Bases**

The RCIC system is designed to:

- Operate automatically in time to maintain sufficient coolant in the RPV so that the low-pressure emergency core cooling systems (low-pressure coolant injection (LPCI) and core spray (CS) systems) are not actuated.
- Provide for remote-manual operation of the system by an operator.
- Provide a high degree of assurance that the system operates when necessary.
- Have the power supply for the system from immediately available energy sources of high reliability.
- Provide for periodic testing during plant operation.

### **5.5.6.3 System Description**

The RCIC system consists of a steam-driven turbine-pump unit and associated valves and piping capable of delivering makeup water to the RPV. The RCIC system is shown on drawing nos. H-26023 and H-26024.

The steam supply to the turbine comes from the reactor vessel. The steam exhaust from the turbine dumps to the suppression pool. The pump can take suction from the demineralized water in the condensate storage tank (CST) or from the suppression pool.

The equipment and the operations required by the operator for all manual operations of the RCIC are as follows:

- A. Manual startup: Start up the gland-condensing equipment. Line up the RCIC pump discharge either to the reactor or to the CST by respectively opening either the reactor injection or storage tank injection valve after first verifying that the other is closed. Verify that the suction line valves are open initially to the storage tank. Depress the RCIC manual initiation push button; then verify the opening of the steam supply valve (2E51-F045).
- B. Manual shutdown: Push the turbine trip while closing the steam supply valve to the turbine. Close the pump discharge valve used. Turn off the gland-condensing equipment.

The pump discharges either to the feedwater line or to a full-flow return test line to the CST. A minimum-flow bypass line to the suppression pool is provided to protect the pump during startup and shutdown. The makeup water is delivered into the RPV through the feedwater line and is distributed within the reactor vessel through the feedwater sparger. Cooling water for the RCIC turbine lube oil cooler and barometric condenser is supplied from the discharge of the pump, as shown on drawing nos. H-26023 and H-26024.

## HNP-2-FSAR-5

Following any reactor shutdown, steam generation continues because of heat produced by the radioactive decay of fission products. Initially, the rate of steam generation can be as much as ~ 6% of rated flow and is augmented during the first few seconds by delayed neutrons and some of the residual energy stored in the fuel. Steam normally flows to the main condenser through the turbine bypass or, if the condenser is isolated, to the suppression pool. The fluid removed from the RPV is normally made up by the feedwater pumps supplemented by leakage from the CRD system. If makeup water is required to supplement these primary sources of water, the RCIC turbine-pump unit starts automatically upon receipt of the RPV water level 2 signal (drawing no. H-24751) or is started by the operator from the MCR. The RCIC delivers its design flow within 45 s after actuation. To limit the amount of fluid leaving the RPV, the RPV water level 1 signal actuates the closure of the MSIVs.

The RCIC makeup capacity is sufficient to avoid the need for the low-pressure emergency core cooling system (ECCS). Pump suction is normally lined up to the CST. The volume of water stored for the RCIC is sufficient to allow operation for 8 h after shutdown, assuming that none of the steam generated in the RPV is returned to the RPV as condensate. Other systems that use the same reservoir and could jeopardize the availability of this quantity of water can be isolated. Should the CST be drawn down to a low level, an automatic transfer of pump suction to the suppression pool occurs.

The RCIC system is sized to prevent actuation of the RPV water level 1 signal for RPV isolation incidents. Prevention of this signal ensures core cooling and prevents automatic depressurization system (ADS) actuation, thus preventing inadvertent blowdown of the RPV for this situation.

Quantitative information on steam and delivery water conditions are given on drawing no. S-25171 for all operating modes of the RCIC system.

The backup supply of cooling water for the RCIC is the suppression pool. The turbine-pump assembly is located below the level of the CST and below the minimum water level in the suppression pool to ensure positive suction head to the pump. NPSH requirements are satisfied by providing adequate suction head and adequate suction line size. System performance under various operating conditions is shown on drawing no S-25171.

All components required for initiating the RCIC are completely independent of auxiliary ac power, plant service air, and external cooling water systems. These components require only power derived from the station battery to operate the valves and logic. The power source for the turbine-pump unit is the steam generated in the RPV by the decay heat in the core. The steam is piped directly to the turbine, and the turbine exhaust is piped to the suppression pool.

The starting sequence for the RCIC turbine involves the use of a steam admission valve having a special contour plug to reduce the severity of the turbine start transient. The contour plug is designed to limit steam flow into the turbine during the initial valve opening stroke, thereby limiting the high angular acceleration rate and the subsequent high turbine speed during the first few seconds of operation. This feature allows the turbine to be under governor valve control before the steam admission valve is opened fully.

## HNP-2-FSAR-5

An analysis of the consequences of a safe shutdown earthquake with a concurrent loss-of-offsite power (LOSP) was performed to demonstrate that the use of manual actions after 10 min to accomplish switchover of the RCIC to the suppression pool suction line is acceptable.

The analysis was made using the following assumptions:

- Reactor scram on RPV water level 3 at  $t = 0$ .
- Isolation (MSIV) shown on an LOSP.
- CST supply to RCIC system not available.
- High-pressure coolant injection (HPCI) system unavailable (worst single failure).
- No offsite power.
- RCIC suction taken from suppression pool at  $t = 10$  min.

The results of this transient analysis show that with the RCIC system delivery at its normal 400 gal/min, from 10 min after the initiation of the event the reactor water level never gets lower than at least 1 1/2 ft above the top of the active fuel. It may be noted that this result is additionally conservative in that for most cases the water level would be ~ 2 ft higher than the scram level at  $t = 0$ . Also, the core may be uncovered by several feet at the top before fuel failure is anticipated. The SAFE 03 computer code (approved for appendix K analysis) was used for this evaluation.

The reference 5 report presents the results of a similar transient analysis. This analysis shows that RCIC can fulfill its design function with a 45-s system response time and the system flow reduced by 10% (from 400 gal/min to 360 gal/min).

If for any reason the RPV is isolated from the main condenser, pressure in the RPV increases but is limited by automatic or remote-manual actuation of the safety relief valves.

Throughout the period of RCIC operation, exhaust from the RCIC turbine is condensed in the suppression pool, which results in a slow temperature rise of ~ 3°F/h in the pool. If necessary, one RHR heat exchanger can be used to cool the suppression pool after ~ 1.5 h. If for any reason the RCIC is unable to supply sufficient flow for core cooling, the ECCS provides the required boundary protection. A further discussion of this is found in section 6.3.

The RCIC turbine-pump unit is located in a shielded area to ensure that personnel access areas are not restricted during RCIC operation. The steam supply valve and turbine controls provide for automatic shutdown of the RCIC turbine on receipt of the following signals:

- RPV water level 8: Indicates that core cooling requirements are satisfied.
- Turbine overspeed: Prevents damage to the turbine and turbine casing.



## HNP-2-FSAR-5

- Pump low suction pressure: Prevents damage to the turbine pump unit that results from loss of cooling water.
- Turbine high exhaust pressure: Indicates turbine or turbine control malfunction.
- System isolation signal: Indicates need to shut down equipment.

If a RPV water level 2 initiation signal is received after the turbine is shut down due to the RPV high water level 8 signal, the system is capable of automatic restart.

Because the steam supply line to the RCIC turbine is a primary containment boundary, certain signals automatically isolate this line and cause shutdown of the RCIC turbine.

The RCIC turbine has a speed governor that is positioned by the demand signal from the flow controller. The speed governor limits the turbine-pump speed to its maximum normal operating value and positions the turbine governor valve as required to maintain constant pump discharge flow over the pressure range of system operation. Maximum output from the controller corresponds to maximum turbine speed.

The RCIC system may provide the ability to mitigate the consequences of small pipe breaks, but it is not provided primarily for such purpose. The ECCS provides redundant protection for the entire spectrum of pipe breaks. For small breaks this protection would be provided by HPCI and automatic depressurization.

The RCIC system provides decay-heat removal capability when the main condenser is unavailable, i.e., isolated from the nuclear system, for heat sink purposes, but is not a subsystem of the ECCS.

Long-term heat removal capability may be provided by the RCIC during scram, pressure relief, core cooling, RPV isolation, and restoration to ac power. The RHR system may be used for long-term heat removal during any long-term isolation. These events are all situations in which the RPV is isolated from the main condenser. None of these events is a pipe break (loss-of-coolant) situation requiring immediate reactor water level restoration.

The HPCI and RCIC systems are located in separate rooms in different corners of the reactor building. Piping runs are separated and the water delivered from each system enters the RPV via different nozzles.

The RCIC system is designed to meet Seismic Category I requirements. Except for isolation the RCIC system is not designed to meet the environmental qualification requirements for harsh environments (Rulemaking 10 CFR 50.49). Details are provided in the Plant Hatch Central File. Environment in the equipment room is maintained by a separate auxiliary system.

RCIC system operation during a station blackout event is discussed in section 8.4.

#### 5.5.6.4 Safety Evaluation

To ensure that the RCIC operates when necessary and in time to provide adequate core cooling, the power supply for the system is taken from immediately available energy sources of high reliability. Added assurance is given in the capability for periodic testing during station operation. Evaluation of reliability of the instrumentation for the RCIC shows that no failure of a single initiating sensor either prevents or falsely starts the system.

The RCIC system components within the drywell, up to and including the outer isolation valve, are designed in accordance with the ASME Boiler and Pressure Vessel Code, Section III, Class 1. See subsection 7.3.2 for a discussion of the isolation signals for the RPV and primary containment isolation system. See subsection 7.4.1 for a discussion of the RCIC system instrumentation and control logic.

The RCIC system is normally lined up with the pump taking suction on the CST. All valves between the storage tank and the first isolation valve on the pump discharge line are open. This allows communication between the CST and the discharge line, through the RCIC pump. The minimum water level in the CST is at el 137 ft, the RCIC pump suction connection to the tank is at el 130 ft 6 in., and the elevation of the first isolation valve in the discharge line is 123 ft 0 in. No portion of the RCIC pump suction or discharge lines is higher in elevation than the suction connection on the storage tank. Therefore, the 14-ft el difference between the water level in the storage tank and the first isolation valve ensures that the discharge line remains completely filled with water up to the isolation valve.

The discharge line connects to the bottom of the feedwater line at el 140 ft 0 in. Therefore, the remainder of the discharge line is maintained full by feedwater flow.

A vacuum breaker system is installed close to the RCIC turbine exhaust line torus penetration to avoid siphoning water from the torus into the exhaust line, as steam in the line condenses during and after turbine operation. The vacuum breaker line runs from the torus air volume to the RCIC exhaust line through two normally open motor-operated gate valves and two swing check valves arranged to allow airflow into the exhaust line and preclude steam flow to the torus air volume.

During turbine operation, condensate buildup in the turbine exhaust line is minimized by the installation of a drain pot in a low point of the line near the turbine exhaust connection. The condensate collected in the drain pot drains to the barometric condenser through a steam trap.

The above described design features and operating procedures preclude water hammer effects at the pump discharge or turbine exhaust.

The most limiting operating condition for the RCIC pump is when taking a suction from the suppression pool. The NPSH margin for this condition is 16.2 ft.

### **5.5.6.5 Tests and Inspections**

A design flow functional test of the RCIC system is performed during plant operation by taking a suction from the CST and discharging through the full-flow test return line back to the CST. The discharge valve to the feedwater line remains closed during the test, and reactor operation is undisturbed. Control of the pump discharge valve is obtained by first closing the upstream discharge valve. Control system design provides automatic return from the test to the operating mode when system operation is required during testing of individual components. Periodic inspections and maintenance of the turbine-pump unit are conducted in accordance with the manufacturer's instructions. Valve position indicators and instrumentation alarms are displayed in the MCR.

## **5.5.7 RHR SYSTEM**

### **5.5.7.1 Safety Design Basis**

The RHR system is designed:

- In the LPCI mode to act automatically, in combination with other ECCS systems, to restore and maintain the coolant inventory in the RPV so that the core is adequately cooled to preclude fuel-cladding perforation and subsequent energy release due to a metal-water reaction.
- In conjunction with other ECCS systems, to such diversity and redundancy that only a highly improbable combination of events could result in its inability to provide adequate core cooling.
- So that a source of water for restoration of reactor vessel coolant inventory is located within the primary containment in such a manner that a closed cooling water path is established.
- To provide a high degree of assurance that the RHR system operates satisfactorily during a LOCA and that each active component is capable of being tested during operation of the nuclear system.
- To satisfy Seismic Category I requirements.
- To satisfy applicable environmental qualification requirements. (Refer to Plant Hatch Central File.)
- So that the residual heat removal service water (RHRSW) can be pumped directly into the RHR system.
- To provide heat exchangers with a heat removal capability for long-term containment cooling.

### 5.5.7.2 Power Generation Design Bases

The RHR system is designed:

- To have enough heat removal capacity to cool down the reactor to 125°F within 20 h after shutdown.
- To have fuel pool connections so that the RHR heat exchangers can be used to supplement the fuel pool cooling capacity.
- So that closed loop flowpath between the suppression pool and the RHR heat exchangers can be established so that the heat removal capability of these heat exchangers can be used to cool the suppression pool.

### 5.5.7.3 System Description

#### 5.5.7.3.1 Summary

The RHR system is designed for six modes of operation to satisfy all the objectives and bases. The modes are summarized as follows:

| <u>Mode</u> <sup>(a)</sup>      | <u>Action</u>        | <u>Function</u>                                                                                         |
|---------------------------------|----------------------|---------------------------------------------------------------------------------------------------------|
| LPCI                            | Accident safety      | Restore and maintain reactor vessel water level after a LOCA.                                           |
| Containment spray               | Post-accident safety | Limit temperature and pressure in the torus and drywell after a LOCA.                                   |
| Pool cooling <sup>(a)</sup>     | Abnormal operation   | Remove heat from the suppression pool water.                                                            |
| Shutdown cooling <sup>(a)</sup> | Planned operation    | Remove decay and residual heat from the reactor core to achieve and maintain a cold shutdown condition. |
| Minimum flow                    | Equipment protection | Prevent pump damage when operating against closed discharge valve.                                      |
| Test                            | System test          | Test RHR system during plant operation.                                                                 |

The major equipment of the RHR system consists of two heat exchangers and four RHR pumps. The RHRSW system (subsection 9.2.7) provides cooling water to the heat exchangers.

a. Containment cooling occurs when RHRSW water and LPCI water (with or without containment spray water) are flowing through the RHR heat exchangers.

## HNP-2-FSAR-5

The equipment is connected by associated valves and piping, while controls and instrumentation are provided for proper system operation. The RHR system is shown on drawing nos. H-26014 and H-26015. The RHR system process flow diagram is shown on drawing nos. S-25140 and S-25141. A description of how operation of the equipment in the RHR system in conjunction with other subsystems of the ECCS protects the core in case of a LOCA is presented in section 6.3.

The RHR pumps are sized for the flow required during LPCI operation, which is the subsystem that requires the maximum flowrate. Paragraph 6.3.2.2.4 contains a discussion of the LPCI system. The pumps are arranged and located so that adequate suction head is ensured for all operating conditions. The pump motor is air cooled.

The heat exchangers are sized on the basis of their required duty for the shutdown cooling function. The heat exchanger shell and tube sides are provided with drain connections. The shell side is provided with a vent to remove noncondensable gases. Relief valves on the heat exchanger shell inlets and a relief valve on the HPCI steam supply line to the RHR heat exchangers protect the heat exchangers from overpressure.

The RHR heat exchangers' duties for the principal modes of operation are shown on drawing no. S-25140.

The most limiting duty is associated with cooling the reactor to 125°F in the normal shutdown cooling mode. The performance of this type of heat exchanger operating in the normal shutdown cooling mode (water to water) is well established in currently operating BWR facilities.

Classification information for the RHR heat exchangers is presented in table 3.2-1.

The RHR system can be connected to the fuel pool cooling and cleanup system (FPCCS), as shown on drawing nos. H-26014 and H-26015, so that the RHR heat exchangers can assist fuel pool cooling during high heat-load conditions. Subsection 9.1.3 contains a description of the FPCCS.

One loop, consisting of a heat exchanger, two RHR pumps in parallel, and associated piping, is located in one area of the reactor building. The remaining heat exchanger, pumps, and piping, all of which form a second loop, are located in another area of the reactor building to minimize the possibility of a single physical event causing the loss of the entire system.

A jockey pump system is provided to preclude water hammer effects (paragraph 6.3.2.2.5).

A suppression pool temperature monitoring system provides a measure of the torus atmosphere and the torus water temperatures during both normal and abnormal plant conditions. The suppression pool temperature monitoring system is required to ensure the suppression pool is within the allowable limits set forth in the plant Technical Specifications. The numbers and distribution of the pool temperature sensors are shown in figure 5.5-12. The sensors can be grouped into two categories:

1. Eleven "high" sensors (T48-N301A through N303A, N304B, N305A through N311A) located ~ 1/2 ft below the normal suppression water surface.

## HNP-2-FSAR-5

2. Four "low" sensors (T48-N009A-D) located ~ 10 ft below the normal suppression pool water surface.

Both groups of sensors are shown on figure 5.5-12. The T48-N301B through N303B, N304A, N305B through N311B sensors are installed spares.

Bulk suppression pool temperature is taken as the average of the group 1 average and group 2 average. This average is manually calculated from readouts available in the MCR. This calculated bulk suppression pool temperature is used for routine Technical Specification surveillance.

The group 1 sensors are not required to be operable per the plant's Technical Specifications; they only input visual alarms. They are all fed from the same (division 1) power supply; nevertheless, they are available for use during routine plant operation.

The group 2 sensors are the original suppression pool water temperature sensors. These sensors input audible alarms, and are fed from redundant power supplies. Should more than two of the group 1 sensors be determined inoperable when the suppression chamber is required, a preplanned alternate method of determining average temperature may be used. The table below illustrates the correction factor (if any) to be added to the operable group 2 elements. These correction factors were developed from a detailed review of Plant Hatch suppression pool temperature data.

| <u>Plant Condition (See Notes)</u>                                                                               | <u>Correction Factor (°F) to Operable Group 2 Elements</u> |
|------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|
| (a) Normal operation; torus cooling not operating (Note 1); no HPCI testing (Note 2); no leaking SRV(s) (Note 3) | 5                                                          |
| (b) Normal operation; with or without torus cooling operating; HPCI testing; with or without leaking SRV(s)      | (Note 4)                                                   |
| (c) Normal operation; torus cooling operating; no HPCI testing; with or without leaking SRV(s)                   | 0                                                          |

### NOTES:

1. Torus cooling is at least one loop of RHR in pool cooling or torus spray mode.
2. The Technical Specifications limit for this condition is 105°F.

## HNP-2-FSAR-5

3. A leaking SRV is defined as an SRV experiencing significant steam leakage past the seat. All the steam is not condensed in the SRV discharge line, thus resulting in steam expulsion into the pool.
4. Without group 1 temperature indication, HPCI testing time should be limited to assure the bulk pool temperature does not exceed 105°F. Pool temperature data should still be recorded each 5 min as instructed by the Technical Specifications, but the run time should be administratively controlled by the following:

$$\text{Maximum run time in minutes} = (105 - T \text{ initial}) \times 2$$

where:

T initial is the pool temperature taken prior to the test with torus cooling operating. This equation assumes a 30°F/h rise in bulk pool temperature.

With the exception of the lack of an audible alarm from the group 1 sensors, the plant's bulk suppression pool temperature monitoring system meets the requirements of NUREG-0661. The lack of an audible alarm from the group 1 sensors is acceptable because suppression pool temperature is monitored daily during normal plant operation and at 5-min intervals during periods of heat addition to the pool. The group 1 sensors also input a visual MCR alarm, and an audible alarm comes from the group 2 sensors.

The suppression pool temperature monitoring system has no control functions but provides the operator with temperature data during normal and abnormal plant conditions.

### 5.5.7.3.2 Shutdown Cooling Mode

The shutdown cooling mode is an integral part of the RHR system. It is operated during normal shutdown and cooldown. The initial phase of nuclear system cooldown is accomplished by dumping steam from the RPV to the main condenser. When the nuclear system temperature has decreased to where the steam supply pressure is not sufficient to maintain the turbine shaft gland seals, the vacuum in the main condenser cannot be maintained and the RHR system is placed in the shutdown cooling edge of operation. The shutdown cooling system is able to complete cooldown to 125°F within 20 h after the control rods have been inserted and can maintain the nuclear system at 125°F for reactor refueling and servicing.

Reactor coolant is pumped from one of the RRS loops by one or both of the RHR pumps in the loop and is discharged through the RHR heat exchangers where cooling occurs by heat being transferred to the RHRSW. Reactor coolant can be returned to the RPV through RRS loops. After the decay heat levels have subsided, the entire shutdown cooling load can be shifted to one residual heat exchanger, leaving the other available for other cooling loads.

The RHR system is normally inactive; therefore, the water between valves F050 and F015 is stagnant and, thus, at ambient conditions, ~ 135°F. For this water to flash into steam when the reactor vessel is being depressurized, the temperature of the water between F050 and F015

must be raised to at least 327°F. This temperature corresponds to a pressure of ~ 85 psi. The RHR system is initiated when the vessel pressure drops from ~ 135 psi to 85 psi so that 327°F is the lowest temperature at which the water would have to be.

The only source of heat that could cause the water to increase in temperature is the hot water, 546°F, in the reactor recirculation lines. This heat can be conducted only through the water and piping in the RHR system from where it interties with the recirculation system since the pipe run is dead ended against F050. This pipe run is ~ 22-ft long, and the results of a heat transfer calculation indicate that the temperature of the water between F050 and F015 cannot increase. At a distance of ~ 13 ft from the point where the RHR system and the RRS intertie, the heat losses due to convection from the pipeline are equal to the heat being transferred through the line by conduction. The temperature of the line is at ambient conditions.

Due to the above, it is not believed that there is flashing between F050 and F015, and therefore water hammer is not a problem.

#### **5.5.7.3.3 Suppression Pool Cooling/Containment Spray Modes**

During reactor operation, suppression pool cooling limits the temperature of the water in the suppression pool so that, immediately after the design basis LOCA, pool temperature does not exceed 170°F. The subsystem also limits the long-term post-accident peak temperature of the pool to < 212°F. Tests show that at 170°F, complete condensation of blowdown steam from the design basis LOCA can be expected. Although complete condensation is expected at higher suppression pool temperatures, no test data are available for any higher temperature.

The containment spray mode is an integral part of the RHR system. The containment spray mode can be manually initiated after the LPCI cooling requirements have been satisfied. The containment spray mode provides containment cooling for post-accident conditions. Water pumped from the suppression pool through the RHR heat exchangers, where it is cooled by the RHRSW system, is diverted to spray headers in the drywell and above the suppression pool. For the containment spray mode of operation, the shell-side inlet temperature is the maximum suppression pool temperature expected at post-accident conditions. The spray in the drywell condenses any steam that may exist in the drywell, thereby lowering containment pressure. The spray collects in the bottom of the drywell until the water level rises to the level of the pressure suppression vent lines. The water then overflows to the suppression pool. Approximately 5% of this flow can be directed to the suppression chamber spray ring to cool any noncondensable gases collected in the free volume above the suppression pool.

The containment spray mode of the RHR system normally cannot be operated unless the core flooding requirements of the LPCI subsystem have been satisfied. The operator can bypass these requirements by using a keylock switch.

The suppression pool cooling and torus spray modes are periodically used during an operating cycle. It may be necessary to place the suppression pool cooling mode in service as the pool temperature increases during the summer months. Also, torus spray may be used to reduce torus pressure if, for example, an SRV is leaking during an operating cycle. If a LOCA signal is



received while operating in either one or both modes, the LPCI response will not be adversely affected.

The equipment purchase specifications for the RHR heat exchangers which are used for the containment cooling and suppression pool cooling modes specify fouling factors. These fouling factors are a function of the nature of the fluids, the temperatures involved, and the fluid velocities. The basis for the fouling factor used in relation to the RHR heat exchangers is obtained from TEMA table T-2.41. This table recommends that a fouling factor of 0.002 be used for river water where the water velocity is  $> 3$  ft/s and the water temperature is  $\leq 125^{\circ}\text{F}$ . HNP-2 uses river water with an outlet temperature of  $92.7^{\circ}\text{F}$  and a water velocity in the tubes of 9.8 ft/s. Thus, a fouling factor of 0.002 was used for the tube side of these heat exchangers. The heat exchanger designer includes the fouling factors in calculating his overall thermal resistance and provides sufficient surface area to allow the required heat transfer rate while in the fouled condition. The heat exchanger performance data sheets supplied by the heat exchanger designer/manufacturer show the expected (designed) performance of the heat exchanger under fouled conditions.

#### **5.5.7.3.4 LPCI Mode**

The LPCI mode is an integral part of the RHR system. It operates to restore and, if necessary, maintain the coolant inventory in the RPV after a LOCA so that the core is adequately cooled to preclude fuel-clad melting and subsequent energy release due to a metal-water reaction. The LPCI operates in conjunction with the HPCI system, the ADS, and the CS system. A discussion of the requirements and response of the LPCI for LOCA is included in paragraph 6.3.2.2.4.

LPCI is a low-head, high-flow function that delivers its rated flow to the RPV through the RRS loops. It is designed to reflood the RPV to at least two-thirds core height and to maintain this level. After the core has been flooded to this height, the capacity of one RHR pump is sufficient to make up for shroud leakage and boiloff.

The HPCI is a high-head, low-flow system that can pump water into the RPV when the NSSS is at high pressure. If the HPCI fails to deliver the required flow of cooling water to the RPV, the automatic depressurization feature of the overpressurization protection system described in subsection 5.2.2 functions to reduce nuclear system pressure, thus, enabling the LPCI and CS to automatically inject water into the RPV. The HPCI turbine is manually shut down after both CS and LPCI are in operation.

During LPCI operation, the RHR pumps take suction from the suppression pool and discharge to the RPV into the core region through the RRS loops. Any spillage through a break in the lines within the primary containment returns to the suppression pool through the pressure suppression vent lines. A minimum-flow bypass line to the suppression pool is provided so that the RHR pumps are not damaged if operating with the discharge valves shut.

RHR flow to the RHR heat exchangers is not required immediately after a LOCA because heat rejection from the containment is not necessary during the time it takes to flood the reactor. Power for the RHR and RHR pumps normally comes from an auxiliary ac power, but if offsite power is lost, power is made available from the standby ac power source.

To provide a source of water if any post-accident flooding of the primary containment is required, a crosstie exists from the piping on the discharge side of a pair of RHRSW pumps to the discharge piping on the shell side of an RHR heat exchanger. This connection is provided with redundant valving appropriate to a primary containment penetration. The valves are remotely operable from the MCR. The pair of RHRSW pumps that provide this function can add water to either RRS loop through the cross-connection between the piping of each RHR loop.

#### **5.5.7.4 Safety Evaluation**

Because the LPCI and containment cooling modes act in conjunction with other subsystems of the ECCS to satisfy the safety objective, they are evaluated in conjunction with the other subsystems of the ECCS in sections 6.2 and 6.3. The evaluation of the controls and instrumentation of the LPCI system is contained in subsection 7.3.1.

An interlock exists in the logic for the RHR shutdown cooling suction valves, which are normally closed during power operation, to prevent opening of the valves above a preset pressure setpoint (table 7.3-9 and drawing no. H-24732). This setpoint is selected to ensure pressure integrity of the RHR system is maintained. Administrative operating procedures require the operator to close these shutdown cooling valves prior to pressure operation. However, as a backup, the interlock automatically closes these valves when the pressure setpoint is reached. Double indicating lights are provided in the for valve-position indication.

The RHR pump piping, controls, and instrumentation are separated and protected so that any single physical event or missile cannot make both RHR loops inoperable.

The RHR system piping cannot be overpressurized from a single failure for the following reasons:

- A. The suction piping may not be connected to the recirculation piping until the pressure has decayed to 145 psig (allowable value). Also, the suction piping outside the suppression pool piping is classed as 300-lb rated.
- B. The discharge piping is not overpressurized whenever the LPCI injection valve is open because a check valve between the system and the vessel blocks pressure. Leakage past the closed check valve is accommodated by relief valves F025A and B and F055A and B. In addition, the injection valve may not be opened for testing unless the upstream valve, rated for full pressure, is also closed.
- C. The heat exchanger and its piping are protected against failure of the steam pressure control valves by relief valves F055A and B.

Impaired post-LOCA RHR system performance due to broken or loose parts in the suppression pool is avoided by providing the suction strainers above the suppression pool bottom, thereby minimizing the accumulation of debris on the screen. The strainer mesh is such that any particles allowed to pass through the strainer are not of sufficient size to block critical flow passage in the pumps. Additionally, debris passing through the strainer does not cause any blockage of small system flow openings. However, some small quantities of particulate matters

which pass through the strainers may accumulate in cracks and crevices throughout the system. This small particulate matter does not cause flow stoppage in the pumps or heat exchangers.

The most limiting condition for RHR pump operation occurs during long-term post-LOCA containment cooling when the suppression pool reaches the peak temperature of 206°F. The NPSH margin under these conditions is discussed in paragraph 6.3.3.9.

#### **5.5.7.5 Tests and Inspections**

A design flow functional test of the RHR pumps is performed for each pair of pumps during normal plant operation by taking suction from the suppression pool. The discharge valves to the RRS loops remain closed during this test, and reactor operation is undisturbed.

An operational test of the discharge valves is performed by shutting the downstream valve after it has been satisfactorily tested, thereby establishing the RCPB at the downstream valve, and then operating the upstream valve. The discharge valves to the containment spray headers are checked in a similar manner by operating the upstream and downstream valves individually. All these valves can be actuated from the MCR by using remote-manual switches. Control system design provides automatic return from the test to the operating mode if LPCI initiation is required during testing.

Testing of the sequencing of the LPCI mode of operation is performed at the frequency, under the plant conditions, and to the extent stipulated in the Technical Specifications and Bases. Testing the operation of the valves required for the remaining modes of operation of the RHR system likewise is performed at the frequency, under the conditions, and to the extent stipulated in the Technical Specifications Bases.

Periodic inspection and maintenance of the RHR pumps, pump motors, and heat exchangers are carried out in accordance with the manufacturer's instructions.

A discussion of the availability of the engineered safety features (ESFs) and frequency of testing of equipment is presented in subsection 6.2.2.

Preoperational tests were conducted during the final stages of plant construction prior to initial startup. These tests ensured correct functioning of all controls, instrumentation, pumps, piping, and valves. System reference characteristics such as pressure differentials and flowrates are documented during the preoperational testing and are used as base points for measurements obtained in subsequent operational tests.

For the containment spray mode, preoperational tests confirm that the containment spray headers and piping are clear of obstructions and the spray nozzles are capable of delivering rated flow. Air is injected into the drywell spray header via the blind flange connection on the outside of the primary containment. Unrestricted flow is verified through each spray nozzle. The spray nozzles in the suppression pool are checked with water during the suppression pool cooling tests.

For the suppression pool cooling mode, the preoperational tests verify that the RHR heat exchanger shell-side design flowrate can be obtained while circulating water from the

## HNP-2-FSAR-5

suppression pool. During the test, head-versus-flow curves are developed for reference in evaluating the future performance of the suppression pool cooling mode, RHR pumps, and restricting orifices fitted to the pump discharge lines to prevent RHR pump runout.

An analysis has been performed for HNP-2 to determine the potential for RHR/LPCI pump runout, post-design basis LOCA. From the standpoint of maximizing LPCI pump flow following a LOCA, the most limiting configuration has been quantitatively determined, by comparison of overall system resistance, to be the case where only one LPCI pump is operating into the broken recirculation loop. Also, the break is conservatively assumed to be at the LPCI connection to the recirculation piping so that no credit is taken for flow resistance of the recirculation system.

The system resistance was calculated by assigning equivalent lengths of straight-pipe values to the various fittings and valves as given in Crane Company Technical Paper 410 and by extracting the lengths of piping runs from the physical piping drawings.

The pressure drop per equivalent 100 ft is expressed by:

$$\Delta P/100 = \frac{0.000336fVM^2}{D^5}$$

where:

- f = friction factor
- V = specific volume of the fluid
- M = mass flowrate
- D = pipe inside diameter

The specific pressure drop in interest is that which occurs at a flowrate of 11,100 gal/min which is the maximum allowable flowrate per pump. The existing system head loss at 11,100 gal/min for one LPCI pump operating into the broken loop was found to be ~ 80 ft of water, using the above equation.

The pump vendor's certified performance curve was then consulted to find the pump total dynamic head at the maximum allowable flowrate of 11,100 gal/min. This was found to be ~ 290 ft of water.

Therefore, for the system curve to match the pump total dynamic head at the point of interest, 11,100 gal/min, an additional 210 ft of water, i.e., 290 to 80, pressure drop must be added to the system by the restricting orifice.

Since the amount of downstream pressure recovery for an inline restricting orifice is a function of the orifice beta ratio (orifice bore diameter to pipe inside diameter), the orifice bore required to give the desired system head loss, after pressure recovery, is found by using a convergence procedure with the pressure drop measured across the orifice as the trial argument and using

the formula for liquid flow through nozzles and orifices from Crane Company Technical Paper 410. This procedure resulted in an orifice bore diameter of 7.56 in.

A description of the RHR/LPCI system preoperational testing is provided in supplement 14A, section 14A.22.

During plant operation, the pumps, valves, piping, instrumentation, wiring, and other components outside the primary containment can be inspected visually at any time. Components inside the primary containment can be inspected when the drywell is open for access. Testing frequencies are correlated with testing frequencies of the associated controls, and instrumentation is tested by the same action. When a system is tested, operation of the components is indicated by installed instrumentation.

The RHR relief valves are removed as scheduled at refueling outages for bench tests and setting adjustments.

### **5.5.8 RWC SYSTEM**

#### **5.5.8.1 Design Basis**

The principal function of the RWC system is to provide a means for reducing the concentration of radioactive and corrosive materials in the RCS.

The RWC system is designed to:

- Discharge excess reactor water during startup, shutdown, and hot standby conditions.
- Minimize reactor heat loss during system operation.
- Remove solid and dissolved impurities from recirculated reactor coolant.
- Minimize temperature gradients in the RRS piping and vessel during periods of low flowrates.

#### **5.5.8.2 System Description**

The RWC system, shown on drawing nos. H-26036 and H-26037, continuously purifies the reactor water. The system continuously removes water from the suction line of each RRS pump and from the reactor bottom head. The processed water is returned to the NSSS or to storage.

A regenerative heat exchanger is provided to limit the loss of heat from the nuclear system. The RWC system can be operated at any time during planned operations, or it may be shut down when not required to clean up or remove reactor coolant.

## HNP-2-FSAR-5

The major equipment of the RWC system is located in the reactor building. This equipment includes pumps, regenerative and nonregenerative heat exchangers, and two filter-demineralizers with supporting equipment. The entire system is connected by associated valves and piping while controls and instrumentation are provided for proper system operation. Design data for the major pieces of equipment are presented in table 5.5-3.

Reactor water is cooled in the regenerative and nonregenerative heat exchangers, then filtered, demineralized, and returned to the reactor feedwater system through the shell side of the regenerative heat exchanger. A process flow diagram of the RWC system is shown on drawing no. S-25285.

Because the maximum temperature of the filter-demineralizer units is limited by the ion-exchange resin operating temperatures (table 5.5-3), the reactor coolant must be cooled before being processed in the filter-demineralizer units. The regenerative heat exchanger transfers heat from the influent water to the effluent water. The effluent returns to the feedwater system. The nonregenerative heat exchanger cools the influent water further by transferring heat to the reactor building closed cooling water system. The nonregenerative heat exchanger is designed to maintain the required filter-demineralizer operating temperature, even when the effectiveness of the regenerative heat exchanger is reduced by diversion of excess reactor water from the filter-demineralizer effluent to either the main condenser (normal discharge) or to the radwaste system. The flow is then returned to storage instead of returning to the reactor through the regenerative heat exchanger.

The filter-demineralizer units, shown on drawing no. H-26037, are pressure-precoat-type filters using only ground, powdered ion-exchange resins as a filter and ion-exchange medium. Spent resins are not regenerable and are backwashed from a filter-demineralizer unit to a resin receiver tank from which they are transferred to the radwaste system for processing and disposal. When the system is being returned to service, slow pressurization of a filter-demineralizer unit is manually executed through a bypass line around the inlet air-operated valves.

The suction line of the RCPB portion of the RWC system contains two motor-operated isolation valves which automatically close in response to signals from the RCPB leak-detection system (LDS). This action prevents the loss of reactor coolant and the release of radioactive material from the reactor. Subsections 5.2.7 and 7.6.9 and table 5.2-6 describe the RCPB LDS.

The outermost isolation valve also automatically closes to prevent removal of liquid poison in the event of standby liquid control system (SLCS) actuation and to prevent damage of the filter-demineralizer resins if the outlet temperature of the nonregenerative heat exchanger is high. These isolation valves may be remote manually operated to isolate the system equipment for maintenance or servicing.

A remote manually operated gate valve on the return line to the reactor provides long-term backup isolation of the system for the reactor. Instantaneous reverse-flow isolation is provided by check valves in the RWC return line, as shown on drawing no. H-26036.

### **5.5.8.3 Safety Evaluation**

To prevent resins from entering the RRS in the event of failure of a filter-demineralizer resin support, a strainer is installed on the outlet of each filter-demineralizer unit. Each strainer has an alarm that is energized by high differential pressure. A bypass line is provided around the filter-demineralizer units for bypassing the units when necessary. Relief valves and instrumentation are provided to protect the equipment against overpressurization and the resins against overheating. The system is automatically isolated for the reasons indicated when signaled by any of the following occurrences:

- High temperature downstream of the nonregenerative heat exchanger to protect the ion exchanger resins from damage due to high temperatures.
- RPV water level 2 to protect the core in case of a possible break in the RWC system piping and equipment.
- SLCS actuation to prevent removal of the boron by the filter-demineralizers.

In the event of low flow or loss of flow in the system, flow is maintained through each filter-demineralizer by its own holding pump. Sample points are provided in the influent header and effluent line of each filter-demineralizer unit for continuous indication and recording of system conductivity. High conductivity is annunciated in the MCR. The influent sample point is also used as the normal source of reactor coolant samples. Sample analysis also indicates the effectiveness of the filter-demineralizer units.

Operation of the RWC system is controlled from the MCR. Resin-changing operations, which include backwashing and precoating, are controlled from a local control panel in the reactor building. Drawing nos. H-24758 and H-24759 show the functional control diagram.

### **5.5.8.4 Tests and Inspections**

Because the RWC system is usually in service during plant operation, satisfactory performance is demonstrated without the need for any special tests and inspections beyond those specified in the manufacturer's instructions.

## **5.5.9 MAIN STEAM LINES AND FEEDWATER PIPING**

### **5.5.9.1 Design Bases**

The main steam lines are designed, as described in section 10.3, Main Steam Supply System, to conduct steam from the reactor vessel to the various components over the full range of reactor power operation. Additional design information concerning the main steam piping is found in sections 3.6, 3.9, 5.2, and 10.3.

The feedwater piping is designed to supply feedwater to the reactor over the full reactor power range and to accommodate all anticipated operational stresses without failure. Additional design information concerning the feedwater piping is found in sections 3.6, 3.9, and 5.2, and subsection 10.4.7.

#### **5.5.9.2 Description**

Information describing the main steam piping is found in sections 3.6, 3.9, 5.2, and 10.3.

Design information describing the feedwater piping is found in sections 3.6, 3.9, and 5.2, and subsection 10.4.7.

#### **5.5.9.3 Safety Evaluation**

An evaluation of the main steam piping is found in sections 5.2 and 10.3.

An evaluation of the feedwater system piping is found in section 5.2 and subsection 10.4.7.

#### **5.5.9.4 Tests and Inspections**

Tests and inspections of the main steam and feedwater piping are conducted as defined in subsections 10.3.4 and 10.4.7.

#### **5.5.10 PRESSURIZER**

This subsection is not applicable to BWRs.

#### **5.5.11 PRESSURIZER RELIEF TANK**

This subsection is not applicable to BWRs.

#### **5.5.12 VALVES**

##### **5.5.12.1 Design Bases**

Valves are components of the system pressure boundary having moving parts and are designed to operate efficiently to maintain the integrity of this boundary.

Line valves, such as gate valves, globe valves, and check valves are located in the various fluid systems to perform a mechanical function, and to allow either operator control or automatic control of the various fluid processes.



The valves are designed to operate under the internal pressure/temperature loading as well as the external loading anticipated during the various system transient and steady-state operating conditions.

#### **5.5.12.2 Description**

Line valves furnished are standard types, designed and constructed in accordance with the requirements of the applicable code. Valve design codes are delineated in subsection 3.2.2.

All materials, exclusive of seals and packing, have been selected to endure the 40-year plant life under the environmental conditions applicable to the particular system. Aging management programs (subsections 18.2.1 and 18.2.9) monitor the ongoing condition of the valves so that actions are taken to provide reasonable assurance that these components are capable of performing their intended functions for 40 years and beyond. Section 3.11 provides the environmental conditions to which all valves required to function to effect a safety action have been designed.

Valve operators are selected to provide operability under the most severe conditions applicable to the particular system.

#### **5.5.12.3 Safety Evaluation**

Line valves are either shop tested, prototype tested, or analyzed to perform at the service conditions/accident conditions specified by the purchase specification. Pressure-retaining parts are selected as required by the applicable code.

To minimize leakage past seating surfaces, maximum allowable leakage rates are specified for both back seat and main seat for gate and globe valves.

#### **5.5.12.4 Tests and Inspections**

Valves serving as containment isolation valves, and which must remain closed or open during normal plant operation, can be partially exercised during plant operation to ensure their operability.

Valves serving as system-block or throttling valves may be fully exercised without jeopardizing system integrity.

Leakage from valve stems is monitored as described in subsection 9.3.3.

#### **5.5.12.5 Motor-Operated Valves Performance Testing**

*Table 5.5-4 lists seismic and environmental tests performed on Limitorque motor operators which are used exclusively on HNP-2 for motor-operated valves provided by Bechtel. Although many of these tests*

## HNP-2-FSAR-5

were conducted after most of the HNP-2 motor operators were purchased, the results were still valid for previously purchased valves.

In addition to these tests, Limitorque tests the performance of each motor operator independently of the valve for proper torque settings. The valve operator assembly is subsequently tested by the valve manufacturer for compliance with the design specification. Bechtel inspection randomly witnessed tests for opening and closing times and proper calibration of position indicators. Each Quality Assurance (QA) documentation package was reviewed by Bechtel inspection prior to release of the valve.

Limitorque's current QA program was approved by the Nuclear Regulatory Commission (NRC) on docket 999-001-00 for program number 44070.

Motor-operated valve performance testing conducted by Georgia Power Company (GPC) includes testing during Construction Assurance Testing Program, the preoperational test phase, and throughout the operating life of the plant by the surveillance testing program.

During the Construction Assurance Testing Phase, extensive testing and documentation of valve performance data was accomplished with the GPC Motor-Operated Valve Data Sheet which includes nameplate data, test data, limit switch setting, torque switch setting, and operating data. The test data section includes 18 different tests:

- *Rotation check.*
- *Lubrication.*
- *Packing adjustment.*
- *Verification of proper packing type.*
- *Packing size check.*
- *Cable termination check.*
- *Controls operability check.*
- *Ground connection check.*
- *Bonnet check.*
- *Cable megger or hi pot.*
- *Motor megger or hi pot.*
- *Alarm operability.*
- *Indicating lights check.*

## HNP-2-FSAR-5

- *Proper size fuses installed.*
- *Thermal overload installed.*
- *Thermal overload size check.*
- *Stem protector installed.*
- *Stem cleaned and lubricated.*

*The Construction Assurance Tests program provided a means to determine that systems and equipment are correctly installed and free from defects, missing components, errors in installation, etc.*

*During the preoperational test program, motor-operated valves were included in the overall systems preoperational test to the extent that the valves proper operation during all modes of system operation is verified. The purpose of the preoperational test program was three-fold:*

- *To confirm that construction was complete to the extent that equipment and systems can be put into use during completion of other construction.*
- *To adjust and calibrate the equipment to the extent possible in the "cold" plant condition.*
- *To assure that all process and safety equipment was operational and in compliance with license requirements to the extent necessary to proceed into initial fuel loading and the startup test program.*

*The foregoing was achieved in accordance with the Final Safety Analysis Report, by formal written preoperational tests on systems related to nuclear safety. Balance-of-plant systems were also tested with a written procedure, using the same format to assure that all plant equipment functions reliably.*

*The preoperational test performance period was an important phase in the training of operating personnel. Experience and understanding of plant systems and components was gained with a minimum of risk to equipment or personnel. This gave maximum opportunity to evaluate and train operating personnel and to troubleshoot systems. In addition, equipment and systems were operated for a sufficient period of time to discover and correct any design, manufacturing, or installation errors, and to adjust and calibrate the equipment.*

Throughout the operating life of the plant, motor-operated valves whose proper operation is required to meet the plant Technical Specifications are periodically tested to ensure that the performance of these valves is satisfactory. This testing is done as required in plant Technical Specifications through the plant surveillance program. Valve cycling is not possible in every case when surveillance is conducted while the plant is operating at power, but valve operation is carried out as a part of the surveillance action whenever conditions permit.

### **5.5.13 SAFETY AND RELIEF VALVES**

Overpressurization protection in the form of safety relief valves is provided to systems and subsystems closely related to the RCS, such as:

- CS system.
- HPCI system.
- RCIC system.
- RHR system and its subsystems.
- SLCS.
- CRD system.
- RWC system.
- Reactor feedwater system.

The safety relief valves of the RCS are discussed in subsection 5.2.2.

#### **5.5.13.1 Safety Design Bases**

Piping systems that are normally isolated from the RCPB by at least two power-operated isolation valves are provided with safety relief valves or other overpressure protection mechanisms to protect the isolated piping from overpressurization due to thermal expansion of the enclosed fluid.

These valves are sized and designed in accordance with the requirements of ASME Boiler and Pressure Vessel Code, Section III.

#### **5.5.13.2 Description**

##### **5.5.13.2.1 CS System Relief Valves**

Each CS pump discharge line is equipped with a relief valve set at 500 psig and having a capacity of 100 gal/min. The CS system is not subject to any kind of energy input except pump motor energy when pumps are operating against closed valves.

#### **5.5.13.2.2 HPCI System Relief Valves**

The HPCI pump suction line is equipped with a relief valve with the setpoint set at 100 psig and the capacity specified as 20 gal/min.

The setpoint and capacity for the cooling water line relief valve are 100 psig and 177 gal/min, respectively.

The barometric condenser is equipped with a relief valve intended to protect against overpressure in the condenser. The valve setpoint is 15 psig, and the capacity is specified as 20 gal/min at 10% accumulation.

In addition, rupture discs on the exhaust line protect the turbine casing. The discs are set at 175 psig and have a capacity of 600,000 lb/h at 175 psig.

The HPCI system is not subject to any kind of energy input except the hydraulic oil pump motor and the motors for the gland-seal condenser vacuum and drain pumps.

#### **5.5.13.2.3 RCIC System Relief Valves**

The RCIC pump suction line is equipped with a relief valve set at 100 psig and having a specified capacity of 10 gal/min at 25% accumulation. This relief valve is intended to protect against overpressurization of the RCIC pump suction piping due to leakage from the main feedwater system.

The relief valve in the cooling water line to the gland-seal condenser is set at 100 psig and has a 75-gal/min capacity. The purpose of this valve is to protect the lube oil cooler and associated piping in the cooling water loop from overpressurization which could result from a failure of the pressure-control valve (F015).

The barometric condenser is equipped with a relief valve set at 15 psig and having a specified capacity of 20 gal/min at 10% accumulation. The purpose of the valve is to protect against overpressurization of the condenser.

Rupture discs on the steam turbine exhaust line protect the turbine casing. The discs are set at 150 psig and have a capacity is 45,000 lb/h at 150 psig.

The RCIC system is not subject to any kind of energy input except when the pumps operate with closed valves.

#### **5.5.13.2.4 RHR System Relief Valves**

Each RHR pump discharge line is equipped with a relief valve set at 400 psig and having a capacity of 50 gal/min.

An RHR discharge line to the RCIC pump suction is provided with a relief valve set at 85 psig and having a capacity of 362 gal/min.

#### **5.5.13.2.5 SLCS Relief Valves**

A relief valve is provided in the discharge line of each pump with the setpoint and capacity set at 1400 psig and 43 gal/min each.

#### **5.5.13.2.6 CRD System Relief Valves**

The CRD pump suction lines and the accumulator charging station on the hydraulic control units are equipped with relief valves. The setpoints and capacities are:

- Pump suction relief valves set at 100 psig with 10 gal/min capacity.
- Accumulator charging station relief valves set at 950 psig.

#### **5.5.13.2.7 RWC System Relief Valves**

Relief valves are installed on the shell side of the heat exchangers and on the line to the condenser.

The setpoint and capacity of the relief valve on the line to the condenser are 150 psig and 204 gal/min at 130°F, respectively.

The relief valve on the shell side of the nonregenerative heat exchangers is set at 150 psig with 29 gal/min at 105°F capacity.

The thermal expansion relief valve on the shell side of the regenerative heat exchangers is set at 1200 psig.

#### **5.5.13.2.8 Feedwater System Relief Valves**

The feedwater system is designed to the maximum pressure of the RCS up to and including the outermost isolation valve. Beyond the outermost isolation valve the system is designated as a nonsafety class. Details of the feedwater system are discussed in subsection 10.4.7.

#### **5.5.13.3 Safety Evaluation**

The assumptions made in the evaluation of the adequacy of the relief valves provided are conservative, and the setpoints and capacities of the valves are sufficiently conservative to

protect the system and subsystem pipings and components from the effects of overpressurization.

Some of the conservative assumptions are:

- A. Conservative isolation valve leakage values are used in sizing the relief valves.
- B. The system is considered isolated with the pump(s) operating at shutoff conditions. A 100% energy conversion from the pump motor horsepower to heat is assumed, neglecting heat losses and mechanical work.
- C. Jet impingement of steam from a nearby broken pipe is taken into account in sizing the relief valves. To be conservative, heating of the piping is assumed to be from the condensation of steam by the piping.
- D. The piping subject to heating is assumed to be uninsulated.
- E. Reaction force on the piping from relief valve operation is assumed to be  $R = 2 \times P \times A$ , where R is the reaction force, P is the pressure setting of the valve, and A is the area of the valve inlet.

#### **5.5.14 COMPONENT SUPPORTS**

Support elements are provided for those components beyond the RCPB which are in systems or subsystems closely allied with the RCS. These systems include reactor feedwater, RHR, RCIC, RWC, HPCI, and standby liquid control.

##### **5.5.14.1 Design Bases**

Support components on the RCS and subsystem piping are provided to ensure the pressure retaining capability of the piping system due to weight, thermal, seismic, and fluid dynamic loads. The support components on nuclear Class 1, 2, and 3 piping are designed in accordance with the applicable subsections of ASME Section III, including addenda, prior to the purchase order date. In addition, methods established in Appendix XVII and Appendix F of the 1974 ASME Code, Section III are adapted where possible. All hanger assemblies are in accordance with the requirements of the Steel Structures Painting Council Standard Practice, SSPC-SP-10, and the Manufacturers Standardization Society of the Valve and Fittings Industry Standard Practices, MSS-SP-58 and MSS-SP-69.

##### **5.5.14.2 Description**

The design parameters of rigid-type supports, variable or constant spring-type supports, and anchors or guides used on the reactor coolant piping are determined by piping stress analysis. Provision is made for spring-type supports for the initial deadweight loading due to hydrostatic testing of steam systems to prevent damage to this type of support. Welded attachments to

Class 1 pipe are minimized but, where necessary, are analyzed as Class 1 components. Classes 2 and 3 attachments are designed to reduce local stresses and are analyzed for the stresses induced in the pipe. Manufacturer's standard hardware is utilized as much as possible, but where nonstandard components are necessary their adequacy is confirmed by analysis. Deflections as well as stresses are limited in the evaluation of support components. The reactor vessel pedestal design is discussed in subsection 3.8.3.

#### **5.5.14.3 Safety Evaluation**

All support components are capable of withstanding the cumulative loading produced by the worst combination of the events classified under each of the normal, upset, emergency, and faulted conditions if applicable.

As discussed in section 3.6, pipe-whip restraints are provided to ensure protection of the RCS and subsystems piping and supports from a postulated line break. Pipe-whip restraints not in contact with the pipe are designed in accordance with the American Institute of Steel Construction (AISC), Seventh Edition. Restraints serving as both whip restraints and pipe supports are designed in accordance with both ASME Section III and the AISC. The pipe rupture design condition is faulted and the restraints are designed for both the rupture loads and the operational loads.

All support components, including hydraulic shock suppressors, are designed to operate under the effects of a gamma radiation of  $1 \times 10^7$  rads over a 40-year period.

#### **5.5.14.4 Tests and Inspections**

Paragraph 3.7.3.14 discusses the field surveillance for seismic supports, which, in addition, verifies installation of all other types of supports on the reactor coolant piping. Upon hot-startup operations, thermal growth is observed to confirm that spring-type hangers and shock suppressors function properly between hot and cold setting positions. Final adjustment capability is provided on all hanger or support types.

Fully assembled shock suppressors are shop tested to verify operational characteristics for compliance with the design requirements. The units are observed for proper piston rod velocities, poppet valve closure, bypass flow, and fluid containment integrity.

#### **5.5.15 OTHER SYSTEMS WITH COMPONENTS WITHIN RCPB**

The HPCI and CS systems penetrate the RCPB. These systems are described in section 6.3.



## 5.5.16 RECIRCULATION PUMP TRIP SYSTEM

### 5.5.16.1 Safety Design Bases

The recirculation pump trip (RPT) system is designed to:

- Mitigate the consequences of the end-of-cycle scram reactivity shortfall.
- Meet the single-failure criterion.
- Meet Seismic Category I, Safety Class 2 requirements.
- Comply with applicable codes, guides, and standards.

### 5.5.16.2 System Description

The RPT system is a subsystem of the RRS. The RPT function in the recirculation control system is to trip the recirculation pumps in response to a turbine-generator trip or load rejection. Scram/recirculation pump trip initiation by either turbine stop valve closure or turbine control valve fast closure initiates a scram and an RPT to prevent the core from exceeding the thermal-hydraulic safety limit during AOOs (section 15.2). The RPT system reduces the severity of the turbine generator trip and load rejection events by tripping the recirculation pumps early in the event. The rapid core flow reduction increases void content and thereby reduces reactivity in conjunction with the control rod scram.

The RPT system is designed to meet Seismic Category I, Safety Class 2 requirements. The system consists of turbine control and stop valve closure sensors, reactor power level sensors control logic storage monitors separate division logics, and four Class 1E, 5-kV, 250-MVA, dual trip coil circuit breakers. The close and trip circuitry for the breakers are individually fused. Light indicators for operating bypasses are provided in the MCR. These lights are continuously indicated when the sensor or division logic has been bypassed or deliberately rendered inoperative for testing or repair purposes. In addition, indicators and annunciators are provided in the MCR for system input trip signals, initiation signal at system level, the status of trip coils, and the mechanical position of the circuit breakers. The RPT system logic receives its power from the same power sources as the reactor protection system (RPS). The RPT breaker control receives its power from the main battery systems (A and B).

During normal operation, all the main power breakers in both loops (figure 5.5-8) are closed. Upon receipt of a trip signal from either the control valve fast closure or the turbine stop valve closure logics, all four breakers open within 135 ms after initiation of the breaker opening mechanism over a specified frequency range of 37 to 45 Hz, interrupting power to the recirculation pump motors (figure 5.5-9), and their tripped status is displayed by the annunciators in the MCR. The trip signals must be reset manually by the operator to allow restarting of the recirculation pumps.

The anticipated transient without scram (ATWS) RPT is described in paragraph 7.6.10.7.

### **5.5.16.3 Safety Evaluation**

The RPT system is designed to meet Seismic Category I requirements and complies with the requirements of the following codes, guides, and standards:

- 10 CFR 50, Appendixes A and B.
- Regulatory Guides 1.47, 1.53, 1.62, and 1.75.
- Institute of Electrical and Electronics Engineers (IEEE) Standards 279, 308, 323, 338, 344, 379, 383, and 384.

The RPT system is designed to be operable over the 1 and 2 recirculation pump operating regions of the thermal power-core flow map when the reactor power exceeds a predetermined power level (~ 30% of rated full load).

The RPT system consists of two separate trip divisions, each having at least two separate trip channels, sensors, and associated equipment for each measured variable. The RPT system logic is designed to preclude the inadvertent trip of more than one pump, given a single component failure.

The RPT system is designed to meet the single-failure criterion so that any single-trip channel (sensor and associated equipment) or system component failure does not prevent the system from performing its intended safety function.

The RPT system is separated from other recirculation control systems to the extent that failure of any single component in those systems does not prevent the RPT system from performing its intended function.

The RPT initiating trip circuitry is provided by the RPS. Existing RPS inputs sense "Turbine Stop Valve Closure" or "Turbine Control Valve Fast Closure." These signals are processed through new logic (equal to the existing RPS design quality) which blocks tripping the circuit breakers unless turbine first-stage pressure is above 30% of rated load.

### **5.5.16.4 Tests and Inspections**

Surveillance tests (functional and calibration) on the sensors and logics may be performed during plant operations. Bypass switches provided prevent tripping of the breakers during these tests. The test requirements are as specified in the Technical Specifications.

## 5.5.17 LOW-LOW SET RELIEF LOGIC SYSTEM

### 5.5.17.1 Design Bases

The low-low set (LLS) relief logic system is designed to:

- Mitigate the effects of postulated thrust loads on the safety relief valve discharge lines (SRVDLs) and the effects of postulated high-frequency pressure loads on the torus shell caused by subsequent actuations of the SRVs during a small- or intermediate-break loss-of-coolant accident (LOCA).
- Extend the time between SRV subsequent actuations to allow the SRVDL water leg to return to original level after an actuation.
- Remain operable in event of loss of offsite power (LOSP).
- Perform its design function assuming the worst postulated single failure. (The failure modes effects analysis (FMEA) is provided in table 5.5-5.)
- Assure no single failure shall cause more than one LLS valve to stick open
- Be testable during normal plant operation.

### 5.5.17.2 System Description

The arrangement of the SRV systems with the LLS design for HNP-2 is shown in table 5.5-6. The LLS design involves four non-ADS SRVs. The LLS control logic operates the four valves through arming and actuation. The arming function requires concurrent signals of any SRV opening and a high reactor vessel pressure exceeding scram setpoint.

The LLS system consists of SRV open-close monitors, nuclear boiler pressure instrumentation, and a cabinet housing LLS logic relays, solenoid valves, and pneumatic supply. (Accumulators are part of the pneumatic supply.) The SRV open-close monitors are pressure switches. Redundant switches on each tailpipe indicate an SRV opening. The nuclear boiler pressure instrumentation provides pressure trips for the arming pressure permissive and the LLS setpoints. One transmitter and master trip unit provide the arming permissive trip. A slave trip unit and another transmitter/master trip unit provide the two-out-of-two logic for LLS opening and one-out-of-two for reclosing logic to the solenoid valves. The solenoid valves and the drywell pneumatic system are used to pneumatically operate the LLS valves. The LLS valves discharge into the suppression pool. An automatic opening of SRVs will also occur at setpoints distributed among 3 groups (table 5.5-6), by pressure switch relay contacts inserted into the LLS pilot solenoid valve circuit. (See paragraph 5.2.2.2.3 for other details.)

### 5.5.17.3 Safety Evaluation

The objective of this analysis is to demonstrate that the design is capable of mitigating the thrust loads on the SRVDLs and the high-frequency loads on the torus shell from subsequent SRV actuations during small- and intermediate-break LOCAs. This can be accomplished by extending the time between actuations to exceed the water leg clearing time and by limiting subsequent SRV actuations to LLS valves only. The LLS system precludes the untimely actuation of the ADS valves by controlling only the LLS valves.<sup>(4)</sup> The capability of allowing sufficient time between SRV actuations was demonstrated by an analysis.<sup>(4)</sup> The overall response of the RPV and, specifically, the response of the SRV system during actuations were evaluated using current BWR evaluation methods and assumptions which are in conformance with the plant design basis.

The logic is designed to initiate opening of the four LLS valves within 1 s of an SRV opening (when reactor pressure is greater than operating pressure) to prevent reopening of the SRV.

The limiting events, which would cause the shortest time between SRV actuations, were analyzed in order to demonstrate the capability of LLS to extend the time between SRV actuations, thus assuring the water leg will recede to original level. These events are:

- Small break with early isolation due to an LOSP.
- Small break with early isolation due to an LOSP and a single failure.

Assuming the worst-case single failure, the LLS logic in HNP-2 can extend the time between SRV actuations from < 3 s to 39 s. Therefore, the LLS can mitigate the thrust load and shell pressure load concern from subsequent SRV actuation during a small-break LOCA even with the worst-case single failure and early reactor isolation occurring concurrently.

The predicted system responses for the limiting events postulated for HNP-2 are shown in figures 5.5-10 and 5.5-11. They show that the system pressure increases sharply as soon as isolation is completed. The pressure rise causes all 11 SRVs to actuate and initiates the LLS system. Actuation of SRVs quickly depressurizes the reactor vessel and all non-LLS valves close at the respective pilot setpoints or at their mechanical backup electric trip unit's deadband minimum (see paragraph 5.2.2.2.3). The LLS valves remain open until their LLS closing setpoints are reached. When the lowest LLS valve closes, the reactor pressure rises again and only that valve continues to cycle to control reactor pressure. The time between actuations is approximately 37 s for HNP-2. Figure 5.5-11 demonstrates the case in which two LLS valves become inoperative in the lowered setpoint relief mode. The remaining two LLS valves can turn the system pressure around before any non-LLS valves actuate at the pilot setpoints; thereafter, the lower operable LLS valve cycles to control reactor pressure. The time between actuations is ~ 39 s. The time is longer, because the two LLS valves take a longer time to depressurize the reactor and subsequent repressurization by decay heat is at a slower rate.

Low-low set design was evaluated at uprated power and vessel pressure<sup>(6, 8, 9)</sup> and for the SRV setpoint change.<sup>(7)</sup> The higher steam generation rate reduced slightly the time between actuations. Reference 7 supports continuous operation with one SRV out-of-service in the

LLS mode. However, ample margin in the time between actuations assured the water level in the SRV discharge line returned to its normal level.

With or without the LLS logic, HPCI or RCIC provide adequate core cooling.<sup>(4)</sup> Although the steam loss per discharge is higher with the LLS valves, the integrated total steam losses are identical for a LLS valve and a non-LLS valve. Initiation of HPCI or RCIC compensates for the steam loss through the LLS valves and provides adequate core cooling.

The LLS design does not result in exceeding any event acceptance limit for any applicable events identified in chapter 15.<sup>(3,4)</sup> Although the scenario for some events, such as loss-of-feedwater flow and small-break LOCA, may be changed, the safety margin of the plant is not reduced.

#### **5.5.17.4 Tests and Inspections**

The LLS relief logic system is demonstrated to be operable at regularly scheduled intervals by performance of:

- Channel functional tests, including calibration of the pressure trip units.
- Channel calibration of all transmitters.
- Functional testing of pressure switches.
- Logic system functional tests including simulated automatic operation of the entire system.
- Response time testing.

In addition, each master trip unit provides continuous readout of the transmitter control current via the meter on its front, which is calibrated in terms of the process variable. Therefore, the operator is able to cross-check the transmitter output currents by comparison and determine whether one of the transmitters is malfunctioning.

## HNP-2-FSAR-5

### REFERENCES

1. "Effectiveness of Core Standby Cooling Systems for General Electric Boiling Water Reactors Main Steam Line Isolation Valves," APED-5458, General Electric Company, March 1968.
2. "Design and Performance of General Electric Boiling Water Reactor Main Steam Line Isolation Valves," APED-5750, General Electric Company, March 1968.
3. "Low-Low Set Logic and Lower MSIV Water Level Trip for BWRs with Mark I Containment," NEDE-22223, General Electric Company, September 1982.
4. "Low-Low Set Relief Logic System and Lower Water Level Trip for Edwin I. Hatch Nuclear Plant Units 1 and 2," NEDE-22224, General Electric Company, December 1982.
5. "Safety Evaluation for Relaxation of RCIC Performance Requirements for Plant Hatch 1 and 2," AES-41-0688, General Electric Company, July 1988.
6. "Power Uprate Safety Analysis Report for Edwin I. Hatch Plant Units 1 and 2," NEDC-32405P, General Electric Company, December 1994.
7. "Safety Review For Edwin I. Hatch Nuclear Power Plant Units 1 and 2 Updated Safety/Relief Valve Performance Requirements," NEDC-32041P, General Electric Company, April 1996.
8. "Safety Analysis Report for Edwin I. Hatch Units 1 and 2 Thermal Power Optimization," NEDC-33085P, GE Nuclear Energy, December 2002.
9. "10-PSI Dome Pressure Increase Project Report for Edwin I. Hatch Units 1 and 2," GE-NE-0000-0003-0634-01, Revision 1, GE Nuclear Energy, July 2003.

TABLE 5.5-1 (SHEET 1 OF 2)

## REACTOR RECIRCULATION SYSTEM DESIGN CHARACTERISTICS

External Loops

|                                                                  |          |
|------------------------------------------------------------------|----------|
| Number of loops                                                  | 2        |
| Pump sizes (nominal outside diameter)                            |          |
| Pump suction (in.)                                               | 28       |
| Pump discharge (in.)                                             | 28       |
| Discharge manifold (in.)                                         | 22       |
| Recirculation inlet line (in.)                                   | 12       |
| Design pressure (psig) design temperature (°F)                   |          |
| Suction piping and valve up to and including pump suction nozzle | 1250/575 |
| Discharge gate valve                                             | 1525/575 |
| Piping up to vessel                                              | 1450/575 |
| Vessel bottom drain                                              | 1275/575 |
| Pump                                                             | 1500/575 |

Operation at Rated Conditions

|                                                    |                        |
|----------------------------------------------------|------------------------|
| RRS pump (each)                                    |                        |
| Flow (gal/min)                                     | 45,200                 |
| Flow (lb/h)                                        | 17.1 x 10 <sup>6</sup> |
| Total developed head (ft)                          | 530                    |
| Suction pressure (static) (psia)                   | 1065                   |
| Required NPSH                                      |                        |
| 10% flow cold (ft)                                 | 70                     |
| Rated hot (ft)                                     | 350                    |
| Water temperature (max) (°F)                       | 540                    |
| Pump brake hp (min)                                | 5260                   |
| Flow velocity at pump suction (approximate) (ft/s) | 28.3                   |

## Pump Motor

|                |      |
|----------------|------|
| Rating (V)     | 4160 |
| Phase          | 3    |
| Frequency (Hz) | 60   |

HNP-2-FSAR-5

**TABLE 5.5-1 (SHEET 2 OF 2)**

Jet Pumps

|                                               |                         |
|-----------------------------------------------|-------------------------|
| Number                                        | 20                      |
| Total jet pump flow (lb/h)                    | 41.72 x 10 <sup>6</sup> |
| Throat inside diameter (in.)                  | 6.86                    |
| Diffuser inside diameter (in.)                | 17                      |
| Nozzle inside diameter (representative) (in.) | 3.4                     |
| Diffuser exit velocity (ft/s)                 | 14.7                    |
| Jet pump head (ft)                            | 91.7                    |

RRS Loop Block Valve

|                                          |                    |
|------------------------------------------|--------------------|
| Type                                     | Gate               |
| Actuator                                 | Motor<br>operated  |
| Material                                 | Stainless<br>steel |
| Shutoff leakage (cm <sup>3</sup> /in./h) | 2                  |
| Valve size diameter (in.)                | 28                 |



TABLE 5.5-3

## RWC SYSTEM EQUIPMENT DESIGN DATA

Main Cleanup Recirculation Pumps

|                                            |        |
|--------------------------------------------|--------|
| Number required (one is a backup)          | 1 of 2 |
| Capacity (each) (%)                        | 100    |
| Discharge flow per pump at 545°F (gal/min) | 270    |
| Design temperature (°F)                    | 575    |
| Design pressure (psig)                     | 1400   |
| Differential head at rated flow (ft)       | 500    |

Heat Exchangers

|                                             | <u>Regenerative</u> | <u>Nonregenerative</u> |
|---------------------------------------------|---------------------|------------------------|
| Number required                             | 3 of 3              | 2 of 2                 |
| Reactor coolant design flow per unit (lb/h) | 100,000             | 100,000                |
| Shell-side design pressure (psig)           | 1400                | 150                    |
| Shell-side design temperature (°F)          | 564                 | 370                    |
| Tube-side design pressure (psig)            | 1400                | 1400                   |
| Tube-side design temperature (°F)           | 564                 | 564                    |

Filter-Demineralizers

|                                                                                |            |
|--------------------------------------------------------------------------------|------------|
| Number required                                                                | 2          |
| Capacity (each) (%)                                                            | 50         |
| Design flow per unit (gal/min)                                                 | 101        |
| Effluent conductivity, (µmho/cm at 25°C)                                       | < 0.1      |
| Effluent pH at 25°C                                                            | 6.5 to 7.5 |
| Effluent insolubles ((ppb) measured as residue on<br>0.45-micron filter paper) | < 10       |
| Design temperature (°F)                                                        | 150        |
| Design pressure (psig)                                                         | 1400       |
| Time to backwash and precoat (min)                                             | ≤ 60       |

HNP-2-FSAR-5

TABLE 5.5-4 (SHEET 1 OF 4)

LIMITORQUE SEISMIC AND ENVIRONMENTAL TEST REPORT INDEX<sup>(a)</sup>

| <u>Report Title and Date</u>      | <u>Test Agency Report No.</u>                  | <u>Date</u>           | <u>Unit</u> | <u>Motor</u>                   | <u>Radiation Level</u> | <u>Test Base</u>                                                                                                                                                                                                                                                                                                          |
|-----------------------------------|------------------------------------------------|-----------------------|-------------|--------------------------------|------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| DC Test<br>1971<br>12/71          | Franklin<br>Institute<br>F-C3117               | 11/16/71              | SMB-0-25    | Peerless<br>Class H            | ---                    | 6 days - 145°F - 100% RH<br>Unit cycled twice<br>145°F - time 0<br>298°F - 5 s from 0<br>Hold 298°F - 3 h from 0<br>Hold 281°F - to 6 h from 0<br>Hold 265°F - to 24 h from 0<br>Unit cycled 8 times                                                                                                                      |
| Class B<br>Steam Test<br>2/72     | Franklin<br>Institute<br>F-C3271               | 1/2/72                | SMB-0-10    | Reliance<br>Class B<br>w/brake | ---                    | Ambient - time 0<br>210°F - 1 h from 0<br>Hold 212°F - to 6 h from<br>0 to 155°F - in 3 h<br>Hold 155°F - to 12 h from 0<br>Unit cycled 11 times                                                                                                                                                                          |
| BWR Test<br>9/72                  | Franklin<br>Institute<br>F-C3441 or<br>600376A | 7/31/72 -<br>8/30/72  | SMB-0-25    | Reliance<br>Class RH           | 200 M rads             | Per proposed IEEE 382<br>(Equivalent IEEE 382-72)                                                                                                                                                                                                                                                                         |
| PWR Test<br>12/9/75               | Limitorque<br>Corporation<br>600456            | 6/7/74 -<br>11/22/74  | SMB-0-40    | Reliance<br>Class RH           | 204 M rads             | IEEE 382-72 - Table I                                                                                                                                                                                                                                                                                                     |
| Class B<br>Outside<br>Containment | Limitorque<br>Corporation<br>B0003             | 11/13/74 -<br>1/23/75 | SMB-0-25    | Reliance<br>Class B            | 20 M rads              | Age - 165°F, 100% RH,<br>200 h - 200 cycles;<br>1800 cycles at room ambient<br>120°F - time 0<br>250°F - 10 s<br>Hold 250°F - to 30 min from time 0<br>to 120°F - to 2 h from time 0<br>120°F to 250°F - 10 s transient<br>Hold 250°F - to 24 h from time 0<br>Hold 200°F - to 16 days from time 0<br>Unit cycled 5 times |

HNP-2-FSAR-5

**TABLE 5.5-4 (SHEET 2 OF 4)**

| <u>Report Title and Date</u>                 | <u>Test Agency Report No.</u>                  | <u>Date</u>         | <u>Unit</u>             | <u>Motor</u>                                        | <u>Radiation Level</u> | <u>Test Base</u>                                                                                                                                                                                                                           |
|----------------------------------------------|------------------------------------------------|---------------------|-------------------------|-----------------------------------------------------|------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| DC Test                                      | Limitorque Corporation<br>B0009                | 9/2/75 -<br>11/3/75 | SMB-0-25                | Peerless<br>Class RH                                | 10 M rads              | Age - Motor 180°C for 100 h<br>2000 cycles at ambient<br>120°F - time 0 to 340°F -<br>1 h from time 0<br>Hold 330°F - to 4 h from time 0<br>Hold 310°F - to 7 h from time 0<br><br>Hold 212°F - to 25 h from time 0<br>Unit cycled 6 times |
| Test of LVC for General Requirements AC Test | Limitorque Corporation<br>600198<br>Addendum I | 10/31/68            | SMB-0-15<br>Brake/Motor | Reliance Class H<br><br>Reliance Class H<br>w/Brake | ---                    | Reference IEEE Subcommittee 2<br>Level 4 Standard Draft dated 6/7/68<br>1 h - 329°F<br>2 h - 312°F<br>2 h - 300°F<br>19 h - 272°F                                                                                                          |
| 1/2/69                                       | 259A-4723-<br>Issue No. 2                      | 8/20/70             |                         |                                                     |                        | 6 days - 251°F<br>Total - 7 days                                                                                                                                                                                                           |

Electric Operators Seismic Test Report Index

| <u>Unit Size<sup>(b)</sup></u> | <u>Test Facility</u> | <u>Report No.</u> | <u>Report Date</u> | <u>Test Base</u>        | <u>G-Level Each Axis</u> |
|--------------------------------|----------------------|-------------------|--------------------|-------------------------|--------------------------|
| SMB-0-25                       | Lockheed Electronics | 2768-4768A        | 10/21/71           | Uniaxial                | 5                        |
| SMB-0-25 +<br>Brake            | Lockheed Electronics | 2768-4768         | 10/21/71           | Uniaxial                | 5.3                      |
| SMC-000-5                      | Ogden                | 7K112-11          | 11/27/72           | Uniaxial                | 5.5 nominal              |
| SMB-0-25                       | Ogden                | 7K112-11          | 11/27/72           | Uniaxial                | 5.5 nominal              |
| SMB-0-40                       | Lockheed Electronics | 3521-4811         | 6/17/74            | Uniaxial<br>IEEE 344-71 | 6                        |

HNP-2-FSAR-5

**TABLE 5.5-4 (SHEET 3 OF 4)**

Electric Operators Seismic Test Report Index (Continued)

| <u>Unit Size</u> <sup>(b)</sup> | <u>Test Facility</u> | <u>Report No.</u> | <u>Report Date</u> | <u>Test Base</u>        | <u>G-Level Each Axis</u> |
|---------------------------------|----------------------|-------------------|--------------------|-------------------------|--------------------------|
| SMB-0-25                        | Aero Nav             | 5720              | 1/6/75             | IEEE 344-75<br>Modified | 5 at 3 g<br>1 at 6 g     |
| SMB-000-5                       | Aero Nav             | 5721              | 1/7/75             | IEEE 344-75<br>Modified | 5 at 3 g<br>1 at 6 g     |
| SMB-1-40                        | Aero Nav             | 5722              | 1/7/75             | IEEE 344-75<br>Modified | 5 at 3 g<br>1 at 6 g     |
| SB-3-100                        | Aero Nav             | 5770              | 10/20/75           | IEEE 344-75             | 5 at 3 g<br>1 at 6 g     |
| SMB-000-5                       | Aero Nav             | 5771              | 10/17/75           | IEEE 344-75             | 1 at 6 g<br>5 at 3 g     |
| SMB-3-100                       | Aero Nev             | 5773              | 10/16/75           | IEEE 344-75             | 2 at 5 g<br>1 at 6 g     |
| SB-0-25                         | Aero Nav             | 5774              | 10/22/75           | IEEE 344-75             | 2 at 5 g<br>1 at 6 g     |
| SMB-0-25DC                      | Aero Nav             | 5772              | 10/21/75           | IEEE 344-75             | 2 at 5 g<br>1 at 6 g     |
| SMB-1-100<br>"E" Line Motor     | Aero Nav             | 5775              | 10/22/75           | IEEE 344-75             | 2 at 5.3 g<br>1 at 6.3 g |
| SMB-5T-250DC                    | Wyle Labs            | 43059-1           | 10/6/75            | Spec biaxial            | 1 g                      |
| SMB-0-25DC                      | AEL                  | 75-149ET          | 10/29/75           | Single axis             | 4 g                      |
| SMB-5T-250AC                    | Wyle Labs            | 43059-02          | 10/30/75           | Single axis             | 6 g                      |

Electric/Manual Operator Seismic Test Report Index

| <u>Unit Size</u> <sup>(b)</sup> | <u>Test Facility</u>    | <u>Report No.</u> | <u>Report Date</u> | <u>Test Base</u> | <u>G-Level Each Axis</u> |
|---------------------------------|-------------------------|-------------------|--------------------|------------------|--------------------------|
| SMB-000-2/HOBC                  | Lockheed<br>Electronics | 2773C-4773        | 5/3/72             | Single axis      | 4.4 g                    |

HNP-2-FSAR-5

**TABLE 5.5-4 (SHEET 4 OF 4)**

Electric/Manual Operator Seismic Test Report Index (Continued)

| <u>Unit Size</u> <sup>(b)</sup>   | <u>Test Facility</u> | <u>Report No.</u>      | <u>Report Date</u> | <u>Test Base</u>           | <u>G-Level Each Axis</u>  |
|-----------------------------------|----------------------|------------------------|--------------------|----------------------------|---------------------------|
| SMB-0-25/H3BC                     | Lockheed Electronics | 2786-4786- Issue No. 2 | 9/5/72             | Single axis                | 3 g                       |
| SMB-3-100-H5BC                    | Lockheed Electronics | 2786-4-4786            | 2/1/73             | Single axis                | 4 g                       |
| SMB-0-H3BC                        | Lockheed Electronics | 2786-3-4786            | 2/6/73             | Single axis                | 3.7 g                     |
| SMB-1-25/H4BC Standard Adapter    | Aero Nav             | 506167-5               | 12/17/75           | IEEE 344-75 Fragility test | 8.0 g Capacity of machine |
| SMB-00-15/H3BC Spec Steel Adapter | Aero Nav             | 5-6167-4               | 12/16/75           | IEEE 344-75                | 2 at 5.3 g<br>1 at 6.3 g  |

Manual Operators Seismic Test Report Index

| <u>Unit Size</u> <sup>(b)</sup> | <u>Test Facility</u> | <u>Report No.</u> | <u>Report Date</u> | <u>Test Base</u> | <u>G-Level Each Axis</u> |
|---------------------------------|----------------------|-------------------|--------------------|------------------|--------------------------|
| H1BC                            | Lockheed Electronics | 2553-4737         | 12/28/70           | Single axis      | 5.3 g                    |
| H1BC                            | Lockheed Electronics | 2786-5-4786       | 1/30/73            | Single axis      | 4.6 g                    |
| H4BC                            | Lockheed Electronics | 2786-6-4786       | 1/30/73            | Single axis      | 4.6 g                    |
| H6BC                            | Lockheed Electronics | 2786-7-4786       | 1/30/73            | Single axis      | 3.6 g                    |

- a. As of 7/26/75, seismic tests were completed to IEEE 344-1975 for both SMB and SB units to 6.0 g vertical and 3.2 g horizontal. Since no cross coupling was noted between axes, the test qualifies the SMB/SB to 6.0 g in both the vertical and horizontal axes. Maximum g-level dwells in each of the three axes qualify the units for any mounting position.
- b. The levels tested for the unit sizes above are not to be construed as applicable to all sizes and combinations of SMB/H-BC units. The maximum g level allowed for all sizes is limited to 3 g in any axis.

TABLE 5.5-5 (SHEET 1 OF 8)

## LOW-LOW SET FMEA FOR FUNCTIONAL COMPONENTS

| <u>Failure Mode</u> <sup>(a)</sup>                         | <u>System Lineup</u> <sup>(b)</sup> | <u>Effect</u> <sup>(c)</sup>                                                              | <u>When Observed</u>                             | <u>Functional Failure</u> <sup>(c)</sup> |
|------------------------------------------------------------|-------------------------------------|-------------------------------------------------------------------------------------------|--------------------------------------------------|------------------------------------------|
| <u>System Component:</u> Pressure Switches PS1-PS11        |                                     |                                                                                           | <u>Function:</u> SRV Open Sensor                 |                                          |
| A1                                                         | A11                                 | Valve operates normally.                                                                  | Surveillance test once/operating cycle           | None                                     |
| A2                                                         | N2, T1, O1, O2, N2, S2              | Valve operates normally.                                                                  | Trip unit surveillance test once/month           | None                                     |
|                                                            | N2 (Note 1)<br>S2 (Note 1)          | All LLS valves.<br>EA or EVO.                                                             | (Note 1)                                         | EA or EVO<br>All valves (Note 2)         |
|                                                            | T2                                  | K9 picks up & one valve opens.                                                            | During monthly surveillance                      | IVO<br>One valve                         |
| <u>System Component:</u> Pressure Transmitters PT1 and PT2 |                                     |                                                                                           | <u>Function:</u> Reactor pressure sensors        |                                          |
| B1                                                         | A11                                 | No valve opening possible. Analog trip trouble annunciator ON. Trip unit meter downscale. | Immediately                                      | FTO<br>One valve                         |
| B2                                                         | N1, N2, T1, T2, O1, O2              | Analog trip trouble annunciator ON. Valve operates normally. Trip unit meter upscale.     | Immediately                                      | None                                     |
| B2 (PT1 only)                                              | S1                                  | One channel arms & annunciates.                                                           | Annunciation when SRV is manually actuated       | IA<br>One channel                        |
|                                                            | S2                                  | Another SRV opens.                                                                        | Annunciation when SRV is manually actuated       | IVO<br>One SRV                           |
| <u>System Component:</u> Trip Units MTU1, MTU2, and STU 1  |                                     |                                                                                           | <u>Function:</u> Reactor pressure trip setpoints |                                          |
| C1                                                         | A11                                 | Same as B1.                                                                               | Immediately                                      | FTO<br>One valve                         |
| C2                                                         | Same as B2                          | Same as B2.                                                                               | Immediately                                      | Same as B2                               |
| C2 (MTU1 only)                                             | S1, S2                              | Same as B2 (PT1 only).                                                                    | Same as B2                                       | Same as B2                               |

HNP-2-FSAR-5

**TABLE 5.5-5 (SHEET 2 OF 8)**

| <u>Failure Mode</u> <sup>(a)</sup>                                  | <u>System Lineup</u> <sup>(b)</sup> | <u>Effect</u> <sup>(c)</sup>                               | <u>When Observed</u>                                          | <u>Functional Failure</u> <sup>(c)</sup> |
|---------------------------------------------------------------------|-------------------------------------|------------------------------------------------------------|---------------------------------------------------------------|------------------------------------------|
| <u>System Component:</u> Relays - K1, K2, K4, K5, K10, K11, and K12 |                                     |                                                            | Function: Divisional isolation for annunciators or indicators |                                          |
| D1, D2                                                              | All                                 | False annunciation or indication. Valve operates normally. | Upon daily or monthly surveillance                            | None                                     |
| <u>System Component:</u> Relay K6                                   |                                     |                                                            | Function: Arming setpoint relay                               |                                          |
| D1, D3                                                              | N1, N2, T2, S1, S2                  | Valve operates normally. Test light does not come ON.      | Monthly surveillance test                                     | None                                     |
| D1 & D3 arming contact                                              | O1, O2                              | K9 does not pick up & arm channel. Valves do not close.    | When valve operates                                           | FTO<br>One valve                         |
| D3 contact with K12                                                 | O1, O2                              | Test indicator fails to function.                          | Monthly surveillance                                          | None                                     |
| D2, D4                                                              | N1, N2, T1, T2, O2, O1              | Valve operates normally.                                   | Monthly surveillance                                          | None                                     |
| D2 & D4 arming contact                                              | S2                                  | Channel arms & valve opens.                                | Upon SRV actuation or monthly surveillance                    | IA IVO<br>One valve                      |
|                                                                     | S1                                  | Channel arms. LLS channel armed. Annunciator ON.           | Immediately upon manual SRV actuation                         | IA<br>One valve                          |
| D5 not used                                                         |                                     |                                                            |                                                               |                                          |
| <u>System Component:</u> Relays K7 and K8                           |                                     |                                                            | Function: LLS trip setpoint                                   |                                          |
| D1, D3                                                              | N1, N2, T1, T2, S1, S2, O2          | Valve operates normally.                                   | Monthly surveillance                                          | None                                     |
| D1 & D3 contact in series with K14 or K15                           | O1                                  | Valve fails to open.                                       | When valves fails to open                                     | FTO<br>One valve                         |
| D2, D4                                                              | N1, N2, T1, T2, O1, O2, S1, S2      | Valve operates normally.                                   | Monthly surveillance                                          | None                                     |
| D5                                                                  | All                                 | Valve operates normally.                                   | Monthly surveillance                                          | None                                     |

HNP-2-FSAR-5

**TABLE 5.5-5 (SHEET 3 OF 8)**

| <u>Failure Mode</u> <sup>(a)</sup>               | <u>System Lineup</u> <sup>(b)</sup> | <u>Effect</u> <sup>(c)</sup>                                                                                                           | <u>When Observed</u>                            | <u>Functional Failure</u> <sup>(c)</sup> |
|--------------------------------------------------|-------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------|------------------------------------------|
| <u>System Component:</u> Relay K9                |                                     |                                                                                                                                        | Function: Logic arming relay                    |                                          |
| D1, D3                                           | N1, N2,<br>T1, T2,<br>S1, S2        | Valve operates normally.                                                                                                               | Monthly surveillance                            | None                                     |
| D1 & D3 for contact in series with K13           | O1, O2                              | Valve fails to open.<br><br>Annunciator OFF.                                                                                           | During arming logic test. LLS channel armed     | FTO<br>One valve                         |
| D3 for contact in series with S5                 | O1, O2                              | Valve does not stay armed; so, it closes at arming pressure setpoint.                                                                  | Monthly during surveillance or during operation | (Note 3)                                 |
| D3 for contact in series with K11                | O1, O2                              | Valve operates normally but channel armed annunciator stays OFF.                                                                       | When annunciator stays off but valve operates   | None                                     |
| D3 for contact in other channel in same division | O1, O2                              | Does not seal in other channel pressure switch sense.                                                                                  | During outage testing                           | None                                     |
| D5 not used                                      |                                     |                                                                                                                                        |                                                 |                                          |
| D2                                               | All except<br>T2, N2,<br>S2         | Annunciator indicates arming.                                                                                                          | Immediately                                     | IA<br>One channel                        |
|                                                  | N2, S2,<br>T2                       | Valve opens, channel arms, & annunciator is ON.                                                                                        | Immediately upon annunciation or tests          | IVO<br>One channel                       |
| D2                                               | (Note 4)                            | Same as T2 except, if reactor pressure reaches arming setpoint without opening SRV, all LLS valves open. Channel armed annunciator ON. | (Note 4)                                        | EVO<br>All LLS<br>Valves<br>(Note 4)     |
| D4 contact in series with solenoid               | N1, T1,<br>O1, O2,<br>S1            | Valve operates normally.                                                                                                               | Monthly surveillance                            | None                                     |
|                                                  | N2, S2,<br>T2                       | Valve opens. L5 does not extinguish.                                                                                                   | During monthly surveillance                     | IVO<br>One valve                         |



HNP-2-FSAR-5

**TABLE 5.5-5 (SHEET 4 OF 8)**

| <u>Failure Mode</u> <sup>(a)</sup>                                                       | <u>System Lineup</u> <sup>(b)</sup> | <u>Effect</u> <sup>(c)</sup>                                                                     | <u>When Observed</u>                                   | <u>Functional Failure</u> <sup>(c)</sup> |
|------------------------------------------------------------------------------------------|-------------------------------------|--------------------------------------------------------------------------------------------------|--------------------------------------------------------|------------------------------------------|
| <u>System Component:</u> Relay 9 (continued)                                             |                                     |                                                                                                  | Function: Logic arming relay                           |                                          |
|                                                                                          | N2, S2, T2                          | Valve opens. L5 does not extinguish.                                                             | During monthly surveillance                            | IVO<br>One valve                         |
| D4 contact in series with K11                                                            | N1, N2 T2, S1                       | Valve operates normally. Channel armed annunciator ON.                                           | Immediately                                            | None                                     |
|                                                                                          | T1, O1, O2                          | Valve operates normally.                                                                         | When annunciator does not go off & channel is reset    | None                                     |
| D4 contact in series with S5                                                             | Same as D2                          | Same as D2 except relay drops out when S5 is pushed & picks up when S5 is released.              | Same as D2                                             | Same as D2                               |
| D4 contact interconnect between channels                                                 | N1, S1, T1, O1, O2, N2, S2          | Valve operates normally.                                                                         | Once/operating Cycle surveillance                      | None                                     |
|                                                                                          | T2                                  | Channel arms or valve opens.                                                                     | During monthly surveillance                            | IA or IVO<br>One valve                   |
| <u>System Component:</u> 125 V-dc battery<br>125 V-dc contractor<br>24 V-dc power supply |                                     |                                                                                                  | Function: Provide logic and trip unit power            |                                          |
| E1, E2                                                                                   | All                                 | No effect on valve operation. Power fail and/or analog trip trouble annunciators ON.             | Immediately                                            | None                                     |
| E3                                                                                       | All                                 | One valve in same division does not open. Power loss annunciator ON.                             | Immediately                                            | FTO<br>One valve                         |
| E4                                                                                       | All                                 | One valve does not open. Analog trip trouble annunciator ON. LLS channel armed. Annunciator OFF. | Immediately                                            | FTO<br>One valve                         |
| <u>System Component:</u> Lights L1, L2, L3, and L4                                       |                                     |                                                                                                  | Function: Test and failure condition indication        |                                          |
| F1                                                                                       | All                                 | Valve operates normally. Light OFF.                                                              | L1, L2-daily surveillance; L3, L4-monthly surveillance | None                                     |

HNP-2-FSAR-5

**TABLE 5.5-5 (SHEET 5 OF 8)**

| <u>Failure Mode</u> <sup>(a)</sup>                             | <u>System Lineup</u> <sup>(b)</sup> | <u>Effect</u> <sup>(c)</sup>                                                                                | <u>When Observed</u>                            | <u>Functional Failure</u> <sup>(c)</sup> |
|----------------------------------------------------------------|-------------------------------------|-------------------------------------------------------------------------------------------------------------|-------------------------------------------------|------------------------------------------|
| <u>System Component:</u> Lights L1, L2, L3, and L4 (continued) |                                     |                                                                                                             | Function: Test and failure condition indication |                                          |
| F2                                                             | All                                 | Blows fuse so all lights are OFF. Valve operates normally.                                                  | Daily surveillance                              | None                                     |
| <u>System Component:</u> Light L5                              |                                     |                                                                                                             | Function: LLS logic test                        |                                          |
| F1                                                             | All                                 | Valve operates normally.                                                                                    | Monthly surveillance                            | None                                     |
| F2 (Note 5)                                                    | N1, N2, T2, O1                      | Valve operates normally.                                                                                    | Monthly surveillance                            | None                                     |
|                                                                | T1                                  | Valve opens if K9 is energized.                                                                             | Immediately during surveillance test            | IVO<br>One valve                         |
|                                                                | O2                                  | K9 is armed, so, one valve is stuck open until reset by operator.                                           | During pressurization transient                 | SOV One valve                            |
| <u>System Component:</u> Switches S1, S2, S3, and S6           |                                     |                                                                                                             | Function: Power test card out-of-file test      |                                          |
| G1                                                             | All                                 | Valve operates normally. Analog trip trouble or power loss annunciators ON.                                 | Immediately                                     | None                                     |
| G2                                                             | All                                 | Valve operates normally. Analog trip trouble or power loss annunciators do not go ON when testing function. | Monthly surveillance                            | None                                     |
| <u>System Component:</u> Switch S4                             |                                     |                                                                                                             | Function: LLS logic test                        |                                          |
| G1                                                             | All                                 | Valve operates normally                                                                                     | Monthly surveillance                            | None                                     |
| G2                                                             | N1                                  | K9 pick ups & latches in arming one channel. LLS channel armed, annunciator ON, does not RESET.             | Immediately (Note 6)                            | IA<br>One channel                        |
|                                                                | N2, S2                              | Failure in line N2; valve operates normally.                                                                | Immediately                                     | None                                     |
|                                                                |                                     | If failure exists (Note 7) during N1, channel is armed when pressure increases to N2. Valve opens.          | One valve                                       | IVO<br>(Note 7)                          |
|                                                                | T1, T2, O1, O2, S1                  | Valve operates normally. No indication until K7 & K8 drop out. Then it is in the N1 or N2 line up.          | Immediately (Note 6)                            | None                                     |

HNP-2-FSAR-5

**TABLE 5.5-5 (SHEET 6 OF 8)**

| <u>Failure Mode</u> <sup>(a)</sup> | <u>System Lineup</u> <sup>(b)</sup> | <u>Effect</u> <sup>(c)</sup>                                                                                                                                                                                                                                               | <u>When Observed</u>                                         | <u>Functional Failure</u> <sup>(c)</sup>    |
|------------------------------------|-------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------|---------------------------------------------|
| <u>System Component:</u> Switch S5 |                                     |                                                                                                                                                                                                                                                                            | Function: Reset armed channel                                |                                             |
| G1                                 | All                                 | Arming relay K9 does not latch in once armed. The one valve involved can only open above the arming enable setpoint and close below the same trip unit reset point if higher than normal. Valve does not operate setpoints. Armed annunciator goes ON & OFF with pressure. | Monthly surveillance or when valve operates                  | One valve opens & closes at wrong setpoint. |
| G2                                 | All                                 | K9 arms normally. Valve opens & closes normally but arming relay cannot be reset so remains armed. Channel armed annunciator stays ON.                                                                                                                                     | Monthly surveillance or when operator tries to reset channel | No arming reset. One valve                  |

NOTES:

1. The failure listed occurs during a transient when reactor pressure increases to its scram setpoint but the SRVs have not lifted. This condition is not expected during plant operation. The stuck-closed contact, i.e., failure mode A2, produces a false indication of a SRV opening, and two LLS valves either arm, or operate, depending on LLS setpoints. An opening produces SRV opening signals in the other division, thus, four LLS valves could be armed.
2. The failure mode A2, coupled with a pressurization transient, contributes to early arming and opening of SRVs. Under these conditions of early LLS initiation, the LLS performs its function to relieve reactor pressure and prevents early subsequent actuations as designed.
3. After the first pop, the valve closes at the arming permissive pressure. For subsequent pops, the valve opens simultaneously with another valve if another LLS valve has an opening setpoint above or near the arming permissive pressure.
4. The failure occurs during a pressurization transient, when reactor pressure increases to its scram setpoint but the SRVs have not lifted, a condition which is not expected during plant operation. This failure mode, coupled with a transient, contributes to an early LLS initiation. EVOs result in the LLS performing its function to relieve reactor pressure.
5. L5 is a neon light with a limiting resistor, and a short requires shorting in both the lamp and the resistor.
6. The switch is also used for power test. If contacts stick closed, the power loss annunciator does not reset.
7. IVO only occurs when the failure is coincident with a change in reactor pressure, i.e., changing from N1 to N2.

**TABLE 5.5-5 (SHEET 7 OF 8)**

a. LLS Components and Their Failure Modes

- A. Pressure switches (normally open contacts)\*\*
  - A1. Contacts stick open, inadvertently open or fail to close.
  - A2. Contacts stick close or fail to open.\*
- B. Transmitter
  - B1. Downscale failure\*\*
  - B2. Upscale failure\*\*
- C. Trip unit
  - C1. Downscale failure\*\*
  - C2. Upscale failure\*\*
- D. Relay
  - D1. All contacts stuck in deenergized state or coil mechanism fails.
  - D2. All contacts stuck in energized state.\*
  - D3. One contact stuck in deenergized state.
  - D4. One contact stuck in energized state.
  - D5. One normally closed contact opens.\*
- E. Power supply and battery
  - E1. Power circuit short fails power.
  - E2. Power circuit open fails power.
  - E3. Logic circuit short blows fuse.
  - E4. Trip unit circuit short blows fuse.
- F. Light
  - F1. Light opens.
  - F2. Light shorts.
- G. Switch
  - G1. Contacts stick open or fail open.
  - G2. Contacts stick closed.\*

b. System Lineups Identification

- N. Normal status (standby)
  - N1. All relays are deenergized
  - N2. K7 and K8 are energized (reactor pressure above LLS setpoints and below the arming permissive).
- O. Operational status
  - O1. K9, K7, and K8 are energized (open valve).
  - O2. K9 is energized.

**TABLE 5.5-5 (SHEET 8 OF 8)**

S. SRV manual test status

- S1. Same as N1 with SRV manually opened.
- S2. Same as N2 with SRV manually opened.

T. Testing status

- T1. K9 is energized.
- T2. K7, K8, and K6 are energized (calibrating trips during N2).

c. Functional Failure Modes Identification

- FTO - Failure to open on demand
- SOV - Stuck-open valve
- IA - Inadvertent arming
- IVO - Inadvertent valve opening
- EA - Early arming
- EVO - Early valve opening

---

\* Inadvertent shorting or closing of normally unconnected points is not considered a single failure in this FMEA.



\*\* Setpoints account for nominal drift; large drift is considered an upscale or downscale failure.

HNP-2-FSAR-5

**TABLE 5.5-6**  
**LLS SRV SYSTEM FOR HNP-2**

|                                                         | SRVs     |          |          |          |          |          |          |          |          |          |          |
|---------------------------------------------------------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|
|                                                         | <u>A</u> | <u>B</u> | <u>C</u> | <u>D</u> | <u>E</u> | <u>F</u> | <u>G</u> | <u>H</u> | <u>K</u> | <u>L</u> | <u>M</u> |
| Pressure relief function                                | X        | X        | X        | X        | X        | X        | X        | X        | X        | X        | X        |
| ADS function                                            | X        | -        | X        | -        | X        | -        | -        | X        | X        | X        | X        |
| Valve group                                             | II       | I        | II       | I        | III      | I        | I        | III      | II       | III      | II       |
| Steam pilot mechanical opening setpoint (psig)          | 1150     | 1150     | 1150     | 1150     | 1150     | 1150     | 1150     | 1150     | 1150     | 1150     | 1150     |
| Electrical backup to mechanical opening setpoint (psig) | 1130     | 1120     | 1130     | 1120     | 1140     | 1120     | 1120     | 1140     | 1130     | 1140     | 1130     |
| LLS relief channel                                      | -        | A        | -        | D        | -        | C        | B        | -        | -        | -        | -        |
| LLS opening allowable value (psig) <sup>(a)</sup>       | -        | ≤ 1010   | -        | ≤ 1050   | -        | ≤ 1040   | ≤ 1025   | -        | -        | -        | -        |
| LLS closing allowable value (psig) <sup>(a)</sup>       | -        | ≤ 860    | -        | ≤ 900    | -        | ≤ 890    | ≤ 875    | -        | -        | -        | -        |

a. LLS setpoints are interchangeable among LLS valves.




REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

REACTOR RECIRCULATING SYSTEM  
ELEVATION AND ISOMETRIC

FIGURE 5.5-1



ACAD 2050502

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

OPERATING PRINCIPLE OF JET PUMP

FIGURE 5.5-2





ACAD 2050503


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

RECIRCULATION SYSTEM-CORE  
FLOODING CAPABILITY

FIGURE 5.5-3



ACAD 2050504


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

MAIN STEAM LINE FLOW  
RESTRICTOR LOCATION

FIGURE 5.5-4



ACAD 2050505


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

MIAN STEAM LINE ISOLATION VALVE

FIGURE 5.5-5



ACAD 2050506


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

LOCATION OF RELIEF VALVE EXITS  
IN THE TORUS

FIGURE 5.5-6



ACAD 2050508


REV 27 10/09



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

RECIRCULATION SYSTEM WITH  
RECIRCULATION PUMP TRIP

FIGURE 5.5-8



ACAD 2050509


REV 22 9/04



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

RECIRCULATION PUMP TRIP CONTROL

FIGURE 5.5-9



ACAD 2050510


REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

SYSTEM RESPONSE FOR LIMITING EVENT WITH  
 FOUR-VALVE LLS

FIGURE 5.5-10



ACAD 2050511

REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

SYSTEM RESPONSE FOR LIMITING EVENT WITH SINGLE FAILURE (ONLY TWO LLS VALVES OPERABLE)

FIGURE 5.5-11





ACAD 2050512

REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

SUPPRESSION POOL TEMPERATURE SENSOR LOCATIONS

FIGURE 5.5-12

## **5.6 INSTRUMENTATION REQUIREMENTS**

The functional requirements for the reactor coolant system instrumentation are discussed in the following subsections. A discussion of the design and logic of the instrumentation is discussed in chapter 7.

### **5.6.1 NEUTRON MONITORING SYSTEM**

This system is described in subsection 7.6.2.

### **5.6.2 REACTOR PRESSURE VESSEL (RPV) INSTRUMENTATION**

RPV instrumentation is designed to provide the operator with sufficient indication of reactor core flowrate, RPV water level, RPV pressure, and nuclear system leakage to maintain proper operating conditions.

#### **5.6.2.1 RPV Temperature**

RPV temperature is determined on the basis of reactor coolant temperature. Temperatures needed for operation and for compliance with the technical specification operating limits are obtained from one of several sources depending on the operating condition. During normal operation, either the reactor pressure and/or the inlet temperature of the coolant in the reactor recirculation system loops can be used to determine the RPV temperature. Below the operating span of the temperature detectors in the RRS loop, the pressure is used for determining the temperature. Below 212°F the coolant temperature in the RPV, and thus the RPV temperature, is reasonably determined by the reactor water cleanup system inlet temperature.

#### **5.6.2.2 RPV Water Level**

The number of RPV water level indications is sufficient to provide the operator with information to determine the adequacy of the coolant inventory to cool the fuel. In addition, by verifying that RPV water level is not rising to an abnormally high level, the operator is assured that turbines are not endangered by the possibility of water carried into the steam lines.

#### **5.6.2.3 RPV Coolant Flowrates and Differential Pressures**

Flow instruments, differential pressure instruments, and recorders are provided so that the core coolant flowrates and the hydraulic performance of RPV internals can be determined.

**5.6.2.4 RPV Internal Pressure**

Pressure switches, indicators, and transmitters detect RPV internal pressure from the same instrument lines used for measuring RPV water level.

**5.6.2.5 RPV Top Head Flange Leak Detection**

A connection is provided on the RPV flange into the annulus between the two metallic seal rings used to seal the RPV and top head flanges. This connection permits detection of leakage past the inner seal ring and is described further in subsection 5.2.7.

**SUPPLEMENT 5A**

**SUMMARY TECHNICAL REPORT OF  
REACTOR VESSEL OVERPRESSURE PROTECTION (HNP-1 AND HNP-2)**

*This section describes the initial analysis for the Edwin I. Hatch Nuclear Plants HNP-1 and HNP-2. Subsequent analyses for reloads are given in table 15.1-1.*

*This report provides sufficient information and documentation to show compliance with all requirements of Article 9 of American Society of Mechanical Engineers (ASME) Pressure Vessel Code - Section III, 1968, Nuclear Vessels in the Area of the Vessel Overpressure Protection Design of the Nuclear Pressure Vessel. Included is the design basis for sizing of the dual purpose, combination safety relief valves, the overpressure protection analysis, and the analysis of the safety relief valve system availability. The effects on the vessel pressure transients of valve capacity are also shown.*

**5A.1 INTRODUCTION**

*The vessel overpressure protection system is designed to satisfy the requirements of Section III, Nuclear Vessels, of the ASME Boiler and Pressure Vessel Code. The general requirements for protection against overpressure as given in Article 9 of Section III of the ASME Code recognize that reactor vessel overpressure protection is one function of the reactor protection systems and allows the integration of pressure relief devices with the protection systems of the nuclear reactor. Hence, credit is taken for the scram protection system as a complimentary pressure protection device. The General Electric Company, however, provides analyses which take credit only for reactor protection signals which are indirectly derived. The Nuclear Regulatory Commission (NRC) has also adopted the ASME Codes as part of their requirements in the Code of Federal Regulations (10 CFR 50.55a).*

**5A.2 DESIGN BASIS**

**5A.2.1 SAFETY RELIEF VALVE SIZING**

*The safety relief valve capacity of HNP-1 and HNP-2 is sized to limit the primary system pressure, including transients, to the requirements of the ASME Boiler and Pressure Vessel Code, Section III, Nuclear Vessels. The essential ASME requirements, which are all met by this analysis, are stated in the following paragraphs.*

- A. It is recognized that the protection of vessels in a nuclear power plant is dependent upon many protective systems to relieve or terminate pressure transients. Installation of pressure relieving devices may not independently provide complete protection.*
- B. The safety relief valve sizing evaluation assumes credit for operation of the scram protective system which may be tripped by any one of three sources, i.e., a direct, flux, or pressure signal. The direct scram signal is derived from position switches mounted on the*

main steam isolation valves (MSIVs) or the turbine stop valves or from pressure switches mounted on the dump valve of the turbine control valve (TCV) hydraulic actuation system. The position switches are actuated when the respective valves are closing and following 10% travel of full stroke. The pressure switches are actuated when a fast closure of the control valves is initiated. However, according to General Electric policy, the safety valve sizing evaluation does not assume credit for direct scram, only for the indirect high neutron flux scram. Further, no credit is taken for power-operated pressure relieving devices. Credit is taken for the dual purpose safety relief valves in their ASME Code qualified mode of safety operation.

- C. *The rated capacity of the pressure relieving devices is sufficient to prevent a rise in pressure within the protected vessel of more than 110% of the design pressure ( $1.10 \times 1250$  psig = 1375 psig). Full account is taken of the pressure drop on both the inlet and discharge sides of the valves. All combination safety relief valves discharge into the suppression pool through a discharge pipe from each valve which is designed to achieve sonic flow conditions through the valve, thus providing flow independence to discharge piping losses.*
- D. *The nominal pressure setting of at least one safety relief valve connected to any vessel or system cannot be greater than a pressure at the safety relief valves corresponding to the design pressure (1250 psig) anywhere in the protected vessel.*
- E. *Valves which are additional to the one(s) set at or below design pressure may be set higher, but in no case do any of these settings exceed a pressure at the safety relief valves corresponding to 105% of the design pressure anywhere in the vessel ( $1.05 \times 1250$  psig = 1312.5 psig).*

### 5A.2.2 AVAILABILITY INDEX

Overpressure protection with valve failure conditions is investigated by the General Electric Company. Valve failure combinations are evaluated with respect to pressure margin criteria which meet the ASME Code requirements. An availability index is derived which expresses the probability that the number of valves which meets the pressure margin criterion will be operational at any future instant of time. This index is a function of:

- *Total number of valves in the system.*
- *Minimum number of valves which satisfies the pressure margin criterion for a MSIV flux scram transient.*
- *Failure rate of the valves.*
- *Testing interval.*

Current General Electric policy has set an availability index ( $I_A$ ) goal for the overpressure protection system  $\geq 0.99999$ .

**5A.3 METHOD OF ANALYSIS**

To design the pressure protection for the nuclear boiler system, extensive analytical models representing all essential dynamic characteristics of the system are simulated on a large digital computing facility. These models include:

- Hydrodynamics of the flow loop.
- Reactor kinetics.
- Thermal characteristics of the fuel and its transfer of heat to the coolant.
- All the principal controller features, such as feedwater flow recirculation flow, reactor water level, pressure, and load demand. (These are represented with all their principal nonlinear features in models that have evolved through extensive experience and favorable comparison of analysis with actual boiling water reactor (BWR) test data.)

A detailed description of this model is documented in licensing topical report NEDO-10802, "Analytical Methods of Plant Transient Evaluations for the GE-BWR," R. B. Linford. Included within this model are components of the reactor vessel pressure protection system, which is the subject of this report. Dual safety relief valves are simulated in the nonlinear representation, and the model thereby allows full investigation of the various valve response times, valve capacities, and actuation setpoints that are available in applicable hardware systems.

Typical capacity characteristics as modeled are represented in figure 5A-1 for the safety relief valves. The associated bypass, TCV, and MSIV characteristics are also represented in the model.

**5A.4 SYSTEM DESIGN**

A parametric study was conducted to determine the required steam flow capacity of the safety relief valves, which satisfies the ASME Code requirements and the availability index goals. This study was based on the following assumptions.

**5A.4.1 OPERATING CONDITIONS**

The following conditions are the most severe because the maximum stored energy exists at these conditions. At lower power conditions, the transients would be less severe.

|                                     | <u>HNP-1</u>        | <u>HNP-2</u>                           |
|-------------------------------------|---------------------|----------------------------------------|
| Operating power (MWt)               | 2537 (design power) | 2533 (104% of reactor warranted power) |
| Vessel dome pressure (psig)         | 1020                | 1020                                   |
| Steam flow (x 10 <sup>6</sup> lb/h) | 10.5                | 10.96                                  |

**5A.4.2 TRANSIENTS**

The overpressure protection system must accommodate the most severe pressurization transient. The evaluation of transient behavior with final plant configuration has shown that the isolation valve closure is slightly more severe when credit is taken only for indirect derived scrams; therefore, it is used as the overpressure protection basis event.

**5A.4.3 SCRAM**

- Direct reactor scram - failed.
- SCRAM reactivity curve - figure 5A-2 (design basis).
- Control rod drive scram motion - figure 5A-2.

**5A.4.4 SAFETY RELIEF VALVE TRANSIENT ANALYSIS SPECIFICATIONS**

|                          | <u>HNP-1</u>              | <u>HNP-2</u>     |
|--------------------------|---------------------------|------------------|
| Valve groups             | One                       | Three            |
| Pressure setpoint (psig) | 1100 (+ 1% assumed error) | 1101, 1111, 1121 |
| Delay time (s)           | 0.40                      | 0.40             |
| Stroke time (s)          | 0.10                      | 0.10             |

**5A.4.5 SAFETY RELIEF VALVE SIZING**

Sizing of the safety relief valve capacity is based on establishing an adequate margin from the peak vessel pressure to the vessel code limit (1375 psig) in response to a specified transient. General Electric design practice and ASME Code requirements are satisfied with the closure of all MSIVs with scram tripped by a high neutron flux signal as the reference transient. The minimum capacity determined according to the specified criteria is translated into a discrete valve requirement and compared with the total number of valves required to meet the availability index criterion.

The safety relief valve capacity required to provide overpressure protection at all levels of indirect scram is derived from an evaluation of the MSIV pressure scram transient.

**5A.4.6 AVAILABILITY INDEX (I<sub>A</sub>)**

The availability index considers both the minimum number of valves determined from the safety relief valve sizing criteria and the total number of operational valves provided for the plant.

The total number of valves provided for the plant is established from the number of valves required to satisfy the availability index criterion.

**5A.5 EVALUATION OF RESULTS**

**5A.5.1 SAFETY RELIEF VALVE SIZING**

The parametric relationship between peak vessel (bottom) pressure and safety relief valve capacity for the MSIV transient with high flux, high pressure, and MSIV position scram is described in figure 5A-3. The safety relief valve sizing requirement, based on MSIV flux scram, is eight valves for HNP-1 and seven valves for HNP-2.

The time response of HNP-1 and HNP-2 vessel pressure to the MSIV transient with both flux and pressure scrams for 11 valves is illustrated in figure 5A-4. The time response of HNP-2 vessel pressure to the MSIV transient with flux scram for 7 valves is also illustrated in figure 5A-4.

**5A.5.2 AVAILABILITY INDEX (I<sub>A</sub>)**

The availability index is based upon the number of safety relief valves required to provide an acceptable margin to the vessel code limit (1375 psig) for the MSIV flux scram transient. The data employed in the derivation of the availability index are outlined as follows:

|                                                                              | <u>HNP-1</u> | <u>HNP-2</u> |
|------------------------------------------------------------------------------|--------------|--------------|
| Safety relief valves (total installed)                                       | 11           | 11           |
| Safety relief valves (MSIV flux scram)                                       | 8            | 7            |
| Valve failure rate <sup>(a)</sup> (failures/10 <sup>6</sup> operating hours) | 1.1          | 1.1          |
| Testing interval (years)                                                     | < 1.666      | ≤ 2.2        |
| Availability index                                                           | > 0.999999   | > 0.999999   |

a. The downtime, or period that the valve would be unavailable for service if it failed, was determined to be dominated by the period between testing. The effects of these differences in downtimes are included in the availability index calculations.



**5A.6 SAFETY RELIEF VALVE CHARACTERISTICS**

**5A.6.1 SCHEMATIC ARRANGEMENT**

The schematic arrangement of the safety relief valves is shown in figures 5A-5 and 5A-6.

**5A.6.2 PRESSURE DROP IN INLET AND DISCHARGE**

Pressure drop on the piping from the reactor vessel to the valves is taken into account in calculating the maximum vessel pressures reported above.

Pressure drop with ASME-rated flow in the discharge piping to the suppression pool is limited by proper discharge line sizing to prevent back pressure on each safety relief valve from exceeding 40% of the valve inlet pressure, thus ensuring choked flow in the valve orifice and no reduction of valve capacity due to the discharge piping. Each safety relief valve has its own separate discharge line.

**5A.6.3 SAFETY RELIEF VALVE DESCRIPTION**

The safety relief valves, which were manufactured by Target Rock to ASME Code Section III, 1968 with Winter 1968 Addenda, comply with ASME Code Section III, Paragraph N911.4(a)(1), for pilot-operated valves. Quantities and setpoints are as follows:


| <u>Quality</u> | <u>Setpoint (psig)<sup>(a)</sup></u> |              | <u>ASME Rated Capacity at 103% of Set Pressure (lb/h minimum)</u> |              |
|----------------|--------------------------------------|--------------|-------------------------------------------------------------------|--------------|
|                | <u>HNP-1</u>                         | <u>HNP-2</u> | <u>HNP-1</u>                                                      | <u>HNP-2</u> |
| 4              | 1080                                 | 1090         | 788,400                                                           | 869,000      |
| 4              | 1090                                 | 1100         | 794,400                                                           | 876,800      |
| 3              | 1100                                 | 1110         | 803,400                                                           | 884,700      |

a. This column reflects the nominal safety relief valve set pressure used in the original overpressure analysis. Current setpoints are listed in HNP-1 table 4.4-1 and HNP-2 table 5.2-4.

**5A.7 CONCLUSION**

*Safety requirements have long demanded very high reliability in the reactor functions. Recognition of this reliability as being completely adequate justification for these functions to contribute to vessel pressure protection is reflected in the Section III ASME Code provisions. Actual General Electric design practice very conservatively applies the code provisions which result in margins even beyond those necessary to satisfy code limits which further enhance the reliability of vessel pressure protection.*

*This design basis for sizing safety relief valves with indirect credit is technically sound and a most realistic approach. It is allowed under Section III of the ASME Boiler and Pressure Vessel Code which has been adopted by the General Electric Company in the design of HNP-1 and HNP-2 BWRs.*



ACAD 25A01


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

TYPICAL DUAL SAFETY RELIEF VALVE  
CAPACITY CHARACTERISTICS

FIGURE 5A-1



ACAD 15A021


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1

SCRAM ROD DRIVE AND SCRAM REACTIVITY VS TIME

FIGURE 5A-2 (SHEET 1 OF 2)



ACAD 25A022


HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

SCRAM ROD DRIVE AND SCRAM REACTIVITY VS TIME

FIGURE 5A-2 (SHEET 2 OF 2)



*HISTORICAL*  
**REV 19 7/01**


ACAD 15A031



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 1

PEAK VESSEL BOTTOM PRESSURE VS  
 SAFETY RELIEF VALVE CAPACITY

FIGURE 5A-3 (SHEET 1 OF 2)



*HISTORICAL*  
**REV 19 7/01**


ACAD 25A032



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

PEAK VESSEL BOTTOM PRESSURE VS  
 SAFETY RELIEF VALVE CAPACITY

FIGURE 5A-3 (SHEET 2 OF 2)



ACAD 15A041

HISTORICAL  
REV 19 7/01




SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 1

TIME RESPONSE OF MSIV TRANSIENTS

FIGURE 5A-4 (SHEET 1 OF 2)





TIME (s)  
*HISTORICAL*  
 REV 19 7/01


ACAD 25A042



SOUTHERN NUCLEAR OPERATING COMPANY  
 EDWIN I. HATCH NUCLEAR PLANT  
 UNIT 2

TIME RESPONSE OF MSIV TRANSIENTS

FIGURE 5A-4 (SHEET 2 OF 2)



ACAD 25A05


*HISTORICAL*  
REV 19 7/01



**SOUTHERN NUCLEAR OPERATING COMPANY**  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

SCHEMATIC ELEVATION

FIGURE 5A-5



ACAD 25A06

HISTORICAL  
REV 19 7/01



SOUTHERN NUCLEAR OPERATING COMPANY  
EDWIN I. HATCH NUCLEAR PLANT  
UNIT 2

SCHEMATIC PLAN

FIGURE 5A-6