

PMSTPCOL PEmails

From: Hilsmeier, Todd
Sent: Tuesday, November 15, 2011 4:37 PM
To: Eudy, Michael
Cc: Foster, Rocky; Hilsmeier, Todd; STPCOL
Subject: RE: COM 17.4-1, FSAR Section 17.4S

Hello Mike,

I am ok with STP's proposed wording to close the commitment. NRC inspections during the detailed design and construction phases of the plants would provide ongoing confidence that the D-RAP activities (including maintaining, revising, and updating the D-RAP list as needed) are effective and consistent with the RAP description in the STP FSAR. Such NRC inspections would include inspection of the D-RAP ITAAC, inspection of the initial maintenance rule program, the inspection of the plant-specific PRA under 10 CFR 50.71(h)(1), or the inspection of the quality assurance program.

Thanks,
Todd Hilsmeier

From: Eudy, Michael
Sent: Tuesday, November 15, 2011 1:02 PM
To: Hilsmeier, Todd
Cc: Foster, Rocky
Subject: RE: COM 17.4-1, FSAR Section 17.4S

Hey Todd,

Checking back in if we can let STP know they can move forward with how they want to revise Rev 7 accordingly. Thanks.

Mike

From: Hilsmeier, Todd
Sent: Tuesday, November 08, 2011 11:07 AM
To: Eudy, Michael; Foster, Rocky
Cc: Hilsmeier, Todd
Subject: RE: COM 17.4-1, FSAR Section 17.4S

Hello Mike,

I found acceptable STP's proposal to reword the FSAR to close the commitment. I will write a more formal response of this conclusion later this week. I do not have a need to discuss STP's proposal during Wednesday's call. Therefore, please remove this item from the telcom agenda, unless STP has something to discuss.

Thanks,
Todd

From: Eudy, Michael
Sent: Tuesday, November 08, 2011 10:25 AM

To: Hilsmeier, Todd
Subject: RE: COM 17.4-1, FSAR Section 17.4S

No problem, thanks for the update.

From: Hilsmeier, Todd
Sent: Tuesday, November 08, 2011 9:13 AM
To: Eudy, Michael
Subject: RE: COM 17.4-1, FSAR Section 17.4S

Hello Mike,

I was out of the office yesterday. I will let you know by cob today if we need to discuss with STP for the call this Wednesday.

Thanks,
Todd

From: Eudy, Michael
Sent: Monday, November 07, 2011 10:50 AM
To: Hilsmeier, Todd
Cc: Foster, Rocky
Subject: RE: COM 17.4-1, FSAR Section 17.4S

Hi Todd,

Can you let us know by c.o.b. today if you need to discuss with STP for the call this Wed ?
Thanks !

Mike

From: Hilsmeier, Todd
Sent: Wednesday, November 02, 2011 10:20 AM
To: Eudy, Michael
Subject: RE: COM 17.4-1, FSAR Section 17.4S

Thanks Mike, I'll give it a look.

Todd

From: Eudy, Michael
Sent: Wednesday, November 02, 2011 9:49 AM
To: Hilsmeier, Todd
Cc: STPCOL; Foster, Rocky
Subject: FW: COM 17.4-1, FSAR Section 17.4S

Todd,

Here is the STP proposal to reword the FSAR to close the commitment. Please let me know what you think. We can discuss with them next week if you still feel the need. If not, you could track it as a CI for rev 7.

Let me know, thanks.

From: Chappell, Coley [<mailto:ccchappell@STPEGS.COM>]
Sent: Tuesday, November 01, 2011 5:26 PM
To: Eudy, Michael
Subject: COM 17.4-1, FSAR Section 17.4S

Mike,

The following is provided to support the discussion on COM 17.4-1 during the Open Items call.

As presented to ACRS ABWR Subcommittee on June 21, 2011, NINA has completed the required actions to satisfy commitment COM 17.4-1 described in FSAR Subsection 17.4S.1. To show that this commitment is completed, the last paragraph in Subsection 17.4S.1 will be deleted in its entirety.

This change will be submitted in the next revision to the COLA, Revision 7, and will be identified in the Summary of Commitments attachment to the cover letter submitting COLA Revision 7, with a Note to clarify the commitment status as Completed, similar to the example shown below:

COLA Section (Commitment Number)	Commitment Summary	Milestone	Commitment Type
Part 2			
Section 17.4S (COM 17.4-1)	The expert panel will complete all of the expert panel system reviews, provide a list of the set of D-RAP SSCs, and have the program elements in place to control future activities.	Third quarter of 2011	Completed (See Note)

Note: The results of the expert panel system reviews, completed using the method described in FSAR Subsection 17.4S.1.4, are used to designate, at the system level, the site specific SSCs which have been determined to be risk significant and within the scope of the D-RAP process, and supplement the initial list included in Appendix 19K. In general, the categorization of a system is determined by the highest categorized system function, and the same categorization is given to all components in the system. The expert panel may further refine the system level categorizations at the component level, by categorizing components based on the supported system functions and identifying critical attributes for components determined to be safety/risk significant, using the method described in Subsection 17.4S.1.4.

Regards,

Coley Chappell
NINA Licensing STP 3&4

Hearing Identifier: SouthTexas34Public_EX
Email Number: 3141

Mail Envelope Properties (CC56DD79EC73A545B9890C3C629E307DABEADF4AED)

Subject: RE: COM 17.4-1, FSAR Section 17.4S
Sent Date: 11/15/2011 4:36:45 PM
Received Date: 11/15/2011 4:36:47 PM
From: Hilsmeier, Todd

Created By: Todd.Hilsmeier@nrc.gov

Recipients:

"Foster, Rocky" <Rocky.Foster@nrc.gov>
Tracking Status: None
"Hilsmeier, Todd" <Todd.Hilsmeier@nrc.gov>
Tracking Status: None
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"Eudy, Michael" <Michael.Eudy@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	5105	11/15/2011 4:36:47 PM

Options

Priority: Standard
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received: