Σ.	<u>f</u>				
)	1			<u>VRETS I</u>	MASTER FILE
•	REGULATURY	INFORMATION	DISTRIBU	TION SYSTEM (RID	SC CC - END
					EFF -07B
ACCESSION NBR:	8503140456	DUC.DATE:	84/12/31	NOTARIZED: NO	DOCKET #
FACIL:50-263	Monticello N	uclear Gener	ating Pla	nt, Northern Sta	tes 05000263
AUTH, NAME	AUTHOR	AFFILIATION			
FEY,F.L.	Northern	States Powe	r Co.		
RECIP.NAME	RECIPIE	NT AFFILIATI	ON		
SUBJECT: "Eff	luent & Wast	e Disposal S	emi-Annua	1 Rept for Jul-D	ec
1984	." W/850301	tr.	•		-
					51
DISTRIBUTION	CODE: IE25L	COPIES RECE	IVED:LTR	_ ENCL _ SIZE	
TITLE: Period	ic Environ M	nitoring Re	pt (50 DK	TJ-Annual/Semian	nual/Effluent/

05000263

NOTES:

0L:09/08/70

RECIPIENT COPIES RECIPIENT COPIES ID CODE/NAME LTTR ENCL ID CODE/NAME LTTR ENCL NRR ORB2 BC 04 7 7 INTERNAL: ACRS AEOD 11 1 1 1 1 1E FILE NRR/DE/EEB 08 1 01 1 1 1 NRR/DL/ORAB NRR/DSI/METB 2 09 2 1 1 NRR7DSI/RAB RM7DUAMI/MIB RGN2/DRSS/EPRPB 10 1 1 1 1 1 1 EXTERNAL: LPDR NRC PDR Ο2 03 1 1 1 1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 19

TRANSMITTAL MANIFEST

NORTHERN STATES POWER COMPANY

NUCLEAR GENERATION DEPARTMENT

MONTICELLO NUCLEAR GENERATING PLANT

Effluent and Waste Disposal Semi-Annual Report for July 1, 1984 through December 31, 1984

Manifest Date: March 1, 1985

USNRC

0 SINC
Regional Admin-III DCD
Resident Inspector
NRR Project Manager
R J Jensen
L R Eliason
G T Goering/G H Neils
M B Sellman
G Charnoff
D C Lowens
B W Clark
ERAD Dept.
Attn: Records Clerk
MDH
Attn: Commissioner of Health
MPCA
Attn: J W Ferman
Monticello Plant Manager
Prairie Island Plant
(E L Watzl)
Media Services Dept.
L H Waldinger
NSS File
NG File

General Electric San Jose Cust. Serv		2
San Jose-Fuel Proj. J N Sorensen (NUS)	Mgr	1
Safety Audit Committee D M Musolf K J Albrecht M H Clarity H S Isbin D D Lanning T M Parker W A Shamla J A Thie F P Tierney	- -	9
SAC File	(Manifest	: Only)



BWC020685GDW01

Period: Jul - Dec 1984 License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Supplemental Information

1. Regulatory Limits - Quarterly levels requiring reporting to Nuclear Regulatory Commission

A. Noble Gases:

-

5 mrad/quarter gamma radiation 10 mrad/quarter beta radiation

B. Long Lived Iodines, Particulates, and Tritium:

7.5 mrem/quarter to any organ

C. Liquid Effluents:

1.5 mrem/quarter dose to the total body 5.0 mrem/quarter dose to any organ

2. Maximum Permissible Concentrations:

- A. Noble Gases: 10 CFR Part 20, Appendix B, Table II, Column 1
- B. Long Lived Iodines, Particulates, and Tritium: 10 CFR Part 20, Appendix B, Table II, Column 1
- C. Liquid Effluents: 10 CFR Part 20, Appendix B, Table II, Column 2 2 E-04 uci/ml for dissolved and entrained gases

3. Average Energy:

(Not Applicable)

Period: Jul - Dec 1984 License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Supplemental Information (continued)

4. Measurements and Approximations of Total Radioactivity:

A. Noble Gases:

11

Continuous gross activity monitors in Reactor Building Vent and plant stack exhaust streams. Weekly isotopic analysis of steam jet air ejector stream. Monthly analysis of storage tank contents.

- B. Iodines in Gaseous Effluent: Continuous monitoring with charcoal cartridges in Reactor Building vent and plant stack exhaust streams with weekly analysis.
- C. Particulates in Gaseous Effluent: Continuous monitoring with particulate filters in Reactor Building vent and plant stack exhaust streams with weekly analysis.
- D. Tritium in Gaseous Effluent: Continuous monitoring with silica gel cartridges in Reactor Building vent and plant stack exhaust streams with biweekly analysis.
- E. Liquid Effluents: Tank sample analyzed prior to each planned release and continuous monitoring of gross activity during planned release.
- 5. Batch Releases:

1. Number of Releases

2. Total Activity Released

		•		
	A.	Liquid:	•	
		1. Number of Batch Releases	0	
		2. Total Time Period For Batch Releases	0.0	Min
		3. Maximum Time Period for a Batch Release	0 0	Min
		4. Average Time Period for a Batch Release	0.0	Min
		5. Minimum Time Period for a Batch Release	0.0	Min
		6. Average River Flow During Releases	0.0	Cf/sec
• .	в.	Gaseous:	•	
		1. Number of Batch Releases	0	
		2. Total Time Period for Batch Releases	NA	Min
		3. Maximum Time Period for a Batch Release	NA	Min
		4. Average Time Period for a Batch Release	NA .	Min
		5. Minimum Time Period for a Batch Release	NA	Min
6.	Ab	normal Releases:		
-	A.	Liquid:	_	
		1. Number of Releases	0	
		2. Total Activity Released	0.0	Ci
	В.	Gaseous:		

0.0

Ci

Period: Jul - Dec 1984 License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 1A Gaseous Effluents - Summation of all Releases

			Units	1st Qtr	2nd 2tr	Pcnt Est Error
	•			 		
Α.	Хор	le Gases:				
	1.	Total Release:				
		A. Elevated Release	Ci		7.95E+00	
		B. Building Vent Release	Ci	7.49E+01	8.68E+01	5 000.01
		C. Total	Ci	8.29E+01	9.47E+01	5.002+01
	2.	Average Release Rate:	• .			
		A. Elevated Release	uCi/sec	1.00E+00	1.00E+00	
		B. Building Vent Release	uCi/sec	9.43E+00	1.09E+01	
		C. Total	uCi/sec	1.04E+01	1.19E+01	5.00E+01
	3	Percent Tech Spec 2trly Reporting			1	
	۷.	Level				
		Gamma Radiation		2.1	1.94	
		Beta Radiation		1.37		
•						
в.	Iod	lines:				•
	1.	Total I-131:				
		A. Elevated Release	Ci	0.0	0.0	
		B. Building Vent Release	Ci	0.0	0.0	
		C. Total	Ċi	0.0	0.0	5.00E+01
	2	Average I-131 Release Rate:				́
		A. Elevated Release	uCi/sec	0.0	0.0	
		B. Building Vent Release	uCi/sec	0.0	0.0	-
		C. Total	uCi/sec		0.0	5.00E+01
C.		ng Lived Particulates and Gross Al	pha Relea	ses:		
	1.	Total Particulates:				
		A. Elevated Release	Ci		3.11E-05	
		B. Building Vent Release	Ci		8 1.87E-03	
		C. Total	Ci	3.40E-03	3 1.90E-03	5.00E+01
	2	Average Release Rate:				
-		A. Elevated Release	uCi/sec	1.80E-05	5 3.92E-06	
		B. Building Vent Release	uCi/sec	4.09E-04	+ 2.36E-04	ŧ ¹
		C. Total	uCi/sec		+ 2.40E-04	+ 5.00E+01
		· · · · · · · · · · · · · · · · · · ·				

-

2 **3**

Page 4

MONTICELLO NUCLEAR GENERATING PLANT NORTHERN STATES POWER COMPANY

Period: Jul - Dec 1984 License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 1A Gaseous Effluents - Summation of All Releases (Continued)

		Units	1st Qtr	2nd Qtr	Pont Est Error
	3. Gross Alpha Radioactivity:				
	A. Elevated Release	Ci		4.71E-07	
	B. Building Vent Release	Ci	4.38E-05		
	C. Total	Ci	4.49E-05	3.27E-05	1.00E+02
D.	Tritium: 1. Total Release:				
	A. Elevated Release	Ci	2.52E-01	1.06E-01	
	B. Building Vent Release	Ci		3.74E+00	·
	C. Total	CI		3.85E+00	5.00E+01
				• .	
	2. Average Release Rate:		3.17E-02	1 345-02	
	A. Elevated Release	uCi/sec		4.70E-01	
	B. Building Vent Release	uCi/sec			5.00E+01
	C. Total	uCi/sec	1.01E+00	4.842-01	. 3. VULTVI

E. Percent Tech Spec 2trly Reporting Level for Long Lived Iodines, Patriculates, and Tritium

3 J

0.06 0.03

MONTICELLO NUCLEAR GENERATING PLANT Northern states power company

.

Period: Jul - Dec 1984 License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 1B Gaseous Effluents - Elevated Release

Nuclides Released Units 1st Qtr 2nd Qtr 1st Qtr 2nd Qt	•	••	Continuous Mode		Batch Mode 1st Qtr 2nd 9	
Xe133 Ci 0.0 0.0 0.0 0.0 Xe135 Ci 0.0 0.0 0.0 0.0 Kr85M Ci 0.0 0.0 0.0 0.0 Kr85M Ci 0.0 0.0 0.0 0.0 Kr87 Ci 0.0 0.0 0.0 0.0 Kr89 Ci 0.0 0.0 0.0 0.0 Kr89 Ci 0.0 0.0 0.0 0.0 Kr89 Ci 0.0 0.0 0.0 0.0 Ke137 Ci 0.0 0.0 0.0 0.0 Kr83M Ci 0.0 0.0 0.0 0.0 Ke133M Ci 0.0 0.0 0.0 0.0 Ke131M Ci 2.43E-05 0.0 0.0 0.0	Nuclides Released	Units	IST QTI	2nd yti		
Xe133 Ci 0.0 0.0 0.0 0.0 Xe135 Ci 0.0 0.0 0.0 0.0 Kr85M Ci 0.0 0.0 0.0 0.0 Kr88 Ci 0.0 0.0 0.0 0.0 Kr88 Ci 0.0 0.0 0.0 0.0 Kr87 Ci 0.0 0.0 0.0 0.0 Xe138 Ci 0.0 0.0 0.0 0.0 Kr87 Ci 0.0 0.0 0.0 0.0 Kr87 Ci 0.0 0.0 0.0 0.0 Kr87 Ci 0.0 0.0 0.0 0.0 Kr89 Ci 0.0 0.0 0.0 0.0 Kr89 Ci 0.0 0.0 0.0 0.0 Xe137M Ci 0.0 0.0 0.0 0.0 Kr83M Ci 0.0 0.0 0.0 0.0 Xe133M Ci 0.0 0.0 0.0 0.0 Xe131M	1. Noble Gases:					·
Xe 135 Ci 0.0 0.0 0.0 0.0 Kr 85M Ci 0.0 0.0 0.0 0.0 Kr 88 Ci 0.0 0.0 0.0 0.0 Kr 87 Ci 0.0 0.0 0.0 0.0 Kr 90 Ci 0.0 0.0 0.0 0.0 Kr 90 Ci 0.0 0.0 0.0 0.0 Kr 89 Ci 0.0 0.0 0.0 0.0 Ke 137 Ci 0.0 0.0 0.0 0.0 Kr 83M Ci 0.0 0.0 0.0 0.0 Ke 133M Ci 0.0 0.0 0.0 0.0 Xe 131M Ci 2.43E-05 0.0 0.0 0.0 0.0	Xe 133	Ci	0.0	0.0	• • •	
Kr85M Ci 0.0 0.0 0.0 0.0 Kr88 Ci 0.0 0.0 0.0 0.0 Kr87 Ci 0.0 0.0 0.0 0.0 Kr89 Ci 0.0 0.0 0.0 0.0 Kr83M Ci 0.0 0.0 0.0 0.0 Kr83M Ci 0.0 0.0 0.0 0.0 Xe133M Ci 0.0 0.0 0.0 0.0 Xe131M Ci 2.43E-05 0.0 0.0 0.0		Ci	0.0	0.0		
Kr88 Ci 0.0 0.0 0.0 0.0 Kr87 Ci 0.0 0.0 0.0 0.0 Xe138 Ci 0.0 0.0 0.0 0.0 Kr87 Ci 0.0 0.0 0.0 0.0 Kr87 Ci 0.0 0.0 0.0 0.0 Kr90 Ci 0.0 0.0 0.0 0.0 Xe139 Ci 0.0 0.0 0.0 0.0 Kr89 Ci 0.0 0.0 0.0 0.0 Xe137 Ci 0.0 0.0 0.0 0.0 Xe135M Ci 0.0 0.0 0.0 0.0 Kr83M Ci 0.0 0.0 0.0 0.0 Xe133M Ci 0.0 0.0 0.0 0.0 Xe131M Ci 2.43E-05 0.0 0.0 0.0		Ci	0.0	0.0	-	
Kr87 Ci 0.0 0.0 0.0 0.0 Xe138 Ci 0.0 0.0 0.0 0.0 Kr90 Ci 0.0 0.0 0.0 0.0 Xe139 Ci 0.0 0.0 0.0 0.0 Kr89 Ci 0.0 0.0 0.0 0.0 Xe137 Ci 0.0 0.0 0.0 0.0 Xe135M Ci 0.0 0.0 0.0 0.0 Xe135M Ci 0.0 0.0 0.0 0.0 Xe133M Ci 0.0 0.0 0.0 0.0 Xe133M Ci 0.0 0.0 0.0 0.0 Xe131M Ci 2.43E-05 0.0 0.0 0.0		Ci	0.0	0.0		
Xe138 Ci 0.0 0.0 0.0 0.0 Kr90 Ci 0.0 0.0 0.0 0.0 Xe139 Ci 0.0 0.0 0.0 0.0 Kr89 Ci 0.0 0.0 0.0 0.0 Xe137 Ci 0.0 0.0 0.0 0.0 Xe137 Ci 0.0 0.0 0.0 0.0 Xe135M Ci 0.0 0.0 0.0 0.0 Kr83M Ci 0.0 0.0 0.0 0.0 Xe133M Ci 0.0 0.0 0.0 0.0 Xe131M Ci 2.43E-05 0.0 0.0 0.0		Ci	0.0	0.0		
Kr90 Ci 0.0 0.0 0.0 0.0 Xe139 Ci 0.0 0.0 0.0 0.0 Kr89 Ci 0.0 0.0 0.0 0.0 Xe137 Ci 0.0 0.0 0.0 0.0 Xe137 Ci 0.0 0.0 0.0 0.0 Xe135M Ci 0.0 0.0 0.0 0.0 Kr83M Ci 0.0 0.0 0.0 0.0 Xe133M Ci 0.0 0.0 0.0 0.0 Xe131M Ci 2.43E-05 0.0 0.0 0.0		Ci	0.0	0.0		
Xe139 Ci 0.0 0.0 0.0 0.0 Kr89 Ci 0.0 0.0 0.0 0.0 Xe137 Ci 0.0 0.0 0.0 0.0 Xe135M Ci 0.0 0.0 0.0 0.0 Xe135M Ci 0.0 0.0 0.0 0.0 Kr83M Ci 0.0 0.0 0.0 0.0 Xe133M Ci 0.0 0.0 0.0 0.0 Xe131M Ci 2.43E-05 0.0 0.0 0.0		Ci	0.0	0.0		
Kr89 Ci 0.0 0.0 0.0 0.0 Xe137 Ci 0.0 0.0 0.0 0.0 Xe137 Ci 0.0 0.0 0.0 0.0 Xe135M Ci 0.0 0.0 0.0 0.0 Kr83M Ci 0.0 0.0 0.0 0.0 Xe133M Ci 0.0 0.0 0.0 0.0 Xe131M Ci 2.43E-05 0.0 0.0 0.0		Ci	0.0	0.0		
Xe137 Ci 0.0 0.0 0.0 0.0 Xe135M Ci 0.0 0.0 0.0 0.0 Kr83M Ci 0.0 0.0 0.0 0.0 Xe133M Ci 0.0 0.0 0.0 0.0 Xe131M Ci 2.43E-05 0.0 0.0 0.0			0.0	0.0		•
Xe135M Ci 0.0 0.0 0.0 0.0 Kr83M Ci 0.0 0.0 0.0 0.0 0.0 Kr83M Ci 0.0 0.0 0.0 0.0 0.0 0.0 Xe133M Ci 0.0 0.0 0.0 0.0 0.0 0.0 Xe131M Ci 2.43E-05 0.0 0.0 0.0 0.0		Ci	0.0	0.0		
Kr83M Ci 0.0 0.0 0.0 0.0 Kr83M Ci 0.0 0.0 0.0 0.0 0.0 Xe133M Ci 2.43E-05 0.0 0.0 0.0 0.0 Xe131M Ci 2.43E-05 0.0 0.0 0.0			0.0	0.0	0.0	
Xe133M Ci 0.0 0.0 0.0 0.0 Xe133M Ci 2.43E-05 0.0 0.0 0.0 Xe131M Ci 2.43E-05 0.0 0.0 0.0			0.0	0.0	0.0	
Xe131M Ci 2.43E-05 0.0 0.0 0.0 0.0				0.0	0.0	0.0
			2.43E-05	0.0	0.0	0.0
			7.95E+00	7.95E+00	0.0	0.0
Total for Period Ci 7.95E+00 7.95E+00 0.0 0.0	Total for Period	Ci	7.952+00	7.95E+00	0.0	0.0
2. Iodines:	2. Iodines:	<i>4</i>				
I-131 Ci 0.0 0.0 0.0 0.0	T-131	Ci	0.0	0.0	0.0	
T-133 Ci 0.0 0.0 0.0 0.0			0.0	0.0	0.0	
I-135 Ci 0.0 0.0 0.0 0.0				0.0	0.0	0.0
				•	,	
Total Ci 0.0 0.0 0.0 0.0	Total	Ci	0.0	0.0	0.0	0.0

Page 6

MONTICELLO NUCLEAR GENERATING PLANT NORTHERN STATES POWER COMPANY

44

Period: Jul - Dec 1984 License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 1B Gaseous Effluents - Elevated Release (Continued)

Nuclides Released	Units	Continuo 1st Qtr	us Mode 2nd 2tr	Batch 1st Qt	
•					
3. Particulates:					
Cs137	Ci	1.64E-05	4.96E-06	0.0	0.0
SIG	Ci	1.79E-07	1.40E-07	0. 0	0.0
Sz89	Ci	2.52E-06	4.79E-09	0.0	0.0
Zn65	Ci	4.44E-05	3.05E-06	0.0	0.0
Co60	Ci	7.51E-05	2.20E-05	0.0	0.0
Mn54	Ci	4.92E-06	9.47E-07	0.0	0.0
Total	Ci	1.43E-04	3.11E-05	0.0	0.0

Period: Jul - Dec 1984 License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 1C Gaseous Effluents - Building Vent Release

		•	Continuo		Batch Mo	
Nuc	clides Released	Units	1st 2tr	2nd Qtr	1st Qtr	2nd Qtr
	·			.		:
1.	Noble Gases:		· ·			
	Xe133	Ci	0.0	0.0	0.0	0.0
	Xe135	Ci	0.0	0. 0	0.0	0.0
	Kr85M	Ci	0.0	0.0	0.0	0.0
	Kr88	Ci	0.0	0.0	0.0	0.0
	Kr87	Ci	0.0	0.0	0.0	0.0
	Xe138	Ci	0.0	0.0	0.0	0.0
	Kr90	Ci	0.0	0.0	0.0	0.0
	Xe139	Ci	0.0	0.0	0.0	0.0
	Kr89	Ci	0.0	0.0	0.0	0.0
	Xe137	Ci	0.0	0.0	0.0	0.0
1	Xe135M	Ci	0.0	0.0	0.0	0.0
	Kr83M	Ci	0.0	0.0	0.0	0.0
	Xe133M	Ci	0.0	0.0	0.0	0.0
	Xe131M	Ci		1.43E-06	0.0	0.0
	Kr85	Ci	7.49E+01		0.0	0.0 ₁
	Total for Period	Ci	7.49E+01	8.68E+01	0.0	0.0
	•	·		•		
2.	Iodines:					
	I-131	Ci	0.0	0.0	0.0	0.0
	I-133	Ci	0.0	0.0	0.0	0.0
	I-135	Ci	0.0	0.0	0.0	0.0
		_ .		0.0	0.0	0.0
	Total	Ci	0.0		0.0	0.0
		•	. •			

-

17

Page 8

MONTICELLO NUCLEAR GENERATING PLANT Northern states power company

· .

Period: Jul - Dec 1984 License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 1C Gaseous Effluents - Building Vent Releases (Continued)

Nuclides Released	Units	Continuo 1st 2tr	us Mode 2nd 2tr	Batch 1 1st Qt	
	میں جنوع میں بنی میں جو میں میں				
3. Particulates:					
Cs137	Ci	1.72E-03	3.21E-04	0.0	0.0
Cs134	Ci	3.88E-05	0.0	0.0	. 0.0
Sr90	Ci	2.86E-06	1.73E-06	0.0	0.0
Sr89	Ci	4.89E-06	3.15E-08	0.0	0.0
Zn65	Ci	7.19E-04	2.83E-04	0.0	0.0
C060	Ci	7.61E-04	1.24E-03	0.0	0.0
Mn54	Ci	4.73E-06	3.21E-05	0.0	. 0.0
Total	Ci	3.25E-03	1.87E-03	0.0	0.0
			•	9	

Page 9

MONTICELLO NUCLEAR GENERATING PLANT NORTHERN STATES POWER COMPANY Period: Jul - Dec 1984 License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 2A Liquid Effluents - Summation of All Releases

		Units	1st 2tr	2nd 2tr	Pcnt Est Error
Α.	Fission and Activation Products:				
	1. Total Release	Ci	0.0	0.0	0.0
	(Except H-3, Gases, and Alpha) 2. Avg Diluted Concentration	uCi/ml	0.0	0.0	
в.	Tritium:	• •			
•	1. Total Release 2. Avg Diluted Concentration	Ci uCi∕ml	0.0	0.0	0.0
c.	Dissolved and Entrained Gases:			•	
	1. Total Release 2. Avg Diluted Concentration	Ci uCi∕ml	0.0	0.0	0.0
D.	Percent 2trly Tech Spec Reporting Level		· .	· · ·	
	Whole Body Dose Organ Dose		0.0	0.0	
Ε.	Gross Alpha Radioactivity:				
	1. Total Release	Ci	0.0	0.0	0.0
F.	Volume of Waste Released	Liters	0.0	0.0	0.0
G.	Volume of Dilution Water Used	Liters	0.0	0.0	0.0

MONTICELLO NUCLEAR GENERATING PLANT Northern states power company

7 7

Period: Jul - Dec 1984 License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 2B Liquid Effluents

		Continuous Mode Batch Mode			
Nuclides Released	Units	1st Qtr	2nd Qtr	1st Qtr	2nd 2tr
			·		

None Released This Period

MONTICELLO NUCLEAR GENERATING PLANT Northern states power company Period: Jul - Dec 1984 License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 3 Solid Waste and Irradiated Fuel Shipments

A. Solid Waste Shipped Offsite For Burial or Disposal:

1. Type of Waste:

		Ur	its	Total	Pcnt Est Error
Α.	Spent Resins, Filter Sludges, Evaporator Bottoms, Ect.		ı Meter L	5.10E+01 3.13E+02	5.00E+01
в.	Dry Compressible Waste, Contaminated Equip, Ect.	Ci Ci		5.86E+02 1.57E+01	5.00E+01
					· · · ·
c.	Irradiated Components, Control Rods, Ect.	Cu Cu	u Meter i	0.0	0.0

D. Other (described below):

None

11

38

i i

Period: Jul - Dec 1984 License No. DPR-22

4.99E+01

5.66E+00

2.81E+01

Co60

Mn54 Fe55

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 3 Solid Waste and Irradiated Fuel Shipments (Coontinued)

2. Measured Major Nuclide Composition by Type of Waste:

TYPE 		Nuclide	Percent
A	 	Cs 137	1.28E+01
•	•	Cs136	3.04E+00
	•	Cs134	1.03E+00
	• •	Sr90	2.06E+00
		Sr89	5.09E+00
	· .	Zn65	2.12E+01
		Co60	1.49E+01
·		Co58	1.77E-01
		Mn54	2.27E+00
		Fe55	3.55E+01
В		Cs137	4.89E-01
		Sr90	5.18E-03
		Sr89	3.32E-02
	· · · · ·	Zn65	1.12E+01

MONTICELLO NUCLEAR GENERATING PLANT Northern states power company

Period: Jul - Dec 1984 License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 3 Solid Waste and Irradiated Fuel Shipments (Continued)

3. Solid Waste Disposition:

•	Number of Shipments	Mode	Destination
	16	Truck	US Ecology, Richland, WA
	9	Rail	US Ecology, Richland, WA

B. Irradiated Fuel Shipments:

Number of Shipments	Mode	Destination
2	Rail	General Electric, Morris, IL

1 1

Period: Jul - Dec 1984 License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Table 3 Solid Waste and Irradiated Fuel Shipments (Continued)

C. Shipping Container and Solidification Method:

No.	Volume (M3)	Activity (Ci)	Type of Waste	Container Code	Solidification Code
	5.66E+00		 A	A	C
	3.81E+01		B	L	
	3.81E+01		B	L	
• - • • - •	5.66E+00		A	A ·	С
	3.81E+01		B	L ·	•
	5.66E+00		· A	A.	C
	2.72E+01		B	L	•
	5.66E+00		A	A	C
84-101		5.00E-01	B	L	•
• • • • •	3.13E+01		B	Ľ	
	3.26E+01		B	Ľ	•
	3.81E+01		B	L	-
	5.66E+00		A	A	C
	3.81E+01		B.	L	
	3.81E+01	2 C	B	L Š	
	3.81E+01		B	L	
84-115		1.34E+01	A	Ā	С
		1.67E+00	B	Ĺ	C .
84-119		4.79E+01	A	Ā	С
	3.81E+01	· · · · - · · ·	B	L	
	3.81E+01		B	L	
	5.66E+00		A	A	с
	3.81E+01		B	L	6
	5.66E+00		A	A	C
84-127		7.50E-01	B	L	
04-127	3.016+01	7.302-01			•
CONTAIN	ER CODES:	L - L	SA		
www.camana			ype A		
			ype B		
			arge Quai	ntity	
				-	

SOLIFICATION CODES: C - Cement

C - Cement U - Urea Formaldehyde

Period: Jul - Dec 1984 License No. DPR-22

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Notes:

8 8

1. Release of individual noble gas isotopes from the plant stack was determined using an isotopic analysis at the steam jet air ejector. Xe133, Xe135, Kr85M, Kr88, Kr87, and Xe138 were measured and used to characterize the mode of gas release from the fuel. Other significant noble gases were determined using known ratios, the measured total offgas holdup system delay time, and the known fraction of the offgas stream released via the gland exhauster.

2. An isotopic analysis for noble gases is normally not possible at the building vents. Individual isotopes are generally below their lower limit of detection (LLD). Therefore, for reactor building vent releases, the noble gas isotopic mixture is assumed to be the same as the mixture determined at the steam jet air ejector.

3. Information specified in Regulatory Guide 1.21 which is not applicable to the Monticello plant is indicated by 'NA'.

4. Nuclides not detected in plant effluents (those below the LLD of the analysis) are not included in the quantities reported released. LLD values are recorded and must be less than the minimum LLD values stated in the Monticello Technical Specifications.

NORTHERN STATES POWER COMPANY

MONTICELLO NUCLEAR GENERATING PLANT

OFFSITE RADIATION DOSE ASSESSMENT FOR January 1 - December 31, 1984

As assessment of radiation dose due to releases for the Monticello Nuclear Generating Plant during 1984 was performed in accordance with the Technical Specifications. Computed doses were well below the 40 CFR Part 190 and 10 CFR Part 50, Appendix I standards and guidelines.

Offsite dose calculational formulas and meteorological data were used from the Offsite Dose Calculation Manual in making this assessment. Source terms were obtained from the two Effluent and Waste Disposal Semi-annual reports prepared for NRC review during the year.

Offsite Doses from Gaseous Releases

Computed doses due to gaseous releases are reported in Table 1. Critical receptor location and pathways for organ dose are reported in Table 2. Doses, both whole body and organ, are a small percentage of Appendix I guidelines.

Offsite Doses from Liquid Releases

There were no liquid releases made from the Monticello Plant during the 1984 calendar year.

Doses to Individuals Due to Activities Inside the Site Boundary

Occasional sportsmen will enter the Monticello site for recreational activities. In addition, an Environmental Protection Agency Field Station is located at the Monticello site (see Figure 3.8.1 or Figure 3.8.2 in the Monticello Technical Specifications). Workers at this field station, spending an average of 40 hours/week, are the most exposed individuals. Whole body doses to theses individuals have been computed using stack and vent X/Q values at the field station location. Annual computed doses were reduced by the factor 40/168 to account for the limited occupancy for workers at this location. Organ doses to workers at the EPA field station due to gaseous releases have been computed for the inhalation pathway (no other pathways exists). Doses to workers at the EPA field station due to liquid releases are not expected to be higher than those computed for individuals beyond the site boundary. Doses at the EPA field station are reported in Table 1.

Doses to Most Exposed Member of the General Public from Reactor Releases and Other Nearby Uranium Fuel Cycle Sources

There are no uranium fuel cycle facilities in the vincinity of the Monticello site.

The only other source of exposure to the general public in addition to the plant gaseous and liquid effluents is from direct radiation. Calculations performed in the past have shown this source to be negligible. An array of TLD monitoring locations at the site boundary has consistently indicated that plant operation in recent years has has no effect on ambient gamma radiation.

Therefore, the most exposed member of the general public will not receive a radiation dose from reactor releases and all other fuel cycle activities in excess of the sum of the liquid and gaseous whole body and organ doses reported in Table 1 for the site boundary and critical receptor, respectively. These doses are well within the 40 CFR Part 190 standards of 25 mrem to the whole body or any organ (except the thyroid) and 75 mrem to the thyroid every 12 months.

BWC021485GDW01

TABLE 1

OFFSITE RADIATION DOSE ASSESSMENT - MONTICELLO

PERIOD: JANUARY 1 THROUGH	DECEMBER 31 1984			
<u>Geseous Releases</u>	10 CFR Part 50 APPENDIX I Guidelines Per Unit Per Year			
Maximum Site Boundary Gamma Air Dose (mrad) 0.46	10			
Maxiumum Site Boundary Beta Air Dose (mrad) 0.58	20			
Maximum Offsite Dose to Any Organ (mrem)*				
Total 0.13	15			
EPA Field Station Dose (mrem) 0.03 Whole Body Organ <u>0.04</u>	5 15			
Liquid Releases (None Released in 1984)				
Maximum Offsite Whole Body Dose (mrem) TotalO	3			
Maximum Offsite Organ Dose (mrem)* TotalO	10			

*Long lived particulates, I-131 & tritium.

BWC021485GDW01

-3-

TABLE 2

OFFISITE RADIATION DOSE ASSESSMENT SUPPLEMENTAL INFORMATION - MONTICELLO

PERIOD: JANUARY 1	THROUGH DECEMBER	31, 1984			
Gaseous Effluents					
Maximum Site Boundary Dose Location (from building vents)	• •				
Sector Distance (mi.)	SSE 0.43				
EPA Field Station					
Sector Distance	ESE 0.31				
Maximum Offsite Dose Location					
Sector Distance (mi.) Pathways	ESE 2.3 Ground, inhalation milk				
Age Group Organ	Infant Thyroid				
Liquid Releases					
Maximum Offsite Dose Location Downstream		•			
Pathways Age Group Organ	Drinking Water Infant Whole Body	Drinking Water, fish Adult GI-LLI			
Dilution Factor (drinking water)	7.1	7.1			

BWC021485GDW01

DMB

Northern States Power Company

414 Nicollet Mall Minneapolis. Minnesota 55401 Telephone (612) 330-5500

NSP

March 1, 1985

Regional Administrator Region III U S Nuclear Regulatory Commission 799 Roosevelt Road Glen Ellyn, Illinois 60137

orig+1



Monticello Nuclear Generating Plant Docket No. 50-628 License No. DPR-22

Effluent and Waste Disposal Semi-Annual Report for July 1, 1984 through December 31, 1984

In accordance with the Monticello Technical Specifications, Appendix A to Operating License DPR-22, we are submitting one copy of the Effluent and Waste Disposal Semi-Annual Report covering the last half of 1984.

Fredd Ley . Jr.

F. L. Fey, Jr., General Superintendent Radiological Protection and Chemistry Nuclear Generation Department

Attachment

cc: U S NRC, Document Control Desk (1)
G. Charnoff (w/o attachment)
MPCA - Attn: J. W. Ferman
Resident Inspector, U S NRC
Project Manager, U S NRC

gdw

reas MAR 4 1985

BWC022685GDW01