

# FUNCTIONAL ARRANGEMENT ITAAC

# The Functional Arrangement ITAAC

- ✓ Do not have to be performed as part of the formal system turnover
- ✓ Can be performed any time after construction is complete
- ✓ Are not for configuration control or final check SSCs have been restored to their required configuration prior to fuel load
- ✓ Verify the physical arrangement of Tier 1 SSCs

# The Functional Arrangement ITAAC include those SSCs

- Tier 1 Design Descriptions
- Tier 1 Figures
- Tier 1 Tables