

**CRYSTAL RIVER UNIT 3
JPM COVER SHEET**

ADMIN JPM #C01

NRC 2011

RO / SRO

**PERFORM AN RCS BORON
CHANGE CALCULATION**

PREPARED/REVIEWED BY: Jim Gregitis

Date: 07/10/11

VALIDATED BY: B. Wooten / B. Webster / R. Virgin

Date: 07/10/11

APPROVAL BY: Mark VanSicklen
(Nuclear Training Supervisor)

Date: 07/27/11

CONCURRED BY: Mike Kelly
(Operations Representative)

Date: 07/28/11

Validation is not required for minor enhancements, procedure revisions that do not affect the JPM or individual step changes that do not affect the flow of the JPM.

Operations concurrence is required for new JPMs and changes that affect the flow, critical steps or time critical steps of the JPM. Operations concurrence is not required for changes that are required due to a procedure revision.

ADMINISTRATIVE JOB PERFORMANCE MEASURE

JPM #: Admin CO2 - NRC 2011

Task: Determine a reactor coolant boron change calculation.

Alternate Path: YES NO

PRA Top Critical Action: YES NO

Safety Function: NA

K/A Rating/Importance: G2.1.37 RO 4.3 SRO 4.6

Task Number: 0020102029 – RO

Position: SRO ONLY RO/SRO NLO/RO/SRO

Task Standard: Perform a reactor coolant boron change calculation using OP-304.

Preferred Evaluation Location:

Preferred Evaluation Method:

SIM PLANT ADMIN

PERFORM SIMULATE

References:

OP-304, Rev 33
OP-103C, Rev 31

Validation Time: 30 minutes

Time Critical: YES NO

Candidate: _____
Printed Name

Time Start: _____

Time Finish: _____

Performance Rating: SAT UNSAT

Performance Time: _____

Examiner: _____
Printed Name

Signature / _____
Date

Comment: _____

ADMINISTRATIVE JOB PERFORMANCE MEASURE

SIMULATOR OPERATOR SETUP INSTRUCTIONS

1. None

SIMULATOR OPERATOR INSTRUCTIONS

1. None

TOOLS/EQUIPMENT/PROCEDURES NEEDED

1. Consumable copies of OP-304, Rev 33
2. Consumable copies of OP-103C, Rev 31
3. Calculators

ADMINISTRATIVE JOB PERFORMANCE MEASURE

READ TO THE OPERATOR

INITIAL CONDITIONS

You are the Reactor Operator.

The following plant conditions exist:

Rx power: 80%
Initial rod index: 280%
EFPD: 300

INITIATING CUES

The CRS has directed you to perform the boron change required to achieve the following final plant conditions:

Rx power: 100%
Final rod index: 280%

Do NOT consider the effects of Xenon.

SWQL B OP304.XLS is NOT available.

Document your answer below.

ANSWER

RCS boron concentration must be **raised / lowered** by _____ ppm (ΔB).
(circle one)

ADMINISTRATIVE JOB PERFORMANCE MEASURE

EXAMINER'S NOTE: FOR STEPS DENOTED AS "CRITICAL STEP", WHICH HAVE MULTIPLE ACTIONS, THE INDIVIDUAL REQUIRED ACTION WILL BE DENOTED "CS". IF NO INDIVIDUAL ACTIONS ARE DENOTED AS SUCH THEN ALL ACTIONS WITHIN THE STEP ARE DEEMED "CRITICAL".

TIME START _____

| | |
|---|-----------------------------------|
| <p><u>STEP 1:</u></p> <p>Obtain copy of appropriate procedure.</p> <p><u>STANDARD:</u></p> <p>Candidate obtains a copy of OP-304.</p> <p><u>EXAMINER NOTE:</u></p> <p>Provide candidate with a copy of OP-304. When candidate asks for OP-103C, provide him/her a copy at that time.</p> <p><u>COMMENTS:</u></p> | <p>SAT_____</p> <p>UNSAT_____</p> |
| <p><u>STEP 2:</u> (OP-304 Enclosure 4 Step 1)</p> <p>Record initial plant data.</p> <p><u>STANDARD:</u></p> <p>Candidate accurately transfers data to Enclosure 4.</p> <p>Rx Power 80%</p> <p>Rod Index 280%</p> <p>EFPD 300</p> <p><u>COMMENTS:</u></p> | <p>SAT_____</p> <p>UNSAT_____</p> |

ADMINISTRATIVE JOB PERFORMANCE MEASURE

| | |
|--|--|
| <p><u>STEP 3:</u> (OP-304 Enclosure 4 Step 2)</p> <p>Record final plant data.</p> <p><u>STANDARD:</u></p> <p>Candidate accurately transfers data to Enclosure 4.</p> <p>Rx Power 100% Rod Index 280%</p> <p><u>COMMENTS:</u></p> | <p>SAT_____</p> <p>UNSAT_____</p> |
| <p><u>STEP 4:</u> (OP-304 Enclosure 4 Step 3)</p> <p>Determine Reactivity for reactor power R_{1RP} (Initial) and R_{2RP} (Final).</p> <p><u>STANDARD:</u></p> <p>Using OP-103C curve 15, candidate determines R_{1RP} to be 0.2056% $\Delta k/k$ and R_{2RP} to be 0% $\Delta k/k$. Candidate accurately transfers data to Enclosure 4.</p> <p><u>EXAMINER NOTE:</u></p> <p>Acceptable ranges for R_{1RP} is 0.19% $\Delta k/k$ to 0.21% $\Delta k/k$ due to readability of curve 15.</p> <p><u>COMMENTS:</u></p> | <p>Critical Step</p> <p>Basis: Reactivity Management</p> <p>SAT_____</p> <p>UNSAT_____</p> |

ADMINISTRATIVE JOB PERFORMANCE MEASURE

| | |
|---|-----------------------------------|
| <p>STEP 5: (OP-304 Enclosure 4 Step 4)</p> <p>Determine Reactivity for rod index R1_{RI} (Initial) and R2_{RI} (Final).</p> <p>STANDARD:</p> <p>Using OP-103C curve 14, candidate determines R1_{RI} and R2_{RI} to be -0.1349% Δk/k. Candidate accurately transfers data to Enclosure 4.</p> <p>EXAMINER NOTE:</p> <p>Step is not critical due to no change in rod height.</p> <p>COMMENTS:</p> | <p>SAT_____</p> <p>UNSAT_____</p> |
| <p>STEP 6: (OP-304 Enclosure 4 Step 5)</p> <p>Determine total reactivity R1_T (Initial) and R2_T (Final).</p> <p>STANDARD:</p> <p>Candidate accurately calculates R1_T (Initial) and R2_T (Final) and transfers to Enclosure 4.</p> <p>$R1_T = R1_{RP} + R1_{RI} = 0.2056\% \Delta k/k - 0.1349\% \Delta k/k = 0.0707\% \Delta k/k$</p> <p>$R2_T = R2_{RP} + R2_{RI} = 0\% \Delta k/k - 0.1349\% \Delta k/k = -0.1349\% \Delta k/k$</p> <p>COMMENTS:</p> | <p>SAT_____</p> <p>UNSAT_____</p> |

ADMINISTRATIVE JOB PERFORMANCE MEASURE

| | |
|--|--|
| <p>STEP 7: (OP-304 Enclosure 4 Step 6)</p> <p>Determine ΔR (Change in reactivity).</p> <p>STANDARD:</p> <p>Candidate accurately calculates ΔR and transfers to Enclosure 4.</p> <p>$\Delta R = R_{2T} - R_{1T} = -0.1349\% \Delta k/k - (0.0707\% \Delta k/k) = -0.2056\% \Delta k/k$</p> <p>COMMENTS:</p> | <p>SAT_____</p> <p>UNSAT_____</p> |
| <p>STEP 8: (OP-304 Enclosure 4 Step 7)</p> <p>Determine IB (Inverse Boron worth).</p> <p>STANDARD:</p> <p>Using OP-103C curve 4, candidate determines IB to be 157.2 ppm/%$\Delta k/k$. Candidate accurately transfers data to Enclosure 4.</p> <p>EXAMINER NOTE:</p> <p>Acceptable range for IB is 156.2 ppm/%$\Delta k/k$ to 158.2 ppm/%$\Delta k/k$ due to readability of curve 4.</p> <p>COMMENTS:</p> | <p>Critical Step</p> <p>Basis: Reactivity Management</p> <p>SAT_____</p> <p>UNSAT_____</p> |

ADMINISTRATIVE JOB PERFORMANCE MEASURE

| | |
|---|---|
| <p>STEP 9: (OP-304 Enclosure 4 Step 8)</p> <p>Determine ΔB (Change in RCS boron). Raise boron if positive, lower boron if negative.</p> <p>STANDARD:</p> <p>Candidate accurately calculates ΔB and transfers to Enclosure 4.</p> <p>$\Delta B = (\Delta R)(IB) = (-0.2056\% \Delta k/k)(157.2 \text{ ppm}/\% \Delta k/k) = -32.32 \text{ ppm}$</p> <p>Candidate determines boron must be lowered by 32.32 ppm.</p> <p>EXAMINER NOTE:</p> <p>Acceptable range for ΔB is -29 ppm to -34 ppm due to previous acceptability ranges (<u>Lower</u> boron by 29 ppm to 34 ppm).</p> <p>COMMENTS:</p> | <p>Critical Step</p> <p>Basis: Reactivity Management</p> <p>SAT_____</p> <p>UNSAT_____</p> |
| <p>TERMINATION CUE: OP-304 Enclosure 4 complete.</p> | |
| <p align="center">END OF TASK</p> | |

TIME STOP _____

ANSWER KEY

ON-LINE REACTIVITY MANAGEMENT

| | | | |
|---|----------------------------------|---|---|
| 1. Record initial plant data. | | | |
| Rx POWER <u>80</u> % | ROD INDEX <u>280</u> % | R1_{XE} Saxon <u>N/A</u> %Δk/k | EFPD Saxon <u>300</u> |
| 2. Record final plant data. | | | |
| Rx POWER <u>100</u> % | ROD INDEX <u>280</u> % | USE CAUTION TO ENSURE PROPER SIGNS ARE MAINTAINED DURING ALL CALCULATIONS. | R2_{XE} Saxon <u>N/A</u> %Δk/k |
| 3. Determine Reactivity for reactor power R1 _{RP} (Initial) and R2 _{RP} (Final) | | | |
| Use OP-103C curve 15 | | R1_{RP} <u>0.2056</u> %Δk/k | R2_{RP} <u>0</u> %Δk/k |
| 4. Determine Reactivity for rod index R1 _{RI} (Initial) and R2 _{RI} (Final) | | | |
| Use OP-103C curve 14 | | R1_{RI} <u>-0.1349</u> %Δk/k | R2_{RI} <u>-0.1349</u> %Δk/k |
| 5. Determine total reactivity R1 _T (Initial) and R2 _T (Final) | | | |
| $R_{1T} = R_{1RP} + R_{1RI} + R_{1XE}$ $R_{1T} = \frac{\% \Delta k}{k} + \frac{\% \Delta k}{k} + \frac{\% \Delta k}{k}$ $R_{2T} = R_{2RP} + R_{2RI} + R_{2XE}$ $R_{2T} = \frac{\% \Delta k}{k} + \frac{\% \Delta k}{k} + \frac{\% \Delta k}{k}$ | | R1_T <u>0.0707</u> %Δk/k | R2_T <u>-0.1349</u> %Δk/k |
| 6. Determine Δ R (Change in reactivity) | | | |
| $\Delta R = R_{2T} - R_{1T}$ $\Delta R = \frac{\% \Delta k}{k} - \frac{\% \Delta k}{k}$ | | | ΔR <u>-0.2056</u> %Δk/k |
| Continue calculation on next page | | | |

ANSWER KEY

ON-LINE REACTIVITY MANAGEMENT

| | |
|---|--|
| 7. Determine IB (Inverse Boron worth) | |
| Use OP-103C curve 4 for current EFPD If reactor power is >18%, use HFP values. | IB <u>157.2000</u> ppm / %Δk/k |
| 8. Determine Δ B (Change in RCS boron). Raise boron if positive, lower boron if negative. | |
| $\Delta B = (\Delta R) (IB)$ $\Delta B = (\frac{\% \Delta k}{k}) (\frac{\text{ppm}}{\% \Delta k})$ | ΔB <u>-32.32</u> ppm |
| PERFORMED BY _____ DATE _____ | |
| VERIFIED BY _____ DATE _____ | |

ADMINISTRATIVE JOB PERFORMANCE MEASURE

CANDIDATE CUE SHEET

(TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

INITIAL CONDITIONS

You are the Reactor Operator.

The following plant conditions exist:

Rx power: 80%
Initial rod index: 280%
EFPD: 300

INITIATING CUES

The CRS has directed you to perform the boron change required to achieve the following final plant conditions:

Rx power: 100%
Final rod index: 280%

Do NOT consider the effects of Xenon.

SWQL B OP304.XLS is NOT available.

Document your answer below.

ANSWER

RCS boron concentration must be **raised / lowered** by _____ ppm (ΔB).
(circle one)

**CRYSTAL RIVER UNIT 3
JPM COVER SHEET**

ADMIN JPM #CO2

NRC 2011

RO / SRO

**CALCULATE SDM WITH A
MISALIGNED CONTROL ROD**

PREPARED/REVIEWED BY: Jim Gregitis Date: 05/24/11

VALIDATED BY: B. Wooten / B. Webster / R. Virgin Date: 07/10/11

APPROVAL BY: Mark VanSicklen Date: 07/27/11
(Nuclear Training Supervisor)

CONCURRED BY: Mike Kelly Date: 07/28/11
(Operations Representative)

Validation is not required for minor enhancements, procedure revisions that do not affect the JPM or individual step changes that do not affect the flow of the JPM.

Operations concurrence is required for new JPMs and changes that affect the flow, critical steps or time critical steps of the JPM. Operations concurrence is not required for changes that are required due to a procedure revision.

ADMINISTRATIVE JOB PERFORMANCE MEASURE

JPM #: Admin CO2 - NRC 2011

Task: Determine Shutdown Margin (SDM).

Alternate Path: YES NO

PRA Top Critical Action: YES NO

Safety Function: NA

K/A Rating/Importance: G2.1.7 RO 3.7 SRO 4.4
G2.2.40 SRO 4.7

Task Number: 1150202005 – RO 1190201006 – SRO

Position: SRO ONLY RO/SRO NLO/RO/SRO

Task Standard: Determine SDM using SP-421, Reactivity Balance Calculations.

Preferred Evaluation Location:

SIM PLANT ADMIN

Preferred Evaluation Method:

PERFORM SIMULATE

References:

OP-103C, Rev 31
SP-421, Rev 61
TS 3.1.4

Validation Time: 15 minutes

Time Critical: YES NO

=====
Candidate: _____

Printed Name

Time Start: _____

Time Finish: _____

Performance Rating: SAT UNSAT

Performance Time: _____

Examiner: _____

Printed Name

_____/_____
Signature Date

Signature

Date

Comment: _____

ADMINISTRATIVE JOB PERFORMANCE MEASURE

SIMULATOR OPERATOR SETUP INSTRUCTIONS

1. None

SIMULATOR OPERATOR INSTRUCTIONS

1. None

TOOLS/EQUIPMENT/PROCEDURES NEEDED

1. Consumable copies of OP-103C, Rev 31
2. Consumable copies of SP-421, Rev 61
3. Copies of ITS
4. Calculators

READ TO THE OPERATOR

INITIAL CONDITIONS

You are the Balance of Plant Operator.

With the plant initially at 100% power, control rod 6-6 dropped from its group average height of 80% to the 60% withdrawn position and has been determined to be untrippable.

The plant is now stable at 60% power.

RCS boron is 1109 ppmB.

210 EFPD

Xenon value from current Saxon is -2.13% $\Delta k/k$. **(This value must be used for calculation.)**

Boron-10 atom percent is 19.8.

RCS temperature is 579° F.

INITIATING CUES

The Control Room Supervisor has directed you to verify if adequate SDM exists using SP-421, Reactivity Balance Calculations. Enter SDM below and document additional actions, if any, you would perform.

SROs only: After calculating SDM, determine if any TS actions are required. Include applicable time requirements. Document your answer below.

ADMINISTRATIVE JOB PERFORMANCE MEASURE

EXAMINER'S NOTE: FOR STEPS DENOTED AS "CRITICAL STEP", WHICH HAVE MULTIPLE ACTIONS, THE INDIVIDUAL REQUIRED ACTION WILL BE DENOTED "CS". IF NO INDIVIDUAL ACTIONS ARE DENOTED AS SUCH THEN ALL ACTIONS WITHIN THE STEP ARE DEEMED "CRITICAL".

TIME START _____

| | |
|---|-------------------------------------|
| <p><u>STEP 1:</u></p> <p>Locate procedures.</p> <p><u>STANDARD:</u></p> <p>Candidate obtains a copy of SP-421 and OP-103C.</p> <p><u>EXAMINER NOTE:</u></p> <p>Provide candidate with a copy of SP-421. When the candidate asks for OP-103C, provide it to him/her at that time.</p> <p><u>COMMENTS:</u></p> | <p>SAT _____</p> <p>UNSAT _____</p> |
|---|-------------------------------------|

ADMINISTRATIVE JOB PERFORMANCE MEASURE

| | |
|---|-----------------------------------|
| <p><u>STEP 2:</u></p> <p>Determine correct enclosure to use.</p> <p><u>STANDARD:</u></p> <p>Candidate determines that Enclosure 1B, One Hour Misaligned Rod Shutdown Margin Calculation, is the enclosure to be used.</p> <p><u>EXAMINER NOTE:</u></p> <p>If candidate determines that Enclosure 1, Shutdown Margin – Normal Conditions, is to be used, allow the candidate to complete the JPM since both enclosures will result at the same endpoint. Make a note of this and during the final exam review point out to the candidate that Enclosure 1B was created just for this type of plant condition.</p> <p><u>COMMENTS:</u></p> | <p>SAT_____</p> <p>UNSAT_____</p> |
|---|-----------------------------------|

ADMINISTRATIVE JOB PERFORMANCE MEASURE

| | |
|--|-----------------------------------|
| <p><u>STEP 3:</u> (SP-421 Enclosure 1B Step 1)</p> <p>Enter core burnup.</p> <p><u>STANDARD:</u></p> <p>Candidate accurately transfers data from Cue Sheet to enclosure.</p> <p><u>COMMENTS:</u></p> | <p>SAT_____</p> <p>UNSAT_____</p> |
|--|-----------------------------------|

ADMINISTRATIVE JOB PERFORMANCE MEASURE

| | |
|---|---|
| <p><u>STEP 4:</u> (SP-421 Enclosure 1B Step 2)</p> <p>Determine Boron Reactivity.</p> <ol style="list-style-type: none"> 1. Enter RCS Boron Concentration. (Cue Sheet) 2. Enter B-10 atom percent. (Cue Sheet) 3. Calculate B-10 adjusted value. 4. Enter RCS temperature. (Cue Sheet) 5. Use Curve 19 to determine boron concentration required for Shutdown Margin. (CS) 6. Use Curve 3 to determine differential boron worth. (CS) 7. Perform calculation to determine boron reactivity. (CS) <p><u>STANDARD:</u></p> <p>Candidate accurately transfers data from Cue Sheet, determines correct curves to use and accurately calculates the value for boron reactivity.</p> <p><u>EXAMINER NOTE:</u></p> <p>Values must be within limits on attached key.</p> <p><u>COMMENTS:</u></p> | <p>Critical Step</p> <p>Basis: Accurate curve selection and calculation required to determine adequate SDM.</p> <p>SAT_____</p> <p>UNSAT_____</p> |
|---|---|

ADMINISTRATIVE JOB PERFORMANCE MEASURE

| | |
|--|-------------------------------------|
| <p><u>STEP 5:</u> (SP-421 Enclosure 1B Step 3)</p> <p>Determine Control Rod Group Reactivity.</p> <p><u>STANDARD:</u></p> <p>Candidate notes that no credit will be taken for APSR position in shutdown margin calculations.</p> <p><u>COMMENTS:</u></p> | <p>SAT _____</p> <p>UNSAT _____</p> |
| <p><u>STEP 6:</u> (SP-421 Enclosure 1B Step 4)</p> <p>Determine Xenon Reactivity.</p> <p><u>STANDARD:</u></p> <p>Candidate accurately transfers data from Cue Sheet to enclosure.</p> <p><u>COMMENTS:</u></p> | <p>SAT _____</p> <p>UNSAT _____</p> |

ADMINISTRATIVE JOB PERFORMANCE MEASURE

| | |
|--|--|
| <p>STEP 7: (SP-421 Enclosure 1B Step 5)</p> <p>Determine SDM.</p> <ol style="list-style-type: none"> 1. Calculate SDM. 2. If SDM is determined to be less negative than $-1.0\% \Delta k/k$ then SDM is unacceptable. Immediately notify the CRS and refer to TS 3.1.1. 3. If SDM is determined to be equal to or more negative than $-1.0\% \Delta k/k$ then SDM is acceptable. <p>STANDARD:</p> <p>Candidate determines that SDM is unacceptable and notifies the CRS.</p> <p>EXAMINER NOTE:</p> <p>Value must be within limits on attached key.</p> <p>COMMENTS:</p> | <p>Critical Step</p> <p>Basis: Accurate calculation and immediate notification of the CRS is required to comply with TS.</p> <p>SAT_____</p> <p>UNSAT_____</p> |
| <p>TERMINATION CUE: SDM calculation complete and unacceptability determined.</p> | |
| <p align="center"><u>RO</u> - END OF TASK</p> | |

ADMINISTRATIVE JOB PERFORMANCE MEASURE

| | |
|--|---|
| <p>STEP 8: (SRO Only)</p> <p>Refer to TS 3.1.4, Control Rod Group Alignment Limits, and determine required actions.</p> <p><u>STANDARD:</u></p> <p>Candidate determines that the following actions are required (TS 3.1.4 Condition D):</p> <ol style="list-style-type: none"> 1. Initiate boration to restore SDM within 1 hour. 2. Be in Mode 3 within 6 hours. <p><u>EXAMINER'S NOTE:</u></p> <p>TS 3.1.1, Shutdown Margin (SDM), is only applicable in Modes 3, 4, and 5. Per the Cue Sheet, the plant is in Mode 1.</p> <p><u>COMMENTS:</u></p> | <p>Critical Step</p> <p>Basis: TS required actions</p> <p>SAT_____</p> <p>UNSAT_____</p> |
| <p><u>TERMINATION CUE:</u> TS required actions determined.</p> | |
| <p align="center"><u>SRO</u> - END OF TASK</p> | |

TIME STOP _____

ONE HOUR MISALIGNED ROD SHUTDOWN MARGIN CALCULATION

NOTES

For this enclosure the following applies:

- (1) It is permissible to round EFPD, boron, %wd, and °F to the nearest Integer.
- (2) For RCS > 532 degrees F, 532 degrees F data may be used.
- (3) Two decimal place accuracy is required for reactivity terms in calculations.

1. Core Burnup

Core Burnup = EFPD (from SAXON) = 210 EFPD

2. Boron Reactivity

a. Measured RCS Boron Concentration = 1109 ppmB

NOTE
The reference Boron-10 (B-10) atom percent (a/o) is 19.8 for all calculations used in deriving the reactivity curves in OP-103C.

b. B-10 atom percent of RCS Boron = 19.8 a/o
supplied by an approved Reactor Engineering Operational Communication (ROC).

c. B-10 adjusted Boron Concentration is
Step 2(a) * Step 2(b) / 19.8 = 1109 ppmB

d. RCS temperature = 579 ° F.

e. Using RCS temperature from 2(d) and core burnup from Step 1, determine the Boron concentration required for shutdown from appropriate Curve 18 or Curve 19 of OP-103C.

= 1602 ppmB
(LIMIT 1590 to 1610)

f. Differential boron worth from Curve 3 of OP-103C, Reactivity Worth Curves.

= 0.6984 % Δk/k /100 ppm
(LIMIT 0.69 to 0.71)

g. Reactivity During Modes 1,2,3,4, and 5
Reactivity = [(e-c) x f/100] - 1.0

= [(1602 - 1109) x 0.6984 / 100] - 1.0 = +/- + 2.44 % Δk/k
(LIMIT + 2.32 to + 2.51)

ONE HOUR MISALIGNED ROD SHUTDOWN MARGIN CALCULATION (Cont'd)

3. Control Rod Group 8 Reactivity

No credit will be taken for APSR position in shutdown margin calculations.

NOTE

(1) For the one hour misaligned rod calculation **ONLY**, the value for xenon calculated prior to the misaligned rod for this hour may still be used provided that:

- the existing SAXON printout accurately reflects the core conditions prior to the misaligned rod, and
- the maximum post-misaligned rod power level is less than, or equal to, the power level used on the existing SAXON printout for calculating this hour's xenon.

(2) Using a xenon value of 0.0% Δk/k is conservative and may be used at any time.

4. Xenon Reactivity

a. Obtain Xenon reactivity from Saxon code (submit printout).

OR

b. IF the Saxon code is unavailable, THEN use 0.0% Δk/k or contact Reactor Engineering for a value (0.0% Δk/k is conservative and therefore preferred).

- 2.13 % Δk/k

5. Shutdown Margin

Determine the shutdown margin by adding Items 2 and 4 above, and round to the nearest hundredth

$$\begin{array}{rcccl}
 \underline{+ 2.44} & + & \underline{- 2.13} & & \\
 \text{Item 2} & & \text{Item 4} & & \\
 & & & & = + / - \underline{+ 0.31} \text{ \% } \Delta k/k \\
 & & & & \text{(LIMIT + 0.19 to + 0.38)}
 \end{array}$$

a. IF the shutdown margin determined in Step 5, rounded to tenths, is less negative than -1.0% Δk/k (i.e., zero, positive or between 0.0 and -1.0).

THEN the shutdown margin is unacceptable. **IMMEDIATELY** inform the Control Room Supervisor and refer to ITS 3.1.1.

b. IF the shutdown margin determined in Step 5, rounded to tenths, is equal to or more negative than -1.0% Δk/k,

THEN the shutdown margin is acceptable.

Calculated By: _____

Date/Time: _____

Checked By: _____

Date/Time: _____

ADMINISTRATIVE JOB PERFORMANCE MEASURE

CANDIDATE CUE SHEET

(TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

INITIAL CONDITIONS

You are the Balance of Plant Operator.

With the plant initially at 100% power, control rod 6-6 dropped from its group average height of 80% to the 60% withdrawn position and has been determined to be untrippable.

The plant is now stable at 60% power.

RCS boron is 1109 ppmB.

210 EFPD

Xenon value from current Saxon is -2.13% $\Delta k/k$. **(This value must be used for calculation.)**

Boron-10 atom percent is 19.8.

RCS temperature is 579° F.

INITIATING CUES

The Control Room Supervisor has directed you to verify if adequate SDM exists using SP-421, Reactivity Balance Calculations. Enter SDM below and document additional actions, if any, you would perform.

SROs only: After calculating SDM, determine if any TS actions are required. Include applicable time requirements. Document your answer below.

**CRYSTAL RIVER UNIT 3
JPM COVER SHEET**

ADMIN JPM #EC1

NRC 2011

RO / SRO

PERFORM A QPTR CALCULATION

PREPARED/REVIEWED BY: Jim Gregitis

Date: 05/25/11

VALIDATED BY: B. Wooten / B. Webster / R. Virgin

Date: 07/07/11

APPROVAL BY: Mark VanSicklen
(Nuclear Training Supervisor)

Date: 07/27/11

CONCURRED BY: Mike Kelly
(Operations Representative)

Date: 07/28/11

Validation is not required for minor enhancements, procedure revisions that do not affect the JPM or individual step changes that do not affect the flow of the JPM.

Operations concurrence is required for new JPMs and changes that affect the flow, critical steps or time critical steps of the JPM. Operations concurrence is not required for changes that are required due to a procedure revision.

ADMINISTRATIVE JOB PERFORMANCE MEASURE

JPM #: Admin EC1 - NRC 2011

Task: Perform a QPTR calculation.

Alternate Path: YES NO

PRA Top Critical Action: YES NO

Safety Function: NA

K/A Rating/Importance: G2.2.12 RO 3.7 SRO 4.1
G2.2.40 SRO 4.7

Task Number: 0150202001 – RO 1190201006 – SRO

Position: SRO ONLY RO/SRO NLO/RO/SRO

Task Standard: Perform a QPTR calculation using SP-303, Tilt Monitoring with an Unavailable Incore System.

Preferred Evaluation Location:

SIM PLANT ADMIN

Preferred Evaluation Method:

PERFORM SIMULATE

References:

COLR (Cycle 17)
SP-303, Rev 6
TS 3.2.4

Validation Time: 20 minutes

Time Critical: YES NO

Candidate: _____
Printed Name

Time Start: _____

Time Finish: _____

Performance Rating: SAT UNSAT

Performance Time: _____

Examiner: _____
Printed Name

Signature / _____
Date

Comment: _____

ADMINISTRATIVE JOB PERFORMANCE MEASURE

SIMULATOR OPERATOR SETUP INSTRUCTIONS

1. None

SIMULATOR OPERATOR INSTRUCTIONS

1. None

TOOLS/EQUIPMENT/PROCEDURES NEEDED

1. Consumable copies of SP-303, Rev 6
2. Copies of COLR (Cycle 17)
3. Copies of ITS
4. Calculators

ADMINISTRATIVE JOB PERFORMANCE MEASURE

READ TO THE OPERATOR

INITIAL CONDITIONS

You are the Balance of Plant Operator.
The plant has been stable at this power level for the previous 3 hours.
The Symmetrical Incore Detector System is inoperable.
Current NI values from the control console are:
NI-5 = 62%
NI-6 = 63%
NI-7 = 63%
NI-8 = 68%
 $\Delta T_c = 0.3^\circ \text{ F}$
Rod Index is 245%.

INITIATING CUES

The Control Room Supervisor has directed you to calculate current out-of-core QPT using SP-303, Tilt Monitoring with an Unavailable Symmetric Incore System. Enter AOT (adjusted out-of-core tilt) values below and document additional actions, if any, you would perform.

SP-303, Enclosure 1, Table 1 is attached.

NI-5 AOT = NI-6 AOT = NI-7 AOT = NI-8 AOT =

SROs only: After calculating AOT, determine if any TS actions are required. Document your answer below.

ADMINISTRATIVE JOB PERFORMANCE MEASURE

EXAMINER'S NOTE: FOR STEPS DENOTED AS "CRITICAL STEP", WHICH HAVE MULTIPLE ACTIONS, THE INDIVIDUAL REQUIRED ACTION WILL BE DENOTED "CS". IF NO INDIVIDUAL ACTIONS ARE DENOTED AS SUCH THEN ALL ACTIONS WITHIN THE STEP ARE DEEMED "CRITICAL".

TIME START _____

| | |
|--|-----------------------------------|
| <p><u>STEP 1:</u></p> <p>Locate procedure.</p> <p><u>STANDARD:</u></p> <p>Candidate obtains a copy of SP-303.</p> <p><u>EXAMINER NOTE:</u></p> <p>Provide candidate with a copy of SP-303.</p> <p><u>COMMENTS:</u></p> | <p>SAT_____</p> <p>UNSAT_____</p> |
| <p><u>STEP 2:</u> (SP-303 Enclosure 3 Step 1)</p> <p>Record time, current NI power levels, ΔT_c and Reg Rod Index in Table 3.</p> <p><u>STANDARD:</u></p> <p>Candidate accurately transfers data from Cue Sheet to Table 3.</p> <p><u>COMMENTS:</u></p> | <p>SAT_____</p> <p>UNSAT_____</p> |

ADMINISTRATIVE JOB PERFORMANCE MEASURE

| | |
|--|-----------------------------------|
| <p><u>STEP 3:</u> (SP-303 Enclosure 3 Step 2)</p> <p>Obtain the appropriate normalization constants (N) for each quadrant from Section 4.1 and record in Table 3.</p> <p><u>STANDARD:</u></p> <p>Candidate accurately transfers data from Table 1 (provided) to Table 3.</p> <p><u>COMMENTS:</u></p> | <p>SAT_____</p> <p>UNSAT_____</p> |
|--|-----------------------------------|

ADMINISTRATIVE JOB PERFORMANCE MEASURE

| | |
|---|-----------------------------------|
| <p><u>STEP 4:</u> (SP-303 Enclosure 3 Step 3a)</p> <p>Calculate the current average NI power.</p> <p><u>STANDARD:</u></p> <p>Candidate accurately calculates an average NI power of 64%.</p> <p><u>COMMENTS:</u></p> | <p>SAT_____</p> <p>UNSAT_____</p> |
| <p><u>STEP 5:</u> (SP-303 Enclosure 3 Step 3b)</p> <p>Calculate the current out-of-core tilt (OCD) in each quadrant.</p> <p><u>STANDARD:</u></p> <p>Candidate accurately calculates OCD tilt for each quadrant.</p> <p><u>COMMENTS:</u></p> | <p>SAT_____</p> <p>UNSAT_____</p> |
| <p><u>STEP 6:</u> (SP-303 Enclosure 3 Step 4)</p> <p>Record the current OCD for each Quadrant in Table 3.</p> <p><u>STANDARD:</u></p> <p>Candidate accurately transfers data to Table 3.</p> <p><u>COMMENTS:</u></p> | <p>SAT_____</p> <p>UNSAT_____</p> |

ADMINISTRATIVE JOB PERFORMANCE MEASURE

| | |
|--|--|
| <p><u>STEP 7:</u> (SP-303 Enclosure 3 Step 5)</p> <p>Calculate adjusted out-of-core tilt (AOT) for each quadrant.</p> <p><u>STANDARD:</u></p> <p>Candidate accurately calculates AOT for each quadrant.</p> <p><u>EXAMINER NOTE:</u></p> <p>Values must be ± 0.1 of values listed on attached key.</p> <p><u>COMMENTS:</u></p> | <p>Critical Step</p> <p>Basis: Accurate calculation of AOT for each quadrant</p> <p>SAT_____</p> <p>UNSAT_____</p> |
| <p><u>STEP 8:</u> (SP-303 Enclosure 3 Step 6)</p> <p>Record AOT values for each Quadrant in Table 3.</p> <p><u>STANDARD:</u></p> <p>Candidate accurately transfers data to Table 3.</p> <p><u>COMMENTS:</u></p> | <p>SAT_____</p> <p>UNSAT_____</p> |

ADMINISTRATIVE JOB PERFORMANCE MEASURE

| | |
|--|---|
| <p>STEP 9: (SP-303 Step 4.2.2)</p> <p>Compare the current AOT for each quadrant to the Power Range Channels QPT limit in the COLR.</p> <p><u>STANDARD:</u></p> <p>Candidate determines that Quadrant ZW AOT exceeds a COLR Power Range Channel QPT limit (above the Transient Limit and below the Maximum Limit) and notifies the CRS to take appropriate actions of Technical Specification 3.2.4.</p> <p><u>COMMENTS:</u></p> | <p>Critical Step</p> <p>Basis: Accurate comparison to the COLR and notification of the CRS is required to comply with TS.</p> <p>SAT _____</p> <p>UNSAT _____</p> |
| <p><u>TERMINATION CUE:</u> Quadrant AOT calculations and comparison to COLR limits complete.</p> | |
| <p align="center"><u>RO</u> - END OF TASK</p> | |
| <p>STEP 10: (SRO Only)</p> <p>Refer to TS 3.2.4, Quadrant Power Tilt, and determine required actions.</p> <p><u>STANDARD:</u></p> <p>Candidate determines that the following actions are required (Condition D):</p> <ol style="list-style-type: none"> 1. Reduce THERMAL POWER to < 60% of the ALLOWABLE THERMAL POWER within 2 hours. 2. Reduce nuclear overpower trip setpoint to \leq 65.5% of the ALLOWABLE THERMAL POWER within 10 hours. <p><u>COMMENTS:</u></p> | <p>Critical Step</p> <p>Basis: TS required actions</p> <p>SAT _____</p> <p>UNSAT _____</p> |

ADMINISTRATIVE JOB PERFORMANCE MEASURE

| | |
|--|--|
| <u>TERMINATION CUE:</u> TS required actions determined. | |
| <u>SRO</u> - END OF TASK | |

TIME STOP _____

ADMINISTRATIVE JOB PERFORMANCE MEASURE

ENCLOSURE 3
(Page 2 of 2)

| TABLE 3 | | | | | | | | | | | | | | Date _____ |
|--------------------------------------|---------|-------|-------|--------------|---------|---|-----|-----|---------|---|-----|-----|---|------------|
| Current Out-Of-Core QPT Calculations | | | | | | | | | | | | | | |
| Time | | | | | | | | | | | | | | |
| | Step | 1 | 2 | 4 | 6 | 1 | 2 | 4 | 6 | 1 | 2 | 4 | 6 | |
| Quadrant / NI | NI Pwr | N | OCD | AOT | NI Pwr | N | OCD | AOT | NI Pwr | N | OCD | AOT | | |
| WX / NI-5 | 62 | +0.10 | -3.13 | -3.03 | | | | | | | | | | |
| YZ / NI-6 | 63 | -1.57 | -1.56 | -3.13 | | | | | | | | | | |
| XY / NI-7 | 63 | +0.10 | -1.56 | -1.46 | | | | | | | | | | |
| ZW / NI-8 | 68 | +1.37 | +6.25 | +7.62 | | | | | | | | | | |
| ΔT_c | 0.3 °F | | | | °F | | | | °F | | | | | |
| Reg Rod Index | 245 %wd | | | | %wd | | | | %wd | | | | | |
| Performed by: | _____ | | | | _____ | | | | _____ | | | | | |
| | Initial | | | | Initial | | | | Initial | | | | | |
| Verified by: | _____ | | | | _____ | | | | _____ | | | | | |
| | Initial | | | | Initial | | | | Initial | | | | | |

Where:

NI Pwr = Out-of-Core Nuclear Inst Power (%)

N = Normalization Factor (%)

OCD = Out-of-Core Detector Tilt (%)

AOT = Adjusted Out-of-Core Detector Tilt (%)

ADMINISTRATIVE JOB PERFORMANCE MEASURE

CANDIDATE CUE SHEET

(TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

INITIAL CONDITIONS

You are the Balance of Plant Operator.
The plant has been stable at this power level for the previous 3 hours.
The Symmetrical Incore Detector System is inoperable.
Current NI values from the control console are:
NI-5 = 62%
NI-6 = 63%
NI-7 = 63%
NI-8 = 68%
 $\Delta T_c = 0.3^\circ \text{ F}$
Rod Index is 245%.

INITIATING CUES

The Control Room Supervisor has directed you to calculate current out-of-core QPT using SP-303, Tilt Monitoring with an Unavailable Symmetric Incore System. Enter AOT (adjusted out-of-core tilt) values below and document additional actions, if any, you would perform.

SP-303, Enclosure 1, Table 1 is attached.

NI-5 AOT = NI-6 AOT = NI-7 AOT = NI-8 AOT =

SROs only: After calculating AOT, determine if any TS actions are required. Document your answer below.

ADMINISTRATIVE JOB PERFORMANCE MEASURE

ENCLOSURE 1
(Page 3 of 3)

Calculation of Normalization Constants

| TABLE 1 Normalization Constants | | | | |
|------------------------------------|----------|------------------|------------------------|----------------------------|
| Quadrant/NI | Step 2 | Step 2 | Step 4 | Step 6 (IT - OCD) |
| | NI Power | Incore Tilt (IT) | Out-of-Core Tilt (OCD) | Normalization Constant (N) |
| WX / NI-5 | 55 | +0.10 | 0 | +0.10 |
| YZ / NI-6 | 56 | +0.25 | +1.82 | -1.57 |
| XY / NI-7 | 55 | +0.10 | 0 | +0.10 |
| ZW / NI-8 | 54 | -0.45 | -1.82 | +1.37 |

Step 7:

Normalization calculations from: Control Console / Yesterday
Source / Date

ΔT_c at the time of the source data: 0 °F

Regulating Rod index at the time of the source data: 240 %wd

Enclosure 1:

Performed by: AK / Yesterday / 0100
Initial / Date / Time

Verified by: GQ / Yesterday / 0130
Initial / Date / Time

**CRYSTAL RIVER UNIT 3
JPM COVER SHEET**

ADMIN JPM #RC1

NRC 2011

RO / SRO

DETERMINE STAY TIMES USING SURVEY MAPS

PREPARED/REVIEWED BY: Jim Gregitis

Date: 05/24/11

VALIDATED BY: B. Wooten / B. Webster / R. Virgin

Date: 07/07/11

APPROVAL BY: Mark VanSicklen
(Nuclear Training Supervisor)

Date: 07/27/11

CONCURRED BY: Mike Kelly
(Operations Representative)

Date: 07/28/11

Validation is not required for minor enhancements, procedure revisions that do not affect the JPM or individual step changes that do not affect the flow of the JPM.

Operations concurrence is required for new JPMs and changes that affect the flow, critical steps or time critical steps of the JPM. Operations concurrence is not required for changes that are required due to a procedure revision.

ADMINISTRATIVE JOB PERFORMANCE MEASURE

JPM #: Admin RC1 - NRC 2011

Task: Determine stay times using survey maps.

Alternate Path: YES NO

PRA Top Critical Action: YES NO

Safety Function: NA

K/A Rating/Importance: G2.3.4 RO 3.2 SRO 3.7

Task Number: 1190102008 - RO

Position: SRO ONLY RO/SRO NLO/RO/SRO

Task Standard: Determine stay times using survey maps.

Preferred Evaluation Location:

SIM PLANT ADMIN

Preferred Evaluation Method:

PERFORM SIMULATE

References:

DOS-NGGC-0004, Rev 12

Validation Time: 15 minutes

Time Critical: YES NO

=====
Candidate: _____
Printed Name

Time Start: _____

Time Finish: _____

Performance Rating: SAT UNSAT

Performance Time: _____

Examiner: _____
Printed Name

Signature / _____
Date

Comment: _____

ADMINISTRATIVE JOB PERFORMANCE MEASURE

SIMULATOR OPERATOR SETUP INSTRUCTIONS

1. None

SIMULATOR OPERATOR INSTRUCTIONS

1. None

TOOLS/EQUIPMENT/PROCEDURES NEEDED

1. Consumable copies of DOS-NGGC-0004, Rev 12
2. Calculators

ADMINISTRATIVE JOB PERFORMANCE MEASURE

READ TO THE OPERATOR

INITIAL CONDITIONS

You are the Primary Plant Operator.

The plant is at full power.

INITIATING CUES

Using the supplied survey map, determine the individual stay times for yourself and another PPO without exceeding the annual administrative dose limit. (Do not consider dose received during transit).

You have an accumulated annual Whole Body dose of 1790 mR (Progress Energy). The other PPO has an accumulated annual Whole Body dose of 1800 mR (Progress Energy). No additional dose has been received at any other site.

A hot spot has developed on MUP-1C ("C" Make-up Pump). You will be flushing the pump through a drain valve on the north side of MUP-1C.

Calculations should be based on Progress Energy Administrative Dose Limits. Do not consider ALARA Task requirements. No dose extensions have been approved by the Site Vice President.

ADMINISTRATIVE JOB PERFORMANCE MEASURE

EXAMINER'S NOTE: FOR STEPS DENOTED AS "CRITICAL STEP", WHICH HAVE MULTIPLE ACTIONS, THE INDIVIDUAL REQUIRED ACTION WILL BE DENOTED "CS". IF NO INDIVIDUAL ACTIONS ARE DENOTED AS SUCH THEN ALL ACTIONS WITHIN THE STEP ARE DEEMED "CRITICAL".

TIME START _____

| | |
|---|---|
| <p><u>STEP 1:</u></p> <p>Candidate uses survey map to determine stay times.</p> <p><u>STANDARD:</u></p> <p>Candidate determines the stay time for him/her is <u>3.5 hours</u> and that the stay time for the other PPO is <u>3.33 hours</u>.</p> <p>This is based on working in an area with a 60 mR field and a dose limit of 2 Rem.</p> <p><u>EXAMINER NOTE:</u></p> <p>If requested, provide candidate a copy of DOS-NGGC-0004.</p> <p>Calculations must be within ± 0.2 hours to pass the JPM.</p> <p><u>COMMENTS:</u></p> | <p>Critical Step</p> <p>Basis: Correct calculation required so dose limit will not be exceeded.</p> <p>SAT _____</p> <p>UNSAT _____</p> |
| <p><u>TERMINATION CUE:</u> Individual stay times calculated.</p> | |
| <p style="text-align: center;">END OF TASK</p> | |

TIME STOP _____

ADMINISTRATIVE JOB PERFORMANCE MEASURE

CANDIDATE CUE SHEET

(TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

INITIAL CONDITIONS

You are the Primary Plant Operator.

The plant is at full power.


INITIATING CUES

Using the supplied survey map, determine the individual stay times for yourself and another PPO without exceeding the annual administrative dose limit. (Do not consider dose received during transit).

You have an accumulated annual Whole Body dose of 1790 mR (Progress Energy). The other PPO has an accumulated annual Whole Body dose of 1800 mR (Progress Energy). No additional dose has been received at any other site.

A hot spot has developed on MUP-1C ("C" Make-up Pump). You will be flushing the pump through a drain valve on the north side of MUP-1C.

Calculations should be based on Progress Energy Administrative Dose Limits. Do not consider ALARA Task requirements. No dose extensions have been approved by the Site Vice President.



ALL DOSE RATES IN MREM/HR
UNLESS OTHERWISE NOTED
NO BETA RADIATION DETECTED
UNLESS OTHERWISE NOTED

* DENOTES CONTACT
READING

RA = RADIATION AREA
HRA= HIGH RADIATION AREA
CA= CONTAMINATED AREA
RMA= RAD MATERIAL AREA

— = BOUNDARY

⊗ = STEP OFF PAD

O/H= IN OVERHEAD

H = HEAD LEVEL DOSE RATE
W = WAIST LEVEL

= DRT

DRT 39 20 MREM/HR
DRT 40 45 MREM/HR
DRT 41 32 MREM/HR

DRT 42 70 MREM/HR
DRT 43 60 MREM/HR
DRT 44 5 MREM/HR

DRT 45 7 MREM/HR
DRT 46 6 MREM/HR
DRT 47 2 MREM/HR

**CRYSTAL RIVER UNIT 3
JPM COVER SHEET**

ADMIN JPM #EP1

NRC 2011

SRO ONLY

**DETERMINE EMERGENCY ACTION LEVEL AND
PROTECTIVE ACTION RECOMMENDATIONS**

Performed in Classroom

PREPARED/REVIEWED BY: Jim Gregitis Date: 05/24/11

VALIDATED BY: B. Wooten / R. Virgin Date: 07/07/11

APPROVAL BY: Mark VanSicklen Date: 07/27/11
(Nuclear Training Supervisor)

CONCURRED BY: Mike Kelly Date: 07/28/11
(Operations Representative)

Validation is not required for minor enhancements, procedure revisions that do not affect the JPM or individual step changes that do not affect the flow of the JPM.

Operations concurrence is required for new JPMs and changes that affect the flow, critical steps or time critical steps of the JPM. Operations concurrence is not required for changes that are required due to a procedure revision.

ADMINISTRATIVE JOB PERFORMANCE MEASURE

JPM #: Admin EP1 - NRC 2011

Task: Determine Emergency Actions Level and Protective Action Recommendations.

Alternate Path: YES NO

PRA Top Critical Action: YES NO

Safety Function: NA

K/A Rating/Importance: G2.4.41 RO 2.9 SRO 4.6
G2.4.44 RO 2.4 SRO 4.4

Task Number: 1150101001 – SRO

Position: SRO ONLY RO/SRO NLO/RO/SRO

Task Standard: Determine Emergency Action Level and Protective Action Recommendations to protect the public.

Preferred Evaluation Location:

SIM PLANT ADMIN

Preferred Evaluation Method:

PERFORM SIMULATE

References:

EM-202, Rev 94
EOP-03 Figure 2, Rev 16
EOP-07 Figure 1, Rev 16

Validation Time: 10 minutes

Time Critical: YES NO

Candidate: _____
Printed Name

Time Start: _____

Time Finish: _____

Performance Rating: SAT UNSAT

Performance Time: _____

Examiner: _____
Printed Name

Signature

Date

Comment: _____

ADMINISTRATIVE JOB PERFORMANCE MEASURE

SIMULATOR OPERATOR SETUP INSTRUCTIONS

1. None

SIMULATOR OPERATOR INSTRUCTIONS

1. None

TOOLS/EQUIPMENT/PROCEDURES NEEDED

1. Consumable copies of EM-202, Rev 94
2. Consumable copies of EOP-03 Figure 2, Rev 16
3. Consumable copies of EOP-07 Figure 1, Rev 16

ADMINISTRATIVE JOB PERFORMANCE MEASURE

READ TO THE OPERATOR

INITIAL CONDITIONS

You are the Shift Manager.

See attached plant data sheet.

INITIATING CUES

Determine the highest Emergency Action Level for the time line provided. Also determine the Protective Action Recommendations (PARs) required, *if any*. Document your answers below.

THIS JPM ***IS*** TIME CRITICAL

ADMINISTRATIVE JOB PERFORMANCE MEASURE

EXAMINER'S NOTE: FOR STEPS DENOTED AS "CRITICAL STEP", WHICH HAVE MULTIPLE ACTIONS, THE INDIVIDUAL REQUIRED ACTION WILL BE DENOTED "CS". IF NO INDIVIDUAL ACTIONS ARE DENOTED AS SUCH THEN ALL ACTIONS WITHIN THE STEP ARE DEEMED "CRITICAL".

TIME START _____

| | |
|---|-----------------------------------|
| <p><u>STEP 1:</u></p> <p>Obtain a copy of the correct procedure.</p> <p><u>STANDARD:</u></p> <p>Candidate obtains a copy of EM-202.</p> <p><u>EXAMINER NOTE:</u></p> <p>Provide candidate with copies of EM-202 and EOP figures.</p> <p><u>COMMENTS:</u></p> | <p>SAT_____</p> <p>UNSAT_____</p> |
|---|-----------------------------------|

ADMINISTRATIVE JOB PERFORMANCE MEASURE

| | | | | | | | |
|---|--|-----------|---|-------------|--------------|-------------|---|
| <p>STEP 2:</p> <p>Determine classification for the data provided.</p> <p>STANDARD:</p> <p>Candidate determines the classification using the Fission Product Barrier Matrix:</p> <table border="0"> <tr> <td>LOSS OF RCS (RM-G29 or 30 > 10 R/hr for 15 minutes or longer)</td> <td align="right">+4</td> </tr> <tr> <td>POTENTIAL LOSS OF CONTAINMENT (RB pressure > 30 psig with no Building Spray available)</td> <td align="right">+1.5</td> </tr> <tr> <td>TOTAL</td> <td align="right">+5.5</td> </tr> </table> <p align="center">SITE AREA EMERGENCY</p> <p>COMMENTS:</p> | LOSS OF RCS (RM-G29 or 30 > 10 R/hr for 15 minutes or longer) | +4 | POTENTIAL LOSS OF CONTAINMENT (RB pressure > 30 psig with no Building Spray available) | +1.5 | TOTAL | +5.5 | <p>Critical Step</p> <p>Basis: Protection of the public</p> <p>SAT_____</p> <p>UNSAT_____</p> |
| LOSS OF RCS (RM-G29 or 30 > 10 R/hr for 15 minutes or longer) | +4 | | | | | | |
| POTENTIAL LOSS OF CONTAINMENT (RB pressure > 30 psig with no Building Spray available) | +1.5 | | | | | | |
| TOTAL | +5.5 | | | | | | |

ADMINISTRATIVE JOB PERFORMANCE MEASURE

| | |
|--|-----------------------------------|
| <p>STEP 3:</p> <p>Determine “Protective Action Recommendations”.</p> <p>STANDARD:</p> <p>The standard for this JPM is that NO “Protective Actions Recommendations” for the general public are required based on a Site Area Emergency.</p> <p>EXAMINER NOTE:</p> <p>Candidate may refer to Enclosure 3 of EM-202. Protective Action Recommendations are applicable to General Emergencies only.</p> <p>Candidate may refer to Section 9.3 of EM-202, Emergency Coordinator’s Guide for Site Area Emergency, Step 9.3.4 and determine using Enclosure 2 that protective actions required for the Energy Complex are to perform assembly and accountability and instruct the fossil control rooms to report results to nuclear security.</p> <p>COMMENTS:</p> | <p>SAT_____</p> <p>UNSAT_____</p> |
| <p>TERMINATION CUE: Emergency Action Level determined and conclusion that NO Protective Action Recommendations for the general public are required.</p> | |
| <p style="text-align: center;">END OF TASK</p> | |

TIME STOP _____

ADMINISTRATIVE JOB PERFORMANCE MEASURE

CANDIDATE CUE SHEET

(TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

INITIAL CONDITIONS

You are the Shift Manager.

See attached plant data sheet.

INITIATING CUES

Determine the highest Emergency Action Level for the time line provided. Also determine the Protective Action Recommendations (PARs) required, *if any*. Document your answers below.

THIS JPM ***IS*** TIME CRITICAL

ADMINISTRATIVE JOB PERFORMANCE MEASURE

PLANT DATA SHEET

At 1330 today, the plant was at 100% power. The plant experiences a transient and the following time line of indications occur:

| | |
|--------------------|-------------|
| TIME | 1345 |
| RCS PRESSURE | 110 PSIG |
| PRESSURIZER LEVEL | 0" |
| INCORES | 370° F |
| RX BLDG SPRAY FLOW | 0 GPM/TRAIN |
| RX BLDG PRESSURE | 48 PSIG |
| RM - G29 & 30 | 15 R/HR |

| | |
|--------------------|-------------|
| TIME | 1400 |
| RCS PRESSURE | 110 PSIG |
| PRESSURIZER LEVEL | 0" |
| INCORES | 360° F |
| RX BLDG SPRAY FLOW | 0 GPM/TRAIN |
| RX BLDG PRESSURE | 47.3 PSIG |
| RM - G29 & 30 | 18 R/HR |

The containment is intact and no release is in progress.

Based on the above information, identify the appropriate EAL and PARs, if required.

FOR THIS EXERCISE DO NOT USE ANY EC DISCRETION!