



**UNITED STATES
NUCLEAR REGULATORY COMMISSION
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
WASHINGTON, DC 20555 - 0001**

November 30, 2011

MEMORANDUM TO: ACRS Members

FROM: John Lai, Senior Staff Engineer /RA/
Technical Support Branch
Advisory Committee on Reactor Safeguards

SUBJECT: CERTIFICATION OF THE MINUTES OF THE MEETING OF THE
SUBCOMMITTEE OF RELIABILITY AND PRA ON MODIFYING
RISK-INFORMED REGULATORY GUIDANCE FOR NEW
REACTORS ON SEPTEMBER 20, 2011, IN ROCKVILLE,
MARYLAND

The minutes for the subject meeting were certified on November 3, 2011. Along with the transcripts and presentation materials, this is the official record of the proceedings of that meeting. A copy of the certified minutes is attached.

Attachment: As stated

cc w/o Attachment: E. Hackett
C. Santos

cc w/ Attachment: ACRS Members



**UNITED STATES
NUCLEAR REGULATORY COMMISSION
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
WASHINGTON, DC 20555 - 0001**

MEMORANDUM TO: John Lai, Senior Staff Engineer
Technical Support Branch
Advisory Committee on Reactor Safeguards

FROM: John W. Stetkar, Chairman /RA/
Subcommittee on Reliability and PRA

SUBJECT: CERTIFICATION OF THE MINUTES OF THE MEETING OF THE
SUBCOMMITTEE OF RELIABILITY AND PRA ON MODIFYING
RISK-INFORMED REGULATORY GUIDANCE FOR NEW
REACTORS ON SEPTEMBER 20, 2011, IN ROCKVILLE,
MARYLAND

I hereby certify, to the best of my knowledge and belief, that the minutes of the
subject meeting on September 20, 2011, are an accurate record of the proceedings for
that meeting.

_____/RA/_____
John W. Stetkar, Chairman
Subcommittee on Reliability and PRA

Date 11/3/11

Certified By: John W. Stetkar
Certified on November 3, 2011

**ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
MINUTES OF THE MEETING OF THE SUBCOMMITTEE ON RELIABILITY AND
PRA ON MODIFYING RISK-INFORMED REGULATORY GUIDANCE FOR NEW
REACTORS ON SEPTEMBER 20, 2011, IN ROCKVILLE, MARYLAND**

INTRODUCTION

On September 20, 2011, the ACRS Subcommittee on Reliability and PRA held a meeting in Room T-2B1, 11545 Rockville Pike, Rockville, Maryland. The purpose of the meeting was to hear the staff's proposed approach, progress made to date and future plans to address the Commission's Staff Requirements Memorandum on SECY 10-0121 regarding risk-informed regulatory guidance for new reactors. Mr. John Lai was the designated federal official for this meeting. The subcommittee received no request from the public to make oral statements. The entire meeting was open to the public. The Subcommittee chairman convened the meeting at 8:30am and adjourned at 2:30pm.

ATTENDEES

ACRS Members

John Stetkar, Subcommittee Chairman
Dennis Bley, Member
Said Abdel-Khalik, Member
William Shack, Member
Joy Rempe, Member
Gordon Skillman, Member

ACRS Staff

John Lai, Designated Federal Official

NRC Staff

Donald Dube, NRO/DSRA
Charles Ader, NRO/DSRA
Eric Powell, NRO/DSRA
Steven Dinsmore, NRR/DRA
Bob Tjader, NRR/DRA
Andrew Howe, NRR/DRA
Hanh Phan, NRO/DSRA
Lynn Mrowca, NRO/DSRA
Rani Franovich, NRR/DIRS
Jigar Patel, NRR/DRA
Ron Frahm, NRR/DIRS
Chris Hunter, RES/DRA
Mark Lombard, NRO/DSRA
Jonathan DeGange, NRO/ARP

Others

Russ Bywater, Mitsubishi

Biff Bradley, NEI

Futoshi Tanaka, Mitsubishi

Patrick O'Regan, EPRI

SUMMARY OF THE MEETING

Major Issues discussed during the meeting are described in the following Table.

Table 1. Major Issues Discussed During the Meeting

Major Issues Discussed	
Issue	Reference Pages in Transcript
Don Dube of NRC stated that some vendors, AREVA in particular, did some scoping calculations for 50.69 applications.	12
Don Dube stated that all of the new reactor change processes are going to be put in one new appendix (Appendix C) of the NEI guidance (NEI 96-07).	14
Chairman Stetkar asked how to determine a "significant" increase for risk metrics. Don Dube replied that if the staff found a large gap between new reactors and current operating fleet, the staff would propose a new risk metric and provide the Commission with a technical basis for determining the definition of "significant".	18
Member Bley asked what the change process is for reactors licensed under Part 52. Don replied that the change will be a 50.59-like process in the sense that it asks the same questions but the new reactors will have additional regulations to insure that the results of the change will not have substantial increase in probability or probable consequences of an ex-vessel accident. The change process is described in the certified design rules and guidance will be added to NEI 96-07.	23
Chairman Stetkar asked why a topical report on PRA adequacy for ISI (Inservice Inspection) is needed. Don replied that it defined the supporting requirements for specific capability category for ISI. It could apply to general applications but it is only applied to ISI now.	26
Don stated that a number of programs remain in place to address degradation mechanisms such as flow-accelerated corrosion and microbiologically induced corrosion regardless of the ASME ISI.	56-57
Chairman Stetkar asked why the new plants could not begin implementing risk-informed ISI immediately. Don replied that it is partly due to the cautiousness of the staff.	60
Don described the benefits of Risk Informed Tech Specs (RITS) Initiative 5(b) for optimization of surveillance frequencies.	69-71

Members and staff discussed the experience and insights from the operating reactors on the implementation of RITS 5(b). The process involves evaluating proposed changes, implementing, and monitoring. The change of test intervals will be in phases, for example, monthly-to-quarterly-to-annual.	73-79
Don stated that the key to the success of RITS 5(b) is continuous monitoring and feedback. The Integrated Decision-making Panel (IDP) review of proposed changes enhanced the effectiveness of the RITS 5(b) program.	89
Member Bley, staff and NEI representative discussed how one evaluates the effects of RITS 5(b) changes on defense-in-depth attributes.	91-94
Don discussed the change process for new reactors under Part 52. Changes to Tier 1 and most Tier 2* information require prior NRC approval. Changes to Tier 2 information can be made without NRC approval. However, changes to Tier 2 information must specifically address the effects on ex-vessel severe accident (EVSA) design features.	96-112
Chairman Stetkar and Don discussed how a change that affects containment bypass should be treated for new reactors. Don stated that it would be evaluated under VIII.B.5.b as a fallback but it doesn't strictly satisfy the regulatory definition of an ex-vessel severe accident design feature.	102-103
Don discussed how to evaluate "substantial increase" by giving some examples.	119-126
Eric Powell of NRC discussed the RITS Initiative 4(b) results using the ABWR SPAR model by allowing different combinations of equipment out of service.	132-139
Eric discussed the results using the AP1000 SPAR models by allowing different combinations of equipment out of service.	141-142
Members and staff discussed the current practice of allowing outage times that are extended beyond Tech Specs limits. The staff noted that current guidance does not allow voluntary entry into a condition that disables a required safety function.	142-148
Eric discussed the vendors' calculation results for US EPR, ESBWR, AP1000 and US-APWR programmatic controls under RITS 4(b).	148-152
Eric presented the preliminary results of RITS 4(b). The staff identified the need for an enhanced definition of loss of safety function in NEI 06-09.	152-154
Don stated that the staff is comfortable about the RITS 4(b) program if loss of safety function can be well defined.	162
Eric presented the results of applying the Maintenance Rule (MR) (a)(4) to regular TS and RITS 4(b) for both ABWR and AP1000. Results showed that the number of cases in the same risk metrics region under RITS 4(b) is different from those in regular TS for ABWR, but are the same for AP1000. The reason is that the regular Tech Specs are very restrictive for the smaller complement of safety-related equipment in the AP1000.	165-167

Eric discussed the plans for future tabletop exercises including the ROP applications and schedules for the draft Commission paper.	169-174
Biff Bradley of NEI stated that some risk applications (e.g., Maintenance Rule) will be implemented at initial start up and others like Risk-informed ISI will have to wait but should also be implemented at the beginning of operation for new reactors.	177-180
Members stated that there are no issues to bring to the Full Committee at this time. Members also noted that there are no apparent reasons why these risk-informed applications cannot be implemented at the start of operations for new reactors.	189-191

Table 2. Action Items

ACTION ITEMS	
Action Item	Reference Pages in Transcript
None	

BACKGROUND MATERIALS PROVIDED TO THE SUBCOMMITTEE

1. SECY-10-0121, "Modifying the Risk-informed Regulatory Guidance for New Reactors", September 14, 2010(ML102230076).
2. Staff Requirements – SECY-10-0121- Modifying the Risk-informed Regulatory Guidance for New Reactors, March 2, 2011(ML110610166).
3. Ex-Vessel Severe Accidents Public Meeting Summary, dated January 31, 2011 (ML110130408).
4. Kick-off Public Meeting Summary Package, dated March 28, 2011(ML110840607).
5. Risk-Informed Inservice Inspection of Piping (RI-ISI) Public Meeting Summary Package, dated May 12, 2011(ML111330381).
6. Risk-informed Technical Specifications, Initiative 4b (RITS 4b) Public Meeting Summary Package, dated June 21, 2011(ML111721655).
7. Risk-informed Technical Specifications, Initiative 4b (RITS 4b) second Public Meeting Summary Package, dated June 22, 2011(ML111650341).
8. Risk-informed Technical Specifications, Initiative 5b (RITS 5b) Public Meeting Summary Package, dated July 6, 2011 (ML11182A976).

NOTE:

Additional details of this meeting can be obtained from a transcript of this meeting available in the NRC Public Document Room, One White Flint North, 11555 Rockville Pike, Rockville, MD, (301) 415-7000, downloading or view on the Internet at

<http://www.nrc.gov/reading-rm/doc-collections/acrs/> or it can be purchased from Neal R. Gross and Co., 1323 Rhode Island Avenue, NW, Washington, D.C. 20005, (202) 234-4433 (voice), (202) 387-7330 (fax), nrgross@nealgross.com (e-mail).

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
Reliability and Probabilistic Risk Assessment

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Tuesday, September 20, 2011

Work Order No.: NRC-1152

Pages 1-191

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

SUBCOMMITTEE ON RELIABILITY AND

PROBABILISTIC RISK ASSESSMENT

+ + + + +

TUESDAY

SEPTEMBER 20, 2011

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B1, 11545 Rockville Pike, at 8:30 a.m., John
Stetkar, Chairman, presiding.

SUBCOMMITTEE MEMBERS PRESENT:

JOHN W. STETKAR, Chairman

SAID ABDEL-KHALIK

DENNIS C. BLEY

JOY REMPE

WILLIAM J. SHACK

GORDON R. SKILLMAN

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

NRC STAFF PRESENT:

JOHN LAI, Designated Federal Official

CHARLES ADER

DONALD DUBE

ERIC POWELL

STEPHEN DINSMORE

BOB TJADER

ANDREW HOWE

ALSO PRESENT:

PATRICK O'REGAN

BIFF BRADLEY

RUSS BYWATER

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

A-G-E-N-D-A

Opening Remarks 4

Introduction and Staff's Approach to Respond to
Commission SRM 5

Tabletop Exercises of Risk-Informed Inservice
Inspection of Piping 24

Tabletop Exercises of Risk-Informed Technical
Specifications Initiative (RITS) 5b 66

"Substantial Increase" in Probability and Public
Consequences of Ex-Vessel Severe Accidents per Section
VIII.B.5.c of Part 52 Appendices 97

Tabletop Exercises of Risk-Informed Technical
Specifications Initiative (RITS) 4b and Maintenance
Rule 50.65(a)(4) 129

Stakeholder Perspectives on Insights from Tabletop
Exercises 168

NEI Presentation 175

Public Comments 187

Member Discussion 188

P R O C E E D I N G S

8:30 a.m.

1
2
3 CHAIR STETKAR: The meeting will now come
4 to order. This is a meeting of the Reliability and
5 PRA Subcommittee. I'm John Stetkar, chairman of the
6 subcommittee meeting. ACRS members in attendance are
7 Said Abdel-Khalik, Dick Skillman, Dennis Bley, Bill
8 Shack and Joy Rempe. John Lai of the ACRS staff is
9 the designated federal official for this meeting. The
10 subcommittee will hear the staff's proposed approach,
11 progress made to date and future plans to address the
12 Commission's Staff Requirements Memorandum of March
13 2nd, 2011, on SECY-10-0121 regarding risk-informed
14 regulatory guidance for new reactors. We'll hear
15 presentations from the NRC staff and an NEI
16 representative. There will be a phone bridge line.
17 To preclude interruption to the meeting the phone will
18 be placed in a listen-in mode during the presentations
19 and committee discussions. We've received no written
20 comments or requests for time to make oral statements
21 from members of the public regarding today's meeting.
22 The entire meeting will be open to public attendance.

23 The subcommittee will gather information,
24 analyze relevant issues and facts and formulate
25 proposed positions and actions as appropriate for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 deliberation by the full committee. The rules for
2 participation in today's meeting have been announced
3 as part of the notice of this meeting previously
4 published in the Federal Register. A transcript of
5 the meeting is being kept and will be made available
6 as stated in the Federal Register notice. Therefore,
7 we request the participants in this meeting use the
8 microphones located throughout the meeting room when
9 addressing the subcommittee. The participants should
10 first identify themselves and speak with sufficient
11 clarity and volume so that they may be readily heard.
12 We will now proceed with the meeting and I call upon
13 Charles Ader to begin the presentations. Charlie?

14 MR. ADER: Actually I was just going to
15 turn it over to Don. I have no opening.

16 CHAIR STETKAR: Well, that's good, we're
17 going to finish early.

18 (Laughter)

19 MR. ADER: Take it away, Don.

20 MR. DUBE: Thank you, John and members of
21 the subcommittee. I want to acknowledge Eric Powell
22 has really done a lot on project management activities
23 as well as a lot of the risk-informed tech spec
24 initiative 4b analyses. And also I want to
25 acknowledge other NRO divisions and offices within the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 NRC tech spec, NRR Division of Inspection of Regional
2 Support, Division of Risk Assessment and Office of
3 Research. It's been a collaborative effort. And also
4 we've had extensive support of stakeholders,
5 particularly new reactor vendors. Consultants and
6 licensees have spent a lot of time and did a lot of
7 calculations and I think you've seen some of those and
8 we'll be presenting some of that material. So, it's
9 been a very busy six months but in many ways it's been
10 rewarding in that a lot of interesting insights have
11 come about. So we'll be sharing a portion of that,
12 those insights with you this morning and afternoon.
13 So again, thank you for this opportunity.

14 So as John mentioned it's a progress
15 report. We discussed a few months ago whether we
16 should drop all this material on you later, I mean
17 earlier next year when we expect to have a draft
18 commission paper on the options and decided that
19 there's just so much material that we will have this
20 interim progress report. But you'll see us again in
21 a few months when we start getting close to options.
22 So this is an informational meeting as I said to
23 present the material. So for those of you who are not
24 familiar we'll provide some background on the
25 commission paper and the staff requirements

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 memorandum. We'll go through the tabletop exercises
2 through end of July. We'll talk about the next steps
3 and there's opportunity for stakeholder inputs,
4 although I think right now NEI has prepared remarks.

5 So over the next four or five slides I
6 tend to go a little bit fast in the sense that this
7 historical will bring everybody up to speed. There's
8 a number of risk-informed applications for new
9 reactors that are proposed or pending. There's an
10 Electric Power Research Institute research program and
11 risk-informed inservice inspection of piping, it's a
12 follow-on to the program for current reactors.
13 Comanche Peak 3 and 4 combined license application has
14 interest in risk-informed tech spec 4b and 5b and it's
15 under review by the staff right now and there's been
16 interest in 50.69. That's the categorization of
17 structure systems and components. The staff issued a
18 white paper over two years ago that expressed some
19 concerns, especially on the reactor oversight process.
20 We will not discuss reactor oversight process today
21 but we do have a tabletop coming up in two weeks so
22 that'll be pretty interesting. There was a commission
23 paper about a year ago with options for a commission
24 vote. The commission briefing was held in October of
25 last year and there was a staff requirements

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 memorandum in March of this year.

2 MEMBER BLEY: Are you going to tell us
3 anything about that tabletop and what you anticipate?
4 How it's planned?

5 MR. DUBE: We can.

6 MEMBER BLEY: Okay, thanks.

7 MR. DUBE: If we can remember. The short-
8 term memory is challenging.

9 MEMBER SHACK: The maintenance rule is one
10 that every new reactor's going to have to live with.

11 MR. DUBE: Yes.

12 MEMBER SHACK: And yet it doesn't seem to
13 have made your tabletop.

14 MR. DUBE: Yes, it did, sir.

15 MEMBER SHACK: It did?

16 MR. DUBE: It's there.

17 MR. POWELL: It's part of RITS 4b.

18 MEMBER SHACK: Oh it's, okay.

19 MR. POWELL: We did it as part of that
20 tabletop.

21 MEMBER SHACK: The (a) (4).

22 MR. DUBE: RITS 4b completion times and
23 maintenance rule 50.65(a) (4).

24 MEMBER SHACK: (a) (4) but not the rest of
25 the maintenance rule.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DUBE: No. So this has to do with me
2 using risk assessment of some sort to evaluate changes
3 in configuration.

4 MEMBER SHACK: I was just thinking of the
5 discussion we had on D-RAP. I mean, you still have
6 what structure system components are subject to the
7 maintenance rule which is going to have to be --

8 MR. DUBE: Addressed.

9 MEMBER SHACK: -- addressed.

10 MR. DUBE: Yes. So, very briefly, the
11 commission paper of a year ago, we discussed the
12 change processes and current guidance. Commission's
13 expectations and some policy papers and where Part 52
14 regulations differ from current fleet. We discussed
15 issues related to changes to licensing basis and the
16 reactor oversight process. We discussed interactions
17 with stakeholders and some options and staff
18 recommendations. There were three options that we
19 proposed. One was treat new reactors the same as
20 current fleet. We called that status quo. Second was
21 look at enhancements to the existing guidance. This
22 is what the staff recommended. And the third was a
23 little more radical which was develop actually lower
24 numeric thresholds for new reactors.

25 So the commission came out with an SRM in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 March which was a hybrid of options 1 and 2 which was
2 basically continue the existing risk-informed
3 framework but do these tabletop exercises to test the
4 guidance, kind of like a stress test I guess, to see
5 if there were any gaps in the existing guidance and
6 what changes if any we might propose. But the
7 commission did issue some pretty firm statements.
8 They reaffirmed the existing safety goals, safety
9 performance expectations, the subsidiary risk goals
10 and associated risk guidance, the key principles in
11 Reg Guide 1.174 as well as things like any change in
12 risk should be small, maintain defense-in-depth,
13 safety margin and so forth. And in fact the
14 commission even came out and said they reaffirmed the
15 quantitative metrics. So this kind of put a firm
16 boundary around the tabletop exercises if you will.
17 We tried to live within those boundaries as much as
18 possible.

19 The commission stated that they expected
20 advanced technologies will result in enhanced margins
21 of safety and as a minimum new reactors have the same
22 degree of protection of the public and environment as
23 the current fleet. They did state finally that the
24 new reactors with these enhanced margins and safety
25 features should have greater operational flexibility

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 than current reactors. So they said while they have
2 this additional margin because the risk profiles are
3 lower unless we demonstrated significant gaps that new
4 reactors should be able to use this margin for
5 flexibility in operation.

6 So the key deliverables in the SRM were a
7 brochure summarizing the commission policies and
8 decisions on new reactor performance. You haven't
9 seen this but there's a draft and it's going through
10 concurrence and it's pretty interesting. It will
11 summarize in layman's terms how the new reactor fleet
12 differ from the current reactors in terms of the risk
13 profiles and the expectations and some of the change
14 processes, how they differ. Guidance on 50.59-like
15 process for new reactors under Part 52. That's the
16 subject of one of the agenda items today. Tabletops
17 specifically on risk-managed tech specs, 50.69 and the
18 ROP were called out. And we'll do these except for
19 the 50.69 didn't make the cutoff but we have had that
20 tabletop already.

21 CHAIR STETKAR: You have had the 50.69
22 tabletop?

23 MR. DUBE: Yes.

24 CHAIR STETKAR: Oh, okay. Good.

25 MR. DUBE: We had that in mid-August,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 early August. And then a progress report every six
2 months, so we had a commission TA brief in mid-August.
3 There will be another one in September. And then the
4 real big deliverable commission paper with specific
5 recommendations by June 2012. We've actually targeted
6 end of May.

7 CHAIR STETKAR: Don, was the 50.69, it was
8 done with the new reactor models?

9 MR. DUBE: Well, we didn't really do much
10 in the way of quantitative analysis.

11 CHAIR STETKAR: Yes, that's what I was
12 going to ask. You did though with the other ones. In
13 terms of what Bill Shack raised of the written is for
14 the passive designs or the D-RAP list for the active
15 designs. You didn't do anything in terms of trying to
16 see how?

17 MR. DUBE: Well, some reactor vendors,
18 AREVA in particular, did do some scoping calculations
19 for I believe an AP -- well, they didn't say who it
20 was, but a passive plant and an active plant. And at
21 this time we can -- some prepared remarks but at the
22 time we could talk about it later. And one of the key
23 participants, Pat O'Regan, who's with Electric Power
24 Research Institute supported that. So you know, we
25 could give some discussion later.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Okay.

2 MEMBER SKILLMAN: Don, my name is Dick
3 Skillman. I'm a new member here and request you to go
4 back to slide 8 please, last line. Could you give an
5 example of what you meant by greater operational
6 flexibility than current reactors, please?

7 MR. DUBE: We'll talk about this in risk-
8 informed tech specs, but right now in the risk-
9 informed tech specs there's guidance in terms of when
10 one removes equipment from service there is an
11 increase in the instantaneous Core Damage Frequency if
12 you will. If you're a current reactor with a baseline
13 Core Damage Frequency in the several times 10^{-5} per
14 year for example that's typical. The amount of time
15 that could remove equipment from service will be
16 constrained by these staying to the incremental core
17 damage probability whereas the current tech specs may
18 be let's say three days or seven days. If one does a
19 calculation they may be able to increase that to 10 or
20 14 days or 21 days. For the new reactor fleet with
21 baseline core damage frequencies were more orders of
22 magnitude lower. If you do the calculations they
23 could have, you know, longer completion times and
24 that's an example of providing this margin to the new
25 reactor fleet, that gives them more flexibility to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 remove the equipment from service. But what you also
2 find is that in the new fleet, the current reactors
3 typically have two trains of Emergency Core Cooling
4 System and some of the access safeguards. All of the
5 new designs pretty much, well certainly the active
6 designs have at least three trains and often four
7 trains. So that third and fourth train is the
8 additional margin and the commission says it built in
9 this extra margin, it should have more operational
10 flexibility for online maintenance and so forth.

11 MEMBER SKILLMAN: Thank you. Thank you.
12 Got it.

13 MR. DUBE: Okay. So on slide 10, briefly,
14 the staff's approach was to leverage -- there was an
15 effort underway even before the SRM on the NEI 96-07.
16 This is guidance on the 50.59-like process and what's
17 been decided by industry and agreed to by the staff is
18 all of the new reactor change processes are going to
19 be put in one new Appendix C to the NEI guidance.
20 It's going to be like one-stop shopping if you will
21 for the change processes for new reactors because
22 there's additional guidance and regulations in fact
23 for new reactors that you don't have for current
24 reactors. So we decided to put all the change
25 processes, everything from loss of large area due to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fires to ex-vessel severe accident change processes,
2 all this is going to be in one appendix. That
3 approval is under way anyway so we decided for this
4 50.59 process our little working group would piggyback
5 on that effort.

6 CHAIR STETKAR: That's going to cover --
7 I guess I haven't followed that at all. That's going
8 to cover you said everything. Everything.

9 MR. DUBE: One-stop shopping.

10 CHAIR STETKAR: Okay.

11 MR. DUBE: Now it may refer one to other
12 regulations in the guidance, but everything will be in
13 one appendix. So we're leveraging off that. The
14 document, the brochure, the public information
15 document is being done within the Office of New
16 Reactors, within Charlie Ader's organization. There
17 is an effort under way to review the APWR risk-managed
18 tech specs so we're leveraging off that. We decided
19 to do 50.69 and a risk-informed inservice inspection
20 of piping early on. ISI mainly because there was
21 consensus that I'll call it low-hanging fruit in the
22 sense of win-win so we thought we'd start with that
23 tabletop before we went on to some of the more
24 challenging ones like risk-informed tech specs and
25 ROP. So we'll talk about ISI very first thing,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 although as I said, 50.69 didn't make the cutoff for
2 this presentation today so we don't have prepared
3 remarks but we could talk a little bit about it.

4 We have SPAR models for AP1000 and ABWR so
5 we did a lot of the calculations in-house. Eric did
6 a lot but we also had support and for the ROP we're
7 doing a large number of calculations in-house and
8 we're comparing the results with the reactor vendors
9 for all our new reactor fleets have all done
10 calculations. Not the ABWR, we did that, but
11 certainly all the other designs, all the vendors have
12 done a large number of calculations.

13 CHAIR STETKAR: I'm sorry. Do those SPAR
14 models include internal fires, internal floods?

15 MR. DUBE: No.

16 CHAIR STETKAR: They're just --

17 MR. DUBE: The conventional internal
18 events at power.

19 CHAIR STETKAR: Okay. Thanks.

20 MR. DUBE: But at least we can benchmark.
21 But as part of the ROP and again, not a subject of
22 today, but we requested input from all the reactor
23 vendors on their external events that they've done so
24 we could augment those calculations. So that'll be
25 very interesting.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Yes, it will.

2 MR. DUBE: So we talked ROP. For that
3 we're using actual events and inspection findings and
4 MSPI results from the current fleet and saying what if
5 this happened at a new reactor or something similar.
6 I mean, sometimes it's not a perfect match but
7 something similar, a very similar kind of down
8 failure, diesel generator failure and so forth and
9 said if you had something similar for the same what
10 they call fault exposure time, in other words it was
11 in a failed condition, what if that occurred in the
12 new fleet. And we're getting interesting results,
13 surprising. And so we were instructed by the
14 commission in the SRM to use real, you know, realistic
15 plant modifications and configurations and not, you
16 know, highly theoretical configurations. So that's,
17 we tried to stay within those boundaries that the
18 commission gave us.

19 We have a few items, you know, as you're
20 familiar for licensing purposes. We use this metric
21 called Large Release Frequency whereas everybody else
22 in the current fleet uses Large Early Release
23 Frequency. And in our next tabletop which is October
24 5th the morning session will be, okay, if the
25 commission told us to use the same metrics for new

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reactors as current reactors. That means we have to
2 use Large Early Release Frequency for risk-informed
3 applications. So we're going to have to propose some
4 transitioning over. So we're going to talk about that
5 and we'll propose to the commission several options
6 for this transition. And then I mentioned the
7 commission paper. So that's real fast.

8 This is the approximate timeline. I won't
9 go through every little window and every diamond, but
10 we are pretty much on schedule I would say.

11 CHAIR STETKAR: Don?

12 MR. DUBE: Yes.

13 CHAIR STETKAR: I may have missed it.
14 There was one more thing from the SRM that I think
15 requested that you determine what is a significant
16 increase.

17 MR. DUBE: Yes.

18 CHAIR STETKAR: I didn't see that bullet
19 here. How are you doing on that?

20 MR. DUBE: If we find a significant
21 increase. You have to read the whole sentence I
22 guess, but if we were to as a result of these
23 exercises find that there's a large gap between
24 current new reactors and current fleet and were to
25 propose a new risk metric or some reason, some large

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 additional guidance that deviates substantially from
2 what currently exists we would have to provide the
3 commission with a technical basis and tell them what
4 we thought it meant, that definition.

5 CHAIR STETKAR: But I mean for now you're
6 operating under the kind of ground rules that
7 significant would be a challenge to the existing sort
8 of metrics that are in 1.174, right?

9 MR. DUBE: Yes, I mean there would --

10 CHAIR STETKAR: Not --

11 MR. DUBE: A significant decrease in the
12 enhanced safety of the new designs.

13 CHAIR STETKAR: Yes. Okay.

14 MR. DUBE: Up until now I would say it's
15 fair to say we have, there are some challenges but we
16 haven't, you know, reached any final conclusions on
17 it.

18 CHAIR STETKAR: Okay. I'm sure we'll hear
19 more about that.

20 MR. DUBE: But you'll see a couple
21 examples where it pushes the limit a little bit maybe.
22 So you know, for your purposes we will start the
23 commission paper draft and alignment meetings later
24 this year. Hope to have a draft commission paper this
25 timetable early next year, let's say February. You'll

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 get it, or ACRS will get a copy of the draft paper and
2 then I expect we will have another, at least one
3 subcommittee meeting.

4 CHAIR STETKAR: Yes, you'll want a letter
5 on that so we probably should have a subcommittee
6 meeting.

7 MR. DUBE: And so that's in that time
8 frame. So for planning purposes you know we're
9 looking at March, April the latest. So.

10 CHAIR STETKAR: And subcommittee probably
11 in February --

12 MR. DUBE: I'll work with John.

13 CHAIR STETKAR: Yes, work with John.

14 MEMBER BLEY: But you're not, from what
15 you've seen so far and what you see planned you don't
16 see any real problem areas coming up that could throw
17 off your plan?

18 MR. DUBE: Hopefully not.

19 MEMBER BLEY: Okay. There's nothing
20 you're really focused on?

21 MR. DUBE: Hopefully not. Got to get
22 alignment. We haven't gone through ROP. ROP will be
23 interesting, you know. I have support from DIRS in
24 case there's any questions on ROP.

25 So real quickly, before the SRM even came

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 out we had a tabletop on ex-vessel severe accident
2 features and the change process and we've worked that
3 into the discussion we had in August. We talked about
4 the draft guidance for ex-vessel severe accident
5 features and that will be a topic of discussion
6 because it was a follow-on to an earlier tabletop. So
7 you'll get to see that today.

8 We had a kickoff meeting in March and we
9 had tabletops, really aggressive schedule. May 4th we
10 did risk-informed inservice inspection of piping, we
11 had two full days on RITS 4b and maintenance rule May
12 26th and June 1st. We did both topics on both days.
13 The first day was mostly staff presentations but we
14 had, industry gave presentations on like online risk
15 monitoring and the, you know, (a)(4) and Eric will
16 talk about that. On the second day, the June 1st day,
17 all of the reactor vendors gave presentations or at
18 least verbal discussion on their results. So that was
19 a lot of work and so again I appreciate their
20 participation. We did a risk-informed tech spec 5b on
21 surveillance frequency control program. We'll talk
22 about that. And then 50.69 and the change process for
23 new reactors, August 9th. We had a prep meeting for
24 tabletop preparation where we proposed these realistic
25 scenarios for the SDP and the Significance

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Determination Process for inspection findings, the
2 mitigating systems performance index, Management
3 Directive 8.3 which is incident investigation. We
4 have outlined about a dozen cases, and if you look at
5 sub-cases there's probably going to be several dozen
6 actual calculations that are being done for the new
7 reactor fleet. And we're better than halfway through
8 those calcs now being done in-house with some of the
9 external events being done by the reactor vendors.
10 And we're going to have a half-day presentation
11 October 5th on that.

12 MEMBER BLEY: Hey, Don?

13 MR. DUBE: Yes.

14 MEMBER BLEY: Your 50.59-like process
15 makes me ask this question again. Has there been any
16 decisions formulated about what happens when a new
17 reactor actually becomes licensed and starts to
18 operate? Will they fall back under Part 50 or will
19 there be something different for the new reactors that
20 are licensed under, that are certified under 52?

21 MR. DUBE: Well, good question. Again,
22 we're putting everything in NEI 96-07 and that'll be
23 applicable to those who will hold a combined license.
24 They do have their own processes. It's 50.59-like in
25 the sense that it asks the same 50.59 questions. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you have this additional pilot regulation, pilot
2 certification on the ex-vessel severe accident that
3 says you know make sure that as a result of the change
4 this is not a substantial increase in probability or
5 probable consequences of an ex-vessel severe accident.
6 So that part is different. The other part that's
7 different is for new reactors the aircraft impact is
8 a regulation, right?

9 MEMBER BLEY: Yes.

10 MR. DUBE: So that's different. As I
11 said, there's this one-stop shopping in the NEI
12 guidance for all the change processes.

13 MEMBER BLEY: Yes, I was wondering from
14 NRC's side how that regulation is going to work
15 because we don't have anything like 50.59 under Part
16 52.

17 MR. DUBE: Yes, you still have it, right?

18 MR. ADER: Yes, each certified design has
19 its own change process and as Don says, it reads very
20 much like 50.59.

21 MEMBER BLEY: Okay, that's defined in the
22 rule itself?

23 MR. ADER: It's in the rule.

24 MEMBER BLEY: Okay.

25 MR. ADER: And there's two parts. There's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 one that looks like 50.59, they call it 50.59-like
2 process, and then there's the ex-vessel severe
3 accident change process.

4 CHAIR STETKAR: And those are all in the
5 rule itself.

6 MR. ADER: They're in each of the
7 certified rule, certified design rules.

8 MEMBER BLEY: Just one last thing along
9 that. Are they likely to belong -- to continue to
10 belong to NRO after they start up or are they going to
11 belong to -- since these things are covered in
12 different rules.

13 MR. ADER: I'm assuming for awhile but I
14 think we're four to five years away from that.

15 MEMBER BLEY: Okay. Fair enough.

16 MR. DUBE: And we mentioned the public
17 communications brochure. So that's a real quick
18 overview of where we are. Any questions up to date of
19 the background or the path that the staff's taken? If
20 not we can check off that agenda item and move on to
21 risk-informed inservice inspection of piping which was
22 the very first tabletop.

23 I want to emphasize that while these
24 tabletops, the discussion of the methodology was
25 provided and I would like to thank Electric Power

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Research Institute and their contractors for a lot of
2 this. It was not the purpose of this tabletop to
3 propose changes to methodology necessarily. It was to
4 say, okay, this is the methodology that's been applied
5 to current fleet. Now to take this methodology and
6 apply it to new reactor design, what does it mean in
7 terms of the impact on risk? Is there gaps? Could a
8 new reactor get away with too much or what have you?
9 What controls and limitations are in place? And a lot
10 of these are deterministic to make sure that there was
11 reasonable constraints other than just, you know,
12 delta risk. So that was the end goal. It wasn't to
13 say, okay, we think we need to make all these changes
14 to the current guidance. That was beyond the scope.

15 I'll give an overview of risk-informed ISI
16 again, not talking about methodology. These are the
17 key methodology and guidance documents. I'm not going
18 to go through them all but there was a Westinghouse
19 Owners Group approach, that's the WCAP, the EPRI
20 approach is in that topical report, 112657. There
21 have been some code cases, N716 streamlined approach.
22 Again, I'm not an expert in this area but fortunately
23 we do have EPRI representation. Pat O'Regan's very
24 familiar in case we get into those kind of details.
25 We've got several reg guides on the methodology 1178

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and then the 1174 which is kind of the umbrella
2 guidance. At this point new light water reactors
3 appear to be potentially interested in applying either
4 what's called the traditional approach or the
5 streamlined EPRI approach. But no one at this point
6 appears to be going in the -- using the Westinghouse
7 Owners Group approach. So even in AP1000 plants if
8 you were, a Westinghouse plant, appear to be headed in
9 that direction, so.

10 CHAIR STETKAR: That was old Westinghouse.

11 MR. DUBE: That makes it easier on the
12 staff. In addition, the staff is reviewing a topical
13 report on PRA technical adequacy which will be
14 applicable to the current and new light water
15 reactors. I'm not going to talk about that here, but
16 just for your background and information. And the
17 staff actually has a draft SER on that topic.

18 So wow, this is a lot on EPRI traditional
19 methodology. I won't do it justice, but go ahead.

20 CHAIR STETKAR: Just quickly before we get
21 into the chart. You mentioned there's a topical
22 report on PRA adequacy. Why, given the reg guides and
23 ASME standards, why is there a need for a separate
24 topical report on? Does it focus specifically on
25 applications?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DUBE: What supporting requirements,
2 what are the capability category for each supporting
3 requirement. Is it capability category 1, 2, or 3, 1
4 being one can use a more generic approach, less
5 detailed, category 3, more detailed. And so the
6 thought process here is the staff will endorse a
7 topical report with exceptions perhaps and a licensee
8 or COL holder who is interested in applying risk-
9 informed ISI can reference this and the staff will not
10 have to do an in-depth PRA review.

11 CHAIR STETKAR: Okay, but what I missed is
12 this is a topical report specifically on capability
13 categories for risk-informed ISI. So if you want to
14 do this you need capability category 2 in these areas
15 and your capability -- I thought it was more, the way
16 I heard it it sounded like a more generic topical
17 report on PRA quality.

18 MR. DUBE: It may, you know, it may
19 ultimately that framework may be used for let's say
20 50.69 or something. But one could generalize.

21 CHAIR STETKAR: Okay.

22 MR. DUBE: Right now it's just ISI.

23 CHAIR STETKAR: It's just ISI.

24 MR. DUBE: And I'm giving credit to EPRI
25 because I copied and pasted their slide from this but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it's part of the public record. This was the first
2 tabletop. So again, I'm not going to do it justice
3 but one first determines what the scope is. So they
4 may apply it to many systems or just Class 1 systems
5 or what have you in the, or Class 1 and 2. So each
6 licensee who wants to use the approach determines what
7 the scope is. It can perform consequence analysis
8 calculations and look at the potential failure
9 mechanisms of the piping. They perform a service
10 review which is operational experience. They
11 segmentize the piping, do the calculations in terms of
12 each segment of piping, what's the consequence of a
13 pipe break, what's the potential for a pipe break.
14 They select the elements for inspection and the
15 methods, perform a risk assessment impact and finalize
16 and do a continual feedback loop of performance
17 monitoring and adjusting as they go along. That's a
18 real quick overview. So it's nothing different and
19 you're probably seeing risk-informed ISI.

20 The, so we wanted to look at this as a
21 two-dimensional matrix. This is a busy slide but the
22 colors have significance. On the x-axis if you will
23 the consequence category. One uses conditional core
24 damage probability, conditional large early release
25 probability as a means of looking at the consequences

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of particular pipes. It can be none, low, medium and
2 high and I'll explain those numerical criteria in a
3 minute. And then on the y-axis if you will categorize
4 the segregation mechanisms as low, medium and high.
5 Degradation assessment, potential assessment. Then
6 there's partition all of the focus of points if you
7 will into high risk evaluation, medium or low.

8 For the y-axis or the degradation
9 mechanism pipe rupture potential is classified as
10 high, medium or low. Large is flow-accelerated
11 erosion, small are a number of degradation mechanisms
12 everywhere from thermal fatigue to the various forms
13 of stress corrosion, cracking. And if you really want
14 definitions of each acronym I could give it to you but
15 they've got big names like transgranular SCC which is
16 this --

17 CHAIR STETKAR: Dr. Shack is an expert.

18 (Laughter)

19 MR. DUBE: Okay.

20 CHAIR STETKAR: He speaks like that.

21 MR. DUBE: ECSCC external chloride.

22 Microbiologically induced or influenced corrosion,
23 that's the MIC erosion-cavitation and so forth. And
24 then the nine is no degradation mechanisms present.
25 So the potential piping location, the weld locations

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are categorized --

2 CHAIR STETKAR: Before you leave this, and
3 I have to admit I really actually don't know much
4 about risk-informed ISI. On this axis is there a
5 notion of frequency involved in this axis to some
6 extent? You know, why for example, primary water
7 stress corrosion stress cracking, why is that a medium
8 compared to flow-accelerated corrosion? Is it because
9 flow-accelerated corrosion tends to progress more
10 rapidly in the real world compared to the other
11 corrosion mechanisms?

12 MR. DUBE: I think there is the notion of
13 probability.

14 CHAIR STETKAR: Frequency?

15 MR. DUBE: Frequency, yes.

16 CHAIR STETKAR: Or weight or something
17 like that.

18 MR. DUBE: And mechanisms for detecting
19 this.

20 CHAIR STETKAR: Okay.

21 MEMBER SHACK: It also comes down to, I
22 mean flow-accelerated corrosion has a way of
23 essentially thinning the pipe in an overall thing that
24 you don't get leak before break. Most of these
25 cracking mechanisms generally tend to lead to leak

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 before break situations.

2 CHAIR STETKAR: Well, I'm thinking of like
3 buried piping systems for service water that might
4 leak but you might not really know a lot about it.

5 MEMBER SHACK: Even there, you know, it is
6 a tendency towards a more global kind of degradation
7 versus a more local kind of degradation.

8 CHAIR STETKAR: I was just curious because
9 you know the two ordinates in the matrix there really
10 don't have a notion of frequency. They're just, you
11 know --

12 MEMBER SHACK: Well I think it's a
13 frequency of rupture. I wouldn't say it's a frequency
14 of occurrence.

15 CHAIR STETKAR: Well, that's --

16 MEMBER BLEY: It almost seems though it's
17 a combination of likelihood with extent of --

18 MEMBER SHACK: Right.

19 CHAIR STETKAR: I was just curious what
20 sort of thought process went into --

21 MR. DUBE: Well, I think Dr. Shack hit it
22 right on the head. Yes.

23 CHAIR STETKAR: Okay.

24 MEMBER ABDEL-KHALIK: I assume this is
25 informed by operating experience.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DUBE: Yes.

2 MEMBER REMPE: As I was going through the
3 material and maybe not just with piping but other
4 components there were several examples where they talk
5 about that they assume a component's essential and
6 they go through some calculations and it determines
7 like the outage time can be always. It is with your
8 example of having four trains versus two trains that
9 maybe the other two trains aren't needed. And is
10 there --

11 MEMBER ABDEL-KHALIK: That would be risk-
12 informed tech specs, yes.

13 MEMBER REMPE: Right. But I see
14 similarities in a lot of these different examples.
15 And is there ever a potential where you would say
16 well, why don't we just start monitoring a fewer
17 number of components. And do other criteria always,
18 like the backstop or whatever they talk about criteria
19 always kick in so that never happens?

20 MR. DUBE: Yes, there are a number of
21 backstops for risk-informed ISI in the sense of a
22 minimum number of weld locations have to be inspected
23 regardless of what the risk tells you or what the
24 probability tells you.

25 MEMBER REMPE: But the advanced reactors

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 never get the flexibility of just having fewer
2 components monitored which would make things a lot
3 simpler for everybody.

4 MR. DUBE: Well, we'll show an advanced
5 one. I think there's a shifting of priorities in
6 finding locations for inspection.

7 CHAIR STETKAR: They do, Joy, because
8 RTNSS in terms of monitoring requirements RTNSS is
9 different than safety-related. And the new reactors
10 have a much smaller complement of safety-related
11 equipment. RTNSS or D-RAP. You know, they still need
12 to monitor them under the maintenance rule program but
13 it's a little bit different than having them in the
14 tech specs as far as safety-related. So they do get
15 some flexibility you know.

16 MEMBER SHACK: Even here in the RI-ISI, I
17 mean most of their piping is going to be down in the
18 low condition so they're going to be hitting backstop,
19 the deterministic backstop most of the time.

20 MR. DUBE: Good point. I mean, in theory
21 the new reactors have been designed to address these
22 right from the start.

23 CHAIR STETKAR: Right. Right.

24 MR. DUBE: So you should see, and we'll
25 show it, I'll show a graph thanks to the EPRI again.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So on the consequence ranking one uses conditional
2 core damage probability, that's CCDP, or conditional
3 large early release probability with CLERP being an
4 order of magnitude lower than CCDP. It categorizes
5 the consequences based on, you know, order of
6 magnitude ranges. I won't go through all the numbers
7 but they're there.

8 And one looks at you know also a delta
9 risk impact. And the interesting thing here is
10 there's, the risk impact in terms of the theoretical
11 change in core damage frequency, change of large early
12 release frequencies, there's a goal acceptance
13 criteria at the plant level and at a system level,
14 with the system level being an order of magnitude
15 lower and that's to ensure that no one system bears
16 all of the risk. That's kind of a defense-in-depth
17 mechanism in the sense that make sure that not all the
18 risk is in the emergency core cooling system or you
19 know, certain portions of the Class 1 piping.

20 MEMBER BLEY: So can you go back to page
21 17? And if you're going to tell me you're going to
22 show us this with examples --

23 MR. DUBE: Yes.

24 MEMBER BLEY: -- then you can put this
25 aside, but as I look at this I'm guessing you look at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a piece of pipe and you look at the system it's in and
2 you decide its vulnerability to those mechanisms on
3 the degradation mechanism category side. It might be
4 vulnerable to more than one so you identify probably
5 the highest one and then you do a PRA calculation to
6 see if that pipe breaks in some fashion. I'm not sure
7 what we would mean by some fashion. Then how can it
8 affect or where is it likely to fall out in terms of
9 core damage or LERF. And then you pick a spot. So
10 you'll walk us through doing this?

11 MR. DUBE: Yes. I think I will. If not,
12 remind me.

13 MEMBER BLEY: So coming back to where you
14 said Bill had it right if we look at the left-hand
15 side and think of those mechanisms, and if we think of
16 flow full-rated corrosion which puts us in the high
17 category are we thinking a different kind of break
18 than we are in the medium category or the low? I
19 would think if we were in the low category we would
20 probably be seeing some small opening in the pipe
21 where in that high category you'd be thinking of
22 almost a double-ended rupture kind of thing. Is there
23 that kind of distinguishing when you use this?

24 MR. DUBE: We're getting into a little bit
25 of details that may be beyond me but I would think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that one would conservatively assume that you know a
2 large break.

3 MEMBER BLEY: So any one of these
4 categories.

5 MR. DUBE: Pat O'Regan's nodding yes so
6 I'll say yes. Just be the conservative I'm assuming.

7 MEMBER BLEY: Okay, whether it's high,
8 medium or low you just assume it's a complete break.
9 Okay.

10 CHAIR STETKAR: Is this limited to only
11 Class 1, Class 2?

12 MR. DUBE: No.

13 CHAIR STETKAR: No?

14 MR. DUBE: Could be any Class 1, 2 or 3.

15 CHAIR STETKAR: Could be heater drain
16 lines out in the turbine building in principle? If
17 you're going to say something --

18 MR. DUBE: Not yes or no.

19 CHAIR STETKAR: -- come up to the
20 microphone.

21 MR. DUBE: Thank you, Pat. Appreciate it.

22 MR. O'REGAN: Pat O'Regan from EPRI. Most
23 plants that have applied it have applied it to either
24 Class 1 or Class 2 -- Class 1 and 2 piping. There
25 were several plants that applied it to the whole plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 which would include heater drain pipes, but usually
2 that's not done.

3 MEMBER SHACK: You get your biggest
4 benefit when you apply it to systems with low and
5 medium. So you know, you want to go to Class 1 when
6 you get out to heater drains.

7 CHAIR STETKAR: I'm thinking though also
8 in the other axis that if I bust a heater drain line
9 or a condensate line out in the turbine building I
10 pretty much fill up a good fraction of the turbine
11 building basement with water which for some plant
12 designs might be interesting.

13 MEMBER BLEY: I'm still having a little
14 trouble with the left-hand side, the degradation one.
15 The only way this makes sense to me is if in fact
16 these are roughly measures of frequency.

17 MR. DUBE: They are.

18 MEMBER BLEY: And if they are the only
19 thing again that kind of makes sense to me, and Bill
20 and others may tell me this is nuts, is that the
21 reason we might see a higher frequency for flow-
22 accelerated corrosion is that we might get surprised
23 on this one and the first real indication we have of
24 it is the rupture which I think has happened in some
25 cases where some of the others we might be giving

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 advanced warning of a problem so we don't actually --
2 we're actually limiting the frequency of those
3 ruptures because we're probably taking some remedial
4 action before it breaks. Is that a reasonable
5 assumption?

6 MR. DUBE: I think it's a reflection of
7 the potential for degradation and the potential to
8 identify it before it gets to a serious condition.

9 MR. DINSMORE: Hi. This is Steve Dinsmore
10 with the NRC staff. I'm going to rely on Pat to
11 correct me if I'm wrong because I review these things
12 and he doesn't. But I think basically the high,
13 medium, the small, everything is assumed to lead to a
14 large break in practice. It is frequency-related. If
15 you know you have FAC it's more likely you're going to
16 get a rupture there than if you just have IGSCC. If
17 you have two or three, if you have IGSCC and PWSCC
18 together in a segment I think there are provisions to
19 call that high. But so you go and you figure out what
20 relation mechanism you have and you just put it into
21 one of those blocks. But you have to know you have
22 FAC in order to put it in the FAC block. So it's not
23 like it would be a surprise, it's just, it is really
24 just frequency-related. If that answers all your
25 questions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: We'll see how it plays out.

2 MEMBER SHACK: One of the things I'm
3 struggling with, just to come back to, I mean, you
4 know stainless steel piping is not subjected to FAC.
5 I mean, you know, the mechanisms are you can look at
6 the piping and determine whether it is in fact
7 susceptible to a mechanism. Low-carbon stainless
8 steels aren't susceptible to IGSCC, you know, they're
9 not -- to PWSCC, you know. The nickel alloys behave
10 differently so you can bin them that way. But I think
11 it really does come down to kind of a think of it as
12 a pipe rupture potential, high, medium and low simply
13 because of the nature of the degradation mechanism in
14 one case can lead to very uniform, very large amounts
15 of degradation, FAC, before you get a leak. In all
16 other cases, and you tend to get leaks. And so you
17 know, it is a combination of the likelihood that it
18 occurs and the way it behaves once it does occur.

19 CHAIR STETKAR: I think the only question
20 in my mind, and this is, we're kind of veering off
21 because this is the way the world works now and it's
22 not really the subject of -- we need to get back on
23 track for the tabletop but if indeed that medium
24 category, or the y-axis categorization has a notion of
25 likelihood or frequency or however you want to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 characterize it, if something is in the medium
2 category because we think it has a low likelihood
3 because we inspect it and we understand the
4 mechanisms, and then we use that medium category to
5 justify the fact that we need to do less inspection is
6 that not necessarily a self-fulfilling type of
7 process? For example --

8 MEMBER SHACK: You're always going to
9 detect leaks, whether you're doing your ASME ISI, you
10 always have the leak detection. So that, you know, if
11 your dependence is on a leak before --

12 CHAIR STETKAR: Yes, that's a functional,
13 physical sort of notion.

14 MEMBER SHACK: So yes, you know, there's
15 several ways to detect these things. One is with a
16 little crystal rubbing over it, the other one is the
17 leak. And you know, these are by and large leak-
18 before-break type failure mechanisms in systems and so
19 you're always dependent on that even if you're
20 reducing your crystal-rubbing.

21 CHAIR STETKAR: Okay. Thanks. Sorry,
22 Don.

23 MR. DUBE: No problem. Thank you for my
24 support out there, Stephen Dinsmore. Okay, so we want
25 to say what's been the experience with the current

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reactor fleet. And through all these tabletops that
2 was an important element which was, okay, before we
3 even worry about new fleet what about the existing
4 fleet. Now, these are staff sampling from past
5 licensing submittals using the EPRI methodology.
6 These are the actual plants, these are actual
7 submittals. These are the, I'll call the theoretical
8 delta core damage frequency and large early release
9 frequency. Sometimes positive, sometimes negative,
10 always --

11 MEMBER SHACK: Two significant figures.

12 CHAIR STETKAR: Three.

13 MR. DUBE: And so sometimes it's just a
14 matter of what was the before and after. And all of
15 these calculations, one of is comparing the current
16 ASME Section 11 approach, eventual ISI versus the
17 risk-informed ISI and doing I'll call it theoretical
18 calculations. And depending where the starting point
19 is whether it's positive or negative. These are other
20 words for zero. When your internal events, core
21 damage frequency is several times 10^{-5} they're other
22 words for zero.

23 And so many have called risk-informed
24 inservice inspection of piping a risk-neutral approach
25 or application in the sense of one is really just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 finding higher priority weld locations for inspection
2 and making some shifting around, reducing burden,
3 perhaps reducing worker exposure to radiation. But
4 basically being, you know, for better or for worse
5 risk-neutral, a term called risk-neutral.

6 Here's some additional considerations.
7 This kind of factor in some of the deterministic
8 backstops if you will, kind of directly/indirectly.
9 Under Code Case -560 the number of elements to be
10 volumetrically examined is 10 percent of the piping
11 weld location based upon performance history. Code
12 Case 578, risk category 1, 2 or 3, and that refers to
13 the red regime here in that slide. The minimum number
14 of inspection elements should be 25 percent of the
15 total elements in that category. Risk category 4/5,
16 inspect 10 percent. So risk category 4 and 5 are
17 those mediums. And the Code Case N-716 identifies
18 portions of systems that should be generically
19 classified as high safety significance. The PRA is
20 used to search for additional plant high safety
21 significant segments so there's a deterministic
22 approach. And then Section 4 of the Code Case
23 requires that 10 percent of the HSS as well shall be
24 selected for examination. And there's real details
25 upon this. I'll call upon my colleagues and EPRI

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 representative.

2 Okay, so again the approach was let's
3 compare new reactors with current reactors. And so
4 for the purpose of these calculations it was one
5 reactor design with active safety features and one
6 with passive features. And right from the beginning
7 EPRI and its contractors noted that there was more
8 differences between BWRs and PWRs in the current fleet
9 than between new and active passive designs. So the
10 fact that we chose one active design plant and one
11 passive ended up being moot in the long run but you
12 don't know it until you know it.

13 CHAIR STETKAR: Did you, I've forgotten
14 which ones you picked. Did you pick a BWR and a PWR
15 of your active and passive?

16 MR. DUBE: I believe they were both PWRs,
17 right? Both PWRs.

18 CHAIR STETKAR: I can look it up but I
19 forgot.

20 MR. DUBE: And then the EPRI and its
21 contractors did a sensitivity study and said well,
22 what if the commission did tell us in the acceptance
23 guidelines to use an order of magnitude lower
24 thresholds for the acceptance criteria? What would it
25 make, what difference would it make and how might it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 shift things around? One real interesting observation
2 that came about was when you go from a two train
3 plant, so you have two trains of emergency core
4 cooling system eventually finding their way to the
5 reactor coolant system piping versus three and four
6 trains that may feed a common header and that header
7 may then branch off into the reactor coolant system
8 loops, one of the interesting findings was there was
9 a shift in the inspection focus to individual branch
10 lines to these common headers because in hindsight it
11 kind of makes sense that if you were to have a break
12 in a common header it's a potential common cause
13 failure of multiple trains of injection capability or
14 in case of a feedwater line or emergency feedwater
15 line, you know, taking out your -- one's emergency
16 feedwater capability. It's an interesting insight
17 from the activity.

18 So this is a very busy slide and on the x-
19 axis is the consequence ranking. So this is the
20 conditional core damage probability if you will for
21 Class 1 welds. And when using the nomenclature
22 remember high, medium and low from earlier slide, from
23 this slide and from these numerical area. And on the
24 y-axis is 100 percent and the numbers have to add up
25 to 100 percent. So if one looks at the hashed bar

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 here, 68 percent high and 32 percent, that adds up to
2 100 percent for operating PWRs. This second bar, 74
3 percent and 19 and 7 should add up to 100. So for
4 each category of plant, for the operating pressurized
5 water reactor the columns add up to 100. For the
6 operating BWRs the columns add up to 100. For new
7 light water reactor because they notice so little
8 difference between active and passive essentially
9 combine the two.

10 CHAIR STETKAR: But just out of curiosity
11 since I couldn't find it quickly do you know, you said
12 there was an active and a passive. Were they both
13 PWRs?

14 MR. DUBE: I believe so, yes. Right?

15 MR. O'REGAN: Yes.

16 CHAIR STETKAR: So you don't know whether
17 there's the difference in the BWR/PWR if you took --
18 if you took a BWR versus a PWR for example.

19 MR. DUBE: We did not do that. But for
20 the current fleet there's a greater difference between
21 Bs and Ps than.

22 CHAIR STETKAR: But I was saying would you
23 observe that in the new plant.

24 MR. DUBE: I will guess yes but I don't
25 know.

1 CHAIR STETKAR: Okay.

2 MR. DUBE: I'll ask the EPRI
3 representative who did many of these calculations.

4 MR. O'REGAN: Yes, there is difference
5 between all the plants, it's just a question of you
6 know relative difference. And also we only looked at
7 several systems. If you looked at 20 systems per
8 plant you'll see more difference.

9 CHAIR STETKAR: Okay. Thank you.

10 MR. DUBE: So let's just take one of these
11 operating PWRs, 68 percent found their way in the high
12 consequence category, 32 in the medium and none in the
13 low. I won't repeat it but operating BWR and yes,
14 what one finds is for a new light water reactor one
15 would have only 27 percent in the high consequence
16 category, 53 percent in the medium, 20 percent in the
17 low. So there's a shifting from high and medium for
18 the current fleet to medium and low. And why is that?
19 The reason is the conditional core damage probability
20 for the new fleet is lower because they have more
21 trains. They'll have typically three and four trains.
22 So given a large loss of coolant accident or some
23 other loss of coolant accident, for example, given a
24 pipe break conditional core damage probability is
25 found to be lower for new reactors because the core

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 damage -- because they have more trains, more highly
2 automated, less reliance on operator action and lower
3 risk profiles. So it could be an explanation.

4 If one were to use acceptance criteria
5 that was an order of magnitude lower, so in this
6 classification of consequence if one were to lower all
7 those numbers by an order of magnitude to the new
8 design. Now the commission did not tell us to do --
9 that they were in favor of this but we're doing these
10 calculations to support you know the proposed
11 approach. There is a shifting back to the high and
12 medium but not a lot, so.

13 So this is on the consequence portion. In
14 the overall risk ranking, so this is now a combination
15 of the consequence, the previous slide, and the
16 potential for degradation. And also taking into
17 account that again, since in theory the new reactors,
18 the material selection for the piping has built upon
19 50 years, calendar years and several thousand reactor
20 years of operating experience one would hope that one
21 in the new reactors designed out a lot of the
22 degradation mechanisms. So one finds a couple of
23 things working here in one's favor, fewer degradation
24 mechanisms and lower conditional core damage
25 probability given a break. So one sees a little bit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 more dramatic shift here. Again, the numbers for each
2 reactor type should add up to 100. So in overall risk
3 ranking there's 33 percent for operating PWRs in the
4 high, 51 percent in the medium, 16 percent in the low.
5 And when we repeat the operating boiling water reactor
6 one finds for Class 1 welds in the new designs the
7 purple is current acceptance criteria, very few high,
8 28 percent medium and the rest in the low. And even
9 with stricter acceptance criteria it doesn't, one does
10 not see a dramatic change. This is a little bit of
11 shifting back to the medium but not a lot, so.

12 So quantitatively the numbers kind of back
13 up what one thinks qualitatively in the sense of new
14 reactors designed out many of the failure mechanisms
15 in terms of the selection of materials and with three
16 and four trains giving out an initiating event be it
17 a steam line break, be it a break of reactor coolant
18 system piping, the conditional core damage probability
19 is significantly lower so there's a shifting from the
20 medium into the low.

21 MEMBER BLEY: Of course in the past we've
22 thought we've designed things out and then when we got
23 extensive operating experience we found out some new
24 mechanism --

25 MR. DUBE: You're right.

1 MEMBER BLEY: -- made up some of our gain.

2 MR. DUBE: That's a good point and that's
3 why in this overall process there's this feedback loop
4 of performance monitoring and adjusting. And I'll
5 talk about that too, the ASME 10-year re-analysis.
6 That's a good point.

7 CHAIR STETKAR: Don, can I ask, so the
8 operating fleet, things are flashing faster than I can
9 see. The operating fleet results are based on
10 comprehensive if I can characterize them that way,
11 comprehensive evaluations that were performed in
12 support of the license submittals, is that right? I
13 mean, you know, they basically looked at all of their
14 piping. Is that?

15 MR. DUBE: Within the system for which
16 they --

17 CHAIR STETKAR: Okay, within the system.
18 Pat said something that kind of caught my attention.
19 He said we only looked at a few systems.

20 MR. DUBE: For the purpose of this
21 exercise.

22 CHAIR STETKAR: Okay. But you're drawing
23 global conclusions based on those.

24 MR. DUBE: Yes.

25 CHAIR STETKAR: My curiosity is what was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the cross-section of those few systems. Did they only
2 look, for example, at the reactor coolant system and
3 connective piping, or did they also look at other
4 Class 1 and 2 piping systems like component cooling
5 water and so forth.

6 MR. DUBE: So that wouldn't be Class 1 but
7 they did look at --

8 CHAIR STETKAR: Oh, it would be Class 2.

9 MR. DUBE: -- mitigating systems, they
10 looked at other mitigating systems. A subset.

11 CHAIR STETKAR: So they did, they did
12 look, okay, at a cross-section of things. Okay. I'm
13 sorry, go ahead.

14 MR. DUBE: Go ahead.

15 CHAIR STETKAR: No, finish that up.

16 MR. DUBE: Well, that's a good point. I
17 mean, this whole tabletop exercise I should have said
18 it right from the beginning has been what I call
19 inductive reasoning. Engineers tend to do very well
20 at deductive reasoning which is I've got some
21 criteria, some formula and I apply it to a specific
22 situation. This whole tabletop exercise has been the
23 reverse which is let's do as many calculations as we
24 can realistically do given the resources and time,
25 look at specific situations and make generalizations

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 about applying this. And so we've done the reverse
2 and yes, you can't analyze everything.

3 CHAIR STETKAR: That's a perfectly
4 reasonable process I think for, you know, given your
5 charter. Although given that process it then becomes
6 really important to understand any limitations or
7 biases that might be inserted in that process based on
8 the sample that you selected. That's why I was asking
9 about the sample of whatever those systems. That's
10 why I was asking about PWRs versus BWRs in the new
11 plant, you know, tabletops.

12 MR. DUBE: Maybe the next slide will help
13 show you specifically. So here's the delta risk
14 calculation. Here we really show a significant figure
15 so we'll make some of you happy. So I'll walk you
16 through to the extent that I can. On the left-most
17 column is the risk categorization from the previous
18 set of slides, high, medium, low, the degradation
19 mechanisms, thermal fatigue, stress corrosion
20 cracking, none and none. The number of, oh and by the
21 way, the top set of table, the top table is for an
22 active plant and the bottom is for a passive plant.
23 So on the third column the number of Section 11
24 inspections that otherwise would have been you can
25 read the numbers, 2, 4, 34, 94. The number of risk-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 informed ISI inspections, somewhat smaller,
2 substantially smaller number. The delta, subtract one
3 from the other, you get that column. The CCDP is the
4 conditional core damage probability. The frequency in
5 terms of the potential for pipe failure per weld, you
6 see the numbers, and then the product of the two are
7 the delta risk numbers. This just happens -- so $6.1E$
8 ¹¹, that's another number for zero.

9 CHAIR STETKAR: So then $9E^{-13}$ is another
10 number for zero.

11 MR. DUBE: Yes, that's it. If they left
12 it blank the staff will come back and say well, what
13 is it, so we're showing whatever the computer puts
14 out. And the bottom table is for passive. And this
15 10^{-10} is another number for zero as well.

16 And one similar table was done assuming
17 one used acceptance criteria from Reg Guide 1.174
18 which was an order of magnitude lower and the same
19 result was zero and zero. So observed is the effect
20 is risk neutral whereas with a substantial reduction
21 in the number of inspection locations.

22 So these quantitative calculations were
23 fine and they helped to inform us but the purpose of
24 the exercise is not to just do calculations. It's to
25 inform the staff in terms of for what, what were the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 features in the guidance and what were the regulatory
2 and programmatic controls to ensure for, when we apply
3 this methodology to a new reactor there would not be
4 a substantial decrease in an enhanced level of safety.
5 So we were very interested at the end of all these
6 exercises to identify what controls are in place.

7 So on the first bullet I mentioned it
8 earlier that the guidelines on the potential core
9 damage frequency and large early release frequency
10 increases are imposed at the system level as well as
11 the overall totals to ensure that no one system
12 absorbed most of the change in risk. So that's
13 applied to -- would be applied to new reactors the
14 same as current reactors.

15 The second bullet says that there's -- one
16 still has to inspect the minimum set of weld locations
17 regardless of whether, what the risk levels are
18 calculated to be. In a sense it's a determinist
19 backstop in the sense of even if you tell me that it's
20 low-risk you still need to do a minimum number of
21 inspections.

22 MEMBER ABDEL-KHALIK: Could you
23 conceptually explain why is it important that no one
24 system absorb most of the change in risk? What
25 difference does that make?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DUBE: Well, what if one was uncertain
2 about the -- all of the risk occurred in one system,
3 and it was dominated by the PRA's calculation of what
4 one thought the conditional core damage probability
5 and there's no operating experience, or dominated by
6 the degradation mechanism and again no operating
7 experience. One would have put all of the risk in one
8 system so it's kind of a means of treating uncertainty
9 if you will to buy yourself at least an order of
10 magnitude.

11 MEMBER ABDEL-KHALIK: Wouldn't that
12 concern about uncertainty be still there whether the
13 risk is distributed or?

14 MR. DUBE: -- but if I'm off by an order
15 of magnitude I'm still within the acceptance
16 guidelines within the system.

17 MEMBER ABDEL-KHALIK: If the reason is to
18 somehow handle uncertainty I'm not sure that that
19 addresses it. Because it's the same.

20 MR. DUBE: No. I mean, I believe because
21 if one was off by an order of magnitude in conditional
22 core damage probability, let's just say a guidance was
23 10^{-6} and I said no one system can have more than 10^{-7}
24 I was off by an order of magnitude I still can roughly
25 meet an acceptance guideline. If I were to put all

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the level of risk in one system and I was at 10^{-6} and
2 I was off by an order of magnitude it could be 10^{-5} ,
3 it could be an order of magnitude more than what I
4 would allocate for the whole plant level.

5 MEMBER ABDEL-KHALIK: Well, the point I'm
6 trying to make, even if the risk is distributed to
7 many systems and you have that level of uncertainty
8 and order of magnitude uncertainty the sum total would
9 still be off by an order of magnitude.

10 MR. DUBE: Well, I'm presuming that I'm
11 not off conditional core damage probability across all
12 the systems and that the degradation mechanism is not
13 the same across all the systems. I'm not putting all
14 the eggs in one basket I guess.

15 CHAIR STETKAR: The way I look at it in
16 some sense is not so much a compensation for
17 uncertainty. There's also this notion of you'd really
18 like to have what they call a balanced risk profile.
19 You know, and this applies, forget ISI or anything
20 else, that although your total core damage frequency
21 is let's say 10^{-6} you don't want 99 percent of that
22 core damage frequency being attributed to let's say a
23 single initiating event or a single system failure,
24 that you'd much prefer to see a much more balanced.

25 MEMBER BLEY: Why? You're not asking me.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: I'm not saying I'm
2 endorsing this, I'm saying there's a notion that
3 that's --

4 MEMBER BLEY: I think the notion is
5 anchored in the kind of things Don was discussing.
6 Otherwise there's nothing there.

7 CHAIR STETKAR: It's applied in a lot of
8 other areas.

9 MEMBER BLEY: In practical cases it
10 almost, it often comes about because you eliminate the
11 big lumps. You find ways to take care of them until
12 you get down to the point it's not practical to fix
13 everything because all of the little pieces are
14 contributing. There is that side of it as well.

15 MEMBER ABDEL-KHALIK: Is the notion of
16 diversity buried in that?

17 MEMBER BLEY: It's right in the middle of
18 it because it's the kind of thing, you have diversity
19 of function is basically what Don was talking about.
20 So yes, it's hidden in there.

21 MR. DUBE: Good question. I think it's in
22 part to address uncertainty. But all of these things
23 have been sort of factored into it. It's important to
24 know that a number of programs remain in place to
25 address degradation mechanisms regardless of the ASME

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ISI such as flow-accelerated corrosion and
2 microbiologically induced corrosion, or influenced.
3 So even, these programs are not going to be impacted
4 I don't believe. So a number of these programs still
5 remain in place.

6 MEMBER SHACK: Of course, you could take
7 another point of view which is if you increase or
8 decrease the acceptance criteria by a factor of 10 you
9 don't really increase the burden on the licensee by
10 very much, less than 10 percent, so.

11 MR. DUBE: Right.

12 MEMBER SHACK: In this particular case it
13 doesn't matter much either way in terms of burden or
14 risk reduction.

15 MR. DUBE: Thank you. A couple more
16 aspects. Risk category 4 which goes way back where.
17 Excuse me. Category 4 was the medium here so it had
18 high consequence but low degradation mechanism
19 potential. And then later I'm going to talk about
20 category 5 so I might as well refresh your memory now.
21 It has low consequence but high degradation mechanism
22 potential.

23 Risk category 4 in the matrix was
24 introduced to address the unknowns with high
25 consequence, low frequency phenomena. So even though

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it has low potential degradation mechanism because of
2 the potential high consequences a number of inspection
3 locations are required. That's to address the
4 unknowns with PRA in a sense. What if one was off by
5 one category of consequence or conditional core damage
6 probability? And the reverse was introduced, category
7 5, to ensure that some inspection is provided even if
8 the consequences of certain pipe failures are
9 identified as low. So even though the PRA said low
10 consequence but it was, you know, a serious
11 degradation mechanism, again, the number of inspection
12 locations are required to address that unknown,
13 unknown unknown.

14 And finally, regarding I think Dennis Bley
15 brought it up, regarding well, over the years you find
16 some other mechanism comes about that one hadn't
17 foreseen when one designed a new reactor and that's
18 true. The ISI program, risk-informed ISI program
19 requires updating the risk rankings of the PRA
20 calculations. It's a living program and roughly every
21 three and one-third years one would be doing an update
22 that's consistent with some regulations that require
23 that the PRA be upgraded to existing standards every
24 four years. And so there's this ongoing mechanism of
25 feedback and update feedback and update. So it's not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a static program. And so that gave the staff a great
2 deal of confidence.

3 So here's some, the preliminary results on
4 risk-informed ISI. Appeared to be, or I could state
5 emphatically it's risk neutral, the new active plant
6 and new passive plant, even with sensitivity studies
7 using more restrictive criteria were applied.
8 Identified numerous regulatory and programmatic
9 controls. Consensus among the participants, that
10 includes the staff and stakeholders. Would not result
11 in any significant decrease in enhanced safety for the
12 new designs. There were a number of potential
13 regulatory implementation issues identified. That
14 wasn't the purpose of these tabletops but they were
15 identified so they will have to be addressed. One is
16 lack of operating experience. So the staff is working
17 with the applicants who want to use risk-informed ISI
18 going forward for how to address operating experience
19 and what is that time frame before one could
20 effectively implement risk-informed ISI in an
21 operating, I mean at a newly operating plant. It's
22 fair to say that a new plant could not begin right
23 from the start. Risk-informed ISI would probably have
24 to be phased in. They could have elements of risk-
25 informed ISI but the notion of just going from nothing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to full speed ahead, we have to, has to be addressed.
2 And a conventional ISI program is required for
3 50.55(a). It's a regulation before one implements
4 risk-informed ISI. So for -- based on the current
5 regulations I know there's desires to just go
6 immediately into risk-informed ISI. Current
7 regulations say no, it's got to be a delta from
8 conventional ISI to risk-informed ISI so one could
9 look at that delta. And that's it. That's a lot but
10 --

11 CHAIR STETKAR: Don, when you say you can
12 look at that delta though how do you understand what
13 that delta buys you without much operating experience?
14 Maybe I'm not understanding the problem very well. In
15 other words, why, if there's a high confidence in
16 implementing risk-informed ISI from everything that
17 you've looked at why not early if not immediately in
18 the operating process?

19 MR. DUBE: Well, some of the staff's
20 cautious.

21 CHAIR STETKAR: Okay.

22 MEMBER SHACK: I'd say you know these are
23 steels in water. There's no new materials here,
24 there's no new environments. You have plenty of
25 operating experience as far as the degradation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mechanisms go. And you're hopefully not going to get
2 too much operating experience on the failure of the
3 systems.

4 MR. DUBE: Your comments are noted.

5 (Laughter)

6 MR. DUBE: Make a note in the letter.

7 MEMBER SHACK: There's no letter coming
8 out of --

9 MR. DUBE: In the spring. Yes, I mean
10 there's varying degrees of thoughts on this.

11 MEMBER SHACK: I understand.

12 MR. DUBE: There's a diversity of opinion
13 within the staff. Thank you.

14 CHAIR STETKAR: Why don't we, Don, before
15 you get into the --

16 MR. DUBE: I think we have a break.

17 (Laughter)

18 CHAIR STETKAR: You're a step ahead of me.
19 Let's do that. First, though, because we're going to
20 switch gears and completely get out of the area of
21 anything that Dr. Shack will contribute to does --

22 (Laughter)

23 CHAIR STETKAR: I'm sorry, in terms of
24 being able to interpret really long acronyms with a
25 lot of Cs and Ps and that sort of stuff. Seriously,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 do any other members have any questions or comments on
2 the ISI issues? Because we're going to get into a
3 completely different area on tech spec stuff.

4 MEMBER SKILLMAN: Yes, I do. Dick
5 Skillman is my name. What is the extent of the
6 database that was used to if you will validate your
7 risk and consequence chart? There is an awful lot of
8 data out there as I think of the last 10-15 years.
9 Davis-Besse's not a pipe but it's certainly a reactor
10 coolant pressure boundary, it is clearly ISI. A
11 number of other units have had very similar
12 degradation mechanisms. And so I would be curious to
13 what extent this chart has been viewed from the
14 perspective of the practical experience that the
15 industry has had over the last decade. One would say
16 you know what, that fits, that fits, that fits, that
17 was slow but it was consequential, that was very fast,
18 very serious. So my question is to what extent does
19 this represent real data and has it been validated.

20 MR. DUBE: On the consequence portion
21 obviously it's relying on the PRA which have undergone
22 varying degrees of review. I mean, the staff, you
23 know, these are for the new reactor designs. Staff's
24 reviewed these very extensively, developed our own
25 models and -- not for all of them yet, but we do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 comparisons using our existing PRA models and
2 licensees and we'll continue to do that. So the
3 consequence portion is being validated to a large
4 extent but I think your question was more on the
5 degradation mechanism. I'll give you a short answer
6 and turn it over to the EPRI representative Pat
7 O'Regan but they've undergone extensive validation and
8 it's done plant by plant, system by system as part of
9 the documentation and the licensing submittal. So if
10 you want a lot of details on the methodology I'll turn
11 it over to.

12 MEMBER BLEY: Before he starts I think
13 just to follow up to Dick's comment is I think your
14 question was kind of focused on the medium box and the
15 assumption that we will probably notice degradation
16 before it goes too far in some events that have
17 surprised us when we didn't see it coming.

18 MEMBER SKILLMAN: I was focused on the
19 whole chart with -- from the practical perspective
20 where industry would say you know what, that makes
21 sense because when we go back and look at the cardinal
22 events in the last 10-15 years one could say you know
23 what, that's pretty much on the money. So my question
24 is one of practical application of this into the real
25 world where the industry is saying that makes sense

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and I can use risk-informed ISI for my piping
2 inspections because it works. That was what I'm
3 really thinking.

4 MR. DUBE: Yes, I mean there's nearly, I
5 believe over half of the current fleet are implemented
6 risk-informed ISI and so there's hundreds of years of
7 experience right now.

8 MEMBER SKILLMAN: And so when there has
9 been a failure would one say you know what, this
10 predictive tool was pretty much on target. That's my
11 question. Is it predicting.

12 MR. DUBE: I'll ask Pat and then Stephen
13 Dinsmore if he wants to add to it based on the current
14 fleet.

15 MR. O'REGAN: As Don had mentioned in a
16 previous slide there's a performance monitoring loop
17 in the system or in the methodology, and if you would
18 turn to that slide right there. If you go to slide
19 18, Don, it has the list of the degradation mechanisms
20 we evaluated. For each of these mechanisms there's a
21 prescriptive set of criteria that you go through.

22 CHAIR STETKAR: Just step up to the mic a
23 little bit closer.

24 MR. O'REGAN: Pat O'Regan from EPRI.

25 CHAIR STETKAR: Just, that one doesn't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pick up as well as these two, so we need you.

2 MR. O'REGAN: Pat O'Regan from EPRI. And
3 I was saying for each of these mechanisms in the EPRI
4 TR there's a prescriptive set of criteria that an
5 analyst goes through to determine whether that
6 mechanism is potentially operative or not. We ask
7 what type of material, what type of water chemistry
8 control, hot and -- mixing of hot and cold fluids,
9 what have you. And that criteria is based upon all
10 the data that we've reviewed, all the root cause
11 analysis we've reviewed where there have been failures
12 and as part of this system program component you'll
13 see there's PWSCC there. That, the criteria that's in
14 the TR is from the 1990s and obviously we've learned
15 a lot since then and each plant that's implemented
16 risk-informed ISI actually no longer uses that
17 criteria, they use the criteria in MRP 139 which has
18 been updated based upon the operating experience.

19 CHAIR STETKAR: Thank you.

20 MR. DUBE: Stephen Dinsmore, you want to
21 add anything? Thank you.

22 CHAIR STETKAR: Anything else from other
23 members? If not thank you very much, and we will
24 recess until 10:15.

25 (Whereupon, the foregoing matter went off

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the record at 9:58 a.m. and went back on the record at
2 10:14 a.m.)

3 CHAIR STETKAR: Okay, we're back in
4 session. Don, back to you.

5 MR. DUBE: Thank you. Thank you. We're
6 going to shift gears to a totally new topic, risk-
7 informed tech spec initiative 5b. This has to do with
8 the surveillance frequency control program. If risk-
9 informed ISI was, these are rough numbers, 50 percent
10 risk and 50 percent deterministic or some proximate
11 fraction like that. Surveillance frequency control
12 program is much more heavily weighted towards, you
13 know, deterministic and the feedback mechanism and
14 risk because it tends to play a surprisingly small
15 role in it. Yes, there's calculations that are done
16 but it's really, you know, operating experience-based
17 in many ways.

18 So there are the key methodology and
19 guidance documents. There's the Nuclear Energy
20 Institute guidance document 04-10. It's been around
21 for several years. And there's again several reg
22 guides, 1.177 is very broadly based risk-informed tech
23 specs, and 1.174 is always there. We looked at one
24 new light water reactor vendor -- oh, I'm sorry, at
25 least one new light water reactor vendor and one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 combined license applicant have expressed interest in
2 applying 5b. And in speaking informally to other
3 applicants, once they get their COL they may be
4 interested in moving forward with this as well. So
5 there is quite a bit of interest out there.

6 CHAIR STETKAR: Don? Just out of
7 curiosity, I know the COL applicant. Can you tell us
8 which reactor vendor is interested in 5b?

9 MR. DUBE: It's Mitsubishi APWR.

10 CHAIR STETKAR: Oh, okay. Because I know
11 they've indicated they're postponing that, at least
12 for the design certification.

13 MR. TJADER: Excuse me, this is Bob
14 Tjader. I'm in the Technical Specifications Branch.
15 Last Friday, I think it was last Friday where you have
16 the MHI APWR ACRS meeting. I intended to be there.
17 Unfortunately I was rained out but I called in on the
18 phone -- this is just an aside -- and unfortunately I
19 found out when I called in that it was listen-only.
20 So I attempted to interject at that meeting because I
21 had called in but I was unable to do so. But MHI
22 misspoke. The risk-informed tech specs for the ones
23 that are significant, that's 5b and 4b, in fact are
24 reflected in the design cert tech specs of the APWR,
25 okay? They are reflected there as an alternative, as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 an alternative approach or an alternative that they
2 can opt to adopt, okay? Now, Comanche Peak is the
3 specific licensee that is adopting that. Now, North
4 Anna is another APWR and they've opted not to do it.
5 It is an option.

6 CHAIR STETKAR: It's an option in the
7 certified design tech specs.

8 MR. TJADER: They are in there as an
9 option.

10 CHAIR STETKAR: Okay. Thanks.

11 MR. DUBE: Thank you, Bob.

12 CHAIR STETKAR: Bob?

13 MR. TJADER: Yes?

14 CHAIR STETKAR: You know, we're having a
15 briefing on that topic for US-APWR on the 20th.

16 MR. TJADER: Right.

17 CHAIR STETKAR: You'll be there?

18 MR. TJADER: Yes.

19 CHAIR STETKAR: Thank you.

20 MEMBER BLEY: Good.

21 MR. DUBE: Okay. And then the last
22 bullet, risk increased assumption. This is a very,
23 very bounding kind of calculation. The definitive
24 probability is derived entirely by the standby failure
25 model $1/2 \lambda T$. When one does a calculation, if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 one does a calculation and you'll see as we go through
2 here a lot of these changes to this advanced test, you
3 almost can't do a calculation, very difficult in any
4 case. The vented assumption is that T is the time
5 between, the interval between testing and cert 1.
6 Normally test monthly and one wanted to extend the
7 test interval to quarterly which is every three
8 months, inherent assumption is that the failure
9 probability on demand for that component would triple.
10 That's not real world. Real world's a combination of
11 demand failures and standby failures, not necessarily
12 linear like that, a lot of complications. But for the
13 purposes of doing these calculations to come up with
14 some kind of bounding risk number there's an inherent
15 assumption.

16 CHAIR STETKAR: Some kind of risk number,
17 not necessarily bounding.

18 MR. DUBE: Yes. The benefits of risk-
19 informed tech spec, at least certainly from the
20 licensee or the applicant's viewpoint but also from
21 the staff and overall stakeholders in society is to
22 optimize surveillance frequencies. In other words,
23 use operating experience to say why, I've been testing
24 this piece of equipment monthly for 10 or 15 or 20
25 years. I've not experienced any adverse trends.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 There's a risk to reactor trip or some other situation
2 as you'll see in a lot of these surveillance systems.
3 Why not try to optimize it and perhaps change the test
4 interval to something less frequently with a larger
5 test in place? In many cases the very process of
6 testing may result in unavailability. In fact,
7 there's an input into PRA models which is test and
8 maintenance unavailability. Testing is a portion of
9 that. So in many cases the very act of testing
10 equipment means sometimes one has to valve out certain
11 portions of the system and the equipment or the system
12 or the train is unavailable during the testing. And
13 that contributes to overall system unavailability.

14 Increased equipment life. A lot of the
15 times just testing equipment wears it down. You've
16 heard the stories of the diesel generator fast starts
17 and others, slow starts for the most part. But
18 there's other cases where just the act of testing it
19 stresses the equipment.

20 It's important to know that tech specs are
21 still required on the equipment, it's just that
22 portions of the tech spec are now put in a separate
23 document that has its own change process and maybe
24 under 50.59 for example. But there is some, tech
25 specs are still applicable. And the bottom line is to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 enhance safety, to optimize testing, reduce stress,
2 reduce equipment wear, reduce unavailability but
3 without necessarily increasing the failure rate and
4 trying to find the happy medium if you will.

5 The next slide nobody can read but this is
6 the methodology. I'm going to take a snapshot of
7 this.

8 MEMBER BLEY: We can't even read it here.

9 MR. DUBE: I know. But two slides from
10 now I'm just going to zero in on a portion that you
11 can read. So that's why I have this process in brief
12 and text. Basically the process is to select
13 candidate for new surveillance frequencies. So a lot
14 of this comes from the engineering and operations
15 staff of the unit, the nuclear unit. They're looking
16 at what's the operational experience, what's the
17 current frequency testing, is it a resource burden,
18 are we wearing out the equipment, is there potential
19 for tripping a reactor. Every time one has control
20 rod motion, every time one does certain testing you
21 can potentially if things go wrong trip the reactor in
22 a worst case scenario, trip a system that may
23 ultimately trip a reactor. So testing does not
24 necessarily, is not always beneficial. So there's a
25 lot that goes behind this. I'm probably not doing it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 justice but a large effort is undertaken to find what
2 equipment are good candidates. And they propose a new
3 frequency, then they'll evaluate the proposed change.
4 They'll review commitments, the reliability history,
5 the availability history, look at the industry as a
6 whole, the plant-specific operating experience. So I
7 mean, none of this is risk-based so until now it's
8 really been driven by operating experience, some of
9 the deterministic criteria.

10 MEMBER BLEY: Don?

11 MR. DUBE: Yes.

12 MEMBER BLEY: Back to a quick remark John
13 made earlier. I studied that flow chart and I
14 actually can read it if I look down at my sheet.
15 There's a potential problem I worry about and we've
16 asked people in I think it was some design cert
17 sessions as well about this. The standby failure rate
18 model that gives you a $1/2 \lambda T$ gives you that
19 because of a constant failure rate assumption. If in
20 fact you extend intervals substantially new failure
21 modes can be introduced. In valves you can build up
22 deposits and things can occur that actually get
23 cleaned every time you cycle the valve. If you extend
24 these intervals you can introduce new failure modes
25 such that you're no longer at constant failure rate.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 It takes a big jump up. And then this isn't
2 conservative, it isn't even close. And I don't see
3 where in the process there's a check to make sure you
4 don't do something like that until, you know, the real
5 world starts telling you hey, these things are failing
6 a whole lot faster than --

7 MR. DUBE: If you want I'll show you the
8 feedback mechanism. I think there are.

9 MEMBER BLEY: Okay. I don't want you to
10 forget this one.

11 MR. DUBE: No, I won't.

12 CHAIR STETKAR: I was going to say if the
13 logical equivalent of those backstops that we saw for
14 ISI we will for 4b.

15 MR. DUBE: I believe there are.

16 MEMBER BLEY: Okay.

17 MEMBER ABDEL-KHALIK: Is there any
18 potential that this process that's on slide 34 can
19 produce a negative outcome? And what would the
20 licensee do in that case?

21 MR. DUBE: We'll talk about it, but the
22 answer is yes, it can. So -- and I'll talk about that
23 in a second. So it's all pilot, the feedback
24 mechanism, it's -- so the proposed changes reviewed
25 and approved at the plant by the licensee as a minimum

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 would be typically reviewed by the Integrated
2 Decision-making Panel or IDP. In some cases it may be
3 reviewed by an oversight committee, oversight review
4 board and then submitted to the staff for the staff's
5 review and approval for a change to the licensing
6 basis.

7 MEMBER BLEY: Is this where you check to
8 make sure they haven't extended too far and might not
9 be introducing new failures?

10 MR. DUBE: No, that's coming --

11 MEMBER BLEY: Okay.

12 MR. DUBE: -- in a slide or two.

13 MEMBER BLEY: Okay.

14 MR. DUBE: Then they implement it and then
15 they monitor and the monitor is the key part to your
16 question, Dr. Bley.

17 MEMBER BLEY: That's what I thought you
18 were going to say, and that means you're going to have
19 a bunch of failures before you realize you did
20 something funny. And it just seems like if you kept
21 some analysis it's extending a quarterly to an annual
22 or biannual test. That ought to be a flag that you
23 ought to have some evidence that you're not going to
24 introduce new failure modes and I don't see that.

25 MR. DUBE: My colleague from NRR Andrew

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Howe.

2 MR. HOWE: This microphone is not made for
3 short people.

4 MEMBER BLEY: You can bend it.

5 MR. HOWE: Can you hear me? I was a
6 reviewer for the 04-10 methodology and I'm the
7 reviewer for a good number of the 5bs that are coming
8 in now. Just for information about 40 percent of the
9 industry has proposed to implement and we've approved
10 about one-third now. Just for your information and I
11 don't know if it's specifically in the methodology but
12 there are checks that are made when you're extending
13 a surveillance test to see not only the specific
14 component that's being tested but what else is done by
15 the test. And in fact during the pilot process at
16 Limerick they identified relays that were only tested
17 by this test they wanted to extend and that was the
18 only time that they were exercised and they found that
19 they couldn't do the test for other reasons. The risk
20 was perfectly acceptable, there were no commitments,
21 so these types of consideration have arisen in the
22 pilot process. It is a part of the process.

23 The other thing we have is you don't go
24 from a monthly test to a 10-year test or something
25 like that. You go to a next logical increment in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 tech specs, monthly to quarterly, quarterly to 18
2 months.

3 MEMBER BLEY: I'd like to see something
4 that implies that because we had at least one case
5 where people were presenting to us and I think it was
6 going from a quarterly to a biannual test. And just
7 hadn't thought about this point that we could be
8 introducing new failure modes. Now if what you just
9 said is how this will be implemented I'm much more
10 comfortable but I don't see anything that limits us to
11 that or if some other person is reviewing we'll make
12 sure that we're picking that up.

13 MR. DUBE: It's specifically in the
14 guidance. It's definitely in the guidance that one
15 increases the surveillance test interval in a phased
16 manner from the next most logical test interval.

17 MEMBER BLEY: I've got to go back and look
18 at this. I'm not sure I saw that. I'm sure I didn't
19 catch that. Okay, so you're done? Okay.

20 MR. HOWE: No, that's good.

21 MR. DUBE: So that was a nice setup.

22 MEMBER SHACK: It is specifically in the
23 guidance.

24 MEMBER BLEY: Okay.

25 MR. DUBE: Thank you. So this is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 continuous feedback mechanism which is increase the
2 interval in increments, stop and observe, monitor. If
3 there is an increase in the failure rate there's a
4 mechanism to go back and go back to the shorter test
5 interval if you will.

6 MEMBER ABDEL-KHALIK: Where is that on
7 this chart? That's the question I was asking before.

8 MR. DUBE: Right here. Adjustment
9 required, go to step 13. So it's a feedback error
10 step 20. The Integrated Decision-making Panel reviews
11 and adjusts the surveillance test interval as needed.
12 Is there an adjustment required because of bad
13 experience? Yes. Go to step 13.

14 MEMBER ABDEL-KHALIK: Do you think the
15 licensees would then just abandon this particular
16 inspection and say forget it, we'll just stick with
17 what we have?

18 MR. DUBE: Based on our experience I don't
19 believe they would.

20 MEMBER ABDEL-KHALIK: I mean how many
21 cases have you seen in which the licensee came to you
22 and said we really ought to change this from quarterly
23 to monthly?

24 MR. DUBE: I haven't seen any personally.
25 I don't know if there's any answers out there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BRADLEY: Biff Bradley, NEI. The way
2 the process is set up it's a -- you implement the
3 process. There's no requirement to go back and report
4 to NRC exactly what you've changed. You set the
5 process up, it's subject to audit and inspection but
6 there's no report of results. We do track this
7 through the owners groups and other industry
8 mechanisms to try to make sure there's a reasonable
9 uniformity to the way this is implemented.

10 MR. DUBE: But in practice since certainly
11 for the new reactors they are required to maintain and
12 update their PRAs and the PRA requires the
13 incorporation of plant-specific operating experience.
14 If there's an increase in the failure rate of the
15 equipment it will be reflected back in the inputs to
16 the PRA model. It's required.

17 CHAIR STETKAR: Failure, yes, but it's a
18 self-fulfilling, if they use a lambda T model you
19 might not necessarily see that because it's sort of a
20 self-fulfilling process.

21 MR. DUBE: Well, the 1/2 lambda T is there
22 for the theoretical calculation of where the risk
23 impact is but nobody really necessarily believes that
24 as the true operating experience-based failure rate.
25 It's not necessarily that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Until you look at the PRA
2 models and you see people predicting the actual
3 failure rates for valves using that model. Anyway,
4 that's a different topic, but indeed they are.

5 MR. DUBE: Yes. So from the current
6 fleet, Andy kind of mentioned it, 40 percent reactors
7 are approved for 5b. The Integrated Decision-making
8 Panel's review is key. They've rejected many proposed
9 changes based on these deterministic considerations,
10 for example, the relays where there's an oxide buildup
11 and if you don't open the relays frequently enough
12 they end up being in effect stuck together, stuck
13 closed in other mechanisms. Whenever possible risk
14 assessments are used but many changes don't lend
15 themselves to precise risk calculations. It's
16 interesting to note that the typical PRA will have
17 three to four to five thousand basic events modeled in
18 the PRA representing several thousand components
19 whereas there's millions of components within the
20 plant. And so many of the components, one's not going
21 to be able to do a quick sensitivity study. It'll
22 have to do some kind of bonding calculation.

23 I've already mentioned the testing
24 interval that changes in phases from monthly to
25 quarterly, for example, to annual. The criteria needs

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to be set that says, this is one of the feedback
2 lessons learned is that when does one decide that the
3 failure rate has increased to an unacceptable level.
4 And one of the other lessons learned is that one needs
5 consistently good performance before moving on to
6 longer test intervals. So one shouldn't go from
7 monthly to quarterly to annual in a period of four
8 months, for example, and that hasn't been the
9 experience.

10 So for the new reactors we look at what
11 are the important considerations and one doesn't have
12 adequate operating experience. So one has to first
13 assess the applicability of the equipment performance
14 from the operating fleet. And there's certainly
15 consensus because of that that it will be several
16 operating cycles before there's an adequate confidence
17 on the baseline performance in the new reactors. So
18 while 5b may be applied to new reactors I'm not
19 expecting right off the beginning that in the first
20 operating cycle one would be implementing this. I
21 mean, even the industry based on their own experience
22 with the current fleet have expressed the notion that
23 they're not going to be ready to jump right into 5b
24 right away. It's going to have to be phased in.

25 CHAIR STETKAR: Don, we'll learn more in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 our US-APWR subcommittee I guess but does that
2 statement also apply for Comanche Peak?

3 MR. TJADER: Excuse me, this is bob Tjader
4 again. What I think, what we mean is that they will
5 have reflected in their tech specs the option to apply
6 the surveillance frequency control program. It will
7 be in the tech specs. The initial surveillance
8 frequencies in the program will be the frequencies
9 that are in the standard tech specs. Those will be
10 the initial ones. What we do not anticipate because
11 of the process, because of 04-10, we don't expect them
12 in the very first cycle to start changing massively
13 surveillance frequencies. We expect them to gain some
14 experience before they then apply what will be in
15 their tech specs as their ability to.

16 CHAIR STETKAR: Okay, so if I understand
17 it you don't expect a submittal from Comanche Peak to
18 come in with Chapter 16 of the COL FSAR saying we're
19 going to test this system at a frequency of once every
20 three and a half years because we've done a risk-
21 informed 5b analysis.

22 MR. TJADER: No, Comanche Peak will have
23 a surveillance frequency control program in those
24 specs. Assuming that the results of the tabletop are
25 acceptable as we anticipate it will be in there and we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 don't ask them to withdraw it. So they will have that
2 option to change it and there will be no subsequent
3 change requirement to come in for a license amendment
4 or anything to change the surveillance frequency.
5 They can do that through the process and the program.
6 Did I misunderstand your question?

7 CHAIR STETKAR: Perhaps but it's actually
8 -- we'll address it when we talk about the Comanche
9 Peak. Keep it focused on more generic issues here.

10 MR. DUBE: Okay.

11 CHAIR STETKAR: But it's interesting
12 because you know from a committee perspective ACRS --
13 Comanche Peak will be the first time we actually see
14 this in practice. So this is actually a defined term
15 type issue that we're going to be addressing, not
16 necessarily under reliability and PRA perspective but
17 under the Comanche Peak COL eventually.

18 MR. DUBE: Okay. I already mentioned the
19 first bullet in so many words that first of all,
20 actually I didn't say this part of it. We did, you
21 know, one of the key points of the program is that
22 components that fall under the ASME inservice testing
23 program, ISD, are not subject to 5b. That's an
24 important insight in that these are typically your
25 major pumps and major valves that often dominate the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 risk at current fleet and new reactors. And those are
2 not subject to risk-informed tech spec 5b. They still
3 have to -- it's a separate program but under 5b
4 they're not subject to changes in the surveillance
5 test interval. So those, again, those are your major
6 pumps and valves that do that. We had one reactor
7 vendor did come in with, did perform sensitivity
8 studies. And in keeping with not having three
9 significant figures I've rounded them to the nearest
10 order of magnitude. They did sensitivity studies on
11 what if they were to apply 5b to certain components
12 that they knew from their PRA to be pretty important
13 in terms of the contribution to risk if you will at
14 that particular reactor design. So they looked at in
15 the first case increasing the test interval on battery
16 testing by a factor of 4 including common cause
17 failure and the change in core damage frequency and
18 LERF on the order of 10^{-8} per year.

19 There's a requirement to ensure that power
20 is removed from motor-operated valves that are open,
21 have to be locked open and you really don't want to
22 change state to a closed connection for example. And
23 there's no reason to believe quite frankly where
24 changing this surveillance factor of 3 is realistic
25 but for the purpose of sensitivity study they triple

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the failure probability of that because they didn't do
2 surveillance to ensure that the valve had power
3 removed, that the failure probability on demand was
4 tripled. The estimates of change of core damage
5 frequency is on the order of 10^{-9} and LERF 10^{-12} .
6 Similarly for residual heat removal, isolation valve
7 power, where they have to observe the power is removed
8 they triple the failure rate and you can see the 10^{-7} ,
9 10^{-8} order of magnitude changes in risk. In the
10 diverse actuation system whereby the manual control
11 they doubled the interval and doubled the failure rate
12 and the estimate was 10^{-9} .

13 Most of these numbers are definitions of
14 zero increase. And they're bounding numbers because
15 as I said the fact that you ensure that power is
16 removed when you remove the valve is typically due to
17 a state of being closed when you thought it was open
18 and so forth.

19 You know, it was difficult to do
20 quantitative analyses on these mainly for the reasons
21 that I stated in the first bullet which was mostly
22 your risk-significant components, valves, diesel
23 generators which doesn't necessarily come under ASME
24 but diesel generators, valves and important pumps are
25 subject to RITS 5b so it tends to be a lot of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 miscellaneous things. Control-wide motion in a
2 boiling water reactor or some of these odd
3 surveillances.

4 CHAIR STETKAR: Hey Don, batteries are
5 pretty important though.

6 MR. DUBE: Yes.

7 MR. HOWE: This is Andrew Howe again. I
8 just want to, maybe this is a fine point. I want to
9 make sure this is clear. If a component is subject to
10 inservice testing the inservice testing program
11 governs the frequency of that test. But you may do
12 other testing on that component that could be subject
13 to 5b. So it's kind of implied on those that an ECCS
14 pump is subject to inservice testing so I can never
15 change a frequency associated with any test on that
16 pump. That's not true. There are other tests you do
17 that could be subject.

18 MR. DUBE: Okay, thanks for the
19 clarification, Andy.

20 CHAIR STETKAR: Don, in the material that
21 we received I don't recall seeing these numbers.

22 MR. DUBE: Correct.

23 CHAIR STETKAR: For the subcommittee
24 meeting. Okay.

25 MR. DUBE: It wasn't part of the meeting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 minutes. It was --

2 CHAIR STETKAR: Okay. The presentations
3 tended to be sort of generic, sort of --

4 MR. DUBE: They weren't part of the
5 meeting minutes and there was no written presentation
6 by the applicant or reactor vendor.

7 CHAIR STETKAR: These are sort of
8 anecdotal.

9 MR. DUBE: If you were there at the
10 meeting -- well, they weren't anecdotal but they were
11 verbal answers. They weren't written down.

12 CHAIR STETKAR: You didn't look. You
13 didn't actually look at what they did in any detail or
14 did you? I can read these numbers here but I mean how
15 they arrived at those numbers.

16 MR. DUBE: No. How they arrived at for
17 example battery testing that has a certain failure
18 rate, or a certain probability of being in a failed
19 state upon demand and they quadrupled it, the failure
20 probability.

21 CHAIR STETKAR: Okay.

22 MR. DUBE: So they're sensitivity studies.
23 But we did not do our own calculations.

24 CHAIR STETKAR: I'm just trying to
25 understand. Those numbers weren't derived from the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 same let's say level of detail of tabletop exercises
2 for example as the ISI or --

3 MR. DUBE: They were.

4 CHAIR STETKAR: Oh, they were?

5 MR. DUBE: The licensee used the PRA
6 model, quadrupled the failure rate and looked at the
7 delta CDF. And they actually gave a number with one
8 significant figure --

9 CHAIR STETKAR: Yes, no, I'm sure,
10 probably 6.

11 MR. DUBE: But I rounded it off.

12 CHAIR STETKAR: Okay.

13 MR. DUBE: Probably two or three
14 significant.

15 CHAIR STETKAR: At least.

16 MR. DUBE: So we mentioned again kind of
17 to the bottom line-ish if there's such a word the
18 surveillance frequency program is controlled by other
19 -- that are controlled by other programs typically
20 excluded. Andy Howe answered it best, equipment
21 covered by inservice testing for example, major
22 function valves. They have some of the highest risk
23 importance in terms of risk achievement at Fussell-
24 Vesely or however you want to typically look at it,
25 and those particular tests are excluded from this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 program.

2 CHAIR STETKAR: But only the tests that
3 the inservice testing program specifically examines
4 particular failure modes for example.

5 MR. DUBE: Right, exactly. There may be
6 certain failure modes that aren't.

7 CHAIR STETKAR: That aren't tested by
8 that.

9 MR. DUBE: But these are typically, you
10 know, start the pump, run the pump, check that the
11 pressures and flow rates meet the criteria and so
12 forth.

13 CHAIR STETKAR: You don't necessarily have
14 to show that the pump actually delivers flow all the
15 way to the reactor vessel for example through the
16 injection lines. Because it's only a pump-centered --

17 MR. DUBE: It can't do that anyway.
18 Again, the Integrated Decision-making Panel's review
19 of the proposed changes strengthens the process again.
20 It's kind of a universal theme for a lot of risk-
21 informed applications. There's an Integrated
22 Decision-making Panel that reviews these to look at
23 deterministic considerations, brings to bear a broad
24 range of expertise. Some licensees have additional
25 approvals such as the Plant Operations Review

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Committee and/or the Oversight Review Board.

2 The key to this is continuous monitoring
3 and feedback and periodic reassessments are fed back
4 to the Integrated Decision-making Panel. I've
5 mentioned before the actual changes in the reliability
6 equipment is captured in the operating experience and
7 fed back into the plant-specific failure rates that I
8 use in the PRA. We mentioned before unacceptable
9 equipment performance could result in returning the
10 surveillance frequency to the previous setting
11 although we could not off the top of our head
12 specifically identify an example for the benefit of
13 the members.

14 MEMBER ABDEL-KHALIK: To the previous
15 setting but not to a more stringent setting.

16 MR. DUBE: Yes, they could. They could go
17 back to a more stringent setting as part of the
18 feedback mechanism. I can't come up with an example
19 off the top. But it's -- in addition to the --
20 there's a lot of reasons other than risk-based why one
21 might not want to substantially increase the
22 surveillance test interval. The applicant or licensee
23 has to look at the impact on defense-in-depth,
24 maintenance rule is factored in there. If they
25 increase the test interval too much and we're seeing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 increase in failure rates this could have an adverse
2 impact on the maintenance rule and shifting it from
3 routine treatment to stricter treatment. In some
4 cases it may impact the mitigating system's
5 performance index in that it could result -- if
6 there's certain failures they could result in an
7 increase in that index. And other programs are
8 impacted. There's a lot of reasons to be cautious.
9 But the licensees have expressed why not to
10 necessarily push the test interval all the way to a
11 point of having enhanced failure rates.

12 In many cases the bottom line here is
13 programs, there's programs for reasons other than risk
14 where they may not want to necessarily have a long
15 increase of test interval because it may reduce
16 operational flexibility and safety margin. If they
17 increase the test interval and were to experience
18 failures one has to, it has to be in a situation of
19 entering tech specs. There's tech spec to allow
20 outage times, completion times perhaps and one might
21 not want to push that envelope. One might want to
22 keep some operational and safety margin. Finally, we
23 mentioned the phased approach whereby surveillance
24 test intervals would be graduated from monthly to
25 quarterly to annually.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So preliminary results on RITS 5b. We
2 mentioned it's more deterministically based certainly
3 than risk-based. I mean to the extent one can do a
4 risk calculation one does it, but it's really driven
5 by factors other than risk. In many cases it's just
6 based on deterministic criteria, the feedback loop,
7 the monitoring of performance and adjustment. We
8 mentioned that there's a need for sufficient baseline
9 operating experience on affected equipment during the
10 initial cycle or cycles of reactor operation before
11 fully commencing the implementation of RITS 5b and
12 beginning the process of changing the surveillance and
13 test interval. I think that's it.

14 MEMBER BLEY: Are there going to be any
15 examples that give us a hint of how one evaluates
16 changes in defense-in-depth when you do this kind of
17 analysis?

18 MR. DUBE: I would look to some of my
19 colleagues?

20 MEMBER BLEY: I'm wondering how you
21 evaluate changes on defense-in-depth and decide if
22 they're significant or troublesome since that's one of
23 the key criteria you went through.

24 MR. HOWE: This is Andrew Howe. I really
25 can't speak to any specifics of how licensees actually

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 implement the non-risk portions of it.

2 MEMBER BLEY: Anything in the tabletops
3 that look at that?

4 MR. HOWE: I'm trying to remember how --
5 I have some of the same short-term memory problems.

6 MR. DUBE: I don't recall.

7 MR. HOWE: Anyone from industry has a
8 recollection?

9 MEMBER BLEY: I mean, those are nice words
10 but I just wonder what they mean.

11 MR. HOWE: Well I think the focus of the
12 tabletops was more on the risk aspects of this.

13 MEMBER BLEY: That's easy.

14 MR. HOWE: So it really wasn't a focus of
15 the tabletop.

16 MR. BRADLEY: This is Biff Bradley, NEI.
17 The process, the guidance has a number of steps that
18 I think inherently address the concept of defense-in-
19 depth. I don't remember that we have a specific DID
20 step but the evaluation as Don has indicated, the risk
21 aspect of this is really just a check on the result.
22 We're really looking extensively at the operational
23 history, the vendor recommendations, everything about
24 these components which, I think that's how we believe
25 we're addressing defense-in-depth. But unlike say 4b

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 or something else there is no backstop in 5b or any
2 specific DID attribute.

3 MR. TJADER: This is Bob Tjader. If I
4 could just put my perspective on the defense-in-depth
5 a little bit on this. And this may relate to whether
6 or not you ratchet the surveillance frequency to a
7 more stringent frequency than it is currently. And
8 that is surveillance frequencies and tech specs are
9 checks to ensure that systems are operable. So the
10 intent is, and not only the intent, the expectation is
11 that when a surveillance frequency is performed it
12 will succeed, it will pass, the system will pass the
13 surveillance frequency, and if it doesn't there's a
14 problem. And as was mentioned by Don, if you fail a
15 surveillance you then enter the LCO, you enter a
16 condition of inoperability and you have to restore
17 that system within a completion time. So if you are
18 in a tech spec you have lost a train for instance of
19 a system and you have lost a certain redundancy,
20 you've lost defense-in-depth. So if there is a
21 history of failing surveillance frequencies then that
22 system or component should not -- then that process of
23 NEI 04-10 should exclude that frequency from being
24 changed to a less frequent interval. If there is a
25 history of failing that surveillance it should not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 even be a candidate for having the surveillance
2 frequency changed because you have a history of
3 entering the LCO, of losing the redundancy, the
4 defense-in-depth and that type of thing.

5 MEMBER BLEY: Okay, I'll just, I'll
6 promise you guys before the next meeting I will have
7 studied the guidance a little better and understand
8 how it does the things we're hearing it's supposed to
9 be doing. And what you say makes sense but it's kind
10 of advertised a little more strongly.

11 CHAIR STETKAR: Don, go back to your slide
12 38 because I think some of the numbers on there. If
13 you look at that first bullet and I think, you know,
14 you're characterizing these in absolute terms but if
15 I look at the relative terms that change changes core
16 damage frequency by 10^{-8} so that's a number. It also
17 changes large early release frequency by 10^{-8} . Now,
18 as a percentage of total core damage frequency that
19 may be a fairly small fraction of core damage
20 frequency. It sure as heck is a much, much larger
21 fraction of large early release frequency so that to
22 me indicates that that proposed change is indeed a
23 degradation of defense-in-depth because we're much
24 more sensitive, given core damage, to getting a large
25 early release for that particular proposed change if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I interpret those numbers that way. Whereas the other
2 examples tend to march down in parallel. So that's I
3 think a bit of the notion that Dennis was curious
4 about, and how that type of comparison is evaluated in
5 terms of the prudence of increasing that. Even though
6 the absolute numbers are relatively small.

7 MR. DUBE: Right. I mean what you're
8 seeing, I don't have the results in front of me nor
9 the cutsets, but what you're seeing here is
10 preferentially affecting sequences associated with
11 electrical support systems where the conditional
12 containment failure probability is approximately 1.

13 CHAIR STETKAR: That's right.

14 MR. DUBE: But what if it, you know, just
15 the way it turned out if it had affected other
16 sequences it might have been delta CDF of 10^{-7} and
17 delta LERF still 10^{-8} , it may not have affected it.

18 CHAIR STETKAR: But I mean we have a risk
19 model and that's the only thing we can use to generate
20 those numbers. But it gives us some insights about
21 where we may be challenging that type of defense-in-
22 depth issue.

23 MR. DUBE: Again, with 10^{-6} and 10^{-6} I
24 might be concerned. I'm not sure.

25 CHAIR STETKAR: Well, but if the total

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 core damage frequency was 4×10^{-8} then the total
2 large early release frequency was 4×10^{-9} I might
3 then be concerned about this on a relative basis. You
4 know, not knowing what particular plant this is or
5 what the absolute magnitudes of those metrics were.
6 Okay, thanks.

7 MR. DUBE: That's it for that topic.

8 CHAIR STETKAR: Before we switch to this
9 topic do the members have any more questions about 5b
10 in particular, the surveillance intervals? Because
11 you're going to switch to a -- now for something
12 completely different. Nothing? Okay. Proceed, sir.

13 MR. DUBE: Okay. Yes, this is
14 dramatically different in the sense of this is not an
15 application so much but a change control process. And
16 which in the Commission SRM the staff was directed to
17 do. And in many ways does reflect itself in
18 probabilistic space or severe accident space. So
19 we'll, you know, it's on the agenda and one of the
20 tabletop exercises but I think the membership here
21 will find the presentation interesting.

22 I mentioned earlier that there's a
23 guidance on the 50.59 process for the current fleet
24 and there's a new Appendix C that's in draft stage
25 regarding a change process for the new reactor design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and the Part 52. This is looking under, put your new
2 reactor hat on, departures from Tier 1, Tier 2 and
3 Tier 2*. I'll give examples certainly of the first
4 two tiers. But in a nutshell Tier 1 are changes that
5 we need prior NRC approval. Tier 2 can receive
6 licensee or license-holder can make changes on their
7 own subject to a 50.59-like process. 2* are in
8 between and they do for the most part require staff
9 prior approval. This guidance will have, as I said,
10 one-stop shopping so it's going to have looking at the
11 impact of the design basis accidents, PRA, aircraft
12 impact, loss of large areas, Tier 2 changes to ex-
13 vessel severe accident design features. And it's the
14 last bullet which was the topic of this particular
15 exercise.

16 We had an internal workshop on this back
17 a year ago to lay the groundwork. We had a public
18 workshop in December of last year and then another
19 public workshop on the draft guidance in August of
20 this year. Now that August didn't make the deadline
21 for today's briefing but since we had done three-
22 quarters of the work might as well just present the
23 results now so that's what we're doing. So that's a
24 quick background.

25 Where does this come from? Each -- in the

1 rule language each certified design, here I give
2 Appendix VIII of Part 52 which is Advanced Boiling
3 Water Reactor. These are exact wording of the change
4 process and it comes under VIII.B.5.c and it states
5 verbatim that a proposed departure from Tier 2
6 affecting resolution of an ex-vessel severe accident
7 design feature identified in the plant-specific design
8 control document requires a license amendment if
9 either one of two conditions are met: there's a
10 substantial increase in the probability of an ex-
11 vessel severe accident such as a particular ex-vessel
12 accident previously reviewed and determined to be not
13 credible becomes credible -- that's a mouthful -- or
14 there's a substantial increase in the consequences to
15 the public of a particular ex-vessel severe accident
16 previously reviewed.

17 Now, this rule language has been there
18 since the very first design certifications 15 years
19 ago or so and to this date no one has defined what
20 does it mean by substantial increase. So it was our
21 task force challenge to if not come up with a complete
22 definition of "substantial increase" at least say this
23 is what it looks like, what a substantial increase
24 might look like. It's like a piece of art. I noticed
25 on Dr. Shack's background or screensaver he had a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 piece of art, it looks like Van Gogh or somebody,
2 something, I don't know. You don't know what
3 beautiful art is, you can't give a definition to it
4 but you know it when you see it. So we started coming
5 up with very precise definitions of "substantial
6 increase" and we ended up coming often into circular
7 logic and it was very hard to pinpoint a definition,
8 especially since the lawyers haven't come up with a
9 definition for 15 years. So we tried to come up with
10 examples and work that way, and you'll see some of the
11 outcome.

12 But let me begin by saying what is an ex-
13 vessel severe accident design feature. The
14 rulemaking, specifically the statements of
15 consideration behind the rule are very explicit and
16 for the advanced boiling water reactor, the final
17 rule, it applies to, quote, "severe accident features
18 where the intended function is relied upon to result
19 in postulated accidents, when the core is melted and
20 exited the reactor vessel and the containment is being
21 challenged." You know, very narrow definition of an
22 ex-vessel severe accident. So when one's going
23 through the process you're looking at those features
24 specifically put there for that purpose. So their
25 core catchers or reactor cavity flooding systems, base

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mat material, what have you, any of these features,
2 but things to prevent core damage not necessarily
3 because it's to prevent or mitigate ex-vessel.

4 In addition, the commission was cognizant
5 of features that have intended functions to meet
6 design basis and resolve severe accidents. And if
7 it's a feature that has a dual role, a dual function,
8 if the change is being made that could impact design
9 basis accidents and pretty straightforward, they were
10 Chapter 15 typically of the design control document.
11 One uses the VIII.B.5.b criteria. If it's an ex-
12 vessel severe accident feature one would be using the
13 B.5.c criteria.

14 The regulations are pretty clear what are
15 meant by challenges to containment integrity. And the
16 design control document that applicants submit are
17 required to address how -- to submit how they address
18 the following containment integrity challenge issues:
19 core-concrete interaction, steam explosions, high-
20 pressure core melt ejection, hydrogen combustion and
21 containment bypass. But when we had the first two or
22 three, these two or three internal and external
23 workshops we did struggle with containment bypass.
24 That's, for example, interfacing systems LOCA or an
25 induced, thermally induced steam generator tube

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 rupture. It didn't necessarily meet the definition of
2 ex-vessel severe accidents and so it was the consensus
3 of workshop participants that while features that
4 address containment bypass certainly are important
5 from the severe accident viewpoint they did not meet
6 the rule language as an ex-vessel severe accident
7 criteria. And it was the consensus that features that
8 address that, these are like to prevent high-pressure
9 to low-pressure situations or interlocks for example
10 on valves would not necessarily fall under VIII.B.5.c
11 criteria. They might fall under other criteria and
12 may in many cases be subject to staff review, but they
13 do not fit ex-vessel severe accident features
14 criteria.

15 CHAIR STETKAR: Don, let me -- hold up
16 there. Because this is sort of a very different topic
17 and I haven't really thought about this very much.
18 But going back to that example from the last
19 presentation about the conditional containment failure
20 probability being 1 given the loss of all dc.

21 MR. DUBE: It wasn't necessarily a loss of
22 all dc but I hear your point. Yes.

23 CHAIR STETKAR: Whatever it was then.

24 MR. DUBE: Right.

25 CHAIR STETKAR: That could be a line

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that's directly, you know, if we're talking about ex-
2 vessel events then we're talking about containment
3 isolation for example. Is that not a candidate under
4 VIII.B.5.c in the context of the way -- that's the
5 separate issue for containment?

6 MR. DUBE: No.

7 CHAIR STETKAR: You would say no. So this
8 is a very, very narrowly defined set of conditions.

9 MR. DUBE: We're using rule language and
10 the statements of considerations.

11 CHAIR STETKAR: Okay. But redefining the
12 concept of what is called a containment bypass. The
13 red section on your slide there says there's
14 apparently still some --

15 MR. DUBE: In and of themselves --

16 CHAIR STETKAR: New definition of what
17 that might mean.

18 MR. DUBE: -- they may not be ex-vessel
19 severe accident features.

20 CHAIR STETKAR: Okay. What is then a
21 containment bypass if it's not, you know, an actual
22 tube rupture, an induced tube rupture or an
23 interfacing system LOCA?

24 MR. DUBE: It's in Never Never Land. In
25 fact, that's one of our conclusions from this.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: There is no containment
2 bypass under VIII.B.5.c.

3 MR. DUBE: It's like an orphan. It never
4 had the best home. The home right now would be, one
5 would evaluate under VIII.B.5.b because that's the
6 fallback. But it doesn't fit ex-vessel severe
7 accident.

8 CHAIR STETKAR: So you're saying that, you
9 know, the attorneys crafted these things and the
10 attorneys hadn't really thought too carefully about
11 what containment bypass might be?

12 MR. DUBE: I don't know. We're correcting
13 this.

14 CHAIR STETKAR: Okay.

15 MEMBER REMPE: So when you have a
16 statement later on that talks about a non-ex vessel
17 severe accident, when I was reading this I was going
18 well, why doesn't he just say in-vessel and that's why
19 you have that phrase, right?

20 MR. DUBE: Yes.

21 MEMBER REMPE: Okay.

22 MR. DUBE: Yes.

23 CHAIR STETKAR: Okay.

24 MR. DUBE: One of the insights from this
25 activity is we don't have the best home for it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Yes, okay.

2 MR. DUBE: In my opinion.

3 CHAIR STETKAR: I mean, as long as there's
4 a home for it someplace, that's the important issue.

5 MR. DUBE: And it turns out there's very,
6 very strict design information in Tier 1 for things
7 like interfacing system LOCA for the pressure
8 interlock valves between high-pressure and low-
9 pressure. I mean, one would think so but. So you
10 know, the whole purpose of this is what has to get
11 staff review, that's the whole purpose of this. Since
12 Tier 1 has to have staff review, feel comfortable by
13 luck --

14 (Laughter)

15 MR. DUBE: -- would require staff review.
16 Because there's a lot more detail in Tier 1 than one
17 would expect. But I'll give you some examples here.
18 So, examples of ex-vessel severe accident features.
19 Reactor cavity flooding systems to promote in-vessel
20 cooling and retention of core debris. This would be
21 in AP1000 would take credit for cooling the reactor
22 vessel. And yes, there's a small probability that for
23 some sequences it may not be able to retain it in-
24 vessel but for many sequences it does. And that would
25 be an example. Reactor vessel depressurization to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 promote in-vessel cooling and retention of core
2 debris. In AP1000 a pre-condition to be able to cool
3 the vessel externally is to depressurize. If they're
4 not able to depressurize the reactor cooling system,
5 the AP1000 PRA Level 2 model assumes it would be a
6 containment failure probability of 1.

7 Reactor cavity flooding to promote ex-
8 vessel cooling of core debris in the lower reactor
9 cavity or base mat area. Reactor cavity designed to
10 enhance core debris spreading and coolability,
11 containment over-pressure protection, combustible gas
12 control. These are igniters and passive catalytic
13 converters. And containment sprays.

14 CHAIR STETKAR: The interesting thing
15 though is on this bullet you call out containment
16 over-pressure protection, containment sprays and heat
17 removal.

18 MR. DUBE: Or it could be --

19 CHAIR STETKAR: Why did they belong in
20 this bin and are not covered under the other design
21 features the same way as my magic dc power sort of
22 thing?

23 MR. DUBE: For example, AP1000 has a non-
24 safety containment spray system.

25 CHAIR STETKAR: Oh, okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DUBE: Fits this criteria. It's not
2 taking platform design basis accident.

3 CHAIR STETKAR: Okay.

4 MR. DUBE: ABWR has a passive hardened
5 wetwell vent is another example that fits here.

6 CHAIR STETKAR: Okay.

7 MR. DUBE: So again, features specifically
8 to address containment bypass don't have -- doesn't
9 have a home here. And to give you an example of a
10 Tier 1, here's from the advanced pressurized water
11 reactor. This is a Tier 1 so any changes to this
12 would require prior NRC approval. This is under the
13 fire protection program but you see in red the fire
14 protection system is to put out fires, but it also can
15 provide containment spray and water injections to the
16 reactor cavity for severe accident mitigation. Very
17 specific. So if they were to make any changes where
18 -- it's kind of a go/no-go where they wouldn't be able
19 to credit this now for flooding the cavity that would
20 obviously require prior staff approval. Under Tier 1,
21 the same feature but in the containment system it
22 appears there with different wording but fire
23 protection water injection may also be used to inject
24 water to the drain lines from the steam vent
25 compartment to the reactor cavity. So these are high-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 level, system-level, function-level changes. They
2 could not make any changes to this without prior staff
3 approval. But they could make changes to Tier 2 and
4 if they did it would have to go through this 50.59-
5 like process and say what's the impact on design basis
6 accidents, what's the impact on ex-vessel severe
7 accidents.

8 And so here the similar language, it turns
9 out to be pretty general. Under the fire protection
10 program for severe accident mitigations, containment
11 spray system and water injections of the reactor
12 cavity. Sometimes you see the same general language
13 in Tier 1 and Tier 2 but often you'll see very
14 specific language in Tier 1 and more frequently than
15 not a lot of specific language in Tier 2. So here
16 under Tier 2 you really see even more specific. Under
17 fire protection system you have 200 percent capacity
18 pumps. One is diesel-driven and one is electric
19 motor-driven fire pump. So could the applicant or the
20 license-holder -- they could make a change to Tier 2,
21 not a change to Tier 1. Under Tier 1 they have to
22 have some kind of system to flood the cavity. Tier 2
23 gets specific as you have to have 200 percent capacity
24 pumps, one's diesel-driven, one's electric-driven.
25 They could propose a change to this and let's say go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 from 200 percent to 250 percent. If it has a design
2 basis, a licensing basis, a function, they have to
3 review it against those criteria. And if it has ex-
4 vessel severe accident function they would have to
5 review it against that. And obviously the fact that
6 the diesel-driven is ac-independent helps mitigate
7 against a number of station blackout sequences has to
8 be taken into consideration before they may propose a
9 change.

10 CHAIR STETKAR: But from a licensing
11 review if it's not in a Tier 1 it's simply, they do
12 the justification and it's an inspection and audit
13 function, right? From the staff's review of changes
14 if it's something that's only in Tier 2, not Tier 2*,
15 not Tier 1, the staff --

16 MR. DUBE: There's very little that's just
17 in Tier 2 that's not in one way, shape or form in Tier
18 1.

19 CHAIR STETKAR: I'm going to get to the
20 second part of the question first. I don't want to
21 understand how the staff -- the staff review. If I
22 went in under the red highlighted material that you've
23 just presented and I decide to put in one and only one
24 crank-driven --

25 MR. DUBE: You change from 2 to 1 because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this --

2 CHAIR STETKAR: Okay, I change from 2 to
3 1 then, and it's motor-driven or you know, manual
4 mechanical driven, whatever. I haven't changed
5 anything in Tier 1. I've simply changed this. In
6 terms of the staff's review of that change that's
7 simply an inspection audit function of the analysis
8 that the, at that time the licensee would perform, is
9 that right?

10 MR. DUBE: At the end of an operating
11 cycle and I forget the frequency the staff, the
12 licensee is to provide the staff with a summary of the
13 changes made under 52. And the staff's resident
14 inspector or otherwise can subject and question the
15 licensee on an adequate or inadequate 50.59 safety
16 evaluation, 50.59-like safety evaluation.

17 CHAIR STETKAR: Now, in the context of
18 this particular narrowly focused ex-vessel severe
19 accident topic the -- is there -- you're NRO. When
20 the staff looks at the design certification is there
21 an active effort made to think about functions that do
22 perform the EVSA --

23 MR. DUBE: Yes.

24 CHAIR STETKAR: -- activity and make sure
25 there's a hook back up into Tier 1?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DUBE: Yes.

2 CHAIR STETKAR: Or at least --

3 MR. DUBE: I think that another important
4 insight of this is you find the design control
5 documents fit two molds. One of them is these things
6 are scattered throughout the design control document
7 in the least likely places. Who would think -- I mean
8 if you're intimately familiar, fine. But who would
9 think you'd have under the fire protection system an
10 ex-vessel severe accident feature. In other cases,
11 I'll give credit, advanced boiling water reactor has
12 all of these features in one nice table. Staff can't
13 require but we strongly encourage as a result of this
14 tabletop and we've said it several times, it would be
15 nice if there was a roadmap to all these features so
16 that pity the system engineer at a plant responsible
17 for fire protection. They've got to do their
18 homework.

19 CHAIR STETKAR: Well and you the staff
20 need to do all of this highlighting as each of the
21 individual system reviewers go through their function.

22 MR. DUBE: And this is a paradigm shift
23 having worked at a nuclear utility for over a dozen
24 years. You need people at plant site familiar with
25 severe accident space because one has to be aware that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 some of this equipment is credited for design basis
2 accident analysis and severe accidents. I mean it's
3 a whole different skill set.

4 CHAIR STETKAR: Yes.

5 MR. DUBE: Just an insight. I mean, just
6 observation. So here's a -- so, one would have, if
7 one proposed a change, I mean they have to obviously,
8 realistically would anyone go from a diesel-driven
9 pump to electric to a hand-cranked? No, but one has
10 to look at the impact on the fire protection program,
11 licensing basis, commitments and severe accident. And
12 someone has to wear a severe accident hat at the site
13 in my opinion.

14 So here's the penetration. One would find
15 this in 6.2, the containment section of the design
16 control document, Tier 2. So theoretically any
17 changes to this penetration, I'm talking substantive
18 change obviously, replacing the check valve with
19 something else, normally a locked closed motor-
20 operated valve. You know, a connecting line from fire
21 pump. It would have to go through a 50.59-like
22 process looking at the impact on the licensing basis,
23 the design basis space and potentially ex-vessel
24 severe accident space.

25 CHAIR STETKAR: Unless they remove that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 check completely does that impact the Tier 1?

2 MR. DUBE: Probably because this is --

3 CHAIR STETKAR: So that isn't the 50.59,
4 that's actual change to the --

5 MR. DUBE: That's a design basis
6 requirements.

7 CHAIR STETKAR: -- design basis change.
8 Okay.

9 MR. DUBE: You couldn't do that. So, why
10 are we here? One of our tasks was to try and come up
11 with definitions of "substantial increase" and it was
12 difficult. We looked within the staff, we looked at
13 qualitative, quantitative definitions, combinations.
14 Fortunately the commission kind of helped lead us in
15 the sense that staff requirements memorandum that I
16 mentioned earlier strongly influenced our decision to
17 refrain from a quantitative definition. The fact that
18 the commission told us do not change the risk metrics
19 in so many words led us to believe that we -- and not
20 to institute new risk metrics or quantitative criteria
21 tended to lead us to try and avoid coming up with a
22 strict quantitative definition of what is a
23 substantial increase. I mean, is it a 10 percent
24 increase, is it a 100 percent increase, is it a 10, I
25 don't know. It's like again going to nice classical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 art. I know it when I see it but I can't tell you 10
2 percent is substantial, it depends on context, depends
3 how close one is to a certain margin. If that 10
4 percent increase put them above 10⁻⁴ core damage
5 frequency goal or 10⁻⁶ large early release frequency
6 goal, that would be different than if they had so much
7 margin that 100 percent increase wouldn't make any
8 difference. We ended up with so many and's and or's
9 you know in a quantitative definition that we tried to
10 stay away. We were concerned with creating a de facto
11 new risk metric that the commission told us not to do
12 so we shied away from a quantitative definition of
13 substantial increase. I think what we have should do.
14 I think it's in the right direction.

15 For evaluation of substantial increase in
16 probability we mentioned just a few minutes ago that
17 each design control document in fact states whether
18 and how each severe accident challenged containment
19 has been addressed either qualitatively or
20 quantitatively. Go back, way back to these challenges
21 to containment integrity. By regulation the applicant
22 reported how they addressed these phenomena and they
23 may have used words like it's incredible, not
24 physically feasible, impossible, so on and so forth
25 but they addressed why these phenomena, how they've

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 addressed these phenomena and why they're no longer of
2 key concern at their particular reactor design. In
3 some cases they use quantitative definition, in some
4 cases qualitative definition, and that's fine. But
5 either qualitative or quantitatively it is stated in
6 the design control document how they've addressed
7 those phenomena and made the concern basically low, of
8 low risk importance.

9 So part of the definition was we said
10 well, you know, as part of the guidance we've used
11 words like don't use the, you know, don't focus in on
12 not credible. The license-holder has to look at how
13 they may have used quantitative definitions,
14 qualitative definitions but they may have used
15 practically eliminated, not physically feasible, not
16 relevant, and they have to take that into
17 consideration. Unfortunately like I said it would
18 have been nice to have the definition 15 years ago but
19 the horse is out of the barn and we can't go back.
20 But we can put in the guidance to say hey, just don't
21 focus in on credible definition. Look at how one
22 eliminated these concerns. A change that adversely
23 affects the original basis for not being credible
24 could be a substantial increase, and we'll give
25 examples. For example, in the US EPR the strategy is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to convert high-pressure core melt sequences into low-
2 pressure sequences. And these are, that's a
3 paraphrase and the exact quote is so that a high-
4 pressure vessel breach can be practically excluded.
5 This is achieved through two dedicated severe accident
6 depressurization valve trains. So it states right
7 there in the design control document that they've
8 addressed the potential for high-pressure melt
9 ejection, direct containment heating and these other
10 ex-vessel severe accident features by turning high-
11 pressure sequences into low-pressure sequences. And
12 they even got more specific and said we had two
13 dedicated depressurization valve trains so there's
14 redundancy there.

15 CHAIR STETKAR: And that's in DCD Tier 1
16 of the US EPR?

17 MR. DUBE: I don't recall off the top.

18 CHAIR STETKAR: Because you've quoted it.

19 MR. DUBE: I think this might be in
20 Chapter 19 of Tier 2. But the basis is, this sets the
21 basis. The reason it's, quote, not credible or we use
22 the word excluded is because of these two trains. So
23 if they made a substantial change or did something to
24 go from that, from two trains to one train or
25 substantially increase the reliability, availability

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of these systems that would negate the basis for why
2 they excluded this in the first place. So train, a
3 feature that was, that addressed the severe accident
4 challenge and made it, use the word you want, not
5 credible, physically impossible, not relevant,
6 practically eliminated. That would make it now in the
7 realm of credible would be a substantial increase.
8 And here in this particular example it would be
9 certainly going from two trains to one train. I mean,
10 one can't write this for all the possibilities and
11 combinations. You've got to leave some latitude to
12 the --

13 CHAIR STETKAR: But for example, let's
14 stick to the two-train and you know, I don't recall
15 and it doesn't make any difference the details of that
16 particular design but if for example those were
17 automatically actuated valves given, you know, core
18 exit temperatures or pressures or something like that,
19 and they change, didn't change it from 2 to 1, but
20 changed them to manually operated is that a
21 substantial change?

22 MR. DUBE: Yes. And the guidance that
23 we've written says to take a look at those things, the
24 power supplies changing from automatic to manual and
25 then there's a number of criteria.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Okay. And you say
2 guidance you've written, it's the --

3 MR. DUBE: That's the NEI and its
4 contractors wrote it and the staff reviewed it and
5 provided substantial comment and proposed changes.

6 CHAIR STETKAR: Is there a reg guide
7 coming out or is it?

8 MR. DUBE: It's Appendix C.

9 CHAIR STETKAR: Oh, it's Appendix C.

10 MEMBER SHACK: Which we haven't seen.

11 CHAIR STETKAR: Okay. I was curious. I
12 didn't remember it but my short-term memory is worse
13 than anybody's.

14 MR. DUBE: I don't know if that was
15 included.

16 MEMBER SHACK: I didn't find it.

17 CHAIR STETKAR: Trust me, if he didn't
18 find it it's not.

19 MR. DUBE: It was sent but it was not
20 identified Appendix C. But it was a marked up
21 guidance for ex-vessel severe accident features. You
22 didn't see -- you wouldn't have seen all of Appendix
23 C.

24 MEMBER BLEY: Because of the ex-vessel
25 stuff that you sent.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DUBE: Because that has design basis
2 changes, LOLA, aircraft impact, so forth. But the
3 two- or three-page lineup specifically on ex-vessel I
4 believe was part of --

5 MR. POWELL: It's an enclosure to the ex-
6 vessel severe accident meeting that we held.

7 MEMBER BLEY: Oh, the meeting summary?

8 MR. POWELL: Yes. It's an enclosure to
9 that meeting.

10 CHAIR STETKAR: The only thing I have is
11 slides from the presentation from that meeting.

12 MEMBER REMPE: There's a four-page
13 summary.

14 MEMBER BLEY: But it has no enclosures.

15 MEMBER REMPE: Yes, I don't see an
16 enclosure to it.

17 CHAIR STETKAR: That's okay. We'll get a
18 --

19 MR. DUBE: We'll check on it. It should
20 have been part of the meeting summary. Oh, I know
21 why.

22 CHAIR STETKAR: The meeting summary is
23 just the short --

24 MR. DUBE: It did not include them because
25 it didn't make the cutoff.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Oh, because of the August
2 9th meeting.

3 MR. POWELL: Oh yes, that was part of the
4 50.69 meeting.

5 CHAIR STETKAR: You mentioned in the
6 introduction that you had a meeting on August 9th I
7 think you said. Okay.

8 MR. DUBE: But the staff did formally,
9 first week of September formally sent to NEI a marked
10 up Appendix C subsection on ex-vessel.

11 CHAIR STETKAR: We'll hear about that then
12 in February let's say or whatever we're targeting for
13 the next subcommittee meeting.

14 MR. DUBE: Unless you're interested in the
15 interim.

16 CHAIR STETKAR: Then as a practical sense
17 I don't think we'd be interested. I don't think it's
18 feasible.

19 MR. DUBE: We'll work with you. Okay.
20 Substantial increase in public consequences. Again,
21 we looked at qualitative and quantitative definitions.
22 It's hard to come up with a definition. Sometimes
23 it's easier to say what is not a substantial increase
24 by demonstrating how the affected functions would
25 still be successfully accomplished. In so many words

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that's -- and then we added to that by saying a
2 substantial increase would be for departures that
3 remove, defeat or significantly degrade the
4 performance in an ex-vessel severe accident design
5 feature and tied it back to for example containment
6 performance goal in SECY-93-087 and SECY-90-016 would
7 no longer be met. These are commission papers and a
8 staff requirements memorandum endorsing a number of
9 severe accident features to address severe accident
10 phenomena. And again, maybe it's easier to give
11 examples on these than to come up with a verbatim or
12 exact quote.

13 An example of not an increase in public
14 consequences would be a licensee or it actually could
15 be not quite a licensee, someone -- well, it would be
16 a licensee in the COL. So a licensee identifies a
17 non-conformance in that the thickness of a portion of
18 the reactor cavity floor concrete is 0.1 foot less
19 than the minimum thickness specified in Tier 2 of the
20 reference DCD. You'd be surprised but many of these
21 dimensions are actually in Tier 1 which the license-
22 holder could not change without prior NRC approval.
23 But let's say for example that there was some
24 specifics on base mat thickness and then there was a
25 non-conformance. Because typically they're not going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to -- one would not purposely reduce the thickness but
2 it's possible as a result of going back and inspecting
3 and the concrete's been laid out, finding the non-
4 conformance. We've got to justify that it's
5 acceptable and not a substantial increase of public
6 consequences. One could look back at the severe
7 accident analyses that were done, either the MAAP
8 analyses, MELCOR analyses, whereby there were ex-
9 vessel calculations done on core concrete interactions
10 for example. And one of the important criteria was
11 that for the most likely severe accidents that
12 containment integrity would hold for at least 24 hours
13 after the initiation of the accident. One would look
14 and say there's a large margin between when one would
15 start to challenge containment integrity resulting
16 from these calculations to the 24-hour. At one point
17 one-tenth of a foot easily falls within the capability
18 and would not impact any of the conclusions regarding
19 the capability to withstand 24 hours, maintain
20 integrity for 24 hours and would not impact any of the
21 guidance in the commission papers.

22 So then I have to go back. You can't just
23 write it off and go back for the -- look at the
24 calculations or the original basis for concluding that
25 a particular ex-vessel or several ex-vessel severe

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 accident challenges were addressed and reached a
2 logical conclusion that 1.2 inches in thickness
3 doesn't impact the original basis. On the other hand
4 there may be another example based on comparison with
5 existing analysis. Oh, that just provides the basis.
6 I'm sorry.

7 An example of increasing of public
8 consequences on the other hand might be where a
9 licensee considers reducing the capacity of the
10 containment venting system by 50 percent either
11 because -- it may be advertent or it may be
12 inadvertent. It may be intentional or unintentional
13 but for whatever reason one found the situation where
14 the containment vent flow rate was reduced 50 percent
15 from what the staff had previously reviewed and
16 approved in the original design control document. The
17 licensee performs the calculation, determines that the
18 50 percent reduction would significantly degrade the
19 containment venting function such that the containment
20 may not be able to survive the pressures associated
21 with the containment performance goals in 93-087, 016
22 as approved by the staff requirements memorandum and
23 described in the standard review plan. So it's not
24 sufficient for the license-holder to do a perfunctory
25 review. They have to go back and look at the original

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 basis, especially for a substantive change like this.
2 So it's possible that some changes are just editorial,
3 talking about changes to the Tier 2 design control
4 document, are not substantive and can easily be
5 screened out. And there's a process in the Appendix
6 C to screen out but certainly a substantive change
7 like this the licensee would be expected to go back,
8 review the original basis for why this system is
9 designed the way it is.

10 MEMBER SHACK: But I mean, you know, this
11 one really could get kind of tricky. I mean, if the
12 original venting was designed to keep it within say
13 design basis pressure but this new one lets you go up
14 to 1.5 times design basis pressure does that
15 significantly degrade the containment? In its
16 ultimate strength? I mean, that's getting to be kind
17 of a judgmental thing here.

18 MR. DUBE: Yes, it is judgment here.
19 Obviously this system is not credit for design basis
20 accident analysis.

21 MEMBER SHACK: Right. But how far above
22 design basis do I go before I significantly degrade
23 the survivability of the containment?

24 MR. DUBE: Well, in this particular plant,
25 assume this is advanced boiling water reactor which we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 purposely left out because in fact in Tier 1 of the
2 ABWR specifies flow rates and pressures. So we want
3 to make the example useful without you know making it
4 a moot but if this were the advanced boiling water
5 reactor they wouldn't even be able to change -- they
6 wouldn't be able to change this under Tier 1 anyway.

7 MEMBER SHACK: Because it's a flow rate --

8 MR. DUBE: Because it actually specifies
9 flow rate, kilogram per second of steam at certain
10 pressure. Let's just say there's a new design out
11 there that hasn't applied yet and so on and so forth.
12 So we want to make the example useful but the answer
13 to your question is I would have to go back, look at
14 what the set point is for the design, what were the
15 flow rates. Was it design intended to limit pressure
16 to 95 percent confidence that you wouldn't exceed the
17 ultimate failure probability or some other value.
18 Sets the original basis and say if I reduce the 50
19 percent would that conclusion change. If the answer
20 is yes it would change that conclusion it could be a
21 substantial increase in public consequences. It still
22 falls within the original basis. If they had margin,
23 then it might not be.

24 MEMBER SHACK: Suppose I still had 70
25 percent confidence that it would survive.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DUBE: Now you know why we didn't have
2 quantitative ID.

3 MR. ADER: Hey Don?

4 MR. DUBE: Go ahead.

5 MR. ADER: I think there's also service-
6 level C for 24 hours is one of the containment
7 performance metrics. Service-level C would be, you
8 know, precise.

9 MEMBER SHACK: Would be the criteria that
10 you would use.

11 MR. DUBE: Right. In that particular
12 example. Thank you, Charles.

13 CHAIR STETKAR: Are there subtle things
14 that creep in here? For example, you know, looking
15 forward 50 years, 60 years in the future when the new
16 reactors are coming in for power uprate, or 30 years
17 in the future, power uprate, somebody does a 20
18 percent power uprate on a new reactor. That in
19 principle would need to be evaluated relative to these
20 criteria also, whatever the criteria are.

21 MR. DUBE: They need to be reviewed.

22 CHAIR STETKAR: Because that's not so much
23 degrading the mitigation system, it's increasing the
24 input hazard.

25 MR. DUBE: And that's the reason for one-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 stop shopping on Appendix C to put all the change
2 processes there. And that example, to put some
3 definition and examples here. Another good reason why
4 it would be nice if each reactor vendor consolidated
5 or at least put some kind of referencing of all these
6 features in one place. It's another reason why, you
7 know, I'm getting ahead of myself but under Reg Guide
8 1.174 it would be nice to have a step in there that
9 says look at these features for new reactors because
10 it's something different that you don't have.

11 CHAIR STETKAR: It would be nice to look
12 at them for old reactors too.

13 MR. DUBE: Well. There's nothing driving
14 new current reactors.

15 CHAIR STETKAR: I understand.

16 MR. DUBE: Right now. So the preliminary
17 results of this little exercise. We focused on
18 definition examples of substantial increase. Certain
19 I'll call them severe accident features do not address
20 ex-vessel conditions and appear not to be in scope by
21 the rule. For example, features to prevent
22 ISLOCA/containment bypasses. A clear example that
23 doesn't have a home right now, the guidance says
24 evaluate under VIII.B.5.b which is the design basis
25 function. I mentioned here, I didn't use the word

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 "lucky," I used the word "fortunately" there's enough
2 details in Tier 1 that such features cannot be removed
3 and significant design changes are precluded. In
4 fact, I did for the AP1000 went through quite a bit of
5 detail and looked at some of these aspects and did a
6 mapping of features that helped address severe
7 accidents but not be ex-vessel. Fortunately, you
8 know, a lot of these like right in Tier 1 it says, you
9 know, you have such and such valves at such design and
10 the low-pressure piping outside containment has to be
11 able to withstand realistically full reactor coolant
12 system pressure capability. That's in one of the
13 commission papers. And you have to have these
14 interlocks and so on and so forth. So for some of the
15 important issues of concern there's backstops if you
16 will, but you can't rule out some, you know, plant
17 down the line not having this detail in Tier 1.

18 CHAIR STETKAR: Yes, I was going to say,
19 you know, the words "fortunately" here and the fact
20 that you went back and looked at AP1000 and sort of
21 satisfied yourself that there was adequate protection
22 if you want to call it that in Tier 1 for that
23 particular design. You know, we're still looking at
24 other design centers and it would be a real
25 confidence-builder I think for us to be able to hear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that people in the staff are actively doing that, you
2 know, absent the nice table of things that apparently
3 the applicants may have some reluctance to deliver.

4 MR. DUBE: So for now this is in, it's
5 right in the guidance in the ex-vessel portion. It
6 says containment bypass, need to evaluate under here.
7 So there is review that's done but it's not, you know,
8 it's not the best home.

9 CHAIR STETKAR: Yes.

10 MR. DUBE: Probably the best way to put
11 it. So we haven't -- this was unanticipated. We
12 haven't decided what we will do with this in terms of
13 the commission paper and so on and so forth. We're
14 still trying to evaluate what to do with this orphan.
15 I mean, there is, like I said, there is guidance,
16 specific guidance now that says take a look at
17 containment bypass but it's not an ex-vessel severe
18 accident feature and does not appear to come under
19 this particular process. But there are other
20 processes that would look at it.

21 CHAIR STETKAR: Yes.

22 MR. DUBE: That's it.

23 CHAIR STETKAR: Okay. Any member
24 comments, questions on this topic? If not we
25 certainly don't want to launch into 4b and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 maintenance rule so we will recess for lunch until
2 1:00. Thank you.

3 (Whereupon, the foregoing matter went off
4 the record at 11:47 a.m. and went back on the record
5 at 12:59 p.m.)

6 CHAIR STETKAR: Okay, we are back in
7 session and I guess we'll hear about initiative 4b and
8 the maintenance rule.

9 MR. POWELL: My name's Eric Powell and
10 I'll be presenting the tabletop exercise on risk-
11 informed tech spec initiative 4b and also on
12 maintenance rule 50.65(a)(4). An overview of my
13 presentation is as follows. I will begin by
14 discussing key methodology and guidance documents, and
15 for RITS 4b the primary guidance document is NEI 06-
16 09. And for Maintenance Rule (a)(4) the primary
17 guidance document is NUMARC 93-01. The rest of my
18 presentation will cover the ABWR SPAR model case
19 studies that were performed, the AP1000 SPAR model
20 case studies, the vendor calculational results and I
21 will conclude with the maintenance rule (a)(4).

22 For the ABWR SPAR model case studies some
23 of the assumptions were that only internal events at
24 power were modeled. CDF values are point estimates.
25 The truncation was set at the default for the ABWR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 SPAR model and that was 10⁻¹³. All tests and
2 maintenance set to false for all cases and any
3 equipment that we took out in the cases we modeled the
4 test and maintenance as set to true.

5 CHAIR STETKAR: Eric, I don't know how
6 much you've played with these models and I certainly
7 haven't played with them at all. You said you don't
8 have -- do you have an external events model for the
9 ABWR?

10 MR. POWELL: Not currently.

11 CHAIR STETKAR: Do you have any sense,
12 have you looked at other SPAR models where you -- have
13 you run any of these cases for other SPAR models for
14 currently operating plants where you do have both
15 internal and external events in the model. And do you
16 see, if you have do you see any substantive difference
17 when you include the external events. In other words,
18 that the external events, part of the model may be
19 more sensitive to particular equipment being out of
20 service than the internal events model.

21 MR. POWELL: For the purposes of the
22 tabletop that we performed we did not look at any
23 existing SPAR models. We just looked at the ABWR
24 which is the GE version and the AP1000.

25 CHAIR STETKAR: I understand that. I just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 wanted to ask a question about, you know, to see if
2 there's any --

3 MR. DUBE: Well, I may call on my
4 colleague from NRR but there are some plants where
5 certain equipment is taken a lot of -- heavy dose of
6 credit is taken for external events like fire. I
7 mean, it's like the safe shutdown path and there you
8 can see big deltas. I would not expect that for new
9 designs where you have three and four trains,
10 physically separated, highly redundant. But as part
11 of the ROP we are doing calcs onlike the significance
12 of certain equipment being out of service for a
13 certain period. Times that we got input from vendors.
14 Right off the top of my head we're saying almost equal
15 amounts from fire and internal.

16 CHAIR STETKAR: Okay, so that may rise to
17 the surface when you look at the ROP stuff.

18 MR. DUBE: Right.

19 CHAIR STETKAR: Even within the context of
20 these exercises.

21 MR. DUBE: Yes.

22 CHAIR STETKAR: Okay, thanks.

23 MR. POWELL: Okay, so I want to give you
24 kind of a flavor for our overall philosophy of the
25 cases that we decided to run. As part of the tabletop

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 exercise. Don and I sat down and we were discussing
2 that we wanted to come up with a systematic approach
3 to taking various equipment out. And that's shown by
4 we grouped it in various ways. And we also wanted to
5 not necessarily think about and limit the cases that
6 we ran up front, we wanted to almost do an academic
7 exercise and try to run as many cases as we could
8 postulate and push the limits of RITS 4b. And then
9 after we did that we wanted to come back and apply the
10 commission direction of what would be realistic cases.

11 And so with that in mind we came up with
12 24 unique cases to run for the ABWR to test the
13 application of RITS 4b. And what I was touching on
14 with the groupings, we took equipment out of service
15 and we took electrical equipment out for the ABWR and
16 that consisted of the diesel generators and also the
17 combustion turbine generator. Then we looked at
18 various ECCS equipment which consisted of RCIC high-
19 pressure core flooders and low-pressure flooders. Then
20 we looked at a combination of the electrical and ECCS.
21 And then the fourth step was a combination of all of
22 that equipment with the ac independent water addition.

23 This is slide 65. This slide shows the
24 electrical connection to equipment taken out of
25 service for the cases that we ran with the SPAR model.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And if you look it's broken up into three divisions,
2 and division 1 has a diesel generator and a low-
3 pressure flooder. Division 2 has a diesel, a high-
4 pressure core flooder and a low-pressure flooder. And
5 division 3 has a diesel, a high-pressure core flooder
6 and a low-pressure flooder. And over top of all there
7 divisions you have a combustion turbine generator that
8 can provide electricity to various equipment in those
9 divisions. And also other equipment that we looked at
10 as part of the cases were the RCIC and also the ac
11 independent water addition.

12 So on slide 66 the configurations that
13 were modeled in the 24 unique cases were one of these
14 three types, configuration A, B or C. Configuration
15 A is what we would classify as most likely where you
16 would have one division out for a planned maintenance.
17 Division 2, or I'm sorry, configuration B would be
18 where you'd have division 1 out for planned
19 maintenance and division 2 out either due to planned
20 or emergent. And we said this is a realistic case.
21 And the vertical dashed line is to represent a
22 snapshot in time of where the cases were run for the
23 SPAR model. Because it wasn't like a time period, it
24 was at a specific instant in time. And then
25 configuration C is something that was unlikely but for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the purposes of the study we wanted to push the
2 boundaries and so that case, that configuration would
3 be one where there was division 1 out for planned
4 maintenance, division 2 for planned or emergency
5 maintenance and division 3 out for emergent. And
6 that's not necessarily the entire division but
7 equipment from one, two or three of those divisions.

8 Okay, so on the next slide this is a
9 snapshot of some of the cases that were run. And just
10 going across and explaining the top row the first case
11 is just an arbitrary number that we decided to number
12 each of the cases. And then the equipment not
13 functional describes the equipment that we tested and
14 then we took out for test and maintenance as part of
15 the case in the SPAR model. And then the baseline CDF
16 with no test and maintenance was 10.6, 10 percent to
17 the -7 for the ABWR SPAR model. And then we
18 calculated the CDF using the SPAR model. For example,
19 case 1 for one diesel generator being out and then we
20 calculated the delta CDF based on those two numbers,
21 the baseline and then also the CDF for the actual
22 case. And then we have a calculated completion time
23 which is based on the risk-informed completion time
24 limit of 10^{-5} .

25 CHAIR STETKAR: So that -- let me make

1 sure I understand what that column means. That says
2 if I keep that diesel out of service for 44,135 days
3 my core damage frequency then will be $1E^{-5}$.

4 MR. POWELL: Correct.

5 CHAIR STETKAR: Okay.

6 MR. POWELL: And then the next column over
7 is the tech spec limit. And we pulled those directly
8 out of tech specs. And for one diesel generator it
9 was a 14-day completion time. And then the allowed
10 completion time is the actual number that we used to
11 calculate the ICDPs and for example this case number
12 one since the completion time calculated was much
13 greater than the tech spec limit it went to the 30-day
14 backstop as designated in the NEI guidance. And then
15 the last column is kind of a defense-in-depth column
16 that shows the other available equipment to -- that
17 you would have to perform the same function.

18 So during the case studies, like I said,
19 I ran 24 unique cases and I want to call attention to
20 case 12. And we can look at this graphical
21 representation but in case 12 we had the RCIC pump as
22 well as the two high-pressure core flooders out due to
23 test and maintenance. And --

24 CHAIR STETKAR: So for those of us who are
25 dummies that's no high-pressure makeup available.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. POWELL: Exactly. We classify that as
2 a loss of function due to not having high-pressure
3 injection.

4 CHAIR STETKAR: Okay.

5 MR. POWELL: And then also, and we'll get
6 into the discussion of loss of safety function and why
7 I'm calling special attention to those cases a little
8 bit later in the preliminary results section. And
9 then also case 21a is an example of where we were
10 really pushing the limits of what would be allowed
11 based on RITS 4b guidance. And if we flip back to
12 that same graphical representation on slide 65. In
13 this case we had two diesels out, diesel F and G.
14 Also, the high-pressure core flooder B and low-
15 pressure flooder A in combination with RCIC. So if
16 you look at all the equipment we have equipment out
17 from all three divisions as well as having RCIC out
18 which is a significant amount of equipment and across
19 all three divisions.

20 CHAIR STETKAR: This is probably a rare
21 event. One would hope.

22 MR. POWELL: Configuration C which we
23 decided was a very unlikely scenario and that was a
24 case where you pushed the 10^{-5} limit of the NEI
25 guidance. And that's kind of the extreme case that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 had to run in order to get to a CDF value that large.

2 CHAIR STETKAR: But if you go back to your
3 case 12.

4 MR. POWELL: Yes.

5 CHAIR STETKAR: That configuration
6 apparently is permitted by the current tech specs, is
7 that right?

8 MR. DUBE: No, they're in a 12-hour action
9 statement.

10 CHAIR STETKAR: well, but I can operate
11 the plant for 12 hours in that configuration. So it's
12 not, as opposed to the last one which is probably not
13 permitted under the existing tech specs at all.

14 MR. DUBE: If you talk to an operator
15 they'll probably tell you all I can do in 12 hours is
16 get ready, call the dispatcher and start shutting
17 down. I mean, you're right, 12 hours theoretically.

18 CHAIR STETKAR: No, I'm just thinking
19 about in terms of this notion of what's realistic,
20 what's not realistic. The 21-A because of the amount
21 of equipment you know is not even addressed in the
22 tech specs and you basically need to shut down, you
23 know, immediately.

24 MR. POWELL: Well, both of those cases
25 would be allowed by existing tech specs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: 21-A would also?

2 MR. POWELL: Yes. Because of the way tech
3 specs --

4 CHAIR STETKAR: There could be multiple
5 LCOs.

6 MR. POWELL: You'd have to look at the
7 electrical and also the ECCS tech specs. And for the
8 electrical systems having two diesels out would
9 require three days would be your completion time. And
10 then RCIC in combination with two ECCS subsystems has
11 a 7-day completion time.

12 CHAIR STETKAR: Oh, okay. So in principle
13 that configuration is indeed allowed legally.

14 MR. DUBE: Now.

15 CHAIR STETKAR: Now.

16 MR. DUBE: Correct.

17 CHAIR STETKAR: I didn't -- thanks, that
18 helps. So in that sense it's not an unrealistic, it
19 might be a rare case but it's not unrealistic because
20 the people who've written the tech specs allow you to
21 operate the plant in that configuration legally.

22 MR. DUBE: They may not have thought of
23 the risk impact, but yes, it's allowable.

24 CHAIR STETKAR: Okay.

25 MR. POWELL: Are there any questions on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the ABWR? Because I'm going to be switching to the
2 AP1000 next.

3 MEMBER ABDEL-KHALIK: This is based on the
4 original GE model? So it didn't include the new
5 alternate feedwater injection system that they put in
6 response to the aircraft impact rule?

7 MR. POWELL: I am not -- we don't credit
8 any --

9 MR. DUBE: We don't --

10 CHAIR STETKAR: They didn't give credit
11 for that in the design basis accident analyses so it
12 probably isn't in --

13 MEMBER ABDEL-KHALIK: I mean, they were
14 using the old GE model, so. Would the results change
15 if you take credit for that?

16 MR. DUBE: I don't know enough about the
17 system design. It probably works but I don't know
18 enough about the system design. The new system.

19 MEMBER ABDEL-KHALIK: Okay.

20 CHAIR STETKAR: This is the certified ABWR
21 design, not the South Texas.

22 MR. POWELL: No, it's not the South Texas.

23

24 CHAIR STETKAR: Oh, okay. It makes a
25 difference. Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. POWELL: Okay, so now switching to the
2 AP1000 model case studies. I would like to put a
3 disclaimer, at least acknowledge that there are issues
4 with knowing that a passive system has failed prior to
5 its use. And also that we used check valves or
6 switchboards or distribution panels as a surrogate to
7 model system or flow path failure for the AP1000 which
8 was something a little bit unique because of its
9 passive nature.

10 And so with that said some of the case
11 study assumptions were again that only internal events
12 at power were modeled. The CDF values are point
13 estimates. For the AP1000 the truncation set default
14 is 10^{-14} and all tests and maintenance again were set
15 to false for all the cases. And any equipment not
16 functional whether switchboards or distribution panels
17 for the electrical systems. Or the valves for the
18 ECCS systems, the test and maintenance was set to true
19 in the SPAR model.

20 Okay, for the AP1000 we came up with 18
21 unique cases to test the application of RITS 4b.
22 Again we came up with a systematic approach to the
23 various categories and groupings of the equipment that
24 we took out. We looked at the electrical equipment,
25 whether it was dc power and ac power. We looked at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the passive core cooling systems of the CMT,
2 accumulator, IRWST and also the passive RHR. And then
3 we looked at a combination of the electrical and
4 passive core cooling systems. And then the final
5 grouping which would be non-safety systems and non-
6 safety systems in combination with the passive core
7 cooling equipment.

8 CHAIR STETKAR: You're saying you took out
9 all non-safety systems or selected?

10 MR. POWELL: Not exactly all of them.

11 CHAIR STETKAR: Okay.

12 MR. POWELL: But a large grouping of them.

13 CHAIR STETKAR: Okay.

14 MR. POWELL: So similar to the ABWR this
15 slide shows the Class 1E dc and passive core cooling
16 system equipment for the AP1000 taken out of service
17 for the cases that we ran with the SPAR model to test
18 the RITS 4b. And if you look at the IDS system and
19 divisions A and D you have a single 24-hour battery
20 and in divisions B and C you have a 24-hour battery
21 and also a 72-hour battery. And for the passive core
22 cooling you pretty much have two direct vessel
23 injection lines, A and B, and you have the accumulator
24 CMT and IRWST injection off of each of those lines.
25 And the IRWST has a motor-operated valve and then it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 breaks into two check valves later on in the flow
2 path. And so those are all equipment and valves that
3 we modeled in the SPAR to simulate failure of those
4 systems.

5 So for the AP1000 the headings for the
6 table are the same as in the ABWR and they were
7 calculated using the same method. I will call
8 attention to case number 7 which was an IRWST
9 injection line B. We modeled the motor-operated valve
10 as failed in that case. And this was a case that we
11 as the staff defined as a loss of function because the
12 design could not mitigate a design basis accident in
13 this case which goes beyond what is in the NEI
14 guidance and that was one of the conclusions that we
15 came to based on the case studies that were run, that
16 there's different situations that could happen to
17 where the loss of function is maybe not as it is
18 defined in the guidance and that was one of the major
19 conclusions we came up with. And also in case 9-A
20 there's a loss of function and you couldn't mitigate
21 against a design basis accident again.

22 CHAIR STETKAR: How are those kind of
23 conditions treated today in -- for an existing plant?
24 Because I'm not familiar with this process. I haven't
25 really looked at what people submit. If someone

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 submits for example for a currently operating plant,
2 a two-loop operating plant and they want to keep both
3 of their accumulators out of service for, pick a
4 number, eight hours. That would remove their
5 mitigation for a design basis large LOCA accident. On
6 the other hand the risk implications of that might be
7 exceedingly small. Does the staff consider these
8 types of issues that you can't mitigate a design basis
9 accident for eight hours out of, you know, an eight-
10 hour time period. Forget the frequency that you might
11 enter it. And not consider those types of
12 applications or, you know, how is that sort of thought
13 process that you've just brought up regarding the
14 IRWST and the accumulator for the AP1000 design? How
15 is that reflected in sort of current practice?

16 MR. DUBE: Well, if it's a current
17 question I'll turn it over to Andy Howe. But your
18 point is well taken, this is very analogous, you know,
19 to be familiar with the AP1000 you have basically two
20 direct injection paths and the design basis accident,
21 one of the more limiting ones is you break the A
22 injection line and B side equipment fails or is
23 unavailable. You theoretically need a design basis
24 accident analysis. Same thing in current reactors.
25 Take a two-loop, at least four accumulators, two in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 each cold leg. If one's unavailable you have to, you
2 know, the assumption is that the other three inject.
3 If you were to have two unavailable you cannot
4 mitigate a design basis accident. And that would be
5 kind of analogous to this.

6 CHAIR STETKAR: Yes, I mean that's where
7 I was trying to get to.

8 MR. DUBE: There's a strong analogy with
9 accumulators and the PWRs.

10 CHAIR STETKAR: But I was curious how is
11 -- is that thought process applied in current risk-
12 informed tech spec submittals such that the staff
13 would disallow those types of configurations
14 regardless of how small the measured incremental risk.

15 MR. DUBE: Well, I mean the guidance says
16 do not voluntarily enter into a situation where you
17 take out -- cause a loss of function. Now, you could
18 be in a situation where one equipment is out and you
19 have an emerging situation on another one.

20 CHAIR STETKAR: That happens in the real
21 world occasionally.

22 MR. DUBE: Yes, then you can meet your
23 time frame but you can't voluntarily cause a loss of
24 function.

25 CHAIR STETKAR: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DUBE: Particular current reactors?
2 I don't know. I'll ask Andy.

3 MR. HOWE: Yes, the answer to your
4 question is yes, the technical staff is very attuned
5 to proposals for changes to tech spec completion times
6 where the condition is a loss of a safety function.

7 CHAIR STETKAR: Okay.

8 MR. HOWE: That typically involves
9 multiple trains inoperable where if you're in a
10 condition single failure is always set aside. But I
11 can give you two specific examples without naming
12 specific licensees but BWRs have a tech spec condition
13 that permits both trains of split to be out of service
14 for up to eight hours to accommodate testing and
15 maintenance. A licensee wanted to extend that to I
16 believe 72 hours. They'd had some NOEDs and they
17 wanted to simply codify the tech spec. That was
18 ultimately on the path for rejection. Then it was
19 pulled back by that licensee. The eight hours was the
20 standard tech spec limit. The staff was not going to
21 go beyond that.

22 We also had a licensee come in recently
23 and wanted permission to remove an SFAS actuation
24 signal completely from service where it's multiple
25 channels but you take more than two channels out in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 certain combinations, the function would be lost. And
2 that was renegotiated painfully over several months
3 and several face-to-face meetings until we could scrap
4 the condition where it wouldn't involve a loss of
5 function. So the short answer is yes.

6 CHAIR STETKAR: Okay, good, thanks. That
7 helps. I was just curious whether this is some new
8 sort of thought or how consistent it is with --

9 MR. DUBE: No. Different systems but same
10 thought process.

11 MEMBER SHACK: I mean, my understanding is
12 though, I mean the NEI guidance would tell them not to
13 come in with that kind of an application.
14 Voluntarily.

15 CHAIR STETKAR: Voluntarily.

16 MEMBER SHACK: But it's still --

17 CHAIR STETKAR: The tech specs have to
18 cover combinations.

19 MEMBER SHACK: You couldn't do it under
20 4b. Your tech specs may allow that. You couldn't get
21 a 4b extension.

22 CHAIR STETKAR: Yes, but you might be able
23 to get one for a single train out of service that
24 would leave you more vulnerable to, you know, entering
25 the other situation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: Yes, that's true.

2 CHAIR STETKAR: That's part of the game
3 that gets played I think.

4 MEMBER SHACK: Right. But the star hitter
5 was both of them out, right?

6 CHAIR STETKAR: Well, but I mean if you
7 look at the timelines it's not.

8 MR. POWELL: This is the one CMT and one
9 accumulator.

10 CHAIR STETKAR: Okay.

11

12 MR. POWELL: In this case. And the
13 existing tech specs allow one hour for that situation.
14 And RITS 4b wouldn't be applied so it would still be
15 one hour.

16 MR. BRADLEY: Biff Bradley of NEI. Just
17 to clarify, in traditional tech specs you get into
18 LCO-3.0.3 if you have both trains out which is a very
19 short shutdown statement. The way the 4b guidance is
20 set up you cannot intentionally enter into that
21 condition if 3.0.3 still applies just like it does
22 today. The only exception is if you have an emergent
23 condition that takes a train out when you already have
24 the other train out and you can still show that it's
25 still essentially functional. There's like a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 paperwork problem or it may be like seismic
2 qualification or something. We call that PRA
3 functionality. I'm not sure that was a great term but
4 that was the term that got put in there. But 4b is
5 basically you cannot intentionally enter into a loss
6 of function. It's no different from the way the
7 current specs are set up.

8 MR. POWELL: Are there any more questions
9 about the AP1000 SPAR model results? Okay. So moving
10 on to the vendors calculational results. We had great
11 industry participation. We had presentations on the
12 US EPR, the ESBWR, the APWR and the AP1000. They
13 didn't actually present results but a representative
14 came and verbally discussed some calculations they
15 performed. And for the US EPR there were very low
16 ICDP values and most of the cases that they ran
17 required the 30-day backstop to limit the ICDP. And
18 these were similar results as the ABWR SPAR model
19 cases that you had to have a significant amount of
20 equipment out in order to reach the 10^{-5} limit.

21 For the ESBWR they were very low ICDP
22 values calculated and this was a result of the ESBWR's
23 N-2 design philosophy. For the AP1000, like I had
24 mentioned a Westinghouse representative came and spoke
25 about cases that they ran. They didn't actually give

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a presentation. And what the representative said was
2 that they confirmed the staff's results and that they
3 were very, very close to what their model showed for
4 the cases that we ran. And then for the APWR there
5 were similar results again to the ABWR SPAR model
6 cases. And for the APWR LERF was more limiting than
7 CDF in some of the cases that they showed.

8 And a side note, the ESPWR and the APWR
9 were the only designs that even looked at LERF
10 factoring into the calculations.

11 CHAIR STETKAR: EPR did not?

12 MR. POWELL: Not in what they presented,
13 no. Okay, so now I'll move on and discuss some of the
14 features and regulatory programmatic controls of the
15 RITS 4b application. One of the programmatic controls
16 is that the risk-informed completion time is limited
17 to a deterministic maximum of 30 days as I referred to
18 as the 30-day backstop. And that's 30 days from the
19 time that the tech spec action was first entered.
20 That seemed to limit a lot of the cases from getting
21 even remotely close to the 10^{-5} limit that is in the
22 NEI guidance. And another one that we've talked about
23 is the voluntary use of risk-managed tech specs for a
24 configuration which represents a loss of tech specs
25 specified safety function or inoperability of all

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 required safety trains is not permitted based on the
2 guidance.

3 And then a regulatory control is that a
4 license amendment request to implement RITS 4b is
5 subject to a staff review and approval including the
6 scope of the LCOs to which the program may be applied.
7 So if an applicant wants to apply RITS 4b to a really
8 specific LCO then to submit a license amendment it has
9 to be reviewed and approved by the staff before they
10 can even begin to apply it.

11 CHAIR STETKAR: But in new reactor space
12 if I understand the process, and again we'll hear more
13 about this in our Comanche Peak. The way the tech
14 specs are now formulated is there are no completion
15 times and it says we'll either use the standard tech
16 specs or we'll use completion times that are defined
17 in a separate document. The changes to that separate
18 document can be made without staff review, right? In
19 other words, I apply RITS 4b to the times in that
20 separate document, not the times in the tech spec.

21 MR. POWELL: We'll call on Bob Tjader to
22 clarify that.

23 MR. TJADER: You're confusing the
24 surveillance frequency control program with the risk-
25 informed completion time. The surveillance frequency

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 control program has a program in which the
2 surveillance frequencies will be specified in that
3 document of the program.

4 CHAIR STETKAR: Okay.

5 MR. TJADER: Risk-informed completion
6 times basically has all of the existing completion
7 times that are in the standard tech specs. They have
8 all of those existing completion times written right
9 there. All of the required actions that is associated
10 with that completion time have to be completed within
11 that completion time.

12 CHAIR STETKAR: I understand.

13 MR. TJADER: If they are not within that
14 completion time, if they have risk-informed completion
15 times they have the option to voluntarily perform a
16 risk assessment, a quantified risk assessment where --
17 in which they determine what the risk-informed
18 completion time will be. When they determine that
19 then they can invoke that or if it exceeds 30 days
20 they can then invoke the backstop.

21 CHAIR STETKAR: All right, okay. Thanks.
22 But the staff doesn't necessarily review that
23 calculation to just -- if they decide okay, you know,
24 my tech spec says that I can have this piece of
25 equipment out for 72 hours and I decide that I'm going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to exceed that. I do this risk-informed calculation
2 that says well, I can have it out for seven days. The
3 staff doesn't review that.

4 MR. TJADER: They don't do a pre-review of
5 that other than review the PRA, review the calculator
6 that is used, the monitor to ensure that that
7 accurately reflects the PRA and does a good
8 calculation. But they don't do a pre-certification of
9 the calculation. They can audit it subsequent to
10 that.

11 CHAIR STETKAR: Okay, okay. Thanks.
12 You're right, I had misinterpreted those two parts.
13 Thank you.

14 MR. POWELL: Okay, so moving on to the
15 preliminary results on slide 74. The case studies
16 that were performed highlighted examples of cases
17 where some configurations ended up being a loss of
18 safety function that were outside of the existing
19 definition in NEI 06-09. As a result we identified
20 the need for an enhanced definition of loss of safety
21 function in NEI 06-09. For example, we recommend
22 using the safety function determination program LCO
23 3.0.6 and examples to more clearly describe what a
24 loss of safety function means.

25 MR. TJADER: Excuse me. Sorry, Eric. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 just want to clarify one thing. There's going to be
2 confusion with this slide in that the safety function
3 determination program there, that is not the same
4 safety function determination program. We should use
5 a different term. LCO 3.0.6 is basically a safety
6 function determination. It's not a program as in the
7 control section of the tech specs. What you have to
8 do is 3.0.6 is because there's not -- getting into
9 some detail -- because since they're not cascading in
10 the tech specs. In other words, if there is a support
11 system tech specs and a supported system that is in
12 the tech specs the support system, i.e., electrical
13 system you enter its LCO. You don't have to cascade
14 to the subsequent system that's in the tech specs.
15 But what you have to do is do a safety function
16 determination in accordance with 3.0.6 to ensure you
17 haven't lost function. If you've lost function then
18 you have to cascade to the supported system in the
19 spec and you have to be in both specs at the same
20 time.

21 CHAIR STETKAR: So if I understand that
22 because I'm woefully uninformed about the intricacies,
23 if I have a simple two-train plant and I have two
24 motor-driven injection pumps you're saying that if I
25 take out the electrical bus that supplies train A I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 don't need -- I need to do a safety function
2 determination such that if I discover that I also have
3 pump B out simultaneously I've now violated that
4 safety function.

5 MR. TJADER: And then you have to be in
6 both specs.

7 CHAIR STETKAR: Yes. Okay. That's the
8 way it works?

9 MR. TJADER: That's the way it works.

10 CHAIR STETKAR: Thanks.

11 MR. DUBE: I don't think Bob's
12 contradicting what we're saying. The point was --

13 MR. TJADER: It's just the term was
14 confusing and I didn't want you to think that that's
15 the same safety function.

16 CHAIR STETKAR: Don't explain it any more.
17 I think I've got it. I might be wrong but at least
18 I'm happy.

19 MR. POWELL: So during the tabletop the
20 staff expressed concern that a reactor with a baseline
21 core damage frequency of 5×10^{-7} per year on a one-
22 time use of the current guidance for a maximum ICDP of
23 5×10^{-6} would represent actually 10 years' worth of
24 core damage probability. And I was going to discuss
25 that on the next slide and make you wait but I think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for continuity purposes I'll just go ahead and explain
2 that now. So if you flip to the next slide this is an
3 example of a case that was run for the ABWR which I
4 was describing on the previous slide where one could
5 achieve 10 years' worth of core damage in a short
6 amount of time based on the given configuration. And
7 for this case it was for the ABWR like I said and the
8 equipment that's red and italicized is the equipment
9 that was taken out due to test and maintenance for the
10 case that was run. That was a diesel from division 2,
11 a low-pressure flooder from B, a high-pressure core
12 flooder from division 3, the RCIC pump as well as the
13 combustion turbine generator. And that's five
14 significant pieces of equipment that was taken out and
15 this is one of the more extreme cases where lots of
16 equipment was taken out and is not what the industry
17 described as current practice. But it is something
18 that is allowed by RITS 4b and it was a case that we
19 did prior to the tabletop and as a result of the
20 discussion at the tabletop and also the commission
21 direction to use realistic cases.

22 This case is one that would be, sorry,
23 would not be classified as realistic, but it was
24 something that the staff brought up as a concern that
25 if you had a mid 10^{-5} plant -- sorry, mid 10^{-7} plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you could get 10 years' worth of CDF based on a
2 particular configuration.

3 MEMBER BLEY: So if I understood what you
4 just said this was just a case you guys made up to
5 show that there would be a way to create such a
6 situation.

7 MR. POWELL: Yes, it --

8 CHAIR STETKAR: Well, and I think they
9 said it's -- this configuration is legally allowed, is
10 legal. It's not illegal.

11 MR. DUBE: It could occur now.

12 CHAIR STETKAR: It could occur.

13 MR. DUBE: I mean it could occur with
14 standard tech specs.

15 CHAIR STETKAR: Right.

16 MR. POWELL: And it was a case that we ran
17 before the tabletop and we were discussing it and our
18 concern was that a plant could receive up to 10 years'
19 worth of CDF in a short amount of time based on a
20 configuration but throughout the discussion at the
21 tabletop it was discussed and the conclusion was that
22 it's not a realistic representative case of current
23 operating practice.

24 MEMBER SHACK: Would there be an update of
25 the guidance that would say you would only take

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 equipment out in one division and that you could not
2 then plan to take major equipment out in the second
3 division? It has to be an emergent case?

4 MR. POWELL: There's nothing in the
5 guidance that states that.

6 MEMBER SHACK: Well, the question is
7 should the guidance be modified to state that.

8 CHAIR STETKAR: That would create havoc
9 because if you look at the new plant designs typically
10 you can have one of the four trains out infinitely,
11 forever they're allowed. And you can do planned
12 maintenance for an extended period of time on the
13 second division.

14 MR. POWELL: For example, the EPR.

15 MR. DUBE: It's tough to write a rule that
16 captures all the situations. I mean, to your point.

17 CHAIR STETKAR: I think it's dangerous to
18 try to write a rule to capture this stuff.

19 MEMBER SHACK: Well, but then you're left
20 sort of to the good judgment of the licensee that he's
21 not going to get himself into this.

22 CHAIR STETKAR: Well, that comes back to
23 when does the staff get involved in --

24 MEMBER SHACK: The question is how heavy
25 a regulatory footprint do you want on this.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Or are you satisfied with
2 the criteria you have anyway.

3 MEMBER SHACK: Well, the criteria now
4 allows me this.

5 CHAIR STETKAR: Yes.

6 MR. POWELL: And that's something that was
7 also brought up that the stakeholders noted that
8 existing standard tech specs provide fewer controls on
9 the frequency of entering certain LCOs, especially
10 risk-significant configurations.

11 MR. BRADLEY: Can I make a comment? This
12 is Biff Bradley, NEI. Just to this point. The
13 existing non-risk informed standard tech specs,
14 there's nothing in there that precludes you from
15 repeatedly entering your 7-day LCO as many times as
16 you want. And you could create the same scenario
17 where you run up 10 years' worth of risk with standard
18 tech specs as you can do here. We simply don't do
19 that. And we do have in the guidance, while it may
20 not be totally prescriptive, we do have words in there
21 to the effect that the primary risk management action
22 is the proper sequencing and planning of activities so
23 you're not overlapping trains and creating these kinds
24 of conditions. And so I think, you know, experience
25 has demonstrated we've maintained that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Doesn't, Biff, and again
2 I'm woefully ill-informed on a lot of the practical
3 aspects of this. Doesn't some of the requirements
4 under the maintenance rule say that you need to
5 examine those configurations before you enter --
6 regardless of this part of the --

7 MR. BRADLEY: Yes. As a matter of fact
8 that's the reason, one of the main reasons (a)(4) of
9 the maintenance rule was promulgated was because of
10 the need to assess the risk impact of entering LCOs
11 for maintenance which at the time was under question
12 whether you could intentionally enter LCOs, especially
13 multiple LCOs. But yes, that's -- you're basically
14 double-regulated here with (a)(4).

15 MEMBER SHACK: With the current kind of
16 limits that you're allowed under (a)(4) this would
17 still be an allowable configuration under (a)(4) for
18 an ABWR I think.

19 MR. BRADLEY: Yes, you are correct, you
20 are correct in that regard.

21 MEMBER SHACK: I mean that's, you know,
22 when you have these highly redundant plants you can do
23 an awful lot.

24 MR. POWELL: Correct. So the last point
25 I would like to make on the results of the tabletop

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 was that industry representatives highlighted current
2 practice as realistic which is one division out for a
3 planned maintenance followed by a single emergent
4 failure in a second division. Given that situation
5 the staff calculated ICDPs in the low 10^{-7} to low 10^{-6}
6 range. So if anyone has anymore questions about the
7 RITS 4b cases? If not I will move on to the
8 maintenance rule 50.65(a)(4).

9 CHAIR STETKAR: What -- I do. At a high
10 level, Eric, what were your or are you not willing to
11 discuss it perhaps at the time overall conclusions
12 with respect to the 4b as it's applied to new
13 reactors? Is it that the current controls given the
14 30-day backstops --

15 MEMBER SHACK: And the loss of function.

16 CHAIR STETKAR: -- and the loss of
17 function provide that adequate protection?

18 MEMBER SHACK: And the increase in risk.

19 CHAIR STETKAR: Yes, I mean that's --

20 MR. POWELL: I can give my opinion based
21 on the cases that we ran for the APWR and the AP1000.
22 The AP1000 cases seem to be more limited based on the
23 existing tech specs. And so, and also the definition
24 of loss of function. So there wasn't the ability to
25 really get to 10^{-5} numbers. And the 30-day backstop

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 applied for the AP1000 when it was also keep the
2 numbers well away from 10^{-5} .

3 CHAIR STETKAR: So not only an absolute
4 but it gave you that margin. Okay.

5 MR. POWELL: And then for the ABWR it
6 seemed like the 30-day backstop was more significant
7 in preventing the approach to 10^{-5} . And also the loss
8 of function was something for like the high-pressure
9 injection case. But loss of function seemed more
10 important for the AP1000.

11 MEMBER SHACK: Okay, that's describing the
12 results. Now the conclusions from that are the
13 controls are sufficient?

14 MR. DUBE: We're still internally debating
15 it but if -- we're certainly no worse off in my
16 opinion with risk-informed tech specs than existing
17 standard tech specs. I mean, I have a big formula
18 there that is probably not solvable or it's at least
19 a PhD thesis to try to solve it. But basically what
20 it's saying, how often and to what extent would a
21 plant using standard tech specs enter these
22 configurations with no extra risk management controls
23 versus a reactor using risk-informed tech spec 4b
24 where there's guidance, there's controls that limit
25 how long one can stay in the configuration and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 specific risk management actions that have to be taken
2 as one incrementally goes up, instantaneous core
3 damage probability. So you know, I know we're being
4 careful not to jump out and write the final overall
5 conclusions but --

6 CHAIR STETKAR: No, and I think we have to
7 be sensitive to that given this is obviously a work in
8 -- I was just looking at this morning in your
9 presentation for the risk-informed ISI you made some
10 if not final, fairly definitive --

11 MR. DUBE: Yes, they were definitive.

12 CHAIR STETKAR: -- conclusions.

13 MR. DUBE: Right.

14 CHAIR STETKAR: And I was curious where
15 you were in this particular initiative.

16 MR. DUBE: I think we'll feel comfortable
17 if we can work on a good solid definition of loss of
18 function, loss of safety function with examples to
19 make sure that certain configurations would not be
20 entered, or at least the right questions would be
21 asked. Because some of these are pretty subtle. When
22 we did some calculations, loss of a dc bus A so to
23 speak and loss of the B emergency core cooling system,
24 well, not very obvious until you go through and you
25 look at does one have a loss of function there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Well and even, you know,
2 on one of the slides that you showed in that sense
3 that, I don't remember which one it is. I can find it
4 quickly here. It's 67. Where you take out seven for
5 those of us who just think in simpleminded terms, your
6 case 12 that you take out all your high-pressure
7 injection. You say you still have your low-pressure
8 core flooders. You still need depressurization for
9 example on this design to get there. So it's not
10 simply looking at high-pressure flooders, you know,
11 there are other things that need to be available.
12 You're right, it's not a simple process.

13 MR. DUBE: If one takes a conservative
14 definition here and says I've lost high-pressure
15 injection, function and not allow this configuration
16 I'd feel comfortable.

17 CHAIR STETKAR: That's right. If you
18 define that as a function.

19 MR. DUBE: Right.

20 CHAIR STETKAR: That's right. Okay.

21 MR. DUBE: That's why to me everything is
22 in a good and solid definition and examples.

23 CHAIR STETKAR: And there's no notion for
24 the new reactors to eliminate the 30-day backstop?

25 MR. DUBE: No.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Okay. Because what I was
2 hearing is that 30 days, the loss of function and the
3 30 days --

4 MR. DUBE: There were also plants right
5 from the beginning in their tech specs that are going
6 to be approved by the staff and Bob Tjader can correct
7 me if I'm wrong are going to allow right up front
8 long, you know, operation with a given that a train
9 is.

10 CHAIR STETKAR: Sure. That's the four
11 designs.

12 MR. DUBE: Yes, the four train.

13 CHAIR STETKAR: You're only required to
14 have three operable before you enter anything.

15 MR. DUBE: But that's pre-analyzed by the
16 staff and so on and so forth.

17 CHAIR STETKAR: Yes. But I mean once you
18 enter some sort of LCO that 30-day ultimata backstop
19 is not being challenged.

20 MR. DUBE: No.

21 CHAIR STETKAR: Okay. Questioned let's
22 say. Maintenance rule?

23 MR. POWELL: Okay, so switching gears to
24 maintenance rule (a)(4) now. This table is taken out
25 of NUMARC 93-01 and it shows the ICDP and the ILERP

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 values and the corresponding actions. And for ICDPs
2 greater than 10^{-5} and also ILERP greater than 10^{-6}
3 those configurations should not be normally entered
4 voluntarily. And for ICDP values 10^{-6} , 10^{-5} and ILERP
5 10^{-7} to 10^{-6} and one has to assess the non-quantifiable
6 factors and establish risk management for those
7 situations. And then for ICDP values less than 10^{-6}
8 and ILERP values less than 10^{-7} normal work controls
9 are applied.

10 For the -- this slide 77 shows the
11 maintenance rule (a)(4) applied to the ABWR RITS 4b
12 cases. And what we did here was took all the cases
13 that were run for the RITS 4b and recalculated the
14 ICDPs using the allowed completion times in tech specs
15 versus the allowed completion time using RITS 4b. I
16 can see there might be some clarification needed.

17 CHAIR STETKAR: Try that again.

18 MR. POWELL: What that means is for this
19 case 1 the ICDP value that's shown in this box is
20 calculated using this value. What I'm trying to show
21 in slide 77 is I re-quantified those, these ICDPs
22 using the tech spec limit of the existing tech specs.
23 So that comparison in the table below that has the
24 RITS 4b cases and that shows you a comparison of how
25 each of these cases would be categorized, whether or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 not you use the existing tech specs or RITS 4b. So
2 using regular tech specs you had one case that was
3 greater than 10^{-5} . Using RITS 4b you had three cases
4 that were greater than 10^{-5} . And then between the
5 range of 10^{-6} and 10^{-5} for the existing tech specs in
6 the cases that we ran there were three cases versus
7 six cases of applying the RITS 4b completion times.
8 And then for ICDPs less than 10^{-6} the regular tech
9 specs had 21 and the RITS 4b tech specs had 16 cases.
10 So this graph or this slide is really to show you a
11 one-for-one comparison of the cases that were run and
12 compare what maintenance rule would look like for the
13 existing tech specs and what maintenance rule would
14 look like for the RITS 4b cases. Any questions on
15 that comparison?

16 Okay. Then for the AP1000 it was the same
17 thing as the ABWR where the recalculation of the ICDPs
18 for the RITS 4b cases was done using the allowed
19 completion time in tech specs. And then the table
20 below that shows a comparison of the ICDPs calculated
21 using the risk-informed completion time. And for the
22 AP1000 all of the cases were below 10^{-6} for the
23 existing tech specs and also applying RITS 4b.

24 MR. DUBE: If I might add, the read of
25 this is one thing that we found is the AP1000 has,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 being a passive plant there's a lot of importance on
2 things like dc batteries because you don't have big
3 diesels, you don't have big pumps. And the batteries,
4 the ac power supply have very restrictive tech specs,
5 very restrictive, and that comes into play all the
6 time. And that's why you see this situation. Tech
7 specs versus RITS 4b, it's, the ICDP is constrained to
8 10^{-6} virtually all the time, at least all the cases we
9 ran.

10 MR. POWELL: So now moving on to slide 79,
11 the preliminary results for the maintenance rule
12 portion of the tabletop. During the tabletop it was
13 highlighted that when PRA approach is combined with
14 other inputs such as the degree of defense-in-depth
15 and plant transient assessment factors other than PRA
16 are often more limiting in terms of the risk
17 management action level. Also, NUMARC 93-01 Section
18 11 explicitly acknowledges there is variability in
19 baseline core damage frequency and large early release
20 frequency. Determination of the appropriate
21 quantitative risk management action thresholds are
22 plant-unique activities. And at the tabletop it was
23 a consensus that NUMARC 93-01 Section 11 on
24 implementation guidance does not appear to need
25 substantive changes to address new reactor designs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: So for example when you
2 assess non-quantifiable factors so you get rid of some
3 of those cases in the ABWR just because.

4 MR. DUBE: It may, yes.

5 MEMBER SHACK: You didn't like the look of
6 all that equipment out.

7 MR. DUBE: Well, yes. I mean, we -- it
8 would have been interesting for you to have seen this
9 because we had a number of contractors come in, Erin
10 Engineering, and they demonstrated their, the online
11 risk management tool PARAGON that's used at several
12 reactors and went through cases. And most of the
13 examples cited, you know, there's a defense-in-depth
14 measure on the online risk management tool, it's not
15 just delta CDF or delta LERF but there's other
16 considerations. There's also concern about plant
17 transient analysis because if you take certain
18 equipment out of service one could put themselves in
19 a situation where one more failure would result in a
20 reactor trip. There's also maybe concerns about they
21 call it regulatory risk which is.

22 (Laughter)

23 MR. DUBE: One more failure could trip an
24 MSPI index, could result in having to request a notice
25 of enforcement discretion or any of a number of things

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and they don't like to use the regulatory margin so to
2 speak. So there's, it's a highly constrained
3 situation that consists of risk, you know, true risk,
4 regulatory risk, you know, plant transient risk,
5 defense-in-depth, and it's like squeezing in from all
6 sides so that -- and most of the situations, it wasn't
7 the change in risk that was the deciding factor on
8 whether or not to enter certain configurations. It
9 was an interesting insight I think.

10 MR. POWELL: Are there any more questions
11 on RITS 4b or maintenance rule (a)(4)?

12 MR. DUBE: By the way, the backup slides
13 have all of the cases for your benefit. There's some
14 slight editorial changes from the handout material
15 from the workshops, some corrections too, but
16 basically they're the same cases pretty much. Okay.

17 MR. POWELL: Okay, so if there are no more
18 questions I will proceed to discuss the next steps for
19 the overall tabletop approach for the risk metrics on
20 new reactor guidance. As we discussed earlier we have
21 a public workshop scheduled for October 5th. And this
22 workshop, the first portion will cover Reg Guide 1.174
23 and also LRF to LERF transition issues and any other
24 miscellaneous licensing issues that haven't been
25 discussed from the previous tabletops. And then the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 second portion would be the ROP tabletop and we'll be
2 discussing the STP findings, MSPI inputs and MD 8.3
3 applications from the current fleet as the examples to
4 exercise the ROP. And I don't know, Dennis, did you
5 need more clarification on the ROP? Because you asked
6 about that earlier. I didn't know if you had received
7 enough throughout the day.

8 MEMBER BLEY: Yes, I think enough until we
9 see something.

10 CHAIR STETKAR: Where, Eric -- if I look
11 at this it sounds like on October 5th you're going to
12 reach agreement on the input for the ROP tabletops, is
13 that right?

14 MR. DUBE: No, the actual results.

15 CHAIR STETKAR: Oh, the actual results.
16 So there's agreement right now on what cases.

17 MR. POWELL: Yes, we had a planning
18 meeting.

19 CHAIR STETKAR: You did.

20 MR. POWELL: And this is the actual
21 findings of the agreed upon cases to run.

22 CHAIR STETKAR: Okay.

23 MEMBER SHACK: So essentially one where
24 you actually took sort of real cases --

25 MR. POWELL: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: -- and kind of applied
2 them.

3 MR. DUBE: Yes, I mean, just to tease you
4 a little bit there was an STP finding at one of our
5 reactors at three turbine-driven aux feedwater pump
6 failures in a short period of time and we took that
7 case and applied it to the APWR that has two turbine-
8 driven. That was an MSPI, actually, finding and
9 applied it there and looked at the results. Other
10 cases were SDP with various situations of emergency ac
11 power and so on and so forth. So took the actual
12 cases, exposure times, what if it occurred at this
13 plant, this plant, this plant new reactor design.

14 CHAIR STETKAR: Do vendors run those cases
15 through their models also for EPR and the APWR?

16 MR. DUBE: We ask them for input from
17 their external events. Well, external. Internal
18 fire, internal flooding. I don't think anyone has a
19 seismic. And they provided us things like core damage
20 frequency and risk achievement worth, and the rest is
21 a simple calculation. So.

22 CHAIR STETKAR: Okay.

23 MR. DUBE: We're doing the calculations
24 but, you know, they have the exact cases, the exact
25 boundary conditions if you will to run the cases

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 separately. So.

2 CHAIR STETKAR: I was just curious
3 because, you know, you have your SPAR models but it's
4 only for the two designs.

5 MR. DUBE: Right.

6 CHAIR STETKAR: I was curious about how
7 the other guys, folks have done that.

8 MR. DUBE: Right. I mean SPAR models are
9 very close to the licensee's reactor PRA models, very,
10 very close. Only, I know there's one big difference
11 on the APWR on the, and you're familiar with this,
12 Birnbaum value or risk achievement for the turbine-
13 driven emergency feedwater pumps. That's a big
14 difference.

15 MEMBER BLEY: That's a result. Why are
16 you getting a different result, do you know?

17 CHAIR STETKAR: You said AP, a pressurized
18 water reactor?

19 MR. DUBE: APWR, yes.

20 CHAIR STETKAR: You don't have a SPAR
21 model for APWR, do you?

22 MR. DUBE: We just got it.

23 CHAIR STETKAR: Oh, okay.

24 MR. DUBE: We didn't have the model.
25 We've got the table of risk achievement worth.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: And that's coming. I have
2 a guess but I'm not going to.

3 MR. DUBE: We haven't certified and
4 verified the model yet so you've got to take the
5 results with a grain of salt.

6 CHAIR STETKAR: No, I suspect I know the
7 reason on APWR but that's speculation and it's not a
8 subject for this meeting anyway.

9 MR. POWELL: Okay, so continuing on with
10 the next steps. In late fall of this year we plan on
11 having another tabletop to identify any gaps in
12 guidance. Then February 2012 there is a draft
13 commission paper with recommendations that will be
14 drafted. And also in February 2012 the public
15 communications brochure should be concurred upon and
16 complete. And then late March or April of 2012 we'll
17 have another ACRS briefing with you all. And then
18 late March of next year the commission paper for
19 notation vote will be going out. So that's our --

20 MEMBER SHACK: You said March but you mean
21 May.

22 MR. POWELL: I do mean May. After we
23 brief you all again. So that concludes the tabletops
24 that we've performed up until August. And that's all
25 that Don and I have prepared for you all. Any other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 additional questions for us?

2 CHAIR STETKAR: I don't think so. I think
3 that as far as the subcommittee is concerned we need
4 to be in communications about what's the most
5 appropriate time to get the early spring briefing,
6 what will be available. Obviously all the tabletops
7 will be, the remaining tabletops will be finished by
8 then. I guess it's just a matter of where in the
9 process we get involved, you know, either for
10 subcommittee meeting. I know you'll want a letter
11 from the full committee but it's a question of timing
12 in terms of what input we might provide in a
13 subcommittee that could affect anything that you might
14 present to the full committee. There's a danger, for
15 example, in scheduling a subcommittee meeting two
16 weeks before the full committee meeting because that
17 doesn't give you enough time to react to any comments
18 that we might have in the subcommittee meeting.

19 MR. POWELL: We can work with John Lai on
20 scheduling.

21 CHAIR STETKAR: If you're, you know, tight
22 on schedule in the first quarter of 2012 we need to be
23 aware of that.

24 MR. DUBE: The key is getting a draft
25 commission paper with a position that the staff takes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: I understand. I mean, you
2 know, that's the problem we always face in terms of
3 the schedules though is that if for example you
4 present, you know, a draft to the subcommittee and we
5 have substantive comments that you take to heart you
6 don't necessarily want to run up too close to a
7 deadline for full committee presentation with a letter
8 because it just doesn't give you enough time to digest
9 our comments, make the appropriate changes and provide
10 the document for the full committee review. So we'll
11 just need to, you know, be aware of that.

12 MR. DUBE: Okay.

13 CHAIR STETKAR: Any other questions from
14 any other members on this? I thank you very, very
15 much. And now I know NEI has requested some time and
16 has prepared some information. The fundamental
17 question is do we take a break or do we just push to
18 completion.

19 MEMBER BLEY: We're essentially done,
20 right?

21 CHAIR STETKAR: It depends on how long.

22 MR. BRADLEY: I'll be brief.

23 CHAIR STETKAR: You will be brief? If you
24 will be brief we will -- we will push to completion
25 then. So I ask NEI or Biff, do you want to come up?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But thank you very much, that was very good.
2 Appreciate it very much.

3 MR. BRADLEY: Are you ready?

4 CHAIR STETKAR: I'm ready if you're ready.

5 MR. BRADLEY: All right. I do have a
6 brief presentation prepared. I'm Biff Bradley from
7 NEI. I've been involved in the tabletops and overall
8 I think this has been a very productive experience.
9 And really I had a few points I wanted to make but for
10 the most part they've been made either by the staff or
11 in questions and answers that have been provided today
12 so I don't want to be unnecessarily duplicative. Let
13 me just run through a few points here.

14 This is just an overview of what I
15 intended to cover. And the SRM, we all, the staff did
16 a good job summarizing the SRM. These are just two
17 quotes from the SRM on the commission reaffirming the
18 existing goals and objectives and the direction to
19 engage in the tabletops. I think these have been
20 clearly and correctly articulated.

21 So we have, we're just about done with the
22 licensing basis and 1.174 related tabletops. As John
23 mentioned we still have one to go on large release
24 frequency and any other 1.174 related issues. We just
25 started the reactor oversight process discussion.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We've had one meeting, we have another one coming up
2 in a couple of weeks. And that should be interesting.
3 I think the ROP may be a little more challenging of an
4 undertaking than the licensing basis changes have
5 been. So again, this is redundant to what's been
6 shown already. This is just a schedule or a listing
7 of the meetings we've had and the topics that we've
8 covered.

9 So, let me just sort of get to some
10 observations. There was a considerable amount of
11 discussion on the need for operational experience
12 before these applications could be implemented on new
13 plants. And we understand the concern and the general
14 idea that PRAs need to have incorporated some amount
15 of plant-specific operational experience before we use
16 them extensively in applications. Just, however, I
17 just wanted to note that there are, and I think this
18 came up at one point this morning, there are some risk
19 applications that are not voluntary and that all new
20 plants would apparently be using from day one. And
21 that includes the maintenance rule, both the
22 monitoring part of the maintenance rule as well as the
23 (a) (4) part of the maintenance rule that was discussed
24 today. Both of those are dependent to some degree on
25 a PRA. And then we have of course the reactor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 oversight process, both the significance determination
2 process and the performance indicators such as the
3 MSPI also rely on PRA. And I guess I haven't heard
4 the staff express the same types of reservations with
5 regard to the ability to commence those applications
6 but it would seem they would be subject to some of the
7 same general considerations. And I guess my only note
8 and especially with regard to some of these things
9 like risk-informed ISI which you know I would
10 certainly like to think there are maybe some things we
11 could start without having to wait for years after
12 initial operation. So I guess my only question to
13 pose sort of for the staff is whatever accommodations
14 or rationalizations you're making to allow these other
15 types of applications to proceed initially maybe
16 there's some way to extend those or consider those
17 same reasons when we come into some of these voluntary
18 applications. Just a question. And we do recognize
19 the general concern of the need for operational
20 experience.

21 CHAIR STETKAR: Biff, have you thought
22 much, and you know, when we discussed it this morning,
23 this notion of we need operational experience. If you
24 look at a lot of the components in the new design this
25 is no different motor-operated valve in new plant X

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 versus motor-operated valve in existing plant Y. Same
2 is by and large true for diesel generators and a large
3 number of the -- some are different. Gas turbine
4 generators are different than diesel generators. Very
5 large squib valves are different than, you know, air-
6 operated valves for example. I was curious, and I'm
7 sure that you're having discussions with the staff
8 about this issue otherwise it wouldn't be on the slide
9 right now but have you discussed, you know, what is
10 enough operational experience? I mean, it's not a
11 year certainly, probably not even a couple of years
12 realistically if you look at typical failure rates of
13 things. So the question is if you wait for
14 operational experience what's an appropriate amount of
15 time? And are you pursuing those discussions? Or
16 not?

17 MR. BRADLEY: We have not explicitly
18 pursued that particular subject yet. And there's a
19 related activity which is the expectation that new
20 plants need to meet Reg Guide 1.200 prior -- as it's
21 effective one year prior to operation. And then
22 there's some work under way in the standards community
23 to look at what elements of that standard endorsed by
24 1.200 can you reasonably meet or not meet given that
25 you don't have operational data. Of course we also,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you know, use a lot of generic data in PRAs and so,
2 but to directly answer your question we have not
3 engaged explicitly on how much operational experience
4 is enough and I would think this might come up when we
5 get into the ROP which is a mandatory. It's not
6 voluntary, it's not like most of the other things
7 we've looked at here. So that, but I think that's a
8 good point.

9 CHAIR STETKAR: I was just curious because
10 you know, when you talk about it it's always a good
11 thing to you know take advantage of operational
12 experience. But the notion of essentially the
13 implicit notion is well, we need to delay the
14 implementation of a certain program until we have
15 enough operating experience to give us confidence.
16 That then begs the question of what is enough.

17 MR. BRADLEY: Yes.

18 CHAIR STETKAR: For 60 years you have
19 enough operating experience.

20 MR. BRADLEY: But you're right. Hopefully
21 the failure rates are low. We're not, you know, so in
22 order to get statistically meaningful results it
23 could, one could argue it could take awhile. But you
24 know, we need to --

25 CHAIR STETKAR: I was just trying to pulse

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you to see where, because you did raise that on this
2 slide, so.

3 MR. BRADLEY: Yes. We'll bring this up as
4 we proceed into ROP space and try to flesh out a
5 little more detail.

6 CHAIR STETKAR: I actually think it's more
7 of an issue in ROP than.

8 MR. BRADLEY: Yes, it's really --
9 maintenance rule is the only, of the things we talked
10 about this morning maintenance rule is the only one
11 that would apply. It's not voluntary, it applies to
12 all plants.

13 CHAIR STETKAR: Even the sense of a
14 voluntary program that there's a notion of you can't
15 implement until you have enough operating experience
16 to justify the numbers.

17 MR. BRADLEY: I thought the staff did a
18 fine job discussing initiative 4b. In reviewing NRC's
19 meeting summaries I think of all the things we looked
20 at 4b was the only one where there was some discussion
21 of maybe we did need to possibly enhance some elements
22 of the guidance. And I'm not averse to the concept of
23 trying to better define safety function. I think to
24 some degree this has come up even in operating plant
25 space. Andy alluded to it you know with his

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 discussion on the standby liquid control system for a
2 BWR. You know, depending on if you define safety
3 function as reactivity control one could argue you
4 still had safety function. But right now safety
5 function is defined on an LCO basis which is clear and
6 understandable and maybe correct but you know, I think
7 there could be value in having further discussion.

8 My only little caveat I guess about
9 considering changes to the guidance, we do have an
10 operating plant proceeding to 4b, Vogtle, and I don't
11 want to do anything to upset the apple cart too much
12 in the middle of their efforts to transition. I don't
13 really think this would happen but that's my only
14 caveat. If we are going to look at the guidance for
15 4b, and this is all preliminary because NRC's not even
16 going to give their final recommendations on this till
17 later this year, but hopefully there would be a way to
18 do it in parallel with the Vogtle activity and not
19 putting some kind of a roadblock into that. I
20 actually you know believe 4b is a better set of tech
21 specs than what we have with standard tech specs. You
22 know, not that there isn't a lot of good stuff in the
23 STS but 4b, I mean I guess I'm surprised that the NRC
24 staff didn't encourage it more strongly. I just think
25 it's a better way to run a plant, especially a new

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plant that has a Reg Guide 1.200 PRA requirement for
2 a full scope and high-quality PRA. It just seems like
3 a no-brainer that 4b should be used. And we talked
4 about the fact that the existing tech specs are not
5 perfect and you know, that's the alternative to 4b.
6 And so 4b I think deserves that consideration.

7 So, the final slide. Again, the SRM you
8 know, we think there's a reasonable direction to the
9 staff to look at the guidance, but in general to try
10 to stay within the existing framework for risk-
11 informed decision-making. I think the tabletops have
12 been very effectively conducted. We've had good
13 representation from the industry and NRC has done an
14 excellent job orchestrating everything and summarizing
15 the results. And I think it's been a rigorous
16 exercise and we really, you know, I wish I could come
17 here and say this more often. I really don't have a
18 lot to disagree with. Substantively I think our
19 conclusions are in accord with what NRC has presented
20 today. I do believe you know as I mentioned the ROP
21 may be a little more interesting. There are a lot of
22 -- it gets a lot of visibility and it'll, that'll be
23 an entertaining discussion. But hopefully we can get
24 through that with the same level of effort and outcome
25 that we have up to now. So we'll do our best to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 continue our participation in this and we do have a
2 pretty good lineup of plants to support the ROP.
3 We're outrunning a bunch of test cases right now on
4 actual events and actually completed a few of those
5 already. So I guess that completes all I had to say.
6 I think this has been a successful and good outcome so
7 far.

8 MEMBER BLEY: So Biff, now that we've done
9 the technical stuff I have two non-technical questions
10 for you.

11 MR. BRADLEY: All right.

12 MEMBER BLEY: One is I've looked all over.
13 I can't figure out where 4b and 5b come from. Were
14 those out of a list of initiatives laid out in some
15 industry document?

16 MR. BRADLEY: Yes.

17 MEMBER BLEY: I can't find them.

18 MR. BRADLEY: Way back, this is I'm
19 thinking back to early '90s. This was actually begun
20 many years ago by the, what used to be the CE Owners
21 Group. It doesn't exist anymore. It was absorbed
22 into the Westinghouse Owners Group and there was --
23 but initially we identified a set of initiatives. I
24 think there may have been six or seven. I don't know
25 if some others may be here that remember this.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Initiative 1, I'm not going to go through the whole
2 list --

3 MEMBER BLEY: No, no. I've been looking
4 all over to figure out where it came from and I wasn't
5 able to find it.

6 MR. BRADLEY: Some of them were sort of
7 low-hanging fruit kind of simple things. 4b and 5b
8 were the ones where we knew we had to have the PRA
9 pedigree, the standards. These were the bigger
10 picture initiatives where we were trying to make
11 holistic changes to the tech specs. So those were the
12 last to come along. But we've implemented one which
13 was, we had mode restraints initiative, the missed
14 surveillance initiative. I'm drawing a blank on what
15 initiative 2 was now.

16 MEMBER BLEY: That's okay. I just wanted
17 to nail them down.

18 CHAIR STETKAR: You have to come up here.

19 MR. BRADLEY: Initiative 1 was being able
20 to go to hot shutdown instead of cold shutdown.
21 Initiative 2 was don't shut the plant down if you miss
22 a surveillance. Initiative 3 was you can change modes
23 within certain constraints if you're in an LCO or
24 entering a mode of applicability of that LCO. And
25 then we have Initiative 4a which is just single

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 completion time extensions versus the holistic 4b.
2 Initiative 5, surveillance. Initiative 6 is 3.0.3,
3 that's the loss of function initiative where we're
4 actually trying to carve out specific loss of function
5 situations and see if we could extend the completion
6 time. There's been some limited approval, fairly
7 limited. And then initiative 7 was the barriers,
8 barriers and snubbers initiative.

9 But we're pretty much at the end of our
10 list now. We've actually achieved completion and
11 we're now trying to achieve widespread implementation.
12 5b is well along the way and 4b, really looking
13 forward to getting the Vogtle case through. STP has
14 4b, but getting another plant beyond STP is critical.
15 The industry likes to see that someone other than STP
16 can achieve success and then you tend to get the herd
17 effect.

18 CHAIR STETKAR: Well, it's only because
19 STP is sort of for those of you who don't know the
20 plant design, they have three trains basically of
21 things most of the other folks don't. So extending it
22 to a more typical-looking plant is important.

23 MEMBER BLEY: Thank you. The other one
24 was I understand in military arena and security arena
25 how tabletop evolved as opposed to force on force

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 activities. I don't know why these are tabletops
2 rather than pilots or trials or something so tell me.

3 MR. BRADLEY: I will defer -- that
4 decision was made by the NRC staff and that
5 terminology came from there.

6 MEMBER BLEY: Okay. I asked the wrong
7 person on that one.

8 MR. BRADLEY: We, you know, we did have a
9 tabletop here even I think in this room once but
10 that's the only thing I know.

11 MEMBER BLEY: So you talked over these
12 trials over a table. Okay, good enough. Thanks.

13 CHAIR STETKAR: Anything else for Biff
14 from any of the members? If not let me do two things.

15 MEMBER BLEY: Okay. Are you going to go
16 around?

17 CHAIR STETKAR: I am, but first I'm going
18 to ask for public, if there are any public comments.
19 And I guess we should open up the bridge line. While
20 we're doing that is there any member of the public
21 here? If you're hiding behind the column. Seeing
22 none I'll wait. I understand -- oh, there is.
23 Excellent.

24 MR. BYWATER: Hello, Mr. Chairman. My
25 name is Russ Bywater. I work for Mitsubishi, also

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 here representing our client Luminant, COL applicant
2 for Comanche Peak Units 3 and 4. And we understand
3 we'll be here next month to brief the US APWR
4 subcommittee on the application for using initiatives
5 4b and 5b in the Comanche Peak COLA. So we'll be
6 eager to answer your questions and present our
7 methodology to you then with the staff.

8 CHAIR STETKAR: That's great. We're
9 really looking forward to that. As I said, as you
10 mentioned it's US APWR but it's the two subcommittees.
11 So that will be a very informative presentation I'm
12 sure. Is the bridge line? If there's anyone out
13 there listening please just utter some sound so that
14 we know that the bridge line is open. Thank you,
15 that's good enough. we know it's open now. Are there
16 any members of the public who wish to make a statement
17 or anyone who's on the bridge line that would like to
18 say anything? Hearing nothing I assume that's a
19 negative response so thank you very much. If we can
20 re-close the bridge line just so that we don't hear
21 the noise in the background. Appreciate that.

22 And now what I'd like to do is go around
23 the table and ask for two things. Number one, if
24 anyone has any final comments or questions on anything
25 we've heard today. And number two, if anyone believes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that -- I'd like to get some input from anything that
2 we've heard today is there a need to bring it to the
3 full committee at this stage in the game in the sense
4 that you know something for full committee attention
5 that we may want to write an interim letter. So I'll
6 start with the most senior and esteemed member.

7 MEMBER ABDEL-KHALIK: I don't have any
8 additional comments and I don't think there's anything
9 at this stage that would be necessary to bring to the
10 full committee.

11 CHAIR STETKAR: Okay. Dick?

12 MEMBER SKILLMAN: Nothing, thank you.

13 CHAIR STETKAR: Dennis.

14 MEMBER BLEY: Nothing to bring to the full
15 committee but I do want to comment since I raised the
16 issue earlier on this idea of needing more experience
17 before we can start using some of these methods. I
18 don't quite understand that. I think the engineering
19 judgment criteria they put in place to control the
20 process as well as the requirements for monitoring are
21 more than adequate. And I don't think there's an
22 alternative that'll give us a better way to address
23 these issues than those that were described here
24 today. So I just don't see a reason to hold back. I
25 mean, the equipment, the materials, as Bill said, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 know, it's the same materials. We may get some
2 surprises but not doing this doesn't help us in any
3 way that I can see so I just don't understand that
4 part. I'd like to see it go on ahead.

5 CHAIR STETKAR: Thank you. Bill?

6 MEMBER SHACK: I'll echo Dennis.

7 CHAIR STETKAR: Okay. Joy?

8 MEMBER REMPE: And I guess I'd echo Said
9 and Dick. I don't have any additional comments and I
10 don't see a need to take it to the full committee.

11 CHAIR STETKAR: Okay, thank you very much.
12 I also echo Dennis's sentiments that I think when we
13 do have the subcommittee presentation in the spring
14 and certainly before the full committee if there's
15 this notion of delay the implementation of this
16 process until we've accumulated enough operating
17 experience I think that you may want to think about
18 explaining some more of the rationale behind that.

19 If nothing else again I'd like to thank
20 the staff very much. I really appreciate the time and
21 effort you put into putting the presentations
22 together. I know it takes quite a bit of effort to
23 compile all of that information into a coherent
24 presentation. And you did really, really well, I
25 appreciate that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: The meeting summaries were
2 quite good too, actually.

3 MEMBER BLEY: Yes.

4 MEMBER SHACK: I've read meeting summaries
5 that don't tell me anything and then I've read meeting
6 summaries that are actually informative and this was
7 the informative.

8 CHAIR STETKAR: And I'd like to thank EPRI
9 and -- who's left and NEI. Bring Pat for something
10 and let him off.

11 MR. BYWATER: We'll let him know you
12 thanked him.

13 CHAIR STETKAR: Okay. And with that we
14 are adjourned.

15 (Whereupon, the foregoing matter went off
16 the record at 2:30 p.m.)

17

18

19

20

21

22

23

24

25



U.S. NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

INFORMATIONAL BRIEFING ON SRM TO SECY-10-0121, “MODIFYING THE RISK-INFORMED REGULATORY GUIDANCE FOR NEW REACTORS”

**Advisory Committee on Reactor Safeguards
Subcommittee on Reliability and PRA**

Contacts: Donald Dube, Office of New Reactors, (301) 415-1483
Eric Powell, Office of New Reactors, (301) 415-4052

September 20, 2011



Meeting Purpose

Provide information on progress regarding the staff's activities in response to the SRM on SECY-10-0121

Agenda

- **Background on SECY-10-0121 and SRM**
- **Tabletop exercises**
 - Risk-informed inservice inspection of piping
 - Risk-informed technical specification initiative (RITS) 5b (surveillance frequency control program)
 - Part 52 change process: ex-vessel severe accident design features
 - RITS 4b (completion times) and Maintenance Rule 50.65(a)(4)
- **Next steps**
- **Stakeholder inputs**

Background

- **A number of risk-informed applications for new reactors are proposed including**
 - EPRI research program on Risk-informed ISI
 - RITS 4b & 5b (Comanche Peak 3 & 4 COLA)
 - 50.69
- **White paper dated February 12, 2009 discussed concerns, particularly on the Reactor Oversight Process (ROP)**
- **SECY-10-0121 dated September 14, 2010 provided options for Commission vote**
- **Commission briefing October 14, 2010**
- **SRM March 2, 2011**

Contents of SECY-10-0121

- **Four major change processes and guidance**
- **Previous Commission expectations, policy papers, and Part 52 regulations**
- **Issues related to risk-informed changes to licensing basis and ROP**
- **Interactions with stakeholders**
- **Options and staff recommendation**

Options Provided in SECY-10-0121

- 1) No changes to existing risk-informed guidance (status quo)**
- 2) Implement enhancements to existing guidance to prevent significant decrease in enhanced safety (NRC staff recommendation)**
- 3) Develop lower numeric thresholds for new reactors**

Commission SRM

Dated March 2, 2011

- **Commission approved a hybrid of Options 1 and 2**
 - Continue existing risk-informed framework pending a series of tabletop exercises that test existing guidance

- **Commission “reaffirms” existing**
 - safety goals
 - safety performance expectations
 - subsidiary risk goals and associated risk guidance
 - key principles (e.g., RG 1.174)
 - quantitative metrics

- **Commission expects:**
 - Advanced technologies in new reactors will result in enhanced margins of safety
 - As a minimum, new reactors have the same degree of protection of the public and environment as current generation LWRs
- **New reactors with these enhanced margins and safety features should have greater operational flexibility than current reactors**

Key Deliverables

- **Brochure summarizing Commission policies and decisions regarding new reactor safety performance**
- **Guidance on 50.59-like process for new reactors under Part 52**
- **Tabletop exercises to test adequacy of existing guidance (risk-managed technical specifications (TS) , 50.69, and ROP specifically called out)**
- **Progress report every 6 months**
- **Commission paper with specific recommendations by June 2012**

Staff's Approach

- **Leverage current industry effort to revise NEI 96-07 to address new reactor change processes (new Appendix C)**
- **Prepare summary document/brochure with input from other NRC offices**
- **Leverage ongoing efforts in the review of US-APWR risk-managed tech specs**
- **Address 50.69 and RI-ISI early on**
- **Exercise SPAR models for AP1000 and ABWR to test certain maintenance configurations**
- **Compare ROP process outcomes for new reactor designs to current fleet**
- **Use insights from reactor designers for realistic plant modifications and licensing basis changes**

Approach (cont.)

- **Address large release frequency (LRF), including such options as its elimination as a risk metric, replacement by LERF, or transition from LRF to LERF by initial fuel loading**
- **Draft Commission paper early 2012 along with holding several ACRS briefings**




Figure 1. Approximate timeline

Steps Taken


- **Pre-SRM tabletop on changes to ex-vessel severe accident features, December 2, 2010**
- **Kickoff public meeting on SRM response, March 24, 2011**
- **Tabletops**
 - Risk-informed ISI, May 4
 - RITS 4b (completion times) and Maintenance Rule 50.65 (a)(4), May 26 & June 1
 - RITS 5b (surveillance frequency control program), June 29
 - 50.69 and 50.59-like process for new reactors, August 9
- **ROP tabletop preparation public meeting, August 25**
- **Summary-level public communication brochure drafted Spring 2011**

Tabletop Exercise on Risk-Informed Inservice Inspection of Piping (RI-ISI)


Overview of RI-ISI

- **Key methodology and guidance documents**
 - WCAP-14572, Revision 1-NP-A (1999)
 - EPRI TR-112657, Rev B-A (1999)
 - ASME CC N716 *“Risk-Informed / Safety Based ISI”* (RIS_B)
 - RG 1.178 (RI-ISI)
 - RG 1.174 (risk-informed changes to licensing basis)
- **At this point, new light-water reactors appear to be potentially interested in applying either the “traditional” or “streamlined” EPRI approach**

EPRI Traditional Methodology



EPRI Risk Evaluation



EPRI Degradation Mechanism Category

Pipe Rupture Potential	Expected Leak Conditions	Degradation Mechanisms To Which The Segment is Susceptible
HIGH	Large	Flow Accelerated Corrosion (FAC)
MEDIUM	Small	Thermal Fatigue Stress Corrosion Cracking (IGSCC, TGSCC, PWSCC, ECSCC) Localized Corrosion (MIC, Crevice Corrosion and Pitting) Erosion-Cavitation
LOW	None	No Degradation Mechanisms Present

EPRI Consequence Ranking: Numerical Criteria

Consequence Category	Corresponding CCDP Range	Corresponding CLERP Range
High	$\text{CCDP} > 1\text{E-}4$	$\text{CCDP} > 1\text{E-}5$
Medium	$1\text{E-}6 < \text{CCDP} \leq 1\text{E-}4$	$1\text{E-}7 < \text{CCDP} \leq 1\text{E-}5$
Low	$\text{CCDP} \leq 1\text{E-}6$	$\text{CCDP} \leq 1\text{E-}7$

EPRI Delta Risk Impact: from ASME Section XI program to RI-ISI

Plant Level:

< 1E-06/yr CDF

< 1E-07/yr LERF

System Level:

< 1E-07/yr CDF

< 1E-08/yr LERF

Staff's Sampling from Past Licensing Submittals using EPRI Methodology


Plant	Submittal Date	Delta CDF/yr	Delta LERF/yr
Dresden 2,3	10/16/2000	3.14E-09	7.57E-10
ANO 1	06/11/2009	2.26E-09	4.53E-10
Shearon Harris 1	04/27/2005	7.43E-09	2.05E-10
Susquehanna 1	09/16/2003	8.27E-09	6.69E-09
Vogtle 1	04/15/2009	-3.66E-08	-3.66E-09
Calvert Cliffs	05/29/2002	-2.61E-08	-5.81E-09

Considerations Concerning RI-ISI Location Selection


- **Code Case N-560:** Number of elements to be volumetrically examined is 10 percent of the piping weld population, based upon the exceptional performance history of this class of piping
- **Code Case N-578:** Risk category 1,2, or 3, the minimum number of inspection elements in each category should be 25 percent of the total number of elements in each risk category. For risk category 4 or 5, inspect 10 percent of the total number of elements in each risk category.
- **Code Case N-716:** Identifies portions of systems that should be generically classified as high safety significant (HSS) at all plants. The licensee's PRA is subsequently used to search for any additional, plant-specific HSS segments that are not included in the generic HSS population. Section 4 in CC N-716 requires that 10 percent of HSS welds shall be selected for examination.

- **One reactor design with active safety features and one with passive features**
 - **Observed more differences between BWRs & PWRs of current fleet than between new active and passive designs**
- **Sensitivity study using one order of magnitude lower Δ CDF and Δ LERF acceptance criteria per RG 1.174**
- **For 3 & 4 train new reactor designs, find shift in inspection focus to common headers**

EPRI's Scoping Calculations: Class 1 Welds Consequence Ranking



EPRI's Scoping Calculations: Class 1 Welds Risk Ranking



EPRI's Scoping Calculations: Delta Risk

Risk	DM	# of Section XI Inspections	# of RI ISI Inspections	Delta in Number of Inspections	CCDP	PBF Frequency per Weld [1/yr]	Delta Risk [1/yr]
High	TF	2	2	0	2.E-03	2.E-07	0.E+00
Medium	IGSCC/TF	4	2	2	1.E-04	2.E-07	4.E-11
Medium	None	34	14	20	1.E-04	1.E-08	2.E-11
Low	None	94	0	94	1.E-06	1.E-08	9.E-13
ACTIVE, Current AC - Average Case	Totals:	134	18	116			6.1E-11
		25.1%	3.4%				

Risk	DM	# of Section XI Inspections	# of RI ISI Inspections	Delta in Number of Inspections	CCDP	PBF Frequency per Weld [1/yr]	Delta Risk [1/yr]
High	TF	4	4	0	2.E-03	2.E-07	0.E+00
Medium	IGSCC/TF	7	3	4	1.E-04	2.E-07	8.E-11
Medium	None	68	28	40	1.E-04	1.E-08	4.E-11
Low	None	188	0	188	1.E-06	1.E-08	2.E-12
PASSIVE, Current AC - Average Case	Totals:	267	35	232			1.2E-10
		25.0%	3.3%				

Features and Regulatory / Programmatic Controls

- **The guidelines on potential CDF and LERF increases imposed at a system level as well as the overall totals. This ensures that no one system absorbs most of the change in risk.**
- **Inspection of a minimum set of weld locations is required regardless of what the risk levels are calculated to be**
- **A number of programs remain in place to address degradation mechanisms such as flow accelerated corrosion and microbiologically induced corrosion**

Features & Controls (cont.)

- **Risk category 4 in the risk evaluation matrix was introduced in the EPRI methodology to address the unknowns with high consequence/low frequency phenomena**
- **Risk category 5 was introduced to ensure that some inspection is provided even if the consequences of certain pipe failures are identified as low**
- **The RI-ISI program requires updating the risk ranking, on average, every 3 and 1/3 years; this interval approximates the Part 52 requirement for periodic upgrade of the plant-specific PRA**

Preliminary Results on RI-ISI

- **Risk-neutral effect for a new active plant and a new passive plant, even when sensitivity studies used more restrictive acceptance criteria**
- **Numerous regulatory and programmatic controls**
- **Consensus that RI-ISI would not result in any significant decrease in enhanced safety**
- **Potential regulatory and implementation issues, for example**
 - **Lack of operating experience**
 - **A new plant could not begin with RI-ISI.**
A conventional ISI program per 50.55a is a requirement to implement RI-ISI

Tabletop Exercise on Risk-Informed Technical Specifications Initiative (RITS) 5b: Surveillance Frequency Control Program (SFCP)

Overview of RITS 5b

- **Key methodology and guidance documents**
 - **NEI 04-10, Risk-Informed Technical Specifications Initiative 5b, Risk-Informed Method for Control of Surveillance Frequencies, Revision 1, April 2007**
 - **RG 1.177 (risk-informed technical specifications)**
 - **RG 1.174 (risk-informed changes to licensing basis)**
- **At least one new light-water reactor vendor and one combined license applicant have expressed interest in applying 5b**
- **Risk increase assumption: failure probability derived entirely from standby failure model $\frac{1}{2} \lambda T$**

Benefits of RITS 5b

- **Optimize surveillance frequencies**
- **Maximize equipment availability**
- **Increase equipment life**
- **Maintain technical specification requirements**
- **Enhance safety**

NEI 04-10 Methodology





Figure 1. Surveillance Frequency Control Program Change Process

Process in Brief

- **Select a candidate for new surveillance frequency**
 - **Frequent testing/resource burden, equipment wear**
- **Propose new frequency**
- **Evaluate proposed change**
 - **Commitments, reliability, unavailability, industry and plant-specific operating experience**
- **Review and approve**
- **Implement**
- **Monitor**

NEI 04-10: Key Steps in Feedback Loop



Experience and Insights from Current Fleet

- **About 40% of operating reactors are approved for 5b**
- **Integrated decision-making panels' (IDP) review is key**
 - **Have rejected many proposed changes based on deterministic considerations**
- **Risk assessments used whenever possible, but many changes do not lend themselves to precise risk calculation (bounding, qualitative)**
- **Test intervals changed in phases, for example:
monthly → quarterly → annual**
- **Appropriate performance monitoring criteria need to be set**
- **Need consistently good performance baseline before moving on to longer test intervals**

- **Need adequate operating experience**
 - **Assess applicability of equipment performance from operating fleet**
 - **May be several operating cycles before adequate confidence on baseline performance in new reactors is achieved**

- **Observation that many key PRA components fall under IST and not subject to 5b**
- **Sensitivity studies**
 - Battery testing: increased STI and hence failure rate 4x including CCF: $\Delta\text{CDF} \sim 10^{-8}$ /yr, $\Delta\text{LERF} \sim 10^{-8}$ /yr
 - Surveillance that power removed on MOV for core cooling (3x): $\Delta\text{CDF} \sim 10^{-9}$ /yr, $\Delta\text{LERF} \sim 10^{-12}$ /yr
 - RHR isolation valve power removed (3x):
 $\Delta\text{CDF} \sim 10^{-7}$ /yr, $\Delta\text{LERF} \sim 10^{-8}$ /yr
 - Diverse actuation system (DAS) manual control (2x):
 $\Delta\text{CDF} \sim 10^{-9}$ /yr

Features and Regulatory / Programmatic Controls

- **Surveillance frequencies controlled by other programs are excluded from the SFCP**
 - **Equipment covered by inservice testing, for example major pumps and valves, tend to have some of the highest risk importances but are excluded**
 - **What remains to be implemented under RITS 5b generally are lower risk importance components**
- **The integrated decision-making panel's (IDP) review of proposed changes strengthens the process**
 - **Broad range of expertise**
 - **Some licensees include additional approvals such as the plant operations review committee, and the oversight review board**

Features & Controls (cont.)

- **Monitoring and feedback, and periodic re-assessment are fed back to the IDP**
 - **Actual changes in the reliability of equipment modeled in the PRA are included in the periodic updates**
 - **Unacceptable equipment performance could result in returning the surveillance frequency to the previous setting**
- **Impact of changes on defense in depth, Maintenance Rule, the mitigating systems performance index, and other programs are assessed**
 - **These programs may limit the scope of RITS 5b changes because of the potential to reduce operational and safety margins**

Features & Controls (cont.)

- **The phased approach whereby surveillance test intervals are gradually increased from, for example, monthly to quarterly to annual assures that failure rate changes are identified and addressed before becoming unacceptably high**

Preliminary Results on RITS 5b

- **Numerous regulatory and programmatic controls**
- **Unlike RITS 4b, RITS 5b is much more deterministically oriented, with risk impact only a secondary consideration in the criteria for changing surveillance test interval**
- **Need for sufficient baseline operating experience on affected equipment during the initial cycle(s) of reactor operation before commencing full implementation of RITS 5b in the new plants**



Tabletop Exercise on Part 52 Change Process: Ex-Vessel Severe Accident Design Features, Section VIII.B.5.c of the Design Certification Rule

Background

- **NEI 96-07, Guidance on 50.59, new Appendix C regarding Part 52 change process, for example:**
 - **Departures from Tier 1, Tier 2, and Tier 2***
 - **Effect on design basis accidents**
 - **Aircraft impact assessment**
 - **Assessment of loss of large areas**
 - **Tier 2 changes to ex-vessel severe accident (EVSA) design features**
- **Staff internal workshop on changes to EVSA design features August, 2010**
- **Public workshop on EVSA December 2, 2010**
- **Public meeting on EVSA draft guidance Aug 9, 2011**

From Part 52 App. A (ABWR)

- **VIII.B.5.c. A proposed departure from Tier 2 affecting resolution of an ex-vessel severe accident design feature identified in the plant-specific DCD, requires a license amendment if:**
 - (1) There is a substantial increase in the probability of an ex-vessel severe accident such that a particular ex-vessel severe accident previously reviewed and determined to be not credible could become credible; or**
 - (2) There is a substantial increase in the consequences to the public of a particular ex-vessel severe accident previously reviewed.**

What is an EVSA Design Feature?

Per the Statement of Considerations for the ABWR Final Rule, the change process for EVSA applies only to “severe accident design features, where the intended function of the design feature is relied upon to resolve postulated accidents when the reactor core has melted and exited the reactor vessel and the containment is being challenged”

EVSA Design Feature (cont.)

“In addition, the Commission is cognizant of certain design features that have intended functions to meet ‘design basis’ requirements and to resolve ‘severe accidents.’ These design features will be reviewed under either VIII.B.5.b or VIII.B.5.c depending upon the design function being changed.”

Design certification document to address challenges to containment integrity caused by:

- core-concrete interaction
- steam explosions
- high pressure core melt ejection
- hydrogen combustion, and
- containment bypass*

* Consensus of workshop participants that design features that prevent or mitigate containment bypass events are not in and of themselves EVSA features, and as such may not fall under Section VIII.B.5.c criteria.

Example EVSA Features

- **Reactor cavity flooding to promote in-vessel cooling and retention of core debris**
- **Reactor vessel depressurization to promote in-vessel cooling and retention of core debris**
- **Reactor vessel depressurization to prevent high pressure melt ejection**
- **Reactor cavity flooding to provide ex-vessel cooling of core debris**
- **Reactor cavity design to enhance core debris spreading and coolability**
- **Containment overpressure protection**
- **Combustible gas control**
- **Containment sprays and heat removal**

Example: US-APWR Tier 1 Fire Protection System Table 2.7.6.9-2

Design Commitment

6.b The FPS fire water supply is available to the containment spray system and **water injection to the reactor cavity for severe accident mitigation.**

Inspection, Tests, Analyses

6.b Inspection will be performed on the as-built FPS fire water supply.

Acceptance Criteria

6.b The as-built FPS fire water supply is provided to the containment spray system and water injection to the reactor cavity for severe accident mitigation.

Tier 1

2.11 Containment Systems

The fundamental design concept of the US-APWR for severe accident termination is reactor cavity flooding and cool down of the molten core by the flooded coolant water.

Reactor cavity flooding to enhance the cool down of the molten core ejected into the reactor cavity is achieved by the CSS, whose operation during a design basis accident is described in Subsection 2.11.3. Drain lines are used to drain spray water, which flows into the SG compartments, to the reactor cavity and cools the molten core. **Fire protection system (FPS) water injection may also be used to inject water to the drain lines from the SG compartment to the reactor cavity.** The FPS water supply is described in Subsection 2.7.6.9.1.

Tier 2

9.5.1 Fire Protection Program

9.5.1.2.2 Fire Protection Water Supply System

The fire water supply system is designed in accordance with the guidance of RG 1.189 (Ref. 9.5.1-12) and the applicable NFPA codes and standards. The fire protection water supply system is sized such that it contains sufficient water for two hours operation of the largest US-APWR sprinkler system plus a 500 gpm manual hose stream allowance to support fire suppression activities. Redundant water supply capability is provided. In addition to fire suppression activities, the fire protection water supply system may also supply water for severe accident prevention, for alternative component cooling water, and **for severe accident mitigation for the containment spray system and water injection to the reactor cavity**, if it is available.


Tier 2

9.5.1 Fire Protection Program

As discussed in Subsection 9.5.1.2, the fire pump arrangement provides **two 100% capacity pumps. One is a diesel driven fire pump and the other is an electric-motor driven fire pump.** One is designated as the lead fire pump. This system arrangement allows one pump to be out of service and still maintain the capability to provide 100% of the system flow requirements. An electric-motor driven jockey pump (or acceptable pressure source) is used to keep the fire water system full of water and pressurized, as required. Piping between the fire water sources and the fire pumps is in accordance with the guidance of NFPA 20 (Ref. 9.5.1-15). A failure in one water source or its piping cannot cause both water sources to be unavailable.

Tier 2

6.2 Containment



Considerations on Definitions of 'Substantial Increase'

- **Qualitative, quantitative, or combination**
- **SRM on SECY-10-0121 strongly influenced staff's and stakeholders' decision to refrain from quantitative definition**
 - **10% increase? 100% increase? 10x?**
 - **Concern with creating *de facto* new risk metric**

Evaluation of ‘Substantial Increase’ in Probability

- Each design control document states whether and how each severe accident challenge to containment has been addressed, either qualitatively or quantitatively
- Terms used such as *not credible*, *practically eliminated*, *not physically feasible*, and *not relevant*
- A change that adversely affects the original basis for not being credible could be a ‘substantial increase.’ For example, for the U.S. EPR, the strategy is to convert high pressure core melt sequences into low pressure sequences:
 - “so that a high pressure vessel breach can be practically excluded... this is achieved through two dedicated severe accident depressurization valve trains”

Evaluation of ‘Substantial Increase’ in Public Consequences

- **Not a substantial increase by demonstrating that the affected EVSA functions will still be successfully accomplished**
- **Substantial increase for departures that**
 - **remove, defeat or significantly degrade the performance of an EVSA design feature**
 - **containment performance goals in SECY-93-087 and SECY-90-016 would no longer be met**

Example: Not Increase in Public Consequences

- **Licensee identifies a nonconformance in that the thickness of a portion of the reactor cavity floor concrete is 0.1 foot less than the minimum thickness specified in Tier 2 of the referenced DCD**
- **Based on a comparison with the existing analysis, the licensee determines that the reduction in thickness would have a negligible impact on the functional performance of the reactor cavity floor in the presence of core debris (e.g., ability to maintain containment integrity for 24 hours)**

Example: Increase in Public Consequences

- **Licensee considers reducing the capacity of the containment venting system by 50%**
- **Licensee performs a calculation and determines that a 50% reduction would significantly degrade the containment venting function such that the containment may not be able to survive the pressures associated with the containment performance goals identified in SECY-93-087 and SECY-90-016, as approved by the associated Staff Requirements Memoranda, and described in NUREG-0800**



Preliminary Results on EVSA Design Feature Change Process

- **Efforts focused on definition and examples of “substantial increase” in probability and public consequences in NEI 96-07 Appendix C**
- **Certain severe accident features do not address “ex-vessel” conditions and appear not to be in-scope by the rule (e.g., features to prevent ISLOCA / containment bypass)**
 - **Fortunately, there are enough details in Tier 1 that such features can not be removed and significant design changes are precluded**
- **Staff generally satisfied with revised NEI 96-07 and has provided comments for clarification of draft guidance**



Tabletop Exercise on Risk-Informed Technical Specifications (RITS) Initiative 4b and Maintenance Rule 50.65(a)(4)

Overview - RITS 4b and MR(a)(4)

- **Key methodology and guidance documents**
 - NEI 06-09, “Risk-Informed Technical Specifications Initiative 4b, Risk-Managed Technical Specifications Guidelines”
 - NUMARC 93-01, “Industry Guideline for Monitoring the Effectiveness of Maintenance at Nuclear Power Plants, draft Rev.4, Section 11”
 - AP1000 DCD, Section 16.3.1 (investment protection short-term availability controls)
 - ESBWR DCD, Section 19ACM (availability controls manual and bases)
- **ABWR SPAR Model Case Studies**
- **AP1000 SPAR Model Case Studies**
- **Vendor’s Computational Results**
- **Maintenance Rule (a)(4)**

Case Study Assumptions - ABWR

- Only internal events at power
- CDF values are point estimates
- Truncation set at default, 1E-13
- All Test & Maintenance set to FALSE for all cases
- Equipment not functional, T&M set to TRUE

Description of Case Studies - ABWR


- 24 unique cases
- Equipment not functional (O.O.S.)
 - Electrical (EDGs and CTG)
 - ECCS (RCIC, HPCF, and LPFL)
 - Combination of Electrical + ECCS
 - Combination + ACIWA (FWEDP)

Electrical Connection to Equipment

Electrical			Other
CTG			
Division 1	Division 2	Division 3	
EDG-E	EDG-F	EDG-G	
	HPCF-B	HPCF-C	RCIC
LPFL-A	LPFL-B	LPFL-C	FWEDP

Configurations Modeled

Configuration



ABWR SPAR Model Results

RITS 4b Case	Equip. Not Functional	CDF	Δ CDF (per year)	Calc Completion Time (days)	Tech Spec Limit (days)	Allowed Completion Time (days)	ICDP	Other Available Equip
Base	None (no T&M)	2.6E-07	--	--	--	--	--	All
1	1 EDG-F	3.4E-07	8.3E-08	44135	14	30	6.8E-09	2 offsite AC power sources, 2 EDGs, and CTG
12*	RCIC and 2 HPCF-B/C	2.9E-04	2.9E-04	12	12 hr	[12 hr]	[4.0E-07]	3 LPFLs
21-A	2 EDG-F/G, 1 HPCF-B, 1 LPFL-A, and RCIC	4.9E-04	4.9E-04	7	EDG - 3 RCIC & 2 ECCS sub- sys. - 7	7	1.0E-05	2 offsite AC power sources, 1 EDG, and CTG; 1 HPCF and 2 LPFLs

Case Study Assumptions – AP1000

- Only internal events at power
- CDF values are point estimates
- Truncation set at default, 1E-14
- All Test & Maintenance set to FALSE for all cases
- Equipment not functional, switchboards / distribution panels, valves, or T&M set to TRUE

Description of Case Studies – AP1000

- 18 unique cases
- Equipment not functional (O.O.S.)
 - Electrical (DCP and ACP)
 - PXS (CMT, Accum., IRWST, and PRHR)
 - Combination of Electrical + PXS
 - Non-safety systems and non-safety systems in combination with PXS equipment

IDS & PXS Equipment Used in Cases

Class 1E DC System (IDS)			
Division A	Division B	Division C	Division D
1 - 24hr Battery	1 - 24hr Battery	1 - 24hr Battery	1 - 24hr Battery
	1 - 72hr Battery	1 - 72hr Battery	

Passive Core Cooling (PXS)	
DVI Line A	DVI Line B
Accum.-A (CKV)	Accum.-B (CKV)
CMT-A (CKV)	CMT-B (CKV)
IRWST-A (MOV)	IRWST-B (MOV)
IRWST-A (CKV1)	IRWST-B (CKV1)
IRWST-A (CKV2)	IRWST-B (CKV2)

AP1000 SPAR Model Results

RITS 4b Case	Equip. Not Functional	CDF	Δ CDF (per year)	Calc Completion Time (days)	Tech. Spec./IP Limit (hrs)	Allowed Completion Time (days)	ICDP	Other Available Equip
Base	None (no T&M)	2.1E-07	--	--	--	--	--	All
1	1 - 1E-DCP-A (DC/AC)	5.9E-07	3.8E-07	9623	6	30	3.1E-08	1 - 24hr division and 2 - 24/72hr divisions
7*	1 IRWST Injection Line-B (MOV)	1.1E-04	1.1E-04	33	1	[1hr]	[1.3E-08]	2 Accum., 1 IRWST ILs (2 flow paths), 2 PHRHs, and 2 CMTs
9-A*	1 CMT-A (CKV) and 1 Accum.-A (CKV)	1.6E-04	1.5E-04	24	CMT - 1 Accum. - 1	[1hr]	[1.8E-08]	1 Accum., 2 IRWST ILs (4 flow paths), 2 PHRHs, and 1 CMT

Vendor's Computational Results

- **U.S. EPR**

- Low ICDP values (most required 30-day backstop)
- Similar results as the ABWR SPAR cases
 - Significant amount of equipment out to reach 10^{-5} limit

- **ESBWR**

- Very low ICDP values calculated
 - N-2 design philosophy

- **AP1000**

- Westinghouse representative confirmed the staff's results using the SPAR models

- **APWR**

- Similar results as the ABWR SPAR cases
- LRF more limiting, not CDF

Features and Regulatory / Programmatic Controls

- The risk-informed completion time is limited to a deterministic maximum of 30 days (referred to as the backstop completion time) from the time the TS action was first entered
- Voluntary use of the risk-managed TS for a configuration which represents a loss of TS specified safety function, or inoperability of all required safety trains, is not permitted
- A license amendment request to implement RITS 4b is subject to staff review and approval, including the scope of the LCOs to which the program may be applied

Preliminary Results

- **RITS 4b**

- Enhanced definition of “loss of safety function” in NEI 06-09 needed
 - Safety Function Determination Program, LCO 3.0.6, and examples
- Staff expressed concern that, for a reactor with a baseline core damage frequency of $5E-7$ /yr, a one-time use of the current guidance for a maximum ICDP of $5E-6$ would represent 10 years’ worth of core damage probability
- With the configuration restricted to major equipment outages within one division (“realistic” based on current industry practice), followed by a single *emergent* equipment outage in a second division, staff calculated ICDPs in the low $1E-7$ to low $1E-6$ range
- Stakeholders noted that existing standard TS provide fewer controls on the frequency of entering certain LCOs, especially risk significant configurations
- Certain implementation and process issues may need to be addressed before implementing RITS 4b for new reactors

ABWR Case 22-B

ICDP = 5.8E-6*

Electrical			Other
<i>CTG</i>			
Division 1	Division 2	Division 3	
EDG-E	<i>EDG-F</i>	EDG-G	
	HPCF-B	<i>HPCF-C</i>	<i>RCIC</i>
LPFL-A	<i>LPFL-B</i>	LPFL-C	FWEDP

* 30 day backstop applied

Maintenance Rule 50.65(a)(4)

From NUMARC 93-01:

ICDP		ILERP
$> 10^{-5}$	- configuration should not normally be entered voluntarily	$> 10^{-6}$
$10^{-6} - 10^{-5}$	- assess non quantifiable factors - establish risk management	$10^{-7} - 10^{-6}$
$< 10^{-6}$	- normal work controls	$< 10^{-7}$

Maintenance Rule 50.65(a)(4) Applied to ABWR

Regular T.S. Cases

ICDP	Number of Cases
$> 10^{-5}$	1
$10^{-6} - 10^{-5}$	3
$< 10^{-6}$	21

RITS 4b Cases

ICDP	Number of Cases
$> 10^{-5}$	3
$10^{-6} - 10^{-5}$	6
$< 10^{-6}$	16

Maintenance Rule 50.65(a)(4) Applied to AP1000

Regular T.S. Cases

ICDP	Number of Cases
$> 10^{-5}$	--
$10^{-6} - 10^{-5}$	--
$< 10^{-6}$	21

RITS 4b Cases

ICDP	Number of Cases
$> 10^{-5}$	--
$10^{-6} - 10^{-5}$	--
$< 10^{-6}$	21

Preliminary Results

- **Maintenance Rule 50.65 (a)(4)**
 - When PRA approach is combined with other inputs such as the degree of defense in depth and plant transient assessment, factors other than PRA are often more limiting in terms of the risk management action level
 - NUMARC 93-01, Section 11 explicitly acknowledges “there is acknowledged variability in baseline core damage frequency and large early release frequency... determination of the appropriate quantitative risk management action thresholds are plant-unique activities”
 - Consensus that NUMARC 93-01, Section 11 on implementation guidance does not appear to need substantive change to address new reactor designs

Next steps

- **October 5, 2011 public workshop:**
 - **RG 1.174 and LRF-to-LERF transition issues**
 - **ROP tabletops using SDP findings, MSPI inputs, and MD8.3 applications from current fleet**
- **Late fall 2011: identify ‘gaps’ in guidance**
- **February 2012: Draft Commission paper with recommendations**
- **February 2012: Public communications brochure complete**
- **March-April 2012: ACRS briefings**
- **Late May 2012: Commission paper for notation vote**



Backup Slides



ABWR SPAR Model Results

RITS 4b Case	Equip. Not Functional	CDF	Δ CDF (per year)	Calc Completion Time (days)	Tech Spec Limit (days)	Allowed Completion Time (days)	ICDP	Other Available Equip
Base	None (no T&M)	2.6E-07	--	--	--	--	--	All
1	1 EDG-F	3.4E-07	8.3E-08	44135	14	30	6.8E-09	2 offsite AC power sources, 2 EDGs, and CTG
2	2 EDG-F/G	4.9E-06	4.6E-06	792	3	30	3.8E-07	2 offsite AC power sources, 1 EDG, and CTG
3*	3 EDG-E/F/G	2.3E-04	2.3E-04	16	Immediately begin shutdown	--	--	2 offsite AC power sources and CTG
4**	CTG	7.3E-07	4.7E-07	N/A	N/A	N/A	--	2 offsite AC power sources and 3 EDGs
5	2 EDG-F/G and CTG	8.6E-05	8.5E-05	43	Hot Shutdown in 12 hrs	30	7.0E-06	2 offsite AC power sources and 1 EDG
6	RCIC	4.7E-07	2.1E-07	17144	14	30	1.7E-08	2 HPCFs and 3 LPFLs
7	1 HPCF-B	4.8E-07	2.2E-07	16614	14	30	1.8E-08	1 HPCF, RCIC, and 3 LPFLs
8	2 HPCF-B/C	1.1E-05	1.1E-05	337	14	30	8.9E-07	RCIC and 3 LPFLs
9	RCIC and 1 HPCF-B	3.7E-06	3.4E-06	1066	14	30	2.8E-07	1 HPCF and 3 LPFLs
10	RCIC, 1 HPCF-B, and 1 LPFL-A	4.0E-06	3.8E-06	970	7	30	3.1E-07	1 HPCF and 2 LPFLs
11	2 HPCF-B/C and 1 LPFL-A	1.1E-05	1.1E-05	338	3	30	8.9E-07	RCIC and 2 LPFLs
12*	RCIC and 2 HPCF-B/C	2.9E-04	2.9E-04	12	12 hr	[12 hr]	[4.0E-07]	3 LPFLs
13	1 EDG-F and RCIC	7.3E-07	4.7E-07	7756	EDG - 14 RCIC - 14	30	3.9E-08	2 offsite AC power sources, 2 EDGs, and CTG; 2 HPCFs and 3 LPFLs



ABWR SPAR Model Results

RITS 4b Case	Equip. Not Functional	CDF	ΔCDF (per year)	Calc Completion Time (days)	Tech Spec Limit (days)	Allowed Completion Time (days)	ICDP	Other Available Equip
14	1 EDG-F and 1 HPCF-C	6.8E-07	4.3E-07	8542	EDG - 14 HPCF - 14	30	3.5E-08	2 offsite AC power sources, 2 EDGs, and CTG; RCIC, 1 HPCF, and 3 LPFLs
15	2 EDG-F/G and RCIC	1.5E-05	1.5E-05	241	EDGs - 3 RCIC - 14	30	1.2E-06	2 offsite AC power sources, 1 EDG, and CTG; 2 HPCFs and 3 LPFLs
16-A	1 EDG-F, 1 HPCF-C, and 1 LPFL-A	1.9E-06	1.6E-06	2246	EDG - 14 2 ECCS sub-sys. - 14	30	1.3E-07	2 offsite AC power sources, 2 EDGs, and CTG; RCIC, 1 HPCF, and 2 LPFLs
16-B	1 EDG-F, 1 HPCF-B, and 1 LPFL-B	6.0E-07	3.4E-07	10723	EDG - 14 2 ECCS sub-sys. - 14	30	2.8E-08	2 offsite AC power sources, 2 EDGs, and CTG; RCIC, 1 HPCF, and 2 LPFLs
17	1 EDG-F, 1 HPCF-C, and RCIC	7.1E-06	6.8E-06	537	EDG - 14 RCIC & ECCS sub-sys. - 14	30	5.6E-07	2 offsite AC power sources, 2 EDGs, and CTG; 1 HPCF and 3 LPFLs
18	1 EDG-F, 1 LPFL-C, and RCIC	8.6E-07	6.0E-07	6083	EDG - 14 RCIC & ECCS sub-sys. - 14	30	4.9E-08	2 offsite AC power sources, 2 EDGs, and CTG; 2 HPCFs and 2 LPFLs
19	1 EDG-F, 1 HPCF-C, 1 LPFL-A, and RCIC	1.8E-05	1.8E-05	202	EDG - 14 RCIC & 2 ECCS sub-sys. - 7	30	1.5E-06	2 offsite AC power sources, 2 EDG, and CTG; 1 HPCF and 2 LPFLs
20	2 EDG-F/G, 1 HPCF-B, and RCIC	1.9E-05	1.8E-05	198	EDG - 3 RCIC & ECCS sub-sys. - 14	30	1.5E-06	2 offsite AC power sources, 1 EDG, and CTG; 1 HPCF and 3 LPFLs



ABWR SPAR Model Results

RITS 4b Case	Equip. Not Functional	CDF	ΔCDF (per year)	Calc Completion Time (days)	Tech Spec Limit (days)	Allowed Completion Time (days)	ICDP	Other Available Equip
21-A	2 EDG-F/G, 1 HPCF-B, 1 LPFL-A, and RCIC	4.9E-04	4.9E-04	7	EDG - 3 RCIC & 2 ECCS sub-sys. - 7	7	1.0E-05	2 offsite AC power sources, 1 EDG, and CTG; 1 HPCF and 2 LPFLs
21-B	2 EDG-F/G, 1 HPCF-B, 1 LPFL-C, and RCIC	1.9E-05	1.8E-05	198	EDG - 3 RCIC & 2 ECCS sub-sys. - 7	30	1.5E-06	2 offsite AC power sources, 1 EDG, and CTG; 1 HPCF and 2 LPFLs
22-A	1 EDG-F, CTG, 1 HPCF-C, 1 LPFL-A, and RCIC	2.7E-04	2.7E-04	14	EDG - H.S. in 12hr RCIC & 2 ECCS sub-sys. - 7	14	1.0E-05	2 offsite AC power sources, 2 EDG; 1 HPCF and 2 LPFLs
22-B	1 EDG-F, CTG, 1 HPCF-C, 1 LPFL-B, and RCIC	7.1E-05	7.1E-05	52	EDG - H.S. in 12hr RCIC & 2 ECCS sub-sys. - 7	30	5.8E-06	2 offsite AC power sources, 2 EDG; 1 HPCF and 2 LPFLs
22-C	1 EDG-F, CTG, 1 HPCF-B, 1 LPFL-B, and RCIC	8.9E-06	8.6E-06	424	EDG - H.S. in 12hr RCIC & 2 ECCS sub-sys. - 7	30	7.1E-07	2 offsite AC power sources, 2 EDG; 1 HPCF and 2 LPFLs
23	2 EDG-F/G, 1 HPCF-C, RCIC, and FWEDP [#]	3.7E-05	3.7E-05	99	EDG - 3 RCIC & ECCS sub-sys. - 14	30	3.0E-06	2 offsite AC power sources, 1 EDG, and CTG; 1 HPCF and 3 LPFLs
24	2 EDG-F/G, 1 HPCF-B, 1 LPFL-A, RCIC, and FWEDP [#]	1.5E-03	1.5E-03	2	EDG - 3 RCIC & 2 ECCS sub-sys. - 7	3	1.3E-05	2 offsite AC power sources, 1 EDG, and CTG; 1 HPCF and 2 LPFLs

AP1000 SPAR Model Results

RITS 4b Case	Equip. Not Functional	CDF	ΔCDF (per year)	Calc Completion Time (days)	Tech. Spec./IP Limit (hrs)	Allowed Completion Time (days)	ICDP	Other Available Equip
Base	None (no T&M)	2.1E-07	--	--	--	--	--	All
1	1 - 1E-DCP-A (DC/AC)	5.9E-07	3.8E-07	9623	6	30	3.1E-08	1 - 24hr division and 2 - 24/72hr divisions
2	1 - 1E-DCP-B (2DC/AC)	5.9E-07	3.8E-07	9628	6	30	3.1E-08	2 - 24hr divisions and 1 - 24/72hr division
3 [#]	2 - 1E-DCP-B/C (2-2DC/AC)	2.9E-06	2.6E-06	1379	2	30	2.2E-07	2 - 24hr divisions and 0 - 24/72hr division
4 [*]	2 - 1E-DCP-B/D (2DC/AC-DC/AC)	1.6E-03	1.6E-03	2	2	[2hr]	[3.6E-07]	1 - 24hr division and 1 - 24/72hr division
5	1 CMT-A (CKV)	5.2E-07	3.0E-07	12070	8	30	2.5E-08	2 Accum., 2 IRWST ILs (4 flow paths), 2 PHRHs, and 1 CMT
6 [*]	1 Accum.-A (CKV)	4.2E-06	4.0E-06	907	8	[8hr]	[3.7E-09]	1 Accum., 2 IRWST ILs (4 flow paths), 2 PHRHs, and 2 CMTs
7 [*]	1 IRWST Injection Line-B (MOV)	1.1E-04	1.1E-04	33	1	[1hr]	[1.3E-08]	2 Accum., 1 IRWST ILs (2 flow paths), 2 PHRHs, and 2 CMTs
8	1 IRWST Injection Line-A (CKV)	8.2E-07	6.1E-07	6000	72	30	5.0E-08	2 Accum., 2 IRWST IL (3 flow paths), 2 PHRHs, and 2 CMTs
9-A [*]	1 CMT-A (CKV) and 1 Accum.-A (CKV)	1.6E-04	1.5E-04	24	CMT - 1 Accum. - 1	[1hr]	[1.8E-08]	1 Accum., 2 IRWST ILs (4 flow paths), 2 PHRHs, and 1 CMT
9-B [*]	1 CMT-A (CKV) and 1 Accum.-B (CKV)	8.9E-06	8.7E-06	419	CMT - 1 Accum. - 1	[1hr]	[9.9E-10]	1 Accum., 2 IRWST ILs (4 flow paths), 2 PHRH, and 1 CMT

AP1000 SPAR Model Results

RITS 4b Case	Equip. Not Functional	CDF	ΔCDF (per year)	Calc Completion Time (days)	Tech. Spec./IP Limit (hrs)	Allowed Completion Time (days)	ICDP	Other Available Equip
10	1 CMT-A (CKV) and 1 IRWST Injection Line-A (CKV)	1.1E-06	8.6E-07	4250	CMT - 8 IRWST IL - 72	30	7.1E-08	2 Accums., 2 IRWST ILs (3 flow paths), 2 PHRHs, and 1 CMT
11-A	1 - 1E-DCP-B (2DC/AC) and 1 CMT-A (CKV)	7.9E-07	5.8E-07	6293	DCP - 6 CMT - 8	30	4.8E-08	2 - 24hr divisions and 1 - 24/72hr division; 2 Accums., 2 IRWST ILs (4 flow paths), 2 PHRHs, and 1 CMT
11-B	1 - 1E-DCP-A (DC/AC) and 1 CMT-A (CKV)	9.9E-07	7.8E-07	4683	DCP - 6 CMT - 8	30	6.4E-08	1 - 24hr divisions and 2 - 24/72hr division; 2 Accums., 2 IRWST ILs (4 flow paths), 2 PHRHs, and 1 CMT
12	1 - 1E-DCP-B (2DC/AC) and 1 IRWST Injection Line-A (CKV)	3.0E-06	2.8E-06	1317	DCP - 6 IRWST IL - 72	30	2.3E-07	2 - 24hr divisions and 1 - 24/72hr division; 2 Accums., 2 IRWST ILs (3 flow paths), 2 PHRHs, and 2 CMTs
13-A	1 - 1E-DCP-B (2DC/AC), 1 CMT-A (CKV), and 1 IRWST Injection Line-A (CKV)	3.4E-06	3.2E-06	1141	DCP - 6 CMT - 8 IRWST IL - 72	30	2.6E-07	2 - 24hr divisions and 1 - 24/72hr division; 2 Accums., 2 IRWST ILs (3 flow paths), 2 PHRHs, and 1 CMT
13-B	1 - 1E-DCP-A (DC/AC), 1 CMT-A (CKV), and 1 IRWST Injection Line-A (CKV)	3.3E-06	3.1E-06	1165	DCP - 6 CMT - 8 IRWST IL - 72	30	2.6E-07	1 - 24hr divisions and 2 - 24/72hr division; 2 Accums., 2 IRWST ILs (3 flow paths), 2 PHRHs, and 1 CMT
14	3 ADS (Stage 1, 2, 3 MOVs)	2.9E-07	8.0E-08	45398	3 ADS - 72	30	6.6E-09	7 ADS flow paths (stage 1, 2, 3, 4)

AP1000 SPAR Model Results

RITS 4b Case	Equip. Not Functional	CDF	Δ CDF (per year)	Calc Completion Time (days)	Tech. Spec./IP Limit (hrs)	Allowed Completion Time (days)	ICDP	Other Available Equip
15	1 SFW-A, 1 DGN-A, 1 CVCS-A, 1 NRHR-A, and DAS	2.2E-07	6.5E-09	561538	NRHR - 14d DAS - 14d DGN - 14d	30	5.3E-10	All PXS equipment
16	2 SFW-A/B, 2 DGN-A/B, 2 CVCS-A/B, 2 NRHR-A/B, and DAS	3.3E-07	1.2E-07	31223	DAS - 14d	30	9.6E-09	All PXS equipment
17	2 SFW-A/B, 2 DGN-A/B, 2 CVCS-A/B, 2 NRHR-A/B, DAS, and 1 PRHR-A (AOV)	3.5E-07	1.4E-07	26681	PRHR - 72 DAS - 14d	30	1.1E-08	2 Accums., 2 IRWST ILs (4 flow paths), 1 PHRH, and 2 CMTs
18	2 SFW-A/B, 2 DGN-A/B, 2 CVCS-A/B, 2 NRHR-A/B, DAS, and 1 CMT-A (CKV)	7.3E-07	5.1E-07	7093	CMT - 8 DAS - 14d	30	4.2E-08	2 Accums., 2 IRWST ILs (4 flow paths), 2 PHRHs, and 1 CMT

Review of Risk-Informed Regulatory Guidance for New Reactors

**ACRS Reliability and PRA
Subcommittee**

September 20, 2011

**Biff Bradley
reb@nei.org**



NUCLEAR
ENERGY
INSTITUTE

Overview

- **Staff Requirements Memorandum**
- **Industry perspective**
- **Tabletop Exercises for Risk Informed Guidance**
- **Preliminary Conclusions**
- **Next steps**

March 2, 2011 Staff Requirements Memorandum

- **The Commission reaffirms that the existing safety goals, safety performance expectations, subsidiary risk goals and associated risk guidance (such as the Commission's 2008 Advanced Reactor Policy Statement and Regulatory Guide 1.174), key principles and quantitative metrics for implementing risk-informed decision making, are sufficient for new plants.**
- **The staff should engage with external stakeholders in a series of tabletop exercises to test various realistic performance deficiencies, events, modifications, and licensing bases changes against current NRC policy, regulations, guidance and all other requirements (e.g., Technical Specifications, license conditions, code requirements) that are or will be relevant to the licensing bases of new reactors.**

Industry Perspective

- **Industry provided paper supporting use of existing risk framework for new plants**
 - Existing Framework derived from Commission Policy (Safety Goal)
 - New plants have PRA requirement and should be encouraged to use risk applications
 - Use of risk applications at operating plants has led to better safety focus, and not led to risk increases
 - Seismic risk will be included in new plant modeled core damage frequency prior to operation

Tabletop Exercises

- **Planned and conducted by NRC with stakeholder participation**
- **First: Licensing basis changes under Regulatory Guide 1.174**
 - Will soon complete
- **Next: Reactor Oversight Process**
 - Just beginning

Licensing Tabletops

- **May 4: Risk Informed Inservice Inspection**
- **May 26 and June 1: Risk Managed Technical Specifications Initiative 4B – Flexible Completion Times, and Maintenance Rule (a)(4) – Assessment and Management of Risk due to Maintenance Activities**
- **August 9: 10 CFR 50.69 and Ex Vessel Severe Accident Change Guidance**
- **October 5: Reg Guide 1.174 and LRF**



Tabletop Observations

- **Process was well thought out and effectively conducted**
- **Good stakeholder participation for both existing and new plant perspectives**
- **Scenarios and examples selected were reasonable, or noted when unrealistic**
- **Additional regulatory controls were identified beyond those directly in guidance**
- **NRC initial observations, as reported in meeting minutes, are reasonable**

Observations

- **Agree that in general, operational experience with new designs is necessary prior to implementing voluntary licensing applications**
- **However, some risk applications would be implemented at initial start up:**
 - **Maintenance Rule – monitoring and assessment and management of maintenance risk**
 - **Reactor Oversight Process – significance determination process, performance indicators**
- **Could the accommodations needed to support the mandatory uses of risk also provide for voluntary applications?**

Observations

- **Technical Specification Initiative 4B**
 - Agree that better definition of “safety function” would be useful
 - Would be willing to entertain dialogue on process improvements for guidance
 - Believe that RITS 4B should be strongly encouraged for new and operating plants
 - Provides better safety focus than Standard Tech Specs, and incentive for improved scope of PRA

Next Steps

- **Industry concurs with direction of SRM**
- **Industry believes tabletops were effective**
- **We do not substantively differ with NRC's preliminary conclusions**
- **Reactor Oversight Process could be more challenging**
- **Industry will continue strong participation in process**