

PMSTPCOL PEmails

From: Joseph, Stacy
Sent: Monday, November 28, 2011 1:23 PM
To: 'Price, John E'
Cc: STPCOL
Subject: Discussion Topic for ACSTIC2 Call on Wednesday

John,

Tom Tai asked that I send the following question to possibly be discussed during the Wednesday's (11/30) phone call.

“The calculation using ACSTIC2 performed by WEC has demonstrated matching frequency with K-6 measurement at about 20 Hz. Please demonstrate matching of amplitude to add confidence of the ACSTIC2 results. If the K-6 test conditions when the measurements were taken are not known, the calculated values can assume a nominal and worst case conditions to bound K-6 results.”

Please feel free to call me this week to discuss.

Stacy Joseph
Project Manager
U. S. Nuclear Regulatory Commission
Office of New Reactors
Division of New Reactor Licensing

(Office) 301-415-2849
Mail Stop T6-D04
Washington DC 20555-0001

Hearing Identifier: SouthTexas34Public_EX
Email Number: 3188

Mail Envelope Properties (BBC4D3C29CD0E64E9FD6CE1AF26D84D591FA67832A)

Subject: Discussion Topic for ACSTIC2 Call on Wednesday
Sent Date: 11/28/2011 1:23:21 PM
Received Date: 11/28/2011 1:23:21 PM
From: Joseph, Stacy

Created By: Stacy.Joseph@nrc.gov

Recipients:
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"Price, John E" <jeprice@STPEGS.COM>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	823	11/28/2011 1:23:21 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: