

ArevaEPRDCPEm Resource

From: WILLIFORD Dennis (AREVA) [Dennis.Williford@areva.com]
Sent: Thursday, December 01, 2011 3:31 PM
To: Tesfaye, Getachew
Cc: BENNETT Kathy (AREVA); DELANO Karen (AREVA); ROMINE Judy (AREVA); RYAN Tom (AREVA); GUCWA Len (EXTERNAL AREVA)
Subject: Response to U.S. EPR Design Certification Application RAI No. 523 (6157), FSAR Ch. 15
Attachments: RAI 523 Response US EPR DC.pdf

Getachew,

Attached please find AREVA NP Inc.'s response to the subject request for additional information (RAI). The attached file, "RAI 523 Response US EPR DC.pdf," provides a schedule since a technically correct and complete response to the one question cannot be provided at this time.

The following table indicates the respective pages in the response document, "RAI 523 Response US EPR DC.pdf," that contain AREVA NP's response to the subject question.

Question #	Start Page	End Page
RAI 523 — 15.06.05-115	2	2

A complete answer is not provided. The schedule for a technically correct and complete final response to this question is provided below.

Question #	Response Date
RAI 523 — 15.06.05-115	March 28, 2012

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B
Charlotte, NC 28262
Phone: 704-805-2223
Email: Dennis.Williford@areva.com

From: Tesfaye, Getachew [<mailto:Getachew.Tesfaye@nrc.gov>]
Sent: Thursday, November 03, 2011 7:09 PM
To: ZZ-DL-A-USEPR-DL
Cc: Lu, Shanlai; Forsaty, Fred; Donoghue, Joseph; Colaccino, Joseph; ArevaEPRDCPEm Resource
Subject: U.S. EPR Design Certification Application RAI No. 523 (6157), FSAR Ch. 15

Attached please find the subject request for additional information (RAI). A draft of the RAI was provided to you on October 28, 2011, and on November 3, 2011, you informed us that the RAI is clear and no further clarification is needed. As a result, no change is made to the draft RAI. The schedule we have established for review of your application assumes technically correct and complete responses within 30 days of receipt of

RAIs. For any RAIs that cannot be answered within 30 days, it is expected that a date for receipt of this information will be provided to the staff within the 30 day period so that the staff can assess how this information will impact the published schedule.

Thanks,
Getachew Tesfaye
Sr. Project Manager
NRO/DNRL/NARP
(301) 415-3361

Hearing Identifier: AREVA_EPR_DC_RAIs
Email Number: 3599

Mail Envelope Properties (2FBE1051AEB2E748A0F98DF9EEE5A5D49B613D)

Subject: Response to U.S. EPR Design Certification Application RAI No. 523 (6157),
FSAR Ch. 15
Sent Date: 12/1/2011 3:31:01 PM
Received Date: 12/1/2011 3:31:28 PM
From: WILLIFORD Dennis (AREVA)

Created By: Dennis.Williford@areva.com

Recipients:

"BENNETT Kathy (AREVA)" <Kathy.Bennett@areva.com>
Tracking Status: None
"DELANO Karen (AREVA)" <Karen.Delano@areva.com>
Tracking Status: None
"ROMINE Judy (AREVA)" <Judy.Romine@areva.com>
Tracking Status: None
"RYAN Tom (AREVA)" <Tom.Ryan@areva.com>
Tracking Status: None
"GUCWA Len (EXTERNAL AREVA)" <Len.Gucwa.ext@areva.com>
Tracking Status: None
"Tsfaye, Getachew" <Getachew.Tsfaye@nrc.gov>
Tracking Status: None

Post Office: auscharm02.adom.ad.corp

Files	Size	Date & Time
MESSAGE	2248	12/1/2011 3:31:28 PM
RAI 523 Response US EPR DC.pdf		56062

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Response to

Request for Additional Information No. 523

11/03/2011

U. S. EPR Standard Design Certification

AREVA NP Inc.

Docket No. 52-020

**SRP Section: 15.06.05 - Loss of Coolant Accidents Resulting From Spectrum of
Postulated Piping Breaks Within the Reactor Coolant Pressure Boundary**

Application Section: 15.06.05

QUESTIONS for Reactor System, Nuclear Performance and Code Review (SRSB)

Question 15.06.05-115:

- a. As part of EPR LOCA long term cooling evaluation, AREVA is planning to address the in-vessel downstream effect considering the accumulation of debris on the surface of the fuel rod surface. Demonstrate that, if a debris bed is developed and covers the fuel rod surface around the spacer grid, the localized heat transfer is still sufficient to maintain the fuel rod surface temperature below 800°F.
- b. In its original submittal of the strainer design technical report, AREVA assumed that the debris would not reach the reactor core until 900 seconds into the LOCA. Provide the basis of this assumption and demonstrate that the selection of 900 seconds to establish the acceptance criteria is conservative.

Response to Question 15.06.05-115:

A response to this question will be provided by March 28, 2012.