

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 ABWR Subcommittee: Open Session

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Tuesday, October 4, 2011

Work Order No.: NRC-1181

Pages 1-223

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION
3 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
4 (ACRS)

5 + + + + +

6 ABWR SUBCOMMITTEE

7 + + + + +

8 OPEN SESSION

9 + + + + +

10 TUESDAY,

11 OCTOBER 4, 2011

12 + + + + +

13 ROCKVILLE, MARYLAND

14 + + + + +

15 The Subcommittee convened at the Nuclear
16 Regulatory Commission, Two White Flint North, Room
17 T2B1, 11545 Rockville Pike, at 8:30 a.m., Said Abdel-
18 Khalik, Chairman, presiding.

19 SUBCOMMITTEE MEMBERS PRESENT:

20 SAID ABDEL-KHALIK, Chairman

21 J. SAM ARMIJO

22 DENNIS C. BLEY *

23 CHARLES H. BROWN, JR.

24 JOHN W. STETKAR

25 WILLIAM J. SHACK

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CONSULTANTS TO THE SUBCOMMITTEE PRESENT:

2 GRAHAM B. WALLIS

3
4 NRC STAFF PRESENT:

5 MAITRI BANERJEE, Designated Federal Official

6 GEORGE WUNDER

7 DINESH TANEJA

8 DONALD DUBE

9 ED FULLER

10 MARK TONACCI

11
12 ALSO PRESENT:

13 SCOTT HEAD

14 CAROLINE SCHLASEMAN

15 JIM TOMKINS

16 TIM ANDREYCHEK

17 MARTIN VAN HALTERN

18 STEVE THOMAS

19 TOM DALEY

20
21
22
23 * Present via telephone.

T-A-B-L-E O-F C-O-N-T-E-N-T-S

WELCOME/OPENING REMARKS:

Said Abdel-Khalik, Chair 5

NRO/NINA:

George Wunder, NRO 7

Scott Head, NINA 7

ACTION ITEM #98:

Caroline Schlaseman, MPR/TANE 8

ACTION ITEM #99:

Tim Andreychek, Westinghouse 62

ACTION ITEM #80:

Martin Van Haltern, Westinghouse 74

ACTION ITEM #47:

Scott Head, NINA 96

EXTENDED STATION BLACKOUT:

Steve Thomas, NINA 102

ABWR DESIGN FEATURES:

Coley Chappell, NINA 133

QUESTIONS: 140ACTION ITEMS #87, #101, #62 & #63 DISCUSSION:

Scott Head, NINA 141

Tom Daley, NINA, Action Item #87 141

OFFICE OF NEW REACTORS:

Don Dube 190

Comments/Discussion: 193

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24

T-A-B-L-E O-F C-O-N-T-E-N-T-S

ACTION ITEM #62:

Tom Daley, NINA 197

ACTION ITEM #63:

Tom Daley, NINA 207

ACTION ITEM #101:

Tom Daley, NINA 212

RECAP:

Scott Head, NINA 220

ADJOURN:

Said Abdel-Khalik, Chair 223

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

P-R-O-C-E-E-D-I-N-G-S

8:28 a.m.

CHAIR ABDEL-KHALIK: The meeting will now come to order. This is a meeting of the ABWR Subcommittee of the Advisory Committee on Reactor Safeguards. I'm Said Abdel-Khalik, Chairman of the Subcommittee.

ACRS Members in attendance are Charlie Brown, Bill Shack, Sam Armijo and John Stetkar.

Dennis Bley will also be joining us by phone.

MEMBER BLEY: I'm already here.

CHAIR ABDEL-KHALIK: Thank you, Dennis. Our consultant, Graham Wallis, is also in attendance. MS. Maitri Banerjee is the Designated Federal Official for this meeting.

As announced in the Federal Register on October 3rd, we are scheduled to discuss resolution of several issues raised during previous ABWR Subcommittee meetings.

Some of these issues relate to the long-term core cooling aspect of the staff Safety Evaluation Report on the COL Application submitted by the Nuclear Innovation North America for two ABWR units at their STP site in Texas.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The rules for participation in today's
2 meeting were announced in the Federal Register for an
3 open/closed meeting. Parts of this meeting will be
4 closed to the public to protect proprietary and
5 security-related information. I'm asking the NRC
6 staff and the applicant to verify that only people
7 with the required clearance and a need-to-know are
8 present before we enter in such discussions.

9 We have a telephone bridge line for the
10 public and stakeholders to hear the deliberations.
11 This line will not carry any signal from this end
12 during the closed portions of the meeting.

13 Also, to minimize disturbance, the line
14 will be kept in a listen-in-only mode until the end of
15 the meeting when time will be allocated for public
16 comments. At that time, any member of the public
17 attending this meeting in person or through the bridge
18 line can make a statement or provide comments, if they
19 desire.

20 As the meeting is being transcribed, I
21 request that participants in this meeting use the
22 microphones located throughout the room when
23 addressing the Subcommittee. Participants should
24 first identify themselves and speak with sufficient
25 clarity and volume, so that they can be readily heard.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 We will now proceed with the meeting and I
2 call upon Mr. George Wunder of NRO to begin the
3 presentation. George?

4 MR. WUNDER: Thank you, Mr. Chairman. We
5 have no introductory remarks for the staff and we
6 don't really have a planned staff presentation. It's
7 -- we would like to turn it over to you to, you know--

8 CHAIR ABDEL-KHALIK: Okay. At this time,
9 I would like to call on the applicant. Scott?

10 MR. HEAD: Thank you, Mr. Chairman.
11 Appreciate this opportunity to brief you on this
12 topic. And as George alluded to, we do have some open
13 items, follow-up items that we would like to discuss
14 with you today.

15 The presenters have all presented these
16 topics before to you and they will be involved again
17 today.

18 The agenda we would like to talk about, we
19 want to talk the action items that came out of the
20 June 21, 2011 meeting and then we want to review
21 Action Item #47(a) with respect to certain aspects of
22 that and the potential closure. And obviously, we
23 will be discussing our response to each item.

24 This morning we are going to talk about
25 Action Item #98, which is the Strainer Screen Loading

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 topic; Action Item #99 the Zinc Oxide Concentration,
2 some clarification there; Action Item #80 was pressure
3 drop vs. the relationship to the exponent; and then,
4 like I mentioned, #47 is an older one and it's a
5 Briefing on the Downstream Fuel Test and the Analysis.

6 We want to revisit that one if we can.

7 With that, I'm going to turn it over to
8 Caroline.

9 MS. SCHLASEMAN: Good morning. This is
10 Caroline Schlaseman with MRP Associates and
11 representing Toshiba. I'm addressing Action Item #98
12 and there are -- the action item is listed here on the
13 slide to address the modeling of perforated strainer
14 screen loading and also to provide evidence that there
15 will be no local damage due to the strainer pockets
16 due to the loads imposed during the hydrodynamic loads
17 of vent clearing, condensation bubble collapse and
18 condensation oscillation.

19 Next slide, please. This slide has a
20 brief recap of where we were and what I presented
21 during the June 21st meeting. And, basically, that
22 meeting addressed the entire methodology for how do
23 you determine the hydrodynamic loads on the cassette-
24 type strainer.

25 The hydrodynamic loads are defined by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Toshiba in accordance with the DCD-prescribed
2 methodology and those are included in the ASME Design
3 Specification.

4 The loads are then combined in accordance
5 with the DCD Tier 2 Table 9.8-12 and they are applied
6 to the Finite Element model of the strainer to
7 determine the stresses and the different elements of
8 the strainer, including the perforated sheets, the
9 flange plates and the internal ribs.

10 The resulting membrane, local membrane,
11 membrane + bending stresses are compared to ASME Code
12 allowable stresses in Section III for the Service
13 Levels A, B, C and D allowables for the limiting
14 combinations as applicable.

15 CONSULTANT WALLIS: Does the ASME Code
16 tell you what to do about perforated surfaces?

17 MS. SCHLASEMAN: We didn't discuss that
18 during the June 21, that's the main part of this
19 presentation, so I'm going to get to that on the next
20 slide.

21 CONSULTANT WALLIS: I just wondered, does
22 the ASME Code address that or does it just address
23 continuous --

24 MS. SCHLASEMAN: It does actually. The
25 methodology that we use is ASME Code. But I'm --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CONSULTANT WALLIS: And the ASME Code does
2 address perforated surfaces?

3 MS. SCHLASEMAN: Correct.

4 CONSULTANT WALLIS: Yes.

5 MS. SCHLASEMAN: There is an appendix, a
6 non-mandatory appendix that addresses --

7 CONSULTANT WALLIS: Okay.

8 MS. SCHLASEMAN: -- perforated plate.

9 CONSULTANT WALLIS: Okay.

10 MS. SCHLASEMAN: And then there is also an
11 ITAAC that is going to confirm that the ASME Code
12 Design Report exists for all the ASME components. And
13 we have chosen to -- even though these are not
14 pressure-retaining components, we have chosen to
15 designate them and N-stamp them in accordance with the
16 code. So, you know, our ECCS suction strainers are
17 going to have ASME Code Design Stress Report and will
18 be N-stamped in accordance with the code.

19 Next slide. So the second part, it's a
20 little backwards, but, because there were two
21 sentences in the question, the action item, the second
22 part of it was providing evidence that there is no
23 local damage due to the hydrodynamic loads.

24 And the proof ultimately, after running
25 through the methodology for developing the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hydrodynamic loads for doing the load combinations
2 comparing them with ASME service levels, stress
3 allowables, is going to be satisfied by showing that
4 the local membrane stresses in the perforated sheets
5 meet the ASME Code stress allowables.

6 The second part or excuse me, well, the
7 first part, the topic that I'm going to discuss this
8 morning is how then do we model the strainer pockets,
9 which are sheet metal and they have -- they are not --
10 they are metal sheets. In fact, I have brought with
11 me a sample that we are going to pass around.

12 And the -- when you see this, this is a
13 1.5 millimeter thick metal sheet and it has the holes
14 machined into it that are the same size as was used
15 for the referenced Japanese plant high-pressure core
16 flooders strainers. And so this is the same material
17 that is going to be used. This is 304 stainless steel
18 and the geometry is the same as will be used for the
19 STP 3 and 4 strainers, because they are identical to
20 the -- they are almost the same as the referenced
21 Japanese ABWR high-pressure core flutter and for RHR
22 also, a similar design.

23 He's gone, so --

24 CONSULTANT WALLIS: Well, there's another
25 part to this. It's not just ASME. I mean, you have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to determine the stresses by doing some fluid-
2 structure interaction analysis, right?

3 MS. SCHLASEMAN: The --

4 CONSULTANT WALLIS: And I'm not sure how
5 that is done.

6 MS. SCHLASEMAN: That was discussed in the
7 previous meeting.

8 CONSULTANT WALLIS: But it wasn't really--
9 there were no details really given.

10 MS. SCHLASEMAN: That's the --

11 CONSULTANT WALLIS: The question is --
12 these are perforated plates, they are not solid. I
13 think it's well-known what to do with solid surfaces,
14 but how --

15 MS. SCHLASEMAN: Right.

16 CONSULTANT WALLIS: -- do you treat solid
17 fluid --

18 MS. SCHLASEMAN: Perforated sheets.

19 CONSULTANT WALLIS: -- interaction when
20 there is a perforated surface?

21 MS. SCHLASEMAN: Okay.

22 CONSULTANT WALLIS: Are you going to test
23 discuss that or not?

24 MS. SCHLASEMAN: Yes. Yes. Well, here we
25 will see if there is any questions when I get through

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the end of this presentation.

2 CONSULTANT WALLIS: Okay. Sure.

3 MS. SCHLASEMAN: Obviously, it is -- when
4 you do the Finite Element Analysis, the individual
5 holes are not modeled.

6 CONSULTANT WALLIS: No.

7 MS. SCHLASEMAN: And so it's modeled as a
8 flat -- well, it's curved, but it's as a solid sheet.

9 ASME Code has a non-mandatory appendix, A-8000, which
10 provides the methodology for determining the -- how to
11 evaluate the stresses in the perforated sheet. And
12 because, like I said, the model will be a solid sheet.

13 Two parts of the methodology. The first
14 part is where you modify the elastic constants, the
15 Young's modulus and the Poisson's ratio, and that's to
16 make sure that you have an appropriate stress
17 distribution in your Finite Element model, which is a
18 solid model.

19 And then the second part is you go ahead
20 and you ratio the resulting stresses. You increase
21 them to account for the missing material.

22 CONSULTANT WALLIS: So E^*/E means that you
23 modify the effective modulus?

24 MS. SCHLASEMAN: That's correct.

25 CONSULTANT WALLIS: Because of the holes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. SCHLASEMAN: That's correct. So
2 instead of being about 30 million psi, it's like about
3 nine million psi.

4 CONSULTANT WALLIS: So it's considerably
5 less. It's more --

6 MS. SCHLASEMAN: Correct.

7 CONSULTANT WALLIS: -- stretchy.

8 MS. SCHLASEMAN: Yes, because it's a
9 weaker plate.

10 MEMBER SHACK: Yes, you change the
11 modulus, so you get the displacements right and then
12 you --

13 CONSULTANT WALLIS: But then you have
14 got --

15 MEMBER SHACK: -- adjust the stresses.

16 CONSULTANT WALLIS: Right. And then you
17 presumably get stress concentrations in this matrix,
18 too, of some sort. Yes, okay.

19 MS. SCHLASEMAN: So then you end up
20 increasing the stresses from the Finite Element model
21 by almost a factor of three. Are we okay on the --

22 CONSULTANT WALLIS: What do you do about
23 flaws created in the --

24 MS. SCHLASEMAN: -- method?

25 CONSULTANT WALLIS: -- manufacture of this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 thing? How is this made? How is this strainer made?

2 MS. SCHLASEMAN: It's machined.

3 CONSULTANT WALLIS: And when they punch
4 holes, do they make flaws around the circumference of
5 the holes?

6 MS. SCHLASEMAN: It's an ASME Code.

7 CONSULTANT WALLIS: Well --

8 MS. SCHLASEMAN: It's a -- the QA program
9 for CCI has to confirm that the --

10 CONSULTANT WALLIS: With no flaws?

11 MS. SCHLASEMAN: -- plate meets the spec.

12 CONSULTANT WALLIS: Does the ASME tell you
13 anything about how to treat flaws in this material?

14 MS. SCHLASEMAN: No.

15 CONSULTANT WALLIS: So it's assumed there
16 aren't any?

17 MEMBER SHACK: It's 304, so it's --

18 CONSULTANT WALLIS: Right.

19 MEMBER SHACK: -- this is about as flaw-
20 tolerant as a material gets.

21 CONSULTANT WALLIS: It's how they make it,
22 isn't it? How they make it. If they make it brutally
23 -- how do they make it? They punch these holes?

24 MEMBER ARMIJO: No, they are drilled, it
25 looks like.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CONSULTANT WALLIS: The holes?

2 MEMBER SHACK: No, I'm sure they are
3 machined.

4 CONSULTANT WALLIS: Machine them.

5 MS. SCHLASEMAN: Machined.

6 CONSULTANT WALLIS: They are machined.
7 Well, these guys have burrs on them.

8 MS. SCHLASEMAN: Well, the one side.

9 MEMBER ARMIJO: Yes.

10 MS. SCHLASEMAN: It's --

11 CONSULTANT WALLIS: Okay.

12 MS. SCHLASEMAN: -- rough.

13 CONSULTANT WALLIS: I'm just trying to
14 cover the basis here.

15 MS. SCHLASEMAN: Yes.

16 CONSULTANT WALLIS: Okay.

17 MR. TOMKINS: Next slide?

18 MS. SCHLASEMAN: Next slide. The
19 methodology in the ASME Code lists five criteria for
20 what the geometry and the other considerations that
21 apply to using this methodology.

22 The fifth criterion is a criterion that
23 the plate thickness to the hole ratio has to be a
24 ratio of 2 and our thickness is about a half. And so,
25 you know, we went back to CCI on whether or not -- how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 they had confirmed that this methodology was
2 appropriate for metal sheet as opposed to tube sheet
3 like for a heat exchanger. The thick plate that the
4 ASME Code, without any further justification, you
5 would be able to use if you met the tube criterion.

6 So their response is, obviously, this came
7 up in the past, this came up for the referenced
8 Japanese plant and Toshiba had pressed them on this
9 point to find out, you know, why this methodology is
10 appropriate to use for the metal sheet.

11 And they -- and in addition to that, there
12 are reports on the testing work that was done to
13 originally confirm this methodology to set what the
14 changes to the elastic constants are. There is a
15 variability in how the material -- in how the
16 perforated plates perform after you get below that
17 ratio of 2 and then the transition region and then
18 where the sheets are.

19 And so at the sheets, this methodology
20 does apply and that was confirmed by going to the
21 methodology, this Handbook for Perforated Metals.
22 It's based on testing by William O'Donnell that is
23 also the basis for the ASME Code methodology. And
24 then in addition to that, CCI did some testing to
25 confirm that the use of this methodology would be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 appropriate, that there wouldn't be something
2 unexpected for use in this ASME methodology.

3 In other words, if you go ahead and prove
4 to yourself analytically that there should be no
5 deformation, they went back and tested to confirm that
6 there would be no damage to the sheets using this
7 methodology, that it would pass code.

8 So the testing that they did, it's based
9 on multiples of the maximum stress that was defined
10 for the referenced Japanese plant. And that that
11 reference -- excuse me. The limiting load combination
12 for the referenced plant is about half a bar, that's
13 7.25 psi, and that's due to a hydrodynamic load
14 combination of chugging plus SRV plus the --

15 CONSULTANT WALLIS: How do you apply this
16 pressure?

17 MS. SCHLASEMAN: It's a --

18 CONSULTANT WALLIS: How do you apply a
19 pressure to a porous surface? I don't quite
20 understand.

21 MR. HEAD: We will show you in just a
22 second.

23 MS. SCHLASEMAN: It's a -- oh, the test?

24 MR. HEAD: Yes.

25 MS. SCHLASEMAN: Well, okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HEAD: We will show you that in just a
2 second.

3 CONSULTANT WALLIS: Okay.

4 MS. SCHLASEMAN: And then it is tested for
5 six different cycles. They start with twice that
6 pressure and then they go to multiples up to four
7 times that pressure. And then the next slide is an
8 example of the figure that they sent us from their
9 test.

10 So the red -- the first cycle is running
11 up to two times what the maximum loading condition
12 would be on the referenced Japanese strainer for the
13 worst case limiting load combination.

14 And then they go and do increased
15 multiples after that. And, basically, what they
16 showed us -- what they told us, even though there
17 seems to be a very, very slight delta between the
18 initial start point of the test and then the final on
19 the red line, but they said, basically, there was zero
20 deformation at --

21 CONSULTANT WALLIS: What is this loop
22 then? Why doesn't it go back the way it came?

23 MS. SCHLASEMAN: Because --

24 CONSULTANT WALLIS: If there is no
25 deformation?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HEAD: There is some deformation.

2 CONSULTANT WALLIS: Must be.

3 MR. HEAD: There is for the higher
4 pressure.

5 MS. SCHLASEMAN: It's very, very small.

6 CONSULTANT WALLIS: They take it up to the
7 point where it yields and then they bring it back.

8 MR. HEAD: Right.

9 CONSULTANT WALLIS: That's --

10 MS. SCHLASEMAN: Well, they are beyond
11 yield.

12 MR. HEAD: Yes.

13 CONSULTANT WALLIS: So saying there is no
14 deformation is not true.

15 MR. HEAD: That's at the --

16 MS. SCHLASEMAN: It's --

17 MR. HEAD: -- higher pressures.

18 MS. SCHLASEMAN: No. Well --

19 CONSULTANT WALLIS: Well, no. I see a
20 yield envelope --

21 MS. SCHLASEMAN: From the first level.

22 CONSULTANT WALLIS: -- or something up
23 there, don't I? Am I misunderstanding?

24 MS. SCHLASEMAN: Are you talking about the
25 red line?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CONSULTANT WALLIS: Any of them.

2 MS. SCHLASEMAN: Or the other ones?

3 CONSULTANT WALLIS: They go up.

4 MS. SCHLASEMAN: Yes.

5 CONSULTANT WALLIS: They bend and they
6 come back a different line.

7 MS. SCHLASEMAN: That's correct.

8 CONSULTANT WALLIS: So they are deformed.

9 MS. SCHLASEMAN: And so you are in the in
10 elastic range when you are up over -- you know, when
11 you are past the one bar.

12 CONSULTANT WALLIS: The orange one, the
13 first ones don't do much.

14 MR. HEAD: Right.

15 MS. SCHLASEMAN: Right.

16 CONSULTANT WALLIS: Okay. So there is
17 sort of a yield surface or something up there or
18 whatever.

19 MS. SCHLASEMAN: Well, you are at four
20 times the design pressure when you are out on the
21 cycle 5, the purple curve and then --

22 CONSULTANT WALLIS: I'm just trying to
23 understand what is happening.

24 MS. SCHLASEMAN: -- you are more than
25 that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TOMKINS: And that yield for the worst
2 case is 1 millimeter.

3 CONSULTANT WALLIS: I understand. What is
4 yielding? Is it yielding and bending or what? Which
5 way is it yielding? You have to show me the test,
6 because 1 millimeter doesn't mean anything unless I
7 know 1 millimeter of what.

8 MS. SCHLASEMAN: Well, this is -- the
9 purpose of this test is to confirm whether or not the
10 application of the ASME Code methodology --

11 CONSULTANT WALLIS: But what is the test?

12 MS. SCHLASEMAN: -- makes sense.

13 CONSULTANT WALLIS: I don't understand the
14 test.

15 MS. SCHLASEMAN: Go to the next slide. Go
16 ahead.

17 CHAIR ABDEL-KHALIK: Before you go, what
18 is the displacement in this graph? How is that
19 defined? Is it global displacement to the plate or
20 maximum displacement at the midpoint or differential
21 displacement between holes or what -- how is
22 displacement defined?

23 MS. SCHLASEMAN: I do not know. I did not
24 find out what -- where their strain gauges were
25 measured on this test, so I'm not sure. I would have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to ask CCI.

2 CHAIR ABDEL-KHALIK: Well, if you show us
3 whether -- the sample how it was tested and whether it
4 is bending, you know, we will be able to figure that
5 out. I just --

6 MS. SCHLASEMAN: Well --

7 CHAIR ABDEL-KHALIK: It's not -- it
8 doesn't -- it's probably not a tensile test, right?

9 MS. SCHLASEMAN: We're going to show you
10 in a minute.

11 CHAIR ABDEL-KHALIK: Okay.

12 MS. SCHLASEMAN: No, it's an internal
13 pressure test. Go ahead.

14 CHAIR ABDEL-KHALIK: Concepts.

15 MS. SCHLASEMAN: Okay. That's just the
16 pocket element.

17 CHAIR ABDEL-KHALIK: Yes.

18 MS. SCHLASEMAN: And the dimples that you
19 are seeing in it are machined in. Those are what they
20 call bowls and those are just to make the plate --

21 CONSULTANT WALLIS: How do you apply a
22 pressure to it and what do you mean by --

23 MR. HEAD: Here it is.

24 CONSULTANT WALLIS: -- displacement?

25 MS. SCHLASEMAN: Here it is.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR ABDEL-KHALIK: Okay.

2 MS. SCHLASEMAN: Okay. So what they do is
3 they go ahead and this is a pocket --

4 CONSULTANT WALLIS: Yes.

5 MS. SCHLASEMAN: -- from a strainer.

6 CONSULTANT WALLIS: Yes.

7 MS. SCHLASEMAN: There is solid plates on
8 either side on the near side to you. There is a very
9 little sliver of the perforated sheet that you can see
10 on the front right corner, edged surface, vertical
11 surface. Thank you, Tim.

12 MR. ANDREYCHEK: Yes.

13 CONSULTANT WALLIS: Just a sliver of the
14 perforated?

15 MS. SCHLASEMAN: No, you can only see it.

16 MEMBER SHACK: It's from the --

17 MS. SCHLASEMAN: It goes all the way
18 through.

19 MR. ANDREYCHEK: It is basically two
20 parallel plates with the pocket that we saw on the
21 previous slide inside the tabs that you saw on the
22 edge --

23 MR. HEAD: See that shape?

24 MR. ANDREYCHEK: -- are actually the tabs
25 sticking out along here. So you, basically, have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 solid surface on either side with perforated in the
2 middle like a U as it were or a V.

3 CONSULTANT WALLIS: Yes.

4 MR. ANDREYCHEK: Supply water comes in
5 here and so you pressurize the inside.

6 CONSULTANT WALLIS: And the water flows
7 through the holes?

8 MR. ANDREYCHEK: That's correct.

9 CHAIR ABDEL-KHALIK: So these are solid?

10 MR. ANDREYCHEK: That's correct.

11 CONSULTANT WALLIS: So it's a static test?

12 MS. SCHLASEMAN: Correct.

13 CONSULTANT WALLIS: So you just pump -- as
14 the pressure drops through the holes, it creates the
15 fault?

16 MS. SCHLASEMAN: Yes.

17 CONSULTANT WALLIS: And then how do you
18 measure displacement?

19 MS. SCHLASEMAN: That's --

20 CONSULTANT WALLIS: You don't know?

21 MS. SCHLASEMAN: -- the part I'm not sure
22 where their gauges are located. I couldn't see it
23 from this photo and I should have asked.

24 MEMBER SHACK: It's probably an LVDT
25 sticking off to the side there, so I'm sort of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 guessing that they are measuring the deflection in the
2 middle of the plate, would be my --

3 MS. SCHLASEMAN: Yes.

4 CHAIR ABDEL-KHALIK: Expected to be the
5 maximum.

6 MEMBER STETKAR: Given that's the only
7 other connection.

8 MS. SCHLASEMAN: I don't know. I mean,
9 it's an instrument. I mean, it's clearly an
10 instrument that is measured, because you can't measure
11 -- I mean, 1 millimeter is just too tiny.

12 CHAIR ABDEL-KHALIK: I mean, given the
13 fact that some of these displacements are several
14 millimeters, they are about an eighth of an inch,
15 which is twice as thick as -- twice as much as the
16 thickness of the plate. I would assume that this is
17 sort of a midpoint deflection or something, rather
18 than local deformation.

19 MS. SCHLASEMAN: Oh, you mean, during the
20 test? Correct.

21 CHAIR ABDEL-KHALIK: Right.

22 MS. SCHLASEMAN: Yes.

23 MEMBER SHACK: Is this the dimension of
24 an actual pocket or is this just a -- this is just set
25 up to verify the analytical model or is this the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 actual dimensions of a pocket?

2 MS. SCHLASEMAN: This would be
3 representative. The pockets come in different sizes.

4 Like for the RHR strainer and the high-pressure core
5 flooder strainer, they are different sizes, because
6 the overall dimensions of the strainers are different.

7 But I would say that this is comparable or it is
8 typical of the size of a standard pocket.

9 MR. TOMKINS: And this is really only
10 designed to make sure that the way we are accounting
11 for the holes is valid.

12 MS. SCHLASEMAN: Right.

13 MR. TOMKINS: Really the purpose of this
14 test.

15 CONSULTANT WALLIS: So do you know how the
16 pocket is made? In the pocket, you have to take this
17 stuff, you have to cut it, you have to bend it, you
18 have to weld it or something. There is all kinds of
19 things that could fail, presumably. Are there welds
20 in there or what? I'm just wondering how
21 representative this is of a real pocket.

22 MS. SCHLASEMAN: The --

23 MR. HEAD: The purpose of this test is to
24 confirm --

25 MS. SCHLASEMAN: That the methodology for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 confirming that the stresses in the holes --

2 CONSULTANT WALLIS: The effect of E and
3 all that stuff.

4 MS. SCHLASEMAN: Right.

5 MR. TOMKINS: Yes.

6 CONSULTANT WALLIS: Yes, okay.

7 MS. SCHLASEMAN: And then your
8 amplification of the stresses to account for the
9 missing hole material.

10 CONSULTANT WALLIS: And then the stress
11 analysis of the pocket is a separate thing?

12 MR. TOMKINS: Yes.

13 MS. SCHLASEMAN: Yes.

14 MEMBER SHACK: Well, in this case, it's
15 really to verify that your departure from the ASME
16 Code isn't really --

17 MS. SCHLASEMAN: Yes, yes.

18 MEMBER SHACK: -- causing the problem
19 here.

20 MR. TOMKINS: Right.

21 MS. SCHLASEMAN: Right. It's the --

22 MR. HEAD: Because it's thinner.

23 MS. SCHLASEMAN: -- the methodology is
24 valid.

25 MR. HEAD: It's thinner than what is in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the code.

2 CHAIR ABDEL-KHALIK: That's in the code?

3 MS. SCHLASEMAN: Right.

4 CONSULTANT WALLIS: This is a static test.

5 Now, condensation oscillations and condensation is a
6 big boom.

7 MS. SCHLASEMAN: Right.

8 CONSULTANT WALLIS: A big bubble collapse
9 and a wave goes out.

10 MS. SCHLASEMAN: Yes.

11 CONSULTANT WALLIS: And a wave hits this
12 and water squirts through in a transient. A very
13 quick squirt through the hole. That's quite different
14 from your test, which is a static test.

15 MS. SCHLASEMAN: Right. And those are
16 accounted for in the dynamic load factors.

17 CONSULTANT WALLIS: That's taken care of
18 in some other analysis?

19 MS. SCHLASEMAN: Right. It's the initial
20 loading to --

21 CONSULTANT WALLIS: I have never seen --

22 MS. SCHLASEMAN: It's --

23 MR. HEAD: And it's hitting a plate.

24 CONSULTANT WALLIS: You talked about it
25 last time.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MS. SCHLASEMAN: It's in the report. It's
2 in the design specification and in the ASME. Well,
3 it's not an ASME Code. It's a JSME Code, but the
4 stress report that CCI did for the RHR strainer for
5 the referenced Japanese plant.

6 CONSULTANT WALLIS: RHR.

7 MR. TOMKINS: And that methodology is in
8 the DCD and is approved and they follow that
9 methodology.

10 CONSULTANT WALLIS: The standard
11 methodology of some sort?

12 MS. SCHLASEMAN: Well, it was developed --

13 CONSULTANT WALLIS: That was one of my
14 curiosities last time that you are not going to answer
15 this time. So I have to -- I never got that. I never
16 got that.

17 MS. SCHLASEMAN: Which one?

18 CONSULTANT WALLIS: The one that defines
19 how they handle the transient load. I mean, the wave
20 comes along and hits this, you know.

21 MS. SCHLASEMAN: The design specifications
22 for the strainers.

23 CONSULTANT WALLIS: So --

24 MS. SCHLASEMAN: Each of the loads -- each
25 of the hydrodynamic loads has a different methodology

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for establishing what it is. And it also is developed
2 and presented in a different format.

3 CONSULTANT WALLIS: Okay.

4 MS. SCHLASEMAN: Some are time dependent,
5 some are not.

6 CONSULTANT WALLIS: So did your lines that
7 you showed in this graph verify the E^* that you
8 calculated?

9 MS. SCHLASEMAN: No.

10 CONSULTANT WALLIS: They didn't?

11 MS. SCHLASEMAN: These lines verify that
12 it is appropriate to use the ASME methodology.

13 CONSULTANT WALLIS: Well, where is the
14 comparison with the ASME methodology? The ASME says
15 calculate E^* .

16 MS. SCHLASEMAN: Right.

17 CONSULTANT WALLIS: Calculate ν^* and then
18 do an analysis. And I didn't see you verified
19 anything until you've done that.

20 MS. SCHLASEMAN: The -- this test was to--
21 like I said, CCI had two parts to their approach to
22 answering Toshiba's questions about whether or not
23 since the ASME fifth criterion was not met, the
24 geometry for the plate thickness was not met. How is
25 it acceptable to use the ASME methodology, which is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 where you define there is a lot of test data that goes
2 into defining --

3 CONSULTANT WALLIS: So what's the
4 criterion for acceptability that is verified by this
5 graph?

6 MS. SCHLASEMAN: The way this graph
7 assures that it makes sense, that it's appropriate, is
8 that the -- in the stress analysis report that CCI did
9 for the referenced plant, they concluded that the JSME
10 -- ASME is -- actually, it's slightly more
11 conservative than ASME, but that the stress criteria
12 for membrane plus bending, local membrane stresses,
13 the criteria were met for this geometry for the
14 maximum worst case pressure loading.

15 CONSULTANT WALLIS: And so what are the
16 criteria? And why does this graph meet them?

17 MS. SCHLASEMAN: I'm trying to explain
18 that.

19 CONSULTANT WALLIS: Okay.

20 MS. SCHLASEMAN: The -- so by proving that
21 you meet the stress allowables in the JSME Code and
22 the maximum stress that was evaluated was half a bar,
23 so that's the peak load. That's the worst case load
24 including all the hydrodynamic load factors. And then
25 they ran a test to confirm that if you went to twice

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that value, you still stay within the elastic range.

2 CONSULTANT WALLIS: You don't.

3 MS. SCHLASEMAN: You have no permanent
4 deformation, that's the one bar. And then to go ahead
5 and check further, they went out and they went to four
6 times that and, again, no damage to the perforated
7 plate.

8 CONSULTANT WALLIS: So you are proving
9 that they are within the elastic range? That's what
10 you are proving? You are not verifying an E* or a nu*
11 or any of those things?

12 MS. SCHLASEMAN: That's correct.

13 CONSULTANT WALLIS: Just proving it's in
14 the elastic range, okay.

15 MS. SCHLASEMAN: Yes.

16 MEMBER ARMIJO: But wouldn't that be
17 confirmed only if you can adequately or exactly
18 duplicate the boundary conditions?

19 MS. SCHLASEMAN: The geometric boundary
20 conditions?

21 MEMBER ARMIJO: Correct.

22 MS. SCHLASEMAN: Well, the geometric
23 boundary conditions, this test is a pocket. That is a
24 representative pocket.

25 MEMBER ARMIJO: But --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. SCHLASEMAN: It is the right geometry.

2 MEMBER ARMIJO: But, you know, the exact
3 way in which supported?

4 MS. SCHLASEMAN: That is how it's
5 supported. It's supported -- the perforated plate is
6 supported continuously by the tabs along its -- you
7 know, it's a U-shaped piece. And it is supported on
8 either side by the plates that are part of the
9 strainer overall structure.

10 And so the tabs then put into those
11 plates, so it is continuously supported along this
12 edge as shown in this test. And then that's
13 consistent also with the analytical model, the Finite
14 Element Analysis.

15 CONSULTANT WALLIS: And this bounds with--

16 MEMBER SHACK: When I saw the pictures of
17 this, I always assumed those pockets were perforated
18 on all sides. You are telling me that it is really
19 two solid plates and a porous U? Which comes back to
20 Said's question of whether this is really totally
21 representative of the geometry.

22 CONSULTANT WALLIS: They are perforated on
23 the sides. They are perforated on all sides.

24 MS. SCHLASEMAN: They are perforated.

25 MEMBER SHACK: That's -- yes, that's sort

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of --

2 MS. SCHLASEMAN: But for the test, they
3 didn't use the side plates. That's correct, they are
4 perforated on the sides. But in this test fixture,
5 they did not do it that way.

6 MEMBER SHACK: So to answer Said's
7 question, this is really --

8 MS. SCHLASEMAN: Right.

9 MEMBER SHACK: -- representative of the
10 real situation only if you size that solid plate the
11 right amount to, essentially, represent --

12 MS. SCHLASEMAN: By plate. That's
13 correct.

14 MEMBER SHACK: -- the same stiffness as
15 you would get for the perforated plate, which we don't
16 know whether they did or didn't.

17 CONSULTANT WALLIS: Right.

18 MS. SCHLASEMAN: Yes.

19 CONSULTANT WALLIS: But it's also a
20 question of how you -- what you did with these tabs.
21 I mean, this thing is fixed to the other plate with
22 these tabs.

23 MS. SCHLASEMAN: Yes.

24 MEMBER ARMIJO: Well, let's give her a
25 chance to answer that first question.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MS. SCHLASEMAN: The first question, like
2 I said, these are going up to twice and up to four
3 times the multiple of the allowed stresses. The
4 question about whether or not -- but --

5 MEMBER ARMIJO: The deformations and the
6 stress levels that you would get are highly dependent
7 on the geometric boundary conditions. And you are
8 using this data to say we take it all the way to four
9 times what the expected load is going to be and
10 nothing happened. And well, this is a different
11 problem.

12 MS. SCHLASEMAN: But I think considering
13 how the -- if the plates were -- on the side had been
14 the perforated sheets, and, obviously, they would be
15 weaker, I mean, surely they would be weaker, but
16 because of the way you are loading it, you are loading
17 it like a membrane. And so I'm still thinking that
18 the load -- you know, the question about the holes
19 tearing open and the pockets -- I mean, that was your
20 original question about whether or not the pockets
21 would tear open, and I'm not seeing how it would
22 necessarily tear open differently.

23 MR. TOMKINS: Remember, this is to
24 simulate --

25 MS. SCHLASEMAN: This is --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. TOMKINS: This is to determine whether
2 how we are accounting for the holes was done properly,
3 not to necessarily simulate the exact geometry of the
4 pocket.

5 CHAIR ABDEL-KHALIK: No, no. This
6 experiment is aimed at sort of assuring that despite
7 the fact that the geometry does not meet a criterion
8 stipulated --

9 MS. SCHLASEMAN: A criterion.

10 CHAIR ABDEL-KHALIK: -- in the ASME Code--

11 MS. SCHLASEMAN: Correct.

12 CHAIR ABDEL-KHALIK: -- that the
13 methodology is still applicable.

14 MS. SCHLASEMAN: Right.

15 CHAIR ABDEL-KHALIK: And you have done
16 that by empirically demonstrating that even if you go
17 to four times the load, nothing bad happens.

18 MS. SCHLASEMAN: Yes.

19 CHAIR ABDEL-KHALIK: And this can only be
20 true or, you know, you can make that deduction if the
21 experiment that you are running truly simulates what
22 actually happens. And that is not the case here.

23 MS. SCHLASEMAN: But --

24 CHAIR ABDEL-KHALIK: So --

25 MS. SCHLASEMAN: -- if you are concerned

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 about opening up the holes themselves in the middle of
2 the plate, and I agree with Dr. Shack that that is,
3 you know, LVDT coming out the back side in the center
4 of the plate. I'm not seeing how, even if you had a
5 more flexible boundary condition on the outer edges,
6 that that would be significantly different in the
7 middle of the plate.

8 MEMBER SHACK: Well, I think what Said--

9 UNIDENTIFIED SPEAKER: It would be less.

10 MEMBER SHACK: -- is saying is, you know,
11 if you did this test and you predicted a certain
12 behavior and you verified it, that would verify the
13 model. That would be fine. If the comparison we're
14 hearing from you is, you know, the load on the real
15 thing is a half a psi --

16 MS. SCHLASEMAN: Yes.

17 MEMBER SHACK: -- and now we have gone to
18 double that and it's still elastic, well, that
19 comparison is only true if this is really
20 representative of the real structure.

21 MR. TOMKINS: Correct.

22 MEMBER SHACK: So, you know, I can
23 understand an argument saying, you know, we did an
24 analysis of this thing using our model and it worked,
25 that would be one comparison, but the comparison that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we are hearing doesn't quite get there, because you --
2 really that comparison sort of requires you to be semi
3 prototypical in the structure. And you are -- as I
4 said, you could size those plates if the thickness --
5 you know, but we haven't heard that those thicknesses
6 are really --

7 CHAIR ABDEL-KHALIK: Matter.

8 MEMBER SHACK: -- sized to represent a
9 perforated plate. I mean, there is various ways this
10 could have been done, but the argument -- until you
11 somehow convince us that this is a prototypical
12 structure or that you have done the analysis of the
13 structure and compared it, it just isn't all coming
14 together.

15 CONSULTANT WALLIS: Well, there is also
16 the tabs. I mean, it could fail where -- along the
17 tabs, couldn't it? It's got these tabs on the side.

18 MS. SCHLASEMAN: Right.

19 CONSULTANT WALLIS: And I don't know how
20 the real structure is, but the tabs --

21 MS. SCHLASEMAN: But that is handled by,
22 you know, Finite Element techniques. I mean, that's
23 the standard. There is no perforations in the tabs.

24 CONSULTANT WALLIS: Can this be a side
25 load? I mean, the wave comes along and it propagates

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 down the pocket, doesn't it? I mean, does it know the
2 pocket all at the same time? I don't quite know what
3 happens. But there is a pressure wave that comes
4 along --

5 MS. SCHLASEMAN: Yes.

6 CONSULTANT WALLIS: -- and it, presumably,
7 progresses down the pocket and the reflections and
8 things.

9 MS. SCHLASEMAN: Yes.

10 CONSULTANT WALLIS: I just don't know how
11 you have handled that. This isn't a dynamic test.

12 MS. SCHLASEMAN: This is the load factors
13 that are in the load to come up with a half bar on
14 this.

15 CHAIR ABDEL-KHALIK: Let's again give you
16 a chance to answer this practicality question.

17 MS. SCHLASEMAN: This is the test that CCI
18 ran. I don't have an answer for you on that.

19 CHAIR ABDEL-KHALIK: Because, I mean,
20 there is no telling what the deformation would be if
21 the geometry was different, right?

22 MS. SCHLASEMAN: Not that it --

23 CHAIR ABDEL-KHALIK: I mean, if --

24 MS. SCHLASEMAN: -- wouldn't be grossly
25 different. The geometry would be different because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the -- I agree that the edge condition at the tab --

2 CHAIR ABDEL-KHALIK: Right.

3 MS. SCHLASEMAN: -- could be more
4 flexible.

5 CHAIR ABDEL-KHALIK: Right.

6 MS. SCHLASEMAN: Than it is with the solid
7 plate.

8 CHAIR ABDEL-KHALIK: Correct.

9 MS. SCHLASEMAN: And so --

10 CHAIR ABDEL-KHALIK: Wouldn't that impact
11 the total deformation?

12 MS. SCHLASEMAN: The permanent set in the
13 plate?

14 CHAIR ABDEL-KHALIK: Well, if the
15 structure --

16 MS. SCHLASEMAN: Like I agree with you
17 that it potentially could on the first curve, you
18 know, where the plots are.

19 CHAIR ABDEL-KHALIK: Right.

20 MS. SCHLASEMAN: They could go to a higher
21 displacement.

22 CHAIR ABDEL-KHALIK: Correct.

23 MS. SCHLASEMAN: And then potentially you
24 would have a higher, because it's a stretch and it
25 would stretch, I would think. But as far as a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 permanent set, I don't know how much more deformation
2 there would be in terms of permanent deformation.

3 I mean, it could be, sure. But again, we
4 are not going into that regime in the real ASME Code
5 space.

6 CHAIR ABDEL-KHALIK: You are not going
7 into that regime in this experiment. But we don't
8 know if that is the case in the actual --

9 MS. SCHLASEMAN: No, I mean, the four
10 times the load.

11 CHAIR ABDEL-KHALIK: -- geometry.

12 MS. SCHLASEMAN: I meant that the loading
13 condition is -- were not going to be going to four
14 times the loading condition.

15 CHAIR ABDEL-KHALIK: I agree, but we don't
16 know what the behavior is. If you were to design an
17 experiment that is prototypical, that is consistent
18 with the actual geometry and boundary conditions, we
19 don't know what the behavior is going to be at .5 psi
20 -- .5 bar loading, do we?

21 MS. SCHLASEMAN: No, they did not run it
22 at .5.

23 CHAIR ABDEL-KHALIK: We don't know what
24 the behavior is going to be at .1 bar loading, do we?

25 MS. SCHLASEMAN: Oh, um, as far as -- it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 -- correct. As far as we haven't tested a specific
2 pocket.

3 CHAIR ABDEL-KHALIK: That is the point.

4 MS. SCHLASEMAN: But there were two parts
5 to this. One was CCI wanted to figure out whether or
6 not this was a standard and valid approach for using
7 the ASME methodology for changing the elastic
8 constants, adjusting the elastic constants. And then
9 multiplying to account -- the final stress to account
10 for the missing mass of the holes.

11 And their first thing was to go back and
12 look at what the designer handbook that is standard
13 for them and for all manufacturers of perforated
14 sheets and they concluded that that methodology,
15 again, also based on testing by Bill O'Donnell decades
16 ago probably, is consistent for thin sheets, not just
17 the thick sheet that ASME Code put into their
18 appendix.

19 And so, you know, they -- their approach
20 is that they have these two different ways of
21 confirming that this is an acceptable approach to
22 account for the holes in the sheet and to properly
23 model them analytically. And this is not -- you know,
24 this test was done as an added assurance that using
25 ASME Code methodology would result in a design that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 would not --

2 CHAIR ABDEL-KHALIK: Well, what you're
3 telling us is that you are really using the designer's
4 handbook methodology, at this point.

5 MS. SCHLASEMAN: Well, that's what CCI
6 did.

7 CHAIR ABDEL-KHALIK: It doesn't meet the
8 code.

9 MS. SCHLASEMAN: It --

10 CHAIR ABDEL-KHALIK: But it does, in fact,
11 meet --

12 MS. SCHLASEMAN: Correct.

13 CHAIR ABDEL-KHALIK: -- the designer's
14 handbook.

15 MS. SCHLASEMAN: Well, it's a non-
16 mandatory appendix. The ASME is not -- it's not that
17 they are not meeting code, it's this is a detail that
18 ASME does not mandate how you design for perforated
19 holes. And so they have this guidance available to
20 you for an appropriate methodology that they would
21 accept no questions asked if you met the thickness
22 criterion.

23 But we don't meet the thickness criterion,
24 so then, you know, the next question is is this an
25 appropriate methodology for the designer to use to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 establish whether or not, you know, what the stresses
2 are that should be compared with the ASME allowables.

3 And so CCI, to back up that this was an
4 appropriate methodology, used the designer handbook
5 that they put in here as a reference, and then that
6 wasn't sufficient for Toshiba. They wanted some more
7 proof or more assurance, not proof, more assurance
8 that this was an acceptable approach.

9 And so then CCI did this test. And,
10 obviously, there is questions about whether or not it
11 was exactly a prototypical strainer pocket was not
12 addressed at that time. This test was selected.

13 MEMBER ARMIJO: Well, it looks like the
14 test confirmed what they wanted to confirm, but it
15 didn't tell us whether a prototypical pocket,
16 completely prototypical, would behave the same way,
17 because they didn't test it. And that's really the
18 question that is in front of us, you know.

19 MR. HEAD: The test confirmed what we
20 would have expected with the prototypical --

21 MEMBER ARMIJO: Yes, they made sure that
22 the deformation would occur in the perforated region,
23 so the sides were not perforated, they were beefy and
24 they measured what they intended to measure. It seems
25 to me that was successful, but it doesn't tell us what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the real structure will do.

2 MS. SCHLASEMAN: Well, depending on the
3 Finite Element Analysis.

4 MR. HEAD: You run through the analysis.

5 MEMBER ARMIJO: You may have to maybe --

6 MS. SCHLASEMAN: It's done through the
7 analysis.

8 MEMBER ARMIJO: It depends.

9 MEMBER SHACK: I mean, if the analysis --
10 I mean, what you said was it showed what the handbook
11 predicted. And if you told me that the analysis using
12 the handbook method predicted a deflection of X
13 millimeter at .1 bar, I would be perfectly happy.

14 MEMBER ARMIJO: Right.

15 MEMBER SHACK: It's when you --

16 MS. SCHLASEMAN: No.

17 MR. HEAD: In terms of it being
18 acceptable, an acceptable approach for --

19 MEMBER SHACK: It's when you say that,
20 okay, the loading is half a bar in the real case and
21 .1 bar in this case, therefore, it's fine. Well,
22 that's the part that doesn't compute.

23 MS. SCHLASEMAN: No, I -- that -- I'm
24 sorry. If I said that, I did not mean that. What I
25 had said was this provided additional assurance that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the methodology was acceptable and appropriate for
2 using that methodology.

3 MEMBER SHACK: What was the basis for that
4 conclusion, I guess, is what we are trying to get to.

5 And the basis we have heard so far is that you have
6 gone through twice the applied load and it's still
7 elastic.

8 MS. SCHLASEMAN: We've gone -- well, and
9 that we have gone to four times and no damage. I
10 mean, that was really the bottom line is that there --
11 this was, like I said, an additional assurance on top
12 of the analytical approaches and the handbook, both
13 the ASME Code method and then the handbook method,
14 that this would be an appropriate way to model the
15 perforated sheets.

16 And that if you showed that the stresses
17 using this methodology met ASME Code, then that would
18 give you assurance that under the design condition
19 hydrodynamic loads, you would not have a failure of
20 the plates.

21 CHAIR ABDEL-KHALIK: The connection is
22 still not there. I mean, you can imagine one being
23 able to design an experimental setup that is far more
24 rigid, far more robust than the actual system and,
25 therefore, whatever deflections you would measure or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 whatever stresses you get in the experiment would be
2 highly atypical.

3 So I guess the only way out of this, if
4 you were to use the methodology to model the
5 experiment and show that the predictions matched the
6 experiment, then that would assure us that the
7 methodology is appropriate, rather than saying, you
8 know, we applied four times the load and it's still
9 okay. Do you agree, Bill?

10 MEMBER SHACK: Yes. I mean, that's the
11 absolute rigorous comparison.

12 CHAIR ABDEL-KHALIK: Right.

13 MEMBER SHACK: Now, whether you think
14 there is enough margin here is another kind of
15 judgment, but the rigorous comparison is that. You do
16 an experiment, you make an analysis and you compare
17 the two.

18 MR. HEAD: But I don't think that's really
19 what we are saying here. I mean, the open item was to
20 address the fact that this is a perforated plate. And
21 if it was the exact right thickness, we would have
22 said here is the ASME Code and that's what we would
23 have used. That was not applicable here and so we did
24 some assessments to understand what is a thinner
25 plate. You know, what does that mean from a stress

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 standpoint?

2 And we concluded that the handbook is a
3 valid way of assessing those stresses when we do the
4 Finite Element Analysis. This is the experiment they
5 did. Okay. And based on their interactions and their
6 judgment and Toshiba's interactions and their
7 judgment, they concluded that the handbook and the
8 stresses they were going to use is appropriate.

9 And I believe, you know, the connection is
10 there. And maybe it's not the perfect experiment for
11 the question.

12 MEMBER ARMIJO: Scott, look, I don't think
13 there is any doubt the perforated plate, at least I
14 don't have it, is going to behave the way you
15 analyzed. The problem is the question we are asking
16 about is what about the strainer, the whole structure?

17 MR. HEAD: Won't the Finite Element
18 Analysis be the real --

19 MEMBER ARMIJO: Well, maybe it is. Maybe
20 it is, I mean.

21 MR. HEAD: If the loads -- this is -- you
22 know, the Finite Element Analysis as it hits structure
23 that is pure structure, the Finite Element Analysis we
24 already know how to model that. This is how do we
25 model the impact of --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CONSULTANT WALLIS: Well, I haven't seen
2 that. I mean --

3 MEMBER ARMIJO: It's missing. Either that
4 or a prototypic test, either a very good analysis or--

5 MS. SCHLASEMAN: Oh, there is a three
6 dimensional Finite Element model and it is in the
7 report --

8 CONSULTANT WALLIS: No, but how focused is
9 that --

10 MS. SCHLASEMAN: -- that we gave you guys.

11 CONSULTANT WALLIS: -- on this small scale
12 when the Finite Element Analysis looks at the
13 strainer, which is a big thing?

14 MS. SCHLASEMAN: Yes.

15 CONSULTANT WALLIS: Does it then -- we are
16 looking at one pocket.

17 MS. SCHLASEMAN: It models individual
18 components. It models --

19 CONSULTANT WALLIS: How precisely does it
20 model that pocket?

21 MS. SCHLASEMAN: It models it with the
22 tabs and everything. What it doesn't do is it doesn't
23 model the holes.

24 CONSULTANT WALLIS: Has lots of little
25 elements in that pocket itself?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MS. SCHLASEMAN: Oh, yes.

2 CONSULTANT WALLIS: It does? I haven't
3 seen that. I don't know that I have seen it.

4 MR. HEAD: And it models --

5 MS. SCHLASEMAN: I can show it to you on
6 the break, if you want, but it's -- yes, it's got
7 Finite Element model of all of the key elements. It
8 has got the ribs. It's got the -- I'll pass it
9 around. But --

10 CONSULTANT WALLIS: It's got the stress
11 distribution within the pocket itself and that sort of
12 thing?

13 MS. SCHLASEMAN: Yes. Oh, yes.

14 CONSULTANT WALLIS: Okay. Well, that
15 would be useful. I don't know --

16 MEMBER SHACK: With the elastic sheet
17 model.

18 CONSULTANT WALLIS: Yes.

19 MS. SCHLASEMAN: Right. It's a solid
20 model.

21 MEMBER SHACK: With a solid sheet.

22 MR. HEAD: With a solid sheet.

23 MS. SCHLASEMAN: That's the catch.

24 MR. HEAD: And then you see what the
25 stresses are and then you use all of this to see if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the holes fail or see if, you know, it fails.

2 MS. SCHLASEMAN: It's one of the Toshiba
3 reports.

4 MR. HEAD: Yes, we can give you the
5 number.

6 MS. SCHLASEMAN: Right. This is the RHR.
7 This is for the referenced Japanese plant. This is
8 their number PDR-2005-100210. And we can pass this
9 around, but, I mean, this is the Finite Element model
10 of exactly what --

11 CHAIR ABDEL-KHALIK: But that's how the
12 question started, because this model uses a solid
13 sheet.

14 MR. HEAD: Yes.

15 MS. SCHLASEMAN: Yes.

16 CHAIR ABDEL-KHALIK: And the question was
17 well, how do we handle the holes? How do we account
18 for -- potential for local failure of the holes --

19 MS. SCHLASEMAN: Right.

20 CHAIR ABDEL-KHALIK: -- say in a much
21 bigger hole?

22 MS. SCHLASEMAN: Right.

23 CHAIR ABDEL-KHALIK: And that's where we
24 are now.

25 MS. SCHLASEMAN: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR ABDEL-KHALIK: And I still don't see
2 the connection between what you are presenting here
3 and how the actual strainer will behave under the
4 estimated load.

5 MS. SCHLASEMAN: Go back a slide, two
6 slides. Okay. Again, actually, I mean, Dr. Shack
7 summarized it very nicely. It's ASME Code gives you a
8 methodology for predicting what the weakened condition
9 of a perforated plate is and how to model that so you
10 get a good stress distribution and then how you go
11 ahead and amplify the stresses at the end.

12 CCI to check whether or not that
13 methodology was appropriate for the thin sheet or thin
14 plate -- sheet, they used this method. This is the
15 method that is used in this handbook for perforated
16 metals. And so that's the base contention is that
17 this -- you know, that even though ASME puts this
18 restriction on it, it's use, that it is an appropriate
19 methodology.

20 And then as an additional assurance, they
21 went ahead and they ran this test at multiples of the
22 design pressure to see whether or not there would be
23 any tearing or any kind of damage to the holes in the
24 middle of the plate. And the -- I agree with you that
25 the boundary conditions for the pocket are not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 identical as in the -- it's more tightly constrained
2 than it would be if the sides were also the perforated
3 sheet.

4 CHAIR ABDEL-KHALIK: Right.

5 MS. SCHLASEMAN: But I also don't see how
6 that changes the behavior or the potential for tearing
7 of the holes in the middle of the plate, which is
8 really what that purpose of that test was is to figure
9 out whether or not this is an acceptable methodology
10 for modeling. You know, it's a very detailed Finite
11 Element Analysis, but it doesn't model all those
12 thousands, yes, millions, I don't know how many holes
13 there are. So that's how the holes are accounted for
14 is using the ASME Code.

15 CONSULTANT WALLIS: Can we talk about --

16 MR. HEAD: What we are really challenging
17 here is the holes.

18 CONSULTANT WALLIS: Said, sorry.

19 MR. HEAD: And we settled that.

20 MEMBER SHACK: Well, let me try another
21 argument here that what you have really demonstrated
22 with this test is that you can undergo a considerable
23 amount of plastic deformation in this sheet and not
24 tear locally.

25 MS. SCHLASEMAN: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HEAD: Yes.

2 MEMBER SHACK: So if your analysis
3 predicts elastic behavior of the overall structure,
4 then you have got confidence that you are not going to
5 locally fail the holes.

6 MS. SCHLASEMAN: Right.

7 MEMBER SHACK: I think that's sort of what
8 you have done. So from that point of view, what you
9 have demonstrated with the test is that you can put a
10 lot of plastic deformation into this thing and not
11 tear holes, which your analysis says okay, for elastic
12 and we are not deforming it plastically, the holes are
13 okay. So I would be willing to buy it sort of based
14 on that kind of an argument.

15 CONSULTANT WALLIS: Can we look at your
16 test theory, your picture? I don't know what you mean
17 by pressure. You've got this water coming in through
18 a jet, right? A hose, which is much smaller than the
19 pocket.

20 MS. SCHLASEMAN: Correct.

21 CONSULTANT WALLIS: So there is some
22 enormous Bernouli effects here. And if it is 2 psi in
23 the pocket somewhere, there is a huge v-squared
24 somewhere in that hose. And you are loading it in a
25 very peculiar way. I mean, the pressure isn't uniform

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 in that pocket at all. Just think about it. Where is
2 the --

3 MEMBER SHACK: But try to come back to the
4 bigger picture, Graham. You can deform this thing
5 plastically --

6 CONSULTANT WALLIS: No, but I don't know
7 what -- when she says there is a pressure applied, I
8 don't know what she means.

9 MEMBER SHACK: Well, even if there is --

10 CONSULTANT WALLIS: Because the pressure--

11 MEMBER SHACK: -- pressure, all you are
12 doing is deforming the sheet plastically.

13 CONSULTANT WALLIS: Yes, but the pressure
14 is tied to the load. The half of psi is something.
15 You know, what is --

16 MEMBER SHACK: Forget that comparison.
17 Just think that all you are demonstrating is that this
18 sheet can undergo considerable plastic deformation
19 without local tearing.

20 CHAIR ABDEL-KHALIK: Right.

21 MEMBER SHACK: Therefore, if it doesn't
22 undergo plastic deformation, it's okay.

23 CONSULTANT WALLIS: At 4 psi, yes. But
24 what's the --

25 MEMBER SHACK: Well, no, no. As long as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the overall analysis shows that it is elastic and you
2 are not deforming it plastically, we know it has a
3 considerable capability to take plastic deformation
4 without local tearing. That's what this test
5 demonstrates. Forget the psi, the bars. What you are
6 demonstrating is its capability to take plastic
7 deformation.

8 CONSULTANT WALLIS: As it was mounted in
9 this device, yes.

10 MEMBER SHACK: It's still plastically
11 deformed, mounted or otherwise. It's comparison with
12 the real pocket maybe --

13 CHAIR ABDEL-KHALIK: Or very substantive.

14 MEMBER SHACK: But the fact that it is
15 plastically deforming and not tearing is the critical
16 aspect.

17 CONSULTANT WALLIS: I think since they had
18 psi, I want to know what that means, because it seems
19 to me that this -- what's the flow rate and all that?

20 I mean, this is -- a large fraction of the area is
21 holes. So the pressure drop is all v-squared through
22 the hole and that v-squared to me, because there are
23 so many holes, it's got to be far less than it is in
24 the pipe coming in, because that's a much smaller
25 area. So the whole thing is a very strange test in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 terms of saying you've got so many psi on the hole.

2 CHAIR ABDEL-KHALIK: But again, if you use
3 Bill's argument, it doesn't matter.

4 CONSULTANT WALLIS: It doesn't matter
5 how --

6 CHAIR ABDEL-KHALIK: It doesn't matter.
7 Okay. Even if you bend it by hand --

8 CONSULTANT WALLIS: Right.

9 CHAIR ABDEL-KHALIK: -- and plastically
10 deform it by that much and the holes don't tear, your
11 argument is that means that if you are elastic, the
12 holes will not tear.

13 CONSULTANT WALLIS: well, that's quite
14 different from -- well, so we just say the psi doesn't
15 matter at all. Their argument here is unimportant.

16 CHAIR ABDEL-KHALIK: Well --

17 CONSULTANT WALLIS: It's just it didn't
18 break.

19 MEMBER ARMIJO: As long as it's the right
20 psi.

21 MEMBER SHACK: I'm just trying to get
22 through to a conclusion.

23 MEMBER ARMIJO: Yes.

24 CHAIR ABDEL-KHALIK: Yes.

25 MEMBER SHACK: You know, we don't have to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 conclude that their test is appropriate. All we have
2 to do is conclude whether the sheet will behave
3 appropriately.

4 CHAIR ABDEL-KHALIK: Right.

5 MEMBER SHACK: And I think that's the
6 question.

7 MR. HEAD: Whether we have found a way of
8 appropriately determining what the holes will do, I
9 mean, that's the question here, obviously.

10 MS. SCHLASEMAN: And whether the
11 analytical methodology is acceptable.

12 MEMBER SHACK: Now, I take -- I mean, Bill
13 O'Donnell did perforated sheets for his PhD thesis 50
14 years ago and he has been working on it ever since, so
15 if it's in his handbook, I probably will believe it.
16 But you might have done better just to quit there.

17 MR. HEAD: You know, at some point in time
18 in the discussion, I thought well that may have been
19 maybe where we quit, but you asked us how we did it
20 and clearly CCI did additional work.

21 MEMBER SHACK: Yes.

22 MS. SCHLASEMAN: Yes.

23 MR. HEAD: And we thought this work --

24 CHAIR ABDEL-KHALIK: I think what started
25 this whole discussion is the argument made that hey,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we raised the loading to four times what we would
2 expect and nothing bad happens. And that doesn't mean
3 anything in terms of making the connection between the
4 experiment and the real system. I think Bill's
5 argument, to me, is plausible and acceptable.

6 MS. BANERJEE: So does it mean we can
7 close this action item?

8 CHAIR ABDEL-KHALIK: Unless anybody
9 objects, the fact that we have something that was
10 plastically deformed by a significant amount without
11 any tearing of the holes, while the actual analysis
12 showed that you are still in the elastic regime, would
13 suggest that the issue that was raised originally
14 about the possibility of the holes locally tearing is
15 not an issue.

16 MEMBER BROWN: Yes, not being a mechanical
17 engineer, but having worked with this a little bit,
18 she made the comment that not all the strainers are
19 the same. There are a number of different sizes. I
20 don't know what the variation in size is, but does
21 this thought process that you all have gone through
22 extrapolate to different size strainers?

23 CHAIR ABDEL-KHALIK: I think that yes.

24 MEMBER SHACK: The analysis is always
25 going to show their elastic consistency.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BROWN: I wanted to ask the
2 question on different -- it's a matter of scale.

3 CONSULTANT WALLIS: But I don't understand
4 your reasoning. I mean, the question was is the
5 analysis valid that shows it's elastic and it's okay?

6 I mean, if you are saying well, just -- we don't care
7 if the analysis is valid, as long as some test showed
8 you could get a plastic deformation. It seems to me a
9 pretty weak way out.

10 MEMBER SHACK: No, I --

11 CONSULTANT WALLIS: Must the analysis --

12 MEMBER SHACK: There is all sorts of
13 confirmation that using this elastic model gives you
14 the right displacement. What you worry about is the
15 fact that you get local effects.

16 CONSULTANT WALLIS: Of holes? When you
17 have holes?

18 MEMBER SHACK: Oh, yes. I mean, you know,
19 perforated plates have been -- as I say, you know,
20 people have worked on this problem for a long time.
21 You know, the question was whether you got the local
22 failures.

23 CONSULTANT WALLIS: Local failures, right.

24 Well, that's a fluid structure interaction problem.
25 And you are concentrating on the --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR ABDEL-KHALIK: Well, unless I hear,
2 you know, strong objections, I think, this item is
3 closed. I think this -- the argument that even with
4 plastic deformation, local failures do not take place
5 is quite persuasive, to me at least personally.

6 MR. HEAD: Okay.

7 CHAIR ABDEL-KHALIK: Okay.

8 MR. HEAD: We'll move on.

9 CHAIR ABDEL-KHALIK: Let's proceed.

10 MR. HEAD: All right. Then we will move
11 on to the next item.

12 MR. ANDREYCHEK: This particular item was
13 to provide documentation that the concentration of
14 zinc oxide is less than 1.6 ppm in the suppression for
15 water.

16 A point of clarification. This was
17 discussed at the last meeting. Dr. Abdel-Khalik, I
18 believe, you and I had an exchange and we had
19 calculated the zinc oxide mass, but had not calculated
20 the concentration calculations. And as a consequence,
21 I believe we have had discussions whether or not it
22 would be less than 1.6 ppm solubility for zinc oxide.

23 CHAIR ABDEL-KHALIK: Right.

24 MR. ANDREYCHEK: We have gone back and
25 done the calculations and the solubility limit of 1.6

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is exceeded based on the minimum mass of water in the
2 suppression pool and I want to present those
3 calculations, at this point in time.

4 So go to the next slide, please.
5 Basically, the assumptions that we used in calculating
6 zinc oxide was we used the maximum amount of zinc
7 oxide corrosion product. We assumed 100 percent of
8 the inorganic zinc coatings were destroyed within the
9 Zone of Influence 10D ZoI within the drywell. And we
10 used the maximum amount of surface area and that was
11 the 10 micron balls of zinc. We maintained that
12 constant throughout the calculation.

13 We used the minimum suppression pool
14 inventory, which is about 7.7×10^6 pounds of water.
15 We looked at 2 pH values and the minimum pH of 5.3 and
16 we calculated the pH --

17 MEMBER SHACK: Well, how did you come up
18 with those pHs?

19 MR. TOMKINS: Those are in the DC --
20 that's -- those are the licensed amounts in the DCD.

21 MS. SCHLASEMAN: They are not the
22 operational, but they are the licensing design limits
23 in the DCD.

24 MR. ANDREYCHEK: Yes. We would expect the
25 pH to be something greater than 5.3.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER SHACK: I would, too, but it's
2 sulfuric acid.

3 MR. ANDREYCHEK: But those are the
4 licensing limits. And so in order to --

5 MEMBER SHACK: The trouble with the BWR is
6 it's not buffered, so it's --

7 MR. ANDREYCHEK: That's right.

8 MEMBER SHACK: -- very hard to tell where
9 the pH is. I guess I --

10 MS. SCHLASEMAN: It's the --
11 operationally, it's supposed to be at 7, obviously.
12 And --

13 MEMBER SHACK: Yes, but this is the -- I
14 mean, operationally, I have no question where the pH
15 is going to be.

16 MS. SCHLASEMAN: Right.

17 MEMBER SHACK: It's how you determine it
18 in an accident that is a little --

19 MS. SCHLASEMAN: Right.

20 MEMBER SHACK: -- but you are saying this
21 is what they did in the DCD, correct?

22 MS. SCHLASEMAN: Well, and then I said
23 there are additional calculations. We went through
24 several RAIs with the staff on this about -- to be
25 able to explain what happened during the accidents and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 what would happen during the accident.

2 And so the -- so to keep it in that range,
3 I mean, like I said, that is our licensed range. Even
4 during accident scenarios, you know, there is
5 potential to do -- you know, standby liquid control
6 system and go ahead and put it as if -- as you are
7 going through the accident and potentially forming
8 nitric acid, you know, several days into the accident,
9 then you would inject the sodium pentaborate from the
10 LSC system.

11 MEMBER SHACK: Oh, and you use that for a
12 buffer?

13 MS. SCHLASEMAN: Yes.

14 MEMBER SHACK: And that would be --

15 MEMBER STETKAR: Do operators have
16 guidance to do that?

17 MS. SCHLASEMAN: It's the --

18 MEMBER SHACK: It's the SAMG, I would
19 suspect.

20 MS. SCHLASEMAN: We put it into -- yes, it
21 is. It's guidelines. It is guidelines. And we --
22 it's in an RAI. It's in that RAI. But they would be
23 getting from technical support center, they would be
24 getting the guidance to inject standby liquid control
25 if they end up dropping too far in the -- with the pH.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. TOMKINS: All right. These are the
2 values we used based on the DCD.

3 MS. SCHLASEMAN: Right. So these were our
4 balance.

5 MR. TOMKINS: What we would ever see.

6 CHAIR ABDEL-KHALIK: Keep going, Tim.

7 MR. ANDREYCHEK: Okay. Thank you. So for
8 a minimum pH of 5.3, we calculate 28.6 pounds mass of
9 zinc oxide and for a maximum pH, that is the standby
10 liquid control system injected that gets you to a pH
11 of 8.9, that's 13.7 pounds. These were assumed that
12 the standby liquid control system was initiated at
13 time zero or you had the maximum pH starting at time
14 zero in the event.

15 MEMBER ARMIJO: So those masses are the
16 maximum amount that could be dissolved?

17 MR. ANDREYCHEK: That's the maximum amount
18 that would be formed.

19 MEMBER ARMIJO: Formed?

20 MR. ANDREYCHEK: Yes, sir. We will get to
21 the dissolved --

22 MEMBER ARMIJO: Okay.

23 MR. ANDREYCHEK: -- in just a second.

24 MEMBER ARMIJO: Okay.

25 MR. ANDREYCHEK: And so you are using the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 7.7 x 10⁶ pounds mass dividing into the mass of zinc
2 oxide that would be -- the concentration would be 7.6
3 ppm at pH 5.3 and 1.8 ppm at a pH of 8.9.

4 So now, addressing your question
5 specifically of, okay, how much would actually become
6 precipitate?

7 Go to the next slide. Obviously, in this
8 case, both values exceed the 1.6 ppm. So by assuming,
9 and this is an assumption, that 1.6 ppm stays in
10 solution and looking at the excess, what would
11 actually come out as precipitate? And that's what
12 this slide shows.

13 So for a pH of 5.3, we would get 21 kg or
14 .6 -- 6.3 pounds of precipitate. For a pH of 8.9, we
15 would get about --

16 CONSULTANT WALLIS: Different than the
17 1.6?

18 MR. ANDREYCHEK: I don't disagree, but the
19 1.6 ppm stays in solution. This is what is --

20 CONSULTANT WALLIS: Oh, that last time --

21 MR. ANDREYCHEK: That was --

22 CONSULTANT WALLIS: Last time I was
23 wondering about the 1.6. Now, you have got a number
24 which is very different or could be very different. I
25 don't -- what is it at 7?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ANDREYCHEK: Say again, please.

2 CONSULTANT WALLIS: What is it at 7 pH?

3 MR. ANDREYCHEK: We did not run that
4 calculation.

5 CONSULTANT WALLIS: It's somewhere in
6 between.

7 MR. ANDREYCHEK: That's correct.

8 CONSULTANT WALLIS: It's probably a lot
9 more than 1.6 we were looking at last time.

10 MR. ANDREYCHEK: I'm assuming it would be.

11 CONSULTANT WALLIS: Yes. Okay. Thank
12 you.

13 CHAIR ABDEL-KHALIK: But is this behavior
14 really a continuous function?

15 CONSULTANT WALLIS: No, no.

16 MR. ANDREYCHEK: I'm not sure I understand
17 what you mean.

18 CHAIR ABDEL-KHALIK: You can essentially
19 assume that this is a continuous function? You only
20 have to evaluate the two points? There are no local
21 minimums or maximums?

22 MR. ANDREYCHEK: As long as you are
23 circulating water, you are going to maintain a
24 reasonably uniform distribution of buffering within or
25 non-buffering. The acids will be in the pool. So I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 would take this to be a relatively uniform continuous
2 function. As long as you are circulating water, you
3 are keeping mixing, reasonable mixing, I would say
4 that this is a uniform or continuous function. This
5 is way outside my area of expertise.

6 MEMBER ARMIJO: Yes. Well, so what
7 happens when 46 pounds of stuff --

8 MEMBER SHACK: I really think this is a
9 well-mixed solution. That's a quite reasonable sort
10 of thing to do.

11 MR. ANDREYCHEK: And again, we assume that
12 we are going to take the whole thing and dump it
13 anyway.

14 MEMBER SHACK: Right, right, exactly.

15 MR. ANDREYCHEK: If you take the 10D Zone
16 of Influence for zinc, we are assuming that with
17 anything within that 10D Zone of Influence --

18 CHAIR ABDEL-KHALIK: What I meant by
19 local, maxima and minima, is sort of with regard to
20 the pH.

21 MR. ANDREYCHEK: Yes.

22 CHAIR ABDEL-KHALIK: If I were to plop
23 this on a pH, would I get a continuous function? So
24 monotonically --

25 MEMBER SHACK: Oh, you mean the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 solubility?

2 CHAIR ABDEL-KHALIK: Right. Would I get a
3 monotonically --

4 MEMBER SHACK: Yes.

5 CHAIR ABDEL-KHALIK: -- between 5.3 and
6 8.9?

7 MEMBER SHACK: Yes.

8 CHAIR ABDEL-KHALIK: Hum. Okay.

9 MR. HEAD: You really mean would you see
10 some spike at some pH level or --

11 CHAIR ABDEL-KHALIK: No. I was just
12 wondering about whether this is a monotonic function.

13 MEMBER SHACK: No, I think you -- it's
14 safe to say it's somewhere between those two values,
15 you know. Just whether it is purely linear in pH
16 might be a stretch, but --

17 CHAIR ABDEL-KHALIK: Right. Okay.

18 MEMBER SHACK: -- between those two values
19 is a pretty good bet.

20 MEMBER ARMIJO: But the limiting problem
21 is when you have a lot of insoluble precipitate.

22 MS. SCHLASEMAN: Yes.

23 MEMBER SHACK: Right.

24 CHAIR ABDEL-KHALIK: Right.

25 MR. ANDREYCHEK: And I think we will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 address that in the next slide or so.

2 MEMBER ARMIJO: Okay.

3 MR. ANDREYCHEK: So if you would? So we
4 have gone through the, if we could go to the next
5 slide, calculation of zinc oxide, maxima amount
6 assuming total failure of the coatings within the Zone
7 of Influence. And we have done testing for other
8 clients where we show that that is not the case, that
9 some of the zinc stays on, so we are using a maximum
10 amount of zinc.

11 We are maximizing the surface area of the
12 zinc particles that we are dealing with. We don't
13 assume any passivation of the zinc particles. And we
14 are using the minimum amount of inventory to calculate
15 a concentration.

16 The testing conservatively assumes the
17 maximum amount of zinc oxide which is the 58.6 pounds
18 mass of zinc. So we're conservatively treating
19 whatever zinc we have. We are assuming it is all
20 precipitate and, therefore, like if we demonstrated
21 through this calculation that we are conservatively
22 treating zinc oxide as a corrosion product for the
23 ABWR at the South Texas Project.

24 MR. TOMKINS: So the key there is we are
25 taking no credit for the solubility of the zinc --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. ANDREYCHEK: Yes.

2 MR. TOMKINS: -- oxide at all. And we are
3 assuming that all of the zinc is gelatinous material
4 as well. So we are not -- we think that really a fair
5 amount of it would be particulate. But you know, some
6 form of gelatinous.

7 MEMBER ARMIJO: Can you form a gelatinous
8 zinc?

9 MR. TOMKINS: Well --

10 MEMBER ARMIJO: I have not seen, whatever
11 it is, molecules.

12 MR. ANDREYCHEK: I have not seen it in any
13 of the work that we have done --

14 MR. TOMKINS: Yes.

15 MR. ANDREYCHEK: -- for

16 MR. TOMKINS: Yes, it's not like aluminum.

17 MR. ANDREYCHEK: No. It's -- any of the
18 work that we have done where we have looked at zinc in
19 either sodium hydroxide or trisodium phosphate, we
20 have not seen a gelatinous form of a zinc oxide
21 product.

22 MEMBER ARMIJO: Yes.

23 MR. ANDREYCHEK: And we are treating it as
24 a gelatinous type of material. So based on the work
25 that we have done and the knowledge that we have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 today, we believe we are treating this as a very
2 conservative approach.

3 MR. TOMKINS: Yes.

4 MEMBER ARMIJO: Very good.

5 CHAIR ABDEL-KHALIK: You're happy?

6 MEMBER ARMIJO: Yes, I'm happy.

7 CHAIR ABDEL-KHALIK: Good. Let's proceed.

8 MEMBER ARMIJO: I know where the zinc is
9 going.

10 MR. HEAD: May I ask? Is this something
11 we can close out, at this point?

12 MEMBER ARMIJO: I am okay.

13 CHAIR ABDEL-KHALIK: Okay.

14 CONSULTANT WALLIS: Well, it's impressive
15 the way the numbers have changed from last time.

16 MR. ANDREYCHEK: Well, again, I would
17 suggest that last time we had masses, but we did not
18 do -- have concentration calculations. This time we
19 are presenting the calculations.

20 CONSULTANT WALLIS: It just shows how
21 things can change when you do a little bit more
22 studying.

23 MR. ANDREYCHEK: I'm not going to argue
24 with that.

25 CONSULTANT WALLIS: So maybe could we ask

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that question?

2 MR. HEAD: So we are going to the next
3 one?

4 CHAIR ABDEL-KHALIK: Sure.

5 MR. HEAD: Marty?

6 MR. VAN HALTERN: Action Item #80. This
7 is really a restatement of what we had before, which
8 is to provide the basis for the acceptance criteria
9 using the square relationship versus some other
10 exponent such as 1.2.

11 Dr. Abdel-Khalik had asked us to come back
12 with the write-up. In some of the backup slides there
13 was a write-up, hopefully you had a chance to go
14 through that.

15 The slides here are just sort of a
16 summary. Our acceptance criteria is based on,
17 essentially, the Darcy equation of looking at the
18 pressure drop versus the flow relationship. The K
19 factor here is when you are doing the test, it's
20 essentially a compilation of several features,
21 including the inlet losses, the debris filtering
22 bottom nozzle, the grids, the friction on the rods and
23 the sides of the assembly, because you are measuring
24 the DP across the entire thing.

25 As Dr. Wallis had pointed out, there was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 an experiment for one of the other reactor types where
2 what they did is they did a series of injections of
[

17]CONSULTANT WALLIS: It's is very peculiar.
18 I would think it would go the other way.

19 Member Shack: Right. Well, that was
20 my reaction.

21 CONSULTANT WALLIS: Right. The more
22 debris, the more laminar it is, the more blockage you
23 have, therefore, it would go the other way.

24 MR. VAN HALTERN: But if you look at the
25 components of the hydraulic resistance, okay, there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 are some which are, essentially, a form loss. Okay.
2 And those tend to not have much dependency on
3 velocity. If you look at Crane or any of the other
4 ones, you -- there was, essentially, a constant, even
5 though they have a very small Reynolds dependency.

6 CONSULTANT WALLIS: I think the --

7 MR. VAN HALTERN: Friction on the other
8 hand --

9 CONSULTANT WALLIS: -- only way this
10 explains to me is because you've got blowholes or
11 something. You have got something which is now a v-
12 squared type thing rather than a laminar flow through
13 the bed.

14 MEMBER SHACK: I mean, a porous medium
15 is the classic linear case. You know, the thicker
16 debris bed would seem like --

17 CONSULTANT WALLIS: Well, but if it's got
18 holes in it, it's got blowholes.

19 MEMBER SHACK: Yes, if it's got holes
20 in it, it looks like a --

21 CONSULTANT WALLIS: That's probably what
22 it is.

23 MR. VAN HALTERN: Yes. And going back to
24 -- that was the behavior that was shown in that test.

25 Okay. Now, our acceptance criteria, what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we were trying to do is determine the acceptance
2 criteria which has a high debris load. And so I
3 believe that the -- that test would tend to indicate
4 that when you have a high debris loading, that
5 exponent two is more appropriate.

6 And just to walk through some of the
7 numbers, if you were to use a different exponent, if
8 you were to start the test with a flow rate of 3 and
9 end up after you have added all of the debris at .5,
10 using an exponent of 2, the allowed pressure drop
11 increase in this equation is about a factor of 33.

12 If you were to use an exponent of 1.5
13 instead, you would actually allow a larger increase in
14 the pressure drop. So I still think an exponent of 2
15 or something close to that is appropriate, based on
16 that experiment. 2, essentially, provides a smaller
17 allowed increase in the pressure drop.

18 CONSULTANT WALLIS: Say that again. Why
19 is that acceptable? I'm trying to work it out. A
20 smaller allowed increase than what?

21 MR. VAN HALTERN: Than the pressure. In
22 other words, as the -- as they run the test, they
23 start out --

24 CONSULTANT WALLIS: During the test,
25 during the test?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. VAN HALTERN: During the test. Okay.
2 So I start out with a clean assembly and a higher
3 velocity.

4 CONSULTANT WALLIS: Right.

5 MR. VAN HALTERN: Okay. And so as I add
6 debris, my velocities decrease, but my hydraulic
7 resistance increases. And the increase due to the
8 debris exceeds the -- what you get from a lower flow
9 rate.

10 CONSULTANT WALLIS: So you calculate the
11 test criterion using 2, right? You calculate the
12 allowed DP during the test, right?

13 MR. VAN HALTERN: Right.

14 CONSULTANT WALLIS: And you use -- and
15 then that is how much? I'm trying to -- I can't
16 follow the rationale. Minimizes the amount increased.
17 I don't follow the rationale.

18 MR. VAN HALTERN: Okay. Using -- this is
19 an acceptance criteria.

20 CONSULTANT WALLIS: Yes.

21 MR. VAN HALTERN: Okay. So if in my test
22 I start at 3 and I go down to .5 in the flow and my
23 pressure drop increases, okay, the acceptance
24 criteria, if I use an exponent of 2 here, I would
25 allow a 33 -- a factor of 33 increase in the pressure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 drop as being acceptable.

2 If I use 1.5, it actually allows a higher
3 increase in the pressure.

4 MR. TOMKINS: 33 is a more restrictive
5 mild increase in pressure.

6 MR. VAN HALTERN: Restrictive.

7 CONSULTANT WALLIS: Acceptance criteria.

8 MR. TOMKINS: More conservative.

9 CONSULTANT WALLIS: So you are really
10 saying that using 2 --

11 MR. VAN HALTERN: Is conservative.

12 MR. TOMKINS: Is more conservative.

13 CONSULTANT WALLIS: -- allows -- is a more
14 restrictive criteria?

15 MR. VAN HALTERN: That's correct.

16 CONSULTANT WALLIS: Because nothing is
17 minimized here. I mean, you are saying one thing is
18 less than another.

19 MR. TOMKINS: Uses.

20 CONSULTANT WALLIS: So you are saying that
21 if you took it one way, you get another and if you do
22 it another way, you get a lower number?

23 MR. VAN HALTERN: Correct.

24 CONSULTANT WALLIS: There's nothing
25 minimized.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. TOMKINS: Reduced.

2 CONSULTANT WALLIS: Absolutely nothing
3 minimized.

4 MR. VAN HALTERN: Yes.

5 CHAIR ABDEL-KHALIK: But where did the
6 1200 number come from?

7 CONSULTANT WALLIS: It came from using 2.

8 MR. VAN HALTERN: Yes.

9 CHAIR ABDEL-KHALIK: Okay.

10 MR. VAN HALTERN: I will walk through the
11 process again. We used the GOBLIN Code to analyze the
12 conditions with the five notifications. You increase
13 the hydraulic loss, the K factor at the inlet, okay,
14 until we got to our acceptance criteria, the .95 void
15 fraction.

16 So there was a significant increase in
17 that K factor. But given the fact that that was done
18 in reactor conditions, in terms of temperature,
19 pressure and everything, but when we do the test, we
20 are doing the test in cold conditions. What we did is
21 looked at what you would be measuring in the test,
22 which is a DP across this test section, okay. And
23 that is comprised of various elements.

24 So we took the -- one of those elements
25 and increased it by that same factor. How much was my

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hydraulic resistance on increase? Because they all
2 add up. And looked at if I -- if I start with a clean
3 condition, I add this in, what would my final
4 condition be in terms of that DP across the test?

5 And the ratio of clean K factor to a
6 fouled K factor at that debris resistance or fouled
7 Delta P with that K factor, I'm losing you, I can
8 tell.

9 CONSULTANT WALLIS: You are. I think your
10 argument is bogus. And I think what you have to do is
11 use 2 all the way through.

12 CHAIR ABDEL-KHALIK: Yes.

13 CONSULTANT WALLIS: If you use 2, you use
14 2 to model the reactor.

15 MR. VAN HALTERN: Correct.

16 CONSULTANT WALLIS: And this gives you the
17 1200. If you interpret the test in terms of 2, the
18 calculated K factor based on 2, that's compatible with
19 what you do here. Let's follow, all you are doing is
20 going through a comparison --

21 MR. VAN HALTERN: Right.

22 CONSULTANT WALLIS: -- but you give it a K
23 factor. What is the K factor in the test based on 2?

24 MR. VAN HALTERN: Right.

25 CONSULTANT WALLIS: Then you compare it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with the reactor based on 2, that's completely fair.

2 MR. VAN HALTERN: That's what we did.

3 CONSULTANT WALLIS: Well, there is a power
4 low which is different or not? Because each time you
5 define it, it's like a friction fight. You have a
6 friction fight based on 2 and the fact that it buries
7 with those numbers is irrelevant, as long as you do
8 all your calculations consistently.

9 But you don't use that argument. You use
10 a bogus argument.

11 MR. VAN HALTERN: Well, I was trying to
12 address the information that you provided.

13 CONSULTANT WALLIS: I know, but --

14 MR. VAN HALTERN: Which was how I
15 partially -- related back to how a partially formed
16 debris bed may have formed as opposed to --

17 CONSULTANT WALLIS: Well, we were saying
18 how do you handle an impact exponent different than 2
19 on the test data? That's what we were asking.

20 MR. ANDREYCHEK: I think the answer is
21 they don't know. We have used a factor of 2 --

22 CONSULTANT WALLIS: You have used --

23 MR. ANDREYCHEK: -- consistently.

24 CONSULTANT WALLIS: So what are you
25 arguing here about then? Now, you're saying you use a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 different end?

2 MR. ANDREYCHEK: I think that -- if I
3 remember correctly, the question was asked well, there
4 has been other data that shows a factor other than 2--

5 CONSULTANT WALLIS: Right.

6 MR. ANDREYCHEK: -- exponent. And that's
7 not what this -- the analyses that are being done for
8 this particular reactor zone are using. They are
9 using a factor of 2 consistently from the analysis to
10 actually analyzing the test data.

11 CONSULTANT WALLIS: Well, is that the
12 argument though? I mean, that should be the argument.

13 MR. ANDREYCHEK: Yes.

14 CONSULTANT WALLIS: But it isn't the
15 argument. You are using some other argument, which is
16 bogus. It doesn't seem relevant or something.

17 CHAIR ABDEL-KHALIK: But the question is
18 had you used an exponent other than 2 in both
19 analyzing the real case and interpreting the data?
20 Would the answers be different?

21 MR. VAN HALTERN: We would have --

22 CHAIR ABDEL-KHALIK: Rather than trying to
23 link the two. If you had --

24 MR. VAN HALTERN: Would the answers have
25 been different?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR ABDEL-KHALIK: Right.

2 MR. VAN HALTERN: We would have gotten a--
3 we would have derived an acceptance criteria based on
4 that other exponent.

5 MR. TOMKINS: And it would have been
6 different probably.

7 MR. VAN HALTERN: Yes, again, we are not
8 trying to analyze data here. We are trying to specify
9 an acceptance criteria that wherever the data falls,
10 as long as it's lower than that acceptance criteria,
11 it's okay.

12 CONSULTANT WALLIS: But the question is
13 how do you compare the test with the real reactor?
14 And how do you scale? It's a scaling question.

15 MR. VAN HALTERN: Correct. And so the way
16 we --

17 CONSULTANT WALLIS: Scaled with a
18 different exponent, would it make a difference?

19 MR. VAN HALTERN: That's --

20 CHAIR ABDEL-KHALIK: Would a different
21 exponent have been appropriate?

22 MEMBER SHACK: Well, in your argument that
23 you have got a more restrictive one, did you use the
24 1.5 consistently for the analysis and the data?

25 MR. VAN HALTERN: I just plugged into it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: But you kept the K at 1200
2 and just changed the exponent?

3 MR. VAN HALTERN: Right, correct.

4 CONSULTANT WALLIS: You can't do that.
5 The K, the 1200, depends on the exponent.

6 MR. VAN HALTERN: Right. But we used --
7 my point was we used the factor of 2 consistently. We
8 developed this methodology and the factor of 2, I
9 believe, is supported by the same test where -- which
10 introduced as providing a lower factor.

11 MR. TOMKINS: And the factor of 2 is more
12 appropriate for acceptance criteria, based on a highly
13 plugged situation.

14 MR. VAN HALTERN: Loaded.

15 MR. TOMKINS: Rightfully loaded.

16 CHAIR ABDEL-KHALIK: But we don't know
17 that for sure, do we?

18 MR. VAN HALTERN: Well, the test -- based
19 on that test --

20 MR. TOMKINS: The previous test -- okay.
21 As you load the -- the debris bed becomes more fully
22 loaded, then the exponent relationship approaches 2.

23 CHAIR ABDEL-KHALIK: I guess the point is
24 the argument that you are presenting here is not
25 consistent, right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: I mean, since we don't know
2 how your test is going to turn out --

3 MR. VAN HALTERN: Right.

4 MR. TOMKINS: Right.

5 MEMBER SHACK: -- it would seem that we
6 would have to have an acceptance criteria that would--
7 you know, whatever your test is, then you would apply
8 that to the analysis and you would -- you know, what
9 you need is a consistency in the margin that we
10 accept, rather than some exponent.

11 CHAIR ABDEL-KHALIK: Okay.

12 MR. VAN HALTERN: And so we were
13 consistent. We had been consistent in how we derived
14 the acceptance criteria compared to the analysis,
15 which gave you, you know, acceptable results. And
16 then in addition to that, because we knew that there
17 were some variations, we added on -- took our
18 acceptance criteria and we reduced that by a factor of
19 4, so we do have a significant amount of margin built
20 into that acceptance criteria.

21 MEMBER SHACK: If I were to go without
22 that -- well, I mean, I guess I would be happier if --
23 you have built the square into the acceptance
24 criteria, too.

25 MR. TOMKINS: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. VAN HALTERN: The standard in terms of
2 the flow relationship.

3 MEMBER SHACK: But it would be better, it
4 would seem to me, to, whatever comes out of your test,
5 then say that you are going to apply a factor of 4 to
6 your analysis results for your acceptance criteria.
7 And, you know, if you get 2 in your test, you use 2.
8 If you get 1.5, you use 1.5.

9 MR. VAN HALTERN: The test is not intended
10 to develop the exponent. It's only to --

11 CONSULTANT WALLIS: You can't do that
12 because the model uses 2. The whole modeling of the
13 reactor itself is based on 2. And you can't sort of
14 use that K criterion and then apply 1.5 to the test.

15 MR. VAN HALTERN: Right.

16 CONSULTANT WALLIS: You can't do that.
17 You've got to interpret the test in terms of the way
18 in which the computer models --

19 MR. VAN HALTERN: Right, correct.

20 CONSULTANT WALLIS: -- the reactor.

21 MR. VAN HALTERN: And that is what we have
22 done.

23 CONSULTANT WALLIS: That is the argument
24 you have got to use. I don't know where you come up
25 with this strange roundabout mixed up different things

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 here. I mean, you've got to convince us that you can
2 go from the test to the reactor. You can know what
3 number to put in the computer as a result of the test
4 modeling, the test number. That's what you need to
5 do.

6 UNIDENTIFIED SPEAKER: The other way
7 around.

8 MR. VAN HALTERN: Okay.

9 CHAIR ABDEL-KHALIK: We'll just have to --

10 MR. VAN HALTERN: I apologize for
11 confusing you. But do you -- I mean --

12 CONSULTANT WALLIS: I mean, this seems to
13 be like the porous media thing. I mean, we can't
14 solve the problem for you. You come up with a strange
15 argument and now in discussion we may actually come up
16 with a valid argument, but I'm not sure that's our
17 function.

18 MR. HEAD: Well, it has worked once today,
19 so, I mean, certainly, you know, a 500 batting average
20 isn't bad right now.

21 I mean, you know, back to the original
22 question, this is what we were asked and I think we
23 took it maybe, you know, head on that what is our
24 basis for thinking, too, is it an appropriately
25 conservative approach? And that is what we have done.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 You know, maybe we haven't addressed the
2 1.2 and how we would have gone back and done that,
3 but, you know, the -- this is where we are.

4 CONSULTANT WALLIS: Your slide 21 says if
5 we would use 1.5 in this W_f/W_i to the 1.5, we would
6 have got something, isn't it? Isn't that what it
7 said? It says the P_f/P_i is some --

8 MR. HEAD: To allow a larger pressure
9 drop.

10 CONSULTANT WALLIS: But you can't do that,
11 because the computer used 2 in your whole model. This
12 is the basis of this whole thing is the 1200.

13 MR. HEAD: Right. Use the 1200.

14 MS. BANERJEE: Just cross out the last
15 column.

16 CHAIR ABDEL-KHALIK: We need to think this
17 one through.

18 MR. VAN HALTERN: Okay.

19 CHAIR ABDEL-KHALIK: Because I need --

20 MR. VAN HALTERN: So what do I need to
21 bring back, if anything? And again, I guess my
22 argument, I apologize to the Committee if I may have
23 confused.

[

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

]

5 Okay. Which in my mind tells me that our
6 acceptance criteria, which is a highly loaded debris,
7 should have an exponent close to 2.

8 CONSULTANT WALLIS: But that goes against
9 all porous media, Reynolds number and everything in
10 the background, so that's not very good either. It
11 must mean that there is something odd about the debris
12 bed.

13 MR. VAN HALTERN: Maybe it's not a debris
14 bed so much, as it's just a flow restriction --

15 CONSULTANT WALLIS: It's just got holes in
16 it.

17 MR. VAN HALTERN: -- at -- flow
18 restriction at the grids and at the lower tie plate
19 and then the refiltering bottom nozzle.

20 CONSULTANT WALLIS: Well, I think there is
21 a much better argument --

22 MR. VAN HALTERN: It's not that it --

23 CONSULTANT WALLIS: -- that it doesn't
24 depend at all --

25 MR. VAN HALTERN: -- isn't porous --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CONSULTANT WALLIS: -- upon the exponent.
2 I think you can make that argument. You have to make
3 it. I'm not going to make it for you.

4 CHAIR ABDEL-KHALIK: I guess the process
5 is you started out with a model, right?

6 MR. VAN HALTERN: Correct. Right.

7 CHAIR ABDEL-KHALIK: You established an
8 acceptance criterion --

9 MR. VAN HALTERN: In terms of --

10 CHAIR ABDEL-KHALIK: -- that would reach
11 your acceptance limit in terms of maximum void
12 fraction.

13 MR. VAN HALTERN: Right.

14 CHAIR ABDEL-KHALIK: And then you multiply
15 that by a factor of 4 to add conservatism. And then
16 you said if we run a test and we pass that limit, then
17 we should be okay.

18 MR. VAN HALTERN: That's correct.

19 CHAIR ABDEL-KHALIK: Okay. What if you
20 had used a factor of 1.5 in the model?

21 MR. VAN HALTERN: I would have --

22 CHAIR ABDEL-KHALIK: How would the
23 criterion be formulated?

24 MR. VAN HALTERN: It would have a 1.5 in
25 the exponent.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR ABDEL-KHALIK: Right.

2 MR. VAN HALTERN: You may have some --

3 CHAIR ABDEL-KHALIK: A completely
4 different --

5 MR. VAN HALTERN: -- difference in the--

6 CHAIR ABDEL-KHALIK: -- multiplier.

7 MR. VAN HALTERN: -- multiplier.

8 CHAIR ABDEL-KHALIK: Right.

9 MR. VAN HALTERN: Upon change.

10 CHAIR ABDEL-KHALIK: Okay. Now, if that
11 is the case, would you end up with, essentially, the
12 same acceptance value for the pressure drop that you
13 would measure experimentally?

14 CONSULTANT WALLIS: No.

15 CHAIR ABDEL-KHALIK: Well, let's just --

16 MR. VAN HALTERN: Right. You would have a
17 different curve.

18 CHAIR ABDEL-KHALIK: And that's what we
19 are asking.

20 MR. VAN HALTERN: Okay.

21 CHAIR ABDEL-KHALIK: Because if you have a
22 different curve, that means you, essentially, have a
23 different margin.

24 CONSULTANT WALLIS: That's right.

25 MR. VAN HALTERN: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CONSULTANT WALLIS: That's correct.

2 MR. VAN HALTERN: Right.

3 CHAIR ABDEL-KHALIK: And we are trying to
4 find out which one reduces the margin using 1.5
5 consistently throughout or using 2 throughout, that
6 was the basis for the question. And this doesn't
7 really clarify it for me.

8 MR. VAN HALTERN: Okay. But again, which
9 appear to be the more appropriate from the test?

10 CHAIR ABDEL-KHALIK: We don't know that,
11 because the value varies all over the place.

12 MR. HEAD: Okay. Marty, I think we have
13 something to go back and look at. And with respect --

14 CHAIR ABDEL-KHALIK: Has the problem been
15 defined?

16 MR. HEAD: I think so. I think --

17 CHAIR ABDEL-KHALIK: Or the question been
18 defined?

19 MR. HEAD: If we had shown this curve or
20 this presentation and the 1200 had been adjusted with
21 the 1.5 and if that was 1100, and if we had a 1.1 and
22 that was 900, and we could -- then you could see that
23 the squared is giving us the --

24 CHAIR ABDEL-KHALIK: That would be great.
25 In other words, comparing apples to apples.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HEAD: But then --

2 CHAIR ABDEL-KHALIK: In a sense that if
3 you are comparing the 2 versus the 1.5, then by gosh
4 use the right multiplier for the case of 1.5.

5 CONSULTANT WALLIS: But then you would
6 have to go back and run your computer code with a loss
7 factor depending on 1.5 and not with just a K.

8 MR. HEAD: Right.

9 MR. VAN HALTERN: Right.

10 CONSULTANT WALLIS: And that --

11 CHAIR ABDEL-KHALIK: And again, which one
12 is the more appropriate?

13 MR. VAN HALTERN: We think 2 is more
14 appropriate.

15 CHAIR ABDEL-KHALIK: Okay.

16 MEMBER SHACK: Well, that is a different
17 argument, I mean, you know, but if it turns out that 2
18 is more conservative than 1.5, we won't have any more
19 discussion.

20 MR. VAN HALTERN: Right.

21 MEMBER SHACK: If it turns out that 1.5 --
22 then we come back to the argument of which is the more
23 appropriate? You could hope that the answer will be
24 the two have come up with --

25 CONSULTANT WALLIS: But I think it doesn't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 make any difference to the criterion for the 9.95
2 percent void or whatever you are using for the limits
3 there.

4 MR. VAN HALTERN: That's the same, right.

5 CONSULTANT WALLIS: The critical condition
6 worked out to be the same, but the margin will be
7 different, because you are on a different curve.

8 MR. VAN HALTERN: And I knew that there
9 would be some variation and that there could be some
10 various -- and because you are going into,
11 essentially, a condition where your rod friction is
12 laminar, okay, where your exponent -- your
13 relationship to pressure drop to flow is almost
14 linear.

15 Okay. And if you don't have high losses
16 at your grids and at your form losses, then that
17 becomes more dominant and that's why you may get an
18 exponent smaller, you know, that is closer to 1.

19 But if you put a very high restriction in
20 your form losses, then that's going to dominate.

21 CHAIR ABDEL-KHALIK: I think this issue
22 will remain open.

23 MR. HEAD: Okay.

24 CHAIR ABDEL-KHALIK: You know what the
25 question is?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. HEAD: I believe we have a point going
2 on.

3 CHAIR ABDEL-KHALIK: Okay. Right. Thank
4 you.

5 MR. HEAD: So we are going on to 47. This
6 is Action Item #47. We view this one as sort of the
7 one that covers the entire long-term cooling. Two
8 points I wanted to make on it.

9 The way it is written, it was to provide
10 downstream test procedure to ACRS and then all the
11 briefings, I think, we have shown you actually how we
12 are going to do, you know, the future work in the out
13 years. And so I would -- was hoping you would agree
14 that that aspect of it is not something you are going
15 to see as part of this proceeding.

16 And then I was going to ask if had closed
17 all of the open items, as to whether we had, in fact,
18 closed the entire long-term cooling issue. But since
19 we still have one that is open, then, you know, that
20 aspect is moot.

21 So if I could at least get agreement that
22 we are not going to be providing you any test
23 procedures, then that aspect of the action item is --
24 we won't have to come back and revisit.

25 CHAIR ABDEL-KHALIK: Let me just go around

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and see how people feel about this.

2 MR. HEAD: I mean, we -- in our previous
3 discussions, we have shown you how we are going to use
4 operating experience. We are going to be working with
5 the owner's group, other -- you know, the industry.

6 CHAIR ABDEL-KHALIK: Industry, to be
7 determined.

8 MR. HEAD: And so those test procedures
9 will be built years from now literally.

10 CHAIR ABDEL-KHALIK: Yes.

11 MR. HEAD: And so --

12 CHAIR ABDEL-KHALIK: I mean, right.

13 MR. HEAD: -- provided to the NRC.

14 MEMBER ARMIJO: I don't think they would
15 mean anything if you gave them to us now anyway.

16 CHAIR ABDEL-KHALIK: Yes.

17 MR. HEAD: Well, yes, sir. I mean, that's
18 just the way it was captured at early on discussions
19 and so we have carried it through. So I wanted to
20 address that aspect of it. And like I said, if we
21 closed all the open items today, then we would suggest
22 maybe this one could be closed or at least that we
23 have done all the actions that we needed to do.

24 And so right now, I would say we have
25 still got to come back and visit on #80. And so if we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 can just get agreement that we are not going to be
2 doing that last sentence and that's all we want to do.

3 CONSULTANT WALLIS: Well, I just have a
4 comment.

5 MR. HEAD: Sure.

6 CONSULTANT WALLIS: I mean, I don't think
7 that the test procedures should be set in concrete.
8 When you start doing the tests, if you find something
9 important, you don't blindly follow some procedure
10 which ignores that thing that was important.

11 MR. HEAD: I agree.

12 CONSULTANT WALLIS: So that I don't think,
13 you know, test procedure just the beginning, you said
14 we are going to do this stuff, but then you start
15 finding things out.

16 MR. HEAD: Yes, sir.

17 CONSULTANT WALLIS: So it's a very fluid
18 situation. And I don't think we can do anything about
19 it today.

20 MR. HEAD: I'm sure we --

21 CONSULTANT WALLIS: But I just wanted to--

22 MR. HEAD: Actually, back when this was
23 written earlier on, you know --

24 CONSULTANT WALLIS: I want to be sure that
25 you don't say we will do 10 tests and if the 10 tests

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 turn out to be so anomalous that they are meaningless,
2 that you then stop.

3 MR. HEAD: I think we discussed that at an
4 earlier meeting also.

5 CONSULTANT WALLIS: Because that's all I
6 wanted to be sure about.

7 MR. HEAD: Yes, okay. All right. So I
8 think we are finished with that one.

9 So I believe, you know, we need to -- we
10 will come back at a later time and provide some more
11 information with respect to Action Item #80.

12 CHAIR ABDEL-KHALIK: Correct.

13 MR. HEAD: And I believe #98 and #99 have
14 -- we have appropriately addressed. Okay. We are
15 done with this one then, right? Okay.

16 CHAIR ABDEL-KHALIK: Okay. Are there any
17 additional questions to the applicant? Okay.

18 CONSULTANT WALLIS: Do you have the
19 summary slide, do you or something?

20 CHAIR ABDEL-KHALIK: The summary slide I
21 guess, you know, you don't want to go through that,
22 because Item #2 is --

23 CONSULTANT WALLIS: Right.

24 CHAIR ABDEL-KHALIK: -- still to be
25 demonstrated.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CONSULTANT WALLIS: Well, Item #1 wasn't
2 shown either.

3 MR. HEAD: I think it was.

4 CONSULTANT WALLIS: Well --

5 MR. HEAD: Okay.

6 CHAIR ABDEL-KHALIK: Maybe the wording is
7 not exactly the right wording.

8 CONSULTANT WALLIS: Yes.

9 CHAIR ABDEL-KHALIK: But with help from
10 the --

11 MEMBER STETKAR: The transcript of this
12 meeting, I think --

13 CHAIR ABDEL-KHALIK: Right.

14 CONSULTANT WALLIS: Now, what's the
15 meaning of #3? I thought you showed that more boron
16 zinc were precipitated than you had expected?

17 MR. VAN HALTERN: That the testing
18 accounts for all --

19 CONSULTANT WALLIS: The testing accounts
20 for -- will account for all of that?

21 MR. VAN HALTERN: Yes, sir.

22 CONSULTANT WALLIS: Okay.

23 MR. VAN HALTERN: Okay.

24 CHAIR ABDEL-KHALIK: Okay.

25 MR. HEAD: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR ABDEL-KHALIK: Thank you.

2 MR. HEAD: Thank you.

3 CHAIR ABDEL-KHALIK: Our agenda calls for
4 a 15 minute break, so let's take a 15 minute break.
5 We will reconvene at 10:20.

6 Whereupon, at 10:03 a.m. a recess until 10:20 a.m.
7 (Then the meeting went into a closed session |^)\↔↔

8 10:29 a.m. CHAIR ABDEL-KHALIK: Yes.

9 MR. HEAD: Yes, this will be our
10 presentation on Extended Station Blackout capability
11 with respect to the ABWR and specific aspects of Units
12 3 and 4. Our attendees today all have briefed the
13 ACRS before.

14 Before we -- I turn it over to Steve, I
15 would like to make a -- what we are going to talk
16 about today is our licensing basis capabilities of the
17 ABWR and some specific aspects with respect to 3 and
18 4.

19 Obviously, the industry, the NRC, the
20 owner's group, different applicants are evaluating or
21 contemplating potential changes or enhancements or
22 design changes that -- procedural changes that might
23 come out of the lessons learned with respect to
24 Fukushima.

25 The point I would like to make with this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 discussion, if we go into those, is that, at this
2 point in time, for us as with everyone those are
3 basically speculative as to what we would be doing.
4 We will describe, you know, our licensing basis and we
5 are more than happy to talk about other things, but I
6 just want to make -- get on the record that those
7 would be, at this point in time, speculation. And we
8 look forward to the regulatory process ultimately, you
9 know, driving towards, you know, the actions that we
10 need to take. Okay?

11 CHAIR ABDEL-KHALIK: Understood.

12 MR. HEAD: All right. Thank you very much
13 for that. I'll turn it over to Steve.

14 MR. THOMAS: All right. Thanks, Scott.
15 Yes, I'm Steve Thomas. I'm the NINA Engineering
16 Manager for STP Units 3 and 4. I'm trying to think,
17 yes, we're on slide 3.

18 MS. BANERJEE: Hold on one second, please,
19 because the line is not open yet.

20 CHAIR ABDEL-KHALIK: Okay. The line is
21 not open. Is Dennis on the line?

22 UNIDENTIFIED SPEAKER: Dennis should be
23 here.

24 MS. BANERJEE: Dennis is on the line. He
25 is separate.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR ABDEL-KHALIK: Okay.

2 MEMBER BLEY: I am on line.

3 CHAIR ABDEL-KHALIK: Okay. And for the
4 public line, that's not open yet?

5 MS. BANERJEE: So bear with me here.

6 CHAIR ABDEL-KHALIK: Okay. We'll just
7 hold on.

8 MR. THOMAS: Sure.

9 MS. BANERJEE: Yes, it is confirmed now.

10 CHAIR ABDEL-KHALIK: Okay. Is there
11 anybody on the line? Any member of the public, if so,
12 please, just let us know, make a noise of some sort.

13 MEMBER SHACK: It's one-way.

14 CHAIR ABDEL-KHALIK: Oh, it is one-way?

15 MEMBER SHACK: Yes. Yes, they are muted.

16 MS. BANERJEE: Yes, they cannot.

17 CHAIR ABDEL-KHALIK: Oh, okay.

18 MS. BANERJEE: They can hear us, but they
19 can't --

20 CHAIR ABDEL-KHALIK: Okay. Go ahead,
21 please.

22 MEMBER SHACK: They are jumping and
23 shouting right now and we can't hear them.

24 CHAIR ABDEL-KHALIK: Pretty frustrated.

25 MR. THOMAS: As you know, one of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 unique design features of the ABWR is the combustion
2 turbine generator. That's a very significant, very
3 significant, and important piece of equipment. And
4 the primary means by which the ABWR design deals with
5 Station Blackout is with the combustion turbine
6 generator. We are going to move past that in just a
7 minute.

8 CONSULTANT WALLIS: Will you give us its
9 kilowatt rating or something?

10 MR. THOMAS: 20 megawatts.

11 CONSULTANT WALLIS: 20 megawatts. Thank
12 you. 20 megawatts?

13 MR. THOMAS: Yes, sir.

14 CONSULTANT WALLIS: It's big.

15 MR. THOMAS: That's a small fraction of a
16 Small Modular Reactor. And there is one region.

17 The combustion turbine generator is flood-
18 protected and protected from external weather events.

19 It is completely independent of the three emergency
20 diesel safety trains. It has a black start
21 capability. There is a small separate little diesel
22 generator to start the combustion turbine generator
23 without any external power supply.

24 It is capable of reaching rated speed and
25 voltage and available for loading within 10 minutes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And it can supply the ESF safety related 1E 4160 volt
2 buses through a realignment of preselective breakers.

3 Of course, normally since it is a non-safety related
4 piece of equipment, it complies with the strict
5 separation between safety and non-safety equipment and
6 divisional separation requirements.

7 So again --

8 CHAIR ABDEL-KHALIK: Physically, how far
9 is it located?

10 MEMBER BLEY: What's its fuel?

11 MR. THOMAS: It is basically diesel fuel,
12 fuel oil.

13 CHAIR ABDEL-KHALIK: Physically, how far
14 is it --

15 MEMBER BLEY: Does it come on separate
16 trucks from the diesel fuel oil that goes into the
17 tanks for diesels?

18 MR. THOMAS: Presumably, it would come
19 from separate trucks, yes.

20 MEMBER BLEY: Presumably or is there some
21 assurance to that?

22 MR. THOMAS: I don't know that --

23 MEMBER BLEY: There is a possible
24 dependency here.

25 MR. THOMAS: There is a requirement that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it has separate fuel storage facilities, so if a truck
2 comes in, it is sampled and then the tanks are sampled
3 and so there is separation between the fuel supply for
4 the diesels and the fuel supply for the CTGs.

5 MEMBER BLEY: So it's coming in on the
6 same truck.

7 MR. THOMAS: Theoretically, I suppose it
8 could.

9 MEMBER BLEY: Okay.

10 MR. THOMAS: But it would be tested
11 separately.

12 CHAIR ABDEL-KHALIK: Does that answer your
13 question, Dennis?

14 MEMBER BLEY: It answers my question. So
15 at least there is some kind of dependency here. It's
16 not totally input.

17 CHAIR ABDEL-KHALIK: Okay.

18 MR. THOMAS: I understand your point. So
19 again, this is a very significant and important piece
20 of equipment. In light of events in the industry
21 right now, I think some of the questions that we are
22 asking are what if this doesn't work?

23 This was considered in the original ABWR
24 design certification document and the material I'm
25 going to summarize for you today is in the design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 certification document, Chapter 19(e) and I'm just
2 going to kind of go through the scenario that is
3 evaluated there for a Station Blackout, what we are
4 calling an extended Station Blackout situation,
5 basically, a station blackout, how the ABWR respond to
6 that without the combustion turbine generator.

7 MEMBER SHACK: This is not seismically-
8 qualified though, right?

9 MR. THOMAS: It is not.

10 MEMBER SHACK: Steve, is it in a seismic-
11 qualified building?

12 MR. THOMAS: It is not.

13 MEMBER STETKAR: And that 10 minute
14 response time is based on manual operator actions to
15 start the combustion segment?

16 MR. THOMAS: It will automatically start
17 on loss-of-power --

18 MEMBER STETKAR: Oh.

19 MR. THOMAS: -- and realign itself to the
20 non-safety buses.

21 MEMBER STETKAR: But the operators have to
22 strip loads, if I recall, to --

23 MR. THOMAS: The operators would have to
24 de-energize those loads and realign breakers to align
25 the combustion turbine generator to the safety buses,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that's correct.

2 MEMBER STETKAR: Okay. Thanks.

3 MEMBER ARMIJO: Is it in a separate
4 building on the site?

5 MR. THOMAS: As stated in the DCD, the
6 combustion turbine generator is located in the turbine
7 building.

8 MEMBER ARMIJO: In the turbine building?

9 MR. THOMAS: In the turbine building.

10 MR. HEAD: Which is a 2-over-1 structure
11 and there is some, even though it's not seismic,
12 obviously, we could do some studies and define the
13 possibility of it surviving different seismic events.

14 MR. CHAPPELL: And there is a Tier 1
15 requirement that it not be located in the same
16 building as the diesel generators, which is the
17 reactor building.

18 MR. THOMAS: Yes. So let's consider that
19 case. Again, on Slide 4 now, even without the
20 combustion turbine generator, if we assume a loss of
21 off-site power, a loss of all three safety trains of
22 diesel generators and the loss of the alternate ac
23 power source, the combustion turbine generator, we
24 also have two of these and they -- which is different
25 from the DCD design.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 But in the COLA we say that there are two
2 of these, one for each unit. And there is a cross-
3 connection capability. But again, we are not going to
4 take credit for that capability. We are going to
5 assume that both combustion turbine generators are
6 unavailable, perhaps we have an event in both units.

7 And in this beyond Design-Basis scenario,
8 the ABWR has several defense and depth features, which
9 provide the capability to prevent fuel damage and
10 maintain containment integrity and that's what we
11 would like to walk through here briefly.

12 In this event, the reactor core isolation
13 cooling, the RCIC turbine pump is assumed to operate
14 for eight hours and maintain core coverage and permit
15 core damage.

16 Now, if, at that point, ac power is still
17 unavailable, we assume that, in the analysis, the
18 reactor core isolation cooling is no longer available.

19 We think that it probably would be, but the analysis
20 assumes that after eight hours RCIC is no longer
21 available. And the operator then switches to ac-
22 independent water addition system to maintain core
23 level.

24 And then the containment over pressure
25 protection system or COPS system, this is the hardened

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 vent system for the ABWR which prevents the loss of
2 containment integrity.

3 CHAIR ABDEL-KHALIK: Now, what sets the
4 eight hours for your case?

5 MR. THOMAS: There is really no specific
6 requirement.

7 CHAIR ABDEL-KHALIK: It's not a
8 requirement.

9 MR. THOMAS: No specific limit.

10 CHAIR ABDEL-KHALIK: What is the
11 constraint that makes it eight hours?

12 MR. THOMAS: Again, no specific
13 constraint. The requirement in the DCD is that we
14 will perform an analysis that looks at the
15 environmental conditions in the RCIC room and make
16 sure that those conditions still are capable of
17 supporting RCIC operation.

18 CHAIR ABDEL-KHALIK: What does that
19 analysis tell you?

20 MR. THOMAS: That analysis is something
21 that needs to be done as part of the detailed design.
22 It has not been done at this point.

23 CHAIR ABDEL-KHALIK: So you really don't
24 know how long it takes for that room to heat up to
25 whatever the temperature qualification of whatever

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 equipment you have in that room?

2 MR. THOMAS: That's correct. For eight
3 hours, that's correct.

4 MR. HEAD: But as part of that, we would
5 probably be defining other actions that we could take
6 to ensure, you know, opening doors and other things
7 that we could take to, you know, even get past eight
8 hours.

9 CHAIR ABDEL-KHALIK: Right, right. In a
10 sense that, you know, you don't have active cooling,
11 you will open doors or whatever to try to lengthen
12 that time period.

13 MR. THOMAS: Correct.

14 CHAIR ABDEL-KHALIK: Before you get to
15 that temperature limit for room heat up.

16 MR. THOMAS: And again, I want to point
17 out that the eight hours was just an assumption. It's
18 just so here is a period of time and since we are
19 assuming this in this analysis, then we have the
20 requirement to confirm the environmental conditions
21 for eight hours.

22 I think that probably when we do that, we
23 will be able to demonstrate that the RCIC turbine pump
24 is capable of operating for a considerably longer
25 period of time than eight hours. We have had some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 discussions with the vendor that would lead us to that
2 discussion. But, at this point in time, we have not
3 determined the specific limitation.

4 MEMBER STETKAR: Steve?

5 MR. THOMAS: Yes, sir?

6 MEMBER STETKAR: Yes, please, excuse me
7 because I get mixed up on all of the details of the
8 designs. This RCIC turbine is the one that basically
9 has two flow setpoints. Is that right?

10 MR. THOMAS: That's correct.

11 MEMBER STETKAR: And on loss of dc power,
12 it reverts to the low flow setpoint. Is that correct?

13 MR. THOMAS: Um, I'm not sure that that's
14 right. I think you -- I think dc power is required to
15 switch it from the high setpoint to the low setpoint.

16 MEMBER STETKAR: Right. So it will
17 maintain the high? Is that --

18 MR. THOMAS: That's correct. That's one
19 of the things I was trying to remember the design and
20 which way it went on loss of dc power. It's normally
21 on the high setpoint.

22 MEMBER STETKAR: Normally on the high
23 setpoint.

24 MR. THOMAS: And there is a dc solenoid
25 that is required to extract the load --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: To switch it to the lower
2 setpoint. So on loss of dc -- I'm thinking about
3 after two hours. If it were on the low setpoint, it
4 would revert to the high setpoint at that time, right?

5 MR. DALEY: You would have to manually
6 switch it.

7 MEMBER STETKAR: No, I'm thinking about if
8 it had throttled back -- I don't know how the control
9 system works on it in that level of detail. It starts
10 off at high flow. I don't know what switches it to
11 low flow. What tells the system it is going to now go
12 to its low flow condition. I don't know whether it
13 is --

14 MR. DALEY: Are you energizing a dc
15 solenoid?

16 MEMBER STETKAR: I understand switching
17 logic. I don't understand the control logic. When in
18 geologic time would some signal come in to say okay,
19 turbine you need to go to low flow?

20 MR. DALEY: Manual.

21 MEMBER STETKAR: It would be manual.

22 MR. DALEY: Manual switch.

23 MEMBER STETKAR: Oh, it's strictly manual.

24 MR. DALEY: Correct. That's the only
25 driven manual operation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Okay. Thanks, thanks,
2 thanks. So it will stay at high flow basically.

3 MR. DALEY: Right.

4 MEMBER STETKAR: Unless the -- but if the
5 operators do set it to low flow, which they may very
6 well do, because you are going to be overfilling --

7 MR. DALEY: Right.

8 MR. THOMAS: Correct.

9 MEMBER STETKAR: -- it will go back to
10 high flow and fill you up faster?

11 MR. CHAPPELL: Now, that's assuming a loss
12 of all dc.

13 MEMBER STETKAR: Dc.

14 MR. CHAPPELL: And we also, as Steve
15 alluded to, have some things to look at to extending
16 the time to eight hours and beyond. And part of that
17 is to extend the life of the Division 1 batteries.

18 MEMBER STETKAR: Oh, the Division 1
19 batteries are only two hours.

20 MR. CHAPPELL: Right. There is actions to
21 take under these types of situations to look at
22 extending those lives under these conditions to --

23 MEMBER STETKAR: Get out to eight hours.

24 MR. CHAPPELL: -- extend out and using
25 manual operations and other options to do so. So we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 would be cognizant of the limitations of the battery
2 and cognizant of what could happen under the
3 conditions where you have the highest flow setting for
4 RCIC injection.

5 MR. HEAD: Which is what plants do now.

6 MEMBER STETKAR: I'm just thinking of
7 getting into a situation of, you know, cycling the
8 thing on and off a lot.

9 MR. CHAPPELL: We had a few action items
10 associated with that and I think we showed in the
11 analysis that even if you did nothing, it was about
12 four times.

13 MEMBER STETKAR: Yes. Okay. Thanks.
14 Some of this is trying to refresh my memory on the
15 design.

16 MEMBER SHACK: So just to come back, if
17 it's in low flow and you lost dc power, you can get
18 back to high flow?

19 MEMBER STETKAR: It will go back to high
20 flow.

21 MEMBER SHACK: It will go back?

22 MEMBER STETKAR: It's an internal
23 pneumatic little thing.

24 MEMBER SHACK: Okay.

25 MEMBER BROWN: So you don't have to -- I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 thought he said you had to manually select it back to
2 high flow and then that's what confused me.

3 MEMBER STETKAR: That is --

4 MR. CHAPPELL: You manually select it to
5 the half flow setting and then you can manually take
6 it back to the full flow setting. But if you lose
7 power, dc power, it just fails to the high flow
8 setting.

9 MEMBER BROWN: Oh, okay. All right. I'm
10 sorry. I misinterpreted that.

11 MEMBER STETKAR: If I remember, there is a
12 little solenoid and kind of an internal hydraulic
13 thing that sets the flow setting.

14 MEMBER BROWN: I just -- it's a mechanical
15 way to mechanical just fails to the other position. I
16 just -- that wasn't what I got out of that.

17 MEMBER STETKAR: I couldn't remember which
18 way it went when you lost dc power. That's what I
19 forgot. Thanks.

20 MR. THOMAS: Okay. And again, the --

21 CHAIR ABDEL-KHALIK: When would you expect
22 to do that RCIC room heat up analysis?

23 MR. THOMAS: I'm sorry?

24 CHAIR ABDEL-KHALIK: When would you expect
25 to do that RCIC room heat up analysis?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. THOMAS: Probably when we, again, do
2 the detailed design, get the final design information
3 from the vendor after the equipment is procured and
4 get, you know, their heat loads and things, the final
5 piping runs and so forth, so you can calculate the
6 heat inputs to the room.

7 MEMBER BROWN: Well, doesn't this scenario
8 -- though it's whether it operates for four hours or
9 eight hours, doesn't this scenario play the same way
10 or is there a dependency on the eight hours to achieve
11 some downstream cooling effects?

12 MR. THOMAS: Ah, not really.

13 MEMBER BROWN: Maximum temperature.

14 MR. THOMAS: No.

15 MEMBER BROWN: So whether --

16 MR. THOMAS: I think if they can see --

17 MEMBER BROWN: Your analysis comes out of
18 four hours as opposed to eight hours or more for the
19 RCIC. You -- the scenario --

20 MR. THOMAS: The scenario could be played
21 out that way as well, yes, sir.

22 MEMBER BROWN: Okay. With no change in
23 the end result?

24 MR. THOMAS: It would actually be a better
25 end result, but if you initiated ac-independent water

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 addition earlier and some other things, it would
2 probably be a better result.

3 MEMBER BROWN: Okay. All right. Thank
4 you.

5 MR. THOMAS: That accident sequence,
6 again, is -- provided the reference here in the DCD
7 where this is discussed.

8 MEMBER BROWN: When you boil the rupture
9 disc, you say it prevents loss of containment
10 integrity?

11 MR. THOMAS: Yes.

12 MEMBER BROWN: Where is it boiling off to?

13 MR. THOMAS: This is venting through the
14 stack.

15 MEMBER BROWN: Outside?

16 MR. THOMAS: Yes.

17 MR. CHAPPELL: That is scrubbed.

18 MR. THOMAS: And scrubbed.

19 MEMBER BROWN: Scrubbed?

20 UNIDENTIFIED SPEAKER: From the wet load
21 side.

22 MEMBER BROWN: So it is effectively open
23 through the scrubbers?

24 MR. THOMAS: Essentially open containment.

25 You do have the ability to isolate that with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 isolation valves for that system. The containment
2 over-pressurization system isolation valves and this
3 is somewhat different than the current vintage of
4 design for these hardened vents.

5 Some of the earlier ones, I know that I
6 have looked at, have gone to great actions to prevent
7 initiation of this system. It requires a positive
8 action on the operator's part to open isolation
9 valves.

10 MEMBER BROWN: Okay.

11 MR. THOMAS: To then allow the ruptured
12 disc to open.

13 MEMBER BROWN: So these are open during
14 operation?

15 MR. THOMAS: These isolation valves are
16 normally open. They fail open and as a consequence,
17 we have a somewhat higher set pressure for those
18 rupture discs than some of the earlier designs. But
19 again, if the ruptured disc opens, at some later time,
20 it would require dc power and pneumatic power to close
21 those isolation valves, to close that vent path. But
22 again, the containment has not ruptured.

23 MEMBER BROWN: But you are blowing up to
24 the atmosphere?

25 MR. THOMAS: You are venting to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 atmosphere.

2 MEMBER BROWN: Okay. I just wanted --

3 MR. THOMAS: After scrubbing through the
4 suppression.

5 MEMBER BROWN: Media of integrity is sort
6 of what you're saying.

7 MR. THOMAS: That's a good question.

8 MEMBER BROWN: Thank you.

9 MR. THOMAS: On Slide 6, this is a summary
10 of a table in the DCD. Just to kind of quickly walk
11 you through this scenario, of course, following
12 initial loss of off-site power, the reactor scrams and
13 main steam isolation valves close in a very short
14 order.

15 Approximately, 52 seconds into this
16 scenario, as the reactor level begins to decrease, to
17 lower, at Level 2, the RCIC system automatically
18 initiates injection. Steam is discharged through the
19 safety relief valves to the suppression pool and this
20 cycle continues. RCIC making up core inventory.

21 Again, eight hours, we assume that RCIC is
22 no longer available and fails. This particular
23 analysis assumes a considerable period of time, at
24 this point, for the operator to realize what is going
25 on, realize he is not going to get ac power back and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 then align the ac-independent water addition system
2 and depressurize with the safety relief valves.

3 And the analysis then assumes that at 9.8
4 hours, 1.8 hours after RCIC is assumed to be lost,
5 that water level -- the injection begins and level is
6 eventually restored.

7 MEMBER BROWN: So the manual operations to
8 get you lined up, you had done some type of a human
9 hand-eye coordination, people got to go places to do
10 things or is it all done from the control room?

11 MR. THOMAS: It requires some manual
12 operator action. Again, going to the ac-independent
13 water addition system, normally, that would be from a
14 diesel generator fire pump.

15 MEMBER BROWN: So you have to line stuff
16 up?

17 MR. THOMAS: You would have to line stuff
18 up. That would not --

19 MEMBER BROWN: Did you walk through? I
20 mean, I presume the 1.8 hours, you have made an
21 assumption as to when that comes on-line?

22 MR. THOMAS: We have not done that. That
23 is just an assumption that was used in this analysis.

24 MEMBER BROWN: So it has to be -- it would
25 have to be verified?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. THOMAS: It would have to be verified
2 at some point in time. Again, I think it is a pretty
3 conservative period of time, but we haven't done time-
4 motion studies to --

5 MEMBER STETKAR: This is while they are
6 hooking up the batteries with the jumper cables, so
7 that they can get the --

8 MR. THOMAS: Well, at this point, I don't
9 know that that would necessarily be required. I mean,
10 you would have to have, basically, one safety relief
11 valve to depressurize.

12 MEMBER STETKAR: Batteries are dead.

13 MR. THOMAS: Correct.

14 MR. DALEY: And as Coley mentioned in
15 response to Action Item #100, we will develop
16 procedures and walk through those procedures by
17 operations as well.

18 CONSULTANT WALLIS: This water level type
19 of active fuel, that's the expanded water level?
20 That's not the collapsed water level?

21 MR. THOMAS: Yes.

22 CONSULTANT WALLIS: It's the expanded
23 water level, which is a little bit uncertain, because
24 it voids in there, isn't it? It's 9.9 hours?

25 MR. THOMAS: I don't have the details of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the computer analysis.

2 CONSULTANT WALLIS: I was just wondering
3 how soon. You've got to get water injection pretty
4 soon after that, presumably. I don't see how those
5 two events are related there. You've got to
6 depressurize enough to get the water injection.

7 MR. THOMAS: Correct.

8 CONSULTANT WALLIS: Before the expanded
9 water level falls below the top of active fuel.

10 MR. THOMAS: Not necessarily. In fact,
11 the analysis assumes that the water level does go
12 below top of active fuel.

13 CONSULTANT WALLIS: So what do you mean by
14 water level then? It's boiling and splashing and
15 stuff, I'm not quite sure what you mean by water --

16 MR. THOMAS: I'm assuming it means the
17 liquid water level.

18 CONSULTANT WALLIS: The collapsed water
19 level or the single phase water level or what?

20 MR. THOMAS: I believe it means the single
21 phase water level. There is, of course, boiling
22 taking place at this time.

23 CONSULTANT WALLIS: Okay.

24 MR. THOMAS: And as the water level drops
25 below top of active fuel, you still are getting some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 cooling from steaming going past the fuel.

2 MR. CHAPPELL: This is based on an
3 analysis, so they used calculated volumes in the
4 vessel and they determined where the level of the
5 bottom of active fuel and the top of active fuel.

6 CONSULTANT WALLIS: So there is some
7 assurance that the water injection will begin only
8 enough before the water level is too low to cause
9 damage?

10 MR. THOMAS: That's correct.

11 CONSULTANT WALLIS: All right.

12 MR. THOMAS: And we will show that here in
13 just a second on the next slide.

14 CONSULTANT WALLIS: Okay.

15 MR. THOMAS: And then, approximately, 32
16 hours --

17 CHAIR ABDEL-KHALIK: Is there a question?
18 Okay.

19 MR. THOMAS: Approximately, 32 hours after
20 -- into this event, the containment over-pressure
21 protection system rupture disc ruptures and
22 containment pressure, you know, rapidly reduces at
23 that point in time. There are several plots from the
24 computer analysis shown in Chapter 19 for this event.

25 We have just picked two of them out here

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 basically.

2 CHAIR ABDEL-KHALIK: What is the setpoint
3 for this containment forward pressure?

4 MR. THOMAS: It's .72 megapascals or about
5 90 pounds.

6 CHAIR ABDEL-KHALIK: 90 pounds.

7 MR. THOMAS: I've got my cheat notes here.

8 CHAIR ABDEL-KHALIK: So it's roughly seven
9 atmospheres?

10 MR. THOMAS: Yes.

11 CHAIR ABDEL-KHALIK: Okay.

12 MR. THOMAS: On the next sheet, this just
13 shows the plot of the fuel temperature throughout this
14 transient. As you can see, when RCIC injection
15 ceases, you get a pretty significant spike in fuel
16 temperature. The peak is 1610 degrees from the
17 analysis, which is below the -- it's the level at
18 which we anticipate fuel damage.

19 And once alternate ac-independent water
20 addition begins and the core is recovered, the fuel
21 temperature rapidly comes back down.

22 What is interesting from this graph is
23 apparently from -- it should be readily apparent that
24 after this begins, the fuel temperature remains
25 relatively steady state for a considerable period of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 time.

2 Likewise on the next sheet, if you look at
3 containment pressure, when RCIC fails, of course,
4 containment pressure starts to increase pretty
5 dramatically until the rupture disc opens again at 90
6 pounds. It decreases rapidly and again approaches
7 equilibrium for a considerable period of time.

8 CONSULTANT WALLIS: So this just -- excuse
9 me. This Slide 7 is responding to my question, isn't
10 it? This is over-raced, but we getting the firewater
11 going and the water level falling in the vessel?

12 MR. THOMAS: Yes, sir.

13 CONSULTANT WALLIS: And that is what is
14 shown by this spike?

15 MR. THOMAS: Yes, sir.

16 CONSULTANT WALLIS: Okay. So it's pretty
17 important that things do happen on time?

18 MR. THOMAS: Absolutely.

19 CONSULTANT WALLIS: All right.

20 MR. THOMAS: One of -- this analysis
21 assumes that -- a considerable delay.

22 CONSULTANT WALLIS: Right. This is a
23 conservative sort of thing? Because the operator
24 seems to be doing something just before the water
25 level falls beyond top of active fuel. And you would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 think they might do it before that.

2 MR. THOMAS: You would think so.

3 CONSULTANT WALLIS: Yes.

4 MR. CHAPPELL: Well, they would. I mean,
5 you're talking about lining up the ac-independent
6 water addition system and you would already be doing
7 that and determining the appropriate time to
8 depressurize the vessel.

9 And another consideration in the analysis
10 is that it assumes the depressurization from rated
11 reactor pressure, whereas other options are to reduce
12 pressure in order to minimize the time before the
13 injection.

14 CONSULTANT WALLIS: So --

15 MEMBER STETKAR: We understand. Yes, I
16 mean, that spike would look a lot more -- a lot
17 different if --

18 MR. CHAPPELL: Very much --

19 MEMBER STETKAR: -- the operators try to
20 control the depressurization.

21 MR. THOMAS: If they were anticipating
22 this event --

23 MR. CHAPPELL: That's right.

24 MR. THOMAS: -- you would expect a much
25 less severe transient.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CHAPPELL: The minimum pressure at
2 which you can operate RCIC is very near the shutoff of
3 the ac-independent water addition pump. So,
4 conceivably, you could have a much smoother transition
5 than what is shown here in the analysis.

6 MR. HEAD: These are out of the DCD,
7 right?

8 MR. CHAPPELL: This is what was provided
9 in the DCD, right.

10 MR. HEAD: Okay.

11 MEMBER STETKAR: This presumes that you
12 are at the safety valve, the relief valve setpoint and
13 then you blow it down.

14 MR. CHAPPELL: That the operators are
15 manually controlling reactor pressure at about 1000
16 pounds.

17 CHAIR ABDEL-KHALIK: Rather than sort of
18 hanging at the lowest setpoint of the SRV.

19 MR. CHAPPELL: The depressurizing and
20 operating at a lower pressure band which does a lot of
21 things in terms of --

22 MEMBER STETKAR: Well, when you say
23 manually controlling, you are basically limited to
24 whatever scheme RCIC is pulling off and whatever the
25 relief valve setpoints are.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CHAPPELL: My understanding for the
2 analysis is that RCIC steam alone will not maintain
3 that the operators will have to periodically use
4 operation of SRVs to maintain a pressure band.

5 CHAIR ABDEL-KHALIK: So they --

6 MEMBER BLEY: Can I ask a question?

7 CHAIR ABDEL-KHALIK: -- would
8 automatically open.

9 MR. CHAPPELL: If you were at a high
10 setpoint.

11 MEMBER BLEY: Looking at Slide 6, which
12 lays things out, and then it's your Slide 7 with the
13 pictures, those things don't seem exactly aligned with
14 each other.

15 MR. CHAPPELL: No.

16 MEMBER BLEY: The analogy in the picture
17 assumes some different timing than on the previous
18 slide? I mean, over there it's eight hours, RCIC
19 failed. Almost two hours later, the operator lines up
20 the ACIWA and depressurizes the vessel. And it seems
21 not quite aligned with what we are seeing on the
22 analysis picture.

23 CHAIR ABDEL-KHALIK: Slide 7.

24 MR. CHAPPELL: That's eight hours on ten.

25 MR. THOMAS: Yes. I'm not sure that the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pressure entirely, you know, scientifically is
2 accurate grasp. But the intent is and the analysis
3 assumes that these time sequences follow.

4 MEMBER STETKAR: I suspect that RCIC fails
5 should be moved to the left where the little hook is
6 and that fuel temperature remains constant because you
7 are just boiling off through the relief valves --

8 MR. THOMAS: Yes.

9 MEMBER STETKAR: -- for that period of
10 time.

11 MR. THOMAS: That makes sense.

12 MEMBER STETKAR: And when you
13 depressurize, you are now losing mass and starting to
14 uncover fuel, which is why your fuel temperature goes
15 up and spikes until you start getting injection. I
16 suspect that's what that transient is trying to tell
17 us.

18 MEMBER BLEY: That sounds reasonable. I
19 guess I'm trying to read too much into that figure.

20 MEMBER STETKAR: Yes. I think the reason
21 it's flat there, you know, from eight hours to ten
22 hours is you are just -- you filled -- it probably
23 presumes you are full from RCIC and you just basically
24 -- that's boil off at whatever that decayed heat is
25 through the relief valves.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 If you saw primary pressure applied, it
2 probably would explain a lot of the reason that this
3 thing looks the way it does.

4 CONSULTANT WALLIS: And then the spike
5 goes on until after 10 hours, because it takes a bit
6 of time to depressurize to the point where --

7 MEMBER STETKAR: Yes, because it's a low
8 head injection.

9 CONSULTANT WALLIS: So it looks as if it
10 makes a difference of -- you know, if you move this
11 thing by 10 minutes one way or the other, you can
12 change that spike quite a bit.

13 MEMBER BLEY: That's what I was worried
14 about.

15 CONSULTANT WALLIS: Right.

16 MR. THOMAS: If we just go to the summary
17 slide on the next sheet, again, what we are calling an
18 extended loss of all ac or Station Blackout without
19 the combustion turbine generator, the capabilities of
20 the current ABWR design can be implemented to avoid
21 fuel damage and still maintain containment integrity
22 under these circumstances for a period of, on the
23 order of, 72 hours and probably longer.

24 I mean, the analysis was concluded at that
25 point in time, but our approaching equilibrium

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 conditions under these circumstances.

2 CHAIR ABDEL-KHALIK: So nothing here about
3 spent fuel pool. And I assume that the heat up time
4 for the spent fuel pool is greater than 72 hours?

5 MR. CHAPPELL: I have -- I'll get into
6 that on the next two slides.

7 MR. THOMAS: Perfect segue. Actually,
8 that was going to conclude my comments.

9 MEMBER STETKAR: I know ACIWA is part of
10 the -- can we talk about it in open session very much?

11 MR. THOMAS: I think so, yes.

12 MR. CHAPPELL: Yes.

13 MEMBER STETKAR: Is it not -- is the water
14 supply for that nominally minimum 72 hours? I don't
15 remember the water supplies and I didn't go back and
16 look at the design.

17 MR. THOMAS: I think -- you know, what we
18 haven't done is calculated -- do the decayed heat
19 calculations and -- quite to the volume -- I think the
20 inventory is 300,000 gallons minimum from that tank.
21 There are two tanks. We take credit for one.

22 CHAIR ABDEL-KHALIK: The minimum inventory
23 is what? I'm sorry.

24 MR. THOMAS: 300,000 gallons.

25 CHAIR ABDEL-KHALIK: 300,000 gallons.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. THOMAS: Again, there are two tanks.
2 We take credit for one.

3 CHAIR ABDEL-KHALIK: And the capacity of
4 those pumps is what?

5 MR. THOMAS: I had that. I'm not --

6 MR. DALEY: The fire pumps, really the
7 largest fire area are your transformers plus a hose
8 reel. So it's usually around 1,000 to 1,200 gpm.

9 MR. THOMAS: I think that's right.

10 MR. CHAPPELL: But there is a --
11 generally, for ac-independent water addition function,
12 you are talking about a 500 gpm injection rate.

13 CHAIR ABDEL-KHALIK: Okay. And that is
14 controllable?

15 MR. CHAPPELL: That's controlled, yes.

16 CHAIR ABDEL-KHALIK: Thanks.

17 MR. THOMAS: Okay. And there are some
18 other design features as I segue over to Coley and
19 address the spent fuel pool. There are some current
20 design features of the ABWR which provide us, again,
21 some defense and depth capabilities for spent fuel
22 pool makeup and I'll let Coley address those.

23 MR. CHAPPELL: And as Steve did, what I'll
24 start for fuel pool makeup is with the capabilities of
25 the ABWR and then walk through what is available if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the CTG is available and then without CTG.

2 So the fuel pool cooling and cleanup
3 system for the ABWR provides the normal removal of
4 decayed heat as well as filtration for the spent fuel
5 pool. There are connections. The suppression pool
6 cleanup system allows for makeup water using either
7 the suppression pool or the condensation storage tank.

8 The normal makeup supply is through these
9 interconnections from the condensate system. Either
10 the fuel pool cooling and cleanup system or the
11 suppression pool cleanup system can be powered by the
12 CTG power supply.

13 The ABWR standard design had two trains,
14 RHR, that were capable of providing Class 1E diesel-
15 powered makeup from the suppression pool to the spent
16 fuel pool, as well as augmented pool cooling.

17 The STP 3 and 4 application included a
18 Tier 1 departure to -- so that all three trains of
19 RHR, three different divisions, are capable of
20 providing this function.

21 Now, the reason that we did that was to
22 assist in outages and for maintenance flexibility, but
23 it has the advantage here as well that it provides an
24 additional form of redundancy.

25 In the case of an extended loss of all ac,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 in which the CTG is not available, the primary makeup
2 is through the fire protection system. Inside the
3 reactor building, there are standpipes up on the
4 refuel floor in which hoses can be used to run over to
5 the fuel pool, which you are probably familiar with
6 that capability. The --

7 CONSULTANT WALLIS: These fire hoses,
8 someone has to lay the hoses?

9 MR. CHAPPELL: Yes. Someone would have to
10 lay those hoses and the connection.

11 In the second bullet, I talk a little bit
12 about the sources. You have a separate water source,
13 as we've discussed, other than the suppression pool or
14 the condensation storage tanks for makeup. And you
15 have diverse monitoring pumps that were also perceived
16 to provide power from the CTG, but, as I said, in the
17 case of CTG not being available, the fire protection
18 system has an install diesel as well as a portable
19 diesel that any portable diesel pump can be connected
20 to.

21 And we have also -- we also have hose
22 connections at the -- at grade external to the reactor
23 building that run up and are hard piped.

24 The ABWR spent fuel pool design features I
25 wanted to highlight a couple. The analysis shows that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 under maximum load and with minimum water inventory,
2 meaning the gate is closed, that it is estimated that
3 you wouldn't reach boiling for 16 hours and that
4 should give some time for operators to recognize such
5 a situation and take some action.

6 So any manual actions that might be
7 associated with the diesel pump or using the fire
8 protection system in a reasonable time.

9 CHAIR ABDEL-KHALIK: Abnormal heat load
10 meaning full off-load?

11 MR. CHAPPELL: Full off-load, design limit
12 off-load.

13 MEMBER ARMIJO: How long would it take
14 under those conditions to boil down the water to the
15 top of the fuel?

16 MR. CHAPPELL: After you have -- after 16
17 hours?

18 MEMBER ARMIJO: Yes.

19 MR. CHAPPELL: I don't know.

20 MEMBER ARMIJO: How many days?

21 MR. CHAPPELL: A long time. It's many,
22 many feet to -- I mean, that's --

23 MEMBER ARMIJO: We are talking about 10
24 days, 15 days?

25 MR. THOMAS: Probably not that long. Some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 number of days. I think there is 20 feet of water
2 over top of active fuel.

3 MEMBER ARMIJO: It's a lot of water.

4 MR. THOMAS: So it's quite a volume of
5 water. I would say something on the order of one to
6 two days perhaps. Maybe not quite that long.

7 MEMBER ARMIJO: I think the numbers for
8 Fukushima were much longer than that.

9 MR. THOMAS: I'm really guessing, so --

10 MEMBER ARMIJO: Yes.

11 MR. THOMAS: -- I hate to speculate --

12 MEMBER ARMIJO: Okay.

13 MR. THOMAS: -- much further. But it's a
14 considerable volume of water.

15 MR. HEAD: I mean, obviously, what we are
16 trying in this slide is that we have a significant
17 amount of time to not get where there is no makeup to
18 the --

19 MEMBER ARMIJO: Right, right.

20 MR. CHAPPELL: And if you are talking
21 about, you know, reacting to an event, the
22 significance of reaching the blowing point is the
23 source term. So if you can take action before then,
24 that's preferable to maintaining capability throughout
25 the reactor.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Sure.

2 MR. CHAPPELL: And another point is that
3 for the spent fuel pool, there are no piping
4 penetrations approximately 10 feet above the top of
5 the active fuel in the fuel racks. So --

6 CONSULTANT WALLIS: Well, the fire hose--

7 MR. CHAPPELL: -- there is not --

8 CONSULTANT WALLIS: -- is connected to a
9 pipe that is immersed in this --

10 MR. CHAPPELL: There are multiple fire
11 protection --

12 CONSULTANT WALLIS: -- spray?

13 MR. CHAPPELL: -- connections.

14 CONSULTANT WALLIS: Does it spray above or
15 is it immersed in some way?

16 MR. CHAPPELL: There is two types of fills
17 that are installed. There is a spray connection and a
18 fill connection that are at the pool.

19 CONSULTANT WALLIS: Well, for the spray
20 connection, you don't really care where the piping
21 connection is outside, it could be anywhere.

22 MR. CHAPPELL: There's a single connection
23 outside at grade that would hook the hose up and then
24 it would run up to the pool. And then there is
25 alternate ways that you could hook hoses up on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 refueling fuel.

2 CONSULTANT WALLIS: Yes.

3 MR. HEAD: There is a single connection,
4 but there is actually two connections.

5 MR. CHAPPELL: There are --

6 MR. HEAD: A third --

7 MR. CHAPPELL: -- multiple connections
8 externally.

9 MR. THOMAS: The third bullet on Slide 11
10 talks about two standpipes that are approximately 180
11 degrees apart in the reactor building. The interior
12 has not -- does not require operator action to get
13 water in the pool. That sprays into the pool and
14 there are connections at grade for fire connections
15 outside the building.

16 MR. CHAPPELL: Right. Okay. And that
17 gives us an overview of the makeup for the spent fuel
18 pool.

19 CHAIR ABDEL-KHALIK: Are there any
20 questions? Thank you for --

21 MR. HEAD: Was that your desired outcomes
22 from the --

23 CHAIR ABDEL-KHALIK: Right. And of
24 course, you know, the comment you made at the
25 beginning, whatever comes out of Fukushima, you know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 you will just have to respond to it.

2 MR. HEAD: Sure.

3 MR. THOMAS: That's right.

4 CHAIR ABDEL-KHALIK: That's -- okay. Any
5 additional questions?

6 MEMBER BLEY: Yes. I just have one. Way
7 back in the beginning, I think, Scott said that
8 although this -- the CTG is not seismically-qualified
9 nor is the building, I thought you said, Scott, that
10 it was qualified as 2-over-1. And most plants, when
11 they get to that point, just make it Class 1. Is
12 there a real distinction for you guys?

13 MR. HEAD: Yes, sir. We will leave it as
14 2-over-1 as a potential threat to the, you know,
15 reactor building and I don't envision us making it
16 seismic Category 1.

17 MEMBER BLEY: Okay.

18 CHAIR ABDEL-KHALIK: It's in the corner.
19 It's over in the corner of the turbine building,
20 right?

21 MR. HEAD: Yes, sir.

22 CHAIR ABDEL-KHALIK: Yes. Are there any
23 additional questions or comments? Okay. Thank you.

24 Now, we are, approximately, 50 minutes
25 ahead of schedule. And we have time for public

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 comments after the next item on the agenda. So let's
2 just continue with the discussion of Action Items #87,
3 #101, #62 and #63 and we will stop when we get to
4 12:00 for lunch.

5 MR. HEAD: Okay.

6 CHAIR ABDEL-KHALIK: Okay. Thanks.

7 MR. HEAD: Okay. Thank you. Yes, we
8 appreciate the opportunity to go ahead and continue
9 the briefing, at this point. And we did want to cover
10 these four action items. We felt like we had
11 developed a response to them and felt like we should
12 have briefed ACRS at this meeting.

13 The first one was addressing failure of
14 speed sensors. We had discussed this one at a
15 previous briefing, but wanted to come back to this one
16 to cover it in some more detail.

17 The 30 minute operator response time on
18 failure of RSW piping that was in one of the previous
19 meetings. The basis for RSW pump NPSH and the
20 suppression pool heat-up with respect to the 77 degree
21 RCIC limit.

22 So we will be discussing those items.

23 Our attendees have been involved with
24 briefing the ACRS before. I'm going to turn it over
25 to Tom on Action Item #87.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DALEY: Good morning. I'm Tom Daley,
2 NINA's Mechanical Engineering Supervisor for STP 3 and
3 4.

4 As Scott mentioned, the first action item
5 to address is the failure of the speed sensors and the
6 primary over-speed protection subsystem for the main
7 turbine. And this is a follow-on from our June
8 presentation where we discussed the turbine generator
9 over-speed protection subsystem.

10 This is a subsystem which we consider
11 highly safe and reliable and yet it protects against
12 unwanted and unnecessary turbine trips. And it has a
13 number of separate redundant and diverse subsystems.

14 We talked about the fact that the active
15 speed sensors which control -- provide inputs to the
16 normal speed control and the emergency over-speed trip
17 system and any failure of those active components will
18 result in a turbine trip. And that's because of the
19 fact that it is feeding the normal speed control
20 system.

21 The passive speed sensors, a diverse
22 system, they feed the primary over-speed trip system.

23 We didn't point out in our submittal that a failure
24 of these passive sensors does not result in a turbine
25 trip. And we feel that because these sensors do not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 control the normal speed control function, that that
2 is appropriate.

3 It does provide an alarm in the control
4 room.

5 CONSULTANT WALLIS: I don't understand
6 Bullet 2. You have to have some sensor to know that
7 the turbine is over-speeding, wouldn't you?
8 Otherwise, you can't have over-speed protection. You
9 have to sense over-speed some how.

10 MR. DALEY: Well, we do. We have two
11 separate sets --

12 CONSULTANT WALLIS: So failure of the
13 speed sensors doesn't affect emergency over-speed
14 protection?

15 MR. DALEY: These speed sensors.

16 CONSULTANT WALLIS: Isn't this an
17 important integral part of the over-speed protection
18 to have a speed sensor that works?

19 MR. CHAPPELL: That bullet only refers to
20 one of the two sets of speed sensors.

21 CONSULTANT WALLIS: What does the speed
22 sensor mean?

23 MR. CHAPPELL: The primary over-speed
24 subsystem and passive speed system.

25 CONSULTANT WALLIS: But you didn't say

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that. You mean some of the speed sensors?

2 MR. CHAPPELL: That is the design.

3 CONSULTANT WALLIS: So what you are
4 meaning is failure of some speed sensors? Failure of
5 all of them wouldn't be acceptable, would it?

6 MR. CHAPPELL: It would not be acceptable
7 and it would --

8 CONSULTANT WALLIS: So these --

9 MR. CHAPPELL: -- be continual turbine
10 trip.

11 CONSULTANT WALLIS: So these meant all?

12 MEMBER ARMIJO: I think these meant
13 passive.

14 MR. DALEY: Right. This bullet refers
15 really --

16 CONSULTANT WALLIS: These meant passive.

17 MR. DALEY: That's correct.

18 CONSULTANT WALLIS: Okay. That clarifies
19 it, otherwise, I didn't understand it.

20 MR. DALEY: Yes, right. Yes, and you are
21 correct that's not --

22 CONSULTANT WALLIS: So these means
23 passive.

24 MR. DALEY: -- clear the way it is worded
25 right there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CONSULTANT WALLIS: Oh.

2 MR. DALEY: Well, let me continue on with
3 the third bullet.

4 CHAIR ABDEL-KHALIK: Go ahead.

5 MR. DALEY: Okay. I did say again with
6 the passive speed sensor failures, you do have an
7 alarm in the control room, which would allow for
8 timely operator action as directed by procedure, which
9 ensures a very low potential for turbine over-speed
10 event to occur.

11 MEMBER BROWN: What type of operator
12 action? You made that statement in your -- I read
13 that in the transcript from the 6/21 presentation,
14 which I had to leave, I apologize for having to leave
15 on that one.

16 MR. DALEY: Right.

17 MEMBER BROWN: But I did, that's a fact.
18 So when I read back, you talked several times about
19 timely operation, appropriate actions, etcetera,
20 etcetera. But I had no idea what you meant by timely
21 or appropriate. And, obviously, you developed those
22 thoughts probably not at this point.

23 MR. DALEY: Right, right. I would be
24 speaking extemporaneously --

25 MEMBER BROWN: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DALEY: -- without --

2 MEMBER BROWN: I want to try to cut to the
3 bottom line of this, since I brought up this issue in
4 the first place. It might be better to let me frame
5 my point to make sure we at least address the
6 fundamental issue.

7 The active sensors feed two systems. They
8 feed your normal control. They feed your emergency
9 over-speed. They each have separate processors
10 dealing with each of those functions. And that's
11 based on slides that you all presented in an earlier--
12 back in February or something like that meeting.

13 MR. DALEY: That's correct.

14 MEMBER BROWN: Each active sensor feeds
15 all six channels effectively. The three control
16 functions and the three monitoring functions.

17 MR. DALEY: Right.

18 MEMBER BROWN: Okay. I just wanted to
19 make sure. Each of the active sensors is powered. So
20 there is power supplies involved with each one. And,
21 therefore, they talk, each sensor talks to every
22 emergency -- each of the emergency monitors, each of
23 the three and each of the control channels. I just
24 wanted to fix that picture.

25 The passive sensors are for the primary

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 over-speed protection completely independent. Each of
2 those passive sensor feeds each of its three monitors,
3 because you evaluate those, and they are completely
4 independent of all the other items.

5 They operate at 110 percent, based on your
6 -- at least on the numbers you -- in the DCD that I
7 saw. The emergency one goes at 111 percent.

8 My point of the question where you have
9 the turbine tripping on failure of the -- some
10 combination of the active sensors --

11 MR. DALEY: Two or more.

12 MEMBER BROWN: -- two or more, was aimed
13 at your primary system, which is passive ones, did not
14 have a trip. All it had was an alarm. If you are
15 taking appropriate action and you are trying to fix
16 something on the passive system, it's effectively out
17 of service. And you talked about that it could be out
18 of service for some time, the way your conversation
19 went in the last transcript.

20 And you would be operating on the normal
21 and the emergency. You now have a circumstance where
22 you have no independence of your over-speed trip from
23 your normal control function from the sensor signal
24 conditioning, all those things, and the power
25 supplies. The common cause failure circumstance while

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you are operating, you no longer have -- and my point
2 is you no longer have an independent over-speed trip
3 system.

4 I find that counterintuitive to operation,
5 just based on experience where, in this case, one
6 power supply could affect all six of your control
7 flow, three control and your three monitoring
8 channels. You could have a failure which told the
9 control system to speed-up and disable the monitoring
10 over-speed trip function.

11 That's not theoretical. It actually
12 happened, okay, in my experience. It was an
13 unfortunate experience. Unfortunately, it was stopped
14 before it over-spiced, but it happened very quickly. If
15 an operator had not been standing within about 5 feet
16 of the turbine generator set, it would have -- because
17 he tripped -- he manually tripped the throttle valves.

18 There would have been serious consequences.

19 It hit close -- about -- I can't give the
20 -- use the numbers, but it was about 1 percent away
21 from its over-speed condition. So that's the point of
22 the whole question is that operation without your
23 independent over-speed trip function seemed to be
24 counterintuitive, but I'm going to allow myself to
25 operate with a system that is subject to a common

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 cause failure, which could take out -- which could
2 result in a specific over-speed for trip -- excuse me,
3 over-speed driven situation and compromise my over-
4 speed trip system. That's what I found
5 counterintuitive.

6 And I, fundamentally, don't think that is
7 a good idea. So that's why I raised the point.

8 MR. DALEY: Okay.

9 MEMBER BROWN: So all the other stuff you
10 can go through all the other shenanigans and that's my
11 concern, because I would have thought, quite frankly,
12 if I had a problem with my -- I'll put this on the
13 record.

14 If your emergency -- say you had a problem
15 with a couple of your emergency over-speed trip
16 functions that are fed by the active sensors, the
17 normal control circuits are all working just fine.
18 You have still got an independent passive, totally
19 independent over-speed trip set. And you have got
20 some time there. That's better than the old days when
21 you had one, you know, centrifugal switch, some type
22 of centrifugal switch more than likely, on your
23 turbine over-speed function, so that would have been
24 an acceptable mode.

25 I just don't see it to be an acceptable --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this is me. This is not the committee. This is me,
2 okay, under the circumstances which I just described.

3 So that's kind of where I came down. I tried to
4 explain it as crisply as I could. And I -- so I kind
5 of -- that's where my heartburn was.

6 Was I clear in the description?

7 MR. CHAPPELL: I think we understood that
8 to be the question.

9 MR. DALEY: Right.

10 MEMBER BROWN: Okay.

11 MR. DALEY: And I tried to format our
12 response on this --

13 MEMBER BROWN: Yes, I read it. I just
14 didn't see it solving --

15 MR. SMITH: Yes.

16 MEMBER BROWN: -- the problem.

17 MR. DALEY: First, the first part of the
18 situation, as you describe, is the loss of a function
19 of two of the three passive speed sensors. So we have
20 talked about that situation occurring. And as we have
21 stated, you won't get a trip on that. You will get an
22 alarm in the control room.

23 There is guidance on probabilities that
24 allows you certain LCO-type recommendations that says,
25 okay, if you have got a probability of a turbine trip

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 between this value and this value, you can operate for
2 this amount of time in order to fix that problem.

3 MR. CHAPPELL: Well, the reduction in
4 over-speed protection.

5 MEMBER BROWN: Well, hold it just a
6 minute. In your comments last time, you were asked is
7 there a tech spec LCO associated with this and you
8 said no.

9 MR. DALEY: There is nothing in the tech
10 specs.

11 MR. HEAD: That doesn't mean we won't be
12 taking actions.

13 MEMBER BROWN: Well, I --

14 MR. HEAD: The procedures won't have that
15 information available in there.

16 MEMBER BROWN: Well, how long? What do
17 you mean by actions? I mean, is that 32 -- is it 72
18 hours? Is it --

19 MR. CHAPPELL: Well, the operator actions
20 that you alluded to earlier based on alarm response
21 procedure. So an operator -- if there is a problem
22 with the over-speed protection system, one sensor
23 fails, two sensors fail, something else, some common
24 cause failure disables it, there will be indications
25 go look at this, figure this out, call this, figure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 out how long you might need to -- how much time you
2 have to take certain actions.

3 So there would be recommendations that
4 would be based on the whole station getting together
5 and looking at those inputs. They would say well, how
6 long can I go before I have to take this turbine off-
7 line to make these corrections? And the LCO-type time
8 frame, as Tom mentioned, are based on a more likely
9 over-speed condition that goes from 10^{-7} to say 10^{-6}
10 probability. And you say well, I have a week or I
11 have two weeks or I can go and troubleshoot this or
12 maybe I have longer or less time.

13 MEMBER BROWN: So we are going to operate
14 for a couple of weeks based on your probabilities.

15 MR. CHAPPELL: Well, I think Tom is going
16 to get to that in the next point as to why that is --
17 may not be as relevant under the conditions when you
18 are on-line.

19 MR. DALEY: Yes. So we have a failure of
20 our passive speed sensors and now we are going to say
21 we have a failure of our active speed sensors. And,
22 of course, if you have got two out of three failures
23 there, that will give you a turbine trip.

24 MEMBER ARMIJO: Tom, could you explain
25 what failure means in the passive sensor? Is it loss

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of all signal? Is it an indication that speed is
2 faster than what the active systems are telling you or
3 slower? You know, what are the failure modes?

4 MR. DALEY: On the sensor side, I would be
5 hard-pressed to come up with --

6 MR. CHAPPELL: An invalid signal.

7 MR. DALEY: -- a failure. But then it
8 feeds into a black box. And so --

9 MEMBER ARMIJO: So how can you define
10 failure?

11 MR. DALEY: -- then that black box goes--

12 MEMBER ARMIJO: Just loss of --

13 MEMBER BROWN: Well, typically, with the
14 passive sensor, which -- at least the ones I'm
15 familiar with, you -- it's more than likely a broken
16 wire in the system. I mean, the sensor is --

17 MEMBER ARMIJO: No signal?

18 MEMBER BROWN: There is no signal.

19 MEMBER ARMIJO: Okay.

20 MEMBER BROWN: It's very hard to get a
21 more signal out of a passive signal -- sensor, because
22 they are self-generated. It's difficult.

23 MEMBER ARMIJO: Okay. So it's --

24 MEMBER BROWN: Probably a way --

25 MEMBER ARMIJO: -- just the loss of signal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is --

2 MEMBER BROWN: It's a loss of signal more
3 than likely. And then you have got the signal
4 condition circuitry down or -- up -- down, excuse me,
5 downstream of that feeding before you go into all of
6 the processing circuitry.

7 MEMBER ARMIJO: Okay.

8 MEMBER BROWN: So there is some ways and
9 then you have got the inputs to the actual processors
10 themselves where there is more ways to do things. So
11 there is a few places along the lines where you can
12 lose that, a single piece of information.

13 MEMBER ARMIJO: But I'll let you go ahead,
14 but I mean --

15 MR. DALEY: Now, again, given this next
16 common mode failure of the active speed sensors, that
17 will give us a turbine trip. But let's suppose that
18 doesn't -- that turbine trip doesn't take place.

19 Now, in your normal situation, your
20 generator is parallel to the grid. The speed control
21 doesn't really control the position of the governor
22 valves. It is -- the turbine speed is controlled by
23 the grid. It doesn't go any faster than 60 cycles or
24 61 cycles.

25 Now, you could say, okay --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: The speed control to try
2 to open the governor valves.

3 MEMBER BROWN: That's not true.

4 MR. DALEY: I'm sorry, John.

5 MR. CHAPPELL: It's a low voltage gate
6 though, that type situation, and so you would be in
7 dome pressure control mode.

8 MR. DALEY: But I want to hear your --

9 MEMBER BROWN: My point being is that the
10 control system is telling you to open the throttles --

11 MR. DALEY: Yes.

12 MEMBER BROWN: -- independent. It's
13 telling the turbine to open the throttles. So whether
14 you are paralleled or not, the TG set will -- the TG
15 set I was talking about was paralleled and it over-
16 sped.

17 MR. DALEY: It would over-speed if the
18 breaker tripped, but it will pick up more real load
19 until maybe the generator breaker will trip because of
20 an overload, but it's not going to go any faster.

21 MR. CHAPPELL: If you look at an
22 analysis --

23 MR. DALEY: It can't go faster than what
24 you are hooked up to.

25 MR. CHAPPELL: If you open all the control

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 valves wide open, you are going to reduce your steam
2 pressure. You might get a reactor scram that way, but
3 you are not going to over-speed because it's locked to
4 the generator.

5 MEMBER STETKAR: However, if that occurs,
6 the over-speed protection from that emergency trip
7 system, since it is now seeing a false high -- I'm
8 sorry, a false low speed, will not close the stop
9 valves. The speed sensors so that the protection
10 system knows that the turbine is running at precisely
11 zero rpm, that's what the protection system knows.

12 MR. CHAPPELL: It knows that it's going to
13 close the stop valves.

14 MEMBER STETKAR: I'm sorry. It knows that
15 the turbine is rotating at precisely zero rpm. The
16 control system wants to open the control valves. It
17 will try to do that. You will then go into some sort
18 of load mismatch probably. You will probably get a
19 signal to trip the reactor or a signal to trip the
20 turbine from some other condition.

21 MR. CHAPPELL: Okay.

22 MEMBER STETKAR: However, if you trip the
23 reactor, you open up the generator output breaker, at
24 that point, the turbine is not -- is going to want to
25 speed up. It has now lost its connection to the grid.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. CHAPPELL: Yes.

2 MEMBER STETKAR: It has lost its load. It
3 is going to want to speed up. The protection system
4 knows that its speed is precisely zero. That's what
5 it knows. It is not going to control to close the
6 stop valves, because it knows that the turbine is not
7 rotating.

8 MR. CHAPPELL: The --

9 MEMBER STETKAR: So if you trip the
10 reactor, if you open up the generator output breaker,
11 the only thing you have left is the primary over-speed
12 protection system with the passive sensors. That's
13 the only thing you have left.

14 MR. DALEY: We have our core load
15 unbalanced, which measures the generator output and
16 measures the steam flow. And a mismatch of more than
17 40 percent there will open your fast acting solenoids
18 and trip your --

19 MEMBER STETKAR: That might help, yes.

20 MR. DALEY: -- and more directly a turbine
21 trip --

22 MEMBER BROWN: Where are they? Are they
23 in the same circuits?

24 MEMBER STETKAR: No.

25 MR. DALEY: Well, when you say where are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 they, the --

2 MEMBER BROWN: Where are they in the
3 control -- are they part of the control system?

4 MR. DALEY: They are part of the normal
5 speed control.

6 MEMBER BROWN: What did I just say? The
7 normal speed control system has been told. You have
8 no idea what is going on in this normal speed control
9 system right now.

10 MR. DALEY: Through your speed --

11 MEMBER BROWN: There could not even be
12 processing.

13 MEMBER STETKAR: Part of, I think, what
14 Charlie is trying to get at is when you say fail, I
15 mean fail, that the system -- the speed control system
16 is absolutely 100 percent positively certain that the
17 turbine is stationary. That's the failures. Those
18 are the common mode failures. So if there are other
19 ways of controlling -- of closing the turbine stop
20 valves independent from the normal speed control
21 processing stuff, because you don't know where those
22 faults are.

23 I mean, we have been talking about speed
24 sensors, but they could be in any part of the chain.
25 If there are other ways of closing the turbine stop

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 valves under those conditions, well, you know, that's
2 worthy of thinking about.

3 MEMBER BROWN: Right.

4 MR. CHAPPELL: That is the case if you
5 have -- I mean, no matter what the speed is, a
6 mismatched trip closes to the fast acting solenoids,
7 the stop valves. That will be the same --

8 MEMBER STETKAR: And that's a separate
9 processing logic outside of the --

10 MEMBER BROWN: If it's not in the normal
11 control circuits, that would be another thing. But
12 you -- if it's -- if that imbalanced calculation is
13 done as part of the normal control processors, then it
14 probably is not working right.

15 MEMBER STETKAR: I don't know.

16 MR. DALEY: But I think it's all part of
17 the electrohydraulic control system. Now, what black
18 box that resides in, I'm not sure. But I do know that
19 the sensors are completely -- it senses your electric
20 power output and senses your steam flow. And if there
21 is a 40 percent mismatch, it trips your fast acting
22 solenoid bounce which shuts your -- all your control
23 valves.

24 MEMBER STETKAR: In many traditional plant
25 designs, those tend to be separate. They tend to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 in separate boxes.

2 MEMBER BROWN: I don't know.

3 MEMBER STETKAR: If you want to use the
4 black box analogy.

5 MEMBER BROWN: I don't know. I don't
6 remember anything in --

7 MEMBER STETKAR: At least this one.

8 MEMBER BROWN: -- the discussion that
9 discusses this.

10 MEMBER STETKAR: No, that's separate
11 turbine protection.

12 MEMBER BROWN: Yes.

13 MEMBER STETKAR: They are a separate
14 turbine trip, reactor trip --

15 MEMBER BROWN: And I have not seen that
16 written up anywhere.

17 MEMBER STETKAR: -- protection modules.

18 MEMBER BROWN: If there is an alternate
19 system that will trip those things, independent, be
20 careful, of your normal speed control in an emergency
21 controlled processing system and your primary over-
22 speed trip system, there is another circuit that will
23 trip these things.

24 MEMBER STETKAR: And that would be worthy
25 of saying --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BROWN: It's worth looking at.
2 It's the other turbine trip signals. It has nothing
3 to do with speed control.

4 MEMBER STETKAR: Absolutely. There is
5 something there that will protect it. It's just it
6 just --

7 MEMBER BROWN: Whatever other signals come
8 into trip the turbine that are not just opening up the
9 generator output breaker, because that's -- that makes
10 this situation worse.

11 MEMBER STETKAR: Yes.

12 MEMBER BROWN: You know, it has got to be
13 a primary turbine trip signal that comes in.

14 MR. CHAPPELL: I think when you are
15 looking at the type of control signal failure that
16 would happen, anything that would normally drive the
17 turbine speed is only during startup. When you are
18 talking about on-line operation, for example, when
19 most likely something like this, even though it's low
20 probability, could occur, then you do have the speed
21 being controlled by the generator.

22 And if you had some kind of fault in your
23 speed control that would tell the valves to open or do
24 something else, the only way that could have an effect
25 is it would tell it to close. And what you would then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have in that particular case is you would end up with
2 certain scrams. You would have either a high pressure
3 reactor scram or you would have a low steam line scram
4 or you would add load to the generator. You would get
5 -- in either case, you would you end up in a result of
6 a turbine trip. And that turbine trip is a signal to
7 close the valves.

8 So even if the turbine sitting at zero rpm
9 and rpm indicates whatever it is or infinite, that
10 speed signal, whatever signal is going to it, there
11 will be a control signal that says close the stop
12 valves and close the control valves. And that would
13 stop the over-speed condition on a turbine trip.

14 MEMBER BROWN: Well, right now, that's not
15 explained anywhere.

16 MR. CHAPPELL: Okay.

17 MEMBER BROWN: And right now, from what I
18 can view, there is a situation where you can end up in
19 a situation with a non-conservative and unsafe mode of
20 operation with your normal speed and emergency trip
21 system. So unless -- I mean, as John points out, if
22 there are some other --

23 MR. CHAPPELL: Sure.

24 MEMBER BROWN: -- circumstances --

25 MEMBER STETKAR: Let's see if we can think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 about something here. If -- I'm trying to think, you
2 know, if there is a take-away from this, what would
3 help us to have a little more confidence that there is
4 some degree of, you know, additional protection, let's
5 say.

6 If they could show that there are other
7 turbine trip signals independent from anything to do
8 with the word speed --

9 MEMBER BROWN: Yes.

10 MEMBER STETKAR: -- that would close the
11 turbine stop valves under a condition where the
12 turbine speed control system, for whatever reason,
13 tries to speed up the turbine, would that provide
14 reasonable assurance that the passive system then
15 could be, you know, out of service for some period of
16 time?

17 And they do. I looked up the table in
18 DCD. There are -- you know, you can argue with
19 numbers and things like that, but there are COL
20 requirements that they have to evaluate probability of
21 turbine over-speed and under degrading conditions,
22 they are allowed to have things out of service for a
23 period of time.

24 They are not tech specs in the same way,
25 but they will be implemented through --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BROWN: Procedures.

2 MEMBER STETKAR: -- procedures or
3 maintenance, you know, your stuff important to safety
4 or whatever it's called. Would that --

5 MEMBER BROWN: If there is something else,
6 that would be fine. I'm just right now operating
7 without an independent over-speed trip system for, you
8 know, more than, I hate to use the words, a few
9 minutes. I'm not going to argue whether it is a few
10 minutes or an hour or whatever, but days or weeks
11 starts -- we are not in a double to failure. You
12 know, we are not doing that.

13 You are still down to single failure modes
14 at that point. So that -- there are some other
15 systems, I would agree with you, John.

16 MEMBER STETKAR: It strikes me that on
17 this slide in the second line down, the last two
18 bullets, I mean, it's true, you know, parallel to the
19 grid, it's a pretty hard 60 hertz thing out there.
20 The speed actually is not going to increase. Perhaps
21 measurably if you have a really small grid, but --
22 which you tend to have on ships.

23 MEMBER BROWN: I don't disagree with that.

24 MEMBER STETKAR: The -- you know, in any
25 kind of reasonable grid. However, it is going to try

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to pick up load. Now, how much load it is going to
2 try to pick up is where your governor valve is set at.

3 The question is then what protections
4 exist to trip the turbine under those conditions that
5 are independent of the emergency trip system?

6 MEMBER BROWN: I understand.

7 MEMBER STETKAR: The over-speed stuff,
8 because, you know, if you do just open up the
9 generator breaker if it's a turbine generator, you
10 know, electrical reactor or however you measure the
11 stuff, that's not so good because the turbine is then
12 going to want to go real fast. And then you are just
13 relying on the, you know, passive -- the primary trip
14 system.

15 So you need to think about things that
16 would actually give you a turbine, you know, signal to
17 close the turbine stop valves first or simultaneous
18 with, you know, opening the generator breaker,
19 hopefully first. And I don't know if they -- you
20 know, and I don't know what they are. I haven't
21 thought about the problem enough. And then the
22 question is do they live in a separate box from
23 whatever turbine control system you have there.

24 MR. CHAPPELL: We were talking about an
25 over-speed protection system that goes to a different

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 way --

2 MEMBER STETKAR: No, not over -- it can't
3 be over -- you can't use the word speed. You need to
4 word -- use words like some sort of pressure sort of
5 imbalance nuclear power versus electrical load that
6 says hey, turbine stop valves, you know, go closed.

7 MR. CHAPPELL: So that first part that I
8 said and then what you have also is the turbine
9 protection system. So you have -- you also have a
10 number of other turbine trips that close the fast
11 acting solenoid.

12 MEMBER STETKAR: True.

13 MR. CHAPPELL: And what Mr. Brown was
14 asking about was examples and you look at failure of
15 speed sensors, that's a list of 10 or some turbine
16 trips that are in there. If you are talking about,
17 you know, that would give you something that doesn't
18 use the word speed in another list, so it's a turbine
19 trip. It's independent of that.

20 MEMBER BROWN: So if you have a generator
21 fault, for example, or you have something else that
22 would --

23 MR. CHAPPELL: With the generator fault,
24 you have the output breaker. That one is not a good--

25 MEMBER STETKAR: Go back and listen to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 scenario. The scenario is the turbine speed sensors
2 that are controlling turbine speed, but are not
3 actually controlling real turbine speed because it is
4 at 60 hertz, the turbine speed sensors suddenly know,
5 all of them, the active ones, that the turbine rotor
6 speed is precisely zero rpm.

7 And, therefore, the control system will
8 then react to that, however the turbine speed under
9 normal operating conditions will react to that signal
10 and say, hey, I'm not supposed to have zero rpm when
11 I'm putting out 100 percent power from my reactor or
12 I've got a 100 percent load demand from my generator.

13 I'm supposed to have, you know, 1,800 rpm or whatever
14 it is.

15 So the only way I can get that is to open
16 up the governor valves, which are mostly open. So
17 it's going to try to do that.

18 Now, in truth, the governor valves are
19 fully open right now, so you are now going to be
20 putting more steam into the turbine, which means you
21 are going to be putting more electricity out from the
22 generator and you are going to see some types of load
23 imbalances and some types of pressure imbalances. How
24 much? I don't know.

25 MR. HEAD: They're going to see those,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 right?

2 MEMBER STETKAR: Huh?

3 MR. HEAD: I mean, that won't be -- I
4 mean, operators will become aware of that situation.

5 MEMBER STETKAR: I would like to know
6 whether the automatic operator will be aware of that
7 situation and whether the automatic operator will
8 initiate a turbine trip, dump the hydraulic fluid
9 under those conditions.

10 MR. CHAPPELL: I think the control valve
11 position would be dominated by the pressure control
12 model and that the signal, whatever signal that might
13 go to the control valves for the sensor --

14 MEMBER STETKAR: Yes, and I don't know how
15 that works on this.

16 MR. CHAPPELL: -- would not override that.
17 It would maintain the control valve position to
18 control reactor pressure in your low mode. And so
19 that signal would exist. It would give you a failure,
20 but it wouldn't actually cause -- it wouldn't override
21 the signal that maintains the control valve.

22 MEMBER STETKAR: That might be the
23 solution. I mean, if the pressure control is going to
24 fix, essentially, that control valve position, the
25 governor valve position, regardless of what signal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 might be coming from, you know, a faulty speed control
2 input, which would, you know, tend to try to drive it
3 open. You know, that might be the solution. You
4 might not get a trip.

5 MR. CHAPPELL: Yes, you might not get a
6 trip.

7 MEMBER STETKAR: But not getting a trip is
8 no big deal under these conditions.

9 MR. CHAPPELL: Well, I think one of the
10 things we -- when we think -- the part about not
11 getting a trip, it's no big deal, is that one of the
12 reasons probably you might ask well, why do you care?
13 Why don't you just put a turbine trip in because of
14 these passive sensor failures? One of the --

15 MEMBER BROWN: Remember, it's not -- you
16 are operating without the passive -- the primary
17 system right now.

18 MR. CHAPPELL: Yes.

19 MEMBER BROWN: So they are gone. You are
20 not operating. You are taking your two weeks of time
21 or whatever your analysis is, so you could take --

22 MR. CHAPPELL: Right.

23 MEMBER BROWN: -- and a single power
24 supply failure in the other system can create these
25 two problems. It's not just the sensors in the other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 -- in the normal system. It's a power supply. You
2 are telling the processors via the sensing lines
3 that in one case speed up and in the other case
4 disable the trip.

5 MR. CHAPPELL: But you agree while on-
6 line, nothing happens with the turbine.

7 MEMBER BROWN: I didn't say that.

8 MR. HEAD: Which we will --

9 MEMBER STETKAR: If either nothing happens
10 when the active -- now, I'm putting some words in
11 Charlie's mouth here so, I'm sure he will correct me.

12 If either nothing happens in the real-world, if the
13 active speed sensors suddenly, and I don't like using
14 the words speed sensors, so if the --

15 MEMBER BROWN: It's the input. It's the
16 input.

17 MEMBER STETKAR: So if the active speed
18 control system suddenly knows that the turbine rotor
19 speed is precisely zero during full power operation,
20 if that suddenly happens, if then nothing happens to
21 move the turbine control valve as a consequence of
22 that, because either some other control function, you
23 know, is overriding, you know, dominant or overriding
24 or dominant or whatever you want to call it, that's
25 fine, you just stay at 100 percent power, you know.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And you've got -- you know, in Charlie's--
2 the passive things, it's not a good situation to be
3 there, but I'm confident that there will be some
4 guidance to the operators.

5 Or if, indeed, the integrated control
6 system does react and for some reason opens up the
7 governor valves under this condition, is there another
8 trip that comes in to trip the turbine independent of
9 anything to do with the word speed?

10 MR. CHAPPELL: Yes.

11 MEMBER STETKAR: You know, and if the
12 answer to that second part is yes, it would guide, you
13 know, I'm hearing a couple different stories, either
14 nothing would happen because there are other control
15 functions that would prevent the governor valve from
16 opening --

17 MR. CHAPPELL: Even if it were to open,
18 even if it were to cause an opening of the control
19 valves and try to add load or try to pickup speed, try
20 to pickup load, even if it were trying to do that, it
21 would eventually end up in, most likely, a scram, a
22 reactor scram which would then result in a turbine
23 trip.

24 MEMBER STETKAR: And that's -- I think, if
25 you had some -- an example of that, why, you know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that would occur, I think that would provide some
2 confidence about why you can operate, you know, for
3 some nominal period of time with the passive sensors,
4 you know, out of service.

5 MR. HEAD: Yes, but that's not the same.
6 I don't think we are saying that we would operate some
7 nominal period of time with the passive out and
8 knowing that these have failed also.

9 MEMBER STETKAR: No. No, no, no, no, no.
10 It's --

11 MEMBER BROWN: Nobody is saying that.

12 MEMBER STETKAR: It's -- the problem is,
13 Scott, that if you are sitting there in that period of
14 time with the passive out and these things go --

15 MR. HEAD: And the second says --

16 MEMBER STETKAR: If you were then
17 guaranteed to over-speed the turbine, that's not a
18 good situation.

19 MR. CHAPPELL: But we are talking about a
20 separate diverse set of sensors.

21 MEMBER STETKAR: That's true.

22 MR. CHAPPELL: We are talking about
23 independent common mode failures. And what we are
24 talking about are systems that are capably testing on-
25 line quite frequently shiftily.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Hold it. We are not
2 talking about an independent common mode failure.
3 Once you are in the normal -- in the emergency system,
4 one failure that --

5 MR. CHAPPELL: Right. That's the second--

6 MEMBER BROWN: -- we -- they are not in --
7 no, it's not a second one. If you are out of service
8 for -- if I'm operating for a week, I'm no longer in a
9 double failure. I'm back into the single failure
10 operation mode. One power supply feeds all six
11 monitoring processors, all of them. It has happened
12 before.

13 MEMBER STETKAR: But I think, Charlie, the
14 first failure was what got you into the condition.

15 MEMBER BROWN: Yes, I understand that.

16 MEMBER STETKAR: You had the passive.

17 MEMBER BROWN: But that's -- once you
18 decide to -- no. Once you decide to operate like that
19 without doing anything, now I have made a decision I'm
20 willing to accept. I have to deal with the
21 consequences of a single failure. I admit two things
22 happening within close proximity in time, like seconds
23 or maybe a minute or two, that's a double failure.
24 I'm not going to deal with that. We don't have to
25 consider those.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 But once I have said, oh, I know it's
2 broke, I'm going to operate without it, one week, two
3 weeks, whatever the time is, now, I have to deal with
4 the circumstance that we are discussing. That's the
5 only point.

6 MR. CHAPPELL: Well, that's why we talked
7 about the LCO-type arrangements that there is an
8 acceptable reduction of risk before you can go in and
9 make those types of adjustments.

10 MR. HEAD: Well, otherwise, you are saying
11 we should immediately take some action immediately on
12 the failure in the first place.

13 MEMBER BROWN: Scott, if it had been me
14 and if I had had a failure in my primary system, I
15 would turn it off. Okay? Now, that's just -- I would
16 trip the TG set. If I -- if my primary system --

17 MEMBER STETKAR: That's not by the way
18 necessarily the safest thing to do in a nuclear power
19 plant.

20 MR. HEAD: I think if that's the way we
21 had designed --

22 MEMBER STETKAR: Just to get that on the
23 record.

24 MR. HEAD: If that's the way we had
25 originally designed the plant, then 10 years after

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 operations, we would be looking for ways to change
2 that design, because it's more of a risk, because we
3 would be tripping the plant unnecessarily.

4 MEMBER BROWN: Right.

5 MR. HEAD: As a way -- is why we're up
6 here defending this design.

7 MEMBER BROWN: I have told you -- in my
8 comments to you I said you have got a nice system for
9 ensuring the plant stays on-line. I made that point.
10 I have no disagreement with the fact that you have got
11 a fairly reliable system for keeping everything
12 running. It's just --

13 MR. HEAD: And --

14 MEMBER BROWN: -- it may not be running
15 safely.

16 MR. HEAD: Well, and keeping it on-line,
17 but keeping it and then, you know, the staff,
18 operations, engineering and management have the
19 opportunity to make the appropriate decisions instead
20 of those decisions being taken out of their hands.
21 And some of those decisions may be, you know,
22 shutdown. Some of those decisions may be additional
23 monitoring. Some may do additional testing to make
24 sure the other equipment is reliable.

25 So at least you have the opportunity to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 make those decisions instead of, you know, like I say,
2 those decisions being taken out of our hands if this
3 failure were to happen. So, you know, we are -- you
4 know, Mr. Chairman, I see -- as I think we are
5 hypothesizing that we have this and and then something
6 else has happened now since the, you know --

7 MEMBER STETKAR: It's a combination of the
8 two. It's clear.

9 MR. HEAD: It's another end that now
10 because the turbine -- what I'm saying is I don't
11 think the turbine knows it is sitting there. And so
12 now we need something else to happen and we need to
13 tell you what is going to happen, what reactor trips
14 are going to happen, so the turbine stop valves will
15 close, I think, to say that we don't know -- we are
16 not going to end up in an over-speed situation.

17 MEMBER STETKAR: I think, you know, from
18 my perspective, I'll push the passive stuff away. If
19 I knew what happens to the turbine, just normal plant
20 operation, if the turbine speed control system
21 suddenly knows that the turbine rotor is rotating at
22 zero rpm, what then happens? What is the response of
23 the turbine control system to that condition?

24 Will it open the governor valve or not? I
25 don't know. I'm not a turbine control guy, so I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 certainly not -- you are a turbine control guy. Will
2 it open the governor valve or not? I don't know. If
3 the answer is no it won't, because there are other
4 control functions that override, you know, that
5 spurious speed sensing thing, that's fine.

6 If, indeed, the governor valves will open,
7 then I would like to know, you know, is there another
8 independent turbine trip that will come because of the
9 way the whole plant works, whether it is from a
10 pressure, you know, or a load imbalance or what is it.

11 CHAIR ABDEL-KHALIK: I'm going to ask --

12 MEMBER STETKAR: The answer is that, yes,
13 there will when it comes in and that's an added
14 measure of confidence that even if the passive system
15 wasn't even there, you have some sort of protection
16 that will trip the turbine.

17 CHAIR ABDEL-KHALIK: Dinesh?

18 MR. TANEJA: Yes. This is Dinesh Taneja,
19 staff. You know, my understanding of the design, the
20 way I understood it, it might help in this discussion.

21 One thing is I think the way I understood it is that
22 during normal operation in a BWR, the turbine is
23 running in a pressure control mode not on a speed
24 control mode. So really, the speed sensors are not
25 actively involved in the turbine control system.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And the other thing that I understood that
2 the power load imbalance PLU controls, they reside in
3 the controllers, in the normal speed controller boxes.

4 Whereas, the emergency over-speed controller boxes
5 are independent of the normal speed control boxes.

6 So the PLU condition that would trip the
7 turbine is independent of the emergency over-speed
8 trip circuits and controller boxes. And, Charlie,
9 there is redundant set of power supply in the system,
10 so really we didn't see --

11 MEMBER BROWN: Not a redundancy of power
12 supplies.

13 MR. TANEJA: There is.

14 MEMBER BROWN: Well, no, that's not the
15 issue. The system which we had the problem with had
16 redundant power supplies.

17 MR. TANEJA: Okay.

18 MEMBER BROWN: They were both operating in
19 parallel and when they went -- they watched it
20 chugging away and they went to troubleshoot and guess
21 what happened when they did their troubleshooting?
22 That's when they had the over-speed. So the
23 redundancy doesn't fix the problem when you are trying
24 to figure out what is going on.

25 MR. TANEJA: Okay. No, I think I heard

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that there was a single power supply.

2 MEMBER BROWN: No, this was not --

3 MR. TANEJA: Okay.

4 MEMBER BROWN: Well, it was a single power
5 supply failure. And when they went to troubleshoot,
6 they took out -- they disabled the wrong power supply
7 in terms of what was the source of the problem as they
8 walked through their troubleshooting steps.

9 MR. TANEJA: And then also the normal
10 speed control system is a fail-safe design, the way,
11 you know, we see it? It's -- you know, so if you do
12 have a multiple failures in a normal speed control,
13 that will result in turbine trip.

14 I just wanted to add my understanding.

15 MEMBER BROWN: I understand the normal --
16 I understand if you have failures in the normal speed
17 control, you will get a turbine trip. I understand
18 that. It's very plainly stated that was my point.
19 And I saw the primary system, nobody seemed to care.
20 And then when I saw the discussion where it can be out
21 of service, that just triggered the additional thought
22 processes.

23 MEMBER ARMIJO: I've got a question for
24 clarification. I'm not a turbine guy by a long shot,
25 but the way your chart says if you lose a signal from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 two of the three passive speed sensors, there will be
2 no automatic turbine trip and you are relying entirely
3 on your -- what happens if you lose all three of the
4 passive speed sensors? Will that trip the turbine?

5 MEMBER BROWN: No.

6 MEMBER ARMIJO: So that won't do it
7 either?

8 MEMBER BROWN: Yes, that's what raised my
9 question before.

10 MEMBER ARMIJO: Yes.

11 MEMBER BROWN: The fact that there are no
12 trips on the passive --

13 MEMBER ARMIJO: Other than information,
14 what use are these passive speed sensors?

15 MEMBER BROWN: Well --

16 MEMBER ARMIJO: I mean, they are not
17 really protection, are they?

18 MEMBER BROWN: Okay, Sam, let me -- we got
19 into this before.

20 MEMBER ARMIJO: Why put them in there if
21 they don't do anything?

22 MEMBER BROWN: My understanding based on
23 what I -- from previous meetings is that there was an
24 expectation initially that you would have a mechanical
25 over-speed trip.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Yes, yes.

2 MEMBER BROWN: And an electrical over-
3 speed trip. Well, they came in and said no.

4 MEMBER ARMIJO: What do --

5 MEMBER BROWN: What would it do to
6 electrical?

7 MEMBER ARMIJO: Right.

8 MEMBER BROWN: Well, if you had -- this
9 whole argument, this whole discussion is moot if they
10 had -- or irrelevant if they had a mechanical over-
11 speed trip system.

12 MEMBER ARMIJO: But they don't.

13 MEMBER BROWN: They could do whatever they
14 want to with the other system. I'm just saying if it
15 was mechanical, why isn't the passive one treated
16 similarly to the mechanical? It's the mechanical one
17 that is out of service and they knew the centrifugal
18 switch was busted, would they operate? I have no
19 idea. And John is shaking his head yes.

20 MEMBER STETKAR: Probably.

21 MEMBER BROWN: That's --

22 MEMBER STETKAR: Because you don't
23 basically know it won't work.

24 MEMBER BROWN: Well, that's because you
25 can't test them the way we can --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: That's right.

2 MEMBER BROWN: -- the other stuff. So I
3 fundamentally like the electrical approach. I don't
4 have any problem with that. It's just that I don't
5 understand the passive system saying hey, I'm going to
6 operate for two or three weeks without it or a month
7 or two months, whatever my probabilistic assessment
8 says.

9 MEMBER ARMIJO: If it fails --

10 MEMBER BROWN: It just doesn't make any
11 sense.

12 MEMBER ARMIJO: You get them signaled. I
13 failed, please, worry. I don't know what you do with
14 it.

15 MR. DALEY: But then you have to fail the
16 other one, too.

17 MEMBER ARMIJO: Right.

18 MEMBER BROWN: Yes.

19 MR. DALEY: It doesn't --

20 MEMBER BROWN: Well, I understand that.

21 MR. DALEY: Which is why I put the and
22 there in bold and underlined.

23 MEMBER BROWN: Hold it. You know, you
24 keep mixing these as if they are occurring within
25 milliseconds or seconds or minutes of each other.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Once I'm operating for a couple of weeks, I can't --
2 that's not a double failure mode. I made a decision
3 to operate with something broken.

4 MR. HEAD: There is no time there.

5 MEMBER BROWN: I'm sorry I get --

6 MR. HEAD: We are saying that has to
7 happen.

8 MEMBER BROWN: -- excited every now and
9 then.

10 MR. CHAPPELL: I think it's analogous to
11 ECCS systems being out of service. I can run
12 continuously. Well, if I lose a train, I don't have
13 to shut down because there might be some problem with
14 the other ones. I have to do -- I have a limited
15 amount of time which I can run under those conditions.

16 MEMBER BROWN: No, but you could have a --
17 but you can handle single failure in those other ones
18 where each of the other -- one of the other trains
19 will operate. In this case, you can have a single
20 failure which doesn't allow any more trains to
21 operate. Different circumstance, so your analogy is
22 not very good.

23 MR. HEAD: You're not -- you can't handle
24 single failure with all tech specs, you know, LCOs. I
25 mean, that's -- your outside design basis at that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 point in time. So that's not -- for some
2 configurations, some three train plants, you can be
3 like that. But if you are in tech specs, that means
4 you are already outside design basis and single
5 failure is not. So that is somewhat analogous to
6 this.

7 MEMBER BROWN: Well, actually, I don't
8 agree with that just because you are not quite within
9 the design basis, still doesn't mean that the system
10 won't work and you won't minimize effects. Here you
11 can't minimize any effects. You just throw blades
12 through the housing.

13 MR. HEAD: Well, I don't -- I think if
14 that's the conclusion, then we, obviously, you know,
15 need to come back and discuss this some more. And I
16 would think --

17 CHAIR ABDEL-KHALIK: Yes, I'm not sure we
18 are converging at all.

19 MR. HEAD: No.

20 MEMBER BROWN: No, we are not converging
21 right now. I just -- I won't say that. John's point
22 is valid. If there are other controlled functions --

23 MR. HEAD: Yes, and that's what we are
24 going to --

25 MEMBER BROWN: -- within this --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR ABDEL-KHALIK: If you can
2 demonstrate that then --

3 MEMBER STETKAR: For take-away, you know.

4 MEMBER BROWN: That is what I -- that's
5 what my take-away would be.

6 MEMBER STETKAR: If there are other things
7 that will intervene to trip that turbine?

8 MR. CHAPPELL: And they are described in
9 Section 10.2. You know, we could --

10 MEMBER BROWN: Relative to this
11 circumstance?

12 MEMBER STETKAR: No, no, no, no.

13 MEMBER BROWN: I'm sorry, John.

14 MEMBER STETKAR: Under the circumstance
15 where the normal speed control system knows that the
16 turbine rotor speed is zero, so just take that as your
17 initiating event. Don't take a generator fault, don't
18 take, you know, any of the other turbine trip signals
19 out there. Take as your initiating event a condition
20 where the normal speed control system knows that the
21 turbine rotor speed is zero.

22 Now, then what will happen? I don't know,
23 you know. The first question is will the governor
24 valve open or not? And if it is totally under
25 pressure control and it only looks at electrical load

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 versus, you know, don't -- reactor dome pressure to
2 control the governor valve position, probably the
3 answer is nothing is going to happen.

4 If that's not the case, if, indeed, the
5 governor valve is going to come open from that
6 condition because speed also factors into it to
7 control, you know, algorithms, then the question is if
8 the governor valves now do go wide open, what trip
9 will come in and open the hydraulic fluid valve?

10 MR. DALEY: Realizing there is another and
11 in that, because if you have a sensor failure in your
12 active sensors, you get a turbine trip.

13 MR. CHAPPELL: That causes a turbine trip
14 in itself, but --

15 MR. DALEY: But you've got to say that
16 doesn't happen.

17 MEMBER STETKAR: Well, and that's -- I'm
18 trying to get -- I know that. And I'm trying to get
19 past -- a little bit past the word sensors to try to
20 help some of Charlie's concern, because it might not--

21 MEMBER BROWN: It's input to the
22 processes.

23 MEMBER STETKAR: I was using the term the
24 turbine speed control system knows however it gets to
25 know that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HEAD: I guess back to an aspect,
2 clearly, if you are in this failure and you in your
3 response procedures, the operators are going to be
4 aware that they are in a degraded position and they
5 are going to be observing the plant. And if any of
6 the things that you are talking about happen, then
7 they are going to be required to make decisions based
8 on that also.

9 And so we will attempt to go to the
10 automatic action, but I don't think that is what is
11 going to happen first. I think you are going to have
12 operators seeing things happen that they are going to
13 then react to.

14 And so I don't want to leave this
15 discussion with thinking that these -- you know, the
16 control room would not be already taking some action
17 if this second failure happened.

18 MEMBER STETKAR: You can see the
19 fluctuations.

20 MEMBER BROWN: That's not the point.

21 CHAIR ABDEL-KHALIK: They may be
22 distracted with something else at the time.

23 MEMBER STETKAR: Well, you know, if that
24 action is trip the turbine, that's good. If it is
25 trip the reactor, that's probably okay. If it's open

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 -- if the first thing they grab for is the generator
2 breaker, that's not so good.

3 CONSULTANT WALLIS: I agree.

4 MR. CHAPPELL: Typically, in this
5 condition if you are going to do that -- you know, I
6 think, we get in this condition if you're going to
7 trip the turbine, you're going to trip the reactor
8 first, with the turbine.

9 CHAIR ABDEL-KHALIK: So you have an
10 understanding of how you are going to proceed to try
11 to find out --

12 MR. HEAD: I visualize --

13 CHAIR ABDEL-KHALIK: -- there is something
14 in the design that would allay that concern?

15 MR. HEAD: Yes.

16 MR. CHAPPELL: If we come back with that
17 level of detail, would that give us enough common
18 ground where we could --

19 CHAIR ABDEL-KHALIK: Yes.

20 MS. BANERJEE: Can I just say something,
21 please?

22 MEMBER BROWN: Yes, as long as it is
23 articulated somewhere. Just not let up in the ether.

24 MS. BANERJEE: So we can --

25 MEMBER BROWN: The point being is you want

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to make sure there is something within the design
2 space with which you are designing the plant that
3 actually achieves what you talk about when you come
4 back. If it is not written down, that means it can be
5 whatever happens three, four or five years from now.

6 CHAIR ABDEL-KHALIK: We will just leave
7 this action item the way it is.

8 MR. HEAD: Sure.

9 MS. BANERJEE: Okay.

10 MR. HEAD: Absolutely.

11 CHAIR ABDEL-KHALIK: Okay. We will just
12 leave it the way it is.

13 MR. HEAD: Understood.

14 CHAIR ABDEL-KHALIK: Let's break for
15 lunch --

16 MR. HEAD: Let's take discussion on this.

17 CHAIR ABDEL-KHALIK: -- at this time. We
18 will reconvene at 1:00.

19 (Whereupon, the Open Session meeting was
20 recessed at 12:00 p.m. to reconvene at 12:58 p.m. this
21 same day.)
22
23
24
25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N

2 12:58 p.m.

3 CHAIR ABDEL-KHALIK: We are back in
4 session. Before we get back to you, Don Dube would
5 like to make a comment.

6 MR. DUBE: Yes, thanks. Thanks. Is this
7 working?

8 CHAIR ABDEL-KHALIK: Yes.

9 MR. DUBE: Thanks, Mr. Chairman. Don
10 Dube, Office of New Reactors, Division of Safety
11 Systems and Risk Assessment.

12 Really, just a couple comments more in the
13 line of observations, because this is the first time I
14 had seen the extended Station Blackout analysis. If I
15 can contribute to the discussion, if it would be worth
16 your effort.

17 Something -- a comment was made or a
18 discussion was made regarding the importance of dc
19 battery life. And I just want to note, you know, we
20 have the ABWR SPAR model, which is a very close PRA
21 model to the applicant's design control document PRA
22 model.

23 And there it is noted that, you know, the
24 ability to extend dc power especially to keep open,
25 for example, the safety relief valves in the long-term

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 when one is using ac-independent water addition is
2 highly critical and at least is modeled in the SPAR
3 model sequences where there is an ability to maintain
4 the safety relief valves open for an extended period
5 of time and recover off-site power and contribute
6 about 18 percent to the internal events core damage
7 frequency.

8 So it's a very -- my point is, it's a very
9 important aspect of extended Station Blackout is the
10 ability to restore dc power to be able to keep a
11 safety relief valve open.

12 Another observation is with regard to the
13 setpoint for the ruptured disc on the containment
14 over-pressure system or event capability. On the
15 whole, the advantages of a passive feature like that
16 far outweigh that of a hardened vent or a venting
17 capability that relies on a lot of manipulation of
18 valves, because there is a lot of dependencies on ac
19 power, dc power, maybe even pneumatic. And so passive
20 design offers a lot of features.

21 The only thing I will note is that the
22 setpoint of 104 psia or normally 90 psig it's quite a
23 bit higher than what you see in the current fleet.
24 Now, there is advantages and disadvantages.
25 Obviously, one advantage is to avert -- to avoid or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 prevent an inadvertent actuation of containment
2 venting.

3 But the other thing is that it does delay
4 containment depressurization and, under some
5 circumstances, there can be some disadvantages such
6 as, you know, the back pressure resulting from such a
7 high setpoint may preclude certain options for ac-
8 independent water addition if you look at the
9 hydraulics of the fire protection system, the back
10 pressure and the pressure drops for various piping
11 locations.

12 In some circumstances, it may be
13 advantageous or one may have wished that one had a
14 lower setpoint to not preclude certain options. And
15 I'll just make a note the one passive plant that I'm
16 aware of in a currently operating reactor Vermont
17 Yankee, has a design pressure of 56 psi gauge and the
18 setpoint for the ruptured disc is 59, plus or minus 3
19 psig. So they vent pretty quickly.

20 And so, you know, one of the lessons
21 learned that I guess we will still be learning these
22 lessons from the Fukushima accident is that, you know,
23 delaying containment venting was a big disadvantage in
24 that particular accident because it precluded a lot of
25 ability to get low pressure systems in.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So just a couple of observations. I don't
2 think it's going to change any conclusions, but I
3 think we will hear more about that in the future.

4 CHAIR ABDEL-KHALIK: Thank you, Don.

5 MR. THOMAS: I'll just comment on your
6 comment, I suppose. This is Steve Thomas again,
7 Engineering Manager for STP 3 and 4.

8 That's an excellent observation. Our
9 earlier presentation, of course, was what has already
10 been evaluated for the ABWR. And certainly in like of
11 Fukushima, we are looking at other enhancements to the
12 containment over-pressurization systems, such as
13 bypasses, which would require active systems or
14 lowering setpoints and things like that. We are just
15 not at that point.

16 CHAIR ABDEL-KHALIK: Yes, it was very
17 clear from Scott's comment that this is where we are
18 now.

19 MR. THOMAS: We will come to understand
20 and agree with your observations.

21 CHAIR ABDEL-KHALIK: Thank you.

22 MR. DUBE: Sure.

23 CHAIR ABDEL-KHALIK: There's another
24 comment?

25 MR. FULLER: Yes. This is Ed Fuller from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the Office of New Reactors. I'm sorry I wasn't here
2 this morning. I had conflicting meetings. I'm
3 looking at the slide where you looked at the sequence
4 of events for the case where you had a Station
5 Blackout without the CTG, but then you were bringing
6 up the ac-independent water addition system to
7 depressurize the vessel.

8 I noticed that you are saying that it
9 would take around a little less than two hours to line
10 it up and do the depressurization. And during that
11 period of time, it is pretty apparent from events that
12 have transpired within the last six or eight months
13 that you would have core damage before you got to that
14 point.

15 Suppose for some reason you had not been
16 able to line it up quickly enough and it took you
17 another hour or two, have you folks assessed what the
18 consequences might be and what you might want to do
19 with the ac-independent water addition system if the
20 vessel failed?

21 MR. TONACCI: Excuse me, Mr. Chairman, I'm
22 not sure where we are in process here.

23 CHAIR ABDEL-KHALIK: Well, these two
24 gentlemen were not able to attend the presentation on
25 the extended SBO Mitigation and they requested time to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 make a comment just for the Committee's enlightenment.

2 MR. TONACCI: Okay.

3 CHAIR ABDEL-KHALIK: So with that, that's
4 why I allowed these comments. So if you will, please,
5 continue?

6 MR. FULLER: I finished the comment, the
7 question.

8 CHAIR ABDEL-KHALIK: Okay. Thank you.

9 MR. FULLER: You were --

10 CHAIR ABDEL-KHALIK: You may or may not
11 answer this question.

12 MEMBER ARMIJO: You were referring to
13 Slide 6?

14 MR. FULLER: Yes.

15 MEMBER ARMIJO: Okay.

16 MR. HEAD: Well, as to the second comment,
17 you know, what Steve has said in the industry, we are
18 going to be looking at all aspects of it. I did want
19 to say though in the scenario that we were presenting,
20 there was no core damage.

21 CHAIR ABDEL-KHALIK: Right, yes.

22 MR. HEAD: I believe there was a -- you
23 mentioned that we could have -- we would have --

24 UNIDENTIFIED SPEAKER: A little bit
25 longer.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HEAD: Right. So I just wanted to
2 clarify that.

3 CHAIR ABDEL-KHALIK: Right. He is talking
4 about what if it took longer. And we haven't been
5 surprised --

6 MR. HEAD: We haven't done that
7 evaluation.

8 MR. FULLER: There wasn't core damage, but
9 if you say there wasn't, there wasn't.

10 MR. HEAD: That first eight hour RCIC is
11 still operating.

12 MR. FULLER: No, I mean between eight
13 hours and 9.8 hours.

14 MR. HEAD: Yes, go ahead.

15 MR. THOMAS: We have not evaluated. I
16 certainly agree with you. As Dr. Wallis pointed out,
17 there is certainly some time-dependent assumptions in
18 that analysis and if those time things aren't met,
19 then there may be different results.

20 A point of our presentation was simply to
21 demonstrate the as-designed current capabilities and
22 what has been analyzed to date.

23 MR. FULLER: Right.

24 MR. THOMAS: Certainly, we are going to
25 reevaluate many of those things as the industry events

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 provide us further insights.

2 CHAIR ABDEL-KHALIK: Let's get back to the
3 agenda.

4 MR. FULLER: Okay. Thank you very much.

5 CHAIR ABDEL-KHALIK: Thank you.

6 MR. FULLER: Thanks for letting me
7 comment.

8 MR. HEAD: Okay. We are on to Action Item
9 #62. I'll turn it back over to Tom.

10 MR. DALEY: Good afternoon. Action Item
11 #62 involved the question about how the ultimate heat
12 sink water storage basin design volume, as described
13 in DCD, accounts for a pipe crack that might occur
14 during the 30 day duty time, specifically, DCD states
15 that a single passive failure of reactor service water
16 piping is considered and the water loss is based on a
17 30 minute response time.

18 Now, I don't know if it was our last
19 meeting or the meeting before when we discussed this.

20 We talked about the fact that the DCD Subsection 19
21 allows this 30 minute response by a control room
22 operator to locally isolate a leak.

23 And we also talked about if there was a
24 leak in the reactor service water piping in the pump
25 house, there would be some indication of that either

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 through a sump alarm or we have flooding monitors in
2 that area as well.

3 And we also mentioned that the inventory
4 in the basin accounts for this 30 minute response
5 time. It has an additional 25,000 gallons to allow
6 for the operator to get and isolate the leak. Well,
7 that all assumes that you can isolate the leak. And
8 really the question came down to what do you do about
9 a leak that you can't isolate? Meaning between the
10 basin itself and the first isolation valve on the pump
11 suction.

12 And really it doesn't account for that
13 amount, however, we have accounted for it in the
14 design. Now, that is we have exercised the capability
15 of designing this piping to very low stress levels,
16 such that we don't have to postulate a crack in the
17 pipe. We designed super-pipe, is what it used to be
18 termed. And the DCD and SRP allows us to do that.

19 If you look closely at it --

20 MEMBER STETKAR: So this pipe can't break?

21 MR. DALEY: This pipe -- and it's designed
22 as Seismic Category 1, so it can't --

23 MEMBER STETKAR: Oh, as is the whole RSW.

24 MR. DALEY: As is the whole RSW. So as
25 the pipe can break --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Does this pipe break?

2 MR. DALEY: As is the ultimate heat sink
3 basin, so we design it to those higher standards so
4 it's not subject to those.

5 MEMBER STETKAR: But if the pipe -- if
6 none of the pipe can break, why do the analyses say
7 that if a pipe break occurs, I have 30 minutes to
8 isolate it? And why does the design account for that
9 30 minute inventory for isolable breaks if the pipe
10 can't break?

11 MR. DALEY: That's a good point. We don't
12 design all of the pipe using this crack exclusion
13 criteria.

14 MEMBER STETKAR: Okay.

15 MR. DALEY: We just design the non-
16 isolable portions to this lower level of stress
17 levels.

18 MEMBER STETKAR: In -- and I'm not a
19 materials guy, so I'm going to keep quiet about the
20 crack exclusion stuff, because I don't know what that
21 means.

22 MEMBER ARMIJO: Well, yes, I was going to
23 ask you about your -- you use the word leak. I mean,
24 this has got to be a fracture of the pipe --

25 MR. DALEY: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: -- to be -- to have any
2 impact on you guys as opposed to a little leak, a
3 pitting leak or a stress corrosion cracking-related
4 leaks. So those are --

5 MEMBER STETKAR: They use -- for
6 reference, the reason I stumble over this, it says in
7 Section 92.5.5.2 of the FSAR, it says "A single
8 passive failure of the RSW piping is considered in the
9 system. A crack is assumed with a leakage flow based
10 on a circular orifice with flow area equal to one-half
11 of the piping outside diameter multiplied by one-half
12 of the nominal wall fittings."

13 So it's not just a drip leak.

14 MEMBER ARMIJO: It's a big leak.

15 MEMBER STETKAR: It's a big leak. They
16 have 30 minutes to isolate the leak. So I originally
17 asked what's the basis? How do you know you have at
18 least 30 minutes for a leak anywhere? And there are
19 sections of this piping that you cannot isolate.

20 MEMBER ARMIJO: Right, right. So for
21 those sections, you have designed them as Seismic
22 Category 1?

23 MR. DALEY: The whole system is --

24 MEMBER ARMIJO: The whole system is
25 Seismic Category 1?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. DALEY: Those portions were designed
2 for the stress levels that are less than, off the top
3 of my head, I believe it is, 40 percent of the
4 allowable stress levels for that kind of pipe. And
5 that leakage is right from the guidance. The guidance
6 -- when you partially have a leak, here is how to --

7 MEMBER ARMIJO: Okay. Okay.

8 MEMBER STETKAR: Tom? Tom, the second
9 bullet on this slide, I always get careful when I see
10 a lot of qualifiers. It says the non-isolable piping
11 in the RSW pump rooms is designed using crack
12 exclusion criteria. What about the non-isolable
13 piping between the basin and the pump room?

14 MR. DALEY: Yes.

15 MEMBER STETKAR: And how much -- how long
16 is that piping run? And is it also designed to be
17 non-isolable, the crack exclusion stuff? Or are they
18 -- I didn't have a good -- I see. Never mind.

19 MR. DALEY: Okay.

20 MEMBER STETKAR: Thank you. I see the
21 answer to my question.

22 MEMBER ARMIJO: Where do you see it?

23 MEMBER STETKAR: It's isolable.

24 MEMBER ARMIJO: You can isolate it?

25 MR. DALEY: No. The key is it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 immediately adjacent. I didn't know whether there
2 were -- the basins were separated by, you know, 25 or
3 30 yards of underground piping or something like that.

4 MEMBER STETKAR: They are right at the
5 basin. The pump and the basin, so it's not --

6 MEMBER ARMIJO: Okay. Thanks.

7 MEMBER STETKAR: -- as far as it used to
8 be, but it's still pretty far.

9 CHAIR ABDEL-KHALIK: Okay.

10 MEMBER ARMIJO: Thank you.

11 MR. HEAD: Does this address this
12 question?

13 MEMBER STETKAR: Yes. That addresses the
14 non-isolable part of it. And the 30 minutes you have
15 done analyses to show that in any of the isolable
16 sections that a leak that large we will give you a 30
17 minute time window to isolate it and still maintain
18 enough inventory in the basin.

19 MR. DALEY: Yes, we have included that
20 inventory in the basin.

21 MEMBER STETKAR: That extra inventory in
22 the basin.

23 MR. DALEY: That's correct, yes.

24 MEMBER STETKAR: Okay.

25 MR. HEAD: And you almost said that the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 other way around. We assume the 30 minutes. And then
2 you add that amount of leakage to the heat sink --

3 MEMBER STETKAR: Yes, okay. Either way
4 you get to the answers.

5 MR. HEAD: Yes, right.

6 MEMBER STETKAR: Either way you say it.

7 MR. HEAD: So that's water you assume that
8 has got to be there, but it isn't going to be there
9 for you.

10 MEMBER STETKAR: You have accounted to the
11 largest isolable section.

12 MR. DALEY: And that's good so that if you
13 ever noticed, they do have a packing leak or
14 something, you don't get into some tech spec limit or
15 anything like that.

16 MEMBER STETKAR: Packing leaks, I'm not so
17 concerned about.

18 MR. DALEY: Right.

19 MEMBER STETKAR: A break -- you know, this
20 says that the design is tolerant of a break this
21 large.

22 MR. DALEY: Yes.

23 MEMBER STETKAR: Of this amount of
24 leakage, so --

25 MEMBER SHACK: What is this material for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this piping?

2 MR. DALEY: It's stainless steel.

3 MEMBER SHACK: But I mean, it's not AL6X
4 or some super type alloy?

5 MR. DALEY: Not yet, it's not. But as --

6 MEMBER SHACK: You know, the trouble with
7 this crack exclusion is it's a criteria set up by
8 mechanical engineers, obviously.

9 MR. DALEY: Yes, right.

10 MEMBER SHACK: Where it all depends on
11 stress level. Whereas, it's probably the most likely
12 failure here is corrosion. And, you know, it's a
13 little tougher to guarantee it won't corrode if it's,
14 you know, ordinary stainless steel --

15 MR. DALEY: Yes.

16 MEMBER SHACK: -- in a muggy environment.

17 MR. DALEY: In the certified design, it is
18 stainless steel, but we are looking at other materials
19 on the side in preparation for potential possible
20 changes in the future HDPE, chrome-moly.

21 MEMBER SHACK: Yes.

22 MR. DALEY: That sort of thing.

23 MEMBER SHACK: Plain carbon steel.

24 MR. DALEY: Yes.

25 MEMBER ARMIJO: But all of this piping

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 would be cathodically protected if you had -- if you--
2 or not?

3 MR. DALEY: No, it's stainless steel.

4 MEMBER SHACK: No, because this --

5 MR. DALEY: None of this is buried. None
6 of this is buried. It's not buried.

7 MEMBER STETKAR: Oh, that's what that
8 second drawing --

9 MEMBER ARMIJO: So where is the corrosion
10 going to come from?

11 MR. DALEY: Pardon?

12 MEMBER ARMIJO: Where is the corrosion
13 concern?

14 MR. DALEY: We will have ultimate heat
15 sink water running in this thing for 60 years, so we
16 will be inspecting this pipe on a regular basis.

17 MEMBER ARMIJO: Okay.

18 MR. DALEY: Wall thickness, measurements.

19 MEMBER ARMIJO: Yes.

20 MEMBER STETKAR: But it's an open element
21 system, you know. It's exposed to the air.

22 MR. DALEY: Yes.

23 MEMBER STETKAR: It's got -- you know, so
24 it's --

25 MEMBER ARMIJO: Circulate, right? It's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not stagnant.

2 MEMBER SHACK: No. This is just plain old
3 garbage water.

4 MEMBER ARMIJO: Oh, wait a minute. You
5 should take exception there.

6 MR. DALEY: Yes, we do.

7 MEMBER STETKAR: Okay. I'm sorry.

8 MEMBER ARMIJO: We didn't mean that.

9 MEMBER SHACK: But it's not reactor
10 cooling system water.

11 MEMBER STETKAR: Yes, right.

12 MEMBER SHACK: Nor is --

13 MEMBER STETKAR: Yes, and it's not a river
14 either.

15 MEMBER SHACK: It's not a river. It's not
16 the Gulf of Mexico, that's true.

17 MR. DALEY: Exactly, yes.

18 MR. HEAD: Okay. With that clarification,
19 have we addressed this?

20 MEMBER STETKAR: Yes. I mean, as long as
21 people who know about material things are happy with
22 the crack exclusion stuff.

23 MEMBER ARMIJO: I'm happy.

24 MR. HEAD: You know, it's used in a couple
25 of places on 1 and 2, you know, Units 1 and 2. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 mean, it is --

2 MR. DALEY: Containment isolations, areas
3 have used that criteria for many years.

4 CHAIR ABDEL-KHALIK: Okay. Let's proceed.

5 MR. HEAD: #63.

6 MR. DALEY: Action Item #63 has to do with
7 the available net positive suction head calculation
8 that was -- that's in the DCD. Originally, we had
9 some of these numbers in here based on 100 degrees
10 centigrade.

11 And so the question of the -- looking at
12 the equation itself and the numbers in the equation
13 came up and so what we have done here is we have
14 listed the available NPSH calculation and we have
15 shown -- we have listed the values for the various
16 parameters here on this slide.

17 And it's a simple matter of adding these
18 all up. And it comes out, if you consider the static
19 head, which is shown on the drawing Coley had flashed
20 up here earlier, which has to do with the level in the
21 basin, and we do this calculation at the end of the 30
22 day period. Go ahead and bring it back, Coley, so I
23 don't have to do this from memory.

24 And you consider the atmospheric head,
25 which is on the water as well.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CONSULTANT WALLIS: Well, that could vary
2 by plus or minus 10 percent or something, too.

3 MR. DALEY: That could.

4 CONSULTANT WALLIS: Could come with 28
5 inches of water or 28 whatever and so 30, then you
6 have got to think different.

7 MR. CHAPPELL: We have some -- that last
8 line alludes to some of the additional conservatisms.

9 MR. DALEY: Yes. And then, of course, you
10 subtract away the vapor pressure and you subtract away
11 the frictional losses and that's what you have
12 available for NPSH to the pump.

13 In our situation, we have applied a 10
14 percent margin on that value. So we are saying that
15 there is less available than what there actually is.
16 And that number 15.9 meters is consistent with the
17 value that we have listed in the DCD, in the COLA now.

18 MEMBER STETKAR: I guess this shows --
19 okay.

20 CHAIR ABDEL-KHALIK: Can I just ask a
21 question while you are thinking about it, John?

22 MEMBER STETKAR: Yes.

23 CHAIR ABDEL-KHALIK: Is there a tech spec
24 limit on the 95 degrees?

25 MR. DALEY: On the 95 degrees? Yes, there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is.

2 CHAIR ABDEL-KHALIK: Okay.

3 CONSULTANT WALLIS: It's kind of
4 roundabout listing, because if there is no flow
5 because of gravitation, there is no frictional loss
6 either. So it's intermittent. If it's beginning to
7 cavitate, you won't get the flow, so you won't get
8 such a high friction loss.

9 MR. DALEY: So it will stop cavitating and
10 then it will go --

11 CONSULTANT WALLIS: There is no way --
12 well, that's the whole NPSH. You will get an error
13 coming out of solution.

14 MR. DALEY: Yes.

15 CONSULTANT WALLIS: Probably that doesn't
16 matter enough to be considered.

17 MEMBER STETKAR: I'm still -- well, I
18 think -- help me out on this, because I'm trying to
19 process -- I didn't see this calculation before hand,
20 so I'm trying to process this and look at numbers that
21 originally prompted this question.

22 In the FSAR it says "The minimum water
23 level in the ultimate heat sink basin, after a 30 day
24 operation, following the design basis accident is set
25 at 1.83 meters above the suction lines center line,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 above the pump suction center line."

2 1.83 meters is about --

3 MR. DALEY: 8 feet.

4 MEMBER STETKAR: -- 8 feet. So I'm not
5 sure where the static head of 31.17 feet comes from in
6 your calculation here if, indeed, it is 1.89 meters.

7 MR. CHAPPELL: It's the 22 plus 8 plus 1.

8 MR. DALEY: This is --

9 MEMBER STETKAR: Because the ultimate
10 conclusion in the FSAR is that you meet -- there is a
11 table that says at the end of 30 days, you have an
12 available net positive suction head of 16.9 meters,
13 which is kind of close to the numbers that you have on
14 that slide, but --

15 MR. DALEY: Yes. This slide here shows
16 the center line from the pipe to the top of the --

17 MR. CHAPPELL: No, the minimum water level
18 is -- the minimum water shown is 17 feet there.

19 MR. DALEY: Right.

20 MR. CHAPPELL: And then you have -- where
21 you have this sump that comes in as berm, that's --
22 there is a flow to the top of that and then it shows
23 the distance as 8 feet to the top of the center line
24 of the suction and then another 22 feet and 2 inches
25 that goes down to the pump center line suction.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So stepping that up, it gets 22.2 plus 8
2 plus 1 and that gets you to the 17 foot minimum, which
3 is the minimum water level.

4 MEMBER STETKAR: But that's not -- my
5 interpretation of the pump suction center line is
6 down --

7 MR. SMITH: By the pump.

8 MEMBER STETKAR: -- by the pump.

9 MR. CHAPPELL: Yes, right.

10 MR. DALEY: It's called the suction.

11 MEMBER STETKAR: That's right.

12 MR. DALEY: The center line really is that
13 pipe that is at 8 feet below the --

14 MEMBER STETKAR: Right.

15 MR. CHAPPELL: Right.

16 MEMBER STETKAR: And that's what you are
17 calling the pump suction center line.

18 MR. DALEY: That's what the DCD --

19 MEMBER STETKAR: Oh, okay.

20 MR. CHAPPELL: And then another 8 feet up.

21 MR. DALEY: It's the difference in what we
22 are interpreting as the pump suction center line.

23 MEMBER STETKAR: Yes. But that means one
24 of suction piping as it goes through the --

25 MR. DALEY: I've got it. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: I was looking at the pump
2 suction center line down there in the basement of the
3 building where the pump suction center line is and
4 adding up 1.83 meters above there and trying to figure
5 out where the water was.

6 MR. DALEY: Okay. Okay.

7 MEMBER STETKAR: I understand.

8 MR. DALEY: Okay.

9 MEMBER STETKAR: That's fine.

10 CHAIR ABDEL-KHALIK: Okay.

11 MEMBER STETKAR: We can close this out.
12 Thanks.

13 CHAIR ABDEL-KHALIK: And the 10 percent
14 margin should account for any variability --

15 MEMBER STETKAR: Yes.

16 CHAIR ABDEL-KHALIK: -- in the
17 atmospheric pressure.

18 MEMBER STETKAR: Yes, yes.

19 CHAIR ABDEL-KHALIK: Okay. Let's move on.

20 MR. DALEY: #101. And we might cover some
21 things that we talked a little bit about this morning
22 in the course of this discussion as well. And this
23 action item results from a discussion we had a couple
24 of meetings ago about the 77 degree C and when under
25 Station Blackout how long do we have until we get to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 77 degrees?

2 Well, now under Station Blackout
3 considerations, RCIC will start off by taking suction
4 on condensation storage tank. And it will switch over
5 to the suppression pool when the level in the
6 suppression pool gets a little bit higher. But then
7 we -- by the EPGs, we override that and put it back on
8 the condensation storage tank.

9 And that condensation storage tank will
10 provide about eight hours of water supply. And a
11 backup source, as I mentioned, is a suppression pool.

12 That suppression pool continues to heat up as a
13 result of SRV discharge and the RCIC pump discharge to
14 the suppression pool. And then it will reach 77
15 degrees in approximately six hours.

16 So but in this situation, we don't -- we
17 won't switch off RCIC at that point. It will still
18 run, because actually in the containment as the
19 suppression pool heats up, it maintains saturation
20 conditions with the rest of primary containment. So
21 the pressure and primary containment is increasing as
22 well along with the temperature.

23 And the level in the suppression pool is
24 increasing as well and both of those will contribute
25 to the NPSH for the pump. So the pump will really run

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 as long as we keep pressure in the reactor vessel to
2 drive the turbine.

3 And that will stay in there until we
4 depressurize. Now, there are some other limits that
5 might cause us to secure the RCIC pump. We talked
6 about this morning what happens if the temperature in
7 the RCIC room heats up and some equipment in there
8 starts to fail?

9 Well, DCD says that temperature needs to
10 be above 151 degrees and you will reach that in about
11 eight hours. I think Steve mentioned that this
12 morning that DCD states that we have got about eight
13 hours for the room to heat up to where all the
14 equipment is qualified.

15 The emergency procedure guidelines will
16 have us depressurize if the suppression pool
17 temperature gets above a certain degree, a certain
18 temperature. And right now, that says if it gets up
19 to about 275 degrees fahrenheit, you need to
20 depressurize the reactor. And that will occur in
21 about 16 hours.

22 Also, if we reach the pressure in the
23 containment where the COPS rupture disc ruptures, now
24 we no longer have this pressure in containment that is
25 maintaining the NPSH. So we might lose NPSH to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 turbine at that point. And as we mentioned this
2 morning, that point will happen around 32 hours.

3 In our discussions with the RCIC pump
4 manufacturer, he states that the bearings in here are
5 rated -- bearings for the pump are rated for 250
6 degrees fahrenheit and will reach that in about 12
7 hours.

8 So you can see just from these various
9 limits on things other than the pump just running, we
10 will be able to operate it from anywhere from eight to
11 32 hours.

12 CONSULTANT WALLIS: So for RCIC you are
13 allowed to use containment over-pressure?

14 MR. DALEY: Not in a design basis
15 situation.

16 CONSULTANT WALLIS: Not in the design
17 basis?

18 MR. DALEY: You're right. But this is
19 beyond -- this is --

20 CONSULTANT WALLIS: Beyond the design
21 basis.

22 MR. DALEY: -- beyond design. So we --
23 this is reality as we know now. So we can run that
24 thing as long as we can run it. However, what we
25 talked about this morning and mentioned is what we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 really want to do is get on ac-independent water
2 addition.

3 So we are going to use the time-run RCIC
4 to get ready and switch over onto ACIWA. So that's
5 the real answer to how long will we run RCIC. We will
6 run RCIC until we get on ACIWA.

7 CONSULTANT WALLIS: By depressurizing?

8 MR. DALEY: Pardon?

9 CONSULTANT WALLIS: By depressurizing?

10 MR. DALEY: By depressurizing and hooking
11 up the --

12 CONSULTANT WALLIS: If you're in doubt,
13 you might want to depressurize earlier.

14 MR. DALEY: Absolutely.

15 CONSULTANT WALLIS: All right.

16 MR. CHAPPELL: I think we'll look at
17 options as we get into that and how we are trying to
18 respond to keeping the RPV control and primary
19 containment controls. We will look at options there.

20 MR. DALEY: And I think that covers it.

21 CONSULTANT WALLIS: The last thing you
22 want to do is hang on to the RCIC long, long, long,
23 then you find you don't have time to depressurize
24 effectively before, you know, something happens.

25 MR. DALEY: Yes. Well, we will -- the way

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we envision it is we will have ACIWA all lined up and
2 someone will say depressurize and we will start the
3 pump up.

4 MR. HEAD: Or we will be assessing
5 whatever has caused the Station Blackout and if
6 that's, you know, about to be addressed, we may head
7 down that path, you know. So there will be a number
8 of options available to us as we go through that and
9 clearly the eight hours is the analysis, but clearly
10 in the event, you know, we will be exploring all of
11 those options.

12 MEMBER STETKAR: And that's part of the
13 concern that you only have a limited number of people
14 to explore a large number of options. And some folks
15 might be reluctant to depressurize because although
16 everybody knows the RCIC turbine will run on, you
17 know, puffs of air --

18 MR. HEAD: You say a limited amount of
19 people, but within an hour we will have a technical
20 support center.

21 MR. DALEY: Yes, and I think --

22 MR. HEAD: And we will have personnel from
23 the other unit, unless there is multiple units, so
24 there is going to be quite a bit of assessment ability
25 and decision making ability on station right before we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 get to the eight hour point.

2 CONSULTANT WALLIS: There is something to
3 be said about having a conservative option where they
4 don't have to think too much about too many things.

5 MR. DALEY: Well, and I think the guidance
6 that is going to be available to us when we start it
7 up is going to be sufficiently, you know,
8 sophisticated that we will have some pretty clear
9 guidance as far as what we should be doing under
10 different situations.

11 CONSULTANT WALLIS: Well, I'm thinking
12 about TMI. TMI, the problem there was that several
13 things went wrong.

14 MR. DALEY: Right.

15 CONSULTANT WALLIS: And they had -- didn't
16 manage to resolve it all in their minds and did the
17 wrong thing. So this is okay unless something else is
18 happening at the same time.

19 MR. DALEY: Well, and certainly there will
20 be something else, that's why I'm saying I think the
21 guidance will be developed sufficiently to provide
22 some clear direction.

23 CONSULTANT WALLIS: But something else
24 unexpected like someone having left a valve closed or
25 something.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR ABDEL-KHALIK: Yes.

2 MR. DALEY: That's correct.

3 CHAIR ABDEL-KHALIK: Yes, John?

4 MEMBER STETKAR: I was going to say, you
5 know, back to -- pulling back to the original question
6 that I asked was at least the heat-up analyses that we
7 just heard about gives me confidence to have at least
8 six hours before you get to that nominal 77 degrees C,
9 hands off, five hours, six hours, something like that,
10 without even taking credit for any extra pressure in
11 the suppression pool and things like that, so it's not
12 an hour. It's not 30 minutes. It's not --

13 CHAIR ABDEL-KHALIK: Okay.

14 MEMBER STETKAR: -- you know, an hour and
15 a half.

16 MR. CHAPPELL: And also, if you are not
17 considering that the condensation storage tank gets
18 your suction source during the eight hour time frame,
19 so that just says up until that six hour point, the
20 suppression pool is the option.

21 MEMBER STETKAR: And I wasn't because the
22 condensation storage tank might not be there.

23 MR. CHAPPELL: Yes.

24 MEMBER STETKAR: So I was sort of thinking
25 about taking the suction from the suppression pool, so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that's fine.

2 CHAIR ABDEL-KHALIK: Okay. So you are
3 happy with closing this item, John?

4 MEMBER STETKAR: Yes, I think so.

5 CHAIR ABDEL-KHALIK: Okay.

6 MEMBER STETKAR: Yes.

7 CHAIR ABDEL-KHALIK: All right. Are there
8 any additional questions to the applicant? Okay. I
9 don't hear any.

10 Could you, please, make sure that the
11 bridge line is open?

12 MS. BANERJEE: Line is open?

13 CHAIR ABDEL-KHALIK: At this time, we
14 are --

15 MR. HEAD: Do we want just a recap of
16 everything?

17 CHAIR ABDEL-KHALIK: Yes, sir.

18 MR. HEAD: Is that okay?

19 CHAIR ABDEL-KHALIK: Let's do that.

20 MR. HEAD: From earlier this morning, #98
21 and #99 were closed. #80 we have got some additional
22 understanding of what we want to do on #80, which was
23 the exponent. #49 we had a further understanding, but
24 it's still open. So #80 and #49 are still open.

25 CHAIR ABDEL-KHALIK: Oh, you mean #47.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: #47.

2 MR. HEAD: #47. Okay. Sorry. #100 is
3 closed. I believe we answered all your questions on
4 Station Blackout. #87 the turbine speed control, I
5 believe we have some additional understanding and we
6 will look forward to getting back to you on that one.

7 And then #62, #63 and #101 are all closed.

8 CHAIR ABDEL-KHALIK: Yes.

9 MR. HEAD: Okay.

10 CHAIR ABDEL-KHALIK: So could you, please,
11 open the bridge line?

12 MS. BANERJEE: I'll go check.

13 MEMBER ARMIJO: Is Dennis still on?

14 CHAIR ABDEL-KHALIK: He has a separate
15 line, so if he is on, he should be on.

16 Before we get to that point, are there any
17 members of the public who wish to make a statement?

18 Is the bridge line open?

19 MEMBER STETKAR: You have to be more
20 specific. If there is anyone out here who can hear us
21 speaking, please, say something. Just anything.

22 PARTICIPANT: Here I am.

23 MEMBER STETKAR: Thank you.

24 CHAIR ABDEL-KHALIK: Okay. Are there any
25 members of the public who wish to make a statement?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Okay. All right. At this time, I guess
2 the agenda calls for us to just summarize any
3 discussions. Are there any additional comments that
4 people would like to make? And I'll start with
5 Charlie.

6 MEMBER BROWN: Nope. I've had my say.

7 CHAIR ABDEL-KHALIK: Bill?

8 MEMBER STETKAR: Nothing.

9 CHAIR ABDEL-KHALIK: John?

10 MEMBER STETKAR: Nothing. Thank you.

11 CHAIR ABDEL-KHALIK: Sam?

12 MEMBER ARMIJO: No.

13 CHAIR ABDEL-KHALIK: Graham?

14 CONSULTANT WALLIS: I think we covered it.

15 CHAIR ABDEL-KHALIK: Okay. Well, thank
16 you very much.

17 MEMBER STETKAR: Thank you.

18 CHAIR ABDEL-KHALIK: Appreciate it.

19 MR. HEAD: We enjoyed it.

20 CHAIR ABDEL-KHALIK: It was very
21 informative. We appreciate your response to our
22 request for the presentation on Station Blackout. It
23 was added sort of late in the game, but we appreciate
24 it.

25 MR. HEAD: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR ABDEL-KHALIK: Thank you very much
2 for an informative meeting.

3 Are there any comments from the staff
4 before we close the meeting? Okay. Thank you. We
5 are adjourned.

6 (Whereupon, the Open Session meeting was
7 concluded at 1:35 p.m.)
8


NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

South Texas Project Units 3 & 4 Presentation to ACRS Subcommittee Chapter 6 Long Term Cooling Follow-up



Attendees

Scott Head	NINA Manager, Regulatory Affairs, STP 3&4
Steven Thomas	NINA Manager, Engineering, STP 3&4
James Tomkins	NINA Licensing, STP 3&4
Tom Daley	NINA Engineering, STP 3&4
Caroline Schlaseman	MPR/TANE
Dale Wuokko	TANE
Martin Van Haltern	Westinghouse
Tim Andreychek	Westinghouse

Desired Outcomes

- Review the action items from the June 21, 2011 meeting
- Review action item # 47(a)
- Discuss our response to each item

Follow-up Action Items

- Action Item # 98 – Strainer Screen Loading
- Action Item # 99 - Zinc Oxide Concentration
- Action Item # 80 – Pressure Drop vs. Flow Relationship Exponent
- Action Item # 47(a) – Briefing on Downstream Fuel Test and Analysis

Action Items

- Action Item # 98
 - Follow-up to Action Item # 72
- *Address modeling of perforated strainer screen loading. Provide evidence of no local damage to strainer pockets due to loads imposed during vent clearing, condensation bubble collapse, and condensation oscillation.*

Action Item # 98 – CCI Strainer Structural Analysis Method Recap

- June 21 ACRS meeting reviewed the following steps in structural analysis of CCI cassette-type strainer:
 - Hydrodynamic loads defined by Toshiba in accordance with DCD-prescribed methodology; included in ASME Design Specification
 - Loads combined in accordance with DCD Tier 2 Table 3.9-2, and applied to Finite Element model of strainer to determine stresses in perforated sheets, flange plate, internal ribs
 - Resulting membrane, local membrane, membrane + bending stresses compared to applicable ASME B&PV Code Section III Service Level A, B, C & D allowables for limiting load combinations
 - ITAAC will confirm acceptable ASME Code Design Report exists for all ASME components, including these ECCS strainers

Action Item # 98 – Overview

- The second sentence in Action Item # 98, “provide evidence of no local damage to strainer pockets due to loads imposed during vent clearing, condensation bubble collapse, and condensation oscillation,” is satisfied by meeting ASME B&PV Section III, Subsection NC, design requirements for local membrane stresses for the required load combinations
- The first sentence of Action Item # 98, “address modeling of perforated strainer screen loading,” is addressed in the following slides

Action Item # 98 - Perforated Metal Sheet Analysis Method

- Stress analysis methodology for perforated metal sheets accounts for holes by applying the non-mandatory ASME B&PV Code, Section III, Appendix A-8000 methodology
- This methodology includes two parts:
 1. Elastic modulus E and Poisson's ratio ν are replaced by the effective elastic modulus E^* ($E^*/E=0.334$) and effective Poisson's ratio ν^* (0.343) of the perforated sheet to determine appropriate stress distribution in solid (no holes) model
 2. Resulting stresses are increased by ratio of pitch/ligament width ($P/h = 2.78$) to account for missing material


Action Item # 98 - Validation of Method Applicability

- ASME A-8110(a) lists 5 criteria for using this analysis method; Criterion (5) on plate thickness to hole pitch ratio is not met by metal sheet
- CCI confirmed the applicability of the ASME A-8000 methodology by:
 - Confirming essentially same method for determining effective elastic constants in *Designers, Specifiers and Buyers Handbook for Perforated Metals* (article based on testing by W. J. O'Donnell)
 - Performing pressure tests at multiples of limiting load combination pressure for RJ-ABWR


Action Item # 98 - Validation of Method Applicability *(continued)*

- RJ-ABWR limiting load combination pressure ~0.5 bar (7.25 psi)
- Tested 6 cycles (*see figure, next slide*) starting with 1 bar up to 2.25 bar
 - At 1 bar: deformation within elastic regime
 - At 2.25 bar: no damage; permanent deformation ~1.0 mm

Action Item # 98 - Validation of Method Applicability *(continued)*



Action Item # 98 - Validation of Method Applicability *(continued)*



Action Item # 98 - Validation of Method Applicability *(continued)*



Action Items *(continued)*

- Action Item # 99
- *Provide documentation of $\ll 1.6$ ppm ZnO in suppression pool water*

Action Item # 99 – Zinc Oxide Concentration in Suppression Pool

■ Clarification:

- As discussed at the last meeting, calculations of the ZnO concentration had not been performed
- The calculations have been performed and the ZnO is NOT \ll the solubility limit of 1.6 ppm
- The calculations are summarized and presented in this presentation
- Both the calculation of ZnO concentration and the treatment of the ZnO products provide for a conservative loading of ZnO

Action Item # 99 – Zinc Oxide Concentration in Suppression Pool

- Assumptions in calculation of zinc oxide (ZnO) corrosion :
 - Maximum zinc corrosion products provided for:
 - Assumes 100% of IOZ coatings destroyed within ZOI
 - Maximum surface area assumed throughout corrosion calculation
 - Minimum suppression pool inventory
 - 30-day time period
- Two pH values evaluated¹
 - Minimum pH = 5.3 26.6 kg (58.6 lb_m)
 - Maximum pH = 8.9 6.2 kg (13.7 lb_m)
- Resulting range of ZnO concentration
 - Minimum pH = 5.3 7.6 ppm
 - Maximum pH = 8.9 1.8 ppm

(1) Transmitted to NRC in response to RAI 06.02.02-29, pH values are the licensing basis as described in the DCD

Action Item # 99 – Zinc

Concentration in Suppression Pool

(continued)

- Solubility of ZnO is 1.6 ppm
- Calculated ZnO concentration exceeds solubility limits for pH range evaluated
- Some ZnO would be expected to form precipitate
- The amount of precipitate that would form is small
 - Minimum pH=5.3 21.0 kg (46.3 lb_m) of precipitate
 - Maximum pH=8.9 0.68 kg (1.51 lb_m) of precipitate

Action Item # 99 – Zinc Concentration in Suppression Pool

(continued)

- ZnO concentration conservatively calculated > 1.6 ppm
 - Maximum Zn from assumed failure of drywell coatings
 - Maximum surface area
 - No passivation of Zn surfaces
 - Minimum water
- Testing conservatively addresses ZnO
 - Maximum ZnO generation (26.6 kg/58.6 lb_m)
 - No credit for ZnO solubility
- Therefore ZnO is conservatively addressed

Action Items *(continued)*

- Action Item # 80
- *Provide the basis for test acceptance criteria utilizing square relationship, vs. use of some other exponent such as 1.2 for debris bed.*

Action Item # 80 – Pressure Drop vs. Flow Exponent

- Acceptance Criteria based on Darcy equation

$$\Delta P = K * \rho * \frac{V^2}{2 * g_c}$$

- Test data showed lower exponent dependency for partially formed debris bed at low flows
- Higher Debris loads resulted in exponent closer to 2 even at low flows.
- Acceptance Criteria corresponds to high debris load

Action Item # 80 – Pressure Drop vs. Flow Exponent *(continued)*

- Test Acceptance Criteria minimizes the allowed increase in DP during the test

$$\left[\frac{\Delta P_f}{\Delta P_i} \right]_{(\text{Test-Measured})} \leq 1200 * \left(\frac{W_f}{W_i} \right)_{(\text{Test-Measured})}^2$$

W_f/W_i ($W_f = 0.5, W_i = 3.0$)	$\Delta P_f/\Delta P_i$ (exp = 2)	$\Delta P_f/\Delta P_i$ (exp = 1.5)
0.167	33.3	81.7

Action Items *(continued)*

- Action Item # 47(a)
- *Provide a future briefing on test and analysis (Licensing Condition) for the downstream test. Provide downstream test procedure to ACRS.*

Action Item # 47(a)- Downstream Fuel Test

- A downstream test will be performed as a condition of the license at least 18 months prior to fuel load
 - This test will use the fuel planned for the initial cycle
- The test analytical basis, the test plan, and the debris amounts and addition protocol are described in detail in FSAR Appendix 6C
- The test plan and protocol will reflect industry downstream testing experience between now and the time the test is performed
- Test procedure will be provided to the NRC 6 months prior to performance of the test

Summary

- Strainer perforated sheets are strong enough to withstand suppression pool loads during a LOCA
- Pressure Drop vs. Flow exponent of 2 is appropriate and conservative
- Some zinc oxide will stay in solution, but no credit is taken for this in the amount of zinc precipitate assumed in the downstream test
- A conservative downstream test will be performed 18 months prior to fuel load
 - This test will reflect industry experience with such tests
 - The downstream test procedure will be available 6 months prior to the test

Appendix to Presentation

- This appendix provides a written response to Action Item # 80, the use of an exponent of 2 in the pressure drop vs. flow relationship.

Exponent Issue

The ACRS Subcommittee has requested additional description of the proposed downstream effects fuel test acceptance criteria in light of Dr. Wallis's question concerning the observation that during another fuel test results showed that the exponent of the flow relationship to pressure drop could be close to 1. The ABWR acceptance criterion uses an exponent of 2 in the flow to pressure drop relationship.

The ABWR acceptance criterion is developed from the analyses of the response of the ABWR to increased fuel hydraulic resistance. The resulting criterion is based upon a highly blocked inlet that still yielded adequate core cooling. This criterion provides the acceptable increase in the hydraulic resistance of the end state of the test compared to the initial resistance of the assembly. Providing the acceptance criterion in this form accounts for the effects of temperature and flow rate on the acceptable pressure drop.

Exponent Issue *(continued)*

The downstream test results from a fuel test for another reactor type that yielded pressure drop to flow rate relationships with different exponents came from a test of increasing amounts of debris. During the test as debris was added, flow sweeps were performed to characterize the pressure drop to flow relationship. The initial debris additions demonstrated lower hydraulic resistance and a flow relationship with a low exponent, closer to a value of 1. As debris was added and the test continued, the hydraulic resistance increased and the exponent of the ΔP to flow relationship increased. For the last debris addition with the bed fully formed, the exponent of the flow relationship was slightly less than 2.

Although the performance of the partially formed debris bed is interesting, we are at this point specifying the acceptance criteria and not trying to predict the behavior of varying debris amounts.

Exponent Issue *(continued)*

The pressure drop measured during the test is made up of several constituent components. It includes losses from the entrance to the test assembly, through the lower tie plate, the debris filter, the grids, and the friction on the test rods and assembly and sub assembly walls. Previous tests have shown that the debris accumulates primarily at the tie plate, debris filter and / or fuel grids causing blockages and a reduction in the flow areas at these components. The hydraulic losses for the grids, filter, and tie plate tend to follow a Darcy type relationship with a resistance coefficient K that is relatively independent of Reynolds number.

$$\Delta P = K * \rho * \frac{V^2}{2 * g_c}$$

Exponent Issue *(continued)*

At low flows, the frictional component of the pressure drop can transition to a more laminar relationship where the pressure drop is almost linear with flow (exponent slightly above 1.0). However, as the blockage at the other components increases and dominates the measured pressure drop, the overall relationship will tend towards a flow squared relationship.

$$\left[\frac{\Delta p_f}{\Delta p_i} \right]_{\text{Test-Measured}} \leq 1200 * \left(\frac{w_f}{w_i} \right)_{\text{Test-Measured}}^2$$


Exponent Issue *(continued)*

By specifying an exponent of 2 for the flow relationship we are bounding the flow changes for partially formed debris beds. The final flow rate will be less than the initial flow so the ratio of final to initial flow rates will be less than one. Specifying a larger, bounding exponent for this relationship will result in a smaller acceptable ratio of final to initial pressure drops than if a lower exponent was used. The following table illustrates the impact of the flow exponent. For a test that has an initial flow rate of 3 kg/s and after all of the debris is added has a final flow rate of 0.5 kg/s the allowed increase in test section pressure drop is shown

W_f/W_i ($W_f = 0.5, W_i = 3.0$)	$\Delta P_f/\Delta P_i$ (exp = 2)	$\Delta P_f/\Delta P_i$ (exp = 1.5)
0.167	33.3	81.7

South Texas Project Units 3 & 4 ACRS ABWR Subcommittee Presentation

Extended Station Blackout





Attendees

Scott Head	NINA Manager, Regulatory Affairs, STP 3&4
Steve Thomas	NINA Engineering Manager, STP 3&4
Tom Daley	NINA Engineering, STP 3&4
Coley Chappell	NINA Licensing, STP 3&4

ABWR Station Blackout (SBO) Response Capability Combustion Turbine Generator (CTG)

The primary means by which the ABWR copes with a station blackout is use of the CTG, which has the following features and capabilities:

- The alternate AC power source during an SBO event.
- Protected from flooding and weather events.
- Independent from the three safety-related diesel generators.
- “Black start” capability.
- Will reach operational speed and voltage and will be available for bus connection within 10 minutes.
- Can supply 4.16kV Class 1E buses through the realignment of pre-selected breakers during SBO events.

ABWR Response Capability

ABWR has the capability to withstand a loss of all AC power:

- Offsite
- Emergency Class 1E diesel generators (DGs)
- Alternate AC power (CTG)

In this beyond design basis scenario, the ABWR has several defense-in-depth design features which provide the capability to

- (1) Prevent core damage; and
- (2) Maintain containment integrity.

ABWR SBO Response Capability without CTG

- The ABWR can withstand an extremely unlikely event of a loss of offsite power, the loss of all three safety-related trains of diesels, and the loss of the CTG (both units).
 - For a period of approximately 8 hours using RCIC.
 - No core damage or loss of containment integrity.
- If AC power is still unavailable beyond this period, core cooling by the RCIC system is assumed to be lost.
 - However, the ACIWA system is capable of preventing core damage.
 - Containment Overpressure Protection System (COPS) prevents loss of containment integrity.
 - This accident sequence is discussed in DCD Subsection 19E.2.2.3.

ABWR SBO Response Capability without CTG

Sequence of Events:

- 0.0 MSIV Closure
- 4.2 s Reactor Scrammed
- 52.0 s Level 2, the RCIC system initiates injection, steam discharged to suppression pool through SRVs
- 8.0 h RCIC assumed to fail
- 9.8 h Operator lines up ACIWA and depressurizes the vessel
- 9.9 h RPV water level falls below Top of Active Fuel (TAF)

Pressure reaches the shutoff head of ACIWA, water injection begins, core cools rapidly, core temperature peaks before fuel damage occurs

- 32.3 h COPS rupture disk opens, containment pressure drops

Station Blackout, RCIC Runs Eight Hours, Firewater Addition Prevents Core Damage, Rupture Disk Opens




Figure 19E.2-6a: UO₂ Temperature

Station Blackout, RCIC Runs Eight Hours, Firewater Addition Prevents Core Damage, Rupture Disk Opens




Figure 19E.2-6a: Drywell Pressure

ABWR Response Capability without CTG

For extended loss of all AC:

- The current ABWR design is capable of withstanding a beyond design basis, extended loss of all AC event for at least 72 hours.
 - Without core damage and
 - Without loss of containment integrity.
- Loss of offsite power circuits, loss of three trains of safety-related diesel generators, loss of CTG's of both units

Fuel Pool Makeup

- ABWR design includes several systems capable of providing makeup to the spent fuel storage pool
 - Fuel Pool Cooling and Cleanup (FPC) System – normal means of removing decay heat in the spent fuel storage pool.
 - Suppression Pool Cleanup (SPCU) System – source of makeup water using either the SP or the CST.
 - Powered by buses with a CTG power supply.
- The safety-related (Class 1E) makeup water source for the spent fuel storage pool is provided by the Residual Heat Removal (RHR) System from the suppression pool.
 - STP 3&4 design provides capability from all three RHR trains.
 - Manual valves for aligning RHR System are accessible.

Fuel Pool Makeup

- For an extended loss of all AC event, additional capability is provided:
 - Fire hoses can be used as an alternate makeup source, and fire protection standpipes in the Reactor Building are seismically designed.
 - Fire Protection (FP) system provides makeup from a separate water source using diesel-driven pumps (installed and portable), and a motor-driven pump capable of being powered from the CTG.
 - Hose connections to FP system standpipes at ground elevation external to the Reactor Building, used to provide makeup (Part 11, Figure 9.2).
- Other ABWR spent fuel storage pool design features:
 - Analysis indicates that, under maximum abnormal heat load with pool gates closed and no cooling, temperature will reach $\sim 100^{\circ}\text{C}$ in ~ 16 hrs.
 - Adequate time for reasonable operator action to establish makeup.
 - There are no piping connections located below a point approximately 10 feet above the top of active fuel located in the spent fuel storage racks.


Conclusion

Questions and Comments



South Texas Project Units 3 & 4 ACRS ABWR Subcommittee Presentation

ACRS Action Items 62, 63, 87 and 101



Agenda

- Introduction/Attendees
- Action Items:
 - #87 Address failure of speed sensors for the main turbine primary overspeed protection subsystem (follow up from 6/21/2011)
 - #62 Basis and application of 30-minute operator response time for failure of RSW piping on UHS 30-day supply
 - #63 Basis for RSW pump NPSH
 - #101 Suppression Pool heat-up during Station Blackout, time to reach RCIC operation 77°C limit
- Conclusion

Attendees

Scott Head	NINA Manager, Regulatory Affairs, STP 3&4
Steve Thomas	NINA Manager, Engineering, STP 3&4
Tom Daley	NINA Engineering, STP 3&4
Coley Chappell	NINA Licensing, STP 3&4
Dale Wuokko	TANE Licensing

Action Item # 87

Address a failure of the speed sensors in the primary overspeed protection subsystem for the main turbine.

Response: The following is a summary of the 6/21/2011 presentation:

- Indications and alarms will be provided in the main control room.
- Failure of these speed sensors does not affect the redundant emergency overspeed protection function or normal speed control.
 - Speed sensors are separate and diverse.
- Timely operator action, as directed by procedure, ensures a very low potential for a turbine overspeed event to occur while the primary overspeed protection is degraded.
- Since this failure does not require an automatic trip, no FSAR revision is required.

Action Item # 87 (cont'd)

- Response to ACRS comments on previous presentation:

SITUATION	RESPONSE
Loss of signal (function) from two of the three passive speed sensors of primary overspeed protection function.	<ul style="list-style-type: none"> Speed sensor failure alarms in main control room. No automatic turbine trip. Guidance recognizes possibility of malfunctions that increase the risk of continuing operation, and provides LCO-type recommendations (see SRP 3.5.1.3, DCD Table 3.5-1).
<p style="text-align: center;"><u>and</u></p> Common mode failure of the active speed sensors of redundant emergency overspeed protection function.	<ul style="list-style-type: none"> Automatic turbine trip due to speed sensor failure. With the main turbine on-line, the normal speed signal is not controlling, since control valve position is determined by steam dome pressure (low-voltage gate). With main generator paralleled with the grid, turbine speed is determined by grid frequency, generator load is limiting. Power load unbalance function senses mechanical power and generator current in case of a load reject.

Action Item # 62

Discuss basis and application of the 30 minute response time upon a single passive failure of the Reactor Service Water (RSW) piping and how the analysis justifies a 30-day supply for the Ultimate Heat Sink (UHS) while accounting for the pipe failure.

Response: The question is about how the UHS water storage basin design volume, as described in Subsection 9.2.5.5.2(8), accounts for a pipe crack that might occur during the 30-day duty time:

A single passive failure of RSW piping is considered.

The water loss is based on a 30 minute response time.

- DCD Tier 2 Subsection 19R.4.1 allows a 30-minute response by control room operators to locally isolate a leak.
- If a leak occurred in RSW piping in the pump room, sump/flooding alarm would alert operators.
- RSW leakage during this time is included in the UHS basin inventory.

Action Item # 62 (cont'd)

- The possibility of a non-isolable leak between the intake line and the first isolation valve in the RSW pump room is not considered credible based on the design requirements:
 - RSW system is classified as Seismic Category I, and designed accordingly.
 - Non-isolable piping in RSW pump rooms is designed using crack exclusion criteria per DCD Tier 2 Subsection 3.6.2.1.5.3.2.

Action Item # 63

Discuss basis for approximately 17 meters (16m – COLA Rev. 4) RSW pump NPSH and how it was calculated, specifically at the end of the 30-day supply.

Response: (Refer to FSAR Table 9.2-17 and Figure 1.2-35)

Available NPSH for RSW pumps:

$$\text{NPSH}_a = H_{st} + H_{sys} - H_{vap} - H_f$$

Where: H_{st} = static head = 31.17 ft. (min. water level 17 ft.)

H_{sys} = system (atmospheric) head = 34.1 ft.

H_{vap} = vapor pressure = 1.89 ft. (at 95°F)

H_f = frictional losses = 5.48 ft.

$$\text{NPSH}_a = (31.17 + 34.1 - 1.89 - 5.48) \text{ ft} = 57.9 \text{ ft. (17.6m)}$$

$$57.9 \text{ ft.} \times 0.90 \text{ (10\% margin)} = 52.1 \text{ ft. (15.9 m)}$$

Action Item # 101

Time for Suppression Pool temperature to reach 77°C under Station Blackout conditions.

Response:

- Station Blackout (SBO)
 - RCIC suction remains on condensate storage tank (CST) per ABWR DCD Emergency Procedure Guidelines (EPGs):
 - 8-hour supply from primary water source CST.
 - Backup source is the suppression pool (SP).
 - Suppression pool temperature reaches 77°C in approximately 6 hours.
 - RCIC will continue to operate automatically for approximately 8 hours (battery life), with the suppression pool heating up and the containment pressurizing.

Action Item # 101 (cont'd)

- Long term containment conditions:
 - RCIC will operate manually since required NPSH is maintained by containment pressure and SP level.
 - RCIC will maintain reactor water level until:
 - RCIC room environment faults equipment ($> 151^{\circ}\text{F}$, > 8 hours).
 - EPGs require RPV depressurization ($\text{SP} > \sim 275^{\circ}\text{F}$, ~ 16 hours).
 - COPS rupture disc actuates (NPSH may be lost, ~ 32 hours).
 - RCIC turbine-pump bearings are rated to 250°F (~ 12 hours).
 - SRVs will maintain RPV pressure until batteries are depleted (“many days” per DCD Tier 2 Subsection 19E.2.1.2.2.2).
 - Depressurize RPV and initiate ACIWA preventing core damage.

ACRS Action Items - Conclusion

Questions and Comments



Action Item # 101 (Backup Info)

- Design basis - Main steamline break:
 - Suppression pool temperature reaches 77°C in ~ 15 minutes.
 - RCIC mission time is complete due to RPV depressurization in approximately 4 minutes (suction from CST).
 - Basis for 77°C: BWR – effectiveness of steam condensation (limit for the end of the LOCA blowdown based on the Bodega Bay and Humboldt Bay tests). ABWR – Question 440.52, degrade RCIC lube oil viscosity.