

DRAFTFacility: **Oconee**Scenario No.: **1R0**Op-Test No.: **1**

Examiners: _____

Operators: _____ **SRO**_____ **OATC**_____ **BOP**

Initial Conditions:

- Reactor Power = 100% Unit 2: 100% Unit 3: 100%

Turnover:

- SASS in Manual for I&E testing
- AMSAC/DSS bypassed for I&E testing
- 1B FDWPT on Handjack for MGU repair, work is completed; NEO on station at 1B FDWPT
- GWD Tank B release in progress
- ACB-3 closed

Event No.	Malfunction No.	Event Type*	Event Description
0a	Pre-Insert		SASS in Manual
0b	Pre-Insert		AMSAC/DSS bypassed for I&E testing
0c	Pre-Insert		1B CC pump fails to auto start
0d	Pre-Insert		Block ALL Turbine trip except MANUAL
1		N: BOP, SRO	Restore 1B MFWP from Hand Jack
2	MPS 290 Override	C: BOP, SRO	1A CC pump trips and 1B CC pump fails to auto start
3	MPS110	C: BOP, SRO (TS)	Restore Letdown (1HP-5 fails CLOSED) (TS)
4	MCS005	I: OATC, SRO	Thot Fails LOW
5	MCR021	R: OATC, SRO (TS)	Dropped Control rod (TS), Manual power reduction
6	MEL170	SRO (TS)	CT-1 Transformer Lockout (TS)
7	MPI290	C: OATC, SRO	Main Turbine Fails to trip (Lockout EHC Pumps) (occurs with event 8)
8	MEL090 MCR024 MEL020	M: ALL	Switchyard Isolate (RX trip) Stuck Control rod KHU-2 lock out
9	MEL180	M: ALL	Blackout due to Loss of second Keowee Unit (KHU-1) Recover power from CT-5

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

DRAFT

Op-Test No.: 1 Scenario-No.: 1 Event No.: 1 Page 1 of 2Event Description: **Restore 1B FDWPT from Hand Jack (N: BOP, SRO)**

Time	Position	Applicant's Actions or Behavior
		<p>Crew Response:</p> <p>SRO Direct BOP to perform OP/1/A/1106/002 B (FDWPT Operation), Encl. 4.13, Taking the 1B FDWPT Off Handjack beginning at Step 2.1</p> <p>BOP Use the above procedure Encl. 4.13, and remove the 1B FDWPT from Handjack and restore speed control to the 1B MGU (motor gear unit)</p> <p>2. Procedure</p> <p>2.1 IF in Mode 1 OR Mode 2, WHILE enclosure is in progress monitor the following indications: {20}</p> <ul style="list-style-type: none"> • Appropriate ranged Nis • Neutron error • RCS Loop ΔT (curve for "Loop ΔT Vs Reactor Power" is in PT/1/A/0600/001) • FDW Flow (curve for "Expected Feedwater Flow Per Header Vs Reactor Power" is in OP/0/A/1108/001) <p>2.2 Remove "T/O SHEET" CR tag from 1B MAIN FDW PUMP (ICS) station.</p> <p>2.3 Run 1B MAIN FDW PUMP (ICS) station to "HSS" (high speed stop).</p> <p>2.4 Perform the following:</p> <p>2.4.1 Establish communication with Operator at 1B FDWPT.</p> <p>Booth Cue: NEO will report "Standing by the 1B FDWPT Motor Gear Unit".</p> <p>2.4.2 Run 1B MAIN FDW PUMP (ICS) to low speed stop.</p> <p>2.4.3 Run 1B MAIN FDW PUMP (ICS) to high speed stop. ($\approx 1/8$" from hard stop)</p> <p>2.4.4 Verify Motor Gear Unit operated smoothly through entire operation.</p> <p>Booth Cue: NEO will report "Motor Gear Unit operated smoothly".</p> <p>2.5 Turn FWT 1B HANDJACK switch to "OFF".</p> <p>2.6 IF Unit 1 is in Mode 1 or 2 AND both FDWPT ICS stations are in "HAND": (does not apply)</p> <p>2.7 Decrease 1B MAIN FDW PUMP (ICS) until 1B FDWPT controlled by 1B MAIN FDW PUMP (ICS) station.</p> <p>2.8 Increase 1B FDWPT Motor Speed Changer.</p> <p>2.9 Verify 1B FDWPT speed does NOT increase.</p>

Op-Test No.: 1 Scenario No.: 1 Event No.: 1

Page 2 of 2

Event Description: **Restore 1B FDWPT from Hand Jack (N: BOP, SRO)**

Time	Position	Applicant's Actions or Behavior
		<p>Crew Response:</p> <p>2.10 Position 1B FWPT MOTOR SPEED CHANGER to 'FR' under "RAISE" until 1B FDWPT MOTOR SPEED CHANGER is at "HSS".</p> <p>2.11 After 1B FDWPT MOTOR SPEED CHANGER reaches "HSS", hold 1B FDWPT MOTOR SPEED CHANGER switch in 'FR' for 3 to 5 seconds to make all contacts.</p> <p>Note: Steps 2.12 – 2.14 do not apply.</p> <p>2.12 IF Unit 1 is in Mode 3:</p> <p>2.13 IF Unit 1 is in Mode 1 or 2 with 1A FDWPT shutdown:</p> <p>2.14 IF Unit 1 is in Mode 1 or 2 with 1A FDWPT operating but NOT in auto:</p> <p>2.15 IF Unit 1 is in Mode 1 or 2 with 1A FDWPT in auto:</p> <p>2.15.1 Verify 1A MAIN FDW PUMP (ICS) in "AUTO".</p> <p>2.15.2 Place 1B MAIN FDW PUMP (ICS) in "AUTO".</p> <p>2.15.3 Verify ICS adjusts 1B FDWPT speed to balance suction flow.</p> <p>2.16 IF required, remove Turnover Sheet note for control of 1B FDWPT with Motor Speed Changer.</p>

This event is complete when the 1B MFDWPT is placed in AUTO, or as directed by the Lead Examiner.

Op-Test No.: 1 Scenario No.: 1 Event No.: 2

Page 1 of 1

Event Description: **1A CC pump trips and 1B CC pump fails to auto start (C: BOP, SRO)**

Time	Position	Applicant's Actions or Behavior
	BOP	<p>Plant response:</p> <ul style="list-style-type: none"> • 1SA-9/B-1, CC CRD RETURN FLOW LOW • 1SA-9/C-1, CC COMP COOLING RETURN FLOW LOW • 1SA-2/C-1, LETDOWN TEMPERATURE HIGH • 1HP-5 (Letdown Isolation) will close due to high letdown temperature • CC Total Flow Low • Component Cooling Pressure Low • Pzr level will begin to increase once 1HP-5 closes <p>Crew Response:</p> <p>Refer to ARG 1SA-9/B-1 <u>OR</u> 1SA-9/C-1</p> <ul style="list-style-type: none"> • Determine low flow is due to CC Pump failure AND Standby CC Pump did NOT start and perform the following: • Verify CC Surge Tank level > 12" • Start Standby CC Pump <p>Note: The SRO will not be required to initiate AP/20 if the Standby Pump is started per the ARG.</p>
	SRO	<p>Initiate AP/20 (Loss of Component Cooling)</p> <p>3.1 IAAT <u>both</u> of the following are lost:</p> <ul style="list-style-type: none"> • CC to RCPs and RCP seal injection <p>THEN Trip the Rx, stop all RCPs and initiate AP/25</p> <p>3.2 IAAT ≥ two CRD stator temperatures ≥ 180°F, THEN trip Rx</p> <p>4.1 Verify <u>at least one</u> CC pump operating</p> <p>RNO: GO TO Step 4.3</p> <p>4.3 Open 1CC-7 and 1CC-8</p> <p>4.4 Verify ≥ one CC pump operating</p> <p>RNO: 1. IF CC Surge Tank level ≥ 12" THEN attempt to start a CC Pump</p> <p>2. IF unable to start any CC pump...(does not apply)</p> <p>4.5 Verify CC TOTAL FLOW > 575 gpm</p> <p>4.6 Verify Letdown in service and LETDOWN TEMP ≤ 130°F</p> <p>RNO: 1. IF LETDOWN TEMP > 130°F, THEN close 1HP-5</p> <p>2. Initiate AP/32 or EOP Encl 5.5 to restore letdown</p> <p>Note: If the SRO initiates EOP Encl 5.5 to restore Letdown, these actions are listed beginning on page 26.</p>

This event is complete when the standby CC pump is started, or as directed by the Lead Examiner.

Op-Test No.: 1 Scenario No.: 1 Event No.: 3 Page 1 of 3Event Description: **Restore Letdown (1HP-5 fails CLOSED) (C: BOP, SRO) (TS)**

Time	Position	Applicant's Actions or Behavior
	SRO BOP	<p>Crew Response:</p> <p>SRO should enter AP/1/A/1700/032 (Loss of Letdown)</p> <p>4.1 Place 1HP-120 in HAND and reduce demand to zero.</p> <p>4.2 Initiate makeup to LDST as required (Encl.5.5 or OP/1/A/1103/004).</p> <p>4.3 Initiate notification of the following:</p> <p>___ OSM to reference the following:</p> <ul style="list-style-type: none"> • OMP 1-14 (Notifications) • Emergency Plan <p>___ STA</p> <p>4.4 Notify Chemistry of the following:</p> <ul style="list-style-type: none"> • Current RCS boron sample is needed for possible unit shutdown. • Normal letdown line is isolated. <p>4.5 IAAT either of the following exists:</p> <p>___ Pzr level $\geq 260''$, AND letdown CANNOT be established</p> <p>___ Plant conditions exist such that letdown will NOT be restored</p> <p>THEN initiate unit shutdown at $\approx 20\%/min$ per AP/29 (Rapid Unit Shutdown).</p> <p>4.6 IAAT Pzr level $\geq 375''$, THEN trip Rx.</p> <p>4.7 Position the standby HPI pump switch to OFF.</p> <p>4.8 Throttle 1HP-31 to establish 12 - 15 gpm SEAL INLET HDR FLOW.</p> <p>Note: Statalarm 1SA-2/B-2 (RCP SEAL INLET HEADER FLOW HIGH/LOW) will actuate once seal inlet header flow is decreased to < 22 gpm)</p> <p>4.9 Verify HPI pump flow ≥ 65 gpm. (<u>30</u> gpm Recirc + ___ SI + ___ MU)</p> <p>RNO: Log beginning time for HPI pump flow below minimum</p> <p>4.10 Determine the cause of loss of letdown and GO TO Step 4.29 for actual letdown temperature high.</p> <p>4.29 Notify SPOC to initiate repairs on failed equipment.</p> <p>4.30 IAAT letdown can be re-established, THEN perform Steps 4.31 – 4.46.</p> <p>4.31 Place CC system in operation</p> <p>4.32 Close 1HP-6.</p> <p>4.33 Close 1HP-7.</p> <p>4.34 Open the following:</p> <ul style="list-style-type: none"> • 1HP-1 • 1HP-2 • 1HP-3 • 1HP-4

Op-Test No.: 1 Scenario No.: 1 Event No.: 3

Page 2 of 3

Event Description: **Restore Letdown (1HP-5 fails CLOSED) (C: BOP, SRO) (TS)**

Time	Position	Applicant's Actions or Behavior
	SRO/ BOP	<p>Crew Response:</p> <p>AP/1/A/1700/032 (Loss of Letdown)</p> <p>4.35 Verify letdown temperature < 135°F (it is not)</p> <p>RNO: 1. Open 1HP-13.</p> <p>2. Close the following:</p> <ul style="list-style-type: none"> • 1HP-8 • 1HP-9&11 <p>3. IF any deborating IX in service...(no deborating IX is in service)</p> <p>4. Select LETDOWN HI TEMP INTLK BYP switch to BYPASS</p> <p>Note: Statalarm 1SA-2/E-4 (HP LETDOWN FLOW INTERLOCK BYPASSED) will actuate once the LETDOWN HI TEMP INTLK BYP switch is placed in BYPASS.</p> <p>4.36 Open 1HP-5.(will not OPEN)</p> <p>RNO: GO TO Step 4.11</p> <p>4.11 Close 1HP-6</p> <p>4.12 Close 1HP-7</p> <p>4.13 Open 1HP-5 (will NOT open)</p> <p>RNO: 1. Dispatch an operator in continuous communication with Control Room to manually open 1HP-5 (LETDOWN ISOLATION)\</p> <p>Booth cue: When called, use TIME COMPRESSION and FIRE TIMER 14 to manually open 1HP-5.</p> <p>2. IF 1HP-5 is manually open, THEN enter TS 3.6.3.</p> <p>3. IF 1HP-5 CANNOT be manually opened, THEN GO TO Step 4.29.</p> <p>4.14 WHEN 1HP-5 is open, THEN continue.</p> <p>4.15 Place the CC system in service.</p> <p>4.16 Verify letdown temperature is < 135°F (it is not)</p> <p>RNO: 1. Open 1HP-13.</p> <p>2. Close the following:</p> <ul style="list-style-type: none"> • 1HP-8 • 1HP-9&11 <p>3. IF any deborating IX in service...(no deborating IX is in service)</p> <p>4. Select LETDOWN HI TEMP INTLK BYP switch to BYPASS.</p>

Op-Test No.: 1 Scenario No.: 1 Event No.: 3 Page 3 of 3Event Description: **Restore Letdown (1HP-5 fails CLOSED) (C: BOP, SRO) (TS)**

Time	Position	Applicant's Actions or Behavior
	SRO/ BOP	<p>Crew Response:</p> <p>4.17 Throttle open 1HP-7 to establish \approx 20 gpm.</p> <p>4.18 WHEN letdown temperature < 130°F, THEN place LETDOWN HI TEMP INTLK BYP switch in NORMAL</p> <p>4.19 Open 1HP-6</p> <p>4.20 Adjust 1HP-7 to control desired letdown flow (\approx 75 gpm)</p> <p>4.21 Re-establish normal makeup through 1HP-120.</p> <p>4.22 Verify <u>any</u> purification IX in service</p> <p>RNO: IF purification IX operation is desired, THEN initiate OP/1/A/1103/004 B (Purification IXs) to establish desired IX operation</p> <p>4.23 Notify SPOC to initiate repairs on 1HP-5</p> <p>4.24 Verify seal injection flow reduced in Step 4.8</p> <p>4.25 Re-establish normal RCP seal injection flow (\approx 32 gpm)</p> <p>4.26 Position the standby HPI pump switch to AUTO</p> <p>4.27 WHEN repairs complete on 1HP-5, THEN perform the following:</p> <p style="padding-left: 40px;">A. Locally turn 1HP-5 handwheel fully clockwise</p> <p style="padding-left: 40px;">B. EXIT TS 3.6.3</p> <p>4.28 EXIT this procedure</p> <p>Note: 1HP-5 will not be repaired for this scenario.</p> <p>Note: If pressurizer level exceeds 260 inches, TS 3.4.9 Condition A should be entered requiring level be restored within 1 hour</p> <p>Note: The crew may request an R&R to place the 1A CC pump switch to OFF.</p>
	SRO	<p>The SRO enters TS 3.6.3 Condition A due to one or more penetration flow paths with one containment isolation valve inoperable</p> <ul style="list-style-type: none"> Required Action is to isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve, one closed and de-activated non-automatic power operated valve, closed manual valve, blind flange, or check valve with flow through the valve secured within 4 hours AND verify the affected penetration flow path is isolated once per 31 days for isolation devices outside containment.

This event is complete when the Standby HPI pump is placed in AUTO, or as directed by the Lead Examiner.

Op-Test No.: 1 Scenario No.: 1 Event No.: 4

Page 1 of 2

Event Description: **Thot Fails LOW (I: OATC, SRO)**

Time	Position	Applicant's Actions or Behavior
	OATC	<p>Plant Response:</p> <ul style="list-style-type: none"> • Loop 1A Th dixon decreases to 573°F • Tave will indicate LOW ($\approx 573^{\circ}\text{F}$) • Feedwater flow will decrease • Control Rods will withdraw • 1SA-2/B4 (RC Average Temperature High/Low) <p>Crew Response:</p> <ul style="list-style-type: none"> • When the Statalarms are received, the candidates should utilize the "Plant Transient Response" process to stabilize the plant. • Verbalize to the SRO reactor power level and direction of movement. • Place the Diamond and both FDW Masters in manual and position as necessary to stabilize the plant. • The SRO should: <ul style="list-style-type: none"> ➤ Refer to AP/28, ICS Instrument Failures ➤ Contact SPOC to repair the failed instrument.
	SRO	<p>AP/28, ICS Instrument Failures</p> <p>4.1 Provide control bands as required.</p> <p>4.2 Initiate notification of the following:</p> <p>___ OSM to reference the following:</p> <ul style="list-style-type: none"> • OMP 1-14 (Notifications) • Emergency Plan <p>___ STA</p> <p>4.3 Verify a power transient $\geq 5\%$ has occurred.</p> <p>RNO: GO TO Step 4.5.</p> <p>4.4 Notify Rx Engineering and discuss the need for a maneuvering plan</p> <p>4.5 Use the following, as necessary, to determine the applicable section from table in Step 4.6:</p> <ul style="list-style-type: none"> • OAC alarm video • OAC display points • Control Board indications • SPOC assistance, as needed <p>4.6 GO TO Section 4A, RCS Temperature</p>

Op-Test No.: 1 Scenario No.: 1 Event No.: 4

Page 2 of 2

Event Description: **Thot Fails LOW (I: OATC, SRO)**

Time	Position	Applicant's Actions or Behavior
	SRO/OATC	<p>Crew Response:</p> <p>AP/1/A/1700/028 Section 4A RCS Temperature Failure</p> <ol style="list-style-type: none"> 1. Ensure the following in HAND: <ul style="list-style-type: none"> ___ 1A FDW MASTER ___ 1B FDW MASTER 2. Ensure DIAMOND in MANUAL. 3. Notify SPOC to perform the following: <ul style="list-style-type: none"> • Select a valid RCS Tave and Delta Tc input to ICS per AM/0/B/0326/020 (Control of Star Module Signal Selection Function). • Investigate and repair the failed RCS temperature instrumentation. 4. PERFORM an instrumentation surveillance using applicable table in Encl 5.2 (ICS Instrument Surveillances) for the failed instrument. 5. Verify instrumentation surveillance in Encl 5.2 (ICS Instrument Surveillances) was performed satisfactorily as written. 6. WHEN notified by SPOC that a valid RCS Tave and Delta Tc input have been restored to ICS, THEN GO TO OP/1/A/1102/004 A Encl (Placing ICS Stations To Auto). <p>Note: The ICS will remain in manual for the remainder of the scenario.</p> <p>Note: The crew may initiate EOP Encl 5.5 for inventory control. These steps are included beginning on page 26 if necessary.</p>

This event is complete when Section 4A Step 6 is reached, or as directed by the Lead Examiner.

Op-Test No.: 1Scenario No.: 1Event No.: 5

Page 1 of 4

Event Description: **Dropped Control Rod, Manual Power Reduction (C: OATC, SRO) (TS)**

Time	Position	Applicant's Actions or Behavior						
	BOP/OATC	<p>Plant Response:</p> <p>Group 2 Rod 6 drops into the core</p> <p>Statalarm 1SA-2/A-10 (CRD GLOBAL TROUBLE)</p> <p>Statalarm 1SA-2/B-10 (CRD ASYMMETRIC ROD POSITION ERROR)</p> <p>Statalarm 1SA-2/D-9 (CRD OUT INHIBIT)</p> <p>Statalarm 1SA-4/C-1 (QUADRANT POWER TILT) (alarms in \approx 2 minutes)</p> <p>Statalarm 1SA-5/A-5 (1A RPS TROUBLE)</p> <p>Statalarm 1SA-5/B-5 (1B RPS TROUBLE)</p> <p>Statalarm 1SA-5/D-5 (1D RPS TROUBLE)</p> <p>Crew Response:</p> <p>Crew should perform Plant Transient Response (PTR)</p> <ul style="list-style-type: none"> • OATC reports to the SRO reactor power level and direction of movement. • The BOP reports no valid runback (due to ICS in MAN) and monitors RCS pressure and inventory and inserts Control Rods as needed. • The OATC will adjust FDW and/or control rods as necessary to restore reactor power to the desired control band. 						
	SRO	<p>SRO should enter AP/1/A/1700/001 (Unit Runback)</p> <p>Entry Conditions:</p> <ul style="list-style-type: none"> • Any control rod dropped or misaligned $> 6.5\%$ (9") from the group average <p>4.1 GO TO the most limiting section per the following table:</p> <table border="1"> <tr> <th>√</th><th>Section</th><th>Runback</th></tr> <tr> <td></td><td>4H</td><td>Asymmetric Control Rod (1%/min to 55% power)</td></tr> </table> <p>Note: The SRO should transfer to Section 4H (Asymmetric Control Rod) of AP/1/A/1700/001</p>	√	Section	Runback		4H	Asymmetric Control Rod (1%/min to 55% power)
√	Section	Runback						
	4H	Asymmetric Control Rod (1%/min to 55% power)						

Op-Test No.: 1 Scenario No.: 1 Event No.: 5 Page 2 of 4
 Event Description: **Dropped Control Rod, Manual Power Reduction (C: OATC, SRO) (TS)**

Time	Position	Applicant's Actions or Behavior
	SRO/OATC	<p>Crew Response: AP/1/A/1700/001 Section 4H</p> <ol style="list-style-type: none"> IAAT more than one control rod is dropped <u>or</u> misaligned $\geq 6.5\%$ (9") from the group average, THEN trip the Rx Verify Rx is critical Verify power $> 55\%$ when the rod was dropped or misaligned. Verify Rx runback to 55% <u>core thermal power</u> in progress <p>RNO: 1. Initiate power reduction to $\leq 55\%$ core thermal power at $\geq 1\%/min$ 2. IF control rods will not insert manually, THEN perform the following: A. Trip reactor B. GO TO Unit 1 EOP</p> <ol style="list-style-type: none"> Initiate Encl 5.1 (Control of Plant Equipment During S/D) (page 13) <div style="border: 1px solid black; padding: 5px; margin: 10px 0;"> <p style="text-align: center;">NOTE</p> <p>The following actions should be performed as quickly as possible due to the complexity of resetting RPS trip setpoints and Tech Spec time limits.</p> </div> <ol style="list-style-type: none"> Notify SPOC to perform the following: ___ Investigate cause of dropped or misaligned control rod. ___ Prepare to reduce the following trip setpoints: <ul style="list-style-type: none"> RPS Flux/Flow-Imbalance RPS High Flux Notify the OSM to ensure the requirements of the following Tech Specs are met: <ul style="list-style-type: none"> TS 3.1.4 (Control Rod Group Alignment Limits) TS 3.1.5 (Safety Rod Position Limits) TS 3.2.3 (Quadrant Power Tilt) (may not apply depending on time rod has been dropped) Notify OSM to make notifications as required per OMP 1-14 (Notifications) <p>Booth cue: If asked, the OSM will <u>NOT</u> refer to Tech Specs.</p> <p>The SRO should enter TS 3.1.4 Condition A for one trippable control rod inoperable, or not aligned to within 6.5% of its group average height, or both.</p> <p>The Required Action is to restore control rod alignment or verify SDM is within the limit specified in the COLR or initiate boration to restore SDM to within limit.</p> <p>Completion Time is within 1 hour</p>
	SRO	

Op-Test No.: 1Scenario No.: 1Event No.: 5

Page 3 of 4

Event Description: **Dropped Control Rod, Manual Power Reduction (C: OATC, SRO) (TS)**

Time	Position	Applicant's Actions or Behavior																		
		<p>Crew Response:</p> <p>AP/1/A/1700/001 Section 4H</p> <p>9. Verify > 1% SDM with allowance for the inoperable control rod per PT/1/A/1103/015 (Reactivity Balance Calculation) <u>within one hour</u></p> <p>10. Reduce <u>core thermal power</u> ≤ the following limits, based on the number of RCPs operating, <u>within two hours</u>:</p> <table border="1"> <thead> <tr> <th>√</th> <th>RCPs</th> <th>Allowable Thermal Power (% FP)</th> </tr> </thead> <tbody> <tr> <td></td> <td>3</td> <td>45</td> </tr> <tr> <td></td> <td>4</td> <td>60</td> </tr> </tbody> </table> <div style="border: 1px solid black; padding: 5px; margin: 10px 0;"> <p style="text-align: center;"><u>NOTE</u></p> <p>The following ensures adequate margin in preparation for resetting RPS trip setpoints.</p> </div> <p>11. IAAT the power decrease is complete, AND <u>any</u> NI is > the following:</p> <table border="1"> <thead> <tr> <th>√</th> <th>RCPs</th> <th>Maximum NI Power (% FP)</th> </tr> </thead> <tbody> <tr> <td></td> <td>3</td> <td>40</td> </tr> <tr> <td></td> <td>4</td> <td>55</td> </tr> </tbody> </table> <p>THEN reduce power until <u>all</u> NIs are ≤ the Maximum NI Power limit for the operating RCP combination per Encl 5.4 (Power Reduction)</p> <p>12. WHEN all NIs are ≤ the Maximum NI Power limit for the operating RCP combination, THEN notify SPOC to reduce RPS trip setpoints based on RPS system installed:</p> <p style="text-align: center;"><u>New RPS System</u></p> <ul style="list-style-type: none"> AM/1/A/0315/017 (TXS RPS Channel A, B, C, And D Parameter Changes For Abnormal/Normal Operating Conditions.) 	√	RCPs	Allowable Thermal Power (% FP)		3	45		4	60	√	RCPs	Maximum NI Power (% FP)		3	40		4	55
√	RCPs	Allowable Thermal Power (% FP)																		
	3	45																		
	4	60																		
√	RCPs	Maximum NI Power (% FP)																		
	3	40																		
	4	55																		

Op-Test No.: 1 Scenario No.: 1 Event No.: 5 Page 4 of 4Event Description: **Dropped Control Rod, Manual Power Reduction (C: OATC, SRO) (TS)**

Time	Position	Applicant's Actions or Behavior
	BOP	<p>Crew Response:</p> <p>AP/1/A/1700/001 Encl 5.1 (Control of Plant Equipment During Shutdown)</p> <ol style="list-style-type: none"> IAAT SRO determines all appropriate actions have been taken, AND the runback is complete, THEN EXIT this Enclosure Notify the WCC SRO to initiate Enclosure 5.2 (WCC SRO Support During Unit Runback). Start the following pumps: <ul style="list-style-type: none"> 1A/1B FDWP SEAL INJECTION PUMP 1A/1B FDWP AUXILIARY OIL PUMP WHEN CTP \leq 80%, THEN stop 1E1/1E2 HTR DRN PUMP WHEN CTP \leq 65%, THEN continue this Enclosure. Place 1FDW-53 and 1FDW-65 in MANUAL and close <div style="border: 1px solid black; padding: 5px; margin: 10px 0;"> <p style="text-align: center;"><u>NOTE</u></p> <p style="text-align: center;">1B FDWP is the preferred pump to shut down first.</p> </div> <ol style="list-style-type: none"> Verify both Main FDWPs operating. Verify 1B FDWP to be shut down first. Adjust the FWP bias <u>counter-clockwise</u> to lower 1B FWP suction flow $\approx 1 \times 10^6$ lb/hr < 1A FWP suction flow. GO TO Step 12 IAAT <u>both</u> Main FDW pumps running, AND <u>both</u> of the following exist: <ul style="list-style-type: none"> <u>1B</u> Main FDW pump is first pump to be shut down <u>Any</u> of the following alarms occur: <ul style="list-style-type: none"> 1SA-16/A-3 (FWP B FLOW MINIMUM) 1SA-16/A-4 (FWP B FLOW BELOW MIN) THEN trip 1B Main FDW Pump

This event is complete when the SRO reaches WHEN Step 12 of AP/01, or as directed by the Lead Examiner.

Op-Test No.: 1Scenario No.: 1Event No.: 6

Page 1 of 1

Event Description: **CT-1 Transformer Lockout (PCB 17 and 18 open) (SRO) (TS)**

Time	Position	Applicant's Actions or Behavior
	BOP	<p>Plant Response:</p> <p>CT-1 transformer will be de-energized 1SA-15/C-2 EL SU SOURCE VOLT MONIT LOGIC UNDERVOLTAGE PCB-17 and PCB-18 will open</p> <p>Crew Response:</p> <p>Refer to ARG 1SA-15/C-2</p> <p>2. Automatic Action</p> <p>2.1 Loss of startup source from the Yellow Bus.</p> <p>3 Manual Action</p> <p>Refer to Technical Specification 3.8.1, AC Sources – Operating</p> <p>Condition A: Both required offsite sources and the overhead emergency power path inoperable due to inoperable unit startup transformer.</p> <p>Required Action:</p> <p>A.1 Perform SR 3.8.13. Within 1 hour if not performed in previous 12 hours.</p> <p><u>AND</u></p> <p>A.2 Align the emergency startup bus to share another unit's startup transformer. Within 12 hours</p> <p><u>AND</u></p> <p>A.3.1 Restore unit startup transformer to OPERABLE status and normal startup bus alignment. Within 36 hours</p> <p><u>OR</u></p> <p>A.3.2 Designate one unit, sharing the startup transformer, to be shutdown. Within 36 hours</p> <p>Note: If asked Unit 2 will perform SR 3.8.1.3.</p> <p>Note: An RO may dispatch a NEO to Emergency Power Switching Logic Panel #1 to determine status.</p>
	SRO	

This event is complete when the SRO has referred to Technical Specifications, or as directed by the Lead Examiner.

Op-Test No.: 1Scenario No.: 1Event No.: 7

Page 1 of 1

Event Description: **Main Turbine Fails to trip (C: OATC, SRO)**
Runs concurrent with Event 8

Time	Position	Applicant's Actions or Behavior
	OATC	<p>Plant Response: The reactor will trip on high RCS pressure due to the Switchyard Isolation.</p> <p>Crew response: The SRO will direct the OATC to perform <u>Immediate Manual Actions</u> (IMAs)</p> <ol style="list-style-type: none"> 3.1 Depress REACTOR TRIP pushbutton. 3.2 Verify reactor power < 5% FP and decreasing. 3.3 Depress turbine TRIP pushbutton. 3.4 Verify all turbine stop valves closed. (They will be open) <p>RNO: Place both EHC pumps in PULL TO LOCK.</p> <ol style="list-style-type: none"> 3.5 Verify RCP seal injection available. <p>RNO: IF CC is unavailable, THEN immediately perform the following:</p> <ul style="list-style-type: none"> • Stop <u>all</u> RCPs. • Notify CR SRO to initiate AP/25 (Standby Shutdown Facility Emergency Operating Procedure). <p>Note: Power will be restored in about 15 seconds.</p>

This event is complete when the EHC pumps have been locked out, or as directed by the Lead Examiner.

Op-Test No.: 1Scenario No.: 1Event No.: 8

Page 1 of 5

Event Description: **Switchyard Isolation (RX trip) (M: ALL)**
Stuck Control Rod
KHU-1 lock out

Time	Position	Applicant's Actions or Behavior
	OATC	<p>Plant Response:</p> <p>The plant will attempt to runback but will trip on HIGH RCS pressure KHU-1 will lock out KHU-2 will supply power to the MFBs via CT-4 and the Standby Bus in about 30 seconds.</p> <p>Crew response:</p> <p>Perform <u>Immediate Manual Actions</u> (IMAs)</p> <ul style="list-style-type: none"> Depress REACTOR TRIP pushbutton. Verify reactor power < 5% FP and decreasing. Depress turbine TRIP pushbutton. Verify all turbine stop valves closed. Verify RCP seal injection available. IF CC is unavailable, THEN immediately perform the following: <ul style="list-style-type: none"> Stop all RCPs. Notify CR SRO to initiate AP/25 (Standby Shutdown Facility Emergency Operating Procedure). <p><u>AP/25 (May not be implement since power will return in ≈ 30 seconds)</u></p> <p>4.1 Verify <u>any</u> of the following required due to loss of function: <ul style="list-style-type: none"> SSF RCMU feed SSF ASW feed to SGs </p> <p>4.2 Stop <u>all</u> RCPs</p> <p>4.3 Verify a Licensed Operator staged in SSF and available to perform AP/0/A/1700/025 (Standby Shutdown Facility Emergency Operating Procedure). (no operator is staged at the SSF)</p> <p>RNO: 1. Obtain the following items: <ul style="list-style-type: none"> Vital area access key ring Flashlight Respirator (if Security Event) 2. Proceed to the SSF.</p> <p>Note: If needed, the RO performing AP/25 actions will be stopped before leaving the control room and informed that a Unit 2 RO will perform SSF actions.</p>

Op-Test No.: 1Scenario No.: 1Event No.: 8

Page 2 of 5

Event Description: **Switchyard Isolation (RX trip) (M: ALL)**
Stuck Control Rod
KHU-1 lock out

Time	Position	Applicant's Actions or Behavior
	BOP	<p>Crew response:</p> <p>Perform <u>Symptoms Check</u></p> <ul style="list-style-type: none"> • Power Range NIs < 5% • Power Range NIs decreasing • Any SCM < 0°F • <u>Loss of Main and Emergency FDW</u> (including unsuccessful manual initiation of EFDW) • Uncontrolled Main Steam line(s) pressure decrease • Indications of SGTR: <p>The SRO will direct an RO to initiate Rule 3 due to a loss of Main FDW (see page 19)</p> <p>When power is restored, the SRO should initiate AP/11 from Parallel Actions Page of Subsequent Actions tab (see page 25)</p>
	SRO	<p>The SRO will refer to EOP Subsequent Actions</p> <p>4.1 Verify all control rods in Groups 1 – 7 fully inserted. (one control rod will NOT be fully inserted)</p> <p>RNO: 1. Open 1HP-24 and 1HP-25 (CT-23)</p> <p>Note: One valve must be opened prior to exiting SA to met this CT.</p> <p>2. Secure makeup to the LDST</p> <p>3. If CRDs are energized... (they are NOT)</p> <p>4.2 Verify Main FDW in operation</p> <p>RNO: 1. Ensure Rule 3 is in progress or complete</p> <p>2. GO TO Step 4.5</p> <p>4.5 IAAT Main FDW is operating, AND level in <u>any</u> SG is > 96% on the Operating Range, THEN perform Steps 4.6 - 4.8</p> <p>RNO: GO TO Step 4.9</p> <p>4.9 IAAT TBVs CANNOT control SG pressure at desired setpoint, THEN manually control pressure in affected SGs</p> <p>4.10 Verify 1RIA-40 operable with CSAE OFF-GAS BLOWER operating</p> <p>4.11 GO TO Step 4.14</p> <p>4.14 Dispatch an operator with Encl 5.29 (MSRV Locations) to verify all MSRVs have reseated</p> <p>4.15 Verify ES is required.</p> <p>RNO: 1. Initiate Encl 5.5 (Pzr and LDST Level Control) (see page 26)</p> <p>2. GO TO Step 4.17</p>

Op-Test No.: 1Scenario No.: 1Event No.: 8

Page 3 of 5

Event Description: **Switchyard Isolation (RX trip) (M, ALL)**
Stuck Control Rod
KHU-1 lock out

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Crew Response:</p> <p>EOP Subsequent Actions</p> <p>4.17 Open PCB-20 and PCB-21</p> <p>4.18 Verify Generator Field Breaker open.</p> <p>4.19 Verify EXCITATION is OFF.</p> <p>4.20 Verify Aux Bldg and Turbine Bldg Instrument Air pressure ≥ 90 psig.</p> <p>4.21 Verify ICS/NNI power available.</p> <p>4.22 Verify all 4160V switchgear (1TC, 1TD & 1TE) energized.</p> <p>4.23 Verify both SGs > 550 psig.</p> <p>4.24 Verify Main FDW operating.</p> <p>RNO: 1. Ensure Rule 3 (Loss of Main or Emergency FDW) in progress or complete.</p> <p>2. Ensure SG levels approaching proper setpoint. (Rule 7)</p> <p>3. GO TO Step 4.28.</p> <p>4.28 Verify all SCMs $> 0^{\circ}\text{F}$.</p> <p>4.29 Verify both SGs intentionally isolated to stop excessive heat transfer.</p> <p>RNO: GO TO Step 4.31.</p> <p>4.31 Verify heat transfer exists.</p> <p>4.32 Verify primary to secondary heat transfer has been excessive.</p> <p>RNO: GO TO Step 4.34.</p> <p>4.34 Verify indications of SGTR ≥ 25 gpm.</p> <p>RNO: GO TO Step 4.36.</p> <p>4.36 Verify required RCS makeup flow within normal makeup capability.</p> <p>4.37 Verify two Main FDW pumps operating.</p> <p>RNO: GO TO Step 4.39.</p> <p>4.39 Verify <u>any</u> CBP operating.</p> <p>RNO: GO TO Step 4.44.</p> <p>4.44 Verify any HWP operating.</p> <p>RNO: GO TO Step 4.48.</p> <p>4.48 Close 1SSH-9, 1MS-76, and 1MS-79</p>

Op-Test No.: 1Scenario No.: 1Event No.: 8

Page 4 of 5

Event Description: **Switchyard Isolation (RX trip) (M, ALL)**
Stuck Control Rod
KHU-1 lock out

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Crew response:</p> <p>EOP Subsequent Actions</p> <p>4.49 Perform the following:</p> <p>___ Stop all Htr Drain pumps.</p> <p>___ Stop both MSRH Drain pumps.</p> <p>4.50 Place 1HD-37 and 1HD-52 in DUMP:</p> <p>4.51 Verify 1MS-24 and 1MS-33 are closed:</p> <p>4.52 Verify <u>all</u> MSRVs reseated.</p> <p>4.53 Verify Pzr level < 375"</p> <p>4.54 Verify <u>any</u> RCP operating.</p> <p>RNO: GO TO Step 4.56.</p> <p>4.56 IAAT <u>all</u> the following exist:</p> <p>___ < one RCP/loop operating</p> <p>___ RCP available for restart in idle loop</p> <p>___ RCS P/T stable</p> <p>4.57 Maintain RCS P/T stable.</p> <p>4.58 IAAT Station Management desires a Natural Circ cooldown, THEN GO TO FCD tab.</p> <p>4.59 WHEN the OSM approves, THEN GO TO OP/1/A/1102/010 (Controlling Procedure For Unit Shutdown) Encl (S/D To Mode 3 Following Rx Trip Or Rapid S/D).</p>
	BOP	<p>Rule 3 (Loss of Main or Emergency Feedwater)</p> <p>1. Verify loss of Main FDW.EFDW is due to Turbine Building Flooding.</p> <p>RNO: GO TO Step 3</p> <p>3. IAAT NO SGs can be fed with FDW (Main/CBP/Emergency), AND any of the following exist:</p> <ul style="list-style-type: none"> • RCS pressure reaches 2300 psig OR NDT limit • Pzr level reaches 375" [340" acc] <p>THEN PERFORM Rule 4 (Initiation of HPI Forced Cooling).</p> <p>4. Start operable EFDW pumps to feed <u>all intact</u> SGs.</p> <p>5. Verify any EFDW pump operating.</p> <p>6. GO TO Step 37.</p> <p>37. IAAT an EFDW valve CANNOT control in AUTO...</p> <p>RNO: GO TO Step 43</p>

This event is complete when RCS temperature and pressure are stable, or as directed by the Lead Examiner.

Op-Test No.: 1Scenario No.: 1Event No.: 8

Page 5 of 5

Event Description: **Switchyard Isolation (RX trip) (M: ALL)**
Stuck Control Rod
KHU-1 lock out

Time	Position	Applicant's Actions or Behavior
	BOP	<p>Crew response:</p> <p>Rule 3 (Loss of Main or Emergency Feedwater)</p> <p>43. Verify <u>any</u> SCM $\leq 0^{\circ}\text{F}$.</p> <p>RNO: IF overcooling, OR exceeding limits in Rule 7, THEN throttle EFDW as necessary</p> <p>44. IAAT Unit 1 EFDW is in operation, THEN initiate Encl 5.9 (Extended EFDW Operation).</p> <p>45. WHEN directed by CR SRO, THEN EXIT this rule.</p>
	BOP	<p>EOP Enclosure 5.9 (Extended EFDW Operation)</p> <ol style="list-style-type: none"> 1. Monitor EFDW parameters on EFW graphic display 2. IAAT UST level is $< 4'$, THEN GO TO Step 117 3. IAAT feeding <u>both</u> SGs with one MD EFDWP is desired, THEN perform Steps 4-7 <p>RNO: GO TO Step 8</p> <p>8. Perform the following as required to maintain UST level $> 7.5'$:</p> <ul style="list-style-type: none"> ___ Makeup with demin water ___ Place CST pumps in AUTO <p>9. IAAT <u>all</u> the following exist:</p> <ul style="list-style-type: none"> ___ Rapid cooldown NOT in progress ___ MD EFDWP operating for each <u>available</u> SG ___ EFDW flow in <u>each</u> header < 600 gpm <p>THEN place 1 TD EFDW PUMP switch in PULL TO LOCK</p> <p>10. Verify 1 TD EFDW PUMP operating</p> <p>RNO: GO TO Step 12</p> <p>12. Notify CR SRO to set priority based on the NOTE above <u>and</u> EOP activities</p>

This event is complete when RCS temperature and pressure are stable, or as directed by the Lead Examiner.

Op-Test No.: 1Scenario No.: 1Event No.: 9

Page 1 of 5

Event Description: **Blackout Loss of second Keowee Unit
Recover Power using CT-5**

Time	Position	Applicant's Actions or Behavior
		<p>Plant response: KHU #2 Emergency Lockout MFBs will de-energize</p> <p>Crew response: The SRO may direct an RO to perform a Symptoms Check The SRO will direct an RO to re-initiate Rule 3 (see page 24) SRO will transfer to the BLACKOUT tab</p> <ul style="list-style-type: none"> • The SRO will direct an RO to initiate AP/25 • Direct and RO to announce plant conditions using the plant page and notify the OSM to reference EP and NSD 202 (reportability). <p>SRO EOP Blackout tab</p> <ol style="list-style-type: none"> 1. Verify <u>two</u> ROs available to perform Control Room actions. 2. Notify <u>one</u> RO to perform Encl 5.38 (Restoration of Power). <p>Note: Enclosure 5.38 steps begin on the next page.</p> <ol style="list-style-type: none"> 3. Verify <u>any</u> SG is being fed. 4. Verify <u>any</u> MD EFDWP operating <p>RNO: Position the following to OFF:</p> <p>___ 1A MD EFDWP ___ 1B MD EFDWP</p> <ol style="list-style-type: none"> 5. Feed and steam <u>available</u> SGs as necessary to stabilize RCS P/T. <div style="border: 1px solid black; padding: 5px; margin: 10px 0;"> <p style="text-align: center;">NOTE</p> <p>Feeding SGs with EFDW is desired above HPI Forced Cooling. Step 6 should be performed prior to re-performing Rule 3.</p> </div> <ol style="list-style-type: none"> 6. IAAT NO SGs are being fed, AND any source of EFDW (Unit 1 or another unit) becomes available, 7. IAAT EFDW from any source is insufficient to maintain stable RCS P/T, THEN notify SSF operator that feeding SGs with SSF ASW is required. 8. IAAT power is restored to 1TC, 1TD, 1TE, THEN GO TO Step 9 <p>RNO: GO TO Step 11</p> <ol style="list-style-type: none"> 9. Initiate AP/11 (Recovery From Loss of Power) 10. GO TO Subsequent Actions tab 11. Verify Encl 5.38 (Restoration of Power) in progress or complete. 12. IAAT all 4160V SWGR (1TC, 1TD, 1TE) are de-energized, AND Standby Bus #1 is energized, THEN GO TO Step 13. <p>RNO: GO TO Step 78</p>

Op-Test No.: 1Scenario No.: 1Event No.: 9

Page 2 of 5

Event Description: **Blackout Loss of second Keowee Unit
Recover Power using CT-5**

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Note: Power may not be restored at this point. In which case the crew will route to Step 78.</p> <p>78. IAAT <u>all</u> 4160V SWGR (1TC, 1TD, 1TE) are de-energized for 1½ hours, THEN dispatch an operator to perform Encl 5.17 (Generator Emergency Hydrogen Purge). {20}</p> <p>79. Verify blackout exists on all three units.</p> <p>RNO: GO TO Step 81.</p> <p>81. Verify MFB 1 and MFB 2 de-energized</p> <p>82. WHEN Encl 5.38 (Restoration of Power) is complete, THEN continue this procedure.</p>
	OATC/BOP	<p>EOP Enclosure 5.38 (Restoration of Power) (CT-8)</p> <p>Note: The CT is not met if Encl 5.38 is completed with power NOT restored.</p> <p>1. Verify power has been restored.</p> <p>RNO: GO TO Step 3</p> <p>3. Place 1HP-31 in HAND <u>and</u> reduce demand to 0.</p> <p>4. Close 1HP-21.</p> <p>5. Verify MFB1/2 is energized</p> <p>RNO: GO TO Step 8</p> <p>8. Verify CT-1 indicates ≈ 4160 volts.</p> <p>RNO: GO TO Step 18</p> <p>18. Verify <u>both</u> Standby Bus #1 and Standby Bus #2 are de-energized.</p> <p>19. Verify <u>both</u> Keowee units operating</p> <p>RNO: 1. Emergency start Keowee units: ___ KEOWEE EMER START CHANNEL A ___ KEOWEE EMER START CHANNEL B (not modeled)</p> <p>2. IF NO Keowee units are operating, THEN GO TO Step 36.</p> <p>36. IAAT CT-5 indicates ≈ 4160 volts, THEN GO TO Step 50.</p> <p>50. Place the following switches in MAN: ___ MFB1 AUTO/MAN ___ MFB2 AUTO/MAN ___ STANDBY 1 AUTO/MAN ___ STANDBY 2 AUTO/MAN</p>

Op-Test No.: 1 Scenario No.: 1 Event No.: 9

Page 3 of 5

Event Description: **Blackout Loss of second Keowee Unit
Recover Power using CT-5**

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew response:</p> <p>EOP Enclosure 5.38</p> <p>51. Open the following breakers:</p> <p>___ N1₁ MFB1 NORMAL FDR</p> <p>___ N2₁ MFB2 NORMAL FDR</p> <p>___ E1₁ MFB1 STARTUP FDR</p> <p>___ E2₁ MFB2 STARTUP FDR</p> <p>52. Place the following switches in MAN:</p> <p>___ CT4 BUS 1 AUTO/MAN</p> <p>___ CT4 BUS 2 AUTO/MAN</p> <p>___ CT5 BUS 1 AUTO/MAN</p> <p>___ CT5 BUS 2 AUTO/MAN</p> <p>53. Open the following breakers:</p> <p>___ SK1 CT4 STBY BUS 1 FEEDER</p> <p>___ SK2 CT4 STDY BUS 2 FEEDER</p> <p>54. Close the following breakers: (CT-8)</p> <p>___ SL1 CT5 STBY BUS 1 FEEDER</p> <p>___ SL2 CT5 STBY BUS 2 FEEDER</p> <p>55. Place the following switches in AUTO:</p> <p>___ CT5 BUS 1 AUTO/MAN</p> <p>___ CT5 BUS 2 AUTO/MAN</p> <p>56. Verify Standby Bus #1 energized.</p> <p>57. Notify CR SRO in each unit where a blackout exists that Standby Bus #1 is energized.</p> <p>58. Close the following breakers:</p> <p>___ S1₁ STBY BUS 1 TO MFB1</p> <p>___ S2₁ STBY BUS 2 TO MFB2</p> <p>59. Verify <u>any</u> of the following energized:</p> <p>___ 1TC</p> <p>___ 1TD</p> <p>___ 1TE</p> <p>60. Notify Unit 1 CR SRO of status of 4160V SWGR.</p> <p>61. Verify Jocassee Hydro is being aligned to ONS.</p> <p>RNO: GO TO Step 63.</p> <p>63. EXIT this enclosure.</p>

Op-Test No.: 1 Scenario No.: 1 Event No.: 9

Page 4 of 5

Event Description: **Blackout Loss of second Keowee Unit
Recover Power using CT-5**

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew response:</p> <p>EOP Rule 3</p> <p>1. Verify loss of Main FDW/EFDW is due to Turbine Building Flooding</p> <p>RNO: GO TO Step 3</p> <p>3. IAAT NO SGs can be fed with FDW (Main/CBP/Emergency), AND <u>any</u> of the following exist:</p> <p>___ RCS pressure reaches 2300 psig OR NDT limit</p> <p>___ Pzr level reaches 375" [340" acc]</p> <p>THEN PERFORM Rule 4</p> <p>4. Start <u>operable</u> EFDW pumps, as required, to feed <u>all intact</u> SGs</p> <p>5. Verify <u>any</u> EFDW pump operating</p> <p>6. GO TO Step 37</p> <p>37. IAAT an EFDW valve CANNOT control in AUTO...</p> <p>RNO: GO TO Step 43</p> <p>43. Verify <u>any</u> SCM $\leq 0^{\circ}\text{F}$.</p> <p>RNO: IF overcooling, OR exceeding limits in Rule 7, THEN throttle EFDW as necessary</p> <p>44. IAAT Unit 1 EFDW is in operation, THEN initiate Encl 5.9 (Extended EFDW Operation).</p> <p>45. WHEN directed by CR SRO, THEN EXIT this rule.</p>

Op-Test No.: 1 Scenario No.: 1 Event No.: 9

Page 5 of 5

Event Description: **Blackout Loss of second Keowee Unit
Recover Power using CT-5**

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew response:</p> <p>AP/1/A/1700/011 Recovery From Loss of Power</p> <p>4.1 Announce AP entry using OMP 1-18 placard</p> <p>4.2 IAAT Pzr level > 80" [180" acc], AND Pzr heaters are desired, THEN position Pzr heaters to AUTO</p> <p>4.3 Verify load shed of inverters was performed per Unit 1 EOP Encl (Load Shed of Inverters During SBO)</p> <p>RNO: GO TO Step 4.9</p> <p>4.9 Verify load shed of inverters has initiated as indicated by <u>either</u> of the following statalarms on:</p> <p>___ 1SA-15/D-4</p> <p>___ 1SA-14/D-4</p> <p>RNO: GO TO Step 4.11</p> <p>4.11 Close the following breakers:</p> <p>___ 1TC INCOMING FDR BUS 1</p> <p>___ 1TC INCOMING FDR BUS 2</p> <p>___ 1TD INCOMING FDR BUS 1</p> <p>___ 1TD INCOMING FDR BUS 2</p> <p>___ 1TE INCOMING FDR BUS 1</p> <p>___ 1TE INCOMING FDR BUS 2</p> <p>4.12 Verify 1SA-15/E-6 (EL SWYD ISOLATION CONFIRMED CHNL A LOGIC) is OFF</p> <p>RNO: GO TO Step 4.15</p> <p>4.15 Verify <u>any</u> Oconee unit receiving power from its normal source</p> <p>4.16 Place transfer switches in MAN for <u>all</u> Oconee units receiving power from the normal source (1T, 2T, 3T)</p> <ul style="list-style-type: none"> • MFB1 AUTO/MAN • MFB2 AUTO/MAN • TA AUTO/MAN • TB AUTO/MAN <p>4.17 Verify load shed was initiated as indicated by either of the following statalarms on:</p> <p>___ 1SA-15/D-4</p> <p>___ 1SA-14/D-4</p>

This event is complete when power is restored, or as directed by the Lead Examiner.

Op-Test No.: 1 Scenario No.: 1 Event No.: _____

Page 1 of 3

Event Description: **EOP Encl 5.5 actions if needed**

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew response:</p> <p>EOP Enclosure 5.5 (Pzr and LDST Level Control)</p> <ol style="list-style-type: none"> Utilize the following as necessary to maintain <u>desired</u> Pzr level: <ul style="list-style-type: none"> 1A HPI Pump 1B HPI Pump 1HP-26 1HP-7 1HP-120 setpoint or valve demand 1HP-5 IAAT <u>makeup</u> to the <u>LDST</u> is desired, THEN makeup from 1A BHUT IAAT it is desired to <u>secure</u> <u>makeup</u> to LDST, THEN secure makeup from 1A BHUT IAAT it is desired to <u>bleed</u> letdown flow to 1A BHUT, THEN perform the following: <ol style="list-style-type: none"> Open 1CS-26 and 1CS-41 Position 1HP-14 to BLEED Notify SRO IAAT letdown <u>bleed</u> is NO longer desired, THEN position 1HP-14 to NORMAL IAAT 1C HPI PUMP is required, THEN perform Steps 7-9 <p>RNO: GO TO Step 10</p> <ol style="list-style-type: none"> Open 1HP-24 and 1HP-25 Start 1C HPI PUMP Throttle 1HP-26 and 1HP-27 as required to maintain desired Pzr level IAAT <u>LDST</u> <u>level</u> CANNOT be maintained, THEN perform Step 11 <p>RNO: GO TO Step 12</p> <ol style="list-style-type: none"> Perform the following: <ul style="list-style-type: none"> Open 1HP-24 and 1HP-25 Close 1HP-16 IAAT additional makeup flow to LDST is desired, AND 1A BLEED TRANSFER PUMP is operating, THEN dispatch an operator to close 1CS-48 IAAT <u>two</u> Letdown Filters are desired, THEN open 1HP-17 and 1HP-18

Op-Test No.: 1 Scenario No.: 1 Event No.:

Page 2 of 3

Event Description: **EOP Encl 5.5 actions if needed**

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew response:</p> <p>EOP Enclosure 5.5 (Pzr and LDST Level Control) continued</p> <p>14. IAAT <u>all</u> of the following exist:</p> <p> ___ Letdown isolated</p> <p> ___ LPSW available</p> <p> ___ Letdown restoration desired</p> <p> THEN perform Steps 15-33</p> <p>RNO: GO TO Step 34</p> <p>15. Open 1CC-7 and 1CC-8</p> <p>16. Ensure only one CC pump running</p> <p>17. Place non-running CC pump in AUTO</p> <p>18. Verify 1HP-1 and 1HP-2 are open</p> <p>19. GO TO Step 22</p> <p>22. Monitor for unexpected conditions while restoring letdown</p> <p>23. Verify <u>both</u> letdown coolers to be placed in service</p> <p>24. Open 1HP-1, 1HP-2, 1HP-3, and 1HP-4</p> <p>25. Verify <u>at least one</u> letdown cooler is aligned</p> <p>26. Close 1HP-6</p> <p>27. Close 1HP-7</p> <p>28. Verify Letdown temperature < 135°F</p> <p>RNO:</p> <p>1. Open 1HP-13</p> <p>2. Close 1HP-8 and 1HP-9&11</p> <p>3. IF <u>any</u> deborating IX is in service, THEN perform the following:</p> <p> A. Select 1HP-14 to NORMAL</p> <p> B. Close 1HP-16</p> <p>4. Select LETDOWN HI TEMP INTLK BYP switch to BYPASS</p> <p>29. Open 1HP-5</p> <p>30. Adjust 1HP-7 for ≈ 20 gpm letdown</p> <p>31. WHEN letdown temperature is < 130°F, THEN place LETDOWN HI TEMP INTLK BYP switch to NORMAL</p> <p>32. Open 1HP-6</p> <p>33. Adjust 1HP-7 to control desired letdown flow</p> <p>34. IAAT it is determined that letdown is unavailable due to equipment failures <u>or</u> letdown system leakage, THEN notify SRO to initiate AP/32</p>

Op-Test No.: 1 Scenario No.: 1 Event No.:

Page 3 of 3

Event Description: **EOP Encl 5.5 actions if needed**

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew response:</p> <p>EOP Enclosure 5.5 (Pzr and LDST Level Control) continued</p> <p>35. IAAT > 1 HPI pump is operating, AND additional HPI pumps are NO longer needed, THEN perform the following:</p> <ul style="list-style-type: none"> A. Obtain SRO concurrence to reduce running HPI pumps B. Secure the desired HPI pumps C. Place secured HPI pump switch in AUTO, if desired <p>36. IAAT <u>all</u> the following conditions exist:</p> <ul style="list-style-type: none"> <u> </u> Makeup from BWST NOT required <u> </u> LDST level > 55" <u> </u> <u>All</u> control rods inserted <u> </u> Cooldown Plateau NOT being used <p>THEN close 1HP-24 and 1HP-25</p> <p>37. Verify 1CS-48 has been closed to provide additional makeup flow to LDST</p> <p>RNO: GO TO Step 39</p> <p>38. WHEN 1CS-48 is NO longer needed to provide additional makeup flow to LDST, THEN perform the following:</p> <ul style="list-style-type: none"> A. Stop 1A BLEED TRANSFER PUMP B. Locally position 1CS-48 <u>one</u> turn open C. Close 1CS-46 D. Start 1A BLEED TRANSFER PUMP E. Locally throttle 1CS-48 to obtain 90-110 psig discharge pressure F. Stop 1A BLEED TRANSFER PUMP <p>39. Verify two Letdown Filters in service, AND <u>only one</u> Letdown filter is desired</p> <p>RNO: GO TO Step 41</p> <p>41. WHEN directed by CR SRO, THEN EXIT this enclosure</p>

These actions are complete when directed by the CR SRO.

CRITICAL TASKS

CT-23 Establish and maintain Reactor Shutdown Requirements

If all rods do not insert (except gp 8), boration is commenced to achieve acceptable SDM.

CT-8 Electrical Power Alignment

Recover Power using CT-5 (CT): Recovering electrical power during a Station Blackout event is necessary for the operation of normal and emergency plant equipment.

SAFETY: Take a Minute			
UNIT 0 (OSM)			
SSF Operable: Yes	KHU's Operable: U1 - UG, U2 - OH	LCTs Operable: 2	Fuel Handling: No
UNIT STATUS (CR SRO)			
Unit 1 Simulator		Other Units	
Mode: 1		Unit 2	Unit 3
Reactor Power: 100%		Mode: 1	Mode: 1
Gross MWE: 900		100% Power	100% Power
RCS Leakage: +.025 gpm (No WCAP action level)		EFDW Backup: Yes	EFDW Backup: Yes
RBNS Rate: .01 gpm			
Technical Specifications/SLC Items (CR SRO)			
Component/Train	OOS Date/Time	Restoration Required Date/Time	TS/SLC #
AMSAC/DSS Bypassed	Today / 06:30	7 Days	SLC 16.7.2 Condition A & B
Shift Turnover Items (CR SRO)			
Primary			
<ul style="list-style-type: none"> SASS in MANUAL for I&E testing AMSAC/DSS Bypassed for I&E testing 			
Secondary			
<ul style="list-style-type: none"> 1SSH-1, 1SSH-3, 1SD-2, 1SD-5, 1SD-140, 1SD-303, 1SD-355, 1SD-356 and 1SD-358 are closed with power supply breakers open per the Startup Procedure for SSF Overcooling Event. Control 1B FDWPT with Motor Speed Changer T/O SHEET CR tag on 1B MAIN FDW PUMP (ICS) station. The BOP is to remove 1B MFDWP from the Hand Jack per OP/1/A/1106/002 B beginning at Step 2.1. NEO is stationed at the 1B MFDWP. GWR Tank 'B' release in progress 			
Reactivity Management (CR SRO)			
RCS Boron: 30 ppmB	Gp 7 Rod Position: 90%		
Human Performance Emphasis (OSM)			
Procedure Use and Adherence			

DRAFT

Facility: **Oconee**Scenario No.: **2R0**Op-Test No.: **1**Examiners: _____

_____Operators: _____ **SRO**
_____ **OATC**
_____ **BOP**

Initial Conditions:

- Unit 1: Reactor Power = 87%
- Unit 2: 100%
- Unit 3: 100%

Turnover:

- SASS in Manual
- AMSAC/DSS bypassed for I&E testing
- GWD Tank B release in progress
- PT/1/A/0290/003, Turbine Valve Movement, in progress. Continue and test CV1.

Event No.	Malfunction No.	Event Type*	Event Description
0a	Pre-Insert		SASS in MANUAL
0b	Pre-Insert		AMSAC/DSS bypassed
0c	Pre-Insert		Block all reactor trips but manual
1		N: BOP, SRO	PT/1/A/0290/003, Turbine Valve Movement, in progress, testing CV1
2	Override	SRO (TS)	1A HPI pump trips (TS)
3	MPS244	C: BOP, SRO	1A2 RCP lower seal failure (requires pump shutdown)
4	MPI281, 68	I: OATC, SRO	ΔT_C Controller fails when 1A2 RCP is secured
5	Override	C: BOP, SRO (TS)	HPSW Jockey Pump trips "A" HPSW pump auto initiation logic inoperable (TS)
6	Override	C: OATC, SRO	PZR spray valve (1RC-1) fails OPEN
7	Override MPI300	C: OATC, SRO	Loss of power to 1TB (Loss of 2 RCPs – 1A2 & 1B2) ATWS with 1C HPI pump failure
8	MPS400 (.23)	M: All	SBLOCA with LOSCM (ES actuation) (Trip RCPs) Rapid RCS cooldown
* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor			

DRAFT

Op-Test No.: 1 Scenario No.: 2 Event No.: 1 Page 1 of 2

Event Description: **PT/1/A/0290/003, Turbine Valve Movement in progress, testing CV1 (N: BOP, SRO)**

Time	Position	Applicant's Actions or Behavior
	BOP	<p>Crew response: The BOP should use the in progress procedure PT/1/A/0290/003 (Turbine Valve Movement) Enclosure 13.2, Control Valve Movement At Power, at Step 2.1 to test CV1:</p> <p>2.1 Ensure Standby EHC pump in operation</p> <p>Note: 1SA-4/C-7 (MT TURBINE PANEL TROUBLE) will actuate when the 1B EHC pump is started.</p> <p>Booth Cue: If contacted to respond to investigate the Turbine Panel alarm, state that 1SA-0/B-5 (STANDBY HYDRAULIC FLUID PUMP RUNNING) is actuated.</p> <p>2.2 Perform the following:</p> <ul style="list-style-type: none"> • Verify Standby EHC Pump Amp > 0 amps • Verify Standby EHC Pump running smoothly • Verify Standby EHC Pump Discharge Pressure > 1500 psig <p>2.3 Verify CV4 closed</p> <p>2.4 IF CV3 and CV4 test required: (test not required, pages 2-4 of the procedure are N/A)</p> <p>2.5 IF CV2 test required: (test not required, pages 5 & 6 of the procedure are N/A)</p> <p>2.6 IF CV1 test required:</p> <p>2.6.1 IF required, select "Control Valve 1 & 2 Test".</p> <p>2.6.2 Verify "Test Permissive" is ON.</p> <p>2.6.3 Record CV1 pretest position: <u>≈ 94 %</u> Open.</p> <p>2.6.4 Select "Initiate Test" for Control Valve 1 Test.</p> <p>2.6.5 IF any of the following conditions occur, select "Abort CV1 Test":</p> <ul style="list-style-type: none"> • NI POWER changes > 2%. (R.M.) • ICS Turbine Master trips to HAND. (R.M.) • Turbine vibration > 10 mils for > 5 seconds. <p>2.6.6 IF "Test Failed" is "ON" AND CV1 is NOT fully closed, select "Abort CV1 Test".</p> <p>2.6.7 IF "Test Failed" is "ON" AND CV1 remains closed perform the following:</p> <ol style="list-style-type: none"> A. Do NOT select "Abort CV1 Test". (R.M.) B. Notify WCC & Engineering that the (FASV) for the Control Valve under test is stuck in the energized state. C. Monitor Turbine Vibrations closely if in this abnormal state.

Op-Test No.: 1 Scenario No.: 2 Event No.: 1

Page 2 of 2

Event Description: **PT/1/A/0290/003, Turbine Valve Movement in progress, testing CV1 (N: BOP, SRO)**

Time	Position	Applicant's Actions or Behavior
	BOP	<p>Crew response:</p> <p>PT/1/A/0290/003 (Turbine Valve Movement) Enclosure 13.2, Control Valve Movement At Power, to test CV1:</p> <p>2.6.8 Perform <u>EITHER</u> for CV1:</p> <p>A. Verify "Test Successful" indicated for CV1.</p> <p>B. <u>IF</u> "Test Successful" <u>NOT</u> indicated for CV1, verify CV1 moved towards closed position.</p> <p>2.6.9 Verify CV1 test indicator reset.</p> <p>2.6.10 Verify CV1 within $\pm 5.0\%$ of pretest position.</p> <p>2.6.11 Perform the following:</p> <ul style="list-style-type: none"> Verify acceptance criteria met. (acceptance is met) <u>IF</u> acceptance criteria <u>NOT</u> met, notify SRO. <p>2.7 <u>IF</u> desired:</p> <p>2.7.1 Stop Standby EHC pump.</p> <p>2.7.2 Place Standby EHC pump control switch to "AUTO".</p>

This event is complete when test of CV1 is complete and the standby EHC pump is placed in AUTO, or as directed by the Lead Examiner.

Op-Test No.: 1 Scenario No.: 2 Event No.: 2

Page 1 of 1

Event Description: **1A HPI pump trips (SRO) (TS)**

Time	Position	Applicant's Actions or Behavior
	BOP	<p>Plant response:</p> <p>Standby HPI Pump starts on low Seal Inlet Header Flow (< 22 gpm) 1SA-02/B-2, HP RCP SEAL INLET HEADER FLOW HIGH/LOW, actuates.</p> <p>Crew response:</p> <p>The crew may perform Plant Transient Response Refer to ARG 1SA-02/B-2 Low Alarm</p> <p>3.2.1 Verify low seal flow condition with individual RCP seal flow indications</p> <p>3.2.2 IF Low Seal Flow condition is due to an HPI System failure, refer to AP/1/A/1700/014 (Loss of Normal HPI Makeup and/or RCP Seal Injection)</p> <p>3.2.3 IF Low Seal Flow condition is NOT due to an HPI System failure, adjust 1HP-31 (RCP Seal Flow Control) per OP/1/A/1104/002 (HPI System)</p> <p>3.2.4 Monitor for low LDST level:</p> <p>A. Makeup as required per OP/1/A/1103/004 (Soluble Poison Concentrate Control)</p> <p>B. Verify LDST levels as read on OAC:</p> <ul style="list-style-type: none"> • O1A1042 HP LDST LVL 1 • O1A1043 HP LDST LVL 2 <p>C. IF an accurate LDST level CANNOT be maintained or verified, align suction for HPI Pumps from BWST per AP/1/A/1700/014 (Loss of Normal HPI Makeup and/or Seal Injection)</p> <p>Note: The crew may request an R&R to place the 1A HPI pump switch in the OFF position.</p>
	SRO	<p>SRO refers to TS 3.5.2 and enters Condition A for one inoperable HPI pump.</p> <p>APPLICABILITY: MODES 1 and 2, MODE 3 with RCS temperature > 350°F</p> <p>CONDITION A: One HPI pump inoperable</p> <p>REQUIRED ACTION: Restore HPI pump to OPERABLE status</p> <p>COMPLETION TIME: 72 hours</p>

This event is complete when TS 3.5.2 is addressed, or as directed by the Lead Examiner.

Op-Test No.: 1 Scenario No.: 2 Event No.: 3 Page 1 of 3Event Description: **1A2 RCP lower seal failure (requires pump shutdown) (C: BOP, SRO)**

Time	Position	Applicant's Actions or Behavior
	BOP	<p>Plant response:</p> <ul style="list-style-type: none"> • 1SA-06/B-5, RC PUMP 1A2 SEAL CAVITY PRESS HI/LOW • OAC Alarm RCP 1A2 LOWER SEAL CAVITY PRESSURE HI HI • OAC Alarm RCP 1A2 UPPER SEAL CAVITY PRESSURE HI HI <p>Crew response: Refer to the ARGs</p> <p>3.1 Upper/Lower Seal Cavity Pressure High</p> <p>3.1.1 <u>Go To</u> AP/1/A/1700/016, Abnormal RCP Operation, for limits and required action</p> <p>3.2 Upper/Lower Seal Cavity Pressure Low</p> <p>3.2.1 <u>IF</u> in Mode 1 or 2, <u>Go To</u> AP/1/A/1700/016, Abnormal RCP Operation, for limits and required action</p>
	SRO	<p>Refer to AP/1/A/1700/016 (Abnormal RCP Operation)</p> <p>4.1 IAAT <u>any</u> RCP meets immediate trip criteria of Encl 5.1 (RCP Immediate Trip Criteria), THEN perform Steps 4.2 - 4.11.</p> <p>RNO: GO TO Step 4.12.</p> <p>4.12 IAAT either of the following apply:</p> <ul style="list-style-type: none"> • <u>Any</u> RCP approaching immediate trip criteria of Encl 5.1 (RCP Immediate Trip Criteria) • It is desired to secure a RCP <p>THEN perform Steps 4.13 - 4.15.</p> <p>RNO: GO TO Step 4.16</p> <p>Note: It is acceptable for the SRO to take either procedure path to secure the 1A2 RCP. Step 4.16 is on the next page.</p> <p>4.13 Verify Rx Power > 70%</p> <p>4.14 Initiate Encl 5.2 (Rapid Power Reduction) (see page 7)</p> <p>4.15 WHEN Rx Power is ≤ 70%, THEN GO TO Step 4.2</p> <p>4.2 Verify MODE 1 or 2</p> <p>4.3 Verify Rx power is ≤ 70% as indicated on all NIs</p> <p>4.4 Verify three RCPs will remain operating after <u>affected</u> RCP is tripped</p> <p>4.5 Verify <u>any</u> SG on Low Level Limits</p> <p>RNO: GO TO Step 4.8</p> <p>4.8 Verify FDW masters in Auto</p> <p>4.9 Stop affected RCP</p> <p>4.10 Verify ICS re-ratios feed water to establish desired ΔT_C</p> <p>Note: When the 1A2 RCP is secured, ICS will not re-ratio FDW as expected and initiate the next event (see page 8).</p>

Op-Test No.: 1 Scenario No.: 2 Event No.: 3 Page 2 of 3Event Description: **1A2 RCP lower seal failure (requires pump shutdown) (C: BOP, SRO)**

Time	Position	Applicant's Actions or Behavior																		
	SRO	<p>Crew response:</p> <p>AP/1/A/1700/016 (Abnormal RCP Operation)</p> <p>4.16 Announce AP entry using the PA system</p> <p>4.17 Notify OSM to request evaluation by RCP Component Engineer</p> <p>4.18 IAAT the failure is identified, THEN GO TO the applicable section per the following table:</p> <table border="1"> <tr> <td>√</td><td>Section</td><td>Failure</td></tr> <tr> <td></td><td>4A</td><td>Seal Failure</td></tr> <tr> <td></td><td>4B</td><td>Abnormal Vibration</td></tr> <tr> <td></td><td>4C</td><td>High or Low Oil Pot Level</td></tr> <tr> <td></td><td>4D</td><td>Loss of Seal Return</td></tr> <tr> <td></td><td>4E</td><td>Abnormal RCP Temperatures</td></tr> </table>	√	Section	Failure		4A	Seal Failure		4B	Abnormal Vibration		4C	High or Low Oil Pot Level		4D	Loss of Seal Return		4E	Abnormal RCP Temperatures
√	Section	Failure																		
	4A	Seal Failure																		
	4B	Abnormal Vibration																		
	4C	High or Low Oil Pot Level																		
	4D	Loss of Seal Return																		
	4E	Abnormal RCP Temperatures																		
	SRO	<p>AP/1/A/1700/016 Section 4A, RCP Seal Failure</p> <p>1. IAAT <u>any</u> RCP meets immediate trip criteria of Encl 5.1, THEN perform Steps 2-11</p> <p>RNO: GO TO Step 12</p> <p>12. IAAT <u>any</u> of the following indicate external RCP seal leakage:</p> <ul style="list-style-type: none"> • RB RIAs increasing <u>or</u> in alarm • RCS Tave constant with LDST level decreasing more than normal • Quench Tank level rate increasing • RB Normal Sump rate increasing • Visual confirmation <p>THEN initiate AP/02 (Excessive RCS Leakage)</p> <p>13. Verify the following are open:</p> <ul style="list-style-type: none"> • 1HP-20 • 1HP-21 <p>14. Verify the following is open for the <u>affected</u> RCP:</p> <ul style="list-style-type: none"> • 1HP-226 (1A2 RCP) <p>15. IAAT <u>either</u> of the following conditions apply to an operating RCP:</p> <table border="1"> <tr> <td>√</td><td>RCS Pressure</td><td>ΔP across <u>any</u> seal</td></tr> <tr> <td></td><td>> 1000 psig</td><td>≤ 100 psid</td></tr> <tr> <td></td><td>≤ 1000 psig</td><td>≤ 35 psid</td></tr> </table> <p>THEN GO TO Step 16 to shut down the <u>affected</u> RCP since shut down of the RCP is desired due to a seal failure.</p>	√	RCS Pressure	ΔP across <u>any</u> seal		> 1000 psig	≤ 100 psid		≤ 1000 psig	≤ 35 psid									
√	RCS Pressure	ΔP across <u>any</u> seal																		
	> 1000 psig	≤ 100 psid																		
	≤ 1000 psig	≤ 35 psid																		

Op-Test No.: 1 Scenario No.: 2 Event No.: 3 Page 3 of 3Event Description: **1A2 RCP lower seal failure (requires pump shutdown) (C: BOP, SRO)**

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Crew response:</p> <p>AP/1/A/1700/016 Section 4A, RCP Seal Failure</p> <p>16 IAAT shut down of an RCP is desired, THEN perform Steps 17-27</p> <p>17. Verify MODE 1 <u>or</u> 2</p> <p>18. Verify three RCPs will remain operating after <u>affected</u> RCP is tripped</p> <p>19. Verify Rx power is $\leq 70\%$ as indicated on <u>all</u> NIs</p> <p>RNO: 1. Direct an RO to initiate Encl 5.2 (Rapid Power Reduction)</p> <p>2. WHEN Rx power is $\leq 70\%$ on <u>all</u> NIs, THEN continue this procedure</p> <p>20. Verify <u>any</u> SG on Low Level Limits</p> <p>RNO: GO TO Step 23</p> <p>23. Verify FDW masters in Auto</p> <p>24. Stop <u>affected</u> RCP</p> <p>25. Verify ICS re-ratios feedwater to establish desired ΔT_C</p> <p>Note: When the 1A2 RCP is secured, the Delta T_C controller will fail and Feedwater will not properly re-ratio as expected and initiate the next event.</p>
	OATC	<p>AP/16 Enclosure 5.2, Rapid Power Reduction</p> <p>1. Verify ICS in AUTO</p> <p>2. Initiate MAXIMUM RUNBACK to $\leq 70\%$ as indicated by <u>all</u> NIs</p> <p>3. WHEN Rx Power is $\leq 70\%$ as indicated by <u>all</u> NIs, THEN press MAXIMUM RUNBACK to stop runback</p> <p>4. Notify CR SRO that Rx Power is $\leq 70\%$</p> <p>5. Adjust CTPD SET to match CTP DEMAND</p> <p>6. Stop the following pumps:</p> <p>___ 1E1 HTR DRN PUMP</p> <p>___ 1E2 HTR DRN PUMP</p> <p>7. Verify Rx Power was reduced $\geq 15\%$ within a 1 hour period</p> <p>8. Notify Primary Chemistry to perform Tech Spec SR 3.4.11.2 as required</p> <p>9. EXIT this enclosure</p>

This event is complete when Rx power is reduced to $\leq 70\%$ and the 1A2 RCP is secured, or as directed by the Lead Examiner.

Op-Test No.: 1 Scenario No.: 2 Event No.: 4 Page 1 of 2Event Description: ΔT_c Controller fails when 1A2 RCP is secured (I: OATC, SRO)

Time	Position	Applicant's Actions or Behavior
	OATC	<p>Crew Response:</p> <p>The crew will be required to diagnose that Feedwater failed to ratio properly and mitigate the failure per AP/16</p> <p>AP/1/A/1700/016 Abnormal RCP Operation</p> <p>25. Verify ICS re-ratios feedwater to establish desired ΔT_c</p> <p>RNO: 1. Place DELTA T_c station in HAND</p> <p>2. Manually adjust DELTA T_c station to achieve desired ΔT_c</p> <p>Note: The approximate value for total FDW flow at 65% power is 7.1 E6 lbm/hr. The 1A S/G FDW flow should be ≈ 2.4 E6 lbm/hr and the 1B S/G FDW flow should be ≈ 4.7 E6 lbm/hr to achieve the desired ΔT_c of \approx zero.</p> <p>3. IF DELTA T_c station does NOT control, THEN perform the following: (does not apply)</p> <p>4. Initiate AP/28 (ICS Instrument Failures)</p> <p>26. Initiate Encl 4.3 (Special Instructions for < 4 RCP Operation) of OP/1/A/1102/004 (Operation at Power)</p> <p>27. Initiate the following notifications:</p> <ul style="list-style-type: none"> • Notify OSM to make required notifications of OMP 1-14 (Notifications) • Notify Rx Engineering and request a power maneuver plan, if needed • Notify SOC if load reduction was required • Notify Chemistry to take RCS boron samples on a 1 hour frequency
	SRO	<p>Refer to AP/1/A/1700/028, ICS Instrument Failures</p> <p>4.1 Provide control bands as required</p> <p>4.2 Initiate notification of the following:</p> <ul style="list-style-type: none"> • OSM to reference OMP 1-14 and Emergency Plan • STA <p>4.3 Verify a power transient $\geq 5\%$ has occurred</p> <p>4.4 Notify Rx Engineering and discuss the need for a maneuvering plan</p> <p>4.5 Use the following, as necessary, to determine the applicable section from table in Step 4.6</p> <ul style="list-style-type: none"> • OAC alarm video • OAC display points • Control Board indications • SPOC assistance, as needed

This event is complete when the crew initiates AP/28, or as directed by the Lead Examiner.

Op-Test No.: 1 Scenario No.: 2 Event No.: 4

Page 2 of 2

Event Description: ΔT_C Controller fails when 1A2 RCP is secured (I: OATC, SRO)

Time	Position	Applicant's Actions or Behavior						
	SRO	<p>Crew Response:</p> <p>AP/1/A/1700/028, ICS Instrument Failures</p> <p>4.1 Provide control bands as required</p> <p>4.2 Initiate notification of the following:</p> <ul style="list-style-type: none"> • OSM to reference OMP 1-14 and Emergency Plan • STA <p>4.3 Verify a power transient $\geq 5\%$ has occurred</p> <p>4.4 Notify Rx Engineering and discuss the need for a maneuvering plan</p> <p>4.5 Use the following, as necessary, to determine the applicable section from table in Step 4.6</p> <ul style="list-style-type: none"> • OAC alarm video • OAC display points • Control Board indications • SPOC assistance, as needed <p>4.6 GO TO the applicable section per the following table:</p> <table border="1"> <tr> <td>✓</td><td>Section</td><td>Failure</td></tr> <tr> <td></td><td>4F</td><td>Delta T_C</td></tr> </table>	✓	Section	Failure		4F	Delta T_C
✓	Section	Failure						
	4F	Delta T_C						
	SRO	<p>AP/1/A/1700/028 Section 4F</p> <p>1. Ensure the following in HAND:</p> <p>___ 1A FDW MASTER</p> <p>___ 1B FDW MASTER</p> <p>___ DELTA T_C</p> <p>2. Re-ratio feed water flow, as required, to establish DELTA T_C while maintaining total feed water flow constant</p> <p>3. Notify SPOC to perform the following:</p> <p>___ Investigate <u>and</u> repair the failed Delta T_C controller</p> <p>4. WHEN notified by SPOC that Delta T_C controller has been repaired, THEN GO TO OP/1/A/1102/004 A Encl (Placing ICS Stations To Auto)</p> <p>Note: The Delta T_C controller will not be repaired for this scenario.</p>						

This event is complete when the crew initiates AP/28, or as directed by the Lead Examiner.

Op-Test No.: 1 Scenario No.: 2 Event No.: 5 Page 1 of 1Event Description: **HPSW Jockey Pump trips with HPSW auto initiation logic inoperable (C: BOP, SRO) (TS)**

Time	Position	Applicant's Actions or Behavior
	BOP	<p>Plant Response:</p> <ul style="list-style-type: none"> 1SA-9/A-8 HPSW Header A/B PRESS LOW 1SA-9/D-8 HPSW JOCKEY PUMP OFF HPSW header pressure decreases due to Jockey Pump trip. <p>Crew Response: Refer to ARG 1SA-9/D-8</p> <p>3.1 Verify automatic actions until jockey pump is restarted</p> <p>3.2 IF there is NO evidence of breaker and/or pump motor problem, attempt to restart jockey pump one time. If restart is unsuccessful, notify Maintenance Department.</p> <p>The crew may refer to ARG 1SA-9/A-8</p> <p>3.1 Verify proper jockey pump operation</p> <p>3.2 Refer to SLC 16.9.8a</p> <p>3.3 Verify HPSW pumps start (start manually if NOT already in operation per OP/0/A/1104/011) when preset levels in EWST are reached</p> <p>3.4 IF HPSW Header Pressure continues to decrease AND EWST level is NOT dropping, manually start a HPSW Pump</p> <p>3.5 Refer to AP/1-2/A/1700/030 (Aux Building Flood)</p> <p>3.6 Investigate and correct reason for excessive HPSW usage</p> <p>3.7 Verify BASE and STANDBY HPSW Pumps stop at 80,000 gals</p> <p>3.8 IF manually started, return HPSW Pumps when NO longer needed</p> <p>Booth Cue: <i>After the crew manually starts the HPSW Jockey Pump, call the Control Room as SPOC and report "During investigation of the Jockey Pump failure, it has been determined that the 'A' HPSW Pump auto initiation logic circuit is OOS (or not functioning properly)".</i></p> <p>Booth Cue: <i>If the crew dispatches a NEO to determine if a problem exists with HPSW Jockey Pump motor/breaker, use TIME COMPRESSION and inform the RO that no problem was found with the Jockey Pump motor or breaker</i></p>
	SRO	<p>SRO refers to SLC 16.9.1 and enters Condition A for HPSW pump A and B auto initiation logic inoperable.</p> <p>APPLICABILITY: At all times</p> <p>CONDITION A: Equipment inoperable in the Ocone Fire Suppression Water Supply System</p> <p>REQUIRED ACTION: Restore inoperable equipment to OPERABLE status</p> <p>COMPLETION TIME: 7 days</p>

This event is complete when the Jockey Pump has been restarted and the SRO refers to SLC 16.9.1, or as directed by the Lead Examiner.

Op-Test No.: 1 Scenario No.: 2 Event No.: 6

Page 1 of 2

Event Description: **PZR spray valve (1RC-1) fails OPEN (C: OATC, SRO)**

Time	Position	Applicant's Actions or Behavior
		<p>Plant Response:</p> <ul style="list-style-type: none"> • RCS pressure will decrease • 1SA-2/D-3 (RC PRESS HIGH/LOW) <p>Crew Response:</p> <p>Note: The crew may perform Plant Transient Response (PTR)</p> <p>Refer to Alarm Response Guide 1SA-2/D-3 (RC PRESS HIGH/LOW)</p> <p>3.2 Low Alarm</p> <p>3.2.1 Refer to AP/1/A/1700/044 (Abnormal Pressurizer Pressure Control)</p> <p>BOP</p> <p>SRO</p> <p>Refer to AP/1/A/1700/044 (Abnormal Pressurizer Pressure Control)</p> <p>1. Entry Conditions</p> <p>1.1 Inability to maintain control of RC pressure due to failure of the PORV, 1RC-1, <u>or</u> PZR heaters as indicated by <u>any</u> of the following:</p> <ul style="list-style-type: none"> • High or Low RC pressure alarms • RC pressure outside of control band • Pressurizer Relief Valve Flow Statalarm <p>3. Immediate Manual Actions</p> <p>3.1 IAAT <u>all</u> of the following conditions exist:</p> <p>___ PORV open</p> <p>___ RC pressure < 2300 psig (HIGH) <u>or</u> 480 psig (LOW)</p> <p>___ PZR level ≤ 375"</p> <p>THEN close 1RC-4</p> <p>Note: The crew may perform Immediate Manual Action Step 3.2 from memory prior to the SRO entering AP/44.</p> <p>3.2 IAAT <u>all</u> the following conditions exist:</p> <p>___ RC pressure < 2155 psig</p> <p>___ RC pressure decreasing without a corresponding decrease in PZR level</p> <p>___ PZR heaters unable to maintain RCS pressure</p> <p>THEN close the following:</p> <p>___ 1RC-1</p> <p>___ 1RC-3</p> <p>Note: If the block valve (1RC-3) is not closed, the Reactor will trip on variable low pressure and ES actuation will occur.</p>

Op-Test No.: 1 Scenario No.: 2 Event No.: 6

Page 2 of 2

Event Description: **PZR spray valve (1RC-1) fails OPEN (C: OATC, SRO)**

Time	Position	Applicant's Actions or Behavior									
	SRO	<p>Crew Response:</p> <p>Note: The PZR spray valve (1RC-1) will remain failed for the remainder of the scenario and the operator will be required to maintain RCS pressure manually, as required, using 1RC-3.</p> <p>Note: 1RC-1 normally maintains RCS pressure 2155-2205 psig.</p> <p>AP/1/A/1700/044 (Abnormal Pressurizer Pressure Control)</p> <p>4.1 Announce AP entry using the PA system</p> <p>4.2 GO TO the applicable per the following table:</p> <table border="1"> <tr> <td>√</td><td>Failure Caused RCS Pressure</td><td>Step</td></tr> <tr> <td></td><td>Decrease</td><td>4.3</td></tr> <tr> <td></td><td>Increase</td><td>4.19</td></tr> </table> <p>4.3 Verify the following: <input type="checkbox"/> 1RC-4 <u>failed</u> to close <input type="checkbox"/> PORV open</p> <p>RNO: GO TO Step 4.5</p> <p>4.5 Verify 1RC-1 failed OPEN</p> <p>4.6 Position the following to maintain RC pressure within desired band, as required: <input type="checkbox"/> 1RC-1 <input type="checkbox"/> 1RC-3</p> <p>4.7 Verify RC pressure decreasing uncontrollably</p> <p>RNO: GO TO Step 4.14</p> <p>4.14 Verify PZR heaters maintaining RCS pressure within desired band</p> <p>4.15 Notify SPOC to repair malfunctioning component</p> <p>4.16 Ensure requirements of following are met: (no TS should not apply) <input type="checkbox"/> TS 3.4.1 (RCS Pressure, Temperature, and Flow DNB Limits) <input type="checkbox"/> TS 3.4.9 (Pressurizer) <input type="checkbox"/> TS 3.4.12 (LTOP System) <input type="checkbox"/> SLC 16.5.1 (RCS Vents)</p> <p>4.17 WHEN repairs complete, THEN place the following components in desired position for current plant conditions as determined by CR SRO</p>	√	Failure Caused RCS Pressure	Step		Decrease	4.3		Increase	4.19
√	Failure Caused RCS Pressure	Step									
	Decrease	4.3									
	Increase	4.19									

This event is complete when the RCS pressure decrease has been stopped and PZR level is stable, or as directed by the Lead Examiner.

Op-Test No.: 1Scenario No.: 2Event No.: 7

Page 1 of 3

Event Description: **Loss of power to 1TB (C: OATC, SRO)
ATWS (Rule 1) with 1C HPI pump failure**

Time	Position	Applicant's Actions or Behavior
		Plant Response: An automatic RX trip should have occurred due to the loss of 2 RCPs.
	OATC	Crew Response: The SRO will direct the OATC to perform EOP Immediate Manual Actions The SRO will direct the BOP to perform a Symptoms Check EOP Immediate Manual Actions: 3.1 Depress REACTOR TRIP pushbutton. 3.2 Verify reactor power < 5% FP and decreasing. RNO: GO TO Rule 1 (ATWS/Unanticipated Nuclear Power Production)
	OATC	EOP Rule 1 (CT-24) 1. Verify any Power Range NI \geq 5% FP 2. Initiate manual control rod insertion to the IN LIMIT 3. Notify CR SRO to GO TO UNPP tab (see next page) 4. Open 1HP-24 and 1HP-25 5. Ensure <u>only one</u> of the following operating: • 1A HPI PUMP • 1B HPI PUMP 6. Start 1C HPI PUMP Note: The 1C HPI pump will not start and only the 1B HPI pump (the standby HPI pump) will be operating. RNO: 1. Start the standby HPI pump 2. IF <u>at least two</u> HPI pumps are operating, THEN open 1HP-409 7. Open 1HP-26 and 1HP-27 8. Dispatch <u>one</u> operator without wearing Arc Flash PPE to open 600V CRD breakers on the following: • 1X9-5C (Unit 1 CRD Norm Fdr Bkr) • 2X1-5B (Unit 1 CRD Alternate Fdr Bkr) 9. Verify only two HPI pumps operating RNO: IF <u>all</u> HPI pumps operating, THEN perform the following: (does not apply) 10. EXIT this rule

Op-Test No.: 1Scenario No.: 2Event No.: 7

Page 2 of 3

Event Description: **Loss of power to 1TB (C: OATC, SRO)
ATWS (Rule 1) with 1C HPI pump failure**

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Crew Response: EOP UNPP tab:</p> <ol style="list-style-type: none"> 1. Ensure Rule 1 is in progress or complete 2. Verify Main FDW is operating <u>and</u> in AUTO 3. IAAT Main FDW is NOT operating, THEN perform the following: <ol style="list-style-type: none"> A. Trip the turbine-generator B. Start <u>all available</u> EFDW pumps 4. IAAT all power range NIs are < 5% FP, THEN perform Steps 5-6 <p>RNO: GO TO Step 7</p> <ol style="list-style-type: none"> 5. Depress turbine TRIP pushbutton 6. Verify <u>all</u> turbine stop valves closed 7. Verify <u>any</u> wide range NI > 1% FP <p>RNO: GO TO Step 15</p> <ol style="list-style-type: none"> 8. Open 1RC-4 and 1HP-5 9. Maximize letdown 10. Verify Main FDW available 11. Adjust Main FDW flow as necessary to control RCS temperature 12. Verify overcooling in progress <p>RNO: GO TO Step 15</p> <ol style="list-style-type: none"> 15. Secure makeup to LDST 16. WHEN <u>all</u> Wide Range NIs are ≤ 1% FP, AND decreasing, THEN continue 17. Control RCS temperature using the following methods: <ul style="list-style-type: none"> ___ Tave ≤ 555°F – Adjust SG pressure as necessary to stabilize RCS temperature using either of the following: <ul style="list-style-type: none"> • TBVs • Dispatch two operators to perform Encl 5.24 (Operation of the ADVs) ___ Tave > 555°F – Utilize Rule 7 (SG Feed Control) to control SG feed rate as necessary to maintain cooldown rate within Tech Spec limits during the approach to the SG Level Control Point 18. Throttle HPI per Rule 6 (HPI) 19. WHEN RCS pressure < 2300 psig, THEN continue 20. Verify PORV closed 21. Adjust letdown flow as desired 22. Verify RCP seal injection available 23. GO TO Subsequent Actions tab

Op-Test No.: 1 Scenario No.: 2 Event No.: 7

Page 3 of 3

Event Description: **Loss of power to 1TB (C: OATC, SRO)
ATWS (Rule 1) with 1C HPI pump failure**

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Crew Response: EOP Subsequent Actions tab:</p> <p>4.1 Verify <u>all</u> control rods in Groups 1-7 fully inserted</p> <p>4.2 Verify Main FDW in operation</p> <p>4.3 Verify <u>either</u> of the following:</p> <p>___ Main FDW overfeeding causing excessive temperature decrease</p> <p>___ Main FDW underfeeding causing SG level decrease below setpoint</p> <p>RNO: GO TO Step 4.5</p> <p>4.5 IAAT Main FDW is operating, AND level in <u>any</u> SG is > 96% on the Operating Range, THEN perform Steps 4.6 – 4.8</p> <p>RNO: GO TO Step 4.9</p> <p>4.9 IAAT TBVs CANNOT control SG pressure at desired setpoint, THEN manually control pressure in <u>affected</u> SG using <u>either</u> of the following:</p> <p>___ TBVs</p> <p>___ Dispatch two operators to perform Encl 5.24 (Operation of the ADVs) (PS)</p> <p>4.10 Verify 1RIA-40 operable with CSAE OFF-GAS BLOWER operating</p> <p>4.11 GO TO Step 4.14</p> <p>4.14 Dispatch operator with Encl 5.29 (MSRV Locations) to verify <u>all</u> MSRVs have reseated</p> <p>4.15 Verify ES is required</p> <p>RNO: 1. Initiate Encl 5.5 (Pzr and LDST Level Control) 2. GO TO Step 4.17</p>

This event is complete when the SRO transfers to the Subsequent Actions tab, or as directed by the Lead Examiner.

Op-Test No.: 1Scenario No.: 2Event No.: 8

Page 1 of 9

Event Description: **SBLOCA with LOSCM (ES actuation) (M: ALL)**
Rapid RCS cooldown

Time	Position	Applicant's Actions or Behavior
		<p>Plant Response: RCS pressure will begin to decrease 1SA-08/A-9 RM Area Monitor Radiation High 1SA-08/B-9 Process Monitor Radiation High 1SA-08/E-9 Reactor Building Normal Sump Isolate ES Channels 1 and 2 will actuate on low RCS pressure (< 1600 psig) ES Channels 3 – 6 will actuate on High RB pressure (> 3 psig) in ≈ 6 min</p> <p>Crew Response: When <u>any</u> SCM indicates 0°F, the SRO will direct an operator to perform Rule 2. (details on page 21) The SRO will transfer to the LOSCM tab of the EOP from Subsequent Actions Parallel Actions page. The SRO will direct an operator to initiate EOP Encl 5.1, ES Actuation, per LOSCM Parallel Actions Page. (details begin on page 22) If the crew asks, Unit 2 will perform AP/1/A/1700/018 (Abnormal Release of Radioactivity) actions.</p> <p>Note: The crew may transfer to the ICC tab if it is noticed that Rx Vessel head level briefly indicates 0" (see page 20)</p>
	SRO	
	SRO	<p>EOP LOSCM tab</p> <ol style="list-style-type: none"> 1. Ensure Rule 2 (Loss of SCM) is in progress or complete 2. Verify Station ASW feeding <u>any</u> SG <p>RNO: GO TO Step 4</p> <ol style="list-style-type: none"> 4. Verify LOSCM caused by excessive heat transfer <p>RNO: GO TO Step 6</p> <ol style="list-style-type: none"> 6. IAAT <u>either</u> of the following exists: <ul style="list-style-type: none"> • LPI FLOW TRAIN A <u>plus</u> LPI FLOW TRAIN B ≥ 3400 gpm • <u>Only one</u> LPI header in operation with header flow ≥ 2900 gpm THEN GO TO LOCA CD tab 7. Verify SSF activated per AP/25 with <u>both</u> of the following systems required: <ul style="list-style-type: none"> • SSF RC Makeup • SSF Aux Service Water <p>RNO: GO TO Step 9</p>

Op-Test No.: 1Scenario No.: 2Event No.: 8

Page 2 of 9

Event Description: **SBLOCA with LOSCM (ES actuation) (M: ALL)**
Rapid RCS cooldown

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Crew Response: EOP LOSCM tab</p> <p>9. Verify <u>all</u> of the following exist:</p> <ul style="list-style-type: none"> • NO RCPs operating • HPI flow in <u>both</u> HPI headers • Adequate <u>total</u> HPI flow per Figure 1 (Total Required HPI Flow) <p>RNO: GO TO Step 11</p> <p>Note: Since only one HPI pump will be operating, HPI flow will <u>not</u> exist in both HPI headers</p> <p>11. IAAT <u>all</u> SCMs are > 0°F, OR <u>all</u> the following exists:</p> <ul style="list-style-type: none"> • NO RCPs operating • HPI flow in <u>both</u> HPI headers • Adequate <u>total</u> HPI flow per Figure 1 <p>THEN GO TO Step 89</p> <p>12. Start <u>both</u> MDEFDW pumps</p> <ul style="list-style-type: none"> • 1A MDEFDW Pump • 1B MDEFDW Pump <p>13. Start the TDEFDWP</p> <p>14. Establish 300 gpm EFDW flow to each of the following:</p> <ul style="list-style-type: none"> • 1A SG • 1B SG <p>15. Verify <u>both</u> MDEFDW pumps are operating</p> <p>16. Initiate full depressurization of <u>both</u> SGs utilizing <u>either</u> of the following:</p> <ul style="list-style-type: none"> • TBVs • ADVs <p>17. Initiate EFDW flow to <u>all available</u> SGs to LOSCM setpoint at maximum allowable rate (per Table 3 of Rule 7)</p> <p>Note: The maximum flow for 1A and 1B MD EFDW pumps are 600 gpm per pump with suction from the UST. The TD EFDW pump maximum flow is 950 gpm. The maximum EFDW flow per header is 1000 gpm.</p> <p>18. Trip <u>both</u> Main FDW Pumps</p> <p>19. Place FDW block valve switches in close:</p> <ul style="list-style-type: none"> • 1FDW-33 • 1FDW-31 • 1FDW-42 • 1FDW-40

Op-Test No.: 1 Scenario No.: 2 Event No.: 8

Page 3 of 9

Event Description: **SBLOCA with LOSCM (ES actuation) (M: ALL)
Rapid RCS cooldown**

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Crew Response: EOP LOSCM tab</p> <ol style="list-style-type: none"> 20. Open 1AS-40 while closing 1MS-47 21. Ensure Rule 3 (Loss of Main or Emergency FDW) is in progress or complete 22. GO TO Step 34 34. IAAT RCS pressure reaches 2450 psig, THEN perform Steps 35 and 36 <p>RNO:</p> <ol style="list-style-type: none"> 1. IF HPI forced cooling is in progress, THEN GO TO Step 37 2. Close 1RC-4 3. GO TO Step 37 37. Close: <ul style="list-style-type: none"> • 1GWD-17 • 1HP-1 • 1HP-2 • 1RC-3 38. Verify <u>either</u> of the following: <ul style="list-style-type: none"> • <u>Core</u> superheated • Rx vessel head level at 0" <p>RNO: GO TO Step 40</p> <ol style="list-style-type: none"> 40. IAAT BWST level is $\leq 19'$, THEN initiate Encl 5.12 (ECCS Suction Swap to RBES) 41. WHEN <u>all</u> SCMs are $> 0^{\circ}\text{F}$, OR <u>all</u> the following exist: <ul style="list-style-type: none"> • NO RCPs operating • HPI flow in <u>both</u> HPI headers • Adequate <u>total</u> HPI flow per Figure 1 THEN maintain SG pressure $<$ RCS pressure utilizing <u>either</u> of the following: <ul style="list-style-type: none"> • TBVs • ADVs 42. Verify primary to secondary heat transfer exists 43. Perform the following: <ul style="list-style-type: none"> ___ Control steaming and feed rates on <u>all intact</u> SGs to maintain cooldown rate within Tech Spec limits: <ul style="list-style-type: none"> • $T_{\text{cold}} > 280^{\circ}\text{F}$: $\leq 50^{\circ}\text{F} / \frac{1}{2} \text{ hr}$ • $T_{\text{cold}} \leq 280^{\circ}\text{F}$: $\leq 25^{\circ}\text{F} / \frac{1}{2} \text{ hr}$ ___ Utilize <u>either</u> of the following: <ul style="list-style-type: none"> • TBVs • ADVs 44. Initiate Encl 5.16 (SG Tube-to-Shell ΔT Control)

Op-Test No.: 1Scenario No.: 2Event No.: 8

Page 4 of 9

Event Description: **SBLOCA with LOSCM (ES actuation) (M: ALL)**
Rapid RCS cooldown

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Crew Response: EOP LOSCM tab</p> <p>45. IAAT an SGTR has occurred, AND <u>any affected</u> SG approaches overfill:</p> <p>46. Verify HPI forced cooling in progress</p> <p>RNO: GO TO Step 48</p> <p>48. Verify CETCs trend decreasing</p> <p>49. Verify primary to secondary heat transfer is excessive</p> <p>RNO: GO TO Step 51</p> <p>51. Verify indications of SGTR ≥ 25 gpm</p> <p>RNO: GO TO Step 53</p> <p>53. Verify required RCS makeup flow within normal makeup capability</p> <p>RNO: GO TO LOCA CD tab</p>
	SRO	<p>EOP LOCA CD tab</p> <p>1. IAAT BWST level is $\leq 19'$, THEN initiate Encl 5.12 (ECCS Suction Swap to RBES)</p> <p>2. Verify ES actuated</p> <p>3. GO TO Step 7</p> <p>7. Perform the following:</p> <p>___ Ensure all RBCUs in low speed</p> <p>___ Open 1LPSW-18</p> <p>___ Open 1LPSW-21</p> <p>___ Open 1LPSW-24</p> <p>8. Initiate Encl 5.35 (Containment Isolation)</p> <p>9. Start <u>all</u> RB Aux Fans</p> <p>10. IAAT <u>either</u> of the following exists:</p> <p>___ LPI FLOW TRAIN A <u>plus</u> LPI FLOW TRAIN B ≥ 3400 gpm</p> <p>___ <u>Only one</u> LPI header in operation with header flow ≥ 2900 gpm</p> <p>THEN GO TO Step 11</p> <p>11. Stop <u>all</u> RCPs</p> <p>12. Dispatch an operator to perform the following (Unit 1 Equip Rm):</p> <p>___ Remove white tag and close 1XO-F5C (1A CFT Outlet)</p> <p>___ Remove white tag and close 1XP-F5C (1B CFT Outlet)</p> <p>___ Close 1XS2-F3D (1LP-104 Post LOCA Boron Dilute)</p>

This event is complete when the SRO transfers to the LOCA CD tab, or as directed by the Lead Examiner.

Op-Test No.: 1Scenario No.: 2Event No.: 8

Page 5 of 9

Event Description: **SBLOCA with LOSCM (ES actuation) (M: ALL)**
Rapid RCS cooldown

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Crew Response: EOP ICC tab (if required)</p> <ol style="list-style-type: none"> IAAT CETCs > 1200°F, AND TSC is ready to provide guidance, THEN perform the following: <ol style="list-style-type: none"> Notify TSC to enter the OSAG EXIT this procedure Ensure full HPI and control per Rule 6 (HPI) IAAT RCS pressure is ≤ 550 psig, OR RB pressure is ≥ 3 psig, THEN perform Steps 4-8 Open 1LP-21 and 1LP-17 Start 1A LPI Pump Open 1LP-22 and 1LP-18 Start 1B LPI Pump Verify two LPI pumps operating IAAT <u>all</u> the following exists: <ul style="list-style-type: none"> <input type="checkbox"/> 1C LPI Pump off <input type="checkbox"/> 1C LPI Pump available <input type="checkbox"/> LPI required <input type="checkbox"/> ECCS pump suction aligned to BWST <input type="checkbox"/> 1A LPI Pump unavailable <input type="checkbox"/> 1B LPI Pump unavailable THEN perform Steps 10-13 <p>RNO: GO TO Step 14</p> <ol style="list-style-type: none"> Open 1CF-1 and 1CF-2 IAAT core SCM is ≥ 0°F, THEN GO TO LOCA CD tab (page 19)

This event is complete when the SRO transfers to the LOCA CD tab, or as directed by the Lead Examiner.

Op-Test No.: 1Scenario No.: 2Event No.: 8

Page 6 of 9

Event Description: **SBLOCA with LOSCM (ES actuation) (M: ALL)**
Rapid RCS cooldown

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew Response: Initiate Rule 2 when <u>any</u> SCM indicates 0°F EOP Rule 2, Loss of SCM</p> <ol style="list-style-type: none"> 1. IAAT <u>all</u> exist: <ul style="list-style-type: none"> • <u>Any</u> SCM ≤ 0°F • Rx power ≤ 1% • ≤ 2 minutes elapsed since loss of SCM THEN perform Steps 2 and 3 2. Stop all RCPs (CT-1) (Within 2 minutes of LOSCM) 3. Notify CR SRO of RCP status 4. Verify Blackout exists <p>RNO: GO TO Step 6</p> <ol style="list-style-type: none"> 6. Open 1HP-24 and 1HP-25 7. Start <u>all available</u> HPI pumps 8. GO TO Step 13 13. Open 1HP-26 and 1HP-27 14. Verify <u>at least two</u> HPI pumps are operating using two diverse indications <p>RNO: GO TO Step 27</p> <ol style="list-style-type: none"> 27. Verify <u>at least two</u> HPI pumps are operating <p>RNO: Maximize HPI flow ≤ 475 gpm (including seal injection for A hdr only)</p> <ol style="list-style-type: none"> 28. Verify RCS pressure > 550 psig 29. IAAT either exists: <ul style="list-style-type: none"> • LPI FLOW TRAIN A <u>plus</u> LPI FLOW TRAIN B ≥ 3400 gpm • <u>Only one</u> LPI header in operation with header flow ≥ 2900 gpm THEN GO TO Step 34 30. Dispatch two operators to perform Encl 5.24 (Operation of the ADVs) 31. Verify 1SA-2/C-8 (AFIS HEADER A INITIATED) lit <p>RNO: Select OFF for <u>both</u> digital channels on AFIS HEADER A</p> <ol style="list-style-type: none"> 32. Verify 1SA-2/D-8 (AFIS HEADER B INITIATED) lit <p>RNO: Select OFF for <u>both</u> digital channels on AFIS HEADER B</p> <ol style="list-style-type: none"> 33. Notify CR SRO: <ul style="list-style-type: none"> • Suspend Rule 3 until directed by LOSCM tab • Degraded HPI exists 34. EXIT this rule

These actions are complete when Rule 2, Loss of Subcooling Margin is exited.

Op-Test No.: 1Scenario No.: 2Event No.: 8

Page 7 of 9

Event Description: **SBLOCA with LOSCM (ES actuation) (M: ALL)**
Rapid RCS cooldown

Time	Position	Applicant's Actions or Behavior															
	OATC/BOP	<p>Crew Response:</p> <p>Note: Initially, ES Channels 1 and 2 will actuate when RCS pressure decreases below 1600 psig. When Reactor Building pressure increases to > 3 psig, ES Channels 3-6 will actuate. If the RO reaches Step 15 prior to ES 3&4 actuation, the procedure directs going to Step 51. When ES Channel 3&4 actuate, the RO should return to IAAT Steps 3, 9, 10, and 15 and perform any required actions</p> <p>EOP Enclosure 5.1, ES Actuation</p> <ol style="list-style-type: none"> Determine all ES channel that <u>should</u> have actuated based on <u>RCS</u> pressure and RB pressure: <table border="1"> <thead> <tr> <th>√</th><th>Actuation Setpoint (psig)</th><th>Associated ES Channel</th></tr> </thead> <tbody> <tr> <td></td><td>1600 (RCS)</td><td>1 & 2</td></tr> <tr> <td></td><td>550 (RCS)</td><td>3 & 4</td></tr> <tr> <td></td><td>3 (RB)</td><td>1, 2, 3, 4, 5, & 6</td></tr> <tr> <td></td><td>10 (RB)</td><td>7 & 8</td></tr> </tbody> </table> Verify <u>all</u> ES channels associated with actuation setpoints have actuated IAAT additional ES actuation setpoints are exceeded, THEN perform Steps 1 – 2 Place Diverse HPI in BYPASS Perform <u>both</u>: <ul style="list-style-type: none"> Place ES CH 1 in MANUAL Place ES CH 2 in MANUAL Verify Rule 2 in progress <u>or</u> complete Verify <u>any</u> RCP operating <p>RNO: GO TO Step 9</p> <ol style="list-style-type: none"> IAAT <u>all</u> exist: <ul style="list-style-type: none"> Voter associated with ES channel is in OVERRIDE An ES channel is <u>manually</u> actuated Components on that channel require manipulation THEN depress RESET on the required channel IAAT <u>any</u> RCP is operating, AND ES Channels 5 and 6 actuate, THEN perform Steps 11-14 <p>RNO: GO TO Step 15</p> <ol style="list-style-type: none"> IAAT ES Channels 3 & 4 are actuated, THEN GO TO Step 16 <p>RNO: GO TO Step 51 (see page 24 if required)</p> <ol style="list-style-type: none"> Place Diverse LPI in BYPASS 	√	Actuation Setpoint (psig)	Associated ES Channel		1600 (RCS)	1 & 2		550 (RCS)	3 & 4		3 (RB)	1, 2, 3, 4, 5, & 6		10 (RB)	7 & 8
√	Actuation Setpoint (psig)	Associated ES Channel															
	1600 (RCS)	1 & 2															
	550 (RCS)	3 & 4															
	3 (RB)	1, 2, 3, 4, 5, & 6															
	10 (RB)	7 & 8															

Op-Test No.: 1Scenario No.: 2Event No.: 8

Page 8 of 9

Event Description: **SBLOCA with LOSCM (ES actuation) (M: ALL)**
Rapid RCS cooldown

Time	Position	Applicant's Actions or Behavior
		<p>Crew Response: EOP Enclosure 5.1, ES Actuation</p> <p>17. Perform <u>both</u>:</p> <ul style="list-style-type: none"> Place ES CH 3 in MANUAL Place ES CH 4 in MANUAL <p>18. IAAT <u>any</u> LPI pump is operating against a shutoff head, THEN at the CR SROs discretion, stop <u>affected</u> LPI pumps</p> <p>19. IAAT RCS pressure is < LPI pump shutoff head, THEN perform Steps 20 - 21</p> <p>RNO: GO TO Step 22</p> <p>22. IAAT 1A <u>and</u> 1B LPI PUMPS are off / tripped, AND <u>all</u> of the following exist:</p> <ul style="list-style-type: none"> RCS pressure < LPI pump shutoff head 1LP-19 closed 1LP-20 closed <p>THEN perform Steps 23 - 24</p> <p>RNO: GO TO Step 25</p> <p>25. IAAT 1A LPI PUMP fails while operating, AND 1B LPI PUMP is operating, THEN close 1LP-17</p> <p>26. IAAT 1B LPI PUMP fails while operating, AND 1A LPI PUMP is operating, THEN close 1LP-18</p> <p>27. Start A and B OUTSIDE AIR BOOSTER FANS (CT-27) (Must be started prior to completing Encl 5.1)</p> <p>28. Notify Unit 3 to start 3A and 3B OUTSIDE AIR BOOSTER FANS</p> <p>29. Verify 1CF-1 and 1CF-2 are open</p> <p>30. Verify 1HP-410 closed</p> <p>31. Secure makeup to the LDST</p> <p>32. Verify <u>all</u> ES channel 1 – 4 components are in the ES position</p> <p>RNO: 1. IF 1HP-3 fails to close, THEN close 1HP-1 2. IF 1HP-4 fails to close, THEN close 1HP-2 3. Notify SRO to evaluate components NOT in ES position <u>and</u> initiate action to place in ES position if desired</p> <p>Note: The 1A & 1C HPI pumps and 1A & 1B LPI pumps will not be in the ES position.</p> <p>33. Verify Unit 2 turbine tripped</p> <p>RNO: GO TO Step 36</p> <p>36. Close 1LPSW-139</p> <p>37. Place in FAIL OPEN: ___ 1LPSW-251 FAIL SWITCH ___ 1LPSW-252 FAIL SWITCH</p> <p>38. Start <u>all available</u> LPSW pumps</p>

Op-Test No.: 1Scenario No.: 2Event No.: 8

Page 9 of 9

Event Description: **SBLOCA with LOSCM (ES actuation) (M: ALL)**
Rapid RCS cooldown

Time	Position	Applicant's Actions or Behavior
		<p>Crew Response: EOP Enclosure 5.1, ES Actuation</p> <p>39. Verify <u>either</u>:</p> <ul style="list-style-type: none"> <input type="checkbox"/> Three LPSW pumps operating <input type="checkbox"/> Two LPSW pumps operating when Tech Specs only requires two operable <p>40. Open 1LPSW-4 and 1LPSW-5</p> <p>41. IAAT BWST level $\leq 19'$, THEN initiate Encl 5.12 (ECCS Suction Swap to RBES)</p> <p>42. Dispatch an operator to perform Encl 5.2 (Placing RB Hydrogen Analyzers In Service) (PS)</p> <p>43. Select DECAY HEAT LOW FLOW ALARM SELECT switch to ON</p> <p>44. IAAT ES channels 5 & 6 have actuated THEN perform Step 45</p> <p>45. Verify <u>all</u> ES channel 5 & 6 components are in the ES position</p> <p>46. IAAT ES channels 7 & 8 have actuated, THEN perform Step 47</p> <p>RNO: GO TO Step 48</p> <p>48. Notify U2 CR SRO that SSF is inoperable due to OTS1-1 open</p> <p>49. IAAT conditions causing ES actuation have cleared, THEN initiate Encl 5.41 (ES Recovery)</p> <p>50. WHEN CR SRO approves, THEN EXIT this enclosure</p> <p>Note: The following steps may be required depending on how quick the RO gets to Step 15 of Encl 5.1. If the RO reaches Step 15 prior to ES 3&4 actuation, the procedure directs going to Step 51. When ES Channel 3&4 actuate, the RO should return to IAAT Steps 3, 9, 10, and 15 and perform any required actions (see page 21).</p> <p>51. Start A and B OUTSIDE AIR BOOSTER FANS</p> <p>52. Notify Unit 3 to start 3A and 3B OUTSIDE AIR BOOSTER FANS</p> <p>53. Verify 1CF-1 and 1CF-2 are open</p> <p>54. Verify 1HP-410 closed</p> <p>55. Secure makeup to the LDST</p> <p>56. Verify all ES channel 1&2 components are in the ES position</p> <p>RNO: 1. IF 1HP-3 fails to close, THEN close 1HP-1 2. IF 1HP-4 fails to close, THEN close 1HP-2 3. Notify SRO to evaluate components NOT in ES position <u>and</u> initiate action to place in ES position if desired</p> <p>Note: The 1C HPI pump will not be in the ES position</p> <p>57. Verify Unit 2 turbine tripped</p> <p>RNO: GO TO Step 60</p> <p>60. Close 1LPSW-139</p>

Op-Test No.: 1 Scenario No.: 2 Event No.:

Page 1 of 2

Event Description: **EOP Enclosure 5.5 (if required)**

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew Response:</p> <p>EOP Enclosure 5.5, Pzr and LDST Level Control (if needed)</p> <ol style="list-style-type: none"> Utilize the following as necessary to maintain <u>desired</u> Pzr level: <ul style="list-style-type: none"> 1A HPI Pump 1B HPI Pump 1HP-26 1HP-7 1HP-120 setpoint or valve demand 1HP-5 IAAT <u>makeup</u> to the <u>LDST</u> is desired, THEN makeup from 1A BHUT. IAAT it is desired to <u>secure makeup</u> to LDST, THEN secure makeup from 1A BHUT. IAAT it is desired to <u>bleed</u> letdown flow to 1A BHUT, THEN perform the following: <ol style="list-style-type: none"> Open: <ul style="list-style-type: none"> 1CS-26 1CS-41 Position 1HP-14 to BLEED. Notify SRO. IAAT letdown <u>bleed</u> is NO longer desired, THEN position 1HP-14 to NORMAL. IAAT 1C HPI PUMP is required, THEN perform Steps 7 – 9. <p>RNO: GO TO Step 10.</p> <ol style="list-style-type: none"> Open 1HP-24 and 1HP-25 Start 1C HPI PUMP Throttle the following as required to maintain desired Pzr level: <ul style="list-style-type: none"> 1HP-26 1HP-27 IAAT <u>LDST level</u> CANNOT be maintained, THEN perform Step 11. <p>RNO: GO TO Step 12.</p> <ol style="list-style-type: none"> Perform the following: <ul style="list-style-type: none"> Open 1HP-24 Open 1HP-25 Close 1HP-16

Op-Test No.: 1Scenario No.: 2Event No.:

Page 2 of 2

Event Description: **EOP Enclosure 5.5 (if required)**

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew Response:</p> <p>12. IAAT additional makeup flow to LDST is desired, AND 1A BLEED TRANSFER PUMP is operating, THEN dispatch an operator to close 1CS-48 (1A BHUT Recirc) (A-1-107, Unit 1 RC Bleed Transfer Pump Rm.).</p> <p>13. IAAT <u>two</u> Letdown Filters are desired, THEN perform the following:</p> <ul style="list-style-type: none"> • Open 1HP-17. • Open 1HP-18 <p>14. IAAT <u>all</u> of the following exist:</p> <ul style="list-style-type: none"> • Letdown isolated • LPSW available • Letdown restoration desired <p>THEN perform Steps 15 - 33</p> <p>RNO: GO TO Step 34.</p> <p>34. IAAT it is determined that letdown is unavailable due to equipment failures <u>or</u> letdown system leakage, THEN notify CR SRO to initiate AP/32 (Loss of Letdown).</p> <p>35. IAAT > 1 HPI pump is operating, AND additional HPI pumps are NO longer needed, THEN perform the following:</p> <ul style="list-style-type: none"> A. Obtain SRO concurrence to reduce running HPI pumps. B. Secure the desired HPI pumps. C. Place secured HPI pump switch in AUTO, if desired. <p>36. IAAT <u>all</u> the following conditions exist:</p> <ul style="list-style-type: none"> • Makeup from BWST NOT required • LDST level > 55" • <u>All</u> control rods inserted • Cooldown Plateau NOT being used <p>THEN close:</p> <ul style="list-style-type: none"> • 1HP-24 • 1HP-25 <p>37. Verify 1CS-48 (1A BHUT Recirc) has been closed to provide additional makeup flow to LDST.</p> <p>RNO: GO TO Step 39.</p> <p>39. Verify two Letdown Filters in service, AND <u>only one</u> Letdown filter is desired.</p> <p>RNO: GO TO Step 41.</p> <p>41. WHEN directed by CR SRO, THEN EXIT this enclosure.</p>

These actions are complete when EOP Enclosure 5.5 (Pzr and LDST Level Control) is exited.

CRITICAL TASKS**CT-24 Shutdown Reactor – ATWS**

In the event the reactor fails to trip in response to automatic and manual demands, then de-energize CRDMs, begin maximum boric acid addition to RCS, and maintain adequate primary to secondary heat transfer.

CT-1 Trip All RCPs

Tripping all RCPs of a within 2 minutes of a LOSCM ensures fuel will remain adequately covered and avoid possible fuel damage.

CT-27 Implementation of Control Room Habitability Guidance

SAFETY: Take a Minute**UNIT 0 (OSM)**

SSF Operable: Yes	KHU's Operable: U1 - OH, U2 - UG	LCTs Operable: 2	Fuel Handling: No
-------------------	----------------------------------	------------------	-------------------

UNIT STATUS (CR SRO)

Unit 1 Simulator	Other Units	
Mode: 1	Unit 2	Unit 3
Reactor Power: 87%	Mode: 1	Mode: 1
Gross MWE: 804	100% Power	100% Power
RCS Leakage: +.025 gpm (No WCAP action level)	EFDW Backup: Yes	EFDW Backup: Yes
RBNS Rate: .01 gpm		

Technical Specifications/SLC Items (CR SRO)

Component/Train	OOS Date/Time	Restoration Required Date/Time	TS/SLC #
AMSAC/DSS Bypassed	Today / 06:30	7 Days	SLC 16.7.2 Condition A & B

Shift Turnover Items (CR SRO)**Primary**

- SASS in MANUAL for I&E testing
- AMSAC/DSS Bypassed for I&E testing
- Reactor power reduced for Turbine Valve Testing.
- GWD Tank B release in progress

Secondary

- 1SSH-1, 1SSH-3, 1SD-2, 1SD-5, 1SD-140, 1SD-303, 1SD-355, 1SD-356 and 1SD-358 are closed with power supply breakers open per the Startup Procedure for SSF Overcooling Event.
- Complete PT/1/A/0290/003 Turbine Valve Movement test for CV1. Begin at step 2.1 of Encl. 13.2 (Control Valve Movement At Power)

Reactivity Management (CR SRO)

RCS Boron: 30 ppmB	Gp 7 Rod Position: 80%	R2 Reactivity management controls established in the Control Room per SOMP 01-02
--------------------	------------------------	--

Human Performance Emphasis (OSM)

Procedure Use and Adherence

Facility: **Oconee**Scenario No.: **3R0**Op-Test No.: **1**

Examiners: _____

Operators: _____ **SRO**_____ **OATC**_____ **BOP**

Initial Conditions:

- Reactor Power = 87% Unit 2: 100% Unit 3: 100%

Turnover:

- Turbine Valve Movement PT has just been completed and awaiting maneuvering plan to return to full power
- SASS in Manual
- AMSAC/DSS bypassed for I&E testing

Event No.	Malfunction No.	Event Type*	Event Description
0a	Pre-Insert		SASS in MANUAL
0b	Pre-Insert		AMSAC/DSS bypassed
0c	Pre-Insert		'A' AFIS Circuit Disabled 'B' AFIS Circuit Disabled
0d	Pre-Insert		1C HPI pump will not start
1	MPI150	I: OATC, SRO (TS)	PZR RTD 'A' Fails LOW (TS)
2	MSS200	C: BOP, SRO	Condenser Vacuum Leak
3	Override	C: BOP, SRO	1B Main FDW Pump Active Thrust Bearing Temperature HIGH Requiring Manual Trip
4	Override	C: OATC, BOP, SRO(TS)	Inadvertent ES Channel 1 actuation (TS)
5	MCS005	I: OATC, SRO	Controlling Tave Fails HIGH
6	MSS360,30	M: ALL	1A MSLB in the reactor building
7	MSS330 MSS260 MSS270	M: ALL	Loss of all SG feed HPI F/C
* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor			

Op-Test No.: 1 Scenario No.: 3 Event No.: 1

Page 1 of 2

Event Description: **PZR RTD 'A' Fails LOW (I: OATC, SRO) (TS)**

Time	Position	Applicant's Actions or Behavior
		<p>Booth Cue: Initiate Timer 13 to actuate 1SA-06/D-9 (FW TREATED WATER PANEL TROUBLE)</p> <p>(This will help to ensure the OATC will take actions for the PZR RTD failure)</p> <p>ARG 1SA-06/D-9 FW TREATED WATER PANEL TROUBLE</p> <p>3. Manual Action</p> <p>3.1 Contact Water Treatment Room and/or inform secondary Chemist</p> <p>Note: Once the BOP has taken action to respond to the alarm, the PZR RTD failure will begin.</p> <p>Plant Response:</p> <p>Statalarms:</p> <ul style="list-style-type: none"> • OAC (RC PZR level 1&3 mismatch) • OAC (RC PZR level 2&3 mismatch) <p>Board indications:</p> <ul style="list-style-type: none"> • PZR level 1 and 2 indicates ≈ 150 inches • PZR level 3 indicates ≈ 220 inches and slowly increasing <p>Crew Response:</p> <p>Refer to ARG 1SA-02/C-3 (RC Pressurizer Level High/Low):</p> <p>1. Alarm Setpoint</p> <p>1.1 High – 260" water</p> <p>1.2 Low – 200" water</p> <p>2. Automatic Action</p> <p>None</p> <p>3. Manual Action</p> <p>3.1 Check alternate PZR level indications.</p> <p>3.2 Check for proper Makeup/Letdown flows and adjust to restore proper level.</p> <ul style="list-style-type: none"> • RO may take 1HP-120 to manual to control PZR level. <p>Note: If taken to MANUAL to control PZR level, the RO should place 1HP-120 back to AUTO.</p> <p>3.3 Refer to the following procedures as required:</p> <ul style="list-style-type: none"> • AP/1/A/1700/002 (Excessive RCS Leakage) • AP/1/A/1700/014 (Loss of Normal HPI M/U and/or RCP SI) • AP/1/A/1700/032 (Loss of Letdown)

Op-Test No.: 1 Scenario No.: 3 Event No.: 1

Page 2 of 2

Event Description: **PZR RTD 'A' Fails LOW (I: OATC, SRO) (TS)**

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Crew Response:</p> <p>Refer to ARG 1SA-02/C-3 (RC Pressurizer Level High/Low):</p> <p>3.4 Refer to Technical Specification 3.4.9, Pressurizer</p> <p>3.5 Refer to Technical Specification 3.3.8, PAM Instrumentation.</p> <ul style="list-style-type: none"> Condition A applies <p>3.6 Refer to OP/1/A/1105/014 (Control Room Instrumentation Operation And Information)</p> <p>OP/1/A/1105/014 Enclosure 4.11 (SASS Information)</p> <p>3.2 SASS (Smart Automatic Signal Selector) Manual Operation</p> <p>3.2.1 IF "MISMATCH" light is on and 'TRIP A' or 'TRIP B' light is on, a SASS trip has occurred.</p> <p>A. Controlling signal will be selected from CR keyswitch (for parameters in ICS Cabinet #8).</p> <p>B. Select valid signal as controlling signal by positioning CR keyswitch or pushbutton for Pzr level to valid signal (for parameters in ICS Cabinet #8).</p> <p>3.2.2 IF "MISMATCH" light is on, a mismatch has occurred</p> <p>A. Controlling signal will be signal selected from CR keyswitch (for parameters in ICS Cabinet #8).</p> <p>B. Select valid signal as controlling signal by positioning CR keyswitch or pushbutton for Pzr level to valid signal (Select Pzr Level #3)</p> <p>3.2.3 Initiate a Work Request to repair faulty signal</p> <p>Note: The SRO may direct an RO to select Pzr Level #3 prior to referencing OP/1/A/1105/014</p> <p>Note: If the SRO has not addressed the TS for this event, continue to next event and ask the TS as a follow up question.</p> <p>The SRO should enter TS 3.3.8 Condition A for one or more Functions with one required channel inoperable (two channels of PZR level are required)</p> <p>The Required Action is to restore the required channel to operable status within 30 days</p>
This event is complete when PZR level 3 is selected, or as directed by the Lead Examiner.		

Op-Test No.: <u>1</u>		Scenario No.: <u>3</u>	Event No.: <u>2</u>	Page 1 of 2
Event Description:		Condenser Vacuum Leak (C: BOP, SRO)		
Time	Position	Applicant's Actions or Behavior		
	BOP	<p>Plant Response:</p> <ul style="list-style-type: none"> 1SA-03/A-6 (COND VACUUM LOW) OAC alarm, Main Condenser Vacuum LOW <p>Crew response:</p> <p>Refer to Alarm Response Guide 1SA-03/A-6</p> <ol style="list-style-type: none"> Alarm setpoint <ul style="list-style-type: none"> 25" Hg vacuum decreasing Automatic Action <ul style="list-style-type: none"> None; however, Main Turbine trip setpoint is ≤ 21.75" Hg and FDWPT trip setpoint is ≤ 19" Hg Manual Action <ul style="list-style-type: none"> Refer to AP/1/A/1700/027 (Loss of Condenser Vacuum) <p>Note: For this scenario, condenser vacuum will not be allowed to decrease below 22" Hg. Once 1SA-03/A-6 alarms, the condenser vacuum leak rate will be decreased to ensure the turbine will not trip.</p> <p>Booth Cue: When the low vacuum statalarm actuates, FIRE TIMER 14 to reduce the leak size.</p> <p>Booth Cue: When directed to isolate the vacuum leak, FIRE TIMER 15 to remove the vacuum leak.</p>		
	SRO	<p>Refer to AP/1/A/1700/027 (Loss of Condenser Vacuum)</p> <ol style="list-style-type: none"> Entry Conditions <ul style="list-style-type: none"> Decreasing condenser vacuum as indicated by low condenser vacuum alarms Announce AP entry using the PA system IAAT both of the following apply: <ul style="list-style-type: none"> Condenser vacuum ≤ 22" Hg MODE 1 or 2 <p>THEN trip the Rx.</p> 		

Op-Test No.: <u>1</u>		Scenario No.: <u>3</u>	Event No.: <u>2</u>	Page 2 of 2
Event Description:		Condenser Vacuum Leak (C: BOP, SRO)		
Time	Position	Applicant's Actions or Behavior		
	SRO	<p>Crew response:</p> <p>AP/1/A/1700/027 (Loss of Condenser Vacuum)</p> <p>4.3 Dispatch operators to perform the following:</p> <p>___ Perform Encl 5.1 (Main Vacuum Pump Alignment) (PS)</p> <p>___ Look for vacuum leaks</p> <p>Booth Cue: Using TIME COMPRESSION, call the Control Room to notify the operator that the Main Vacuum Pumps are aligned and Enclosure 5.1 is complete.</p> <p>4.4 Ensure <u>all</u> available Main Vacuum Pumps operating (A, B, & C)</p> <p>4.5 Ensure 1V-186 is closed</p> <p>4.6 Ensure Stm to Stm Air Eject A, B, C > 255 psig</p> <p>4.7 Verify Stm Seal Hdr Press > 1.5 psig</p> <p>4.8 Ensure <u>all</u> available CCW pumps operating</p> <p>Booth Cue: Call Control Room as the NEO sent out to look for vacuum leaks and report that a leak was found on a Hotwell sight glass.</p> <p>The leak will be removed after the control room directs the NEO to isolate the sight glass.</p> <p>4.9 Verify Condensate flow \geq 2300 gpm</p> <p>4.10 WHEN condenser vacuum is stable, AND Encl 5.1 (Main Vacuum Pump Alignment) is complete, THEN EXIT this procedure</p> <p>Note: The crew may request an R&R for configuration control of the valves manipulated to stop the vacuum leak.</p>		
<p>This event is complete when the SRO reaches Step 4.10 of AP/27, or as directed by the Lead Examiner.</p>				

Op-Test No.: 1Scenario No.: 3Event No.: 3

Page 1 of 3

Event Description: **1B Main FDW Pump Active Thrust Bearing Temperature HIGH Requiring Manual Trip (C: BOP, SRO)**

Time	Position	Applicant's Actions or Behavior
		<p>Plant response:</p> <p>OAC Alarm O1A0928 FWPT 1B ACTIVE THRUST BEARING TEMP</p> <p>Crew Response:</p> <p>Refer to OAC Alarm Response for O1A0928 for HI-HI temperature > 200°F</p> <p>HI-HI: 1) If temperature cannot be maintained below HI-HI setpoint, refer to OP/1/A/1106/002 B (FDWPT Operation) to remove FDWP from service</p> <p>2) Refer to OP/1/A/1102/004 (Operation at Power)</p> <p>3) Notify Component Engineer</p> <p>Booth Cue: If contacted, respond as the Component Engineer and recommend that the 1B FDWPT be removed from service as soon as possible.</p> <p>Booth Cue: If contacted, respond as the OSM and recommend that the 1B FDWPT be removed from service as soon as possible</p> <p>The BOP should refer to OP/1/A/1106/002 B (FDWPT Operation)</p> <p>The SRO will refer to AP/1/A/1700/029 (Rapid Unit Shutdown) (see next page)</p> <p>OP/1/A/1106/002 B (FDWPT Operation) Enclosure 4.9</p> <p>Initial Conditions</p> <p>1.1 CTP DEMAND < 65% power</p> <p>1.2 Review Limits and Precautions</p> <p>Procedure</p> <p>2.1 IF this is <u>first</u> FDWPT to be shutdown:</p> <p>2.1.1 Verify 1SA-5/E-1 (FWPT/RX TRIP ALERT) NOT in alarm</p> <p>2.1.2 Position the following:</p> <p>A. Ensure 1FDW-53 (1A FDWP RECIRC CONTROL) in MAN</p> <p>B. Ensure Closed 1FDW-53 (1A FDWP RECIRC CONTROL)</p> <p>C. Ensure 1FDW-65 (1B FDWP RECIRC CONTROL) in MAN</p> <p>D. Ensure Closed 1FDW-65 (1B FDWP RECIRC CONTROL)</p> <p>2.2 IF in FDW Heatup, perform the following: (does not apply)</p> <p>2.3 Ensure running 1B FDWP AUX OIL PUMP</p> <p>2.4 IF 1A FDWP is NOT isolated for maintenance, start 1A FDWP AUX OIL PUMP</p> <p>2.5 Place 1B MAIN FDW PUMP (ICS) in HAND</p> <p>2.6 Slowly run 1B MAIN FDW PUMP demand signal to minimum</p> <p>2.7 IF required, verify 1A FDWPT picks up load by observing FDWPT suction flow instruments</p>
	SRO	
	BOP	

Op-Test No.: 1Scenario No.: 3Event No.: 3

Page 2 of 3

Event Description: **1B Main FDW Pump Active Thrust Bearing Temperature HIGH Requiring Manual Trip (C: BOP, SRO)**

Time	Position	Applicant's Actions or Behavior
	BOP	<p>Crew Response:</p> <p>OP/1/A/1106/002 B (FDWPT Operation) continued</p> <p>Procedure</p> <p>2.8 Immediately trip 1B FDWPT from FW TURB 1B TRIP/RESET switch</p> <ul style="list-style-type: none"> • Verify closed 1B FDWPT HP stop valve • Verify closed 1B FDWPT LP stop valve <p>2.9 WHEN 1B FDWPT reaches 0 speed:</p> <ul style="list-style-type: none"> • Ensure 1B FDWP TURNING GEAR MOTOR starts • Ensure 1B FDWP TURNING GEAR engages <p>2.10 Open the following:</p> <ul style="list-style-type: none"> • 1SD-125 (1B FDWPT LPSV BS Stm Trap Byp) (T-1-C25) • 1SD-126 (1B FDWPT HPSV BS Stm Trap Byp) (T-1-D25) <p>2.11 Place 1B FDWP Runback Bypass switch to BYPASS (T-1 Located on SG FDW Panel 1 SGFP)</p> <p>Booth Cue: When contacted, respond as a NEO and state that 1SD-125 and 1SD-126 are OPEN.</p> <p>Booth Cue: When contacted, respond as a NEO and state that the 1B FDWP Runback Bypass switch is in BYPASS.</p> <p>2.12 IF both FDWPTs are tripped, close 1AS-97 (does not apply)</p>
	SRO	<p>AP/1/A/1700/029 (Rapid Unit Shutdown)</p> <p>4.1 Initiate Encl 5.1 (Support Actions During Rapid Unit Shutdown) (see next page)</p> <p>4.2 Announce AP entry using the PA system</p> <p>4.3 IAAT both of the following apply:</p> <p>___ It is desired to stop power decrease</p> <p>___ CTP > 18%</p> <p>THEN perform Steps 4.4 – 4.7</p> <p>RNO: GO TO Step 4.8</p> <p>Note: Steps 4.4-4.7 will apply once Rx power has been reduced to < 65%</p> <p>4.4 Verify ICS in AUTO</p> <p>4.5 Deselect MAXIMUM RUNBACK</p> <p>4.6 Initiate OP/1/A/1102/004 (Operation at Power) power reduction Encl</p> <p>4.7 WHEN conditions permit, THEN perform <u>one</u> of the following:</p> <p>___ Depress MAXIMUM RUNBACK to resume power reduction</p> <p>___ GO TO appropriate operating procedure for continued operation</p>

Op-Test No.: 1 Scenario No.: 3 Event No.: 3 Page 3 of 3Event Description: **1B Main FDW Pump Active Thrust Bearing Temperature HIGH Requiring Manual Trip (C: BOP, SRO)**

Time	Position	Applicant's Actions or Behavior
	SRO	Crew Response: AP/1/A/1700/029 (Rapid Unit Shutdown) 4.8 Verify ICS in AUTO 4.9 Depress MAXIMUM RUNBACK 4.10 Verify <u>both</u> Main FDW pumps running 4.11 Adjust bias for first Main FDW pump desired to be shutdown until suction flow is $\approx 1 \times 10^6$ lbm/hr less than remaining Main FDW pump suction flow 4.12 WHEN core thermal power is < 65%, THEN continue
	BOP	AP/1/A/1700/029 Enclosure 5.1 (Support Actions During Rapid Unit Shutdown) 1. Notify WCC SRO to initiate Encl 5.2 (WCC SRO Support During Rapid Unit Shutdown) 2. Start the following pumps: ___ 1A FDWP SEAL INJECTION PUMP ___ 1A FDWP AUXILIARY OIL PUMP ___ 1B FDWP AUXILIARY OIL PUMP ___ 1B FDWP SEAL INJECTION PUMP 3. WHEN CTP is $\leq 80\%$, THEN continue 4. Stop 1E1 HTR DRN PUMP 5. Place 1HD-254 switch to OPEN 6. Stop 1E2 HTR DRN PUMP 7. Place 1HD-276 switch to OPEN 8. Verify Turbine-Generator shutdown is required RNO: GO TO Step 20 20. IAAT 1SSH-9 is NOT closed, AND CTP is $\leq 75\%$, THEN throttle 1SSH-9 to maintain Steam Seal Header pressure 2.5 – 4.5 psig 21. WHEN CTP $\leq 65\%$, THEN place the following in MANUAL <u>and</u> close: ___ 1FDW-53 and 1FDW-65 22. IAAT load is ≤ 550 MWe, THEN perform Steps 23 – 24 RNO: GO TO Step 25 23. Ensure 1A and 1B MSRH DRN PUMPs are stopped 24. Place 1HD-37 and 1HD-52 in DUMP 25. WHEN CTP is $\leq 60\%$, THEN ensure 1SSH-9 is closed

This event is complete when 1B Main FDW Pump has been secured, or as directed by the Lead Examiner.

Op-Test No.: 1Scenario No.: 3Event No.: 4

Page 1 of 4

Event Description: **Inadvertent ES Channel 1 Actuation (C: OATC, BOP, SRO) (TS)**

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Plant response:</p> <p>1SA-1/A-10 ES 1 Trip 1SA-16/B-1 EL CT-4 SB Bus 1 Breaker Closed 2SA-17/A-5 KEOWEE STATALARM PANEL ALARM 2SA-17/C-1 KHU 1 EMERGENCY START INITIATED 2SA-18/C-1 KHU 2 EMERGENCY START INITIATED 1SA-6/A-5, B-5, C-5, D-5, RC Pump Seal Cavity Press Hi/Low (≈ 1 min later) 1SA-6/D-7, E-5, E-6, E-7 RC Pump Seal Return Temp High Both Keowee Hydro Units Emergency Start Over time, Reactor power will begin to slowly decrease due to BWST water injecting into the core. This affect will vary depending on crew response (how quickly 1HP-24 is closed). The SRO may enter TS 3.4.9 if PZR level increases to $> 260''$</p> <p>Crew Response:</p> <p>The SRO will initiate AP/1/A/1700/042 Inadvertent ES Actuation</p> <p>4.1 Verify <u>any</u> of the following have <u>inadvertently actuated</u>: <input type="checkbox"/> Diverse HPI (not actuated) <input type="checkbox"/> ES Channel 1 <input type="checkbox"/> ES Channel 2 (not actuated)</p> <p>4.2 Perform the following on <u>all inadvertently actuated</u> system(s): <input type="checkbox"/> Ensure DIVERSE HPI BYPASS is in BYPASS (does not apply) <input type="checkbox"/> Ensure ES CH-1 is in MANUAL <input type="checkbox"/> Ensure ES CH-2 is in MANUAL (does not apply)</p> <p>4.3 Throttle HPI, as required, to maintain <u>desired</u> Pzr level</p> <p>4.4 Verify <u>any</u> of the following have <u>inadvertently actuated</u>: <input type="checkbox"/> ES Channel 5 (not actuated) <input type="checkbox"/> ES Channel 6 (not actuated)</p> <p>RNO: 1. IF ES Channel 1, ES Channel 2, <u>or</u> Diverse HPI have inadvertently actuated, AND it is desired to restore letdown, THEN initiate AP/42 Encl 5.2 (Letdown Restoration) (see page 12) 2. GO TO Step 4.10</p> <p>4.10 Close 1HP-24 and 1HP-25</p> <p>4.11 Ensure AP/42 Encl 5.1 (Required Operator Actions) is in progress (see page 11)</p>

Op-Test No.: 1Scenario No.: 3Event No.: 4

Page 2 of 4

Event Description: **Inadvertent ES Channel 1 Actuation (C: OATC, BOP, SRO) (TS)**

Time	Position	Applicant's Actions or Behavior
		<p>Crew Response:</p> <p>AP/1/A/1700/042 Inadvertent ES Actuation</p> <p>4.12 Verify <u>any</u> of the following have <u>inadvertently actuated</u>:</p> <p>___ Diverse LPI</p> <p>___ ES Channel 3</p> <p>___ ES Channel 4</p> <p>RNO: GO TO Step 4.17</p> <p>4.17 Verify the Rx is critical</p> <p>4.18 Verify ICS in Auto</p> <p>4.19 Verify control rods are outside the desired control band</p> <p>RNO: GO TO Step 4.21</p> <p>4.21 Verify <u>any</u> of the following have <u>inadvertently actuated</u>:</p> <p>___ ES Channel 1</p> <p>___ Diverse HPI</p> <p>4.22 Perform the following on <u>all</u> <u>inadvertently actuated</u> system(s):</p> <p>___ Ensure DIVERSE HPI BYPASS is in BYPASSED (does not apply)</p> <p>___ Ensure ES ELECTRICAL 1 is in MANUAL</p> <p>4.23 Dispatch an operator to perform Encl 5.3 (SSF Restoration)</p> <p>4.24 Notify SPOC to investigate <u>and</u> repair the cause of the inadvertent ES actuation, as necessary</p> <p>4.25 Initiate logging TS/SLC Entry/Exit, as applicable, in accordance with Encl 5.4 (TS/SLC Requirements)</p> <p>4.26 WHEN <u>all</u> of the following exist:</p> <p>___ Reason for inadvertent ES Channel <u>or</u> Diverse HPI/LPI actuation has need resolved</p> <p>___ ES Channel <u>or</u> Diverse HPI/LPI reset is desired</p> <p>___ OSM concurs</p> <p>THEN continue</p> <p>The SRO refers to TS 3.3.7 and enters Condition A for one inoperable digital automatic actuation logic channel inoperable (discuss with Cliff)</p> <p>APPLICABILITY: MODES 1 and 2</p> <p>CONDITION A: One or more digital automatic actuation logic channel inoperable</p> <p>REQUIRED ACTION: Place associated component(s) in ES configuration OR Declare the associated component(s) inoperable</p> <p>COMPLETION TIME: 1 hour</p>

Op-Test No.: 1Scenario No.: 3Event No.: 4

Page 3 of 4

Event Description: **Inadvertent ES Channel 1 Actuation (C: OATC, BOP, SRO) (TS)**

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew Response:</p> <p>AP/1/A/1700/042 Enclosure 5.1 Required Operator Actions</p> <ol style="list-style-type: none"> 1 Initiate announcement of AP entry using the PA system 2 Verify <u>any</u> of the following have <u>inadvertently actuated</u>: <ul style="list-style-type: none"> <input type="checkbox"/> Diverse HPI <input type="checkbox"/> ES Channel 1 <input type="checkbox"/> ES Channel 2 3 Open the following: <ul style="list-style-type: none"> <input type="checkbox"/> 1HP-20 <input type="checkbox"/> 1HP-21 4 Open the following for operating RCPs: <ul style="list-style-type: none"> <input type="checkbox"/> 1HP-228 (1A1) <input type="checkbox"/> 1HP-226 (1A2) <input type="checkbox"/> 1HP-232 (1B1) <input type="checkbox"/> 1HP-230 (1B2) 5 Verify <u>any</u> of the following have <u>inadvertently actuated</u>: <ul style="list-style-type: none"> <input type="checkbox"/> ES Channel 7 <input type="checkbox"/> ES Channel 8 <p>RNO: GO TO Step 9</p> <ol style="list-style-type: none"> 9 Perform the following: <ol style="list-style-type: none"> A. Open the following to restore RB RIAs: <ul style="list-style-type: none"> <input type="checkbox"/> 1PR-7 <input type="checkbox"/> 1PR-8 <input type="checkbox"/> 1PR-9 <input type="checkbox"/> 1PR-10 B. From the ENABLE CONTROLS screen on the RIA View Node, perform the following: <ol style="list-style-type: none"> 1. Select OFF for RB RIA sample pump 2. Start the RB RIA sample pump 10. Verify <u>any</u> of the following have <u>inadvertently actuated</u>: <ul style="list-style-type: none"> <input type="checkbox"/> Diverse HPI <input type="checkbox"/> ES Channel 1 11. Notify the following that the SSF is inoperable due to the SSF power loss <ul style="list-style-type: none"> • Unit 2, Unit3, and Security 12. EXIT this enclosure

Op-Test No.: 1Scenario No.: 3Event No.: 4

Page 4 of 4

Event Description: **Inadvertent ES Channel 1 Actuation (C: OATC, BOP, SRO) (TS)**

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew Response:</p> <p>AP/1/A/1700/042 Enclosure 5.2 Letdown Restoration</p> <ol style="list-style-type: none"> 1. Verify a CC pump operating 2. Verify letdown is isolated 3. Close 1HP-5 4. Verify it is desired to place <u>both</u> letdown coolers in service 5. Open the following: <ul style="list-style-type: none"> ___ 1HP-1 ___ 1HP-2 ___ 1HP-3 ___ 1HP-4 6. Close 1HP-6 7. Close 1HP-7 8. Verify letdown temperature < 135°F 9. Open 1HP-5 10. Adjust 1HP-7 for ≈ 20 gpm letdown 11. WHEN letdown temperature < 130°F, THEN place LETDOWN HI TEMP INTLK BYP switch in NORMAL 12. Open 1HP-6 13. Adjust 1HP-7 to control desired letdown flow 14. IAAT it is desired to <u>bleed</u> letdown flow to 1A BHUT, THEN perform the following: <ol style="list-style-type: none"> A. Open the following: <ul style="list-style-type: none"> ___ 1CS-26 ___ 1CS-41 B. Position 1HP-14 to BLEED C. Notify SRO 15. IAAT letdown <u>bleed</u> is NO longer desired, THEN position 1HP-14 to NORMAL 16. WHEN SRO approves, THEN EXIT this enclosure

This event is complete when the SRO reaches WHEN step 4.26 and has referred to TS, or as directed by the Lead Examiner.

Op-Test No.: 1 Scenario No.: 3 Event No.: 5

Page 1 of 2

Event Description: **Controlling Tave Fails HIGH (I: OATC, SRO)**

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Plant Response:</p> <ul style="list-style-type: none"> • 1SA-02/A-12 (ICS Tracking) will actuate due to neutron and feedwater cross-limits. • Controlling T_{ave} will indicate $\approx 596.2^{\circ}\text{F}$. • Actual Loop A & B Tave will decrease until operator stops transient. • RCS pressure and temperature will decrease. • Rx power will initially increase and an ICS FDWPT Runback may occur due to RCS temperature decrease <p>Crew Response:</p> <p>When the Statalarms are received, the candidates should utilize the Plant Transient Response (PTR) process to stabilize the plant.</p> <ul style="list-style-type: none"> • OATC reports to the SRO reactor power level and direction of movement. • Place the Diamond and both FDW Masters in manual and position as necessary to stabilize the plant. • The SRO should: <ul style="list-style-type: none"> ➤ Refer to AP/28 (ICS Instrument Failures) • If the crew initiates EOP enclosure 5.5 for inventory control, the actions are listed beginning on page 28 <p>Note: The ICS will remain in manual for the remainder of the scenario.</p> <p>Note: The crew may manually trip the Reactor if the failure is not immediately recognized due to the power increase. If the crew trips the Reactor, continue with the next event.</p> <p>Refer to AP/1/A/1700/028 (ICS Instrument Failures)</p> <p>4.1 Provide control bands as required (per OMP 1-18 Attachment I)</p> <ul style="list-style-type: none"> • NI Power $\pm 1\%$ not to exceed the pre-transient or allowable power • Current $T_{ave} \pm 2^{\circ}\text{F}$ • Current SG Outlet Pressure ± 10 PSIG • Delta T_c $0^{\circ}\text{F} \pm 2^{\circ}\text{F}$ <p>4.2 Initiate notification of the following:</p> <p>___ OSM to reference the following:</p> <ul style="list-style-type: none"> • OMP 1-14 (Notifications) • Emergency Plan <p>___ STA</p>

Op-Test No.: 1 Scenario No.: 3 Event No.: 5

Page 2 of 2

Event Description: **Controlling Tave Fails HIGH (I: OATC, SRO)**

Time	Position	Applicant's Actions or Behavior						
	SRO	<p>Crew Response:</p> <p>AP/1/A/1700/028 (ICS Instrument Failures)</p> <p>4.3 Verify a power transient $\geq 5\%$ has occurred.</p> <p>RNO: GO TO Step 4.5</p> <p>Note: Step 4.3 will be performed based on whether a power transient $\geq 5\%$ has or has not occurred.</p> <p>4.4 Notify Rx Engineering and discuss the need for a maneuvering plan.</p> <p>4.5 Use the following, as necessary, to determine the applicable section from table in Step 4.6:</p> <ul style="list-style-type: none"> • OAC alarm video • OAC display points • Control Board indications • SPOC assistance, as needed <p>4.6 GO TO the applicable section per the following table:</p> <table border="1"> <tr> <td>√</td><td>Section</td><td>Failure</td></tr> <tr> <td></td><td>4A</td><td>RCS Temperature</td></tr> </table>	√	Section	Failure		4A	RCS Temperature
√	Section	Failure						
	4A	RCS Temperature						
	SRO	<p>AP/1/A/1700/028 Section 4A (RCS Temperature Failure)</p> <ol style="list-style-type: none"> 1. Ensure the following in HAND: <ul style="list-style-type: none"> ___ 1A FDW MASTER ___ 1B FDW MASTER 2. Ensure DIAMOND in MANUAL. 3. Notify SPOC to perform the following: <ul style="list-style-type: none"> • Select a valid RCS Tave and Delta T_c input to ICS per AM/0/B/0326/020 (Control of Star Module Signal Selection Function) • Investigate <u>and</u> repair the failed RCS temperature instrumentation 4. PERFORM an instrumentation surveillance using applicable table in Encl 5.2 (ICS Instrument Surveillances) for the failed instrument 5. Verify instrumentation surveillance in Encl 5.2 (ICS Instrument Surveillances) was performed satisfactorily as written 6. WHEN notified by SPOC that a valid RCS Tave <u>and</u> Delta T_c input have been restored to ICS, THEN GO TO OP/1/A/1102/004 A Encl (Placing ICS Stations To AUTO) <p>Note: The Controlling Tave failure will not be repaired for this scenario.</p>						

This event is complete when the SRO reaches the WHEN step (6) in Section 4A, or as directed by the Lead Examiner.

Op-Test No.: 1 Scenario No.: 3 Event No.: 6

Page 1 of 9

Event Description: **1A Main Steam Line Break in RB (M: ALL)
1C HPI Pump Fails to start on ES**

Time	Position	Applicant's Actions or Behavior
		<p>Plant response:</p> <ul style="list-style-type: none"> • 1SA-1/A-1, B-1, C-1, D-1, RP Channel Trip • 1SA-2/D-3, RC Press High/Low • Statalarm 1SA-02/A-9 (MS PRESS HIGH/LOW) • The 1C HPI pump will fail to start on ES Channel 2 actuation • ES Channels 1-8 will actuate <p>Crew response:</p> <p>SRO will enter the EOP by directing the OATC to perform Immediate Manual Actions (or IMAs).</p> <p>OATC will perform Immediate Manual Actions</p> <ul style="list-style-type: none"> ➤ Depress REACTOR TRIP pushbutton ➤ Verify reactor power < 5% FP and decreasing ➤ Depress turbine TRIP pushbutton. ➤ Verify all turbine stop valves closed ➤ Verify RCP seal injection available <p>BOP will perform a Symptoms Check (per OMP 1-18 Attachment C)</p> <ul style="list-style-type: none"> • Reactivity Control <ul style="list-style-type: none"> ○ Power Range NIs < 5% and decreasing • ICC/Loss of Subcooling Margin (SCM) <ul style="list-style-type: none"> ○ If any SCM ≤ 0°F, perform Rule 2 • Loss of Heat Transfer (LOHT) <ul style="list-style-type: none"> ○ Loss of Main and Emergency FDW (including unsuccessful manual initiation of EFDW) • Excessive Heat Transfer (EHT) <ul style="list-style-type: none"> ○ Uncontrolled Main Steam Line(s) pressure decrease • Steam Generator Tube Rupture <ul style="list-style-type: none"> ○ CSAE off-gas alarms, process RIAs (RIA-40, 59, 60), area RIAs (RIA-16/17) <p>BOP performs Rule #5 (Main Steam Line Break) after receiving concurrence from the SRO (detail begin on page 18)</p> <p>SRO refers to "Parallel Actions" page of the Subsequent Actions Tab and transfers to the Excessive Heat Transfer Tab</p> <p>SRO will initiate EOP Enclosure 5.1 (ES Actuation) (details begin on page 21)</p> <p>The SRO will direct Excessive Heat Transfer Tab actions (see next page)</p> <p>The SRO will direct an RO to make a PA announcement and notify the OSM to reference the Emergency Plan and NSD-202</p>

Op-Test No.: 1Scenario No.: 3Event No.: 6

Page 2 of 9

Event Description: **1A Main Steam Line Break in RB (M: ALL)**
1C HPI Pump Fails to start on ES

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Crew Response:</p> <p>EOP Excessive Heat Transfer Tab (EHT)</p> <ol style="list-style-type: none"> 1. Verify <u>any</u> SG pressure < 550 psig 2. Ensure Rule 5 (Main Steam Line Break) in progress or complete 3. Place the following in HAND and decrease demand to zero on <u>all affected</u> SGs: <ul style="list-style-type: none"> • 1FDW-32 and 1FDW-35 (for 1A SG) 4. Close the following on <u>all affected</u> SGs: <ul style="list-style-type: none"> • 1FDW-372, 1MS-17, 1MS-79, 1MS-35, 1MS-82, 1MS-368 5. Verify level in <u>both</u> SGs < 96% O.R. 6. IAAT core SCM is > 0°F, THEN perform Steps 7 and 8 7. Throttle HPI per Rule 6 (HPI) (CT-5) <p>Note: HPI flow must be throttled and RCS temperature controlled to prevent a solid Pzr and subsequent operation of the PORV.</p> <ol style="list-style-type: none"> 8. Verify letdown in service <p>RNO: IF desired to restore letdown, THEN initiate Encl 5.5 (Pzr and LDST Level Control) (see page 24)</p> <ol style="list-style-type: none"> 9. Verify <u>any</u> SG has an intact secondary boundary (intact SG) 10. Open the following on <u>all intact</u> SGs <ul style="list-style-type: none"> • 1FDW-382, 1FDW-369, and 1MS-26 11. Start MDEFDWP associated with <u>all intact</u> SGs <ul style="list-style-type: none"> • 1B MD EFDWP 12. Feed and steam <u>all intact</u> SGs to stabilize RCS P/T using <u>either</u> of the following: <p>Note: RCS temperature must be controlled, HPI throttled, and letdown</p> <ul style="list-style-type: none"> • TBVs • Dispatch two operators to perform Encl 5.24 (Operation of the ADVs) 13. GO TO Step 32 32. Verify <u>any</u> of the following: <ul style="list-style-type: none"> ___ HPI has operated in the injection mode while NO RCPs were operating ___ A cooldown below 400°F at > 100°F/hr has occurred <p>RNO: GO TO Step 34</p> <ol style="list-style-type: none"> 34. Verify 1MS-24 and 1MS-33 are closed 35. Open 1AS-8 36. Close 1SSH-9

Op-Test No.: 1Scenario No.: 3Event No.: 6

Page 3 of 9

Event Description: **1A Main Steam Line Break in RB (M: ALL)**
1C HPI Pump Fails to start on ES

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Crew Response:</p> <p>EOP Excessive Heat Transfer Tab</p> <p>37. Perform the following notifications:</p> <ul style="list-style-type: none"> • Notify Chemistry to determine RCS boron concentration • Notify Secondary Chemistry to check for indications of SGTR • Notify RP to check for indications of a SGTR <p>38. IAAT RCS boron is determined to be insufficient for adequate SDM, THEN initiate Encl 5.11 (RCS Boration)</p> <p>39. IAAT <u>all</u> the following exist:</p> <ul style="list-style-type: none"> • ES Bypass Permit satisfied • <u>All</u> SCMs > 0°F • RCS pressure controllable <p>THEN bypass ES as necessary</p> <p>RNO: GO TO Step 41</p> <p>41. Verify <u>any</u> SG is dry</p> <p>42. Minimize SCM using the following methods as necessary:</p> <ul style="list-style-type: none"> <input type="checkbox"/> De-energize all Pzr heaters <input type="checkbox"/> Use Pzr spray <input type="checkbox"/> Throttle HPI to maintain Pzr level > 100" [180" acc] <input type="checkbox"/> Use PORV

Op-Test No.: 1Scenario No.: 3Event No.: 6

Page 4 of 9

Event Description: **1A Main Steam Line Break in RB (M: ALL)**
1C HPI Pump Fails to start on ES

Time	Position	Applicant's Actions or Behavior
		<p>Crew Response:</p> <p>EOP Rule 5</p> <ol style="list-style-type: none"> 1. Perform the following on <u>affected</u> headers: <ul style="list-style-type: none"> • Initiate AFIS 1A SG Digital Channels 1 and 2 • Select OFF for 1A MDEFDW Pump (CT-17) <p>Note: Overcooling must be stopped prior to violating NDT limits.</p> <p>Note: The critical task is to stop feeding the affected SG.</p> <ol style="list-style-type: none"> • Trip both Main FDW pumps • Close 1FDW-315, 1FDW-33, and 1FDW-31 <ol style="list-style-type: none"> 2. Verify 1 TD EFDW PUMP operating. <p>RNO: IF MD EFDWP for the <u>intact</u> SG is operating, THEN GO TO Step 5.</p> <ol style="list-style-type: none"> 5. Verify 1B SG is an <u>affected</u> SG. <p>RNO: GO TO Step 7</p> <ol style="list-style-type: none"> 7. WHEN overcooling is stopped, THEN adjust steaming of <u>unaffected</u> SG to maintain CETCs constant using <u>either</u> of the following: <ul style="list-style-type: none"> • TBVs • Dispatch two operators to perform Encl 5.24 (Operation of ADV's) 8. WHEN <u>all</u> of the following exist: <ul style="list-style-type: none"> ___ Core SCM >0° F ___ Rx Pwr ≤ 1% ___ Pzr Level increasing, THEN continue 9. Verify ES HPI actuated 10. Place Diverse HPI in BYPASS 11. Place ES CH 1 and ES CH 2 in MANUAL 12. Perform the following to stabilize RCS P/T: <ul style="list-style-type: none"> • Throttle HPI • Reduce 1HP-120 setpoint to > 100" (180" ACC) • Adjust steaming of <u>unaffected</u> SG (1B SG) to maintain CETCs constant 13. WHEN CETCs have stabilized, THEN resume use of T_C for RCS temperature control 14. Ensure Rule 3 (Loss of Main or Emergency FDW) is in progress or complete (see next page) 15. Ensure Rule 8 (Pressurized Thermal Shock (PTS)) is in progress or complete 16. WHEN directed by CR SRO, THEN EXIT this rule

Op-Test No.: 1Scenario No.: 3Event No.: 6

Page 5 of 9

Event Description: **1A Main Steam Line Break in RB (M: ALL)**
1C HPI Pump Fails to start on ES

Time	Position	Applicant's Actions or Behavior
		<p>Crew Response:</p> <p>EOP Rule 3</p> <ol style="list-style-type: none"> 1. Verify loss of Main FDW/EFDW is due to Turbine Building Flooding <p>RNO: GO TO Step 3</p> <ol style="list-style-type: none"> 3. IAAT NO SGs can be fed with FDW (Main/CBP/Emergency), AND <u>any</u> of the following exist: <ul style="list-style-type: none"> • RCS pressure reaches 2300 psig OR NDT limit • Pzr level reaches 375" [340" acc] THEN PERFORM Rule 4 (Initiation of HPI Forced Cooling) 4. Start <u>operable</u> EFDW pumps, as required, to feed all <u>intact</u> SGs 5. Verify <u>any</u> EFDW pump operating. (<i>1B MD is operating to 1B SG</i>) 6. GO TO Step 37 37. IAAT an EFDW valve CANNOT control in AUTO OR manual operation if EFDW valve is desired to control flow/level, THEN perform Steps 38-42 <p>RNO: GO TO step 43</p> <ol style="list-style-type: none"> 43. Verify <u>any</u> SCM $\leq 0^{\circ}\text{F}$ <p>RNO: IF overcooling or exceeding limits in Rule 7, THEN throttle EFDW as necessary.</p> <ol style="list-style-type: none"> 44. IAAT Unit 1 EFDW is in operation, THEN initiate Encl 5.9 (Extended EFDW Operation) (see next page) 45. WHEN directed by CR SRO, THEN EXIT this rule

Op-Test No.: 1 Scenario No.: 3 Event No.: 6

Page 6 of 9

Event Description: **1A Main Steam Line Break in RB (M: ALL)
1C HPI Pump Fails to start on ES**

Time	Position	Applicant's Actions or Behavior
		<p>Crew Response:</p> <p>EOP Enclosure 5.9 (Extended EFDW Operation)</p> <ol style="list-style-type: none"> 1. Monitor EFDW parameters on EFW graphic display 2. IAAT UST level is < 4', THEN GO TO Step 117 3. IAAT feeding <u>both</u> SGs with one MD EFDWP is desired, THEN perform Steps 4-7 <p>RNO: GO TO Step 8</p> <ol style="list-style-type: none"> 8. Perform the following as required to maintain UST level > 7.5' <ul style="list-style-type: none"> ___ Makeup with demin water ___ Place CST pumps in AUTO 9. IAAT <u>all</u> the following exist: <ul style="list-style-type: none"> ___ Rapid cooldown NOT in progress ___ MD EFDWP operating for each <u>available</u> SG ___ EFDW flow in <u>each</u> header < 600 gpm <p>THEN place 1 TD EFDW PUMP switch in PULL TO LOCK</p> <ol style="list-style-type: none"> 10 Verify 1 TD EFDW PUMP operating <p>RNO: GO TO Step 12</p> <div style="border: 1px solid black; padding: 10px; margin: 10px 0;"> <p style="text-align: center;">NOTE</p> <ul style="list-style-type: none"> • Loss of the condensate system for ≥ 25 minutes results in cooling down to LPI using the ADVs. If NO HWP's are operating, continuing this enclosure to restore the condensate system is a priority unless the CR SRO deems EOP activities higher priority. The 25 minute criterion is satisfied when a HWP is started and 1C-10 is 10% open. • If the condensate system is operating, the remaining guidance establishes FDW recirc, monitors and maintains UST, and transfers EFDW suction to the hotwell if required. </div> <ol style="list-style-type: none"> 12. Notify CR SRO to set priority based on the NOTE above <u>and</u> EOP activities <p>Note: The SRO should determine that restoring the secondary side of the plant is not a priority at this time and direct the RO to continue in Rule 3.</p>

Op-Test No.: 1Scenario No.: 3Event No.: 6

Page 7 of 9

Event Description: **1A Main Steam Line Break in RB (M: ALL)**
1C HPI Pump Fails to start on ES

Time	Position	Applicant's Actions or Behavior								
	OATC/BOP	<p>Crew Response:</p> <p>EOP Enclosure 5.1 (ES Actuation)</p> <p>1. Determine <u>all</u> ES channels that <u>should</u> have actuated based on <u>RCS pressure and RB pressure</u>.</p> <ul style="list-style-type: none">• RB 3 psig: Channels 1, 2, 3, 4, 5 & 6• RB 10 psig: Channels 7 & 8 <p>2. Verify <u>all</u> ES digital channels associated with actuation setpoints have actuated.</p> <p>RNO: Depress TRIP on <u>affected</u> ES logic channels that have NOT previously been actuated</p> <p>Note: The SRO may direct an RO to manually actuate ES Channel 1 which was previously placed in manual (place in AUTO)</p> <p>3. IAAT <u>additional</u> ES actuation setpoints are exceeded, THEN perform Steps 1-2.</p> <p>4. Place Diverse HPI in BYPASS</p> <p>5. Place ES CH 1 and ES CH 2 in MANUAL</p> <p>6. Verify Rule 2 in progress <u>or</u> complete.</p> <p>RNO: GO TO Step 70</p> <p>70. Open 1HP-24 and 1HP-25</p> <p>71. Ensure <u>at least two</u> HPI pumps are operating</p> <p>72. Verify 1HP-26 and 1HP-27 are open</p> <p>73. IAAT at least two HPI pumps are operating, AND HPI flow in <u>any</u> header that has NOT been <u>intentionally</u> throttled is in the Unacceptable Region of Figure 1, THEN open the following in the <u>affected</u> header:</p> <table><tr><td>√</td><td>1A Header</td><td>√</td><td>1B Header</td></tr><tr><td></td><td>1HP-410</td><td></td><td>1HP-409</td></tr></table> <p>Note: 1HP-409 may be opened to allow HPI flow in both headers due to the failure of the 1C HPI pump. This will occur if Rule 5 has not intentionally throttled HPI when the RO reaches this step.</p> <p>74. Verify <u>any</u> RCP operating</p> <p>75. Open 1HP-20 and 1HP-21</p> <p>76. IAAT <u>all</u> exist:</p> <ul style="list-style-type: none">___ Voter associated with ES channel is in OVERRIDE___ An ES channel is <u>manually</u> actuated___ Components on that channel required manipulation <p>THEN depress RESET on the required channel</p>	√	1A Header	√	1B Header		1HP-410		1HP-409
√	1A Header	√	1B Header							
	1HP-410		1HP-409							

Op-Test No.: 1 Scenario No.: 3 Event No.: 6

Page 8 of 9

Event Description: **1A Main Steam Line Break in RB (M: ALL)
1C HPI Pump Fails to start on ES**

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew Response:</p> <p>EOP Enclosure 5.1 (ES Actuation)</p> <p>77. IAAT <u>any</u> RCP is operating, AND ES Channels 5 and 6 actuate, THEN perform Steps 78-81</p> <p>78. Place ES CH 5 and ES CH 6 in MANUAL</p> <p>79. Open:</p> <p>___ 1CC-7</p> <p>___ 1CC-8</p> <p>___ 1LPSW-15</p> <p>___ 1LPSW-6</p> <p>80. Ensure <u>only one</u> CC pump operating</p> <p>81. Ensure Standby CC pump in AUTO</p> <p>82. IAAT ES Channels 3 & 4 are actuated, THEN GO TO Step 83</p> <p>83. Place Diverse LPI in BYPASS</p> <p>84. Place ES CH 3 and ES CH 4 in MANUAL</p> <div style="border: 1px solid black; padding: 5px; margin: 10px 0;"> <p style="text-align: center;">CAUTION</p> <p>LPI pump damage may occur if operated in excess of 30 minutes against shutoff head</p> </div> <p>85. IAAT <u>any</u> LPI pump is operating against shutoff head, THEN at the CR SROs discretion, stop <u>affected</u> LPI pumps</p> <p>86. IAAT RCS pressure is < LPI pump shutoff head, THEN perform Steps 87-88</p> <p>RNO: GO TO Step 89</p> <p>89. IAAT 1A <u>and</u> 1B LPI PUMPS are off/tripped, AND <u>all</u> of the following exists.....</p> <p>RNO: GO TO Step 92</p> <p>92. IAAT 1A LPI PUMP fails while operating, AND 1B LPI PUMP is operating, THEN close 1LP-17</p> <p>93. IAAT 1B LPI PUMP fails while operating, AND 1A LPI PUMP is operating, THEN close 1LP-18</p> <p>94. Start A and B OUTSIDE AIR BOOSTER FANS</p> <p>95. Notify Unit 3 to start 3A and 3B OUTSIDE AIR BOOSTER FANS</p> <p>96. Verify 1CF-1 and 1CF-2 are open</p> <p>97. Verify 1HP-410 closed</p> <p>98. Secure makeup to the LDST</p>

Op-Test No.: 1Scenario No.: 3Event No.: 6

Page 9 of 9

Event Description: **1A Main Steam Line Break in RB (M: ALL)**
1C HPI Pump Fails to start on ES

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew Response:</p> <p>EOP Enclosure 5.1 (ES Actuation)</p> <p>99. Verify <u>all</u> ES channel 1-4 components are in the ES position</p> <p>RNO: 1. IF 1HP-3 fails to close, THEN close 1HP-1 2. IF 1HP-4 fails to close, THEN close 1HP-2 3. Notify SRO to evaluate components NOT in ES position <u>and</u> initiate action to place in ES position if desired</p> <p>Note: The 1C HPI pump, 1A & 1B LPI pumps, 1HP-26, 1HP-20, and 1HP-21 will not be in its ES position.</p> <p>100. Verify Unit 2 turbine tripped</p> <p>RNO: GO TO Step 103</p> <p>103. Close 1LPSW-139</p> <p>104. Place 1LPSW-251 and 1LPSW-252 FAIL SWITCH in FAIL OPEN</p> <p>105. Start <u>all available</u> LPSW pumps</p> <p>106. Verify <u>either</u>:</p> <p>___ Three LPSW pumps operating</p> <p>___ Two LPSW pumps operating when TS only requires two operable</p> <p>107. Open 1LPSW-4 and 1LPSW-5</p> <p>108. IAAT BWST level $\leq 19'$, THEN initiate Encl 5.12 (ECCS Suction Swap to RBES)</p> <p>109. Dispatch an operator to perform Encl 5.2 (Placing RB Hydrogen Analyzers In Service) (PS)</p> <p>110. Select DECAY HEAT LOW FLOW ALARM SELECT switch to ON</p> <p>111. IAAT ES channels 5 & 6 have actuated, THEN perform Step 112</p> <p>112. Verify <u>all</u> ES channel 5 & 6 components in the ES position</p> <p>RNO: Notify SRO to evaluate components NOT in ES position <u>and</u> initiate action to place in ES position if desired</p> <p>Note: 1CC-7, 1CC-8, 1LPSW-6, and 1LPSW-15 will not be in the ES position.</p> <p>113. IAAT ES channels 7 & 8 have actuated, THEN perform Step 114</p> <p>114. Verify <u>all</u> ES channel 7 & 8 components are in the ES position</p> <p>115. Notify U2 CR SRO that SSF is inoperable due to OTS1-1 open</p> <p>116. IAAT conditions causing ES actuation have cleared, THEN initiate Encl 5.41 (ES Recovery)</p> <p>117. WHEN CR SRO approves, THEN EXIT this enclosure</p>

This event is complete when the SRO reaches Step 32 of the Excessive Heat Transfer tab of the EOP, or as directed by the Lead Examiner.

Op-Test No.: 1Scenario No.: 3Event No.: 7

Page 1 of 4

Event Description: **Loss of all SG feed requiring HPI F/C (M: ALL)**

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Plant Response:</p> <p>EFDW flow goes to zero and level in the 1B SG begins to decrease RCS pressure and temperature will begin to increase</p> <p>Crew Response:</p> <p>The SRO may direct an RO to perform a Symptoms Check An RO may attempt to start the TD EFDW pump during a Symptoms Check The SRO will direct an RO to re-perform Rule 3 (see page 27) The SRO will transfer to the Loss of Heat Transfer tab from the Excessive Heat Transfer tab Parallel Actions Page When RCS pressure increases to > 2300 psig, the SRO will direct an RO to perform Rule 4 (HPI Forced Cooling) (see page 26) The SRO will declare Emergency Dose Limits once HPI Forced Cooling is initiated</p> <p>EOP Loss of Heat Transfer tab</p> <ol style="list-style-type: none"> 1. Ensure Rule 3 (Loss of Main or Emergency FDW) is in progress or complete 2. IAAT the RCS heats to the point where <u>core</u> SCM = 0°F, THEN GO TO Step 4 3. IAAT NO SGs can be fed with FDW (Main/CBP/Emergency), AND <u>any</u> of the following exists: <input type="checkbox"/> RCS pressure reaches 2300 psig OR NDT limit <input type="checkbox"/> Pzr level reaches 375" [340" acc] THEN GO TO Step 4 4. PERFORM Rule 4 (Initiation of HPI Forced Cooling) 5. Verify <u>all</u> the following: <input type="checkbox"/> At least two HPI pumps operating <input type="checkbox"/> Acceptable HPI flow exists in <u>both</u> HPI headers per Rule 4 <input type="checkbox"/> PORV open <input type="checkbox"/> 1RC-4 open 6. GO TO HPI CD tab

This event is complete when the SRO transfers to the HPI CD tab of the EOP, or as directed by the Lead Examiner.

Op-Test No.: 1Scenario No.: 3Event No.: 7

Page 2 of 4

Event Description: **Loss of all SG feed requiring HPI F/C (M: ALL)**

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Crew Response:</p> <p>EOP HPI CD tab</p> <ol style="list-style-type: none"> IAAT BWST level is $\leq 19'$, THEN initiate Encl 5.12 (ECCS Suction Swap to RBES) IAAT <u>either</u> of the following exists: <input type="checkbox"/> LPI FLOW TRAIN A <u>plus</u> LPI FLOW TRAIN B ≥ 3400 gpm <input type="checkbox"/> <u>Only one</u> LPI header in operation with header flow ≥ 2900 gpm THEN GO TO LOCA CD tab Verify <u>all</u> of the following exists: <input type="checkbox"/> PORV open <input type="checkbox"/> 1RC-4 open <input type="checkbox"/> Two HPI trains injecting <input type="checkbox"/> CETCs $\leq 640^\circ\text{F}$ Perform the following: <input type="checkbox"/> Ensure all RBCUs in low speed <input type="checkbox"/> Open 1LPSW-18 <input type="checkbox"/> Open 1LPSW-21 <input type="checkbox"/> Open 1LPSW-24 Initiate Encl 5.35 (Containment Isolation) IAAT <u>all</u> the following exist: <input type="checkbox"/> <u>Any</u> RBS pump operating <input type="checkbox"/> RB pressure < 3 psig <input type="checkbox"/> < 24 hours into event <input type="checkbox"/> Reactor Engineering confirms Condition Zero <u>or</u> Condition One per RP/0/B/1000/018 (Core Damage Assessment) THEN stop <u>all</u> RBS pumps Start A and B Outside Air Booster Fans Notify Unit 3 to start 3A and 3B Outside Air Booster Fans Verify 1SA-2/C-8 (AFIS HEADER A INITIATED) lit Verify 1SA-2/D-8 (AFIS HEADER B INITIATED) lit <p>RNO: Select OFF for <u>both</u> digital channels on AFIS HEADER B</p> <ol style="list-style-type: none"> Verify indications of SGTR ≥ 25 gpm <p>RNO: GO TO Step 17</p>

Op-Test No.: 1Scenario No.: 3Event No.: 7

Page 3 of 4

Event Description: **Loss of all SG feed requiring HPI F/C (M: ALL)**

Time	Position	Applicant's Actions or Behavior						
		<p>Crew Response:</p> <p>EOP Rule 4 (Initiation of HPI Forced Cooling)</p> <ol style="list-style-type: none">1. Verify <u>any</u> HPI pump can be operated2. Open 1HP-24 and 1HP-253. Start <u>all available</u> HPI pumps4. Open 1HP-26 and 1HP-275. Open 1RC-46. Verify flow exists in <u>any</u> HPI header7. Perform the following: ___ Place 1RC-66 SETPOINT SELECTOR to OPEN ___ Depress 1RC-66 OPEN PERMIT pushbutton8. Verify <u>at least two</u> HPI pumps operating9. Verify flow in <u>both</u> HPI headers is in the acceptable region of Figure 1 <p>RNO: 1. IF 1A HPI header flow is unacceptable, THEN open 1HP-410 2. IF 1B HPI header flow is unacceptable, THEN open 1HP-409</p> <p>Note: 1HP-409 may have been previously opened per EOP Encl 5.1 due to the failure of the 1C HPI pump.</p> <ol style="list-style-type: none">10. Verify flow exists in <u>any</u> HPI header11. Perform the following: ___ Place 1RC-66 SETPOINT SELECTOR to OPEN ___ Depress 1RC-66 OPEN PERMIT pushbutton12. Verify > one RCP operating13. Stop all but one RCP14. IAAT the following limits are exceeded, <table><tr><th>Pump Operation</th><th>Limit</th></tr><tr><td>1 HPI pump/hdr</td><td>475 gpm (incl. seal injection for A hdr)</td></tr><tr><td>1A & 1B HPI pumps operating with 1HP-409 open</td><td>Total flow of 950 gpm (incl. seal injection)</td></tr></table> <p>THEN throttle HPI to maximize flow ≤ flow limit</p> <ol style="list-style-type: none">15. De-energize <u>all</u> Pzr heaters16. Close 1HP-517. Close TBVs, 1FDW-35, and 1FDW-44	Pump Operation	Limit	1 HPI pump/hdr	475 gpm (incl. seal injection for A hdr)	1A & 1B HPI pumps operating with 1HP-409 open	Total flow of 950 gpm (incl. seal injection)
Pump Operation	Limit							
1 HPI pump/hdr	475 gpm (incl. seal injection for A hdr)							
1A & 1B HPI pumps operating with 1HP-409 open	Total flow of 950 gpm (incl. seal injection)							

This event is complete when the SRO transfers to the HPI CD tab of the EOP, or as directed by the Lead Examiner.

Op-Test No.: 1Scenario No.: 3Event No.: 7

Page 4 of 4

Event Description: **Loss of all SG feed requiring HPI F/C (M: ALL)**

Time	Position	Applicant's Actions or Behavior
		<p>Crew Response:</p> <p>EOP Rule 3 (Loss of Main or Emergency FDW)</p> <ol style="list-style-type: none"> 1. Verify loss of Main FDW/EFDW is due to Turbine Building Flooding <p>RNO: GO TO Step 3</p> <ol style="list-style-type: none"> 3. IAAT NO SGs can be fed with FDW (Main/CBP/Emergency), AND <u>any</u> of the following exist: <ul style="list-style-type: none"> • RCS pressure reaches 2300 psig OR NDT limit • Pzr level reaches 375" [340" acc] <p>THEN PERFORM Rule 4 (Initiation of HPI Forced Cooling)</p> 4. Start <u>operable</u> EFDW pumps, as required, to feed all <u>intact</u> SGs 5. Verify <u>any</u> EFDW pump operating. (1B MD is operating to 1B SG) <p>RNO: GO TO Step 7</p> <ol style="list-style-type: none"> 7. Place the following in MANUAL and close: <ul style="list-style-type: none"> ___ 1FDW-315 and 1FDW-316 8. Verify <u>both</u> of the following: <ul style="list-style-type: none"> ___ <u>Any</u> CBP operating ___ TBVs available on an <u>intact</u> SG <p>RNO: GO TO Step 16</p> <ol style="list-style-type: none"> 16. Verify 1 TD EFDW PUMP is operable and available for manual start 17. Dispatch an operator to perform Encl 5.26 (MAN Start of TDEFDWP) 18. Verify cross-tie with Unit 2 is desired <p>RNO: 1. Dispatch an operator to open 1FDW-313 and 1FDW-314</p> <ol style="list-style-type: none"> 2. GO TO Step 20 19. Dispatch an operator to open 2FDW-313 and 2FDW-314 20. Dispatch an operator to 1FDW-313 <u>and</u> have them notify the CR when in position 21. Notify alternate unit to perform the following: <ul style="list-style-type: none"> ___ Place <u>both</u> EFDW control valves in manual and closed ___ Start their TD EFDW PUMP 22. WHEN <u>either</u> of the follow exists: <ul style="list-style-type: none"> ___ Operator is in position at 1FDW-313 ___ Unit 1 TD EFDW PUMP has been manually started <p>THEN continue</p> <p>Note: RCS pressure will increase to > 2300 psig and Rule 3 will be suspended while HPI Forced Cooling is aligned.</p>

This event is complete when the SRO transfers to the HPI CD tab of the EOP, or as directed by the Lead Examiner.

Op-Test No.: 1Scenario No.: 3Event No.: 6

Page 1 of 3

Event Description: **EOP Enclosure 5.5 (Pzr and LDST Level Control) if needed**

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew Response:</p> <p>EOP Enclosure 5.5, Pzr and LDST Level Control</p> <ol style="list-style-type: none"> Utilize the following as necessary to maintain <u>desired</u> Pzr level: <ul style="list-style-type: none"> 1A HPI Pump 1B HPI Pump 1HP-26 1HP-7 1HP-120 setpoint or valve demand 1HP-5 IAAT <u>makeup</u> to the <u>LDST</u> is desired, THEN makeup from 1A BHUT. IAAT it is desired to <u>secure makeup</u> to LDST, THEN secure makeup from 1A BHUT. IAAT it is desired to <u>bleed</u> letdown flow to 1A BHUT, THEN perform the following: <ol style="list-style-type: none"> Open: <ul style="list-style-type: none"> 1CS-26 1CS-41 Position 1HP-14 to BLEED. Notify SRO. IAAT letdown <u>bleed</u> is NO longer desired, THEN position 1HP-14 to NORMAL. IAAT 1C HPI PUMP is required, THEN perform Steps 7 – 9. <p>RNO: GO TO Step 10.</p> <ol style="list-style-type: none"> IAAT <u>LDST level</u> CANNOT be maintained, THEN perform Step 11. <p>RNO: GO TO Step 12.</p> <ol style="list-style-type: none"> Perform the following: <ul style="list-style-type: none"> Open 1HP-24 Open 1HP-25 Close 1HP-16 IAAT additional makeup flow to LDST is desired, AND 1A BLEED TRANSFER PUMP is operating, THEN dispatch an operator to close 1CS-48 (1A BHUT Recirc) (A-1-107, Unit 1 RC Bleed Transfer Pump Rm.). IAAT <u>two</u> Letdown Filters are desired, THEN perform the following: <ul style="list-style-type: none"> Open 1HP-17. Open 1HP-18

Op-Test No.: 1Scenario No.: 3Event No.: 6

Page 2 of 3

Event Description: **EOP Enclosure 5.5 (Pzr and LDST Level Control) if needed**

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew Response:</p> <p>EOP Enclosure 5.5, Pzr and LDST Level Control</p> <p>14. IAAT <u>all</u> of the following exist:</p> <ul style="list-style-type: none"> • Letdown isolated • LPSW available • Letdown restoration desired <p>THEN perform Steps 15 - 33</p> <p>RNO: GO TO Step 34</p> <p>15. Open 1CC-7 and 1CC-8</p> <p>16. Ensure only one CC pump running</p> <p>17. Place the non-running CC pump in AUTO</p> <p>18. Verify 1HP-1 and 1HP-2 are open</p> <p>19. GO TO Step 22</p> <p>22. Monitor for unexpected conditions while restoring letdown</p> <p>23. Verify <u>both</u> letdown coolers to be placed in service</p> <p>24. Open 1HP-1, 1HP-2, 1HP-3, and 1HP-4</p> <p>25. Verify <u>at least one</u> letdown cooler is aligned</p> <p>26. Close 1HP-6</p> <p>27. Close 1HP-7</p> <p>28. Verify letdown temperature < 135°F</p> <p>RNO: 1. Open 1HP-13</p> <p>2. Close 1HP-8 and 1HP-9&11</p> <p>3. IF <u>any</u> deborating IX is in service, THEN perform the following:</p> <p>___ Select 1HP-14 to NORMAL</p> <p>___ Close 1HP-16</p> <p>4. Select LETDOWN HI TEMP INTLK BYP switch to BYPASS</p> <p>29. Open 1HP-5</p> <p>30. Adjust 1HP-7 for ≈ 20 gpm letdown</p> <p>31. WHEN letdown temperature is < 130°F, THEN place LETDOWN HI TEMP INTLK BYP switch to NORMAL</p> <p>32. Open 1HP-6</p> <p>33. Adjust 1HP-7 to control desired letdown flow</p> <p>34. IAAT it is determined that letdown is unavailable due to equipment failures <u>or</u> letdown system leakage, THEN notify CR SRO to initiate AP/32 (Loss of Letdown).</p>

Op-Test No.: 1Scenario No.: 3Event No.: 6

Page 3 of 3

Event Description: **EOP Enclosure 5.5 (Pzr and LDST Level Control) if needed**

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew Response:</p> <p>EOP Enclosure 5.5, Pzr and LDST Level Control</p> <p>35. IAAT > 1 HPI pump is operating, AND additional HPI pumps are NO longer needed, THEN perform the following:</p> <p>A. Obtain SRO concurrence to reduce running HPI pumps.</p> <p>B. Secure the desired HPI pumps.</p> <p>C. Place secured HPI pump switch in AUTO, if desired.</p> <p>36. IAAT <u>all</u> the following conditions exist:</p> <ul style="list-style-type: none"> • Makeup from BWST NOT required • LDST level > 55" • <u>All</u> control rods inserted • Cooldown Plateau NOT being used <p>THEN close:</p> <ul style="list-style-type: none"> • 1HP-24 • 1HP-25 <p>37. Verify 1CS-48 (1A BHUT Recirc) has been closed to provide additional makeup flow to LDST.</p> <p>RNO: GO TO Step 39</p> <p>38. WHEN 1CS-48 is NO longer needed to provide additional makeup flow to LDST, THEN perform the following:</p> <p>A. Stop 1A BLEED TRANSFER PUMP</p> <p>B. Locally position 1CS-48 <u>one</u> turn open</p> <p>C. Close 1CS-46</p> <p>D. Start 1A BLEED TRANSFER PUMP</p> <p>E. Locally throttle 1CS-48 to obtain 90-110 psig discharge pressure</p> <p>F. Stop 1A BLEED TRANSFER PUMP</p> <p>39. Verify two Letdown Filters in service, AND <u>only one</u> Letdown filter is desired</p> <p>RNO: GO TO Step 41</p> <p>41. WHEN directed by CR SRO, THEN EXIT this enclosure</p>

These steps will be completed as directed by the SRO for RCS inventory control.

CRITICAL TASKS

CT-17, Isolate overcooling SG

CT-5, Control HPI

SAFETY: Take a Minute			
UNIT 0 (OSM)			
SSF Operable: Yes	KHU's Operable: U1 - OH, U2 - UG	LCTs Operable: 2	Fuel Handling: No
UNIT STATUS (CR SRO)			
Unit 1 Simulator		Other Units	
Mode: 1		Unit 2	Unit 3
Reactor Power: 87%		Mode: 1	Mode: 1
Gross MWE: 802		100% Power	100% Power
RCS Leakage: +.025 gpm (No WCAP action level)		EFDW Backup: Yes	EFDW Backup: Yes
RBNS Rate: .01 gpm			
Technical Specifications/SLC Items (CR SRO)			
Component/Train	OOS Date/Time	Restoration Required Date/Time	TS/SLC #
AMSAC/DSS Bypassed	Today / 06:30	7 Days	SLC 16.7.2 Condition A & B
Shift Turnover Items (CR SRO)			
Primary			
<ul style="list-style-type: none"> SASS in MANUAL for I&E testing AMSAC/DSS Bypassed for I&E testing 			
Secondary			
<ul style="list-style-type: none"> 1SSH-1, 1SSH-3, 1SD-2, 1SD-5, 1SD-140, 1SD-303, 1SD-355, 1SD-356 and 1SD-358 are closed with power supply breakers open per the Startup Procedure for SSF Overcooling Event. Turbine Valve Movement PT has just been completed and awaiting maneuvering plan to return to full power 			
Reactivity Management (CR SRO)			
RCS Boron: 30 ppmB	Gp 7 Rod Position: 80%	R2 Reactivity management controls established in the Control Room per SOMP 01-02	
Human Performance Emphasis (OSM)			
Procedure Use and Adherence			

Facility: **Oconee**Scenario No.: **4R0**Op-Test No.: **1**Examiners: _____

_____Operators: _____ **SRO**
_____ **OATC**
_____ **BOP**

Initial Conditions:

- Unit 1: Reactor Power = 3% Unit 2: 100% Unit 3: 100%

Turnover:

- SASS in Manual
- AMSAC/DSS bypassed for I&E testing
- GWD Tank B release in progress
- 1C RPS Channel Thot failed to 620°F; this input is bypassed

Event No.	Malfunction No.	Event Type*	Event Description
0a	Pre-Insert		SASS in MANUAL
0b	Pre-Insert		AMSAC/DSS bypassed
0b	Pre-Insert		1B RBCU fails to receive an ES signal
1		N: OATC, SRO	OP/1/A/1103/004, Encl 4.6 RCS Makeup from 1A and 1B BHUT
2	Override	I: BOP, SRO (TS)	1RIA-37 and 38 fails to terminate GWR (SLC) (TS)
3	Override MSS450	C: BOP, SRO (TS)	Seismic Event With 1A RBCU Rupture (TS)
4	MPS090	C: OATC SRO	1HP-120 (RC Volume Control) Fails CLOSED
5	Updater	I: BOP, SRO (TS)	1A RPS Channel RC pressure fails HIGH (TS)
6	MCR070	C: OATC, SRO	Drop Group 5 Control Rods
7	MPS020	M: ALL	1B S/G Tube Rupture
8	MPS400	M: ALL	LBLOCA

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

Op-Test No.: 1 Scenario No.: 4 Event No.: 1 Page 1 of 3Event Description: **OP/1/A/1103/004, Encl 4.6 RCS Makeup from 1A and 1B BHUT
(N: OATC, SRO)**

Time	Position	Applicant's Actions or Behavior
	OATC	<p>Crew response: The OATC should use the in progress procedure OP/1/A/1103/004 (Soluble Poison Control) Enclosure 4.6 (RCS Makeup From 1A and 1B BHUT) beginning at Step 2.1 to makeup to the RCS from 1A and 1B BHUT.</p> <p>2.1 Perform appropriate section(s) to achieve desired results:</p> <ul style="list-style-type: none"> Perform Section 3 (Makeup From 1A and 1B BHUT) for RCS Makeup <p>3.1 Determine required RCS Makeup volume by performing the following:</p> <p>3.1.1 IF desired, utilize Enclosure 4.1 (RCS Boron Change Calculation)</p> <p>3.1.2 IF two Letdown Filters are available, perform the following:</p> <p>A. Review Component Boron Log for out-of-service Letdown Filter boron</p> <p>B. Make appropriate adjustments to Makeup volumes for placing second Letdown Filter in service</p> <p>3.1.3 Perform the following:</p> <p>A. Review Component Boron Log for 1A RC Bleed Storage Header boron. {18}</p> <p>B. Make appropriate adjustments to Makeup volumes based on 1A RC Bleed Storage Header boron {18}</p> <p>3.1.4 Record required Makeup volume: <u>100</u> gallons (≈ 62 gals 1A BHUT and ≈ 38 gals DW)</p> <p>3.2 Ensure required RCS Makeup volume and source acceptable. (R.M.)</p> <p>3.3 IF two Letdown Filters are available, perform the following:</p> <ul style="list-style-type: none"> Open 1HP-17 (1A LETDOWN FILTER INLET) Open 1HP-18 (1B LETDOWN FILTER INLET) <p>3.4 Ensure open 1HP-16 (LDST MAKEUP ISOLATION).</p> <p>Note: The crew may chose to perform the makeup with 1HP-15 in AUTO or MANUAL.</p> <p>3.5 IF Makeup with 1HP-15 in "AUTO" desired, perform the following:</p> <p>3.5.1 Select "S" on 1HP-15 Controller.</p> <p>3.5.2 Enter batch size on 1HP-15 Controller. (R.M.)</p> <p>3.5.3 Place 1HP-15 Controller in "AUTO".</p> <p>3.5.4 Ensure "P" on 1HP-15 Controller.</p> <p>3.6 WHILE making up to Unit 1 LDST from 1A and 1B BHUT, monitor the following indications: (R.M.)</p> <ul style="list-style-type: none"> Appropriate ranged NIs Primary tank levels Neutron error (if applicable) CRD position (if applicable)

Op-Test No.: 1 Scenario No.: 4 Event No.: 1 Page 2 of 3
 Event Description: **OP/1/A/1103/004, Encl 4.6 RCS Makeup from 1A BHUT (N: OATC, SRO)**

Time	Position	Applicant's Actions or Behavior
	OATC	<p>Crew response:</p> <p>3.7 IF AT ANY TIME abnormal condition(s) require stopping RCS Makeup, perform the following: (RM)</p> <p>3.7.1 Stop 1A BLEED TRANSFER PUMP.</p> <p>3.7.2 IF RCS Makeup stopped due to alarm(s) OR abnormal indication(s), notify CRSRO.</p> <p>3.7.3 WHEN conditions allow RCS Makeup to continue, perform one of the following:</p> <ul style="list-style-type: none"> • Start 1A BLEED TRANSFER PUMP. • <u>Go To</u> Step 3.12 to terminate the addition. <p>3.8 Start 1A BLEED TRANSFER PUMP.</p> <p>3.9 Open 1CS-46 (1A RC BLEED XFER PUMP DISCH).</p> <p>3.10 IF increased Makeup flow required, perform the following: (AB-1, Unit 1-BTP Room).</p> <ul style="list-style-type: none"> • Throttle 1CS-48 (1A BHUT Recirc) to establish desired flow. • Ensure 90 - 125 psig on 1CS-PG-0084. <p>3.11 WHEN required volume is added, ensure stopped 1A BLEED TRANSFER PUMP.</p> <p>3.12 Close 1CS-46 (1A RC BLEED XFER PUMP DISCH). (R.M.)</p> <p>3.13 Perform one of the following: (R.M.)</p> <ul style="list-style-type: none"> • Verify correct volume added • Notify CRSRO of incorrect volume added. <p>3.14 Reset 1HP-15 Controller for Normal Operation.</p> <p>3.15 Record 1A BHUT boron in Component Boron Log for 1A RC Bleed Storage Header</p> <p>Note: The crew may chose to perform the makeup with 1HP-15 in AUTO or MANUAL.</p> <p>3.16 IF Makeup with 1HP-15 in "AUTO" desired, perform the following:</p> <p>3.16.1 Select "S" on 1HP-15 Controller.</p> <p>3.16.2 Enter batch size on 1HP-15 Controller. (R.M.)</p> <p>3.16.3 Place 1HP-15 Controller in "AUTO".</p> <p>3.16.4 Ensure "P" on 1HP-15 Controller.</p> <p>3.17 IF AT ANY TIME abnormal condition(s) require stopping RCS Makeup, perform the following: (RM)</p> <p>3.7.1 Stop 1B BLEED TRANSFER PUMP.</p> <p>3.7.2 IF RCS Makeup stopped due to alarm(s) OR abnormal indication(s), notify CRSRO.</p> <p>3.7.3 WHEN conditions allow RCS Makeup to continue, perform one of the following:</p> <ul style="list-style-type: none"> • Start 1B BLEED TRANSFER PUMP. • <u>Go To</u> Step 3.22 to terminate the addition.

Op-Test No.: 1 Scenario No.: 4 Event No.: 1 Page 3 of 3
 Event Description: **OP/1/A/1103/004, Encl 4.6 RCS Makeup from 1A BHUT (N: OATC, SRO)**

Time	Position	Applicant's Actions or Behavior
	OATC	<p>Crew response:</p> <p>3.18 Start 1B BLEED TRANSFER PUMP.</p> <p>3.19 Open 1CS-56 (1B RC BLEED XFER PUMP DISCH).</p> <p>3.20 IF increased Makeup flow required, perform the following: (AB-1, Unit 1-BTP Room).</p> <ul style="list-style-type: none"> Throttle 1CS-58 (1A BHUT Recirc) to establish desired flow. Ensure 90 - 125 psig on 1CS-PG-0085. <p>3.21 WHEN required volume is added, stop 1B BLEED TRANSFER PUMP.</p> <p>3.22 Close 1CS-56 (1B RC BLEED XFER PUMP DISCH). (R.M.)</p> <p>3.23 Perform one of the following: (R.M.)</p> <ul style="list-style-type: none"> Verify correct volume added Notify CRSRO of incorrect volume added. <p>3.24 Reset 1HP-15 Controller for Normal Operation.</p> <p>3.25 Close 1HP-16 (LDST MAKEUP ISOLATION).</p> <p>3.26 Record RCS batch volume in AutoLog.</p> <p>3.27 IF desired to remove one Letdown Filter from service, perform the following: (Continue)</p> <p>3.27.1 Verify > 10 minutes since LDST Makeup was secured. {8} (R.M.)</p> <p>3.27.2 Position one of the following:</p> <ul style="list-style-type: none"> Close 1HP-17 (1A LETDOWN FILTER INLET) Close 1HP-18 (1B LETDOWN FILTER INLET) <p>3.27.3 Record RCS boron for out-of-service Letdown Filter in Component Boron Log</p> <p>3.28 IF RCS sample for boron required, notify Chemistry to sample</p> <p>3.29 IF increased Makeup flow from 1A BHUT was required, perform the following:</p> <p>3.29.1 Start 1A BLEED TRANSFER PUMP</p> <p>3.29.2 IF discharge pressure is NOT 90-110 psig, throttle 1CS-48 to obtain 90 – 110 psig on 1CS-PG-0084</p> <p>3.29.3 Stop 1A BLEED TRANSFER PUMP</p> <p>3.30 IF increased Makeup flow from 1B BHUT was required, perform the following:</p> <p>3.30.1 Start 1B BLEED TRANSFER PUMP</p> <p>3.30.2 IF discharge pressure is NOT 90-110 psig, throttle 1CS-58 to obtain 90 – 110 psig on 1CS-PG-0085</p> <p>3.30.3 Stop 1B BLEED TRANSFER PUMP</p>

This event is complete when Step 3.24 is complete to reset 1HP-15, or as directed by the Lead Examiner.

Op-Test No.: 1 Scenario No.: 4 Event No.: 2 Page 1 of 2Event Description: **1RIA-37 and 38 fails to terminate GWR (I: BOP, SRO) (TS)**

Time	Position	Applicant's Actions or Behavior
	BOP	<p>Plant response:</p> <ul style="list-style-type: none"> 1SA-9/A-4, (GWD DISCH RADIATION INHIBIT) 1SA-8/B-9, (RM AREA MONITOR HIGH) <p>Note: SRO may invoke OMP1-18 to close 1GWD-5</p> <p>Crew response: Statalarm 1SA-9/A-4, (GWD DISCH RADIATION INHIBIT)</p> <p>2. Automatic Action</p> <p>2.1 IF high alarm is received, 1RIA-37 and/or 1RIA-38 will close valves 1GWD-4, 5, 6, and 7 and GWD-206, 207 and stop the WG Exhauster.</p> <p>3. Manual Action</p> <p>3.1 Ensure automatic action has taken place. (they have not)</p> <p>3.2 Refer to OP/1-2/A/1104/18 (Gaseous Waste Disposal System) for direction on continuing or terminating release</p>
	BOP	<p>Crew response: Statalarm 1SA-8/B-9, (RM AREA MONITOR HIGH)</p> <p>2. Automatic Action</p> <p>2.1 1RIA-37 AND/OR RIA-38 will close valves 1GWD-4, 5, 6, 7, GWD-206, 207 and stop the WG exhauster if high setpoint is received.</p> <p>2.2 AP/1/A/1700/018 (Abnormal Release of Radioactivity) will provide additional Automatic Actions if this ARG directs entry into the AP. (This ARG does not direct use of AP/18)</p> <p>3. Manual Action</p> <p>3.1 Determine radiation monitors in alarm</p> <p>3.10 IF 1RIA-37 or 1RIA-38 alarms during GWD tank release, GO TO OP/1-2/A/1104/018 (GWD System) for applicable guidance.</p>
	BOP	<p>Crew response: OP/1-2/A/1104/018 (GWD Tank Release) Complete Encl. 4.9 of OP/1-2/A/1104/018 (GWD Tank Release)</p> <p>3.30 IF 1RIA-37 or 38 High Alarm is received, perform the following:</p> <p>3.30.1 Close GWR DISCHARGE FLOW CONTROL</p> <p>3.30.2 Record maximum cpm of 1RIA-37 and 1RIA-38</p> <p>Note: 1RIA-37 maximum value is 7.2E5 cpm and 1RIA-38 maximum value is 1.11E1 cpm.</p> <p>3.30.3 IF desired to continue release, <u>Go To</u> Enclosure 4.15</p> <p>3.30.4 IF desired to terminate release. <u>Go To</u> Section 4 (GWR Termination).</p>

Op-Test No.: 1 Scenario No.: 4 Event No.: 2 Page 2 of 2Event Description: **1RIA-37 and 38 fails to terminate GWR (I: BOP, SRO) (SLC)**

Time	Position	Applicant's Actions or Behavior
	BOP	<p>Crew Response:</p> <p>Section 4. GWR Termination:</p> <p>4.1 Record "Stop GWR # _____" in Auto Log</p> <p>4.2 Complete Enclosure 4.10 (GWD Tank Sample Request) and route to RP</p> <p>4.3 IF GWD Tank 'A' released, perform the following: (does not apply)</p> <p>4.4 IF GWD Tank 'B' released, perform the following:</p> <p>4.4.1 Isolate GWD Tank 'B' as follows:</p> <ul style="list-style-type: none"> • Close GWD-99 (Tank 1B Discharge Block) • GWD-100 (Decay Tanks Discharge Header Block) • Place GWD-5 (B GWD Tank Discharge) switch in CLOSED <p>4.4.2 Check GWD Tank 'B' for accumulation of water as follows:</p> <ul style="list-style-type: none"> • Throttle open LWD-241 • Throttle open LWD-355 • Throttle open LWD-353 • Throttle open LWD-354 <p>4.4.3 WHEN no water passes through sight-glass, position the following:</p> <ul style="list-style-type: none"> • Close LWD-241 • Close LWD-355 • Close LWD-353 • Close LWD-354 <p>4.5 IF GWD Tank 'C' released, perform the following: (does not apply)</p> <p>4.6 IF GWD Tank 'D' released, perform the following: (does not apply)</p> <p>4.7 Drain GWD Filters as follows:</p> <ul style="list-style-type: none"> • Throttle LWD-242 (Waste Gas Absolute Filter Drain) • Throttle LWD-243 (Waste Gas Charcoal Filter Drain) <p>4.8 After one minute, perform the following:</p> <ul style="list-style-type: none"> • Close LWD-242 (Waste Gas Absolute Filter Drain) • Close LWD-243 (Waste Gas Charcoal Filter Drain)
	SRO	<p>SRO refers to SLC 16.11.3 and enters Condition I</p> <p>APPLICABILITY: At all times</p> <p>CONDITION I: As required by Required Action C.1 in Table 16.11.3-2</p> <p>REQUIRED ACTION: Suspend release of radioactive effluents</p> <p>COMPLETION TIME: Immediately</p>

This event is complete when GWD Tank B is isolated (GWD-5 closed) in Step 4.4, or as directed by the Lead Examiner.

Op-Test No.: 1 Scenario No.: 4 Event No.: 3 Page 1 of 2Event Description: **Seismic Event With 1A RBCU Rupture (C: BOP, SRO) (TS)**

Time	Position	Applicant's Actions or Behavior
	BOP	<p>Plant response:</p> <ul style="list-style-type: none"> • 1SA-9/B-9 (LPSW RBCU A Cooler Rupture) • Reactor Building Normal Sump level will increase <p>Crew response:</p> <p>The BOP should refer to ARG for 1SA-9/B-9</p> <ol style="list-style-type: none"> 3.1 Verify alarm condition is valid by checking RBCU 1A Inlet Flow and RBCU 1A Δ Flow. 3.2 Verify 1LPSW-18 (RBCU 1A OUTLET) open 3.3 Verify adequate LPSW flow is available; check LPSW pump operation <ol style="list-style-type: none"> 3.3.1 Verify 1LPSW-16 (1A RBCU INLET PENE) is open 3.3.2 IF 1LPSW-16 (1A RBCU INLET PENE) is NOT open, refer to TS and SLCs <p>Booth Cue: Once the BOP begins to perform ARG actions, call the Control Room (4911) as a security guard and state "We have felt a tremor and have observed no plant damage". If asked, state that the tremor was felt in the Turbine Building.</p> <ol style="list-style-type: none"> 3.4 Monitor RBNS Level for any unexplained increase 3.5 IF RBNS Level is increasing AND ES has actuated, notify Chemistry to sample the RBNS for boron concentration to determine if a cooler rupture has occurred based on sample results. 3.6 IF RBCU 1A Cooler rupture or line break is indicated, then: <ol style="list-style-type: none"> 3.6.1 Isolate the 1A RBCU Cooler as follows: <ol style="list-style-type: none"> A. Close 1LPSW-16 (1A RBCU INLET PENE) B. Close 1LPSW-18 (1A RBCU OUTLET) C. Perform TS 3.6.3 Condition C for closed containment system. D. Enter TS 3.6.5 for RBCU inoperable. E. Continue to monitor RBNS level for increase. F. IF RBNS level is still increasing, notify TSC to evaluate further isolation of 1A RBCU. 3.6.2 Refer to Technical Specifications. 3.6.3 Refer to SLC 16.9.12 (Additional LPSW and Siphon Seal Water System Operability Requirements) (Does not apply) 3.6.4 Refer to OP/1/A/1104/010 (Low Pressure Service Water). 3.6.5 Refer to OP/1/A/1104/015 (Reactor Building Cooling System).

Op-Test No.: 1 Scenario No.: 4 Event No.: 3 Page 2 of 2Event Description: **Seismic Event With 1A RBCU Rupture (C: BOP, SRO) (TS)**

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Crew Response:</p> <p>Refer To AP/0/A/1700/005, EARTHQUAKE:</p> <p>4.1 Announce AP entry using the PA system</p> <p>4.2. IAAT <u>any</u> of the following occur:</p> <ul style="list-style-type: none"> • Re-flash of SEISMIC TRIGGER (1SA-9, E-1) and/or (3SA-9, E-1) • Re-flash of computer alarm: SEISMIC RECORDER (01D0201) on Unit 1 • Aftershocks felt at ONS <u>or</u> Keowee Hydro Station <p>THEN GO TO Step 4.3</p> <p>4.3 IAAT major visible damage is observed, THEN evaluate Rx trip on <u>all affected</u> units.</p> <p>4.4 Notify Keowee operating personnel to initiate AP/0/A/2000/001 (Natural Disaster).</p> <p>Booth Cue: Respond as the Keowee Operator and state that AP/001 will be initiated.</p> <p>4.5 Notify Hydro Central.</p> <p>4.6 Dispatch operators to perform the following enclosures:</p> <ul style="list-style-type: none"> • Encl 5.1 (Outside Inspections) • Encl 5.2 (AB Inspections) • Encl 5.3 (LPSW Inspections) <p>4.7 IAAT <u>any</u> Oconee unit is shutdown, THEN dispatch an operator to perform Encl 5.4 (RB Inspections).</p> <p>4.8 Notify the OSM to reference the following:</p> <ul style="list-style-type: none"> • RP/0/B/1000/001 (Emergency Classification) • OMP 1-14 (Notifications) • Contingency Plan Information supplied from EP for seismic instruments that are out of service, as applicable <p>Booth Cue: If asked, Unit 2 will continue AP/5 actions.</p> <p>4.9 Initiate the following to monitor SF Pool temperature <u>and</u> level:</p> <ul style="list-style-type: none"> • Unit 1-2 AP/35 (Loss of SFP Cooling and/or Level) Encl 5.14 (SFP Temperature and Level Monitoring) • Unit 3 AP/35 (Loss of SFP Cooling and/or Level) Encl 5.14 (SFP Temperature and Level Monitoring) <p>4.10 Monitor Keowee lake level for indications of dam/dike leakage</p>

This event is complete when 1A RBCU has been isolated, or as directed by the Lead Examiner.

Op-Test No.: 1 Scenario No.: 4 Event No.: 4

Page 1 of 2

Event Description: **1HP-120 (RC Volume Control) Fails CLOSED (C: OATC, SRO)**

Note: Activate this event during event 3.

Time	Position	Applicant's Actions or Behavior
		<p>Plant Response:</p> <ul style="list-style-type: none"> RCS makeup flow goes to \approx 10 gpm (HPI Warming Flow) PZR level begins to decrease LDST level begins to increase Valve position <u>demand</u> for 1HP-120 begins to increase to the 100% demand value and valve position indication will indicate closed (green light) 1SA-02/ B-1, HP LETDOWN TANK LEVEL HIGH/LOW, will illuminate after several minute time delay <p>Crew Response:</p> <p>The crew may refer to ARG 1SA-02/B-1, HP LETDOWN TANK LEVEL HIGH/LOW and perform the required actions.</p> <p>3.1 Instrument Failed:</p> <p>3.1.1 Compare alternate channels to verify alarm validity:</p> <ul style="list-style-type: none"> O1A1042 LDST LEVEL 1 O1A1043 LDST LEVEL 2 <p>3.2 Verify LDST pressure does not exceed LDST level/pressure operability requirement per OP/1/A/1104/002, (HPI System).</p> <p>3.3 IF High Level alarm is received:</p> <p>3.3.1 Bleed as required by OP/1/A/1103/004 (Soluble Poison Concentration Control).</p>
	BOP	
	BOP	<p>OP/1/A/1103/004, Soluble Poison Concentration Control</p> <p>Refer to Enclosure 4.8 Reducing RCS Inventory:</p> <p>1.1 Verify HPI System operating</p> <p>1.2 Ensure open 1CS-26 (LETDOWN TO RC BHUT).</p> <p>1.3 Ensure open 1CS-41 (1A RC BHUT INLET).</p> <p>1.4 Position 1HP-14 (LDST BYPASS) to "BLEED".</p> <p>1.5 WHEN desired LDST level achieved, position 1HP-14 (LDST BYPASS) to "NORMAL".</p>
	SRO	<p>Refer to AP/1/A/1700/014, Loss of Normal Makeup and/or RCP Seal Injection</p> <p>3.1 IAAT RCP seal injection flow is lost, AND Component Cooling is lost, THEN perform the following:</p> <p>A. Trip the Rx</p> <p>B. Stop all RCPs</p> <p>C. Initiate AP/25 (SSF EOP)</p> <p>Note: The crew may initiate EOP Encl 5.5 for RCS inventory control due LDST level increase (see page 22)</p>

Op-Test No.: 1 Scenario No.: 4 Event No.: 4 Page 2 of 2Event Description: **1HP-120 (RC Volume Control) Fails CLOSED (C: OATC, SRO)**

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Crew Response: AP/1/A/1700/014, Loss of Normal Makeup and/or RCP Seal Injection 3.2 IAAT loss of suction to operating HPI pumps is indicated:</p> <ul style="list-style-type: none"> • Motor amps low or cycling • Discharge pressure low or cycling • Abnormal LDST level trend <p>THEN GO TO Step 3.3</p> <p>RNO: GO TO Step 4.7</p> <p>4.7 Announce AP entry using PA System</p> <p>4.8 Verify <u>any</u> HPI pump operating</p> <p>4.9 Verify RCP seal injection or HPI makeup line leak indicated by <u>any</u> of the following:</p> <ul style="list-style-type: none"> • Report of line leak • Abnormal LDST level decrease • 1RIA-32 (AUX BLDG GAS) • 1RIA-45 (NORM VENT GAS) • RB RIAs in alarm • Abnormal RBNS level increase • Abnormal LAWT or HAWT level increase <p>RNO: GO TO Step 4.11</p> <p>4.11 Verify RCP seal injection flow exists to <u>any</u> RCP</p> <p>4.12 Verify 1HP-120 operable in AUTO</p> <p>RNO: 1. Attempt to operate 1HP-120 in HAND 2. IF 1HP-120 fails to operate, THEN GO TO Step 4.176</p> <p>4.176 Perform the following as necessary to maintain Pzr level > 200"</p> <ul style="list-style-type: none"> • Close 1HP-6 • Throttle 1HP-7 • Throttle 1HP-26 <p>4.177 Place 1HP-120 in HAND and close</p> <p>4.178 Notify SPOC to investigate and repair 1HP-120</p> <p>4.179 WHEN 1HP-120 is repaired, THEN slowly re-establish flow through 1HP-120</p> <p>Note: 1HP-120 will remain failed for the remainder of the scenario.</p>

This event is complete when Pzr level is returned to normal band (200-230"), or as directed by the Lead Examiner.

Op-Test No.: 1 Scenario No.: 4 Event No.: 5

Page 1 of 2

Event Description: **1A RPS Channel RC pressure fails HIGH (I: BOP, SRO) (TS)**

Time	Position	Applicant's Actions or Behavior
	BOP	<p>Plant Response:</p> <ul style="list-style-type: none"> • 1SA-1/A6 (1A HI PRESS TRIP • 1SA-5/A5 (1A RPS TROUBLE) actuates • OAC alarm for 1A RPS RC PRESS DEV actuates <p>Crew Response:</p> <p>Refer to ARG for 1SA-5/A5 (1A RPS TROUBLE)</p> <p>3.1 IF Reactor trips, <u>Go To</u> EP/1/A/1800/001 (Emergency Operating Procedure).</p> <p>3.2 Refer to OP/1/A/1105/014 (Control Room Instrumentation Operation and Information).</p> <p>3.3 Initiate Work Request for I&E to investigate cause.</p> <p>Refer to ARG for 1SA-1/A-6 (1A HI PRESS TRIP</p> <p>3.1 Check instrumentation to verify high pressure</p> <p>3.2 Refer to OP/1/A/1105/014 (Control Room Instrumentation Operation and Information)</p> <p>Refer to OP/1/A/1105/014 (Control Room Instrumentation Operation and Information) Enclosure 4.7 (Removal and Restoration of RPS Channels)</p> <p>2. Initial Conditions</p> <p>2.1 Verify one of the following:</p> <p>2.1.1 A procedure requires RPS Channel to be placed in Trip or Bypass.</p> <p>2.1.2 Equipment failure requires RPS Channel to be placed in Trip or Bypass.</p> <p>2.2 Identify <u>affected</u> RPS Channel 1A (1A, 1B, 1C, 1D)</p> <p>3. Procedure</p> <p>3.1 IF affected RPS channel is NOT required per TS 3.3.1, perform one of the following: (step not applicable - it is required)</p> <p>3.2 IF affected RPS channel is required per TS 3.3.1, perform the following:</p> <p>3.2.1 Verify one of the following for the <u>remaining</u> unaffected RPS channels:</p> <p>A. Verify no RPS channels tripped AND no RPS functions are tripped.</p> <p>B. Perform the following:</p> <ul style="list-style-type: none"> • IF any RPS channel is tripped, verify RPS channel is bypassed • IF any RPS function is tripped, verify RPS functions are bypassed OR verify RPS channel is bypassed <p>3.2.2 Declare <u>affected</u> RPS Channel inoperable.</p>

Op-Test No.: 1 Scenario No.: 4 Event No.: 5

Page 2 of 2

Event Description: **1A RPS Channel RC pressure fails HIGH (I: BOP, SRO) (TS)**

Time	Position	Applicant's Actions or Behavior
	BOP	<p>Crew Response:</p> <div style="border: 1px solid black; padding: 5px; margin: 10px 0;"> <p>NOTE: For determining appropriate TS condition a tripped channel is considered inoperable.</p> </div> <p>3.2.3 Refer to TS 3.3.1 and enter appropriate TS Condition.</p> <p>3.2.4 Trip affected RPS channel using MANUAL TRIP Key as follows:</p> <p style="margin-left: 40px;">A. Obtain Key #312.</p> <p style="margin-left: 40px;">B. Place MANUAL TRIP Keyswitch in "TRIP". (Cab. 2, 4, 6, or 8)</p> <p>3.3 IF RPS Channel removed from service due to equipment failure, perform the following:</p> <ul style="list-style-type: none"> • Initiate Work Request • IF required per OMP 1-14 (notifications), perform appropriate notifications <p>3.4 WHEN notified by I&E, restore RPS channels as follows:</p> <p>Note: The 1A RPS channel will remain tripped for the remainder of the scenario.</p>
	SRO	<p>The SRO should enter TS 3.3.1 Condition A for one required channel inoperable.</p> <p>The Required Action is to place the channel in trip within 4 hours for Unit(s) with RPS digital upgrade complete</p>

This event is complete when the 1A RPS channel is placed in trip, or as directed by the Lead Examiner.

Op-Test No.: 1Scenario No.: 4Event No.: 6

Page 1 of 1

Event Description: **Drop Group 5 Control Rods (C: OATC, SRO)**

Time	Position	Applicant's Actions or Behavior
		<p>Plant Response:</p> <p>Group 6 control rods will drop into the core which will cause Reactor power to decrease</p> <p>Crew Response:</p> <p>The OATC should manually trip the reactor</p> <p>Booth Cue: FIRE TIMER 7 to initiate a SGTL in the 1B SG when the Reactor is manually tripped.</p> <p>The SRO will direct the OATC to perform Immediate Manual Actions:</p> <ul style="list-style-type: none"> • Depress REACTOR TRIP pushbutton • Verify reactor power < 5% FP and decreasing • Depress turbine TRIP pushbutton. • Verify all turbine stop valves closed • Verify RCP seal injection available <p>The SRO will direct the BOP to perform a Symptoms Check</p> <ul style="list-style-type: none"> • Reactivity Control <ul style="list-style-type: none"> ➢ Power Range NIs < 5% and decreasing • ICC/Loss of Subcooling Margin (SCM) <ul style="list-style-type: none"> ➢ If any SCM ≤ 0°F, perform Rule 2 • Loss of Heat Transfer (LOHT) <ul style="list-style-type: none"> ➢ Loss of Main and Emergency FDW (including unsuccessful manual initiation of EFDW) • Excessive Heat Transfer (EHT) <ul style="list-style-type: none"> ➢ Uncontrolled Main Steam Line(s) pressure decrease • Steam Generator Tube Rupture <ul style="list-style-type: none"> ➢ CSAE off-gas alarms, process RIAs (RIA-40, 59, 60), area RIAs (RIA-16/17) <p>Note: The BOP will report indications of a SGTL in the 1B SG which will initiate the next event.</p>

This event is complete when the reactor is tripped, or as directed by the Lead Examiner.

Op-Test No.: 1Scenario No.: 4Event No.: 7

Page 1 of 2

Event Description: **1B S/G Tube Rupture (M: ALL)**

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Plant Response:</p> <p>1SA-08/E-10 (N-16 RM PRIMARY TO SECONDARY TUBE LEAK) 1SA-08/D-10 (RM CSAE EXHAUST RADIATION HIGH)</p> <p>Crew Response:</p> <p>The SRO will transfer to the SGTR tab from Subsequent Actions Parallel Actions Page</p> <p>The SRO will declare Emergency Dose Limits in effect.</p> <p>EOP SGTR tab</p> <ol style="list-style-type: none"> 1. Verify Rx tripped 2. Maintain Pzr level 140 – 180" [175 – 215" acc] by <u>initiating</u> Encl 5.5 3. Start A and B OUTSIDE AIR BOOSTER FANS (CT-27) <p>(Note: Fans must be started prior to completing Encl 5.1)</p> <ol style="list-style-type: none"> 4. Notify Unit 3 to start 3A and 3B OUTSIDE AIR BOOSTER FANS 5. Perform the following: <ul style="list-style-type: none"> ___ Monitor RIAs 16 and 17 to identify <u>all</u> SGs with a tube rupture ___ Inform SRO of results 6. Dispatch an operator to open A and B Turbine Bldg Sump pump BKR's 7. Notify RP to survey <u>both</u> MS lines for radiation 8. GO TO Step 27 27. Secure <u>any</u> unnecessary offsite release paths (Main Vacuum Pumps, TDEFDW, Emergency Steam Air Ejector, etc.) 28. Verify Main FDW <u>or</u> EFDW controlling properly 29. Open 1HP-24 and 1HP-25 30. Secure makeup to LDST 31. Maintain <u>both</u> SG pressures < 950 psig using TBVs 32. IAAT <u>all</u> the following exists: <ul style="list-style-type: none"> ___ <u>All</u> SCMs > 0°F ___ ES Bypass Permit satisfied ___ RCS pressure controllable <p>THEN perform Step 33</p> <p>RNO: GO TO Step 34</p> <ol style="list-style-type: none"> 34. Verify <u>any</u> RCP operating 35. Maintain RCP NPSH during the reduction of SCM

Op-Test No.: 1 Scenario No.: 4 Event No.: 7 Page 2 of 2Event Description: **S/G Tube Rupture (M: ALL)**

Time	Position	Applicant's Actions or Behavior
		<p>Crew Response:</p> <p>36. Reduce <u>and</u> maintain <u>core</u> SCM at minimum using <u>any/all</u> of the following methods: (CT-7)</p> <p>Note: To satisfy this CT, SCM must be being reduced to $\approx 10 - 20$ degrees subcooling.</p> <p>___ De-energize <u>all</u> Pzr heaters</p> <p>___ Use Pzr spray</p> <p>___ Maintain Pzr level 140 – 180" [175 – 215" acc]</p> <p>37. IAAT RCS de-pressurization methods are inadequate in minimizing <u>core</u> SCM, THEN perform Steps 38-40</p> <p>RNO: GO TO Step 41</p> <p>38. Verify Pzr spray nozzle $\Delta T \geq 410^\circ\text{F}$</p> <p>39. Close 1LWD-1 and 1LWD-2</p> <p>40. Cycle PORV as necessary</p> <p>41. Verify 1SA-2/C-8 (AFIS HEADER A INITIATED) lit</p> <p>RNO: Select OFF for <u>both</u> digital channels on AFIS HEADER A</p> <p>42. Verify 1SA-2/D-8 (AFIS HEADER B INITIATED) lit</p> <p>RNO: Select OFF for <u>both</u> digital channels on AFIS HEADER B</p> <p>43. Verify RCS temperature $> 532^\circ\text{F}$</p> <p>44. Initiate a cooldown as follows:</p> <p>___ Decrease SG pressure to 835 – 845 psig using any of the following:</p> <ul style="list-style-type: none"> • TBV setpoint adjusted to 710 – 720 psig • TBVs in manual • ADVs <p>___ Maximize cooldown rate limited only by the ability to maintain Pzr level > 100" [180" acc]</p>

This event is complete when the crew begins to action to reduce SCM at Step 36 of the SGTR tab, or as directed by the Lead Examiner.

Op-Test No.: 1Scenario No.: 4Event No.: 8

Page 1 of 6

Event Description: **LBLOCA (M: ALL)**

Time	Position	Applicant's Actions or Behavior
		<p>Plant Response:</p> <p>ES Channels 1 – 8 actuate</p> <p>RCS pressure begins to rapidly decrease which will quickly reduce SCM to $\leq 0^{\circ}\text{F}$</p> <p>1B RBCU fails to receive an ES signal</p> <p>Crew Response:</p> <p>The SRO may direct an RO to perform a Symptoms Check</p> <p>The SRO will direct an RO to perform Rule 2 (Loss of SCM) once any SCM = 0°F (see page 18)</p> <p>The SRO will transfer to the LOSCM tab from the SGTR Parallel Actions Page</p> <p>The SRO may transfer to the ICC tab from the LOSCM tab Parallel Actions Page if Reactor Vessel head level indicates 0" (see next page)</p> <p>The SRO will direct an RO to perform EOP Encl 5.1 (ES Actuation) (see page 19)</p>
	SRO	<p>EOP LOSCM tab</p> <ol style="list-style-type: none"> 1. Ensure Rule 2 (Loss of SCM) is in progress or complete 2. Verify Station ASW feeding <u>any</u> SG <p>RNO: GO TO Step 4</p> <ol style="list-style-type: none"> 4. Verify LOSCM caused by excessive heat transfer <p>RNO: GO TO Step 6</p> <ol style="list-style-type: none"> 6. IAAT <u>either</u> of the following exists: <ul style="list-style-type: none"> <u> </u> LPI FLOW TRAIN A <u>plus</u> LPI FLOW TRAIN B ≥ 3400 gpm <u> </u> <u>Only one</u> LPI HEADER in operation with header flow ≥ 2900 gpm <p>THEN GO TO LOCA CD tab</p>
	SRO	<p>EOP LOCA CD tab</p> <ol style="list-style-type: none"> 1. IAAT BWST level is $\leq 19'$, THEN initiate Encl 5.12 (ECCS Suction Swap to RBES) 2. Verify ES actuated 3. GO TO Step 7 7. Perform the following: <ul style="list-style-type: none"> <u> </u> Ensure all RBCUs in low speed <u> </u> Open 1LPSW-18, 1LPSW-21, and 1LPSW-24 8. Initiate Encl 5.35 (Containment Isolation) 9. Start <u>all</u> RB Aux fans

This event is complete when Encl 5.1 actions are complete and the SRO transfers to the LOCA CD tab, or as directed by the Lead Examiner.

Op-Test No.: 1Scenario No.: 4Event No.: 8

Page 2 of 6

Event Description: **LBLOCA (M: ALL)**

Time	Position	Applicant's Actions or Behavior
	SRO	<p>Crew response:</p> <p>EOP ICC tab</p> <ol style="list-style-type: none"> IAAT CETCs > 1200°F, AND TSC is ready to provide mitigation guidance, THEN perform the following: <ol style="list-style-type: none"> Notify TSC to enter the OSAG EXIT this procedure Ensure full HPI and control per Rule 6 (HPI) IAAT RCS pressure is ≤ 550 psig, OR RB pressure is ≥ 3 psig, THEN perform Steps 4-8 Open 1LP-21 and 1LP-17 Start 1A LPI Pump Open 1LP-22 and 1LP-18 Start 1B LPI Pump Verify two LPI pumps operating IAAT <u>all</u> the following exist: <ul style="list-style-type: none"> <input type="checkbox"/> 1C LPI Pump off <input type="checkbox"/> 1C LPI Pump available <input type="checkbox"/> LPI required <input type="checkbox"/> ECCS pump suction aligned to BWST <input type="checkbox"/> 1A LPI Pump unavailable <input type="checkbox"/> 1B LPI Pump unavailable THEN perform Steps 10-13 <p>RNO: GO TO Step 14</p> <ol style="list-style-type: none"> Open 1CF-1 and 1CF-2 IAAT core SCM is ≥ 0°F, THEN GO TO LOCA CD tab

Op-Test No.: 1 Scenario No.: 4 Event No.: 8

Page 3 of 6

Event Description: **LBLOCA (M: ALL)**

Time	Position	Applicant's Actions or Behavior						
	OATC/BOP	<p>Crew response:</p> <p>EOP Rule 2 (Loss of SCM)</p> <p>1. IAAT <u>all</u> exist:</p> <p> ___ Any SCM $\leq 0^{\circ}\text{F}$</p> <p> ___ Rx power $\leq 1\%$</p> <p> ___ ≤ 2 minutes elapsed since loss of SCM</p> <p> THEN perform Steps 2 and 3</p> <p>2. Stop <u>all</u> RCPs</p> <p>3. Notify CR SRO of RCP status</p> <p>4. Verify Blackout exists</p> <p>RNO: GO TO Step 6</p> <p>6. Open 1HP-24 and 1HP-25</p> <p>7. Start <u>all available</u> HPI pumps</p> <p>8. GO TO Step 13</p> <p>13. Open 1HP-26 and 1HP-27</p> <p>14. Verify <u>at least two</u> HPI pumps are operating using two diverse indications</p> <p>15. IAAT ≥ 2 HPI pumps operating, AND HPI flow in <u>any</u> header is in the Unacceptable Region of Figure 1, THEN perform Step 16-21</p> <p>RNO: GO TO Step 17</p> <p>17. IAAT flow limits are exceeded,</p> <table><tr><th>Pump Operation</th><th>Limit</th></tr><tr><td>1 HPI pump/hdr</td><td>475 gpm (incl, seal injection for A hdr)</td></tr><tr><td>1A & 1B HPI pumps operating with 1HP-409 open</td><td>Total flow of 950 gpm (incl. seal injection)</td></tr></table> <p>THEN perform Steps 18-20</p> <p>RNO: GO TO Step 21</p> <p>18. Place Diverse HPI in BYPASS</p> <p>19. Place ES CH 1 and ES CH 2 in MANUAL</p> <p>20. Throttle HPI to maximize flow \leq flow limit</p> <p>21. Notify SRO of HPI status</p> <p>22. Verify RCS pressure > 550 psig</p> <p>RNO: Ensure ES Channels 3 <u>and</u> 4 actuated</p>	Pump Operation	Limit	1 HPI pump/hdr	475 gpm (incl, seal injection for A hdr)	1A & 1B HPI pumps operating with 1HP-409 open	Total flow of 950 gpm (incl. seal injection)
Pump Operation	Limit							
1 HPI pump/hdr	475 gpm (incl, seal injection for A hdr)							
1A & 1B HPI pumps operating with 1HP-409 open	Total flow of 950 gpm (incl. seal injection)							

Op-Test No.: 1 Scenario No.: 4 Event No.: 8

Page 4 of 6

Event Description: **LBLOCA (M: ALL)**

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew response:</p> <p>EOP Rule 2 (Loss of SCM)</p> <p>23. IAAT <u>either</u> exists:</p> <p>___ LPI FLOW TRAIN A plus LPI FLOW TRAIN B \geq 3400 gpm</p> <p>___ <u>Only one</u> LPI header in operation with header flow \geq 2900 gpm</p> <p>THEN GO TO Step 24</p> <p>24. Perform the following:</p> <p>___ Place 1FDW-315 in MANUAL and close</p> <p>___ Place 1FDW-316 in MANUAL and close</p> <p>___ Place 1FDW-35 in HAND and close</p> <p>___ Place 1FDW-44 in HAND and close</p> <p>25. Notify crew that performance of Rule 3 is NOT required due to LB LOCA</p> <p>26. WHEN directed by CR SRO, THEN EXIT this rule</p>
	OATC/BOP	<p>EOP Enclosure 5.1 (ES Actuation)</p> <p>1. Determine <u>all</u> ES channels that <u>should</u> have actuated based on <u>RCS pressure and RB pressure</u>.</p> <ul style="list-style-type: none"> • RB 3 psig: Channels 1, 2, 3, 4, 5 & 6 • RB 10 psig: Channels 7 & 8 <p>2. Verify <u>all</u> ES digital channels associated with actuation setpoints have actuated.</p> <p>3. IAAT <u>additional</u> ES actuation setpoints are exceeded, THEN perform Steps 1-2.</p> <p>4. Place Diverse HPI in BYPASS</p> <p>5. Place ES CH 1 and ES CH 2 in MANUAL</p> <p>6. Verify Rule 2 in progress <u>or</u> complete.</p> <p>7. Verify <u>any</u> RCP operating</p> <p>RNO: GO TO Step 9</p> <p>9. IAAT <u>all</u> exist:</p> <p>___ Voter associated with ES channel is in OVERRIDE</p> <p>___ An ES channel is <u>manually</u> actuated</p> <p>___ Components on that channel require manipulation</p> <p>THEN depress RESET on the required channel</p> <p>10. IAAT <u>any</u> RCP is operating, AND ES Channels 5 and 6 actuate, THEN perform Steps 11-14</p> <p>RNO: GO TO Step 15</p> <p>15. IAAT ES Channels 3 & 4 are actuated, THEN GO TO Step 16</p>

Op-Test No.: 1Scenario No.: 4Event No.: 8

Page 5 of 6

Event Description: **LBLOCA (M: ALL)**

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew response:</p> <p>EOP Enclosure 5.1 (ES Actuation)</p> <ol style="list-style-type: none"> 16. Place Diverse LPI in BYPASS 17. Perform <u>both</u>: <ul style="list-style-type: none"> • Place ES CH 3 in MANUAL • Place ES CH 4 in MANUAL 18. IAAT <u>any</u> LPI pump is operating against a shutoff head, THEN at the CR SROs discretion, stop <u>affected</u> LPI pumps 19. IAAT RCS pressure is < LPI pump shutoff head, THEN perform Steps 20 – 21 20. Open 1LP-17 and Start 1A LPI PUMP 21. Open 1LP-18 and Start 1B LPI PUMP 22. IAAT 1A <u>and</u> 1B LPI PUMPs are off / tripped, AND <u>all</u> of the following exist: <ul style="list-style-type: none"> ___ RCS pressure < LPI pump shutoff head ___ 1LP-19 closed ___ 1LP-20 closed THEN perform Steps 23 - 24 <p>RNO: GO TO Step 25</p> <ol style="list-style-type: none"> 25. IAAT 1A LPI PUMP fails while operating, AND 1B LPI PUMP is operating, THEN close 1LP-17 26. IAAT 1B LPI PUMP fails while operating, AND 1A LPI PUMP is operating, THEN close 1LP-18 27. Start A and B OUTSIDE AIR BOOSTER FANs 28. Notify Unit 3 to start 3A and 3B OUTSIDE AIR BOOSTER FANs 29. Verify 1CF-1 and 1CF-2 are open 30. Verify 1HP-410 closed 31. Secure makeup to the LDST 32. Verify <u>all</u> ES channel 1 – 4 components are in the ES position 33. Verify Unit 2 turbine tripped <p>RNO: GO TO Step 36</p> <ol style="list-style-type: none"> 36. Close 1LPSW-139 37. Place in FAIL OPEN: <ul style="list-style-type: none"> ___ 1LPSW-251 FAIL SWITCH ___ 1LPSW-252 FAIL SWITCH 38. Start <u>all available</u> LPSW pumps

Op-Test No.: 1 Scenario No.: 4 Event No.: 8 Page 6 of 6

Event Description: **LBLOCA (M: ALL)**

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew response:</p> <p>EOP Enclosure 5.1 (ES Actuation)</p> <p>39. Verify <u>either</u>:</p> <p> ___ Three LPSW pumps operating</p> <p> ___ Two LPSW pumps operating when Tech Specs only requires two operable</p> <p>40. Open 1LPSW-4 and 1LPSW-5</p> <p>41. IAAT BWST level $\leq 19'$, THEN initiate Encl 5.12 (ECCS Suction Swap to RBES)</p> <p>42. Dispatch an operator to perform Encl 5.2 (Placing RB Hydrogen Analyzers In Service) (PS)</p> <p>43. Select DECAY HEAT LOW FLOW ALARM SELECT switch to ON</p> <p>44. IAAT ES channels 5 & 6 have actuated THEN perform Step 45</p> <p>45. Verify <u>all</u> ES channel 5 & 6 components are in the ES position</p> <p>RNO: Notify SRO to evaluate components NOT in ES position <u>and</u> initiate action to place in ES position if desired</p> <p>Note: The 1B RBCU fails to receive an ES signal and will not be in the ES position.</p> <p>46. IAAT ES channels 7 & 8 have actuated, THEN perform Step 47</p> <p>47. Verify <u>all</u> ES 7 & 8 components are in the ES position</p> <p>48. Notify U2 CR SRO that SSF is inoperable due to OTS1-1 open</p> <p>49. IAAT conditions causing ES actuation have cleared, THEN initiate Encl 5.41 (ES Recovery)</p> <p>50. WHEN CR SRO approves, THEN EXIT this enclosure</p>

This event is complete when Encl 5.1 actions are complete and the SRO transfers to the LOCA CD tab, or as directed by the Lead Examiner.

Op-Test No.: 1 Scenario No.: 4 Event No.: 8

Page 1 of 2

Event Description: **EOP Enclosure 5.5 (if required)**

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew response:</p> <p>EOP Enclosure 5.5 (Pzr and LDST Level Control) (if needed)</p> <ol style="list-style-type: none"> Utilize the following as necessary to maintain <u>desired</u> Pzr level: <ul style="list-style-type: none"> 1A HPI Pump 1B HPI Pump 1HP-26 1HP-7 1HP-120 setpoint or valve demand 1HP-5 IAAT <u>makeup</u> to the <u>LDST</u> is desired, THEN makeup from 1A BHUT. IAAT it is desired to <u>secure</u> <u>makeup</u> to LDST, THEN secure makeup from 1A BHUT. IAAT it is desired to <u>bleed</u> letdown flow to 1A BHUT, THEN perform the following: <ol style="list-style-type: none"> Open: <ul style="list-style-type: none"> 1CS-26 1CS-41 Position 1HP-14 to BLEED. Notify SRO. IAAT letdown <u>bleed</u> is NO longer desired, THEN position 1HP-14 to NORMAL. IAAT 1C HPI PUMP is required, THEN perform Steps 7 – 9. <p>RNO: GO TO Step 10.</p> <ol style="list-style-type: none"> Open 1HP-24 and 1HP-25 Start 1C HPI PUMP Throttle the following as required to maintain desired Pzr level: <ul style="list-style-type: none"> 1HP-26 1HP-27 IAAT <u>LDST</u> <u>level</u> CANNOT be maintained, THEN perform Step 11. <p>RNO: GO TO Step 12.</p> <ol style="list-style-type: none"> Perform the following: <ul style="list-style-type: none"> Open 1HP-24 Open 1HP-25 Close 1HP-16

Op-Test No.: 1Scenario No.: 4Event No.: 8

Page 2 of 2

Event Description: **EOP Enclosure 5.5 (if required)**

Time	Position	Applicant's Actions or Behavior
	OATC/BOP	<p>Crew response:</p> <p>EOP Enclosure 5.5 (Pzr and LDST Level Control) (if needed)</p> <p>12. IAAT additional makeup flow to LDST is desired, AND 1A BLEED TRANSFER PUMP is operating, THEN dispatch an operator to close 1CS-48 (1A BHUT Recirc) (A-1-107, Unit 1 RC Bleed Transfer Pump Rm.).</p> <p>13. IAAT <u>two</u> Letdown Filters are desired, THEN perform the following:</p> <ul style="list-style-type: none"> • Open 1HP-17. • Open 1HP-18 <p>14. IAAT <u>all</u> of the following exist:</p> <ul style="list-style-type: none"> • Letdown isolated • LPSW available • Letdown restoration desired <p>THEN perform Steps 15 - 33</p> <p>RNO: GO TO Step 34.</p> <p>34. IAAT it is determined that letdown is unavailable due to equipment failures <u>or</u> letdown system leakage, THEN notify CR SRO to initiate AP/32 (Loss of Letdown).</p> <p>35. IAAT > 1 HPI pump is operating, AND additional HPI pumps are NO longer needed, THEN perform the following:</p> <p>A. Obtain SRO concurrence to reduce running HPI pumps.</p> <p>B. Secure the desired HPI pumps.</p> <p>C. Place secured HPI pump switch in AUTO, if desired.</p> <p>36. IAAT <u>all</u> the following conditions exist:</p> <ul style="list-style-type: none"> • Makeup from BWST NOT required • LDST level > 55" • <u>All</u> control rods inserted • Cooldown Plateau NOT being used <p>THEN close:</p> <ul style="list-style-type: none"> • 1HP-24 • 1HP-25 <p>37. Verify 1CS-48 (1A BHUT Recirc) has been closed to provide additional makeup flow to LDST.</p> <p>RNO: GO TO Step 39.</p> <p>39. Verify two Letdown Filters in service, AND <u>only one</u> Letdown filter is desired.</p> <p>RNO: GO TO Step 41.</p> <p>41. WHEN directed by CR SRO, THEN EXIT this enclosure.</p>

These actions are complete when EOP Enclosure 5.5 (Pzr and LDST Level Control) is exited.

**CRITICAL TASKS**

CT-27 Implementation of Control Room Habitability Guidance

CT-7 Minimize SCM to reduce the leak flowrate from the RCS to the secondary side of a SG

SAFETY: Take a Minute			
UNIT 0 (OSM)			
SSF Operable: Yes	KHU's Operable: U1 - OH, U2 - UG	LCTs Operable: 2	Fuel Handling: No
UNIT STATUS (CR SRO)			
Unit 1 Simulator		Other Units	
Mode: 2		Unit 2	Unit 3
Reactor Power: 3%		Mode: 1	Mode: 1
Gross MWE: 0		100% Power	100% Power
RCS Leakage: +.025 gpm (No WCAP action level)		EFDW Backup: Yes	EFDW Backup: Yes
RBNS Rate: .01 gpm			
Technical Specifications/SLC Items (CR SRO)			
Component/Train	OOS Date/Time	Restoration Required Date/Time	TS/SLC #
AMSAC/DSS Bypassed	Today / 06:30	7 Days	SLC 16.7.2 Condition A & B
Shift Turnover Items (CR SRO)			
Primary			
<ul style="list-style-type: none"> SASS in MANUAL for I&E testing AMSAC/DSS Bypassed for I&E testing 1C RPS Channel Thot is failed to 620°F – input bypassed OATC is to use the in progress procedure to perform a 100 gallon batch addition to the LDST from 1A and 1B BHUT (OP/1/A/1103/004 Encl 4.6 beginning at Step 2.1) OP/1/A/1102/002, Encl 4.7 in progress and complete up to step 3.39 GWD Tank "B" release in progress 			
Secondary			
<ul style="list-style-type: none"> 1SSH-1, 1SSH-3, 1SD-2, 1SD-5, 1SD-140, 1SD-303, 1SD-355, 1SD-356 and 1SD-358 are closed with power supply breakers open per the Startup Procedure for SSF Overcooling Event. OP/1/A/1102/001 Encl 4.7 is in progress and complete up to Step 3.39. Holding current power level while Rx Engineering is taking data. 			
Reactivity Management (CR SRO)			
RCS Boron: 1756 ppmB	Gp 7 Rod Position: 6%	R2 Reactivity Management controls established in the Control Room per SOMP 01-02	
Human Performance Emphasis (OSM)			
Procedure Use and Adherence			