ArevaEPRDCPEm Resource

From:	WILLIFORD Dennis (AREVA) [Dennis.Williford@areva.com]
Sent:	Sunday, December 04, 2011 3:07 PM
To:	Tesfaye, Getachew
Cc:	BENNETT Kathy (AREVA); CRIBB Arnie (EXTERNAL AREVA); DELANO Karen (AREVA);
	HATHCOCK Phillip (AREVA); ROMINE Judy (AREVA); RYAN Tom (AREVA); WELLS
	Russell (AREVA); PEDERSON Ronda (AREVA); WILLIAMSON Rick (AREVA)
Subject:	Revised DRAFT Response to U.S. EPR Design Certification Application RAI No. 491 (5795),
	FSAR Ch. 14 - Question 14.03.12-58
Attachments:	RAI 491 Question 14 03 12-58 Response US EPR DC - Revised DRAFT.pdf

Getachew,

Attached is a revised draft response for RAI No. 491 (5795), FSAR Ch. 14, Question 14.03.12-58 in advance of the December 10, 2011 final date.

Let me know if the staff has questions or if this can be sent as a final response.

Thanks,

Dennis Williford, P.E. U.S. EPR Design Certification Licensing Manager AREVA NP Inc. 7207 IBM Drive, Mail Code CLT 2B

Charlotte, NC 28262 Phone: 704-805-2223 Email: <u>Dennis.Williford@areva.com</u>

From: WILLIFORD Dennis (RS/NB)
Sent: Tuesday, November 08, 2011 4:31 PM
To: Getachew.Tesfaye@nrc.gov
Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB); WELLS Russell (RS/NB)
Subject: Response to U.S. EPR Design Certification Application RAI No. 491 (5795), FSAR Ch. 14, Supplement 2

Getachew,

On July 5, 2011, AREVA NP Inc. provided a schedule for a technically correct and complete response to the 1 question in RAI 491. A revised schedule was sent to NRC in Supplement 1 on September 30, 2011.

The schedule for the response to this question has been revised as provided below.

Question #	Response Date	
RAI 491 — 14.03.12-58	December 10, 2011	

Sincerely,

Dennis Williford, P.E. U.S. EPR Design Certification Licensing Manager AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B Charlotte, NC 28262 Phone: 704-805-2223 Email: Dennis.Williford@areva.com

From: WILLIFORD Dennis (RS/NB)
Sent: Friday, September 30, 2011 5:36 PM
To: <u>Getachew.Tesfaye@nrc.gov</u>
Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB); WELLS Russell (RS/NB)
Subject: Response to U.S. EPR Design Certification Application RAI No. 491 (5795), FSAR Ch. 14, Supplement 1

Getachew,

On July 5, 2011, AREVA NP Inc. provided a schedule for a technically correct and complete response to the 1 question in RAI 491. The schedule for the response to this question has been revised as provided below.

Question #	Response Date	
RAI 491 — 14.03.12-58	November 10, 2011	

Sincerely,

Dennis Williford, P.E. U.S. EPR Design Certification Licensing Manager AREVA NP Inc. 7207 IBM Drive, Mail Code CLT 2B Charlotte, NC 28262

Phone: 704-805-2223 Email: <u>Dennis.Williford@areva.com</u>

From: WILLIFORD Dennis (RS/NB)
Sent: Tuesday, July 05, 2011 10:06 AM
To: Tesfaye, Getachew
Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)
Subject: Response to U.S. EPR Design Certification Application RAI No. 491 (5795), FSAR Ch. 14

Getachew,

Attached please find AREVA NP Inc.'s response to the subject request for additional information (RAI). The attached file, "RAI 491 Response US EPR DC.pdf" provides a schedule since a technically correct and complete response to the question cannot be provided at this time.

The following table indicates the respective pages in the response document, "RAI 491 Response US EPR DC.pdf," that contain AREVA NP's response to the subject question.

Question #	Start Page	End Page
RAI 491 — 14.03.12-58	2	2

The schedule for a technically correct and complete response to this question is provided below.

Question #	Response Date	
RAI 491 — 14.03.12-58	September 30, 2011	

Sincerely,

Dennis Williford, P.E. U.S. EPR Design Certification Licensing Manager AREVA NP Inc. 7207 IBM Drive, Mail Code CLT 2B

Charlotte, NC 28262 Phone: 704-805-2223 Email: Dennis.Williford@areva.com

From: Tesfaye, Getachew [mailto:Getachew.Tesfaye@nrc.gov]
Sent: Friday, June 03, 2011 7:23 PM
To: ZZ-DL-A-USEPR-DL
Cc: Lee, Pete; Huyck, Doug; Miernicki, Michael; Colaccino, Joseph; ArevaEPRDCPEm Resource
Subject: U.S. EPR Design Certification Application RAI No. 491 (5795), FSAR Ch. 14

Attached please find the subject requests for additional information (RAI). A draft of the RAI was provided to you on May 16, 2011, and discussed with your staff on June 2, 2011. No change is made to the draft RAI as a result of that discussion except for minor editorial changes. The schedule we have established for review of your application assumes technically correct and complete responses within 30 days of receipt of RAIs. For any RAIs that cannot be answered within 30 days, it is expected that a date for receipt of this information will be provided to the staff within the 30 day period so that the staff can assess how this information will impact the published schedule.

Thanks,

Getachew Tesfaye Sr. Project Manager NRO/DNRL/NARP (301) 415-3361 Hearing Identifier:AREVA_EPR_DC_RAIsEmail Number:3603

Mail Envelope Properties (2FBE1051AEB2E748A0F98DF9EEE5A5D49B6242)

Subject:	Revised DRAFT Response to U.S. EPR Design Certification Application RAI No.
491 (5795), FSAR Ch.	14 - Question 14.03.12-58
Sent Date:	12/4/2011 3:07:11 PM
Received Date:	12/4/2011 3:07:27 PM
From:	WILLIFORD Dennis (AREVA)

Created By: Dennis.Williford@areva.com

Recipients:

"BENNETT Kathy (AREVA)" <Kathy.Bennett@areva.com> Tracking Status: None "CRIBB Arnie (EXTERNAL AREVA)" <arnie.cribb.ext@areva.com> Tracking Status: None "DELANO Karen (AREVA)" <Karen.Delano@areva.com> **Tracking Status: None** "HATHCOCK Phillip (AREVA)" < Phillip.Hathcock@areva.com> **Tracking Status: None** "ROMINE Judy (AREVA)" <Judy.Romine@areva.com> **Tracking Status: None** "RYAN Tom (AREVA)" <Tom.Ryan@areva.com> Tracking Status: None "WELLS Russell (AREVA)" <Russell.Wells@areva.com> Tracking Status: None "PEDERSON Ronda (AREVA)" <Ronda.Pederson@areva.com> Tracking Status: None "WILLIAMSON Rick (AREVA)" <Rick.Williamson@areva.com> Tracking Status: None "Tesfaye, Getachew" <Getachew.Tesfaye@nrc.gov> Tracking Status: None

Post Office:

auscharmx02.adom.ad.corp

Files	Size	Date & Time
MESSAGE	5071	12/4/2011 3:07:27 PM
RAI 491 Question 14 03 12-5	8 Response US	EPR DC - Revised DRAFT.pdf

710298

Options	
Priority:	Standard
Return Notification:	No
Reply Requested:	No
Sensitivity:	Normal
Expiration Date:	
Recipients Received:	

Response to

Request for Additional Information No. 491(5795), Revision 0 Question 14.03.12-58

6/3/2011

U. S. EPR Standard Design Certification AREVA NP Inc. Docket No. 52-020 SRP Section: 14.03.12 - Physical Security Hardware - Inspections, Tests, Analyses, and Acceptance Criteria Application Section: Tier 1, Chapter 3

QUESTIONS for Reactor Security Rulemaking and Licensing Branch (NSIR/DSP/RSRLB)



Question 14.03.12-58:

Follow-up to RAI No. 447, Question 14.03.12-57

<u>Tier 1, Chapter 3, Table 3.3-1, Security ITAAC (3 pages)</u>: Revise Table 3.3-1, Security ITAAC, descriptions of commitment, inspections, tests, and/or analyses (ITA), and acceptance criteria to conform to NUREG 0800, SRP 14.3.12 (May 2010).

<u>Regulatory Basis</u>: Subpart B of Title 10 CFR (10 CFR) 52, § 52.47, requires that information submitted for a design certification (DC) must include performance requirements and design information sufficiently detailed to permit the preparation of acceptance and inspection requirements by the NRC, and procurement specifications and construction and installation specifications by an applicant. Title 10 CFR 52.80(a) and 52.80(a)(2) requires content of applications to propose ITA and acceptance criteria that are necessary and sufficient to provide reasonable assurance the facility has been constructed and will be operated in conformity with the combined license. The ITAAC contained in the DC must be described for certification and for approval.

The Tier 1, Chapter 3, Table 3.3-1, in Revision 2 of the FSAR, which contains descriptions of security ITAAC has not been updated to conform to NUREG 0800, SRP 14.3.12 dated May, 2010, which superseded the standard security ITAAC descriptions. Table 3.3-1 was updated to in 2008. The applicant in response to RAI No. 42, Question No. 14.03.12-6, Supplement 1, dated August 7, 2008, revised Table 3.3-1 to incorporate the standard security ITAAC descriptions current at that time. Since then, the standard security ITAAC had been revised with industry input to the current descriptions contained in SRP 14.3.12 (May 2010). The recent response to RAI No. 447, Question 14.03.12-57, submitted on April 18, 2011, indicated that Table 3.1-1 will be revised to add SRP 14.3.12 (May 2010) Items 11(b) through (e). The staff requests the applicant to update the remaining portions of the Table 3.3-1 to reflect the current standard security ITAAC descriptions that are within the scope of the design certification. The security ITAAC that are not within the scope of the standard design should be identified as reserved for COL applicant implementation for completeness.

Response to Question 14.03.12-58:

U.S. EPR FSAR Tier 1, Section 3.1 will be revised to be consistent with the guidance of SRP 14.3.12, Revision 1.

The portions of SRP 14.3.12, Revision 1 that are COL applicant interface requirements are identified in U.S. EPR FSAR Tier 1, Section 3.1.2. Other deviations from SRP 14.3.12, Revision 1 are noted as follows:

 The NRC guidance in SRP 14.3.12, Revision 1, includes standard language for some design commitment statements regarding "design" or "construction" activities. This language is typically only used for those instances with the design has not been specified at the time of design certification and the design commitments and associated ITAAC represent design acceptance criteria, or "DAC." During ITAAC closure for DAC, the design is reviewed for acceptability. For the U.S. EPR, the design has been reviewed by the staff, therefore, the ITAAC for the design commitments in Tier 1 should be limited to a verification that the design commitments have been met and further review of the design is not appropriate or necessary during the ITAAC closure process. Therefore, the proposed design commitments and ITAAC for the U.S. EPR have been modified from the proposed language in the standard to remove references to design and construction activities more closely associated with DAC. AREVA believes the proposed ITAAC are consistent with the intent of SRP 14.3.12 while maintaining consistency with the general guidance for writing ITAAC.

• "The design commitment for SRP 14.3.12, ITAAC 6, "Bullet-Resisting Barriers Requirements," states:

"The external walls, doors, ceiling and floors in the main control room, central alarm station, secondary alarm station, and the last access control function for access to the protected area will be bullet resistant, to at least Underwriters Laboratories Ballistic Standard 752, 'The Standard of Safety for Bullet-Resisting Equipment,' Level 4, or National Institute of Justice Standard 0108.01, 'Ballistic Resistant Protective Materials,' Type III."

The rational for this change is provided below:

10CFR 73.55(e)(5) states:

"The reactor control room, the central alarm station and the location within which the last access control function for access to the protected area is performed, must be bullet–resisting."

The portion of SRP 14.3.12, ITAAC 6 that is related to "the last access control function for access to the protected area" is the responsibility of the COL applicant, as listed in U.S. EPR FSAR Tier 1, Section 3.1.2.

For the reasons stated above, the corresponding U.S. EPR FSAR Tier 1, Table 3.1-1, Item 1.3 design commitment states: "The external walls, doors, ceiling and floors in the main control room, central alarm station, secondary alarm station will be bullet resistant." The Underwriters Laboratories Ballistic Standard 752 is the acceptance criteria for meeting the bullet resistant commitment and is therefore listed as Acceptance Criteria, only.

 The acceptance criteria for SRP 14.3.12, ITAAC 7, "Vehicle Control Measures Requirements," make reference to NUREG/CR-6190. This NUREG is not specified in the corresponding U.S. EPR FSAR Tier 1, Table 3.1-1, Item 1.6 since the NUREG provides guidance not requirements. As noted in SRP 14.3, Section IV.4.A:

"The use of codes and standards in Tier 1 should be minimized, with exceptions granted on a case-by-case basis. Instead, the applicable requirements from the regulations, codes, or standards should be stated in Tier 1, rather than reference them."

• The portion of SRP 14.3.12, Item 11(a) that is related to "continuously manned" onsite alarm stations is not within the scope of the standard design, and is reserved for COL applicant implementation via operational programs. The portion of Item 11(a) that is related to "concurrent display" is within the scope of the standard design, and will be addressed as part of the design certification.

Response to Request for Additional Information No. 491, Question 14.03.12-58 U.S. EPR Design Certification Application

• Minor changes in SRP 14.3 (e.g., use of present tense versus future tense) have been made to be consistent with the style guide for ITAAC.

ANP-10295P, "U.S. EPR Security Design Features Technical Report," Appendix G, will also be revised to reflect the revised standard security ITAAC description that is within the scope of the design certification. This revision will be submitted to NRC via AREVA NP letter NRC:11:115.

FSAR Impact:

U.S. EPR FSAR Tier 1, Section 3.1 will be revised as described in the response and indicated on the enclosed markup.

Technical Report Impact:

ANP-10295P, "U.S. EPR Security Design Features Technical Report," Revision 3, will be revised as described in the response.

U.S. EPR Final Safety Analysis Report Markups





3.0 Nonsystem Based Design Descriptions and ITAAC

3.1 Security

The physical security program provides physical features to detect, delay, assist response to, and defend against the design basis threat (DBT) for radiological sabotage.

3.1.1 Design Features

- 1.1 Vital equipment is located only within a vital area.
- 1.2 Isolation zones and exterior areas within the protected area are provided with illumination to permit <u>assessment in the isolation zones and observation of activities within exterior</u> <u>areas of the protected area.</u> observation of abnormal presence or activity of persons or vehicles.
- 1.3 The external walls, doors, ceiling and floors in the main control room (MCR), and central alarm station, and secondary alarm station are bullet resistant to at least a Underwriter's Laboratories Inc. (UL) Ballistic Standard 752, "The Standard of Safety for Bullet-Resisting Equipment," Level 4.
- 1.4The central and secondary alarm stations are designed, equipped and constructed such
that no single act, in accordance with the DBT of radiological sabotage, can
simultaneously remove the ability of both the central and secondary alarm stations to (1)
detect and assess alarms, (2) initiate and coordinate an adequate response to alarms, (3)
summon offsite assistance, and (4) provide effective command and control.
- 1.5Both the central and secondary alarm stations are constructed, located, protected, and
equipped to the standards for the central alarm station (alarm stations need not be
identical in design but shall be equal and redundant, capable of performing all functions
required of alarm stations).
- <u>1.41.6</u> The vehicle barrier system is <u>designed</u>, <u>installed</u>, <u>and</u> located at the necessary stand-off distance to protect against the DBT vehicle bombs.
- 1.7The perimeter intrusion detection system provides detection of designed to detectpenetration or attempted penetration of the protected area perimeter barrier beforecompleted penetration of the barrier, and for subsequent alarms to annunciateconcurrently in at least two onsite alarm stations (central and secondary alarm stations).
- 1.5Unoccupied vital areas are locked and alarmed with activated designed
equipped with
locking devices and intrusion detection devices systems that annunciate in the C
central and S
secondary A
alarm S
stations upon intrusion into a vital area.
- 1.9The perimeter assessment equipment are designed to provides video image recording
with real-time and playback capability that can provides ability to assessment of detected
activities before and after each alarm annunciation at the protected area perimeter barrier.

Next File

All changes are in response to RAI 491, Question 14.03.12-58 U.S. EPR FINAL SAFETY ANALYSIS REPORT



<u>1.10</u>	The intrusion detection and assessment equipment at the protected area perimeter are designed to-remain operable from an uninterruptible power supply in the event of the loss of normal power.
<u>1.61.11</u>	Intrusion detection equipment and video assessment equipment annunciates and displays concurrently in at least two onsite alarms stations (central and secondary alarm <u>stations).Security alarm annunciation occurs in the central alarm station and in at least</u> one other continuously manned station not necessarily onsite.
<u>1.12</u>	<u>1.1312</u> <u>The Cc</u> entral and secondary alarm stations are located inside the protected area and are designed so that the interiors of both alarm stations are not visible from the perimeter of the protected area.
<u>1.13</u>	<u>1.1413</u> The alarm system does not allow the status of a detection point, locking mechanism or access control device to be changed without the knowledge and concurrence of the alarm station operator in the other alarm station.
<u>1.14</u>	Intrusion detection and assessment systems are designed to provide visual display and audible annunciation of alarms in both the central and secondary alarm stations.
1.7 1.15	The <u>Ss</u> econdary security power supply system for alarm annunciator equipment and non-portable communications equipment is located within a vital area.
1.16	Nonportable communications equipment in the central and secondary alarm stations remain operable from an independent power source in the event of loss of normal power.
1.8 1.17	Security alarm devices, including transmission lines to annunciators, are tamper- indicating and self-checking; (e.g. an automatic indication is provided when failure of the alarm system or a component occurs or when on standby power), and alarm annunciation indicates the type of alarm; (e.g., intrusion alarms, emergency exit alarm, etc.) and location.
1.9 1.18	<u>The security alarm system will Intrusion detection systems recording equipment records</u> <u>each-onsite security</u> alarm annunciation including the location of the alarm, any-false alarm, alarm check, and tamper indication by recording and the alarm type of alarm, <u>location, alarm</u> circuit, location, date, and time.
1.10 1.19	Emergency exits through the vital area boundaries are alarmed with intrusion detection devices and secured by locking devices that allow prompt egress during an emergency.
<u>1.11</u> 1.20	<u>The Cc</u> entral and secondary alarm stations have conventional (land line) telephone service and other communication capabilities with the control room and local law enforcement authorities.
1.12 1.21	<u>The C</u> central and secondary alarm stations are capable of continuous communication with <u>on-duty</u> security <u>force</u> personnel.
3.1.2	Interface Requirements
1.1	Access to vital equipment requires passage through at least two physical barriers.

All changes are in response to RAI 491, Question 14.03.12-58 U.S. EPR FINAL SAFETY ANALYSIS REPORT

1.2	Physical barriers for the protected area perimeter are not part of vital area barriers.	
1.3	Penetrations through the protected area barrier are secured and monitored.	
1.4	Unattended openings that intersect a security boundary, such as underground pathways, are protected by a physical barrier and monitored by intrusion detection equipment or provided surveillance at a frequency sufficient to detect exploitation.	
1.5	Isolation zones exist in outdoor areas adjacent to the physical barrier at the perimeter of the protected area <u>and are designed that allow 20 feet of observation that allow 20 feet of observation and assessment</u> on either side of the barrier.	
<u>1.6</u>	Areas Wwhere permanent buildings do not allow sufficient observation distance between the intrusion detection system a 20 foot observation distance on the inside of and the protected area barrier (e.g., the building walls are immediately adjacent to, or an integral part of, the protected area barrier) are monitored with intrusion detection and assessment equipment that is designed to detects the attempted or actual penetration of the protected area perimeter barrier before completed penetration of the barrier and assessment of detected activities.	
<u>1.7</u>	Isolation zones are monitored with intrusion detection and assessment equipment that is capable of providing detection and assessment of activities within the isolation zone.	
<u>1.4</u> 1.8	Deleted.Intrusion detection system can detect penetration or attempted penetration of the protected area barrier.	
1.5 1.9	The external walls, doors, ceiling and floors in the last access control function for access to the protected area are bullet resistant to at least a UL <u>Ballistic Standard 752, "The</u> <u>Standard of Safety for Bullet-Resisting Equipment," ILevel 4 round.</u>	
1.6 1.10	Access control points are established and designed to control personnel and vehicle access into the protected area.	
1.7 1.11	Access control points are established and designed with equipment for the detection of to detect firearms, explosives, and incendiary devices, or other items which can be used to commit radiological sabotage at the protected area personnel access points.	
<u>1.8</u> 1.12	A security access control system with <u>a</u> numbered <u>photo identification picture</u> -badges <u>system</u> is <u>designed and</u> -installed for use by individuals who are authorized access to protected areas <u>and vital areas</u> without escort.	
1.9 1.13	Emergency exits through the protected area perimeter are alarmed with intrusion detection devices and secured by locking devices that allow prompt egress during an emergency.	
3.1.3	Inspections, Tests, Analyses, and Acceptance Criteria	

Certain documentation of security features will be SGI, which has restricted availability under 10 CFR 73.21. The phrase "a report exists and concludes" is used in security-related ITAAC to indicate that a non-SGI executive summary with the applicable conclusions exists and will be part of the ITAAC closure. This <u>non-SGI</u>



executive summary is supported by a separate SGI document which contains the salient details leading to the conclusions of the <u>non-SGI</u> executive summary.

Table 3.1-1 lists the security ITAAC.



		Commitment	Inspections, Tests, Analyses	Acceptance Criteria
1	.1	Vital equipment is located only within a vital area.	Inspections <u>of vital</u> <u>equipment</u> will be performed. to confirm that vital equipment is located within a vital area.	A report exists and concludes that vVital equipment is located only within a vital area.
1	.2	Isolation zones and exterior areas within the protected area are provided with illumination to permit <u>assessment in the isolation</u> <u>zones and observation of</u> <u>activities within exterior</u> <u>areas of the protected</u> <u>area.observation of abnormal</u> <u>presence or activity of</u> <u>persons or vehicles.</u>	Initial ation zones and exteriorTests, Linspections, or aas within the protectedcombination of tests andas within the protectedinspections of thea are provided withinspections of themination to permitillumination in the isolationessment in the isolationzones and external areas ofwithin exteriorwithin the protected area willas of the protectedsufficient illumination toas of the protectedsufficient illumination toas of the protectedsufficient illumination tosence or activity ofpermit observation.	
1	3	The external walls, doors, ceiling and floors in the main control room (MCR), and central alarm station, and <u>secondary alarm station</u> are bullet resistant. to at least a <u>Underwriter's Laboratories</u> Inc. (UL) <u>Ballistie Standard</u> <u>752, "The Standard of Safety</u> for Bullet-Resisting <u>Equipment," Level 4.level 4</u> round.	Type test, analysis, or a combination of type test and analysis will be performed for of the external walls, doors, ceilings, and floors, and any windows in the walls in the MCR, and central alarm station, and secondary alarm station will be performed, to ensure they are bullet resistant to at least a UL level 4 round.	A report exists and concludes that the external walls, doors, ceilings and floors in the MCR, and central alarm station, and secondary alarm station are bullet resistant to at least a-UL Ballistic Standard 752, "The Standard of Safety for Bullet-Resisting Equipment," Level 4. round.



	Commitment	Inspections, Tests, Analyses	Acceptance Criteria
1. <u>4</u> 15	<u>The Cc</u> entral and secondary alarm stations are designed, equipped and constructed such that no single act, in accordance with the design basis threat <u>DBT</u> of radiological sabotage, can simultaneously remove the ability of both the central and secondary alarm stations to (1) detect and assess alarms, (2) initiate and coordinate an adequate response to alarms, (3) summon offsite assistance, and (4) provide effective command and control.	Tests, inspections, or a combination of tests and inspections of the central and secondary alarm stations will be performed.	A report exists and concludes that for the as-built <u>The</u> central and secondary alarm stations <u>are designed</u> , <u>equipped</u> , <u>and constructed</u> <u>such that</u> no single act, in accordance with the <u>design basis threat DBT</u> of radiological sabotage, can simultaneously remove the ability of both the central and secondary alarm stations to (1) detect and assess alarms, (2) initiate and coordinate an adequate response to alarms, (3) summon offsite assistance, and (4) provide effective command and control.
1. <u>5</u> 16	Both the central and secondary alarm stations are constructed, located, protected, and equipped to the standards for the central alarm station (alarm stations need not be identical in design but each shall be <u>equal and redundant, capable</u> of performing all functions required of alarm stations).	Tests, inspections, or a combination of tests and inspections of the central and secondary alarm stations will be performed <u>to verify that</u> they are capable of performing all functions required of alarm stations.	A report exists and concludes that t <u>T</u> he central and secondary alarm stations are located, constructed, protected, and equipped to the standards of the central alarm station and are <u>functionally redundant</u> capable of performing all functions required of alarm stations. (Stations need not be identical in design.)
1. <u>6</u> 4	The vehicle barrier system is designed, installed, and located at the necessary stand-off distance to protect against the DBT vehicle bombs.	Type test, iInspections, analysis_ or a combination of type tests, inspections and analysis_of the vehicle barrier system will be performed_ for the vehicle barrier system to ensure it will protect against the DBT vehicle bombs based upon the stand-off distance for the system.	A report exists and concludes that t <u>T</u> he vehicle barrier system will protect against the DBT vehicle bombs based upon the stand-off distance for the system.



	Commitment	Inspections, Tests, Analyses	Acceptance Criteria
<u>1.7</u>	The perimeter intrusion detection system provides designed to detection of penetration or attempted penetration of the protected area perimeter barrier before completed penetration of the barrier, and for subsequent alarms to annunciate concurrently in at least two onsite alarm stations (central and secondary alarm stations).	Tests, inspections, or a combination of tests and inspections of the intrusion detection system will be performed.	The intrusion detection system can detect penetration or attempted penetration of the protected area perimeter barrier before completed penetration of the barrier, and subsequent alarms annunciate concurrently in at least two onsite alarms stations (central and secondary alarm stations).
1. <u>8</u> 5	Unoccupied vital areas are locked and alarmed with activated <u>designed</u> cquipped with locking devices and intrusion detection <u>devices</u> systems-that annunciate in the <u>C</u> central and <u>S</u> secondary <u>A</u> alarm <u>S</u> stations-upon intrusion into a vital area.	A t <u>T</u> est <u>s</u> , inspection <u>s</u> , or a combination of tests and inspections <u>of unoccupied</u> <u>vital area intrusion detection</u> <u>equipment and locking</u> <u>devices</u> will be performed <u>-to</u> <u>verify that unoccupied vital</u> <u>areas are locked and that</u> <u>intrusion will be detected and</u> <u>annunciated in both the</u> <u>Central Alarm Station and</u> <u>Secondary Alarm Station.</u>	A report exists and concludes that uUnoccupied vital areas are locked <u>and alarmed</u> and intrusion is detected and annunciated in both the central alarm station and secondary alarm station <u>s</u> .
<u>1.9</u>	The perimeter assessment equipment are designed to provides video image recording with real-time and playback capability that can provides ability to assessment of detected activities before and after each alarm annunciation at the protected area perimeter barrier.	Tests, inspections, or a combination of tests and inspections of the video assessment equipment will be performed.	The perimeter assessment equipment is capable of real- time and playback video image recording that provides ability to assessment of detected activities before and after each alarm annunciation at the protected area perimeter barrier.
<u>1.10</u>	The intrusion detection and assessment equipment at the protected area perimeter are designed to-remain operable from an uninterruptible power supply in the event of the loss of normal power.	Tests, inspections, or a combination of tests and inspections of the uninterruptible power supply will be performed.	Intrusion detection and assessment equipment at the protected area perimeter remains operable from an uninterruptible power supply in the event of the loss of normal power.



	Commitment	Inspections, Tests, Analyses	Acceptance Criteria
1. <u>11</u> 6	Intrusion detection equipment and video assessment equipment annunciates and displays concurrently in at least two onsite alarms stations (central and secondary alarm stations).Security alarm annunciation occurs in the central alarm station and in at least one other continuously manned station not necessarily onsite.	Test <u>s</u> , inspection <u>s</u> , or a combination of tests and inspections of <u>intrusion</u> <u>detection equipment and</u> <u>video assessment equipment</u> the installed systems will be performed <u>.</u> to ensure that security alarms annunciate in the central alarm station and in at least one other continuously manned station.	Intrusion detection equipment and video assessment equipment annunciate and display concurrently in at least two onsite alarm stations (central and secondary alarm stations). A report exists and concludes that security alarms annunciate in the central alarm station and in at least one other continuously manned station.
1.1 <u>2</u> 3	Central and secondary alarm stations are located inside the protected area and are designed so that the interiors of both alarm stations are not visible from the perimeter of the protected area.	The central and secondary alarm station locations will be inspected. <u>to verify that</u> the interiors of both alarm stations are not visible from the perimeter of the protected area	A report exists and concludes that t <u>T</u> he as-built central and secondary alarm stations are located inside the protected area, and the interiors of both alarm stations are not visible from the perimeter of the protected area.
1.1 <u>3</u> 4	The alarm system does not allow the status of a detection point, locking mechanism or access control device to be changed without the knowledge and concurrence of the alarm station operator in the other alarm station.	Tests, inspections, or a combination of tests and inspections of intrusion detection equipment and access control equipment will be performed.	A report exists and concludes that the as built <u>The</u> alarm system <u>will_does</u> not allow the status of a detection point, locking mechanism or access control device to be changed without the knowledge and concurrence of the alarm station operator in the other alarm station.
<u>1.14</u>	Intrusion detection and assessment systems are designed to provide visual display and audible annunciation of alarms in both the central and secondary alarm stations.	Intrusion detection and assessment systems will be tested.	The intrusion detection systems provide a visual display and audible annunciation of all alarms concurrently in at least two onsite alarms stations (central and secondary alarm stations).



	Commitment	Inspections, Tests, Analyses	Acceptance Criteria
1. <u>15</u> 7	<u>The Ss</u> econdary security power supply system for alarm annunciator equipment and non-portable communications equipment is located within a vital area.	The secondary security power supply system will be inspected.An inspection will be performed to ensure that the location of the secondary security power supply system for alarm annunciator equipment and non-portable communications equipment is within a vital area.	A report exists and concludes that t <u>T</u> he secondary security power system for alarm annunciator equipment and non-portable communications equipment is located within a vital area.
<u>1.16</u>	Nonportable communications equipment in the central and secondary alarm stations remains operable from an independent power source in the event of loss of normal power.	Tests, inspections, or a combination of tests and inspections of the nonportable communications equipment will be performed.	All nonportable communication devices (including conventional telephone systems) in the central and secondary alarm stations are wired to an independent power supply that enables those systems to remain operable (without disruption) during the loss of normal power.
1. <u>17</u> 8	Security alarm devices, including transmission lines to annunciators, are tamper- indicating and self-checking, (e.g. an automatic indication is provided when failure of the alarm system or a component occurs or when on standby power), and alarm annunciation indicates the type of alarm, (e.g., intrusion alarms, emergency exit alarm, etc.) and location.	Security alarm devices and transmission lines will be tested. A test will be performed to verify that security alarms including transmission lines to annunciators are tamper indicating and self-checking, (e.g. an automatic indication is provided when failure of the alarm system or a component occurs, or when on standby power) and that alarm annunciation indicates the type of alarm, (e.g., intrusion alarms, emergency exit alarm, etc.) and location.	A report exists and concludes that <u>s</u> ecurity alarm devices including transmission lines to annunciators are tamper- indicating and self-checking; (e.g., an automatic indication is provided when failure of the alarm system or a component occurs, or when the system is on standby power); and that-the alarm annunciation indicates the type of alarm, (e.g., intrusion alarms, emergency exit alarm, etc.) and location.



	Commitment	Inspections, Tests, Analyses	Acceptance Criteria
1. <u>18</u> 9	The security alarm system will-Intrusion detection systems recording equipment records each onsite security alarm annunciation including the location of the alarm, any false alarm, alarm check, and tamper indication by recording and the alarm-type of alarm, location, alarm circuit, location, date, and time.	The intrusion detection systems recording equipment will be tested. Tests will be performed to ensure that equipment is capable of recording each onsite security alarm annunciation including the location of the alarm, false alarm, alarm check, and tamper indication and the type of alarm, location, alarm circuit, date, and time.	A report exists and concludes that the security alarm system will record Intrusion detection systems recording equipment is capable of recording each onsite security alarm annunciation including the location of the alarm, any false alarm, alarm check, and tamper indication by recording and the alarm type of alarm, location, alarm circuit, location, date, and time.
1. <u>19</u> 40	Emergency exits through the vital area boundaries are alarmed with intrusion detection devices and secured by locking devices that allow prompt egress during an emergency.	Test <u>s</u> , inspection <u>s</u> , or a combination of tests and inspections will be performed to verify that of emergency exits through the vital area boundaries will be performed.are alarmed.	A report exists and concludes that eEmergency exits through the vital area boundariesy are alarmed with intrusion detection devices and secured by locking devices that allow prompt egress during an emergency.
1. <u>20</u> 11	<u>The Cc</u> entral and secondary alarm stations have conventional (land line) telephone service and other communication capabilities with <u>the control room and</u> local law enforcement authorities.	Test <u>s</u> , inspection <u>s</u> , or a combination of tests and inspections <u>of the central and</u> <u>secondary alarm stations'</u> <u>conventional (land line)</u> <u>telephone service</u> will be performed <u>.</u> to verify that the alarm stations are equipped with conventional (land line) telephone service and other capability to communicate with local law enforcement authorities.	A report exists and concludes that tThe central and secondary alarm stations are equipped with conventional (land line) telephone service and other capability to communicate with the control room and local law enforcement authorities.



	Commitment	Inspections, Tests, Analyses	Acceptance Criteria
1. <u>21</u> 12	The Ccentral and secondary alarm stations are capable of continuous communication with <u>on-duty</u> security <u>force</u> personnel.	Test <u>s</u> , inspection <u>s</u> , or a combination of tests and inspections <u>of the central and</u> <u>secondary alarm stations'</u> <u>continuous communication</u> <u>capabilities</u> will be performed <u>-</u> to verify that the alarm stations are equipped with the capability to continuously communicate with security officers, watchmen or armed response individuals, or other security personnel that have responsibilities during a contingency event.	A report exists and concludes that tThe central and secondary alarm stations are capable of continuous communication equipped with the capability to continuously communicate with on-duty watchmen, armed security officers, watchmen or armed respondsers individuals, or other security personnel who that have responsibilities within the physical protection program and during a contingency response events.





Report No. Date (See Notes 1, 2, Submitted **FSAR Section** Title to NRC and 3) Number(s) ANP-10287P Incore Trip Setpoint and Transient 11/27/07 4.3, 4.4, 7.1, 7.2, ANP-10287NP Methodology for U.S. EPR Topical 15.0, 15.1, Report 15.2, 15.3, 15.4, 15.6, 16 U.S. EPR Post-LOCA Boron 01/10 ANP-10288P 15 ANP-10288NP Precipitation and Boron Dilution Revision 1 Technical Report AREVA NP Environmental Report ANP-10290 9/11/09 19.2 Revision 1 Standard Design Certification ANP-10291P Small Break LOCA and Non-LOCA 5/09 15 ANP-10291NP Sensitivity Studies and Methodology Technical Report U.S. EPR Conformance with Standard ANP-10292 5/09 1.9 Revision 1 Review Plan (NUREG-0800) Technical Report U.S. EPR Design Features to Address ANP-10293. 3/11 6.3 and 15.6.5.4.3 Revision 3 GSI-191 Technical Report ANP-10294 U.S. EPR Reactor Coolant Pump Motor 3/09 5.4.1.6.6 Revision 1 Flywheel Structural Analysis Technical Report U.S. EPR Security Design Features_ ANP-10295P 13.6 10/0912/11 ANP-<u>10295NP</u> Technical Report Revision 3 ANP-10295 Revision 1 ANP-10296 U.S. EPR Design Features that Enhance 12/08 13.6 Security ANP-10299P Applicability of AREVA NP 6.2.1 and 6.2.25 12/09 Containment Response Evaluation Revision 2 Methodology to the U.S. EPR for Large Break LOCA Analysis, including Supplement 1, August 2011. ANP-10304 1.9, 7.1, 7.2, 7.3, U.S. EPR Diversity and Defense in Depth 6/11 Assessment Technical Report Revision 4 7.8, 18.7, 19.1 ANP-10306P Comprehensive Vibration Assessment 12/09 3.9.2.1.1, 3.9.2.3, Program for U.S. EPR Reactor Internals 3.9.2.4, and 3.9.2.7 Technical Report

Table 1.6-1—Reports Referenced Sheet 2 of 5



Vital Area is the Protected Area boundary which is described by the COL applicant in the site-specific PSP. The second substantial boundary is the Vital Area boundary. The description of the Vital Area boundary, and minimum separation between Vital Area and Protected Area boundary, can be found in Section 1.0 of Technical Report ANP-10295<u>P.</u>, "U.S. EPR Security Features." The COL applicant will describe the Protected Area boundary in the site-specific PSP.

- 4. Physical barriers for Protected Area perimeter are not also part of Vital Area boundary. The COL applicant will demonstrate that the Protected Area boundary is separate from the Vital Area boundaries in the site-specific PSP.
- 5. Isolation zones are maintained in outdoor areas adjacent to the Protected Area boundary which permits observation of 20 feet on either side of the boundary. Where permanent buildings do not allow a 20 foot observation distance on the inside of the Protected Area, the building walls are immediately adjacent to, or an integral part of, the Protected Area barrier. The COL applicant will describe the Isolation Zones in the site-specific PSP.
- 6. The external walls, doors, windows, ceiling, and floors in the main control room, central alarm station, secondary alarm station, and the last access control function for access to the Protected Area and between [CAS] and [SAS] are bullet resistant to at least an Underwriter's Laboratories Inc. (UL) Ballistic Standard 752, "The Standard of Safety for Bullet-Resisting Equipment," Level 4 round (UL 752 Level 4 round). Descriptions of the applicable sections of walls, floors and ceilings of the main control room, central alarm station, and secondary alarm station as well as the minimum concrete thickness for bullet resistance to a UL 752 Level 4 round are found in Section 3.0 of Technical Report ANP-10295P., "U.S. EPR Security Features." Doors into the main control room, central alarm station, and secondary alarm station, and secondary alarm station are UL rated asbullet resistant to at a least a UL 752 Level 4 round. The interior of the central alarm station and secondary alarm station cannot be observed from the Protected Area perimeter.
- 7. The walls, ceiling, and floor of the last access control function for access to the Protected Area are commensurate with the minimum concrete thickness listed in Section 3.0 of Technical Report ANP-10295<u>P., "U.S. EPR Security Features."</u> Doors and windows into the last access control function for access to the Protected Area are <u>UL rated asbullet</u> resistant to at a least a <u>UL 752</u> Level 4 round. <u>The COL applicant will demonstrate that the last access control function is resistant to at a least a UL 752 Level 4 round.</u>
- 8. The secondary alarm station will be functionally equivalent to the central alarm station. The central alarm station and the secondary alarm station will be protected, designed, and equipped to equivalent standards.

13.6.2 Security Power System

 The secondary security power supply system for alarm annunciator equipment and non-portable communications equipment is located within a Vital Area. The description of the Security Power System can be found in Section 2.0 of Technical Report ANP-10295<u>P.</u>, "U.S. EPR Security Features."



13.6.3 Security Detection, Surveillance and Lighting

- 1. The intrusion detection system detects penetration or attempted penetration of the Protected Area barrier. Detection is defined as the generation of an alarm in the security alarm station. Performance testing of installed equipment is conducted to assure detection in not less than 96% of the attempts (48 of 50 attempts).
- 2. Exterior areas within the Protected Area are illuminated to 0.2 foot-candles where necessary to permit observation and detection. The exterior lighting is provided by offsite power and backed by a highly reliable onsite generator which starts upon loss of offsite power. The description of the Security Power System can be found in Section 2.0 of Technical Report ANP-10295<u>P.</u>, <u>"U.S. EPR Security Features."</u>

13.6.4 Security Alarm System

- 1. The Security Computer System is a subsystem of the Security System which interfaces with other security equipment and subsystems. The Plant Security Computer System provides complete alarm and event assessment software functionality for all security applications, access control, badging, personnel, security doors, Intrusion Detection System, complete biometric integration, historical, and reporting requirements.
- 2. The Security Computer System shall <u>provide concurrent visual displays and</u> <u>audible</u> annunciat<u>ione of</u> all alarms in both a continuously manned central alarm station (CAS) and in the continuously manned secondary alarm station (SAS), so that a single act cannot remove the capability of calling for assistance or otherwise responding to an alarm.
- 3. The Security Computer System shall employ tamper indicating and self-checking provisions to identify errant operation. Redundant CPUs shall be provided to ensure reliable system operation in the event of a single failure and during maintenance efforts on one of the processor systems. Each CPU monitors the status of the other and reports any errors detected. The automatic switchover logic is designed to avoid contention for master processor status.
- 4. The Plant Security Computer shall be located within a Vital Area; physical access to equipment shall be restricted to authorized personnel.
- 5. The Security Computer System has the capability to interface with individual video components and the distribution system.
- 6. Unoccupied Vital Areas are equipped with locks that can be locked and are alarmed with intrusion detection systems that annunciate in the central and secondary alarm stations upon intrusion into a Vital Area.
- 7. The security alarm system will record each onsite alarm annunciation including the location of each alarm, false alarm, alarm check, and tamper indication to include the type of alarm, location, alarm circuit, date, and time.



- 14. ANP-10295<u>P</u>, Revision <u>3</u>+, "U.S. EPR Security Design Features <u>Technical Report</u>," AREVA NP Inc., <u>October 2009December 2011</u>.
- 15. ANP-10296, Revision 0, "U.S. EPR Design Features that Enhance Security," AREVA NP Inc., December 2008.

