



Serial: RNP-RA/11-0100

NOV 23 2011

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/ RENEWED LICENSE NO. DPR-23

ANNUAL REPORT OF CHANGES TO OR ERRORS DISCOVERED
IN AN ACCEPTABLE LOSS-OF-COOLANT ACCIDENT EVALUATION
MODEL APPLICATION FOR THE EMERGENCY CORE COOLING SYSTEM

Ladies and Gentlemen:

In accordance with the provisions of the Code of Federal Regulations, Title 10, Part 50.46 (10 CFR 50.46), Carolina Power & Light Company (CP&L), now doing business as Progress Energy Carolinas, Inc., hereby submits the attached report of non-significant changes to and errors discovered in an acceptable Loss-of-Coolant Accident (LOCA) evaluation model (EM) for the Emergency Core Cooling System at the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2. The applicable LOCA EMs are referenced in the HBRSEP, Unit No. 2, Core Operating Limits Report. This submittal satisfies the 10 CFR 50.46(a)(3)(ii) requirement for annual reporting of LOCA EM changes for HBRSEP, Unit No. 2.

The last annual report was submitted to the Nuclear Regulatory Commission by letter dated November 29, 2010, covering changes through November 8, 2010. This annual report provides the changes covering the period of November 9, 2010 through November 14, 2011. The non-significant changes and error corrections are provided in Attachment I. The effects of these non-significant changes and error corrections on HBRSEP, Unit No. 2, peak cladding temperature (PCT) estimates are also summarized in Attachment I.

The latest PCT estimates for the Large Break (LB) LOCA and Small Break (SB) LOCA are included in Attachment II.

This document contains no new Regulatory Commitments. If you have any questions, please contact me at (843) 857-1329.

Sincerely,

Richard Hightower
Supervisor – Licensing/Regulatory Programs

A002
NRR

United States Nuclear Regulatory Commission

Serial: RNP-RA/11-0100

Page 2 of 2

RJR/rjr

Attachments:

- I. Report of Changes/Errors in Loss-of-Coolant Accident Evaluation Models for the Emergency Core Cooling System
- II. Peak Cladding Temperature Estimates

c: V. M. McCree, NRC, Region II
B. Mozafari, NRC Project Manager, NRR
NRC Resident Inspector, HBRSEP

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

**REPORT OF CHANGES/ERRORS IN LOSS-OF-COOLANT ACCIDENT
EVALUATION MODELS FOR THE EMERGENCY CORE COOLING SYSTEM**

This report provides an estimate of the effect on peak cladding temperature (PCT) of changes and error corrections in the Loss-of-Coolant Accident (LOCA) evaluation models (EMs) and EM applications for the Emergency Core Cooling System (ECCS) at the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2, covering the period of November 9, 2010 through November 14, 2011.

Large Break Loss-of-Coolant Accident (LBLOCA) Evaluation Model

CHANGED CONDITION	PCT IMPACT (°F)
One error was found in the Robinson LBLOCA analysis. The analysis model produces a non-physical event, the influx of liquid into the hot channel and surrounding 6 assemblies from the upper plenum.	0
Cumulative Impact	0

Small Break Loss-of-Coolant Accident (SBLOCA) Evaluation Model

CHANGED CONDITION	PCT IMPACT (°F)
No changes or errors	0
Cumulative Impact	0

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

PEAK CLADDING TEMPERATURE ESTIMATES

The current peak cladding temperature (PCT) estimates associated with Loss-of-Coolant Accident (LOCA) Emergency Core Cooling System (ECCS) evaluation models are listed below. These estimates include the cumulative effects of significant and non-significant error corrections and evaluation model changes through November 14, 2010.

<u>Event</u>	<u>PCT (°F)</u>
Large Break LOCA, ECCS Injection Mode	1820
Small Break LOCA, ECCS Injection Mode	1615