NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Entry
01	LICENSEE CODE (2)	M N M N P 1
	LICENSE NUMBER (3)	0 0 - 0 0 0 0 0 - 0 0
	LICENSE TYPE (4)	4 1 1 1 1
	CAT (5)	
CON'T 01	REPORT SOURCE (6)	L
	DOCKET NUMBER (7)	0 5 0 0 0 2 6 3
	EVENT DATE (8)	1 0 1 4 7 8
	REPORT DATE (9)	1 1 2 2 7 8

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 WHILE PERFORMING LOCAL LEAK RATE TEST THE "A" OUTBOARD MSIV, AO-2-86A WAS FOUND

03 LEAKING IN EXCESS OF THE TECHNICAL SPECIFICATION ACCEPTANCE CRITERIA (T.S. 4.7.A.2.f).

04 REDUNDANT ISOLATION VALVE LEAKING WITHIN ACCEPTANCE CRITERIA. TWO PREVIOUS

05 REPORTABLE EVENTS (AO 75-17, M-RO-77-24).

06

07

08

Line 09	
SYSTEM CODE (11)	C D
CAUSE CODE (12)	E
CAUSE SUBCODE (13)	B
COMPONENT CODE (14)	V A L V E X
COMP. SUBCODE (15)	F
VALVE SUBCODE (16)	D

(17) LER/RO REPORT NUMBER	
EVENT YEAR	7 8
	—
SEQUENTIAL REPORT NO.	0 2 3
	/
OCCURRENCE CODE	0 1
REPORT TYPE	T
	—
REVISION NO.	0

Field	Entry
ACTION TAKEN (18)	X
FUTURE ACTION (19)	Z
EFFECT ON PLANT (20)	Z
SHUTDOWN METHOD (21)	Z
HOURS (22)	0 0 0 0
ATTACHMENT SUBMITTED (23)	N
NPRD-4 FORM SUB. (24)	Y
PRIME COMP. SUPPLIER (25)	N
COMPONENT MANUFACTURER (26)	A 5 8 5

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 ATWOOD AND MORRILL COMPANY 18" Y TYPE GLOBE VALVE, DRAWING 20786-H. VALVE STEM WAS

11 BENT AND LOWER GUIDE RIB WORN. CAUSE OF BENT STEM UNKNOWN. VALVE STEM WAS REPLACED

12 AND LOWER GUIDE RIB REBUILT. SEATS LAPPED AND VALVE RETESTED SATISFACTORILY.

13

14

Line	Field	Entry
15	FACILITY STATUS (28)	H
	% POWER (29)	0 0 0
	OTHER STATUS (30)	NA
	METHOD OF DISCOVERY (31)	B
	DISCOVERY DESCRIPTION (32)	LOCAL LEAK RATE TESTING
16	ACTIVITY RELEASED (33)	Z
	CONTENT OF RELEASE (34)	Z
	AMOUNT OF ACTIVITY (35)	NA
	LOCATION OF RELEASE (36)	NA
17	PERSONNEL EXPOSURES NUMBER (37)	0 0 0
	TYPE (38)	Z
	DESCRIPTION (39)	NA
18	PERSONNEL INJURIES NUMBER (40)	0 0 0
	DESCRIPTION (41)	NA
19	LOSS OF OR DAMAGE TO FACILITY TYPE (42)	Z
	DESCRIPTION (43)	NA
20	PUBLICITY ISSUED (44)	N
	DESCRIPTION (45)	NA

NRC USE ONLY

7811280244

NAME OF PREPARER P. A. TOBIN

PHONE: 612/295-5151

GPO 917-926