



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

December 21, 2011

LICENSEE: FirstEnergy Nuclear Operating Company


FACILITY: Davis-Besse Nuclear Power Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON NOVEMBER 1, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND FIRSTENERGY NUCLEAR OPERATING COMPANY, CONCERNING REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE DAVIS-BESSE NUCLEAR POWER STATION, LICENSE RENEWAL APPLICATION (TAC. NO. ME4640)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of FirstEnergy Nuclear Operating Company (FENOC or the applicant) held a telephone conference call on November 1, 2011, to discuss and clarify the applicant's responses to the staff's requests for additional information (RAIs) concerning the Davis-Besse Nuclear Power Station, license renewal application.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a description of the staff concerns discussed with the applicant, a brief description of the status of the items is also included.

The applicant had an opportunity to comment on this summary.


Samuel Cuadrado de Jesus, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Number:50-346

Enclosures:
As stated

cc w/encls: Listserv

TELEPHONE CONFERENCE CALL
DAVIS-BESSE NUCLEAR POWER STATION
LICENSE RENEWAL APPLICATION

LIST OF PARTICIPANTS
NOVEMBER 1, 2011

PARTICIPANTS

AFFILIATIONS

Samuel Cuadrado de Jesús

U.S. Nuclear Regulatory Commission (NRC)

John Klos

NRC

Naeem Iqbal

NRC

Cliff Custer

FirstEnergy Nuclear Operating Company (FENOC)

Steve Dort

FENOC

Allen McAllister

FENOC

Larry Hinkle

FENOC

John Hartigan

FENOC

REQUESTS FOR ADDITIONAL INFORMATION
DAVIS-BESSE NUCLEAR POWER STATION
LICENSE RENEWAL APPLICATION
NOVEMBER 1, 2011

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of FirstEnergy Nuclear Operating Company (FENOC or the applicant) held a telephone conference call on November 1, 2011, to discuss and clarify the following response to requests for additional information (RAI) concerning the Davis-Besse Nuclear Power Station (Davis-Besse) license renewal application (LRA).

10/7/2011 Supplemental Response to RAI 3.3.2.14-1

Discussion: The staff discussed with the applicant why the Davis-Besse fire water storage tank heat exchanger was removed from the scope of license renewal. The staff stated that the fire water storage tank heat exchanger and related equipment used to keep the fire water above the Davis-Besse Fire Hazards Analysis Report (FHAR) minimum temperature limit needs to be included in the scope of license renewal and subject to aging management. The applicant identified that the heat exchanger and tank recirculation equipment in question is credited with ensuring the appropriate initial conditions and, therefore, this equipment is not in scope.

Additionally, the applicant stated that NUREG-1800, "Standard Review Plan for Review of License Renewal Applications for Nuclear Power Plants," Revision 2, Section 2.1.3.1.3, "Regulated Events," page 2.1-8, specifically states that "an applicant need not consider hypothetical failures or second-, third-, or fourth-level support systems in determining the systems, structures and components within the scope of the rule under 10 CFR 54.4(a)(3)."

Action: Staff would review the response and the information discussed, and consider whether another RAI is necessary.

There was no further discussion, and the call was concluded.

December 21, 2011

LICENSEE: FirstEnergy Nuclear Operating Company

FACILITY: Davis-Besse Nuclear Power Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON NOVEMBER 1, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND FIRSTENERGY NUCLEAR OPERATING COMPANY, CONCERNING REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE DAVIS-BESSE NUCLEAR POWER STATION, LICENSE RENEWAL APPLICATION (TAC. NO. ME4640)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of FirstEnergy Nuclear Operating Company (FENOC or the applicant) held a telephone conference call on November 1, 2011, to discuss and clarify the applicant's responses to the staff's requests for additional information (RAIs) concerning the Davis-Besse Nuclear Power Station, license renewal application.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a description of the staff concerns discussed with the applicant, a brief description of the status of the items is also included.

The applicant had an opportunity to comment on this summary.

/RA/

Samuel Cuadrado de Jesús, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No.: 50-346

Enclosures:
As stated

cc w/encls: Listserv

DISTRIBUTION: See next page

ADAMS Accession No.: ML11348A021

*concurrence via email

OFFICE	LA:DLR*	PM:RPB1:DLR	BC:RPB1:DLR	PM:RPB1:DLR
NAME	SFiguroa	SCuadrado de Jesús	DMorey	SCuadrado de Jesús
DATE	12/20/11	12/21/11	12/21/11	12/21/11

OFFICIAL RECORD COPY

Memorandum to FirstEnergy Nuclear Operating Company from S. Cuadrado de Jesús dated December 21, 2011

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON NOVEMBER 1, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND FIRSTENERGY NUCLEAR OPERATING COMPANY, CONCERNING REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE DAVIS-BESSE NUCLEAR POWER STATION, LICENSE RENEWAL APPLICATION (TAC. NO. ME4640)

DISTRIBUTION:

E-MAIL:

PUBLIC

RidsNrrDir Resource
RidsNrrDirRpb1 Resource
RidsNrrDirRpb2 Resource
RidsNrrDirRarb Resource
RidsNrrDirRapb Resource
RidsNrrDirRasb Resource
RidsNrrDirRerb Resource
RidsNrrDirRpob Resource

PCooper
BHarris
SCuadrado
EMiller
MMahoney
ICouret, OPA
TReilly, OCA
BHarris, OGC