

Part 21 (PAR)

Event # 47521

Rep Org: EMERSON PROCESS MANAGEMENT	Notification Date / Time: 12/13/2011 16:55 (EST)
Supplier: EMERSON PROCESS MANAGEMENT	Event Date / Time: 10/13/2011 12:00 (CST)
	Last Modification: 12/13/2011
Region: 3	Docket #:
City: MARSHALLTOWN	Agreement State: Yes
County:	License #:
State: IA	
NRC Notified by: GEORGE BAITLINGER	Notifications: BILLY DICKSON R3DO
HQ Ops Officer: VINCE KLCO	PART 21 via email
Emergency Class: NON EMERGENCY	
10 CFR Section:	
21.21 UNSPECIFIED PARAGRAPH	

FISHER CONTROLS PART 21 NOTIFICATION INTERIM REPORT - POSSIBLE DISC PIN ISSUE ON A TYPE A11 BUTTERFLY VALVE

The following information was received by facsimile:

"Pursuant to 10 CFR 21.21(a)(2), Fisher Controls International, LLC ("Fisher") is providing the required written interim notification of a possible deviation or failure to comply. On October 13, 2011, Fisher became aware of a possible issue with the disc pin engagement of a 20" Type A11 Butterfly Valve, Serial Number 19102243. The affected valve was returned to Fisher for evaluation and correction and, upon correction, was returned to the customer [Clinton Power Station] on November 21, 2011.

"Fisher expects to complete its evaluation by January 31, 2012. At that time, if the evaluation reveals that a potential issue exists with the disc pin engagement, Fisher will issue a notification per the requirements of 10 CFR 21.21(b)."

IE19
NRR



Facsimile

301 South First Ave
Marshalltown, IA 50158

T

T 641-754-2688
F 641-754-2684

To: Vernon Hodge

Fax: 301-816-5151

From: Bill Fitzgerald □ VP Nuclear Business Unit

Date: 12/13/2011

Pages: 1
(incl cover)

Vernon

Original 10 CFR 21.21 (a)(2) Interim Notification is be sent out today by certified mail.
We will also send a copy by fax to 301-816-5151.

If you have any questions, please contact the following:

George Baitinger
QA Manager
641-754-2026

Thanks

Trish Crosser | Executive Assistant | Fisher Division
Emerson Process Management | 301 S. 1st Avenue | Marshalltown, Iowa 50158 | USA
T +1 641.754.2688 | F +1 641.754.2688
Trish.Crosser@Emerson.com



Facsimile

301 South First Ave
Marshalltown, IA 50158

T

T 641-754-2688
F 641-754-2684

To: Vernon Hodge

Fax: 301-816-5151

From: Bill Fitzgerald □ VP Nuclear Business Unit

Date: 12/13/2011

Pages: 1
(incl cover)

Vernon

Original 10 CFR 21.21 (a)(2) Interim Notification is be sent out today by certified mail.
We will also send a copy by fax to 301-816-5151.

If you have any questions, please contact the following:

George Baitinger
QA Manager
641-754-2026

Thanks

Trish Crosser | Executive Assistant | Fisher Division
Emerson Process Management | 301 S. 1st Avenue | Marshalltown, Iowa 50158 | USA
T +1 641.754.2688 | F +1 641.754.2688
Trish.Crosser@Emerson.com