

1

1

۱

SOARCA Seismic Issue

Briefing for M. Virgilio, DEDMRT Dec. 11, 2008

Background

- Sequences for Peach Bottom and Surry selected early 2007 briefed ACRS July 2007
- ACRS in an October 2008 meeting identified a potential LERF seismic event for Surry from NUREG-1150
 - SBO + LOCA + direct containment failure
 - In NUREG-1150, consequence analysis for this sequence was not reported because of uncertainty with comparison to non-nuclear seismic risks. Performed as a sensitivity calculation in NUREG/CR
- Sequence originally screened out, qualitatively, by project
 - Low frequency
 - High uncertainty (both seismic input and fragility input)
- First quantitative estimate in October at roughly 5x10⁻⁸, below our criterion
- Recent quantitative reassessment using updated seismic hazard curve (but old fragility estimates) suggests this sequence has a frequency of ~2x10⁻⁷ which meets screening criterion
- Questions remain on the state of quantification of the event
- How do we address?

Options

- Option 1 SECY and Exec Summary exclude sequence from SOARCA analysis, acknowledge existence but defer to future resolution in separate project (when better quantification is available)
 - No delay
 - Develop a separate seismic research program to address this longstanding issue
 - Investigate the recent Japanese seismic experience at the Kashiwazaki-Kariwa nuclear power plant
 - Impact of seismic on dual units
 - Develop seismic PRA guidance
- Option 2 SECY and full NUREG address event with expedited and limited update of fragility and seismic
 - Assessment of mitigation, accident progression and source term, and offsite consequences as necessary depending on outcome of seismic + fragility
 - Requires assessment of non-nuclear risks from seismic
 - Modest delay (~10 months)

Options (cont)

- Option 3 SECY and full NUREG address event rigorously both seismic hazard and plant specific fragility for LOCA and containment failure
 - Assessment of mitigation, accident progression and source term and offsite consequences as necessary
 - Requires assessment of non-nuclear risks from seismic
 - Potentially lengthy delay (2 yrs?)
- Option 4 Assume worst case and calculate the consequences for the event
 - Assessment of mitigation, accident progression and source term and offsite consequences as necessary
 - Requires assessment of non-nuclear risks from seismic
 - Delay of approximately 1 year

Option 1 – SECY w/Executive Summary

• Pros

- No delay
- Seismic event is highly uncertain
 - Seismic hazard curve
 - Fragility estimates
- GI-199 ongoing
- Near term resolution highly unlikely much work needed (Plant specific detailed seismic modeling is ultimately required, reconciliation of Japanese seismic experience for US plants) – methods must be developed
- Consistent with current PRA treatment (event not identified in Surry or Peach Bottom IPEEE)
 - No requirement for seismic PRA
- Consistent with SOARCA focus on mitigation extreme seismic event has little/no remedy
- Cons
 - Potential LERF event not analyzed
 - Potential conflict with ACRS, stakeholders

Option 1 – SECY w/Executive Summary (cont)

- Schedule
 - Provide SECY and Executive Summary to Commission in January 2009 to meet existing milestone to report results
 - Provide NUREG to Commission in April 2009
- Additional resources
 - Address long-standing seismic issue in a separate research program
- Staff recommend this option

Option 2 – Quick Reassessment of Large Seismic Event

• Pros

- Provides updated estimate for the frequency of this event, an updated look at seismic and fragility which is needed
- If frequency determined to be sufficiently high, analysis of event would then provide bound on consequences
- More complete picture of risk provided/quantified
- Less potential for ACRS conflict
- Cons
 - Long-standing issue; quick reassessment not likely to be dispositive or demonstrably "realistic"
 - Tendency toward conservatism in "quick reassessment" when data or methods are lacking (this is a "con" which is not unique to this issue)
 - Difficulty in assessing non-nuclear seismic risk; masonry buildings
 - Several month delay in SOARCA
 - Highlight on EP without rigorous quantification (if event is ultimately screened-in)
 - Quick reassessment may be subject of strong criticism if event is ultimately screened out
 - Will need to include source term from spent fuel pool and ISFSIs failures

Option 2 – Quick Reassessment of Large Seismic Event

- Schedule
 - Provide SECY and NUREG to Commission in late 2009
- Resources
 - Updated seismic and fragility estimates 10 staff-months
 - Integrating seismic and structural information to develop new seismic event CDFs 5 staff-months
 - Assessment of direct offsite health consequences of earthquake (collapse of office buildings and schools) – 2 staff-months, ~\$200k contractor support
 - If screened in, mitigation review, accident progression and consequence analyses, documentation – 6 staff months, ~\$250k contractor support
- Communication Issues (for Options 2, 3, and 4)
 - Licensees
 - Need time to let them respond (new seismic event identified)
 - SOARCA Steering Committee, ACRS, Commission TAs

Option 3 – Detailed Reassessment of Large Seismic Event

• Pros

- Provides modern/updated assessment of seismic risk
- More comparable in analytical quality to assessment of internal events
- Would provide basis for updating EE PRA methods /standards
- Technical basis for new regulatory requirements

Cons

- Longstanding issue; significant uncertainties in event frequency and fragility will remain
- Extent of uncertainty will depend on analyses/expert elicitation
- Difficulty in assessing non-nuclear seismic risk
- Problems similar to option 2 if screened out or screened in
- If screened out skepticism (though less than option 2)
- If screened in emphasis on EP, Commission policy (greater than option 2)
- Focus of SOARCA activities and report will be radically altered, focus will be shifted to low frequency/ end-of-spectrum seismic event with limited prospect of mitigation, still well below safety goal
- Emphasis by stakeholders will be on sequence which looks like 1982 study -SST1?
- Significant delay and cost
- Will need to include source term from spent fuel pool and ISFSIs failures

Option 3 – Detailed Reassessment of Large Seismic Event

- Schedule
 - Provide NUREG to Commission TBD (2010?)
- Resources
 - Updated seismic and fragility estimates 2 staff-years
 - Integrating seismic and structural information to develop new seismic event CDFs – 2 staff-years, \$2 million for a seismic PRA
 - Assessment of direct offsite health consequences of earthquake (collapse of office buildings and parking garages) – 2 staffmonths, \$200k contractor support
 - Assessment of mitigation measures, accident progression, and source term, and offsite radiological consequences – 8 staffmonths and \$350k contract dollars
- Communication Issues (for Options 2, 3, and 4)
 - Licensees
 - Need time to let them respond (new seismic event identified)
 - SOARCA Steering Committee, ACRS, Commission TAs

Option 4 – Assume Worst Case: Calculate Consequences

- Pros
 - No perception of screening out a sequence that could be above the 1E-7 threshold
 - Highlights that seismic initiators are the dominant events
 - Focus PRA efforts on external events
- Cons
 - Counter to the SOARCA philosophy to use realistic estimates
 - Legitimizes a sequence that still has much uncertainty since last addressed in NUREG-1150 ~ 20 years ago
 - Old fragility estimates
 - The sequence becomes the focus of SOARCA results

Option 4 – Assume Worst Case: Calculate Consequences (cont)

• Schedule

- Provide NUREG to Commission TBD (Early 2010)

- Resources
 - Assessment of direct offsite health consequences of earthquake (collapse of office buildings and parking garages) – 2 staffmonths, \$200k contractor support
 - Assessment of mitigation measures, accident progression, and source term, and offsite radiological consequences – 8 staffmonths and \$350k contract dollars
- Communication Issues (for Options 2, 3, and 4)
 - Licensees
 - Need time to let them respond (new seismic event identified)
 - SOARCA Steering Committee, ACRS, Commission TAs

OFFICIAL USE ONLY - PREDECISIONAL INFORMATION

SOARCA Seismic Issue

Briefing for the Commissioners' Technical Assistants

OFFICIAL USE ONLY PREDECTISTIONAL INFORMATION

1

OFFICIAL USE ONLY PREDECISIONAL INFORMATION

Background

- Sequences for Peach Bottom and Surry selected early 2007 briefed ACRS July 2007
- ACRS in an October 2, 2008 public meeting identified a potential LERF seismic event for Surry from NUREG-1150
 - SBO + LOCA + direct containment failure
 - In NUREG-1150, consequence analysis for this sequence was not reported because of a lack of quantification of non-nuclear seismic risks necessary for comparison. Performed as a sensitivity calculation in NUREG/CR
- Sequence originally screened out, qualitatively, by project
 - Low frequency
 - Lack of current plant specific quantification for fragility
 - Lack of licensee analysis for identification / quantification
- First quantitative estimate in October at roughly 5x10⁻⁸, below our criterion
- Recent quantitative reassessment using updated seismic hazard curve (but old fragility estimates) suggests this sequence has a frequency of ~2x10⁻⁷ which meets screening criterion
- Questions remain on the state of quantification of the event
- How do we address?

OFFICIAL USE ONLY - PREDECISIONAL INFORMATION

OFFICIAL USE ONLY - PREDECISIONAL INFORMATION Path Forward

- Approach exclude sequence from SOARCA analyses, acknowledge existence but defer to future resolution in separate project (development of better quantification is needed)
 - No delay in analyses
 - Develop a separate seismic research program to address this long-standing issue
 - Investigate the recent Japanese seismic experience at the Kashiwazaki-Kariwa nuclear power plant
 - Develop seismic PRA guidance



OFFICIAL USE ONLY - PREDECISIONAL INFORMATION

Path Forward (cont)

- Advantages
 - No delay
 - Seismic event is poorly quantified
 - Seismic hazard curve
 - Fragility estimates
 - Individual ACRS members consented
 - GI-199 ongoing
 - Near term resolution highly unlikely much work needed (Plant specific detailed seismic modeling is ultimately required, reconciliation of Japanese seismic experience for US plants) – methods must be developed
 - Consistent with current PRA treatment (event not identified in Surry or Peach Bottom IPEEE)
 - No requirement for seismic PRA
 - Consistent with SOARCA focus on mitigation extreme seismic event has little/no remedy
- Disadvantages
 - Potential LERF event not analyzed
 - Potential conflict with some stakeholders

OFFICIAL USE ONLY - PREDECISIONAL INFORMATION

OFFICIAL USE ONLY - PREDECISIONAL INFORMATION

Other approaches considered

- Address event with expedited and limited update of fragility and seismic
- Address event rigorously both seismic hazard and plant specific fragility for LOCA and containment failure
- Assume worst case and calculate the consequences for the event

OFFICIAL USE-ONLY - PREDECUSIONAL INFORMATION

Summary

- Identification of potential large seismic event does not diminish the overall SOARCA messages
 - Sequences in the 10⁻⁵ to 10⁻⁷/reactor-year range can be mitigated by SAMGs, post-9/11 measures
 - Releases from sequences, assuming no mitigation, are small and delayed
 - Phenomena that resulted in large early release shown to be extremely unlikely or unfeasible
 - alpha-mode failure
 - direct containment heating
 - Releases from thermally induced steam generator tube rupture are small, due to subsequent hot leg and lower head failure

USE ONLY - PREDECISIONAL INFORMATION